

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of March' 2022

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
1	8	WTPL-ADANI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	AR Mode to be kept OFF for PID testing of polymer insulators.	1-Mar-22	9:00	20-Mar-22	17:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.	At a time only one A/R will be facilitated on 400KV-PUNE-GIS-PARLI-D/C or 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-D/C
2	9	WTPL-ADANI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	AR Mode to be kept OFF for PID testing of polymer insulators.	1-Mar-22	9:00	20-Mar-22	17:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.	At a time only one A/R will be facilitated on 400KV-PUNE-GIS-PARLI-D/C or 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-D/C
3	46	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1	D	For taking LR out of service	1-Mar-22	7:00	1-Mar-22	7:30		
4	47	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	For LR AMP	1-Mar-22	7:00	1-Mar-22	18:00		
5	48	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1	D	For taking LR into service	1-Mar-22	17:30	1-Mar-22	18:00		
6	57	POWERGRID_WRI	400KV IEPL-Warora & 400kV Warora-Wardha (MSETCL line)	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	1-Mar-22	7:00	15-Mar-22	18:00		SLDC STU MSETCL NOC to be taken by PGCIL . SLDC MH Consent is required.
7	66	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipments.	1-Mar-22	09:00	1-Mar-22	18:00	Annual Maintenance of Bay Equipments	
8	67	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1(ON TBC)	C	1) Capital overhauling and servicing of Mechanism Drive, SF6 gas monitoring assembly, Hydraulic pressure monitoring assembly and Poles and Interrupters. 2) Measurement of Timing, CRM and DCRM of CB. 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	1-Mar-22	08:00	15-Mar-22	18:00	During outage, HVDC ckt- 1 will be in service via TBC-2 and there will not be any power restriction on Bi pole. i.e. HVDC Pole-1 & 2.	
9	68	MSETCL	TIE BAY (405) OF PGCIL & ICT - 2 @ LAMBOTI	C	405-52 CB Y-Ph Pole servicing/overhauling.	1-Mar-22	10:00	5-Mar-22	18:00	Without load interruption, 400kv Lamboti-PGCIL Line will be in service via 406-52 Main CB	
10	69	MSETCL	400KV-BHUSAWAL-DEEPNAGAR-2	D	For replacement of Earth wire by OPGW by MTCIL	1-Mar-22	08:00	31-Mar-22	19:00	During work A/R should be in NON-AUTO mode	
11	70	MSETCL	400KV-BHUSAWAL-DEEPNAGAR-1	D	For replacement of Earth Wire by OPGW by MTCIL	1-Mar-22	08:00	31-Mar-22	19:00	During the work A/R should be required in NON-AUTO mode	
12	71	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	1-Mar-22	08:00	1-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
13	72	MSETCL	220KV-BOISAR-NALASOPARA-1	D	Only AR to kept off during outage, for OPGW wire stringing work	1-Mar-22	7:00	31-Mar-22	19:00	Permission for Auto Reclose to be kept in Non auto mode	
14	73	MSETCL	400KV-SSP-DHULE-MS-1	D	Online PID testing work, 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	1-Mar-22	09:00	31-Mar-22	17:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
15	74	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-22	09:00	31-Mar-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	
16	75	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing	1-Mar-22	09:00	15-Mar-22	17:00	PID testing	
17	76	MSETCL	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work	1-Mar-22	08:00	15-Mar-22	18:00	-	
18	77	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	PID Testing Auto-Reclose function to be out of service.	1-Mar-22	09:00	10-Mar-22	18:00	PID Testing Auto-Reclose function to be out of service.	
19	78	MSETCL	400KV-WARORA-CHANDRAPU-II-1	D	For PID testing work,shifting autoreclose switch to non auto mode	1-Mar-22	08:00	5-Mar-22	17:00	400kv chandrapur2-warora ckt 1 will be service	
20	79	MSETCL	400KV-WARORA-CHANDRAPU-II-2	D	For PID testing work,shifting autoreclose switch to non auto mode	1-Mar-22	08:00	5-Mar-22	17:00	400kv chandrapur2-warora ckt 2 will be service	
21	80	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-22	09:00	31-Mar-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	
22	81	MSETCL	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-22	09:00	5-Mar-22	18:00	--	
23	82	MSETCL	220KV-WARDHA-PUSAD-1	D	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard	1-Mar-22	08:00	31-Mar-22	18:00	Shifting of auto reclose switch to non auto mode	
24	83	MSETCL	400KV-SSP-DHULE-MS-2	D	Online PID testing work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	1-Mar-22	09:00	31-Mar-22	17:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
25	88	APML-ADANI	400KV/11.5KV TIRODA-ST-1	C	Bay equipment and Transformer Maintenance	2-Mar-22	8:00	3-Mar-22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
26	123	MSETCL	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	2-Mar-22	09:00	2-Mar-22	17:00	Line will charged through tie bay no 421.	
27	124	MSETCL	KARAD - 400KV - BUS 1	D	PID testing of 400 kV Bus-I 400 kV Bus-II & 400 kV TBC bus & 400 kV Gantry disc insulator string for checking healthiness of Insulator strings	2-Mar-22	10:00	17-Mar-22	18:00	PID Team Ogalewadi is available during March-22	
28	125	MSETCL	220KV-WARDHA-BADNERA-1	D	For Hot line Work, Replacement of R phase & B Phase string at Loc. no. 268, Shifting of auto reclose switch to non auto mode.	2-Mar-22	11:00	5-Mar-22	17:00	Shifting of auto reclose switch to non auto mode.	
29	155	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	AMP of Line /Bay Equipment/ Updating Siemens Distance Relay to Comply IEC61850 and Resolving Front Port Communication Issue of M1 Relay of Padghe Boisar Line at Padghe MSETCL SS.	3-Mar-22	8:00	3-Mar-22	17:00		
30	161	POWERGRID_WR1	132kV Bhugaon - Deoli & 132kV Pulgaon-Deoli (MSETCL line)	C	Loc. 03-04 MSEDCL Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	3-Mar-22	7:00	4-Mar-22	18:00		SLDC MH STU MSETCL NOC to be taken by PGCIL . SLDC MH consent
31	166	MEGPTCL	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV	D	Annual Maintenance of Bay Equipments.	3-Mar-22	09:00	3-Mar-22	18:00	Annual Maintenance of Bay Equipments.	
32	167	MSETCL	400KV-LONIKHAND-CHAKAN-1	D	Distance relay retrofitting under MTAMC project.	3-Mar-22	08:00	3-Mar-22	23:30	---	
33	168	MSETCL	400KV/220KV NEW KOYNA-ICT-2	C	R Ph. & B ph. Oil filtration work	3-Mar-22	08:00	5-Mar-22	18:00	Moisture content 2.9% in r.Ph. & 2.7% in B.Ph.	
34	169	MSETCL	220KV-NASIK-NAVSARI-1	D	Bay & line maint. & any abnormalities observed attending other works if any required to be carried out will be covered during this outage.	3-Mar-22	09:30	3-Mar-22	17:30	-	
35	174	APML-ADANI	400KV/11.5KV TIRODA-ST-2	C	Bay equipment and Transformer Maintenance	4-Mar-22	8:00	5-Mar-22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.	
36	212	MEGPTCL	Main Bay - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - Bus 1	D	Maintenance of Circuit Breaker.	4-Mar-22	09:30	4-Mar-22	14:30	Maintenance of Circuit Breaker.	
37	213	MSETCL	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	C	For replacement of damaged quadruple conductor span between 400kV Buscoupler & TBC of 400kV A Bus.	4-Mar-22	07:00	5-Mar-22	18:00	400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.	
38	214	MSETCL	KHARGHAR - 400KV - BUS 1	C	For replacement of damaged quadruple conductor span between 400kV Buscoupler & TBC of 400kV A Bus.	4-Mar-22	07:00	5-Mar-22	18:00	400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.	
39	215	MSETCL	400KV-WARORA-CHANDRAPUR-II-2	D	R Phase LINE CVT replacement by agency and Diagnostic testing work of CVT and Tan Delta of LINE /BUS CT isolator maintenance work etc	4-Mar-22	09:00	4-Mar-22	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.	
40	216	MSETCL	BUS COUPLER BAY - KORADI - 400KV - BUS 1 AND KORADI - 400KV - BUS 2 at Koradi - 400KV	C	Overhauling of CB Mechanism	4-Mar-22	09:00	8-Mar-22	18:00	Outages will be availed subject to weather conditions.	
41	217	MSETCL	220KV-NASIK-NAVSARI-2	D	Bay & line maint. & any abnormalities observed attending other works if any required to be carried out will be covered during this outage.	4-Mar-22	09:31	4-Mar-22	17:31	-	
42	249	MSETCL	400KV-BHUSAWAL-BABLESHWAR-1(ON TBC)	C	For CGL Circuit Breaker Overhauling work with the agency	5-Mar-22	08:00	12-Mar-22	18:00	.	
43	254	POWERGRID_WR2	BOISAR - 400KV - BUS 1	D	AMP works	6-Mar-22	9:00	6-Mar-22	17:30	PG-WR2-Boisar	Subjected to Maharashtra consent
44	256	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For AMP Work	6-Mar-22	8:00	6-Mar-22	18:00		SLDC MHPlease reschedule on 06.03.22 with MSETCL
45	263	MSETCL	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	6-Mar-22	09:00	31-Mar-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	
46	264	MSETCL	400KV-KARAD-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	6-Mar-22	09:00	31-Mar-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	
47	265	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	6-Mar-22	08:00	6-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
48	266	MSETCL	220KV-WARDHA-PUSAD-1	D	For Routine Maintenance Work	6-Mar-22	07:00	6-Mar-22	18:00	.	
49	267	MSETCL	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance, Diag. Testing.	6-Mar-22	10:00	6-Mar-22	18:00	---	
50	279	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	C	For SSN to DSN insulator string conversion at tower location no M/C-13,14,15 220kv CB overhauling work by agency	7-Mar-22	09:00	9-Mar-22	18:00	Other lines at 220 kV buscoupler & switch will be in service. Also 220 kV Talandje-Chikodi line will be in service Line is in charged condition from Mudshingi to Chikodi.	
51	305	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - BUS 1	C	Replacement of BUS 1 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	7-Mar-22	8:00	9-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL . SLDC MH consent is required. Not considered in studies. Shall be facilitated subject to feasibility studies on D-2.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
52	306	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-3	C	Replacement of BUS 1 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	7-Mar-22	8:00	9-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL , pantograph isolator of ckt 1 and 2 to be replaced, then why ckt 3, 4 outage needed. Not considered in studies. Shall be facilitated subject to feasibility studies on D-2.
53	307	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	C	Replacement of BUS 1 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	7-Mar-22	8:00	9-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL , pantograph isolator of ckt 1 and 2 to be replaced, then why ckt 3, 4 outage needed. Not considered in studies. Shall be facilitated subject to feasibility studies on D-2.
54	319	MSETCL	JEJURI - 400KV - BUS 1	D	Faulty Insulator string replacement, Annual Testing, Maintenance, CTR repairs work.	7-Mar-22	09:30	7-Mar-22	17:30	400/220/33kV 501MVA ICT-II & ICT-III will be in service through 400kV Main bus-II.	
55	320	MSETCL	220KV-BOISAR-BOISAR-M-1	D	PREMANSOON MAINTENANCE OF LINE & Bay strengthening work	7-Mar-22	09:00	7-Mar-22	17:00	PREMANSOON MAINTENANCE OF LINE & Bay strengthening work	
56	321	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	D	Maintenance of Circuit Breaker.	7-Mar-22	09:30	7-Mar-22	14:30	Maintenance of Circuit Breaker.	
57	322	MSETCL	400KV-PADGHE-NAGOTHANE-2(ON TBC)	C	1) Replacement of PG Isolator under LES scheme	7-Mar-22	09:00	10-Mar-22	19:00	1) 400kV Nagothane -2 in service through TBC 2) Hot line work for Hanger replacement 3) Agency will be present on site	
58	323	MSETCL	400KV-EKTUNI-BABLESHWAR-1	D	Replacement of damaged disc insulator, corona ring, damaged nut bolts,	7-Mar-22	09:00	7-Mar-22	18:00	400kV Bhabaleshwar ckt-II will be in service	Subject to generation at APML/Koradi II/Ratan India
59	324	MSETCL	400KV-EKTUNI-BABLESHWAR-1	D	CT, CB relay testing work & 29D & 29C Isolator repairing work and Line maintenance work	7-Mar-22	09:00	7-Mar-22	17:00	400kV Ektuni ckt II, 400kV Bhusawal, Dhule I&II and 400kV Aurangabad will be in service	Subject to generation at APML/Koradi II/Ratan India
60	325	MSETCL	Main Bay of 400KV-SOLAPUR-M-SOLAPUR-1 AND SOLAPUR-M - 400KV - BUS 2 @SOLAPUR-M - 400KV	C	406-52 CB Overhauling.	7-Mar-22	10:00	12-Mar-22	18:00	Without Load interruption, 400kV Lamboti-PGCIL Line will be in service via 405-52 Tie CB.	
61	326	MSETCL	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	7-Mar-22	09:00	7-Mar-22	17:00	Simultaneous outage is required on 403(Spare bay) at the same time for line CT testing work.	
62	327	MSETCL	Main Bay of 400KV-KUDUS-PADGHE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV	D	Simultaneous outage is required on 403(Spare bay) at the same time for line CT testing work.	7-Mar-22	09:00	7-Mar-22	17:00	Simultaneous outage is required on 402(Tie bay) at the same time for line CT testing work.	
63	328	MSETCL	400KV-PARLI-M-NANDED-2(ON TBC)	C	Overhauling of 400kV Circuit Breaker (CGL Make) of 400kV Girwali- Nanded (Kumbhargaoon) Ckt-2	7-Mar-22	09:00	12-Mar-22	18:00	-	
64	329	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	C	For SSN to DSN insulator string conversion at tower location no M/C-13,14,15 220kv CB overhauling work by agency	7-Mar-22	09:00	9-Mar-22	18:00	Other lines at 220 kV mudshingi s/s will be in service. Also 220 kV Talandge-Chikodi line will be in service Line is in charged condition from Mudshingi and on.	Duplicate entry
65	330	MSETCL	220KV-WARDHA-BADNERA-1	D	For replacement of PT selection relay	7-Mar-22	09:00	7-Mar-22	17:00	.	
66	331	MSETCL	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	7-Mar-22	09:00	12-Mar-22	18:00	--	
67	332	MSETCL	400KV-CHANDRAPUR-II-NANDED-2	D	For PID testing work, shifting autoreclose switch to non auto mode	7-Mar-22	08:00	17-Mar-22	17:00	400kv chandrapur-2-kumbhargaoon(Nanded) ckt 2 will be in service	
68	333	MSETCL	400KV-JAIGAD-NEW KOYNA-1	D	Hotline washing works	7-Mar-22	09:00	7-Mar-22	18:00	Only AR to be disable	
69	334	MSETCL	400KV-JAIGAD-NEW KOYNA-2	D	Hotline washing works	7-Mar-22	09:00	7-Mar-22	18:00	AR to be disabled	
70	335	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	D	For PID testing work, shifting autoreclose switch to non auto mode	7-Mar-22	08:00	17-Mar-22	17:00	400kv chandrapur-parli ckt 3 will be in service	
71	338	APML-ADANI	TIE BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV B/R 1 at TIRODA - 765KV	C	(705-52)CB Maintenance & Testing, Overall maintenance of breaker mechanism by OEM	8-Mar-22	8:00	9-Mar-22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.	
72	374	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2	D	Routine Maintenance & Diagnostic testing work .	8-Mar-22	09:00	8-Mar-22	17:00	Line will be charged through Tie CB 428.	
73	375	MSETCL	400KV-EKTUNI-BABLESHWAR-2	D	Replacement of damaged disc insulator, corona ring, damaged nut bolts,	8-Mar-22	09:00	8-Mar-22	18:00	400kV Ektuni-Bhabaleshwar ckt-I will be in service	Subjected to Generation at APML/Koradi-II/Amrawati.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
74	376	MSETCL	400KV-EKTUNI-BABLESHWAR-2	D	CT, CB relay testing work & 29D & 29C Isolator repairing work.	8-Mar-22	09:00	8-Mar-22	17:00	400kV Ektuni ckt 1400kV Bhasawal, Dhule I&II and 400kV Aurangabad will be in in service	Subjected to Generation at APML/Koradi-II/Amrawati.
75	377	MSETCL	TIE BAY OF 400KV-KALA-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	8-Mar-22	09:00	8-Mar-22	17:00	Simultaneous outage is required on 406(Spare bay) at the same time for line CT testing work.	
76	378	MSETCL	Main Bay - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - Bus 2	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	8-Mar-22	09:00	8-Mar-22	17:00	Simultaneous outage is required on 405(Tie bay) at the same time for line CT testing work.	
77	379	MSETCL	KHARGHAR - 400KV - BUS 1	D	Online Testing of ABB make 400kV Bus Bar	8-Mar-22	09:00	8-Mar-22	18:00	1) SE, TCC, Vashi instructed to test the 400kV Bus Bar System. 2) All feeders & its own protection will be in service. 3) No any load will be affected. 4) At the time of Bus Bar testing, NR make Busbar will be in service.	
78	380	MSETCL	KHARGHAR - 400KV - BUS 2	D	Online Testing of ABB make 400kV Bus Bar	8-Mar-22	09:00	8-Mar-22	18:00	1) SE, TCC, Vashi instructed to test the 400kV Bus Bar System. 2) All feeders & its own protection will be in service. 3) No any load will be affected. 4) At the time of Bus Bar testing, NR make Busbar will be in service.	
79	381	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	8-Mar-22	08:00	8-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
80	382	MSETCL	400KV-RGPPL-NEW KOYNA-1	D	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	8-Mar-22	08:00	9-Mar-22	18:00	--	
81	383	MSETCL	220KV-WARDHA-WARDHAM-1	D	Routine line maintenance work under LM SDs Wardha	8-Mar-22	08:00	8-Mar-22	18:00	NA	
82	384	MSETCL	400KV-KARAD-JAIGAD-1	D	Hotline washing works	8-Mar-22	09:00	9-Mar-22	18:00	AR to be disabled	
83	385	MSETCL	400KV-KARAD-JAIGAD-2	D	Hotline washing works	8-Mar-22	09:00	9-Mar-22	18:00	AR to be disabled	
84	400	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	routine maintenance	9-Mar-22	09:00	9-Mar-22	18:00		
85	401	MP_SLDC	220KV-PANDHURNA-MP-KALMESHVAR-MH	D	FOR LINE MAINTENANCE WORK	9-Mar-22	9:00	9-Mar-22	18:00		
86	423	RGPP	400kv BUS-1 SHUT DOWN, RGPP	D	Annual maintenance of bus side equipment, Suspension string replacement, Isolators PM and Earth switch replacement	9-Mar-22	9:00	12-Mar-22	18:00		SLDC MH consent. Pl explore on daily basis.
87	427	POWERGRID_WR1	400KV-KORADI-BHILAI	D	OUTAGE OF LINE FOR RECTIFICATION WORKS OF OPGW	9-Mar-22	8:00	9-Mar-22	18:00		
88	428	POWERGRID_WR1	400KV-KORADI-SATPURA	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW RECTIFICATION WORKS OF LINE KORADI-BHILAI	9-Mar-22	8:00	9-Mar-22	18:00		
89	434	POWERGRID_WR1	MAIN BAY-400KV-TARAPUR 3&4-PADGHE-1 at Padghe MH	D	AMP OF 400 KV Padghe Tarapur-1 Main Bay at Padghe MSETCL SS. 400 KV Padghe Tarapur 1 will be in service through TBC CB.	9-Mar-22	8:00	9-Mar-22	17:00		
90	442	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	9-Mar-22	08:00	9-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
91	443	MEGPCL	400KV-AKOLA (2)-NANDGAONPETH-2	D	Annual Maintenance of Line Equipment	9-Mar-22	09:00	9-Mar-22	18:00	Annual Maintenance of Line Equipment	
92	444	MSETCL	TIE BAY OF 400KV/220KV KUDUS-ICT-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	9-Mar-22	09:00	9-Mar-22	17:00	Simultaneously outage is required on 409(Spare Bay) for line CT testing work.	
93	445	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	9-Mar-22	09:00	9-Mar-22	17:00	Line will be charged through Main CB 429.	
94	446	MSETCL	Main Bay of 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	9-Mar-22	09:00	9-Mar-22	17:00	Simultaneously outage is required on 408(Tie Bay) for line CT testing work.	
95	447	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	routine maintenance	9-Mar-22	09:00	9-Mar-22	18:00	-	
96	448	MSETCL	220KV-PANDURNA-KALMESHVAR-1	D	Routine Maintenance & Dignostic testing work	9-Mar-22	09:00	9-Mar-22	17:00	NA	
97	449	MSETCL	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	routine maintenance	9-Mar-22	09:00	9-Mar-22	18:00	-	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
98	450	MSETCL	220KV-AURANGABAD-CHITEGAON-1	D	Battery replacement of distance protection relay	9-Mar-22	12:00	9-Mar-22	18:01	existing battery is weak hence needed to replace the new one.	
99	451	MSETCL	132KV-PENCH-MP-KANHAN-1	D	Routine Maintenance work.	9-Mar-22	09:00	9-Mar-22	17:00	NA	
100	489	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2	D	For CVT Testing	10-Mar-22	8:00	10-Mar-22	18:00		
101	490	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For AMP of Line Terminal equipments	10-Mar-22	8:00	10-Mar-22	18:00		
102	491	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - BUS 2	C	Replacement of BUS-2 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	10-Mar-22	8:00	12-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL, Not considered in study depend on D-2 feasibility study it will be facilitated after consent from SLDC MH
103	492	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#1	C	Replacement of BUS-2 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	10-Mar-22	8:00	12-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL, Not considered in study depend on D-2 feasibility study it will be facilitated after consent from SLDC MH
104	493	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#2	C	Replacement of BUS-2 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	10-Mar-22	8:00	12-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL, Not considered in study depend on D-2 feasibility study it will be facilitated after consent from SLDC MH
105	494	POWERGRID_WR1	MAIN BAY-400KV-TARAPUR 3&4-PADGHE-2	D	AMP OF 400 KV Padghe Tarapur-2 Main Bay at Padghe MSETCL SS. 400 KV Padghe Tarapur 2 will be in service through TBC CB.	10-Mar-22	8:00	10-Mar-22	17:00		
106	501	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware Tightening and Fitting Work.	10-Mar-22	09:30	10-Mar-22	18:30	-	
107	502	MSETCL	220KV-PARLI-OSMANABAD-M-1	D	Line Maintenance	10-Mar-22	09:30	10-Mar-22	17:30	-	
108	503	APTCL	400KV-AKOLA (2)-NANDGAONPETH-I	D	Routine Maintenance of 400kV RPL to Akola II Line I.	10-Mar-22	09:00	10-Mar-22	18:00	Routine Maintenance of 400kV RPL to Akola II Line I.	
109	504	MEGPTCL	765KV-TIRODA-KORADI-III-1	C	Annual Maintenance of line equipment and associated Reactor equipments at Koradi end and for LR (707-52LR) CB Maintenance & L/R CB SF6 gas leakage attending at Tiroda end.	10-Mar-22	08:00	12-Mar-22	18:00	Annual Maintenance of line equipment and associated Reactor equipments at Koradi end and for LR (707-52LR) CB Maintenance & L/R CB SF6 gas leakage attending at Tiroda end.	SLDC MH consent in view of Load/Generation, Tentative gen at Tiroda/Koradi-II. L/R is S/W, nldc consent line will be in service with out L/R. Plan in daily basis.
110	505	MSETCL	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Annual Maintenance work	10-Mar-22	09:00	10-Mar-22	18:00	Annual Maintenance work	
111	506	MSETCL	MAIN BAY (407) OF ICT-1 @ KUDUS	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	10-Mar-22	09:00	10-Mar-22	17:00	Simultaneously outage is required on 408(Tie Bay) for diagnostic testing of ICT-1.	
112	507	MSETCL	TIE BAY OF 400KV/220KV KUDUS-ICT-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	10-Mar-22	09:00	10-Mar-22	17:00	Simultaneously outage is required on Bay No 407(ICT-1 Main Bay) for diagnostic testing of ICT-1	
113	508	MSETCL	220KV-WARDHA-PUSAD-1	D	For Routine Maintenance Work	10-Mar-22	07:00	10-Mar-22	18:00	-	
114	509	MSETCL	132KV-DHARNI-NEPANAGAR-1	D	i)Routine Maintenance work, ii)Line Signature Work	10-Mar-22	10:00	10-Mar-22	16:00	-	
115	563	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	D	For taking LR out of service	11-Mar-22	7:00	11-Mar-22	7:30		
116	564	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	AMP and Relay testing works	11-Mar-22	7:00	11-Mar-22	18:00		
117	565	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	D	For taking LR into service	11-Mar-22	17:30	11-Mar-22	18:00		
118	577	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV	D	Upgradation of 400KV isolat ors 41589A,41589LR,41589L,41589FCS CAP1,41589FCS CAP2, 41589FCS Bypass arms from 40KA to 50KA under Substation package-SS11	11-Mar-22	8:00	18-Mar-22	18:00		
119	583	MSETCL	400KV-BABLESHWAR-PADGHE-1	C	Line maintenance work, CT, CB relay testing work, quarterly maintenance work	11-Mar-22	09:00	13-Mar-22	17:00	400kV Padghe II will be in in service	
120	584	MSETCL	400KV-BABLESHWAR-PADGHE-1	D	1) Relay Replacement work under MTAMC 2) Bay Maint work 3) PG Isolator Replacement work along with Hanger fixing by Hot line unit	11-Mar-22	09:00	11-Mar-22	20:00	1) Agency will be present on site 2) Hot line work for Hanger replacement	
121	585	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	D	Chemical washing	11-Mar-22	09:00	11-Mar-22	18:00	Chemical washing	
122	586	MSETCL	EKTUNI - 765KV B/R 1	D	To restore Rph unit of Bus Reactor in service.	11-Mar-22	10:00	11-Mar-22	18:00	Bus Reactor will be out of service	
123	587	MSETCL	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Annual Maintenance work	11-Mar-22	09:00	11-Mar-22	18:00	Annual Maintenance work	
124	588	MSETCL	400KV-KALWA-PADGHE-1	D	PID Testing Auto-Reclose function to be out of service.	11-Mar-22	09:00	19-Mar-22	18:00	PID Testing Auto-Reclose function to be out of service.	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
125	617	MSETCL	400KV-CHAKAN-PUNE-PG-1	D	Routine maintenance and testing activities.	12-Mar-22	08:00	12-Mar-22	18:00	---	
126	618	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	12-Mar-22	08:00	12-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
127	619	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	12-Mar-22	08:00	12-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
128	620	MSETCL	220KV-BOISAR-BOISAR-M-2	D	Bay Maintenance works	12-Mar-22	07:00	12-Mar-22	18:00	Bay Maintenance works	
129	638	MSETCL	400KV-PARLI-M-KARIAT-1	D	Fixing of bird diverter	13-Mar-22	09:00	13-Mar-22	18:00	Fixing of bird diverter	
130	639	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	13-Mar-22	08:00	13-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
131	640	MSETCL	400KV-RGPPL-NEW KOYNA-2	D	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	13-Mar-22	08:00	14-Mar-22	18:00	--	
132	641	APTCL	400KV-AKOLA (2)-NANDGAONPETH-2	D	Routine Maintenance of 400kV RPL to Akola II Line II.	13-Mar-22	09:00	14-Mar-22	18:00	Routine Maintenance of 400kV RPL to Akola II Line II.	Shall be facilitated subject to rescheduling of outage of 765KV-TIRODA-KORADI-III-2
133	642	MSETCL	220KV-BOISAR-NALASOPARA-1	D	PREMONSOON MAINTENANCE OF LINE	13-Mar-22	09:00	13-Mar-22	17:00	PREMONSOON MAINTENANCE OF LINE	
134	680	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - TRANSFER BUS	C	Replacement of AUXILIARY BUS Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	14-Mar-22	8:00	16-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL
135	681	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#1	C	Replacement of AUXILIARY BUS Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	14-Mar-22	8:00	16-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL
136	682	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#2	C	Replacement of AUXILIARY BUS Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	14-Mar-22	8:00	16-Mar-22	18:00		SLDC MH MSPGCL NOC to be taken by PGCIL
137	691	MEGPTCL	765KV-TIRODA-KORADI-III-2	C	Annual Maintenance of line equipment and associated Reactor equipments at Koradi end and for LR (704-52LR) CB Maintenance & L/R CB SF6 gas leakage attending at Tiroda end	14-Mar-22	08:00	15-Mar-22	22:00	Annual Maintenance of line equipment and associated Reactor equipments at Koradi end and for LR (704-52LR) CB Maintenance & L/R CB SF6 gas leakage attending at Tiroda end	SLDC MH consent in view of Load/Generation, Tentative gen at Tiroda/Koradi-II. Plane in daily basis and complete the work within 2 days due to approved no. of parallel corridor outages.
138	692	MSETCL	765KV/400KV EKTUNI-ICT-2	D	Diagnostic and Maintenance Work	14-Mar-22	10:00	14-Mar-22	18:00	765/400kV 1500MVA ICT-1 will be in service	Shall be facilitated subject to rescheduling of outage of 400KV-AKOLA (2)-NANDGAONPETH-2
139	693	MSETCL	400KV-KARAD-JAIGAD-2(ON TBC)	C	Overhauling of GE make CB in presence of GE Service Engineer. CB is not overhauled since commissioning i.e. from 2010.Line to be in service through TBC	14-Mar-22	09:00	19-Mar-22	18:00	Load will be managed on other Jaigad Ckt-I	
140	694	MSETCL	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work under LM SDn Wardha	14-Mar-22	08:00	14-Mar-22	18:00	NA	
141	729	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	D	Bay AMP, Outage required on CB only. Bus reactor can be kept in service through TBC.	15-Mar-22	8:00	15-Mar-22	18:00		
142	730	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	D	AMP OF 400 KV Padghe Tarapur-1 Line Equipment/ CT Replacement at Padghe MSETCL SS. 400 KV Padghe Tarapur 1 will be out of service.	15-Mar-22	8:00	15-Mar-22	17:00		
143	734	MSETCL	400KV-BABLESHWAR-PADGHE-2	D	1) Replacement of PG Isolator 2) Replacement of Main line jumper of Yph CT 3) Bay maint work 4) MTAMC work	15-Mar-22	09:00	15-Mar-22	18:45	1) Hot line work for Hanger replacement 2) During Outage IPS tube will be removed and line will be charged on TBC for 29D isolator replacement 3) Agency will be present on Site	
144	735	MSETCL	400KV-BABLESHWAR-PADGHE-2	C	1) Replacement of 29D isolator 2) Replacement of PG Isolator	15-Mar-22	00:00	15-Mar-22	20:00	1) Hot line work for Hanger replacement 2) Agency will be present on site	Contingency plan in case of tripping of HVDC. Mumbai Load/Generation.
145	736	MSETCL	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	15-Mar-22	08:00	15-Mar-22	18:00	NA	
146	747	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	routine maintenance	16-Mar-22	09:00	16-Mar-22	18:00	-	
147	776	POWERGRID_WR1	400kV Koradi-PGCIL Wardha (MSETCL line)	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	16-Mar-22	7:00	23-Mar-22	18:00		SLDC MH STU MSETCL NOC to be taken by PGCIL
148	779	POWERGRID_WR1	220KV-SOLAPUR-KUMBARI-2	D	Line side equipments AMP	16-Mar-22	7:00	16-Mar-22	18:00		SLDC MH Please reschedule on 16.03.22
149	780	POWERGRID_WR1	220KV-AURANGABAD-SHENDRA-1	D	208L Bay AMP Works	16-Mar-22	7:00	16-Mar-22	18:00		
150	786	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Upgradation of 400KV isolators 41489A arms from 40KA to 50KA under Substation package-SS11	16-Mar-22	8:00	17-Mar-22	18:00		
151	787	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	D	Upgradation of 400KV isolators 41489A arms from 40KA to 50KA under Substation package-SS11 (new construction work)	16-Mar-22	8:00	17-Mar-22	18:00		

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
152	788	MSETCL	Main Bay - 400KV-Wardha-KORADI-II-1 AND Wardha - 400KV - Bus 1	D	Routine Maintenance & Diagnostic testing work .	16-Mar-22	09:00	16-Mar-22	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.	
153	789	MSETCL	KOLHAPUR - 220KV - BUS 2	D	1.Replacement of 400kV B Bus isolator of 400kV TBC 2. Chemical cleaning of Main Bus 2 insulator Strings	16-Mar-22	07:00	16-Mar-22	18:00	Monday is load staggering day in Kolhapur	Outage of 400 kV or 220 kV bus is required?
154	790	MSETCL	400KV-KARAD-KOLHAPUR-MS-2	D	400 kV TBC B bus isolator replacement work	16-Mar-22	07:00	16-Mar-22	18:00	Required Bay outage along with 400kV Main Bus -2 Outage for 400 kV TBC B bus isolator replacement work	
155	791	POWERGRID	400KV-KOLHAPUR-MS-SOLAPUR-2	D	400kV TBC B Bus isolator replacement work	16-Mar-22	07:00	16-Mar-22	18:00	Bay outage required along with 400kV Main Bus-2 outage for isolator replacement work	
156	792	MSETCL	400KV-WARDHA-KORADI-II-1	D	Line maintenance work	16-Mar-22	08:00	16-Mar-22	18:00	NA	
157	793	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND FUTURE at CHANDRAPUR-II - 400KV	D	Daignosis testing and allied bay maintenance work	16-Mar-22	10:00	16-Mar-22	18:00	Daignosis testing and allied bay maintenance work	
158	794	MSETCL	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Diagnostic testing work .	16-Mar-22	09:00	16-Mar-22	17:00	400 KV WARORA - DEOLI 2 Line is in ckt	
159	795	MSETCL	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	16-Mar-22	08:00	16-Mar-22	18:00	NA	
160	796	MSETCL	220KV-PARLI-PARLI-M-1	C	Line Maintenance	16-Mar-22	09:30	16-Mar-22	17:30	-	
161	797	MSETCL	220KV-MUDSHINGLI-CHIKKODI-II-1	D	routine maintenance	16-Mar-22	09:00	16-Mar-22	18:00	-	
162	798	MSETCL	132KV-MANSAR-MS-PENCH-1	D	Routine Maintenance work.	16-Mar-22	09:00	16-Mar-22	17:00	NA	
163	799	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	D	PID testing	16-Mar-22	09:00	31-Mar-22	17:00	PID testing	
164	800	MSETCL	400KV-BABLESHWAR-PADGHE-2	D	PID Testing work	16-Mar-22	08:00	31-Mar-22	18:00	-	
165	805	GETCO	400KV-SSP-DHULE-MS-1	D	PMM. Auto reclose of SSP -Dhule 2 will remain out.	17-Mar-22	8:00	17-Mar-22	18:00		
166	826	MSETCL	400KV-PARLI-M-PARLI-1	C	1) Main-1 distance relay testing work. 2) Bay maintenance work.	17-Mar-22	09:00	17-Mar-22	18:00	-	
167	827	MSETCL	220KV-TALEGAON-PUNE-PG-1	D	Half yearly maintenance, Diag. Testing .	17-Mar-22	10:00	17-Mar-22	18:00	---	
168	828	MSETCL	BABLESHWAR - 400KV - BUS 1	C	Permission to shift LBB protection wire from 400kV RADSS & 400kV ZIV Numerical Busbar .Bus Bar protection Out	17-Mar-22	08:00	18-Mar-22	18:00	outage required 400kV RADSS & 400kV Numerical Busbar@BBLR	130 PCM recommendations to be confirmed before availing the outage.
169	829	MSETCL	BABLESHWAR - 400KV - BUS 2	C	Permission to shift LBB protection wire from 400kV RADSS & 400kV ZIV Numerical Busbar .Bus Bar protection Out	17-Mar-22	08:00	18-Mar-22	18:00	outage required 400kV RADSS & 400kV Numerical Busbar@BBLR	130 PCM recommendations to be confirmed before availing the outage.
170	830	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	17-Mar-22	08:00	17-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
171	831	MSETCL	220KV-WARDHA-PUSAD-1	D	For Routine Maintenance Work	17-Mar-22	07:00	17-Mar-22	18:00	.	
172	840	GETCO	400KV-SSP-DHULE-MS-2	D	PMM. Auto reclose of SSP -Dhule 1 will remain out.	18-Mar-22	7:00	18-Mar-22	18:00		
173	841	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	For Isolator Servicing	18-Mar-22	6:00	18-Mar-22	18:00	PG-WR2-Boisar	SLDC MH Please reschedule on 18.03.22
174	842	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For Isolator Servicing	18-Mar-22	6:00	18-Mar-22	10:00	PG-WR2-Boisar	SLDC MH Please reschedule on 18.03.23
175	843	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-NALASOPARA-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For Isolator Servicing	18-Mar-22	10:00	18-Mar-22	14:00	PG-WR2-Boisar	SLDC MH Please reschedule on 18.03.24
176	844	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For Isolator Servicing	18-Mar-22	14:00	18-Mar-22	18:00	PG-WR2-Boisar	SLDC MH Please reschedule on 18.03.25
177	854	POWERGRID_WR1	220KV-AURANGABAD-CHITEGAON-1	D	207L Bay AMP Works	18-Mar-22	7:00	18-Mar-22	18:00		
178	856	MSETCL	400KV-LONIKHAND-PUNE-PG-1	D	Routine maintenance and testing activities.	18-Mar-22	08:00	18-Mar-22	18:00	---	
179	857	MSETCL	220KV-TILLARI-AMONA-1	D	routine maintenance	18-Mar-22	09:00	18-Mar-22	18:00	-	
180	864	POWERGRID_WR1	400kV D/C Wardha-Warora PG line	C	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme	19-Mar-22	7:00	31-Mar-22	18:00		SLDC MH STU MSETCL NOC to be taken by PGCIL. Double ckt outage 7, 765KV wardha-Aurangabad or wradha-warora D/c
181	870	MSETCL	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	C	For replacement of damaged quadruple conductor span between 400kV Buscoupler & TBC of 400kV B Bus.	19-Mar-22	07:00	20-Mar-22	18:00	400KV A Bus will be in service. All Lines & ICT's will be on A bus, load will be shifted via TBC.	Contingency plan/study result in case of tripping of other Bus. Mumbai Load/Generation.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
182	871	MSETCL	KHARGHAR - 400KV - BUS 2	C	For replacement of damaged quadruple conductor span between 400kV Buscoupler & TBC of 400kV B Bus.	19-Mar-22	07:00	20-Mar-22	18:00	400KV A Bus will be in service. All Lines & ICTs will be on A bus, load will be shifted via TBC.	Contingency plan/study result in case of tripping of other Bus. Mumbai Load/Generation.
183	872	MSETCL	400KV-WARDHA-WARORA-PG-1	D	1) Routine Maintenance & Diagnostic testing work.2) Repeat LINE CVT TAN DELTA Work. Replacement by agency if needed and Diagnostic testing work and isolater maintenance work etc	19-Mar-22	09:00	19-Mar-22	17:00	400KV WARORA-IEPL Line is in ckt	
184	873	MSETCL	400KV-PARLI-M-KARIAT-1	D	Hardware Tightening and Fitting Work.	19-Mar-22	09:30	19-Mar-22	18:30	-	
185	874	ATIL	400KV-TIRODA-WARORA-1	D	Shutdown required for Annual maintenance of transmission line.	19-Mar-22	08:00	19-Mar-22	18:00	Shutdown required for Annual maintenance of transmission line.	
186	875	ATIL	400KV-TIRODA-WARORA-2	D	AR to be kept OFF for safety purpose during 400KV-TIRODA-WARORA-1 outage.	19-Mar-22	08:00	19-Mar-22	18:00	AR to be kept OFF for safety purpose during 400KV-TIRODA-WARORA-1 outage.	
187	876	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	19-Mar-22	08:00	19-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
188	877	MSETCL	400KV-CHANDRAPUR-II-NANDED-1	D	For PID testing work,shifting autoreclose switch to non auto mode	19-Mar-22	08:00	26-Mar-22	17:00	400kv chandrapur2-kumbhargan(nanded) ckt 1 will be in service	
189	881	APML-ADANI	400KV/11.5KV TIRODA-ST-3	C	Bay equipment and Transformer Maintenance	20-Mar-22	8:00	21-Mar-22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.	
190	886	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	For Isolator Servicing	20-Mar-22	6:00	20-Mar-22	18:00	PG-WR2-Boisar	Kharghar Bus shutdown is also planned by MSLDC from 19 - 20. Boisar bus shutdown will be facilitated if Kharghar Bus outage is not availed.
191	887	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For Isolator Servicing	20-Mar-22	6:00	20-Mar-22	10:00	PG-WR2-Boisar	Kharghar Bus shutdown is also planned by MSLDC from 19 - 20. Boisar bus shutdown will be facilitated if Kharghar Bus outage is not availed.
192	888	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For Isolator Servicing	20-Mar-22	10:00	20-Mar-22	14:00	PG-WR2-Boisar	Kharghar Bus shutdown is also planned by MSLDC from 19 - 20. Boisar bus shutdown will be facilitated if Kharghar Bus outage is not availed.
193	889	POWERGRID_WR2	MAIN BAY - 220KV-TARAPUR 3&4-BOISAR-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For Isolator Servicing	20-Mar-22	14:00	20-Mar-22	18:00	PG-WR2-Boisar	Kharghar Bus shutdown is also planned by MSLDC from 19 - 20. Boisar bus shutdown will be facilitated if Kharghar Bus outage is not availed.
194	894	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTING AT KUDUS END.	20-Mar-22	8:00	20-Mar-22	17:00		SLDC Guj It shall be planned on Sunday or 18.03.22
195	897	MSETCL	765KV/400KV EKTUNI-ICT-1	D	Diagnostic and Maintenance Work	20-Mar-22	10:00	20-Mar-22	18:00	765/400kV 1500MVA ICT-II will be in service	
196	898	MSETCL	400KV-PARLI-M-KARIAT-2	D	Fixing of bird diverter	20-Mar-22	09:00	20-Mar-22	18:00	Fixing of bird diverter	
197	901	WTPL-ADANI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	Shutdown required for Annual maintenance of transmission line.	21-Mar-22	9:00	21-Mar-22	17:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.	
198	902	WTPL-ADANI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	AR to be kept OFF for safety purpose during 400KV Pune-GIS-Aurangabad(Waluj)-II outage.	21-Mar-22	9:00	21-Mar-22	17:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.	
199	941	MSETCL	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	D	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	21-Mar-22	08:00	21-Mar-22	18:00	400kV Main Bus I & II will be seperated.	
200	942	MSETCL	220KV-BOISAR-BOISAR-M-3	D	PREMONSOON MAINTENANCE OF LINE	21-Mar-22	13:00	21-Mar-22	17:00	PREMONSOON MAINTENANCE OF LINE	
201	943	MSETCL	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1	D	Diagnostic Testing & Routine Maintenance	21-Mar-22	10:30	21-Mar-22	18:00	240 MVAr Bus Reactor will be in service through its TIE (712) Bay.	
202	944	MSETCL	400KV/220KV PARLI-M-ICT-2(ON TBC)	C	Overhauling of 400kV Circuit Breaker (CGL Make) of 440/220kV, 315 MVA ICT-2 @ Girwali	21-Mar-22	09:00	26-Mar-22	18:00	-	
203	945	MSETCL	400KV-JAIGAD-NEW KOYNA-1(ON TBC)	C	C.B. Overhauling work Shitting on TBC	21-Mar-22	08:00	26-Mar-22	18:00	--	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
204	946	ATIL	400KV-TIRODA-WARORA-2	D	Shutdown required for Annual maintenance of transmission line.	21-Mar-22	08:00	21-Mar-22	18:00	Shutdown required for Annual maintenance of transmission line.	Subject to generation at APML/Tiroda.
205	947	ATIL	400KV-TIRODA-WARORA-1	D	AR to be kept OFF for safety purpose during 400KV-TIRODA-WARORA-2 outage.	21-Mar-22	08:00	21-Mar-22	18:00	AR to be kept OFF for safety purpose during 400KV-TIRODA-WARORA-2 outage.	
206	948	MSETCL	400KV-KALWA-PADGHE-2	D	PID Testing Auto-Reclose function to be out of service.	21-Mar-22	09:00	31-Mar-22	18:00	PID Testing Auto-Reclose function to be out of service.	
207	950	APML-ADANI	400KV/11.5KV TIRODA-ST-4	C	Bay equipment and Transformer Maintenance	22-Mar-22	8:00	23-Mar-22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.	
208	983	MSETCL	400KV-BABLESHWAR-PADGHE-2	C	Line maintenance work, CT, CB relay testing work, quarterly maintenance work	22-Mar-22	09:00	23-Mar-22	17:00	400kV Padghe I will be in in service	
209	984	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	D	PREMONSOON MAINTENANCE OF LINE & Bay Maintenance works.	22-Mar-22	09:00	22-Mar-22	17:00	PREMONSOON MAINTENANCE OF LINE & Bay Maintenance works.	
210	985	MSETCL	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	D	Diagnostic Testing & Routine Maintenance	22-Mar-22	10:30	22-Mar-22	18:00	i)1500 MVA ICT-II will be in service through its Main (713) Bay & Bus-II ii) 240 Mvar Bus Reactor will be in service through its Main (711) Bay & Bus-I.	
211	986	ATIL	Main Bay - 400KV-TIRODA-WARORA-1 AND WARORA - 400KV - Bus 1	D	Annual Maintenance of Bay Equipments	22-Mar-22	09:00	22-Mar-22	18:00	Annual Maintenance of Bay Equipments	
212	987	MSETCL	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	22-Mar-22	08:00	22-Mar-22	18:00	NA	
213	1018	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Annual Maintenance of Line Reactor Bay Equipment (Akola end)	23-Mar-22	08:30	23-Mar-22	15:30	Annual Maintenance of Line Reactor Bay Equipment (Akola end)	
214	1019	ATIL	Main Bay - 400KV-TIRODA-WARORA-2 AND WARORA - 400KV - Bus 1	D	Annual Maintenance of Bay Equipments	23-Mar-22	09:00	23-Mar-22	18:00	Annual Maintenance of Bay Equipments	
215	1020	MSETCL	220KV-PARLI-OSMANABAD-M-1	D	Line Maintenance	23-Mar-22	09:30	23-Mar-22	17:30	-	
216	1021	MSETCL	220KV-SOLAPUR-JEUR-1	D	Fixing of bird diverter	23-Mar-22	09:00	23-Mar-22	18:00	Fixing of bird diverter	
217	1022	MSETCL	132KV-MANSAR-MS-KANHAN-1	D	Routine Maintenance work.	23-Mar-22	09:00	23-Mar-22	17:00	NA	
218	1026	APML-ADANI	400KV/11.5KV TIRODA-ST-5	C	Bay equipment and Transformer Maintenance	24-Mar-22	8:00	25-Mar-22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.	
219	1058	POWERGRID_WR1	220kV Pusad-PGCIL Deoli & 220kV Bhugaon-PGCIL Deoli (MSETCL line)	D	Loc. 03 Wardha-Warora new tower erection for TL diversion works associated with Bus-splitting Scheme	24-Mar-22	6:00	30-Mar-22	18:00		Confirmation from STU not received by SLDC MH. MSLDC consent required for load management.
220	1062	POWERGRID_WR1	220kV Pusad-PGCIL Deoli & 220kV Bhugaon-PGCIL Deoli (MSETCL line)	C	Loc. 03-04 POWERGRID Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	24-Mar-22	7:00	25-Mar-22	18:00		Confirmation from STU not received by SLDC MH. MSLDC consent required for load management.
221	1070	MSETCL	KORADI-II - 400KV - BUS 1	D	DIAGNOSTIC TESTING BUS CVT OF MAIN BUS-1 AND ROUTINE MAINTENANCE WORK	24-Mar-22	10:00	24-Mar-22	15:00	ALL THE 400KV FEEDER WILL IN SERVICE THROUGH THEIR RESPECTIVE BAYS CONNECTED	In view of the outage on 40 0 kV IEPL Warora & 400 kV Wardha Warora.
222	1071	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	24-Mar-22	08:00	24-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
223	1072	MSETCL	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	24-Mar-22	08:00	24-Mar-22	18:00	NA	
224	1073	MSETCL	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance, Diag. Testing .	24-Mar-22	10:00	24-Mar-22	18:00	---	
225	1074	MSETCL	400KV-RGPPL-NAGOTHANE-1	D	earth wire Replacement and jumper tightening work	24-Mar-22	08:00	24-Mar-22	17:00	NA	
226	1075	MSETCL	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	24-Mar-22	09:00	29-Mar-22	18:00	--	
227	1076	MSETCL	400KV-KARIAT-LONIKHAND-II-2	D	DT & Line Maintenance.	24-Mar-22	08:00	24-Mar-22	18:00	---	
228	1116	MEGPTCL	KORADI-III - 400KV - BUS 1	D	Annual Maintenance of Bus Equipments.	25-Mar-22	09:00	25-Mar-22	18:00	Annual Maintenance of Bus Equipments.	
229	1117	MSETCL	PADGHE - 400KV - BUS 2	C	1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3) During Bus 2 outage 400 KV Kalwa -Padghe ckt-1 I/H/T for safety purpose. 6 hrs. 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole - 1 out durion BUS-2 outage. 6) HVDC-pole 2 out for safety purpose .Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV Nagaothane ckt-2	25-Mar-22	00:02	27-Mar-22	23:59	1) Hot line work for Jumper removing work 2) Agency will be present on site. 3) Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV Nagaothane ckt-2	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
230	1118	MSETCL	400KV-KALWA-PADGHE-1	C	1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3) During Bus 2 outag 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage. 6) HVDC-pole 2 out for safety purpose. Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV Nagothane ckt-2	25-Mar-22	8:00	27-Mar-22	13:30	safety purpose. Removing of Jumper of B Bus Section-4	
231	1119	MSETCL	400KV-KALWA-PADGHE-2	C	1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3) During Bus 2 outag 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage. 6) HVDC-pole 2 out for safety purpose .	25-Mar-22	00:02	27-Mar-22	23:59	Line will be in service through TBC	
232	1120	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3) During Bus 2 outag 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage. 6) HVDC-pole 2 out for safety purpose. Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV Nagothane ckt-2	25-Mar-22	22:00	27-Mar-22	23:59	HVDC pole -1 out during BUS-2 outage for 4 days	
233	1121	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	1) Replacement of B Bus Conductor by Partial Bus Outage 2) Replacement of PG Isolator 3) During Bus 2 outag 400 KV Kalwa -Padghe ckt-1 H/T for safety purpose. 6 hrs 4) During Bus 2 outage 400KV Kalwa-Padghe ckt-2 will be in service through TBC. 5.) HVDC pole -1 out durion BUS-2 outage. 6) HVDC-pole 2 out for safety purpose. Shifting below lines B-bus to ABus through TBC 400KV Tarapur -ckt 2 and 400KV Nagothane ckt-2	25-Mar-22	22:30	27-Mar-22	2:00	safety purpose. Removing of Jumper of B Bus Section-4. HVDC-pole 2 out for 5 hrs for safety purpose.	
234	1122	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	25-Mar-22	08:00	25-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
235	1123	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	D	1) C & tan delta measurement of reactor. 2) Bay maintenance work.	25-Mar-22	09:00	25-Mar-22	18:00	-	
236	1124	MSETCL	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	25-Mar-22	10:00	25-Mar-22	18:00	NA	
237	1125	MSETCL	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work, Routine Maintenance & Diagnostic testing work etc.	25-Mar-22	09:00	25-Mar-22	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 2 Bay no 416	
238	1157	MEGPTCL	KORADI-III - 400KV - BUS 2	D	Annual Maintenance of Bus Equipments.	26-Mar-22	09:00	26-Mar-22	18:00	Annual Maintenance of Bus Equipments.	
239	1158	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	Restoration Padghe BUS 2	26-Mar-22	22:00	27-Mar-22	2:00	Safety purpose. HVDC pole -2 Restoration Padghe BUS 2	
240	1159	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	26-Mar-22	08:00	26-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
241	1160	MSETCL	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	26-Mar-22	10:00	26-Mar-22	18:00	NA	
242	1177	MSETCL	KORADI - 400KV - BUS 2	D	CVT TAN Delta	27-Mar-22	06:00	27-Mar-22	18:00	Outages will be availed subject to weather conditions.	
243	1178	MSETCL	400KV-KALWA-PADGHE-1	D	Restoration Padghe BUS 2	27-Mar-22	8:00	27-Mar-22	13:30	safety purpose. Line H/T. Restoration Padghe BUS 2	
244	1179	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	27-Mar-22	08:00	27-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
245	1180	MSETCL	220KV-TALEGAON-PUNE-PG-1	D	Half yearly maintenance, Diag. Testing .	27-Mar-22	10:00	27-Mar-22	18:00	---	
246	1229	MSETCL	400KV-RGPPL-NAGOTHANE-2	D	cold washing and jumper tightening work	28-Mar-22	08:00	28-Mar-22	17:00	NA	
247	1230	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	C	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	28-Mar-22	08:00	29-Mar-22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	SLDC MH consent in view of Load/Generation, Tentative gen at Tiroda/Koradi-II/Ratan india
248	1231	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	C	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	28-Mar-22	08:00	29-Mar-22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	SLDC MH consent in view of Load/Generation, Tentative gen at Tiroda/Koradi-II/Ratan india
249	1232	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	D	PREMONSOON MAINTENANCE OF LINE	28-Mar-22	09:00	28-Mar-22	17:00	PREMONSOON MAINTENANCE OF LINE	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
250	1233	MEGPTCL	KORADI-III - 400KV - BUS 1	D	Annual Maintenance of Bus Equipments	28-Mar-22	09:00	28-Mar-22	18:00	Annual Maintenance of Bus Equipments	
251	1234	MSETCL	BABLESHWAR - 400KV - BUS 1	D	Bus CVT Testing work	28-Mar-22	09:00	28-Mar-22	18:00	All 400kV Bay and feeders will be shifted on 400kV Bus 2	shall be facilitated subject to Maharashtra demand
252	1235	MSETCL	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	28-Mar-22	09:00	31-Mar-22	18:00	--	
253	1260	POWERGRID_WR1	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Bay AMP Works	29-Mar-22	7:00	29-Mar-22	18:00		
254	1262	MSETCL	KOLHAPUR - 220KV - BUS 1	C	1. Annual Maintenance Work. 2. Chemical cleaning of Bus Insulators 3. C & Tan delta testing of Bus CVT	29-Mar-22	09:00	2-Apr-22	18:00	Annual Maintenance Work	
255	1263	MSETCL	220KV-BOISAR-BORIVALI-1	D	PREMANSOON MAINTENANCE OF LINE	29-Mar-22	09:00	29-Mar-22	17:00	PREMANSOON MAINTENANCE OF LINE	
256	1264	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	29-Mar-22	08:00	29-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
257	1265	MEGPTCL	KORADI-III - 400KV - BUS 2	D	Annual Maintenance of Bus Equipments	29-Mar-22	09:00	29-Mar-22	18:00	Annual Maintenance of Bus Equipments	
258	1298	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto	30-Mar-22	08:00	30-Mar-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	
259	1299	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Annual Maintenance of Line Equipment .	30-Mar-22	08:30	30-Mar-22	18:30	Annual Maintenance of Line Equipment .	
260	1300	MSETCL	220KV-PARLI-PARLI-M-2	C	Line Maintenance	30-Mar-22	09:30	30-Mar-22	17:30	-	
261	1311	MSETCL	400KV-SSP-DHULE-MS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	31-Mar-22	08:00	31-Mar-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	
262	1312	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	C	To attend the sag correction in tower no. 534, to stop the deforming of tower members in the first section.	31-Mar-22	08:00	31-Mar-22	18:00	To attend the sag correction in tower no. 534, to stop the deforming of tower members in the first section.	SLDC MH consent in view of Load/Generation, Tentative gen at Tiroda/Koradi-II/Ratan india
263	1313	MSETCL	NANDED - 400KV - BUS 1	D	Bus CVT Testing, Bus Isolator Maintenance & Relay Routine Testing.	31-Mar-22	10:30	31-Mar-22	18:00	-	

Outages not considered by WRPC OCCM for the Month of March' 2022

Sr.No.	OCCM Sr. No.	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
1	1203	MSETCL	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	All diagnostic testing work, Bay maintenance work.	19-Mar-22	08:00	19-Mar-22	18:00	All diagnostic testing work, Bay maintenance work.	Please plan in the next month due to number of outages in Mumbai area
2	1208	MSETCL	BOISAR-M - 220KV - BUS 1	C	Bus Maintenance works.	26-Mar-22	07:00	27-Mar-22	19:00	Bus Maintenance works.	In view of other approved outages in Mumbai area. Please plan in the next month.
3	1209	MSETCL	400KV-KALWA-PADGHE-2	D	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity. 2) CB, DCRM /Timing testing work at 400KV RS Kalwa	26-Mar-22	09:00	26-Mar-22	18:00	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity. 2) CB, DCRM /Timing testing work at 400KV RS Kalwa	In view of other approved outages in Mumbai area. Please plan in the next month.
4	1210	MSETCL	400KV-KALWA-PADGHE-1	D	1) Bay Maint work 2) Diagnostic Testing work 3) MTAMC work 4) Replacement of PG Isolator along with hanger	27-Mar-22	09:00	27-Mar-22	19:30	1) Hot line work for Hanger replacement 2) Agency will be present on site	In view of other approved outages in Mumbai area. Please plan in the next month.
5	1275	MSETCL	400KV-KALWA-PUNE-PG-1	D	Chemical cleaning of insulator strings.	19-Mar-22	08:00	19-Mar-22	18:00	—	Please plan in the next month due to number of outages in Mumbai area
6	1279	MSETCL	400KV-KALWA-PADGHE-1	D	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity 2) CB, DCRM /Timing testing work at 400KV RS Kalwa	27-Mar-22	09:00	27-Mar-22	18:00	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity 2) CB, DCRM /Timing testing work at 400KV RS Kalwa	In view of other approved outages in Mumbai area. Please plan in the next month.
7	1287	MSETCL	400KV-SSP-DHULEMS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSSNLL Ckt-2 A/R switch will be kept on non auto mode.	14-Mar-22	08:00	14-Mar-22	18:00	400KV SSSNLL Ckt-2 A/R switch will be kept on non auto mode.	Please plan in the next month due to number of outages from SSP
8	1317	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	Chemical cleaning of insulator strings.	19-Mar-22	08:00	19-Mar-22	18:00	—	Please plan in the next month due to number of outages in Mumbai area
9	1323	MSETCL	BOISAR-M - 220KV - BUS 2	C	Bay Maintenance works.	19-Mar-22	07:00	20-Mar-22	18:00	Bay Maintenance works.	Please plan in the next month due to number of outages in Mumbai area
10	1326	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	19-Mar-22	09:00	19-Mar-22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	Please plan in the next month due to number of outages in Mumbai area
11	1345	MSETCL	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT/ CT on delta, and, isolator maintenance work. 1-400KV MAIN BUS-2 WILL BE IN SERVICE 2-DURING OUTAGE REACTOR WILL IN OFF CONDITION	22-Mar-22	08:00	22-Mar-22	18:00	1-400KV MAIN BUS-2 WILL BE IN SERVICE 2-DURING OUTAGE REACTOR WILL IN OFF CONDITION	Please plan in next month due to approved outages at Wadga.
12	1351	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	C	1) Replacement of CB under LES scheme 2) Replacement of PG Isolator 3) Diagnostic Testing work 4) MTAMC work	23-Mar-22	09:00	1-Apr-22	20:00	1) Hot line work for Hanger replacement 2) agency will be present on site	Please plan in the next month due to number of outages in Mumbai area
13	1358	MSETCL	400KV-SSP-DHULEMS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSSNLL Ckt-2 A/R switch will be kept on non auto mode.	24-Mar-22	08:00	24-Mar-22	18:00	400KV SSSNLL Ckt-2 A/R switch will be kept on non auto mode.	Please plan in the next month
14	1363	MSETCL	400KV-KALWA-PUNE-PG-1	D	Chemical cleaning of insulator strings.	25-Mar-22	08:00	25-Mar-22	18:00	—	Please plan in the next month
15	1366	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Annual Maintenance of Line Equipment	31-Mar-22	08:30	31-Mar-22	18:30	Annual Maintenance of Line Equipment	Please plan in the next month
16	1367	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	Chemical cleaning of insulator strings.	26-Mar-22	08:00	26-Mar-22	18:00	—	Please plan in the next month due to number of outages in Mumbai area
17	1368	MSETCL	400KV-SSP-DHULEMS-1	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSSNLL Ckt-2 A/R switch will be kept on non auto mode.	27-Mar-22	08:00	27-Mar-22	18:00	400KV SSSNLL Ckt-2 A/R switch will be kept on non auto mode.	Please plan in the next month due to other approved outages in SSP
18	1370	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Annual Maintenance of Line Reactor Bay Equipment	31-Mar-22	08:30	31-Mar-22	15:30	Annual Maintenance of Line Reactor Bay Equipment	Please plan in the next month
19	1371	MSETCL	400KV-KALWA-PUNE-PG-1	D	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity.	27-Mar-22	09:00	27-Mar-22	18:00	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity.	Please plan in the next month due to number of outages in Mumbai area
20	1376	MSETCL	400KV-SSP-DHULEMS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSSNLL Ckt-1 A/R switch will be kept on non auto mode.	28-Mar-22	08:00	28-Mar-22	18:00	400KV SSSNLL Ckt-1 A/R switch will be kept on non auto mode.	Please plan in the next month due to other approved outages in SSP
21	1381	MSETCL	400KV-SSP-DHULEMS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSSNLL Ckt-1 A/R switch will be kept on non auto mode.	31-Mar-22	08:00	31-Mar-22	18:00	400KV SSSNLL Ckt-1 A/R switch will be kept on non auto mode.	Please plan in the next month due to other approved outages in SSP

State Element List for the month of March'2022

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	01-Mar-22	10:00	31-Mar-22	16:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Koradi-Bhusawal line shall be carried out by PID unit Akola.	MSETCL	MSETCL	PID will be carried out as per the weather condition & availability of PID unit Akola.
2	400 KV	DHULE- - BABLESHWAR - I	02-Mar-22	09:00	02-Mar-22	17:00	Daily	Main I and II relay and LBB testing,Relay testing work and quarterly maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule II,Aurangabad will be in in service
3	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	02-Mar-22	10:00	02-Mar-22	17:00	Daily	CTR Servicing, Maintenance Work	MSETCL	MSETCL	NA
4	400 KV	DHULE- - BABLESHWAR - II	03-Mar-22	09:00	03-Mar-22	17:00	Daily	LBB testing Relay testing work and quarterly maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I,Aurangabad will be in in service
5	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	03-Mar-22	09:00	03-Mar-22	18:00	Daily	SERGI Fire fighting Schem Overhauling and Servicing.	MSETCL	MSETCL	---
6	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	03-Mar-22	09:30	03-Mar-22	17:30	Daily	Faulty Insulator string replacement, Annual Testing, Maintenance, CTR repairs work.	MSETCL	MSETCL	400/220/33kV 501MVA ICT-II & ICT-III will be in service through 400kV Main bus-II.
7	400 KV	KHADKA-AURANGABAD	03-Mar-22	08:00	05-Mar-22	18:00	Daily	Replacement of Faulty Disc Insulator strings detected in MP	MSETCL	MSETCL	NIL
8	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALLUJ	04-Mar-22	10:00	04-Mar-22	18:00	Daily	1)Diagnostic Testing Work 2) Routine Maintenance Work	MSETCL	MSETCL	NA
9	400 KV	105 MVA SPARE ICT @ AKOLA	04-Mar-22	10:00	04-Mar-22	17:00	Daily	SFRA, Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	N.A.
10	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	04-Mar-22	10:00	04-Mar-22	18:00	Daily	Daignotic testing and allied bay maintenance work	MSETCL	MSETCL	Daignotic testing and allied bay maintenance work
11	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	05-Mar-22	09:00	05-Mar-22	18:00	Daily	Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 3, 4 will be in service
12	400 KV	PADGHE - NAGOTHANE CKT - 1	07-Mar-22	08:00	07-Mar-22	17:00	Daily	earth wire Replacement and jumper tightening work	MSETCL	MSETCL	NA
13	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	07-Mar-22	10:00	07-Mar-22	18:00	Daily	DIAGNOSTIC TESTING OF ICT-1	MSETCL	MSETCL	LOAD WILL SHIFTED TO 400/220/33KV ICT-2
14	400 KV	PADGHE - NAGOTHANE CKT - 2	08-Mar-22	08:00	08-Mar-22	17:00	Daily	cold washing and jumper tighting work	MSETCL	MSETCL	NA
15	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	08-Mar-22	09:00	08-Mar-22	18:00	Daily	1) C & tan delta measurement of CTs. 2) Bay maintenance work.	MSETCL	MSETCL	-
16	400 KV	125MVAr BUS REACTOR @ WARORA	08-Mar-22	09:00	08-Mar-22	17:00	Daily	Relay testing work, Routine Maintenance & Diagnostic testing work etc.	MSETCL	MSETCL	During outage reactor is in off condition
17	400 KV	400/220 KV 500 MVA ICT @ ALKUD	08-Mar-22	10:00	08-Mar-22	17:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Tuesday is load staggering day for Sangli district
18	400 KV	DHULE- - BABLESHWAR - I	08-Mar-22	08:00	08-Mar-22	18:00	Daily	Replacement of Suspicious faulty strings if found in PID testing	MSETCL	MSETCL	400KV Dhule-BBLR II to be kept on Non-auto Mode
19	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	08-Mar-22	10:00	08-Mar-22	18:00	Daily	Daignostc testing and allied bay maintenance work	MSETCL	MSETCL	Daignostc testing and allied bay maintenance work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	08-Mar-22	10:00	08-Mar-22	18:00	Daily	DIAGNOSTIC TESTING OF ICT-1	MSETCL	MSETCL	LOAD WILL SHIFTED TO 400/220/33KV ICT-2
21	400 KV	DHULE- - BABLESHWAR - II	09-Mar-22	08:00	09-Mar-22	18:00	Daily	replacement of suspicious faulty strings if found in PID testing	MSETCL	MSETCL	400KV Dhule-BBLR I is to be kept on Non-Auto mode
22	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	09-Mar-22	10:00	09-Mar-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
23	400 KV	125 MVAr BUS REACTOR @ TALANDGE	09-Mar-22	09:00	09-Mar-22	18:00	Daily	1.Annual Maintenance work 2. Annual Relay Testing work.	MSETCL	MSETCL	Annual Maintenance work
24	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	09-Mar-22	10:00	09-Mar-22	18:00	Daily	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
25	400 KV	KARAD - LONIKAND I	10-Mar-22	10:00	10-Mar-22	17:30	Daily	Half Yearly Bay Maintenance & DT work.	MSETCL	MSETCL	---
26	400 KV	KARAD - LONIKAND I	10-Mar-22	08:00	10-Mar-22	17:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
27	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	10-Mar-22	10:00	10-Mar-22	18:00	Daily	DIAGNOSTIC TESTING OF ICT-2	MSETCL	MSETCL	LOAD WILL SHIFTED TO 400/220/33KV ICT-1
28	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	10-Mar-22	09:00	10-Mar-22	18:00	Daily	SERGI Fire fighting Schem Overhauling and Servicing.	MSETCL	MSETCL	---
29	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	10-Mar-22	09:30	10-Mar-22	17:30	Daily	Annual testing, maintenance & CTR repairs work.	MSETCL	MSETCL	400/220/33kv 501MVA ICT-I & ICT-III will be in service.
30	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	10-Mar-22	10:00	10-Mar-22	18:00	Daily	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
31	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	10-Mar-22	10:30	10-Mar-22	18:00	Continuous	Replacement of Broken Vibration Damper by LMSD. Line CVT Testing & Bay maintenance. Relay Routine Testing.	MSETCL	MSETCL	-
32	400 KV	TBC @ WALUJ	11-Mar-22	10:00	11-Mar-22	18:00	Daily	1)Diagnostic Testing Work 2) Routine Maintenance Work	MSETCL	MSETCL	Outgae on 400kV TBC Bay@Waluj
33	400 KV	KHADKA - BABLESHWAR	11-Mar-22	09:00	12-Mar-22	17:00	Continuous	Line maintenance work, CT, CB relay testing work, quarterly maintenance work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Aurangabad, Dhule I&II will be in in service
34	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	11-Mar-22	10:00	11-Mar-22	18:00	Daily	DIAGNOSTIC TESTING OF ICT-2	MSETCL	MSETCL	LOAD WILL SHIFTED TO 400/220/33KV ICT-1
35	400 KV	KORADI - KHAPERKHEDA CKT - 2	11-Mar-22	09:00	11-Mar-22	18:00	Daily	CVT TAN Delta	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
36	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	11-Mar-22	10:00	11-Mar-22	18:00	Daily	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
37	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	12-Mar-22	09:00	12-Mar-22	18:00	Daily	Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 2, 3, 4 will be in service
38	400 KV	KHADKA - BABLESHWAR	14-Mar-22	08:00	17-Mar-22	18:00	Daily	Replacement of Faulty Disc Insulator strings detected in MP	MSETCL	MSETCL	NIL
39	400 KV	DEEPNAGAR - THAPTI TANDA	14-Mar-22	08:00	19-Mar-22	18:00	Daily	Replacement of Faulty insulator strings detected in PID & tightening of HW N/Bs detected in MP	MSETCL	MSETCL	NIL
40	400 KV	TBC @ BABHALESHWAR	14-Mar-22	08:00	14-Mar-22	18:00	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	PADGHE - NAGOTHANE CKT - 1	14-Mar-22	08:00	14-Mar-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA
42	400 KV	DHULE- - BABLESHWAR - I	15-Mar-22	08:00	15-Mar-22	18:00	Daily	Replacement of suspicious faulty strings if found in PID testing	MSETCL	MSETCL	400 KV Dhule-BBLR II is to be kept on Non-Auto mode
43	400 KV	WARORA - IEPL	15-Mar-22	09:00	15-Mar-22	17:00	Daily	1) Routine Maintenance & Diagnostic testing work. 2) Routine maintenance and diagnostic testing such as CVT/CT tan delta, and, isolater maintenance work	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL. Line is in ckt
44	400 KV	PADGHE - NAGOTHANE CKT - 2	15-Mar-22	08:00	15-Mar-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NIL
45	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	15-Mar-22	09:00	15-Mar-22	18:00	Daily	Hardware Tightening and Fitting Work.	MSETCL	MSETCL	-
46	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	15-Mar-22	10:00	15-Mar-22	18:00	Daily	Daignosis testing and allied bay maintenance work	MSETCL	MSETCL	Daignosis testing and allied bay maintenance work
47	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	16-Mar-22	10:00	16-Mar-22	18:00	Daily	400/220/33 KV 500 MVA ICT - 2 painting work	MSETCL	MSETCL	Without Load interruption. Load will be managed on ICT 1.
48	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	16-Mar-22	09:00	16-Mar-22	18:00	Daily	1) C & tan delta measurement of reactor. 2) Bay maintenance work.	MSETCL	MSETCL	-
49	400 KV	DHULE- - BABLESHWAR - II	16-Mar-22	08:00	16-Mar-22	18:00	Daily	Replacement of suspicious faulty strings if found in PID testing	MSETCL	MSETCL	400KV Dhule-BBLR I is to be kept on Non-Auto mode
50	400 KV	TIE BAY (415) OF KORADI CKT - 2 & STN TF 5A @ KHAPERKHEDA	16-Mar-22	10:00	16-Mar-22	17:00	Daily	IR values of LA	MSETCL	MSETCL	NA
51	400 KV	MAIN BAY 416 OF STN TF 5A @ 400 KV KHAPARKHEDA 2	16-Mar-22	10:00	16-Mar-22	17:00	Daily	IR values of LA	MSETCL	MSETCL	NA
52	400 KV	167 MVA SPARE ICT @ TALANDGE	16-Mar-22	09:00	16-Mar-22	18:00	Daily	Annual Maintenance work	MSETCL	MSETCL	Annual Maintenance work
53	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	17-Mar-22	09:00	17-Mar-22	18:00	Daily	SERGI Fire fighting Schem Overhauling and Servicing.	MSETCL	MSETCL	---
54	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	17-Mar-22	10:30	17-Mar-22	18:00	Continuous	Annual Tan-d testing of Bushings & Windings. Bay Maintenance & Relay routine testing.	MSETCL	MSETCL	-
55	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	17-Mar-22	09:00	17-Mar-22	18:00	Daily	Half Yearly Bay Maintenance & DT work.	MSETCL	MSETCL	---
56	400 KV	LONIKAND I - KOYNA STAGE-IV	17-Mar-22	08:00	17-Mar-22	18:00	Daily	DT & Line Maintenance.	MSETCL	MSETCL	---
57	400 KV	DHULE- - BABLESHWAR - I	17-Mar-22	08:00	17-Mar-22	18:00	Daily	Replacement of suspicious faulty string insulators if found in PID testing	MSETCL	MSETCL	400KV Dhule-BBLR II is to be kept on Non_Auto mode
58	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	18-Mar-22	10:00	18-Mar-22	18:00	Daily	400/220/33 KV 500 MVA ICT - 2 painting work	MSETCL	MSETCL	Without load interruption. Load will be managed on ICT 1
59	400 KV	DHULE- - BABLESHWAR - II	18-Mar-22	08:00	18-Mar-22	18:00	Daily	replacement of suspicious faulty strings if found in PID testing	MSETCL	MSETCL	400KV dhule-BBLR I is to be kept on Non-Auto mode
60	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	18-Mar-22	10:00	18-Mar-22	18:00	Daily	Daignosis testing and allied bay maintenance work	MSETCL	MSETCL	Daignosis testing and allied bay maintenance work
61	400 KV	GTR - 5 @ CHANDRAPUR SS	19-Mar-22	08:00	19-Mar-22	18:00	Daily	1) Measurement of Timing, CRM and DCRM of CB. 2) Maintenance and alignments of PG-1 and PG-2 Isolators.	MSETCL	MSETCL	During outage, GT-5 bay will be in service via TBC -2 bay CB. Only TBC-2 bay will not be available.

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
62	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END)	21-Mar-22	08:00	22-Mar-22	18:00	Continuous	1) For replacement of old M-1 & M-2 distance relays, 86 master trip relays under MTAMC project. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	MSETCL	MSETCL	During outage, outage 400KV CHANDRAPUR-1 - CHANDRAPUR-2 ckt. No.-2, 400KV Parli Ckt.-3, 400KV Chandrapur-Khaparkheda ckt., 400KV Chandrapur -PGCIL Bhadravati ckt. No.- 1, 2, 3 & 4 will be in service
63	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	21-Mar-22	08:00	31-Mar-22	18:00	Daily	Replacement of Faulty insulator strings detected in PID & replacement of Dead end & Mid Span Joints & Tightening of HW N/B detected in MP	MSETCL	MSETCL	NIL
64	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	22-Mar-22	10:00	22-Mar-22	17:00	Daily	Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	ICT-02 will be in service
65	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	22-Mar-22	09:00	22-Mar-22	18:00	DAILY	1) IV Backup relay & CTs Testing work. 2) Bay maintenance work.	MSETCL	MSETCL	-
66	400 KV	KORADI II - IEPL	22-Mar-22	08:00	22-Mar-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
67	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	22-Mar-22	08:00	24-Mar-22	18:00	Daily	Replacement of polymer insulator to antifog long rod porcelain insulator	MSETCL	MSETCL	Replacement of polymer insulator to antifog long rod porcelain insulator
68	400 KV	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	23-Mar-22	10:00	23-Mar-22	17:00	Daily	Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	Tie bay 403 will be in service
69	400 KV	PADGHE - NAGOTHANE CKT - 1	23-Mar-22	08:00	23-Mar-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NIL
70	400 KV	GT - 6 @ KORADI-I	23-Mar-22	09:00	23-Mar-22	18:00	Daily	DCRM, CRM, CB TIMING	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
71	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	24-Mar-22	08:00	25-Mar-22	18:00	Continuous	1) For replacement of old M-1 & M-2 distance relays, 86 master trip relays under MTAMC project. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	MSETCL	MSETCL	During outage, outage 400KV CHANDRAPUR-1 - CHANDRAPUR-2 ckt. No.-1, 400KV Parli Ckt.-3, 400KV Chandrapur-Khaparkheda ckt., 400KV Chandrapur -PGCIL Bhadravati ckt. No.- 1, 2, 3 & 4 will be in service
72	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	24-Mar-22	09:00	24-Mar-22	18:00	Daily	SERGI Fire fighting Schem Overhauling and Servicing.	MSETCL	MSETCL	---
73	400 KV	MAIN BAY - 405 OF PARLI (GIRWALI) CKT-2 @ NANDED	24-Mar-22	10:30	24-Mar-22	18:00	Daily	Replacement of Broken Vibration Damper by LMSD. Line CVT Testing & Bay maintenance. Relay Routine Testing.	MSETCL	MSETCL	-
74	400 KV	TIE BAY (403) OF ICT - 1 & AURANGABAD CKT - 1 @ AKOLA	24-Mar-22	10:00	24-Mar-22	17:00	Daily	Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	Main Bay 402 of ICT-01 & main bay 404 of Aurangabad Ckt 01 will be in service
75	400 KV	PADGHE - NAGOTHANE CKT - 2	24-Mar-22	08:00	24-Mar-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA
76	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	24-Mar-22	09:30	24-Mar-22	17:30	Daily	Annual testing, maintenance & CTR repairs work	MSETCL	MSETCL	400/220/33kV 501MVA ICT-I & ICT-II will be in service.
77	400 KV	LONIKAND I - KOYNA STAGE-IV	24-Mar-22	08:00	24-Mar-22	17:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
78	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	25-Mar-22	08:00	26-Mar-22	18:00	Continuous	MTAMC work and oltc overhauling work	MSETCL	MSETCL	-
79	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	25-Mar-22	10:00	25-Mar-22	17:00	Daily	Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	ICT-01 will be in service
80	400 KV	NEW KOYNA-KARAD CKT - 1	25-Mar-22	08:00	25-Mar-22	17:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
81	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	25-Mar-22	09:00	26-Mar-22	17:00	Continuous	Line maintenance work, Testing & verification of CVT, quarterly maintenance work	MSETCL	MSETCL	400kV Eknai ckt I&II,400kV Bhusawal, Dhule I&II will be in service
82	400 KV	CHANDRAPUR-PARLI CKT-3	25-Mar-22	08:00	27-Mar-22	18:00	Daily	Replacement of polymer insulator to antifog long rod porcelain insulator	MSETCL	MSETCL	Replacement of polymer insulator to antifog long rod porcelain insulator

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
83	400 KV	NEW KOYNA-KARAD CKT - 2	26-Mar-22	08:00	26-Mar-22	17:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
84	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	28-Mar-22	08:00	29-Mar-22	19:00	Continuous	1) For replacement of old REF relay & 86 master trip relays under MTAMC project. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators. 3) Servicing & maintenance of CTR make N2 injection fire protection and prevention system. 4) Applying of fire retardant cable coating to various control cables of ICT-1.	MSETCL	MSETCL	During Outage, ICT-2 and 220KV Chandrapur -2 ckt will be in service.
85	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	28-Mar-22	09:00	28-Mar-22	18:00	Daily	1. Pre monsoon Maintenance work 2. Coating of 33kV IPS Tube	MSETCL	MSETCL	Monday is load Staggering day in Kolhapur
86	400 KV	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	28-Mar-22	10:00	28-Mar-22	17:00	Daily	Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	Tie bay 406 will be in service
87	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	28-Mar-22	08:00	30-Mar-22	17:00	Daily	Replacement of polymer insulator to antifog long rod porcelain insulator	MSETCL	MSETCL	Replacement of polymer insulator to antifog long rod porcelain insulator
88	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	29-Mar-22	09:00	29-Mar-22	18:00	Daily	1) Winding resistance measurement ICT Units. 2) Bay maintenance work.	MSETCL	MSETCL	-
89	400 KV	MAIN BAY (401) OF 167 MVA SPARE ICT @ WARORA	29-Mar-22	07:00	29-Mar-22	17:00	Daily	Routine maintenance and diagnostic testing such as CT tan delta, and, isolator maintenance work	MSETCL	MSETCL	400/220/33KV SPARE ICT BAY NO 401 IS PRESENTLY OFF CONDITION (400/220/33KV SPARE ICT HANDOVER TO PADGHA))
90	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	29-Mar-22	08:00	29-Mar-22	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	--
91	400 KV	JAIGAD - NEW KOYNA CKT - 2	30-Mar-22	08:00	30-Mar-22	18:00	Daily	Diagnostic testing of CB work Shitting on TBC	MSETCL	MSETCL	--
92	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	30-Mar-22	08:00	31-Mar-22	18:00	Continuous	3) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators. 1) Servicing & maintenance of CTR make N2 injection fire protection and prevention system. 2) Applying of fire retardant cable coating to various control cables of ICT-1. 3) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	MSETCL	MSETCL	During Outage, ICT-1 and 220KV Chandrapur -2 ckt will be in service.
93	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	31-Mar-22	09:00	31-Mar-22	18:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---