

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDCC OCCM for the Month of MARCH' 2023

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
1	3	PLANNED	OCC_564	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-1	D	For shutdown of non switchable line reactor. Non-Switchable Reactor to be made switchable(New Construction Works)	1-Mar-23	07:00	1-Mar-23	12:00	For construction works at Parli SS
2	10	PLANNED	OCC_564	POWERGRID_WR1	WARDHA - 220KV - BUS 1	D	bus bar# 1 testing of main bay 210 (outage of 220kV Wardha Wardha (M) shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-1 (contruction	1-Mar-23	07:00	1-Mar-23	20:00	
3	11	PLANNED	OCC_564	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	bus bar# 1 testing of main bay 210 (outage of 220kV Wardha Wardha (M) shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-1 (contruction outage)	1-Mar-23	07:00	1-Mar-23	20:00	
4	24	PLANNED	OCC_564	MSLDC_OUTAGE	SOLAPUR-M - 400KV - BUS 2	D	For Jumpering between 409 CB bus II. On line trial for PCD on breaker 408/409 shunt reactor.	1-Mar-23	09:00	1-Mar-23	12:00	Planned outage
5	52	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-AKOLA (2)-NANDGAONPETH-1	D	For routine maintenance of 400kV RPL to Akola 2 Line 1.	1-Mar-23	08:00	1-Mar-23	18:00	For routine maintenance of 400kV RPL to Akola 2 Line 1.
6	53	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Badnera S/s	1-Mar-23	09:00	1-Mar-23	17:00	.
7	54	PLANNED	OCC_564	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	D	Testing of Metering CT	1-Mar-23	10:00	1-Mar-23	12:00	Testing of Metering CT
8	61	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-3	C	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.	1-Mar-23	08:00	4-Mar-23	18:00	400KV STN-3 load will be shifted on 400KV STN TF-4, 400KV STN TF-5 will be in service.
9	62	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	PID scanning of insulator strings	1-Mar-23	08:00	4-Mar-23	18:00	-
10	63	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Cold washing work	1-Mar-23	08:00	6-Mar-23	18:00	Planned outage
11	65	PLANNED	OCC_564	POWERGRID_WR1	TIE BAY - 765KV/440KV WARDHA-ICT-2 AND WARDHA - 400KV B/R 3 at Wardha - 400KV	C	For Replacement of BHEL CB with CGL CB	1-Mar-23	08:00	7-Mar-23	18:00	408
12	74	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	1-Mar-23	09:00	11-Mar-23	18:00	PID Testing of Insulators Auto-Reclose function to be out of service.
13	79	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID work	1-Mar-23	08:00	15-Mar-23	18:00	-
14	80	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	1-Mar-23	09:00	15-Mar-23	17:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower hence non auto reqired on both ckt.
15	81	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	1-Mar-23	09:00	15-Mar-23	17:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower hence non auto reqired on
16	136	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KOYNA STAGE IV- LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-23	08:00	31-Mar-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
17	137	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-23	08:00	31-Mar-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
18	138	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	Installation of OPGW on 400 kV Thapatitanda-Ektuni line	1-Mar-23	08:00	31-Mar-23	18:00	Work will be carried out by MTCIL
19	139	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	Installation of OPGW on 400 kV Thapatitanda-Ektuni line	1-Mar-23	08:00	31-Mar-23	18:00	Work will be carried out by MTCIL
20	140	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-1	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Mar-23	08:00	31-Mar-23	18:00	.
21	141	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-2	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Mar-23	08:00	31-Mar-23	18:00	.
22	142	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-PARLI-M-3	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Mar-23	08:00	31-Mar-23	18:00	.
23	143	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	A/R out of service for PID work	1-Mar-23	08:00	31-Mar-23	18:00	PID unit chandrapur reschedule the PID work in february - 2023 instead of
24	144	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	A/R out of service for PID work	1-Mar-23	08:00	31-Mar-23	18:00	PID unit chandrapur reschedule the PID work in february - 2023 instead of
25	146	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-23	09:00	31-Mar-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
26	147	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-23	09:00	31-Mar-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
27	148	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-23	09:00	31-Mar-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
28	149	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	On Line PID work	1-Mar-23	09:00	31-Mar-23	17:00	400 kV Dhule-BBLR ckr-1 A/R switch to be kept on Non auto mode.
29	150	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Mar-23	09:00	31-Mar-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
30	151	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline work	1-Mar-23	09:00	31-Mar-23	17:30	-

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
31	152	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	1-Mar-23	09:00	31-Mar-23	17:30	-
32	153	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	1-Mar-23	09:00	31-Mar-23	18:00	-
33	154	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	1-Mar-23	09:00	31-Mar-23	18:00	-
34	156	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	ON LINE PID work.	1-Mar-23	11:00	31-Mar-23	15:00	400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.
35	157	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	ON LINE PID WORK.	1-Mar-23	11:00	31-Mar-23	15:00	400 KV DHULE-SSNNL CKT 2 A/R switch to be kept on Non Auto mode.
36	158	PLANNED	OCC_564	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	C	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS- KOLHAPUR GIS-1	1-Mar-23	07:00	31-Mar-23	17:00	For Stringing of Kolhapur- Kolhapur#2, outage will require on Kolhapur- Mapusa#1
37	160	PLANNED	OCC_564	MSLDC_OUTAGE	CHANDRAPUR SWITCHING STATION - 400KV - BUS 2	D	Diagnostic testing work	1-Mar-23	08:00	1-Mar-23	18:00	
38	161	PLANNED	OCC_564	MSLDC_OUTAGE	WARORA - 400KV - BUS 2	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	1-Mar-23	08:00	1-Mar-23	18:00	
39	177	PLANNED	OCC_564	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	D	Bay ISO Copper contact cleaning work and Relay Testing Works.	2-Mar-23	07:00	2-Mar-23	18:00	
40	180	PLANNED	OCC_564	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	bus bar#2 testing of main bay 210(outage of 220kV Wardha bhugaon shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-1 (contruction outage)	2-Mar-23	07:00	2-Mar-23	20:00	
41	181	PLANNED	OCC_564	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	bus bar#2 testing of main bay 210(outage of 220kV Wardha bhugaon shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-1 (contruction outage)	2-Mar-23	07:00	2-Mar-23	20:00	
42	219	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work And For stringing between Loc No 12A to 13 of 220kV Deoli Ghatodi Line crossing overhead to 220kV Deoli(PGCIL)-Pusad Line and 220kV Deoli(PGCIL)-Bhugaon Line.	2-Mar-23	08:00	2-Mar-23	18:00	Work of stringing between Loc No 12A to 13 of 220kV Deoli Ghatodi Line crossing overhead to 220kV Deoli(PGCIL)-Pusad Line and 220kV Deoli(PGCIL)-Bhugaon Line will be supervised by project wing.
43	220	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work.	2-Mar-23	09:00	2-Mar-23	17:00	400KV WARORA-IEPL Line is in ckt
44	221	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Hardware tightening,cold line washing and string replacement	2-Mar-23	09:00	2-Mar-23	18:00	Load will be managed on 400kv karjat-parli ckt 2
45	222	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) Reactor testing work. (2) Bay maintenance work.	2-Mar-23	09:00	2-Mar-23	18:00	-
46	223	PLANNED	OCC_564	MSLDC_OUTAGE	CHANDRAPUR SWITCHING STATION - 400KV - BUS 1	D	Diagnostic testing work	2-Mar-23	10:00	2-Mar-23	18:00	Diagnostic testing work
47	232	PLANNED	OCC_564	RGPPPL	400KV-401-52B-Bay	C	ANNUAL BAY MAINTENANCE AND EQUIPMENT TESTING	2-Mar-23	08:00	4-Mar-23	18:00	MAINTENANCE OF EQUIPMENT AND SCHEDULE TESTING
48	233	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/220KV JEJURI-ICT-1	C	For Y ph oil filtration work	2-Mar-23	09:30	4-Mar-23	17:30	During outage ICT 2 & ICT 3 will be service.
49	234	PLANNED	OCC_564	POWERGRID_WR1	MAIN BAY - 400KV-KORADI- SATPURA-1 AND KORADI - 400KV - BUS 1 AT KORADI - 400KV at Koradi	C	Overhauling of SRN CGL CB at Koradi SS. Line to be shifted on TBC bay	2-Mar-23	08:00	6-Mar-23	18:00	SRN
50	235	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Overhead Hotline Stringing Work at section AP-117/0 to AP-118/0 of 765kV D/C Warora to Wargal transmission line (MH Portion) Auto Reclosed off Mode.	2-Mar-23	08:00	9-Mar-23	18:30	Overhead Hotline Stringing Work only shifting on Non Auto Mode both ckt is in service 1) 400 KV Warora-Warora PGCIL Nagri Ckt 2) 400kV Warora-IEPL Ckt
51	236	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-IEPL-WARORA-1	D	Overhead Hotline Stringing Work at section AP-117/0 to AP-118/0 of 765kV D/C Warora to Wargal transmission line (MH Portion) Auto Reclosed off Mode.	2-Mar-23	08:00	9-Mar-23	18:30	Overhead Hotline Stringing Work only shifting on Non Auto Mode both ckt is in service 1) 400 KV Warora-Warora PGCIL Nagri Ckt 2) 400kV Warora-IEPL Ckt
52	237	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	the outage is required for Non-Auto Mode and Overhead hotline stringing permission at section AP-117/0 to AP. Only AR will be kept off. Line to be in service	2-Mar-23	08:00	9-Mar-23	18:00	Only AR will be kept off. Line to be in service
53	238	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	2-Mar-23	11:00	31-Mar-23	15:00	.
54	240	PLANNED	OCC_564	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	For AMP works of LTE at Boisar PG end	3-Mar-23	09:00	3-Mar-23	17:30	PG-WR2-BOISAR
55	242	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Replacement of PID Suspecious Disc & other Maintenance work. 400 KV DHULE- SSNNL CKT 2 A/R switch to be kept on Non Auto mode.	3-Mar-23	08:00	4-Mar-23	18:00	
56	243	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	To complete Balance work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor, Hardware.	3-Mar-23	22:00	6-Mar-23	06:00	To complete Balance work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor. Hardware.
57	251	PLANNED	OCC_564	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	bus bar#1 testing of main bay 212 (outage of 220kV Wardha Wardha (M) shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-2 (contruction outage)	3-Mar-23	07:00	3-Mar-23	20:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
58	266	PLANNED	OCC_564	GETCO	400KV-SSP-DHULE-MS-1	D	Maintenance work. A/R of 400 kV SSP - Dhule - 2 will remain out	3-Mar-23	08:00	3-Mar-23	18:00	Non auto reclose code for 400KV SSP Dhule No 2
59	276	PLANNED	OCC_564	POWERGRID_WR2	BOISAR - 220KV - BUS 1	D	For AMP works	3-Mar-23	09:00	3-Mar-23	17:30	PG-WR2-BOISAR
60	277	PLANNED	OCC_564	POWERGRID_WR1	TBC BAY - PUNE-PG - 220KV - BUS 1 AND FUTURE AT PUNE-PG - 220KV at PUNE-PG - 220KV	D	For AMP WORK	3-Mar-23	09:00	3-Mar-23	18:00	
61	279	PLANNED	OCC_564	APML-ADANI	400KV/11.5KV TIRODA-ST-4	D	For bay equipment maintenance and testing work.	3-Mar-23	09:00	3-Mar-23	18:00	TRANSFORMER OUTAGE
62	303	PLANNED	OCC_564	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	CB Maintenance	3-Mar-23	10:00	3-Mar-23	15:00	CB Maintenance
63	304	PLANNED	OCC_564	MSLDC_OUTAGE	LONIKHAND-II - 400KV - BUS 1	C	Diagnostic testing and Maintenance	3-Mar-23	22:00	3-Mar-23	06:00	-
64	317	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Bay Maintenance Work & Line Maintenance Work	3-Mar-23	07:00	3-Mar-23	17:00	Bay Maintenance Work & Line Maintenance Work
65	322	PLANNED	OCC_564	POWERGRID_WR1	BUS COUPLER BAY - PUNE-PG - 220KV - BUS 1 AND PUNE-PG - 220KV - BUS 2 AT PUNE-PG - 220KV at PUNE-PG - 220KV	D	For AMP WORK	4-Mar-23	07:00	4-Mar-23	18:00	
66	323	PLANNED	OCC_564	POWERGRID_WR1	400KV-PARLI-SOLAPUR-1	D	Line terminal equipments AMP and Relay Testing in Solapur Substation	4-Mar-23	07:00	4-Mar-23	18:00	
67	324	PLANNED	OCC_564	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	bus bar#2 testing of main bay 212(outage of 220kV Wardha bhugaon shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-2 (contruction outage)	4-Mar-23	07:00	4-Mar-23	20:00	
68	325	PLANNED	OCC_564	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	bus bar#2 testing of main bay 212(outage of 220kV Wardha bhugaon shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-2 (contruction outage)	4-Mar-23	07:00	4-Mar-23	20:00	
69	337	PLANNED	OCC_564	APML-ADANI	400KV/11.5KV TIRODA-ST-5	D	For bay equipment maintenance and testing work.	4-Mar-23	09:00	4-Mar-23	18:00	TRANSFORMER OUTAGE
70	356	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Bay Maintenance Work	4-Mar-23	07:00	4-Mar-23	17:00	Bay Maintenance Work
71	358	PLANNED	OCC_564	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 1	D	400kV BUS A & Bus B Busbar Relay Online Testing	4-Mar-23	08:00	4-Mar-23	20:00	-
72	359	PLANNED	OCC_564	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 2	D	400kV BUS A & Bus B Busbar Relay Online Testing	4-Mar-23	08:00	4-Mar-23	20:00	-
73	360	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	4-Mar-23	09:00	4-Mar-23	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
74	361	PLANNED	OCC_564	MSLDC_OUTAGE	LONIKHAND-II - 400KV - BUS 2	C	Diagnostic testing and Maintenance	4-Mar-23	22:00	4-Mar-23	06:00	-
75	362	PLANNED	OCC_564	POWERGRID_WR1	220KV-TALANGADE(MS)-CHIKKODI-II-1 & 220KV-MUDSHINGI-CHIKKODI-II-1	D	For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1	4-Mar-23	07:00	5-Mar-23	18:00	Crossing 64-65
76	367	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TELEGAON-PUNE-PG-1	C	Half yearly maintenance Work	4-Mar-23	19:00	5-Mar-23	04:00	-
77	368	PLANNED	OCC_564	MSLDC_OUTAGE	KALWA - 400KV - BUS 1	C	Strengthening of 400KV Padgha-II bay at 400KV RS Kalwa by replacement of existing 0.5ACSR Stub Bus conductor of 400 KV Kalwa-Padgha-II line by HTLS conductor at 400KV RS Kalwa S/s by availing the Partial Outage on 400KV A-Bus as follows: 1) Shifting of Partial 400KV A-Bus element (500MVA, 400/22KV ICT-1 & 4, 400KV Kalwa-Kharghar Line to B-Bus through TBC and hand tripping the Bus-coupler) to B-Bus 2) Removing of Quadra A bus jumper (R,Y & B ph) as A bus dead. Near TBC & Padgha I gantry. 3) SHIFTING OF 400 KV ELEMENTS (400KV Padgha-1, 500MVA ICT-1 & 4 and closing of Bus Coupler CB) FROM B BUS TO A BUS 4) Stringing of HTLS conductor in Stub bus of 400 KV Padgha II line. 5) Shifting of following elements on A bus	4-Mar-23	00:02	5-Mar-23	23:59	1) For the said work outage is required on 400KV Kalwa-Padgha-II line whose outage is also proposed from 02.03.2023 to 07.03.2023 for HTLS work. 2) It is necessary to carry out the strengthening of 400KV Padgha-II Bay at 400KV RS Kalwa in view of HTLS of 400KV Kalwa-Padgha-II Line.
78	369	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-1	C	Required for Main Bus -2 outage work.	4-Mar-23	05:00	5-Mar-23	18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not
79	370	PLANNED	OCC_564	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	C	1. Replacement of damaged Bus conductor in span of 400KV HVDC-1 & 400KV GTR-6 bays. 2. Nut Bolts and hardware tightening work.	4-Mar-23	05:00	5-Mar-23	18:00	"This circuits/bays which are connected to 400KV MainBUS-2 will be shifted on 400KV Main Bus-1 one by one via TBC-1 & TBC-2
80	371	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/21KV CHANDRAPUR-GT-6	C	Required for Main Bus -2 outage work.	4-Mar-23	05:00	5-Mar-23	18:00	This bay will be in service via 400KV TBC-2 during Main Bus-2 outage period.
81	372	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	Required for Main Bus -2 outage work.	4-Mar-23	05:00	5-Mar-23	18:00	400KV STN TF-3, 400KV STN TF-5 will be in service
82	373	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	Required for Main Bus -2 outage work.	4-Mar-23	05:00	5-Mar-23	18:00	There will be a power restriction on HVDC Bipole of 750MW.
83	374	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-2	C	Required for Main Bus -2 outage work.	4-Mar-23	05:00	5-Mar-23	18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
84	375	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -2 outage work.	4-Mar-23	05:00	5-Mar-23	18:00	Required for Main Bus -2 outage work.
85	376	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor, Hardware in ROW issue area of line in Jambhul-Gaon, Ambernath.	4-Mar-23	06:00	5-Mar-23	18:00	work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor, Hardware in ROW issue area of line in Jambhul-Gaon, Ambernath.
86	377	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Chemical Cleaning of Insulator string and Routine Line maintenance work	4-Mar-23	08:00	5-Mar-23	18:00	400kv Padghe II will be in in service
87	378	PLANNED	OCC_564	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	1)Connecting jumper replacement of capacitor bank of all phase in pole-1 base filter bank 2) fire retardant coating of cable on converter transformer 3) Chemical cleaning of insulator disc in AC yard	4-Mar-23	20:00	5-Mar-23	20:00	pole-2 will be in service with 750 MW .
88	384	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Bay Maintenance Work at 220KV Boisar-II S/stn.	5-Mar-23	07:00	5-Mar-23	17:00	Bay Maintenance Work at 220KV Boisar-II S/stn.
89	385	PLANNED	OCC_564	GETCO	400KV-SSP-DHULE-MS-2	D	Maintenance work. A/R of 400 kV SSP - Dhule - 1 will remain out	5-Mar-23	08:00	5-Mar-23	18:00	Non auto reclose code for 400KV SSP Dhule No 1
90	387	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance work & Diagnostic Testing work.	5-Mar-23	09:00	5-Mar-23	18:00	Bay maintenance work & Diagnostic Testing work.
91	410	PLANNED	OCC_564	POWERGRID_WR1	MAIN BAY - KOLHAPUR GIS - 400KV B/R 1 AND KOLHAPUR GIS - 400KV - BUS 2 AT KOLHAPUR GIS - 400KV at Kolhapur GIS - 400KV	D	Bay AMP	6-Mar-23	09:00	6-Mar-23	18:00	412 Bay
92	413	PLANNED	OCC_564	APML-ADANI	400KV/11.5KV TIRODA-ST-3	D	For bay equipment maintenance and testing work.	6-Mar-23	09:00	6-Mar-23	18:00	TRANSFORMER OUTAGE
93	418	PLANNED	OCC_564	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR RESAGGING WORK OF CONDUCTOR TO MAINTAIN PROPER CLEARANCE & LINE MAINTENANCE WORK	6-Mar-23	09:00	6-Mar-23	18:00	
94	434	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KORADI-KHAPARKHEDA-2	D	FOR ATTENDING BUS-2 PG ISOLATOR Y PHASE ROTARY PROBLEM BY AGENCY & CB TIMING,CRM & DCRM.	6-Mar-23	06:00	6-Mar-23	21:00	Outages will be availed subject to weather conditions.
95	435	PLANNED	OCC_564	MSLDC_OUTAGE	TBC @ KORADI-1 (Element not available in WRLDC software)	D	FOR ATTENDING 400KV KHAPERKHEDA CKT-2 BUS-2 PG ISOLATOR Y PHASE ROTARY PROBLEM.400KV KHAPERKHEDA CKT-2 REQUIRE TO SHIFT ON 400KV TBC BAY.	6-Mar-23	06:00	6-Mar-23	21:00	Outages will be availed subject to weather conditions.
96	436	PLANNED	OCC_564	MSLDC_OUTAGE	MAIN BAY OF 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	6-Mar-23	07:00	6-Mar-23	15:00	Annual Maintenance of bays equipment & Diagnostics Testing Work
97	437	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	6-Mar-23	10:00	6-Mar-23	18:00	NA
98	438	PLANNED	OCC_564	POWERGRID_WR1	220kV Talandage-Sawantwadi (D/C)	D	For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1	6-Mar-23	07:00	7-Mar-23	18:00	LI26-LI27
99	441	PLANNED	OCC_564	RGPL	400KV-401-52B-Bay	C	ANNUAL BAY MAINTENANCE AND EQUIPMENT TESTING	6-Mar-23	08:00	7-Mar-23	18:00	MAINTENANCE OF EQUIPMENT AND SCHEDULE TESTING
100	452	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	D	Hotline washing work	6-Mar-23	09:00	11-Mar-23	18:00	hotline washing work
101	453	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-2	D	Hotline washing work	6-Mar-23	09:00	11-Mar-23	18:00	Hotline washing work
102	454	PLANNED	OCC_564	MSLDC_OUTAGE	TIE BAY OF 400KV/220KV SOLAPUR-M-ICT-2 AND 400KV-SOLAPUR-M-SOLAPUR-1 @SOLAPUR-M - 400KV at SOLAPUR-M - 400KV	C	Overhauling/servicing of 402-52CB	6-Mar-23	10:00	11-Mar-23	18:00	Without load interruption. 400/220kV ICT 1 and 400kV LBT-Parali line will be in service with respective main circuit breakers.
103	456	PLANNED	OCC_564	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 - Bhilad	C	220kV Bhilad feeder SF6 breaker major overhauling at TAPS1&2 end. Line will be in service with TBC	6-Mar-23	08:00	18-Mar-23	20:00	Feeder outage is not required; feeder will be on bus coupler; code is required during bus transfer process while taking work on the feeder and circuit breaker.
104	465	PLANNED	OCC_564	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	For taking LR in and out of service	7-Mar-23	07:00	7-Mar-23	18:00	401L
105	466	PLANNED	OCC_564	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	401LR AMP Work and Relay Testing works.	7-Mar-23	07:00	7-Mar-23	18:00	401LR
106	467	PLANNED	OCC_564	POWERGRID_WR1	WARDHA - 400KV B/R 1	D	Amp work of Reactor and Relay Testing works.	7-Mar-23	07:00	7-Mar-23	18:00	418R
107	480	PLANNED	OCC_564	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR RESAGGING WORK OF CONDUCTOR TO MAINTAIN PROPER CLEARANCE & LINE MAINTENANCE WORK	7-Mar-23	09:00	7-Mar-23	18:00	
108	491	PLANNED	OCC_564	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	D	CB Maintenance	7-Mar-23	10:00	7-Mar-23	15:00	CB Maintenance
109	492	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	7-Mar-23	10:00	7-Mar-23	18:00	NA
110	497	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-RGPL-NAGOTHANE-2	D	Cold washing work	7-Mar-23	08:00	12-Mar-23	18:00	Planned outage

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
111	510	PLANNED	OCC_564	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR RESAGGING WORK OF CONDUCTOR TO MAINTAIN PROPER CLEARANCE & LINE MAINTENANCE WORK	8-Mar-23	09:00	8-Mar-23	18:00	
112	513	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-AKOLA (2)-NANDGAONPETH-2	D	Outage required for routine maintenance of 400kV RPL to Akola 2 Line 2.	8-Mar-23	08:00	8-Mar-23	18:00	Outage required for routine maintenance of 400kV RPL to Akola 2 Line 2.
113	514	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	8-Mar-23	09:00	8-Mar-23	17:30	-
114	515	PLANNED	OCC_564	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	D	Annual Maintenance of ICT	8-Mar-23	09:00	8-Mar-23	18:00	Annual Maintenance of ICT
115	516	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	String replacment work & Hardware Tightening & Fitting Work	8-Mar-23	09:00	8-Mar-23	18:00	-
116	517	PLANNED	OCC_564	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	Routine Maint. Work	8-Mar-23	09:00	8-Mar-23	18:00	NA
117	518	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Annual maintenance work	8-Mar-23	09:00	8-Mar-23	18:00	The said work is very important
118	519	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	Routine Maint. Work	8-Mar-23	09:00	8-Mar-23	18:00	NA
119	520	PLANNED	OCC_564	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	D	Testing of Metering CT	8-Mar-23	10:00	8-Mar-23	12:00	Testing of Metering CT
120	521	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Quarterly Maintenance	8-Mar-23	10:00	8-Mar-23	17:00	Quarterly Maintenance
121	522	PLANNED	OCC_564	POWERGRID_WR1	110kV Mudshingi-Dudhganga (S/C)	D	For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1	8-Mar-23	07:00	9-Mar-23	18:00	LI16-LI17
122	525	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3 ON TBC @ BOISAR-M	C	CB Maintenance Work by shifting the line on TBC.	8-Mar-23	07:00	9-Mar-23	17:00	BOISAR II - BOISAR (PG) CKT - 3 will be shifted on TBC & will be in service.
123	526	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Replacement of PID Suspecious Disc & other Maintenance work. 400 KV DHULE-SSNNL CKT 2 A/R switch to be kept on Non Auto mode.	8-Mar-23	08:00	9-Mar-23	18:00	400 KV DHULE-SSNNL CKT 2 A/R switch to be kept on Non Auto mode.
124	528	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Replacement of Rusted Hardware, conductor & old earthwire.	8-Mar-23	07:00	11-Mar-23	17:00	Replacement of Rusted Hardware, conductor & old earthwire.
125	529	PLANNED	OCC_564	POWERGRID_WR1	MAIN BAY - 400KV-BHILAI-KORADI-1 AND KORADI - 400KV - BUS 1 AT KORADI - 400KV at Koradi - 400KV	C	Overhauling of BHI CGL CB at Koradi SS. Line to be shifted on TBC bay	8-Mar-23	08:00	13-Mar-23	18:00	BHI
126	530	PLANNED	OCC_564	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV/220KV WARDHA-ICT-1 AT WARDHA - 400KV at Wardha - 400KV	C	For Replacement of BHLE CB with CGL CB	8-Mar-23	08:00	14-Mar-23	18:00	420
127	551	PLANNED	OCC_564	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR RESAGGING WORK OF CONDUCTOR TO MAINTAIN PROPER CLEARANCE & LINE MAINTENANCE WORK	9-Mar-23	09:00	9-Mar-23	18:00	
128	560	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	9-Mar-23	08:00	9-Mar-23	18:00	.
129	561	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	DT, O/H & Servicing of 29 D Isolator mechanism box	9-Mar-23	08:00	9-Mar-23	20:00	-
130	562	PLANNED	OCC_564	MEGPTCL	AKOLA (2) - 765KV - BUS 1	D	Maintenance of Bus equipment's	9-Mar-23	09:30	9-Mar-23	18:30	Maintenance of Bus equipment's
131	573	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor, Hardware in ROW issue area of line in Jambhul-Gaon, Ambernath.	9-Mar-23	06:00	14-Mar-23	18:00	work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor, Hardware in ROW issue area of line in Jambhul-Gaon, Ambernath.
132	574	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1 ON TBC @ NAGOTHANE	C	CB replacement work	9-Mar-23	08:00	18-Mar-23	17:00	400 kV Nagothane Padgha -1 will be in service through TBC
133	577	PLANNED	OCC_564	MSLDC_OUTAGE	KORADI - 400KV - BUS 2	D	FOR ATTENDING 400KV KHAPERKHEDA CKT-2 BUS-2 PG ISOLATOR Y PHASE ROTARY PROBLEM BY AGENCY. ATTENDING ABOVE PROBLEM REQUIRE TO SHIFT ALL FEEDERS ON 400KV BUS-1.	10-Mar-23	06:00	10-Mar-23	21:00	Outages will be availed subject to weather conditions.
134	582	PLANNED	OCC_564	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE	D	401A LR AMP Work	10-Mar-23	07:00	10-Mar-23	18:00	401A LR AMP Work
135	583	Planned	OCC_564	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	401A LR AMP Work and Relay Testing works.	10-Mar-23	07:00	10-Mar-23	18:00	401ALR
136	584	PLANNED	OCC_564	POWERGRID_WR1	BHADRAWATI - 400KV - BUS 2	D	AMP works	10-Mar-23	07:00	10-Mar-23	18:00	AMP works
137	599	PLANNED	OCC_564	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	For AMP works of LTE at Boisar PG end	10-Mar-23	09:00	10-Mar-23	17:30	PG-WR2-BOISAR
138	600	PLANNED	OCC_564	POWERGRID_WR1	MAIN BAY - 400KV-KALWA-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 AT PUNE-PG - 400KV at PUNE-PG - 400KV	D	For AMP WORK	10-Mar-23	09:00	10-Mar-23	18:00	
139	616	PLANNED	OCC_564	MEGPTCL	KORADI-III - 765KV - BUS 1	D	Annual Maintenance of Bus equipment's	10-Mar-23	08:00	10-Mar-23	18:00	Annual Maintenance of Bus equipment's

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
140	617	PLANNED	OCC_564	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	10-Mar-23	09:00	10-Mar-23	17:00	During 400KV Busbar Protection Relay testing works Outage , (1). 400KV Bus-I and 400KV Bus-II
141	618	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	MTAMC work. No outage required only permission for shorting metering core to replace MFM meter. 400 KV Ektuni II will be in service as outage not required	10-Mar-23	10:00	10-Mar-23	14:00	400 KV Ektuni II will be in service as outage not required
142	619	PLANNED	OCC_564	POWERGRID_WR1	KOLHAPUR-MS - 400KV - BUS 1	D	For PG isolator alignment with bus hanger in bay augmentation work of Kolhapur(PG)-Kolhapur(MSETCL)#1 Bay at MSETCL, Talandage(Kolhapur)	10-Mar-23	06:00	11-Mar-23	19:00	Bus-1
143	629	PLANNED	OCC_564	MEGPTCL	KORADI-III - 400KV - BUS 1	D	Annual Maintenance of Bus equipment's	11-Mar-23	09:00	11-Mar-23	18:00	Annual Maintenance of Bus equipment's
144	630	PLANNED	OCC_564	MSLDC_OUTAGE	EKTUNI - 765KV - BUS 2	D	Diagnostic, Relay Testing & Routine Maintenance	11-Mar-23	10:00	11-Mar-23	18:00	765kV Main Bus-1 will be in service.
145	631	PLANNED	OCC_564	POWERGRID_WR1	765KV/400KV AURANGABAD-ICT-1	D	For Spare Changeover	11-Mar-23	07:00	11-Mar-23	12:00	703T
146	645	PLANNED	OCC_564	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	For AMP works. Dia to be kept opened at both side.	11-Mar-23	09:00	11-Mar-23	17:30	PG-WR2-BOISAR
147	646	Planned	OCC_564	POWERGRID_WR1	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 AT PUNE-PG - 400KV at PUNE-PG - 400KV	D	TO Check CT Bellows	11-Mar-23	09:00	11-Mar-23	18:00	
148	662	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	DT & O/H , Serviceing of 29C PG Isolator & Replacement of PGI mechanism box.	11-Mar-23	08:00	11-Mar-23	20:00	-
149	664	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -1 outage work.	11-Mar-23	05:00	12-Mar-23	18:00	Required for Main Bus-1 outage work.
150	665	PLANNED	OCC_564	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	1. Replacement of damaged bus conductor of 2. Nut Bolts and hardware tightening work.	11-Mar-23	05:00	12-Mar-23	18:00	"This circuits/bays which are connected to 400KV MainBUS-1 will be shifted on 400KV Main Bus-2 one by one via TBC-1 & TBC-2
151	666	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	C	Required for Main Bus -1 outage work.	11-Mar-23	05:00	12-Mar-23	18:00	HVDC-1 wil be in service. There will be a power restriction on HVDC Bipole of 750MW.
152	667	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	Required for Main Bus -1 outage work.	11-Mar-23	05:00	12-Mar-23	18:00	This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
153	668	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-5	C	Required for Main Bus -1 outage work.	11-Mar-23	05:00	12-Mar-23	18:00	Load on 400KV STN-5 will be shifted on 400KV STN TF-3, 400KV STN TF-4 will be in
154	669	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/21KV CHANDRAPUR-GT-6	C	Required for Main Bus -1 outage work.	11-Mar-23	05:00	12-Mar-23	18:00	This bay will be in Service via TBC-2
155	670	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	Required for Main Bus -1 outage work.	11-Mar-23	05:00	12-Mar-23	18:00	This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
156	671	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	cold line washing of insulator string and routine Line maintenance work and bay maintenance work	11-Mar-23	08:00	12-Mar-23	18:00	400kv Padghe I will be in in service
157	672	PLANNED	OCC_564	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	C	Bus Isolator R/M & other R/M Work.	11-Mar-23	09:00	12-Mar-23	21:00	Bus Isolator R/M & other R/M Work.
158	673	PLANNED	OCC_564	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	1)Chemical cleaning of insulator disc in pole-2 AC yard 2) Pole-2 Z21-Q1 R-ph AC Circuit breaker interrupter replacement due to high CRM value 3) Fire retardant coating of cable on pole-2 converter transformer	11-Mar-23	20:00	12-Mar-23	08:00	Pole-1 will be in service with 750 Mw
159	681	PLANNED	OCC_564	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For AMP WORK and Relay Testing works.	12-Mar-23	07:00	12-Mar-23	18:00	
160	682	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	PID faulty insulator strings replacement	12-Mar-23	08:00	12-Mar-23	18:00	-
161	683	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware tightening,cold line washing and string replacement	12-Mar-23	09:00	12-Mar-23	18:00	Load will be managed on 400kv karjat-parli ckt 1
162	684	PLANNED	OCC_564	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Diagnostic, Relay Testing & Routine Maintenance	12-Mar-23	09:30	12-Mar-23	18:00	765/400kv 1500MVA ICT-II will be in service.
163	691	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance Work	12-Mar-23	09:00	12-Mar-23	17:00	-
164	692	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	Diagnostic Testing and Bay maintenance work.	12-Mar-23	09:00	12-Mar-23	18:00	Diagnostic Testing and Bay maintenance work.
165	693	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-BOISAR-NALASOPARA-1	D	Bay Maintenance Work & Line Maintenance Work	12-Mar-23	09:00	12-Mar-23	18:00	Bay Maintenance Work & Line Maintenance Work
166	694	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1) MTAMC work 2) Diagnostic Testing work 3) Replacement of all phase CT having ratio 3000/1A 4) Bay maint work 5) Replacement of PG isolator under LES scheme	12-Mar-23	09:00	12-Mar-23	22:00	400kv kalwa -2 in service
167	704	PLANNED	OCC_564	POWERGRID_WR1	400KV-PARLI-SOLAPUR-2	D	For AMP and Relay Testing works.	13-Mar-23	07:00	13-Mar-23	18:00	AMP OF LINE CIRCUIT

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
168	714	PLANNED	OCC_564	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR- ICT-4 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	D	For AMP works	13-Mar-23	09:00	13-Mar-23	17:30	PG-WR2-BOISAR
169	742	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Over voltage Relay replacement work	13-Mar-23	08:00	13-Mar-23	17:00	outage required
170	743	PLANNED	OCC_564	MSLDC_OUTAGE	WARORA - 400KV - BUS 2	D	BUS CVT ,Tan Delta & Isolator Maintenance work. Relay testing work.	13-Mar-23	08:00	13-Mar-23	18:00	1) During 400KV Main Bus II outage Ckt's connected on Bus II i.e., 400KV C'pur 2 Ckt1 400KV C'pur 2 Ckt 1 400KV 400 KV Ektuni II will be in service
171	746	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	CT tan D and LBB relay testing and bay maintenance work	13-Mar-23	09:00	13-Mar-23	17:00	
172	747	PLANNED	OCC_564	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Hanger rod dismantle and erection by hotline method in 400 KV Padghe 1 bay	13-Mar-23	09:00	13-Mar-23	17:00	Work will be carried out by Hotline method
173	748	PLANNED	OCC_564	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Dharni S/s	13-Mar-23	09:00	13-Mar-23	17:00	.
174	749	PLANNED	OCC_564	MEGPTCL	AKOLA (2) - 400KV - BUS 1	D	Maintenance of Bus equipment's	13-Mar-23	09:30	13-Mar-23	18:30	Maintenance of Bus equipment's
175	750	PLANNED	OCC_564	MSLDC_OUTAGE	ALKUD - 400KV - BUS 1	D	Routine maintenance work	13-Mar-23	10:00	13-Mar-23	17:00	Load will be managed on Main Bus -2
176	751	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Routine Maintenance work	13-Mar-23	10:00	13-Mar-23	17:00	Load will be managed on Alkud-Kolhapur line
177	752	PLANNED	OCC_564	POWERGRID_WR1	KOLHAPUR-MS - 400KV - BUS 2	D	For erection of jack bus and PG isolator alignment with bus hanger in bay augmentation work of Kolhapur(PG)- Kolhapur(MSETCL)#1 Bay at MSETCL, Talandage(Kolhapur)	13-Mar-23	06:00	14-Mar-23	19:00	Bus-2
178	757	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1 ON TBC @ BABHALESHWAR	C	PG maintenance work,CB timing and DCRM	13-Mar-23	08:00	14-Mar-23	18:00	400kv Padghe I will be in in service through TBC Babhaleshwar- Padghe I on
179	758	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Replacement of PID Suspecious Disc & other Maintenance work. 400 KV DHULE- SSNNL CKT 2 A/R switch to be kept on Non Auto mode.	13-Mar-23	08:00	14-Mar-23	18:00	400 KV DHULE-SSNNL CKT 2 A/R switch to be kept on Non Auto mode.
180	759	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Replacement of damaged disc insulator, corona ring, damaged nut bolts.	13-Mar-23	09:00	14-Mar-23	18:00	400kv Ektuni-Bhabaleshwar ckt-II will be in service
181	769	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold washing work	13-Mar-23	08:00	18-Mar-23	18:00	---
182	770	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-1	D	Hotline washing work	13-Mar-23	09:00	18-Mar-23	18:00	Hotline washing work
183	771	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	Hotline washing work	13-Mar-23	09:00	18-Mar-23	18:00	Hotline washing work
184	773	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	13-Mar-23	09:00	22-Mar-23	18:00	PID Testing of Insulators Auto- Reclose function to be out of service.
185	779	PLANNED	OCC_564	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	D	Line Equipment AMP and B PH Line CT Replacement of Padghe Kudus Line 1 at Kudus SS.	14-Mar-23	07:00	14-Mar-23	17:00	400 KV Padghe Kudus Line 1 will be out of service.
186	813	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Over voltage Relay replacement work	14-Mar-23	08:00	14-Mar-23	17:00	outage required
187	816	PLANNED	OCC_564	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Annual Maintenance of ICT-1	14-Mar-23	08:00	14-Mar-23	19:00	Annual Maintenance of ICT-1
188	817	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-1	D	Routine Testing work, CT Tan-delta, CB CRM & Timing testing work and Routine Maintenance work.	14-Mar-23	10:00	14-Mar-23	18:00	Outage proposed as per Diagnostics Testing Schedule
189	824	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	cold line washing of insulator string and routine Line maintenance work on DHULE- - BABLESHWAR CKT - 1 hence AR out required on ckt.2	14-Mar-23	08:00	15-Mar-23	18:00	-
190	828	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	Replacement of Rusted Hardware, Old earthwire and other maintenance work.	14-Mar-23	07:00	17-Mar-23	17:00	Replacement of Rusted Hardware, Old earthwire and other maintenance work.
191	836	PLANNED	OCC_564	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4 L/R@ PUNE-PG - 400KV	D	For AMP WORK and Relay Testing works.	15-Mar-23	07:00	15-Mar-23	18:00	
192	876	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	D	Over voltage Relay replacement work	15-Mar-23	08:00	15-Mar-23	17:00	outage required
193	877	PLANNED	OCC_564	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	BUS CVT ,Tan Delta & Isolator Maintenance work.	15-Mar-23	08:00	15-Mar-23	18:00	1) During 400KV Main Bus I outage Ckt's connected on Bus I i.e.,400KV Adani ckt. 1 & 2 PGCIL,IEPL ckt charged through respective Tie CB's connected on Main Bus II. 2) For 400KV BUSBAR I relay testing work both 400KV Bus I & Bus II will be kept out of service during testing work.
194	879	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line / s/sMaintenance	15-Mar-23	09:00	15-Mar-23	17:30	-
195	880	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening,cold line washing and string replacement	15-Mar-23	09:00	15-Mar-23	18:00	Load will be managed on 400kv lamboti-solapur(PG)
196	881	PLANNED	OCC_564	MSLDC_OUTAGE	KHAPARKHEDA - 400KV - BUS 2	D	Diagonastic testing of CVT's and Bus isolator maint.	15-Mar-23	09:00	15-Mar-23	18:00	NA

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
197	882	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Annual maintenance work	15-Mar-23	09:00	15-Mar-23	18:00	The said work is very important
198	883	PLANNED	OCC_564	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	Routine Maint. Work	15-Mar-23	09:00	15-Mar-23	18:00	NA
199	884	PLANNED	OCC_564	MEGPTCL	AKOLA (2) - 400KV - BUS 2	D	Maintenance of Bus equipment's	15-Mar-23	09:30	15-Mar-23	18:30	Maintenance of Bus equipment's
200	892	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintainance work	15-Mar-23	08:00	16-Mar-23	18:00	NA
201	893	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Replacement of damaged disc insulator, corona ring, damaged nut bolts.	15-Mar-23	09:00	16-Mar-23	18:00	400kV Ektuni-Bhabaleshwar ckt-I will be in service
202	897	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	C	Overhauling of GE make CB Drive & pole overhauling work. 400 kV Jaigad Ckt-II will be in service through TBC	15-Mar-23	09:00	18-Mar-23	18:00	GE service engineer is available from 15.03.2023 to 18.03.23.400 kV Jaigad Ckt-II will be in service through TBC
203	900	PLANNED	OCC_564	POWERGRID_WR1	400KV-KOLHAPUR GIS-Mapusa-1	D	For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#2. AR to be kept in Non-Auto mode for 400KV-KOLHAPUR GIS-Mapusa-2 for safety purpose.	15-Mar-23	07:00	25-Mar-23	18:00	Multi ckt
204	901	PLANNED	OCC_564	POWERGRID_WR1	400KV-KORBA WEST-KORBA-NTPC-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	15-Mar-23	07:00	31-Mar-23	18:00	
205	916	PLANNED	OCC_564	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Relay Replacement of Bosar Line/AMC of Line Equipment	16-Mar-23	07:00	16-Mar-23	17:00	400 KV Padghe Boisar LINE along with Line Reactor will be out of service.
206	948	PLANNED	OCC_564	MSLDC_OUTAGE	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	16-Mar-23	07:00	16-Mar-23	15:00	Annual Maintenance of bays equipment & Diagnostics Testing Work
207	949	PLANNED	OCC_564	MSLDC_OUTAGE	KARAD - 400KV - BUS 1	D	Hot line permission is required alongwith 400KV Jejuri - Karad ckt for replacement of Horizontal Cu bar along with nut bolts which is damaged of Y ph of Y ph Bus-I PG isolator with the help of Hot Line Unit,Ogalewadi	16-Mar-23	08:00	16-Mar-23	17:00	work will be carried out alongwith 400kV Jejuri - Karad ckt
208	950	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-JEJURI-KARAD-1	D	PID Faulty disc insulator replacement work & Cold line washing work	16-Mar-23	08:00	16-Mar-23	17:00	PID Faulty disc insulator replacement work & Cold line washing work Also Hot line permission is required for
209	951	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	Over voltage Relay replacement work	16-Mar-23	08:00	16-Mar-23	17:00	outage required
210	952	PLANNED	OCC_564	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Annual maintenance work	16-Mar-23	09:00	16-Mar-23	18:00	The said work is very important
211	953	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Annual maintenance work	16-Mar-23	09:00	16-Mar-23	18:00	The said work is very important
212	957	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	cold line washing of insulator string and routine Line maintenance work on DHULE- BABLESHWAR CKT - 2 hence AR out required on ckt 1	16-Mar-23	08:00	17-Mar-23	16:00	-
213	958	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Replacement of PID Suspecious Disc & other Maintenance work. 400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.	16-Mar-23	08:00	17-Mar-23	18:00	400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.
214	959	PLANNED	OCC_564	POWERGRID_WR1	TIE BAY OF 400KV-WARDHA-AURANGABAD-2 AND 400KV/220KV WARDHA-ICT-3 @WARDHA - 400KV AT WARDHA - 400KV at Wardha - 400KV	C	Installation of CSD for 400/220kV ICT#3 (construction outage)	16-Mar-23	07:00	18-Mar-23	20:00	
215	961	PLANNED	OCC_564	RGPPPL	400KV-402-52A-Bay	C	ANNUAL BAY MAINTENANCE AND EQUIPMENT TESTING	16-Mar-23	08:00	18-Mar-23	18:00	400KV-NewKoyna line-1 will be in service through tie breaker 402-52T
216	962	PLANNED	OCC_564	APML-ADANI	MAIN BAY- 400KV TIRORA-WARORA-1 AND 400KV BUS-2 AT TIRORA SS	C	For line main bay breaker arcing contact inspection and testing work	16-Mar-23	09:00	18-Mar-23	18:00	Bay Outage
217	964	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-4	C	Rapid Restoration Scheme Work,DFRA testing and bay maintenance work	16-Mar-23	09:00	18-Mar-23	20:00	ICT 1, 2, and 3 will be in service
218	965	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	16-Mar-23	08:00	19-Mar-23	18:00	.
219	967	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	PID Testing work	16-Mar-23	08:00	31-Mar-23	18:00	-
220	973	PLANNED	OCC_564	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	D	Line jumper Spacer and Clamps replacement and work. Dia to be kept open.	17-Mar-23	07:00	17-Mar-23	18:00	
221	983	PLANNED	OCC_564	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	D	Replacement of Porcelain insulators. Ckt#2 to be kept in Non Auto mode. Dia to be kept opened at both ends.	17-Mar-23	08:00	17-Mar-23	19:00	PG-WR2-BOISAR
222	984	PLANNED	OCC_564	POWERGRID_WR1	MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-2 AND PADGHE - 400KV - BUS 1 AT PADGHE - 400KV at PADGHE - 400KV	D	AMP of Bay Equipment.	17-Mar-23	09:00	17-Mar-23	17:00	400 KV Padghe Tarapur 2 will be in service through TBC
223	994	PLANNED	OCC_564	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	D	Line Outage for attending SD nature defects in Line. Dia to be kept opened at both end. A/R to be kept in non auto mode of 400KV Khandwa-Dhule 2 Line	17-Mar-23	09:00	17-Mar-23	18:00	PG-WR2-KHANDWA
224	1007	PLANNED	OCC_564	MEGPTCL	KORADI-III - 765KV - BUS 2	D	Annual Maintenance of Bus equipment's	17-Mar-23	08:00	17-Mar-23	18:00	Annual Maintenance of Bus equipment's
225	1008	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	Bay Maintenance Work	17-Mar-23	09:00	17-Mar-23	17:00	Bay Maintenance Work

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
226	1009	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-2	D	Routine Testing work, CT Tan-delta, CB CRM & Timing testing work and Routine Maintenance work.	17-Mar-23	10:00	17-Mar-23	18:00	Outage proposed as per Diagnostics Testing Schedule
227	1010	PLANNED	OCC_564	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	C	For AMP and Radiator replacement works. Dia to be kept opened at both side.	17-Mar-23	09:00	18-Mar-23	17:30	PG-WR2-BOISAR
228	1012	PLANNED	OCC_564	MSLDC_OUTAGE	LONIKHAND-II - 400KV - BUS 2	D	Diagnostic testing and Maintenance	17-Mar-23	22:00	18-Mar-23	06:00	-
229	1015	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	Conductor replacement in span between loc. No.33-34, Cold washing/chemical cleaning of insulator strings	17-Mar-23	07:00	20-Mar-23	18:00	-
230	1038	PLANNED	OCC_564	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	D	Line Outage for attending SD nature defects in Line. Dia to be kept opened at both end. A/R to be kept in non auto mode of 400KV Khandwa-Dhule 1 Line	18-Mar-23	09:00	18-Mar-23	18:00	PG-WR2-KHANDWA
231	1048	PLANNED	OCC_564	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Testing of Metering CT	18-Mar-23	10:00	18-Mar-23	13:00	Testing of Metering CT
232	1049	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Chemical Cleaning of Insulator string and Routine Line maintenance work	18-Mar-23	08:00	19-Mar-23	18:00	400kV Padghe II will be in in service
233	1050	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	C	For Overhauling of Bus A 89A &BUS B 89 B Rph, Yph, Bph PG Isolators. Cold washing/chemical cleaning of insulator strings Diagnostic Testing, Relay Testing	18-Mar-23	10:00	19-Mar-23	21:00	-
234	1056	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	PID faulty insulator strings replacement	19-Mar-23	08:00	19-Mar-23	18:00	-
235	1057	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) Reactor testing work. (2) Bay maintenance work.	19-Mar-23	09:00	19-Mar-23	18:00	-
236	1063	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Routine Maintenance & Insulator cleaning work	19-Mar-23	08:00	19-Mar-23	18:00	Routine Maintenance & Insulator cleaning work
237	1064	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	TO ATTEND DEFECTS IDENTIFIED IN MONKEY PATROLLING UNDER PADGHE AND JUNNER S-DN:-1. To FIX REPAIR SLEEVE AT BROKEN CONDUCTOR STRANDS.2. REPLACEMENT OF BROKEN AND FLASHOVER DISC INSULATORS STRINGS.3. CHEMICAL AND COLD WASHING OF DUST/BIRD SHIT POLLUTED INSULATOR STRING.4. FIX OF BIRD GUARD AT INSULATORS STRING AT BIRD SHIT LOCATIONS.5. FIXING OF MISSING/DAMAGED HARDWARE.6. TIGHTENING LOOSE OF NUT BOLTS OF CONDUCTOR JUMPER AND EARTHWIRE HARDWARE. works at 400kV Padghe 1) Bay maint work 2) diagnostic testing work 3) MTAMC work 4) Replacement of LA under LES scheme. 5) Replacement of 29C bus PG isolator under LES scheme.	19-Mar-23	08:00	19-Mar-23	18:00	The 400kV Babhaleshwar-Padghe Ckt-1 will be available.
238	1065	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	Cold washing/chemical cleaning of insulator strings Diagnostic Testing, Relay Testing	19-Mar-23	09:00	19-Mar-23	18:00	-
239	1066	PLANNED	OCC_564	APML-ADANI	MAIN BAY- 400KV TIRORA-WARORA-2 AND 400KV BUS-2 AT TIRORA SS	C	For line main bay breaker arcing contact inspection and testing work	19-Mar-23	09:00	21-Mar-23	18:00	Bay Outage
240	1068	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance Work	19-Mar-23	09:00	19-Mar-23	17:00	-
241	1079	PLANNED	OCC_564	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	D	Replacement of Porcelin insulators. Ckt#2 to be kept in Non Auto mode. Dia to be kept opened at both ends.	20-Mar-23	08:00	20-Mar-23	19:00	PG-WR2-BOISAR
242	1111	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	D	1. AM work 2. A & B bus isolator OH work	20-Mar-23	09:00	20-Mar-23	20:00	1. Monday is load staggering day in Kolhapur 2. Bus loading is in balance condition.
243	1112	PLANNED	OCC_564	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Testing of Metering CT	20-Mar-23	10:00	20-Mar-23	13:00	Testing of Metering CT
244	1113	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	MTAMC work. No outage required only permission for shorting metering core to replace MFM meter. 400 KV Ektuni I will be in service as outage not required	20-Mar-23	10:00	20-Mar-23	14:00	400 KV Ektuni I will be in service as outage not required
245	1114	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Routine Maintenance work	20-Mar-23	10:00	20-Mar-23	17:00	Load will be managed on Solapur- Alkud line
246	1115	PLANNED	OCC_564	MSLDC_OUTAGE	ALKUD - 400KV - BUS 2	D	Routine Maintenance work	20-Mar-23	10:00	20-Mar-23	17:00	Load will be managed on Main Bus 1
247	1118	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Replacement of PID Suspecious Disc & other Maintenance work. 400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.	20-Mar-23	08:00	21-Mar-23	18:00	400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.
248	1119	PLANNED	OCC_564	MSLDC_OUTAGE	KORADI - 400KV - BUS 2	D	PID TESTING	20-Mar-23	10:00	21-Mar-23	18:00	Outages will be availed subject to weather conditions.
249	1125	PLANNED	OCC_564	RGPPL	400KV-404-52T-Bay	C	ANNUAL BAY MAINTENANCE AND EQUIPMENT TESTING	20-Mar-23	08:00	22-Mar-23	18:00	400KV-NewKoyana Line-2 will be in service through tie breaker 404-52B
250	1129	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2 ON TBC @ NEW KOYNA	C	Circuit breaker Overhauling work by Shifting on TBC	20-Mar-23	08:00	25-Mar-23	17:00	TBC Shifting Proposal

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
251	1130	PLANNED	OCC_564	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV - BUS 2	C	1. AM work 2. Buc CVT replacement work 3. PID faulty strings replacement work.	20-Mar-23	09:00	25-Mar-23	20:00	All the bays will be shifted online to main Bus 1 through TBC
252	1132	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2 ON TBC @ NAGOTHANE	C	CB replacement work	20-Mar-23	08:00	28-Mar-23	17:00	400 kV Nagothane Padgha -II will be in service through TBC
253	1139	PLANNED	OCC_564	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 – Borivali	C	220kV Borivali feeder SF6 breaker major overhauling at TAPS1&2 end	20-Mar-23	08:00	31-Mar-23	20:00	Feeder outage is not required; feeder will be on bus coupler; code is required during bus
254	1146	PLANNED	OCC_564	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment.	21-Mar-23	07:00	21-Mar-23	17:00	400 KV Padghe Tarapur 2 will be out of service.
255	1149	PLANNED	OCC_564	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme. New Constructions works.	21-Mar-23	07:00	21-Mar-23	18:00	
256	1150	PLANNED	OCC_564	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme. New Constructions works.	21-Mar-23	07:00	21-Mar-23	18:00	
257	1156	PLANNED	OCC_564	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	D	Replacement of Porcelain insulators. Ckt#1 to be kept in Non Auto mode. Dia to be kept opened at both ends.	21-Mar-23	08:00	21-Mar-23	19:00	PG-WR2-BOISAR
258	1181	PLANNED	OCC_564	MEGPTCL	400KV-AKOLA-AKOLA (2)-1	D	Testing of Metering CT	21-Mar-23	10:00	21-Mar-23	12:00	Testing of Metering CT
259	1182	PLANNED	OCC_564	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Diagnostic Testing & Routine Maintenance	21-Mar-23	10:00	21-Mar-23	18:00	765/400kV 1500MVA ICT-1 will be in service though its TIE 709 Bay & Main Bus-1
260	1209	PLANNED	OCC_564	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Annual Maintenance of ICT-2	22-Mar-23	08:00	22-Mar-23	19:00	Annual Maintenance of ICT-2
261	1210	PLANNED	OCC_564	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Annual maintenance work	22-Mar-23	09:00	22-Mar-23	18:00	The said work is very important
262	1211	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Annual maintenance work	22-Mar-23	09:00	22-Mar-23	18:00	The said work is very important
263	1212	PLANNED	OCC_564	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	22-Mar-23	09:00	22-Mar-23	18:00	NA
264	1213	PLANNED	OCC_564	MSLDC_OUTAGE	SOLAPUR-M - 400KV - BUS 1	D	Routine Maintenance activities	22-Mar-23	10:00	22-Mar-23	13:00	Without Load interruption. Load will be managed on 400kV Main Bus II
265	1214	PLANNED	OCC_564	MSLDC_OUTAGE	SOLAPUR-M - 400KV - BUS 2	D	Routine Maintenance work.	22-Mar-23	14:00	22-Mar-23	18:00	Without Load interruption. Load will be managed on 400kV Main Bus I
266	1221	PLANNED	OCC_564	POWERGRID_WR1	MAIN BAY - 400KV/220KV WARDHA-ICT-2 AND WARDHA - 400KV - BUS 2B at Wardha - 400KV	C	For Replacement of BHEL CB with CGL CB	22-Mar-23	08:00	28-Mar-23	18:00	424
267	1222	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Replacement of PID Suspecious Disc & other Maintenance work. 400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.	22-Mar-23	08:00	23-Mar-23	18:00	400 KV DHULE-SSNNL CKT 1 A/R switch to be kept on Non Auto mode.
268	1238	PLANNED	OCC_564	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-2 AND FUTURE @KUDUS - 400KV AT KUDUS - 400KV at KUDUS - 400KV	D	R PH CT Replacement of 417 Bay and Bay AMP at Kudus SS.	23-Mar-23	09:00	23-Mar-23	17:00	400 KV Padghe Kudus Line 2 will be in service through Main Bay 418.
269	1252	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	23-Mar-23	08:00	23-Mar-23	18:00	.
270	1253	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	D	O/H & Servicing of 29A & 29B PG Isolator & Replacement of PGI mechanism box.	23-Mar-23	08:00	23-Mar-23	20:00	-
271	1255	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line, s/s Maintenance	23-Mar-23	09:00	23-Mar-23	17:30	-
272	1256	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening,cold line washing and string replacement	23-Mar-23	09:00	23-Mar-23	18:00	Load will be managed on 400kv lamboti-Parli line
273	1257	PLANNED	OCC_564	MEGPTCL	400KV-AKOLA-AKOLA (2)-2	D	Testing of Metering CT	23-Mar-23	10:00	23-Mar-23	12:00	Testing of Metering CT
274	1260	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400KV	C	For Overhauling of Bus A 89A & BUS B 89 B Rph, Yph, Bph PG Isolators. Diagnostic Testing, Relay Testing	23-Mar-23	10:00	24-Mar-23	21:00	-
275	1261	PLANNED	OCC_564	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - BUS 2	C	Retrofitting of PG-2 Isolators of MSEB ckt-1 and MSEB ckt-2	23-Mar-23	07:00	25-Mar-23	18:00	Retrofitting of PG-2 Isolators of MSEB ckt-1 and MSEB ckt-2
276	1263	PLANNED	OCC_564	RGPPPL	400KV-404-52B-Bay	C	ANNUAL BAY MAINTENANCE AND EQUIPMENT TESTING	23-Mar-23	08:00	25-Mar-23	18:00	400KV-NewKoyana Line-2 will be in service through tie breaker 404-52T
277	1267	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	23-Mar-23	09:00	31-Mar-23	18:00	PID Testing of Insulators Auto-Reclose function to be out of service.
278	1268	PLANNED	OCC_564	RSTCL	765KV-RAICHUR_PG-SHOLAPUR-2	D	Planned AMP Work	23-Mar-23	09:00	23-Mar-23	17:00	
279	1280	PLANNED	OCC_564	POWERGRID_WR2	BOISAR - 400KV - BUS 1	D	For AMP works	24-Mar-23	09:00	24-Mar-23	17:30	PG-WR2-BOISAR
280	1281	PLANNED	OCC_564	ATIL	400KV-TIRODA-WARORA-1	D	Line equipment Maintenance work	24-Mar-23	09:00	24-Mar-23	18:00	Line outage

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
281	1294	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	1) shifting from B bus to A bus for partial Bus outage 2) H/T required for 2 to 3 hrs. for jumper removing work by cold line method between Nagothane 2&1 in afternoon hrs.	24-Mar-23	05:00	24-Mar-23	15:00	Weather condition should be clear
282	1295	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	D	1) H/T required for safety proposed for removing jumper between HVDC 1&2 gantry by Hot line method. 2) power restriction of 750 MW for 3 hrs.	24-Mar-23	08:30	24-Mar-23	12:00	Weather condition should be clear
283	1296	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	24-Mar-23	09:00	24-Mar-23	17:00	Reactor kept in OFF position., The Bay No. 403 also kept in OFF position.
284	1297	PLANNED	OCC_564	RSTCL	765KV-RAICHUR-PG-SHOLAPUR-2	D	Planned AMP Work	24-Mar-23	09:00	24-Mar-23	17:00	SR Import/Export ATC to be curtailed by 500/500 MW.
285	1298	PLANNED	OCC_564	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Diagnostic, Relay Testing & Routine Maintenance	24-Mar-23	09:30	24-Mar-23	18:00	765/400kV 1500MVA ICT-I will be in service.
286	1299	PLANNED	OCC_564	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Changeover of R-ph Line Reactor with Spare Reactor at Ektuni SS as per CEA guideline (Line outage is required as LR is non switchable at Ektuni SS.)	24-Mar-23	10:00	24-Mar-23	14:00	Changeover of R-ph Line Reactor with Spare Reactor at Ektuni SS as per CEA guideline (Line outage is
287	1300	PLANNED	OCC_564	MSLDC_OUTAGE	AURANGABAD-M (WALUJ) - 400KV - BUS 1	D	1) Diagnostic Testing Work 2) Routine Maintenance Work	24-Mar-23	10:00	24-Mar-23	18:00	Outage on 400kV Main Bus - 1
288	1304	PLANNED	OCC_564	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	1. Tan delta measurement of Bus CVT. 2. Replacement of faulty disc insulator string of Main Bus-1 3. Nut Bolts and hardware tightening work.	24-Mar-23	05:00	25-Mar-23	18:00	This circuits/bays which are connected to 400KV MainBUS-1 will be shifted on 400KV Main Bus-2 one by one via TBC-1 & TBC-2
289	1305	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-1	C	Required for Main Bus -1 outage work.	24-Mar-23	05:00	25-Mar-23	18:00	Required for replacement of faulty string of 400KV Main Bus-1 this bay section
290	1306	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	Required for Main Bus -1 outage work.	24-Mar-23	05:00	25-Mar-23	18:00	This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
291	1307	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	Required for Main Bus -1 outage work.	24-Mar-23	05:00	25-Mar-23	18:00	This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
292	1308	PLANNED	OCC_564	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -1 outage work.	24-Mar-23	05:00	25-Mar-23	18:00	Required for Main Bus-1 outage work.
293	1309	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	C	1) Shifting from B bus to A bus for partial Bus outage	24-Mar-23	05:00	26-Mar-23	11:00	Weather condition should be clear
294	1310	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-2	C	1) shifting on TBC for partial bus outage for Bus conductor replacement work 2) PG isolator alignment work	24-Mar-23	05:00	26-Mar-23	23:00	Weather condition should be clear
295	1311	Planned	OCC_564	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1)B Bus Conductor Replacement of Section -3 between 400kV HVDC II& Nagothane I 2) 400kV HVDC -2 on	24-Mar-23	05:00	26-Mar-23	23:59	agency will be present on site.
296	1312	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	C	1)H/T require for 3 days for Bus conductor replacement work of sec-3 between Nago-1 & HVDC-2 2) IPS tube removing work below B bus for Bus conductor replacement 3) PG isolator replacement & alignment work of B bus	24-Mar-23	11:00	26-Mar-23	23:59	Weather condition should be clear
297	1313	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	C	Conductor replacement in span between loc. No.33-34, Cold washing/chemical cleaning of insulator strings	24-Mar-23	07:00	27-Mar-23	18:00	-
298	1335	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	1) For shifting of 400KV Kalwa-Padgha-II Line (between suitable location) on 400KV Dead Ckt to facilitate HTLS work on 400KV Kalwa-Padgha-I line from 26.03.2023. (After above shifting, 400KV Kalwa-Padgha-I line will be shifted on dead portion of 400KV Kalwa-Padgha-II line so as to make the 400KV Kalwa-Padgha-I line dead between the above suitable location) 2) 400KV Kalwa-Padgha-II Line will be charged through Dead Ckt till the completion of HTLS work on dead portion of 400KV Kalwa-Padgha-I Line after above arrangement.	25-Mar-23	06:00	25-Mar-23	18:00	-
299	1336	PLANNED	OCC_564	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Bus CVT Testing	25-Mar-23	09:00	25-Mar-23	17:00	400 KV BUS -1 feeders and ICTs to be shifted on 400 KV Bus-1
300	1337	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	cold line washing of insulator string and routine Line maintenance work	25-Mar-23	08:00	26-Mar-23	18:00	400kV Padghe I will be in in service
301	1338	PLANNED	OCC_564	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	C	Bus Isolator R/M & other R/M Work	25-Mar-23	09:00	26-Mar-23	20:00	Bus Isolator R/M & other R/M Work
302	1339	PLANNED	OCC_564	MEGPTCL	765KV-TIRODA-KORADI-III-1	D	Installation of Bird flight Divertor In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2022	25-Mar-23	08:00	26-Mar-23	18:00	Installation of Bird flight Divertor In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2022

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
303	1340	PLANNED	OCC_564	POWERGRID_WR2	BOISAR - 400KV - BUS 2	D	For AMP works	25-Mar-23	09:00	25-Mar-23	17:30	PG-WR2-BOISAR
304	1341	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	Half yearly maintenance Work	26-Mar-23	09:00	26-Mar-23	17:00	-
305	1342	PLANNED	OCC_564	POWERGRID_WR2	400KV-VINDHYACHAL-JABALPUR-1	C	Replacement of line CVT in add cap at Jabalpur 400 end. Dia to be kept opened at both end.	26-Mar-23	09:00	27-Mar-23	20:00	PG-WR2-JABALPUR 400
306	1343	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1) Shifting of 400KV Kalwa-Padgha-I line on dead portion of 400KV Kalwa-Padgha-II line (Padgha-II line partial portion is proposed to be made dead by shifting this line on 400KV dead ckt on 25.03.2023) 2) 400KV Kalwa-Padgha-I line will be charged through dead portion of 400KV Kalwa-Padgha-II line after above proposed network changes till the completion of HTLS work on dead portion of Padgha-I Ckt.	26-Mar-23	06:00	26-Mar-23	18:00	-
307	1344	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	TO ATTEND DEFECTS IDENTIFIED IN MONKEY PATROLLING UNDER PADGHE AND JUNNER S-DN--1. REPLACEMENT OF BROKEN AND FLASHOVER DISC INSULATORS STRINGS.3. CHEMICAL AND COLD WASHING OF DUST/BIRD SHIT POLLUTED INSULATOR STRING.4. FIX OF BIRD GUARD AT INSULATORS BIRD SHIT LOCATIONS.5. TIGHTENING OF NUT BOLTS OF CONDUCTOR JUMPER AND EARTHWIRE HARDWARE.6. STRINGING OF EARTHWIRE AND LOC 919-920.7. FIXING OF MISSING/DAMAGED HARDWARE. works at 400kV Padghe 1) MTAMC work 2) Bay maint work 3) Diagnostic Testing work 4) Replacement of 29C bus PG isolator under LES scheme	26-Mar-23	08:00	26-Mar-23	18:00	The 400kV Babhaleshwar-Padghe Ckt -2 will be available.
308	1345	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Routine Maintenance & Insulator cleaning work	26-Mar-23	08:00	26-Mar-23	18:00	Routine Maintenance & Insulator cleaning work
309	1346	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	1) H/t requires for safety purposed for re connection of jumper by cold line method between Nago I & II 2) shifting from A bus to B bus after Bus conductor replacement work.	26-Mar-23	12:00	26-Mar-23	22:00	Weather condition should be clear
310	1347	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	D	1) H/T requires for safety purposed for re connection of jumper between HVDC 1 & II gantry of B bus by Hot line method.	26-Mar-23	14:00	26-Mar-23	17:35	1) weather condition should be clear for Hot line method.
311	1348	PLANNED	OCC_564	POWERGRID_WR1	765KV/400KV CHAMPA-ICT-4	D	For Spare Change Over.	27-Mar-23	07:00	27-Mar-23	12:00	
312	1373	PLANNED	OCC_564	MSLDC_OUTAGE	KORADI - 400KV - BUS 1	D	CVT Tan Delta	27-Mar-23	06:00	27-Mar-23	23:00	Outages will be availed subject to weather conditions.
313	1375	PLANNED	OCC_564	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2	D	Routine Maintenance & Dignostic testing work .	27-Mar-23	09:00	27-Mar-23	17:00	Line will be charged through Tie CB 428.
314	1376	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Badnera S/s	27-Mar-23	09:00	27-Mar-23	17:00	.
315	1379	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1 ON TBC @ LONIKHAND	C	O/H & Servicing of 29A PG Isolator & Replacement of PGI mechanism box by shifting load on 400kV TBC	27-Mar-23	08:00	28-Mar-23	20:00	Line will be in service through TBC
316	1420	PLANNED	OCC_564	MSLDC_OUTAGE	MAIN BAY OF 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400kV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	28-Mar-23	07:00	28-Mar-23	16:00	Annual Maintenance of bays equipment & Diagnostics Testing Work
317	1422	PLANNED	OCC_564	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	28-Mar-23	09:00	28-Mar-23	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
318	1423	PLANNED	OCC_564	MSLDC_OUTAGE	EKTUNI - 400KV - BUS 2	D	Diagnostic, Relay Testing & Routine Maintenance	28-Mar-23	10:00	28-Mar-23	18:00	400kV Main Bus-1 will be in service
319	1426	PLANNED	OCC_564	MEGPTCL	765KV-TIRODA-KORADI-III-2	C	Installation of Bird flight divertor - In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2022	28-Mar-23	08:00	29-Mar-23	18:00	Installation of Bird flight divertor - In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2022
320	1427	PLANNED	OCC_564	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	1) Measurement of tandelta and capacitance of CT. 3) Maintenance and alignments of PG-1 & PG-2 , CBI ,PG-3 Isolator.	28-Mar-23	08:00	29-Mar-23	18:00	400KV STN TF-3 will be in service via TBC-2 in to order to carry out PID testing work on Aux Bus (Section-2)
321	1450	PLANNED	OCC_564	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	29-Mar-23	09:00	29-Mar-23	17:00	Line will be charged through Main CB 429.
322	1451	PLANNED	OCC_564	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	29-Mar-23	09:00	29-Mar-23	17:00	.
323	1452	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line, s/s Maintenance	29-Mar-23	09:00	29-Mar-23	17:30	-
324	1453	PLANNED	OCC_564	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	D	Outage is required for Quarterly Maintenance	29-Mar-23	09:00	29-Mar-23	18:00	Quarterly Maintenance

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
325	1466	PLANNED	OCC_564	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 2	D	400KV BB online relay testing, all bays will be in service, all protection will be in service except 400kV BB	30-Mar-23	09:00	30-Mar-23	18:00	-
326	1467	PLANNED	OCC_564	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 1	D	400KV BB online relay testing, all bays will be in service, all protection will be in service except 400kV BB	30-Mar-23	09:00	30-Mar-23	18:00	-
327	1470	PLANNED	OCC_564	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID scanning of insulator strings	30-Mar-23	08:00	31-Mar-23	18:00	-
328	1471	PLANNED	OCC_564	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	Replacement of Hanger assembly of B bus all phase PG isolator by Hot line method of 315MVA ICT-3 2) All other bays on B bus will be in service through TBC	30-Mar-23	11:00	8-Apr-23	16:00	weather condition should be clear
329	1472	PLANNED	OCC_565	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-3 ON TBC	C	1) CB replacement under LES scheme 2) Replacement of B bus PG isolator under LES scheme . Also B bus Bph PG isolator support structure damaged . 3) 315MVA ICT-3 HV side in service through TBC .	30-Mar-23	09:00	9-Apr-23	21:00	Agency will be present on site
330	1481	PLANNED	OCC_566	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 – Boisar	C	220kV Boisar feeder SF6 breaker major overhauling at TAPS1&2 end	1-Apr-23	08:00	14-Apr-23	20:00	Feeder outage is not required; feeder will be on bus coupler; code is required during bus transfer process while taking out the breaker and also while putting the breaker in service.

State Element outage list for the month of MARCH'2023

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	STATION TF-3 @ KORADI 2	01-Mar-23	10:00	01-Mar-23	18:00	Daily	Diagnostic testing of Line CT at Bay 404.	MSETCL	MSETCL	Station Transformer-1 & Station Transformer-2 will remain in service.
2	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	01-Mar-23	10:00	02-Mar-23	17:00	Continuous	RTV Coating of 33 kV Tertiary Side Equipments & Filtration of Y Ph Unit	MSETCL	MSETCL	NA
3	400 KV	BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR	01-Mar-23	08:00	02-Mar-23	20:00	Continuous	Oil top up and oil filtration work due to high water PPM,SFRA and DFRA testing	MSETCL	MSETCL	NA
4	400 KV	AKOLA - KHADKA (BHUSAWAL)	01-Mar-23	10:00	18-Mar-23	16:00	Daily	PID testing work will be carried out by PID Unit Akola & Hot Line Unit Akola of 400 kV Akola-Bhusawal line	MSETCL	MSETCL	PID testing work will be carried out by PID Unit Akola & Hot Line Unit Akola of 400 kV Akola-Bhusawal line
5	400 KV	JEJURI- KOYNA STAGE-IV	02-Mar-23	08:00	02-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
6	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	02-Mar-23	08:00	02-Mar-23	20:00	Daily	O/H, Servicing & Alignment of 29 D Isolator	MSETCL	MSETCL	-
7	400 KV	CHANDRAPUR-PARLI CKT-3	02-Mar-23	09:00	02-Mar-23	18:00	Daily	spacer replacement & earthwire fixing at loc.613	MSETCL	MSETCL	-
8	400 KV	400/220KV 315MVA ICT - 3 ON TBC @ CHAKAN	02-Mar-23	10:00	02-Mar-23	21:00	Daily	For Overhauling of Bus B 89B Rph, Yph, Bph PG Isolators.	MSETCL	MSETCL	ICT-3 will be in service through 400 KV TBC.
9	400 KV	MAIN BAY - 408 OF CHANDRAPUR 2 CKT - 1 @ NANDED-KUMBHARGAON	02-Mar-23	10:00	02-Mar-23	17:00	Daily	DCRM of 408 bay CB	MSETCL	MSETCL	-
10	400 KV	400/220/33 KV 315 MVA ICT - 1 ON TBC @ WALUJ	03-Mar-23	10:00	03-Mar-23	18:00	Daily	1) Diagnostic CB Testing Work 2) Routine Maintenance Work. 400/220/33 KV 315 MVA ICT - 1 @ WALUJ (Through TBC Bay)	MSETCL	MSETCL	Outage on 400/220/33 KV 315 MVA ICT - 1 @ WALUJ (Through TBC Bay)
11	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	03-Mar-23	10:00	03-Mar-23	18:00	Daily	Diagnostic Testing of bushing of ICT unit and routine bay maintenance work	MSETCL	MSETCL	501 MVA 400/220/33 KV ICT-II will remain in service as alternate source of supply
12	400 KV	WARORA - IEPL	03-Mar-23	09:00	03-Mar-23	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV WARORA - DEOLI 2 Line is in ckt
13	400 KV	NEW KOYNA-KARAD CKT - 1	03-Mar-23	08:00	03-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
14	400 KV	NEW KOYNA-KARAD CKT - 2	04-Mar-23	08:00	04-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
15	400 KV	LONIKAND - JEJURI CKT - 2	04-Mar-23	09:00	04-Mar-23	18:00	Daily	Cold washing/chemical cleaning of insulator strings	MSETCL	MSETCL	-
16	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	04-Mar-23	09:00	04-Mar-23	17:00	Daily	HV CB DCRM timing, SFRA, REF and NDR testing and bay equipment maintenance work	MSETCL	MSETCL	ICT 1, 3 and 4 will be in service
17	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	05-Mar-23	10:00	05-Mar-23	18:00	Daily	Diagnostic Testing, Relay Testing	MSETCL	MSETCL	-
18	400 KV	KARAD - TALANDGE CKT - 1	06-Mar-23	08:00	06-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
19	400 KV	KARAD - TALANDGE CKT - 1	06-Mar-23	09:00	06-Mar-23	20:00	Daily	1.AM Work 2. CT & CVT testing work	MSETCL	MSETCL	Load will be managed on Talandge-Karad ckt -2
20	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	06-Mar-23	09:00	06-Mar-23	20:00	Daily	1. C & tan delta testing of 33kV bushings 2. Annual Maintenance Work 3. PID faulty strings replacement work at 220kv side	MSETCL	MSETCL	1. Load will be managed on 315 MVA ICT-2 & 501 MVA ICT-3 2. Monday is load staggering day in Kolhapur.
21	400 KV	400/220 KV 500 MVA ICT @ ALKUD	07-Mar-23	10:00	07-Mar-23	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	Tuesday is load staggering day of Sangli District. Load will be managed on 400KV Karad & 400KV Talandge.
22	400 KV	MAIN BAY (403) OF CHANDRAPUR GCR CKT - 1 @ CHANDRAPUR - 2	07-Mar-23	10:00	07-Mar-23	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
23	400 KV	KARAD - TALANDGE CKT - 2	07-Mar-23	08:00	07-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
24	400 KV	BUS REACTOR (125 MVA) @ ALKUD	09-Mar-23	10:00	09-Mar-23	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	-
25	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	09-Mar-23	10:00	09-Mar-23	18:00	Daily	Diagnostic Testing of bushing of ICT unit and routine bay maintenance work	MSETCL	MSETCL	501 MVA 400/220/33 KV ICT-I will remain in service as alternate source of supply
26	400 KV	WARORA - IEPL	09-Mar-23	09:00	09-Mar-23	17:00	Daily	Line CT,CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
27	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	09-Mar-23	10:00	09-Mar-23	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
28	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	09-Mar-23	09:00	09-Mar-23	18:00	Daily	spacer replacement & earthwire stringing at location no. 497 to 500	MSETCL	MSETCL	-
29	400 KV	MAIN BAY - 408 OF CHANDRAPUR 2 CKT - 1 @ NANDED-KUMBHARGAON	09-Mar-23	10:00	09-Mar-23	17:00	Daily	DCRM of 409 bay CB	MSETCL	MSETCL	-
30	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	09-Mar-23	09:30	09-Mar-23	17:30	Daily	Annual testing & maintenance.	MSETCL	MSETCL	During outage ICT 1 & ICT 2 will be service.
31	400 KV	LONIKAND I - KOYNA STAGE-IV	09-Mar-23	08:00	09-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
32	400 KV	TBC @ CHAKAN	10-Mar-23	10:00	10-Mar-23	21:00	Daily	For Overhauling of Bus A 89A Rph, Yph, Bph PG Isolators.	MSETCL	MSETCL	-
33	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	10-Mar-23	10:00	10-Mar-23	17:00	Daily	Diagonastic testing of CT's and CB	MSETCL	MSETCL	NA
34	400 KV	400 KV WALLUJ (400 KV) - BABHALESHWAR CKT	10-Mar-23	10:00	10-Mar-23	18:00	Daily	1) Diagnostic Testing Work 2) Routine Maintenance Work.	MSETCL	MSETCL	NIL
35	400 KV	TBC @ PADGHE	10-Mar-23	09:00	11-Mar-23	19:00	Continuous	1) Replacement of CT having 3000/1A ratio to avoid power restriction on HVDC bay when in service through TBC 2) Bay maint work	MSETCL	MSETCL	400KV TBC will not be available
36	400 KV	NEW KOYNA-KARAD CKT - 1	10-Mar-23	08:00	10-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
37	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	11-Mar-23	11:00	11-Mar-23	14:00	Daily	MTAMC work. No outage required only permission for shorting metering core to replace MFm meter. ICT III will be in service as outage not required	MSETCL	MSETCL	ICT III will be in service as outage not required
38	400 KV	JEJURI - KARAD	11-Mar-23	09:00	11-Mar-23	18:00	Daily	Cold washing/chemical cleaning of insulator strings	MSETCL	MSETCL	-
39	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	11-Mar-23	08:00	11-Mar-23	18:00	Daily	Maintenance work	MSETCL	MSETCL	
40	400 KV	NEW KOYNA-KARAD CKT - 2	11-Mar-23	08:00	11-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
41	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	13-Mar-23	08:00	15-Mar-23	18:00	Daily	For replacement of polymer Insulator string	MSETCL	MSETCL	
42	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	13-Mar-23	09:00	13-Mar-23	20:00	Daily	1. OLTC oil filtration work. 2. C Bus Isolator OH work	MSETCL	MSETCL	1. Monday is load staggering day in Kolhapur. 2. Load will be managed on 501 ICT-1 & 501 MVA ICT-3
43	400 KV	KARAD - TALANDGE CKT - 2	13-Mar-23	08:00	13-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
44	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	13-Mar-23	11:00	13-Mar-23	17:30	Daily	ICT-2 Diagnostic Testing works & CT-1 Tan-d test	MSETCL	MSETCL	-
45	400 KV	KARAD - TALANDGE CKT - 1	14-Mar-23	08:00	14-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
46	400 KV	400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	14-Mar-23	09:00	14-Mar-23	15:00	Daily	DFRA testing	MSETCL	MSETCL	105 MVA Spare ICT-1 not charged
47	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	14-Mar-23	09:00	14-Mar-23	17:00	Daily	Line CT, Sync CVT Tan delta, IR values & Routine maintenance and isolator maintenance work .	MSETCL	MSETCL	400KV, 125MVAR Bus reactor charged on own main CB (Bay no.402)
48	400 KV	DHULE- - BABLESHWAR CKT - 1	14-Mar-23	08:00	15-Mar-23	18:00	Daily	cold line washing of insulator string and routine Line maintenance work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in service
49	400 KV	KARAD - TALANDGE CKT - 2	14-Mar-23	09:00	14-Mar-23	20:00	Daily	1. AM work 2. C bus Isolator OH work	MSETCL	MSETCL	Load will be managed on 400kv Talandge Karad Ckt-1
50	400 KV	400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	14-Mar-23	10:00	14-Mar-23	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
51	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	16-Mar-23	09:00	16-Mar-23	18:00	Daily	(1) Reactor testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
52	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	16-Mar-23	09:00	16-Mar-23	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
53	400 KV	MAIN BAY - 410 OF PARLI (GIRWALI) CKT-1 @ NANDED	16-Mar-23	11:00	16-Mar-23	17:00	Daily	DCRM of 410 bay CB	MSETCL	MSETCL	-
54	400 KV	CHANDRAPUR-PARLI CKT-3	16-Mar-23	08:00	18-Mar-23	18:00	Daily	For replacement of polymer Insulator string	MSETCL	MSETCL	-
55	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	16-Mar-23	10:00	16-Mar-23	18:00	Daily	Diagnostic Testing, Relay Testing	MSETCL	MSETCL	-
56	400 KV	DHULE- - BABLESHWAR CKT - 2	16-Mar-23	08:00	17-Mar-23	18:00	Daily	cold line washing of insulator string and routine Line maintenance work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in service
57	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	16-Mar-23	09:00	16-Mar-23	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 412 is in OFF condition, respective ckt charged through its own main CB.
58	400 KV	CHANDRAPUR - KHAPERKHEDA	16-Mar-23	09:00	25-Mar-23	17:00	Daily	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	MSETCL	MSETCL	For PID Testing Work,shifting autoreclose switch to Non auto Mode .
59	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	17-Mar-23	08:00	18-Mar-23	18:00	Daily	1) Measurement Circuit Breaker timing, CRM & DCRM. 2) Measurement of tandelta of CVT. 3) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadravati Ckt. No.- 1, 2, 3 & 4 and ICT-1 will be in service through TBC
60	400 KV	400/220/33 KV 315 MVA ICT - 1 ON TBC @ LONIKAND	17-Mar-23	08:00	18-Mar-23	20:00	Continuous	O/H & Servicing of 29A PG Isolator & Replacement of PGI mechanism box by shifting load on 400kv TBC	MSETCL	MSETCL	
61	400 KV	NEW KOYNA-KARAD CKT - 1	17-Mar-23	08:00	17-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
62	400 KV	KORADI II - IEPL	17-Mar-23	08:00	18-Mar-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
63	400 KV	FUTURE CKT - 1 @ WARORA	17-Mar-23	09:00	17-Mar-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
64	400 KV	400 KV FUTURE BAY II @ WARORA	18-Mar-23	09:00	18-Mar-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
65	400 KV	NEW KOYNA-KARAD CKT - 2	18-Mar-23	08:00	18-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
66	400 KV	BUS REACTOR (125MVA) @ WARORA	20-Mar-23	09:00	20-Mar-23	17:00	Daily	Maintenance work	MSETCL	MSETCL	Reactor kept in OFF position. , Tie Bay No. 403 also kept in OFF position.
67	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	20-Mar-23	10:00	20-Mar-23	18:00	Daily	CTR maintenance work. N2 injection and firefighting system annual maintenance work.	MSETCL	MSETCL	Maintenance work shall be carried out by CTR engineer.
68	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	20-Mar-23	09:00	20-Mar-23	18:00	Daily	(1)Diff. relay testing work; (2) Bay maintenance work.	MSETCL	MSETCL	-
69	400 KV	AKOLA - KHADKA (BHUSAWAL)	20-Mar-23	06:00	24-Mar-23	18:00	Daily	String replacement work will be carried out by engaging agency which are detected punctured in PID testing.	MSETCL	MSETCL	String replacement work will be carried out by engaging agency which are detected punctured in PID testing.
70	400 KV	KARAD - TALANDGE CKT - 1	20-Mar-23	08:00	20-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
71	400 KV	105 MVA SPARE ICT @ AKOLA	21-Mar-23	10:00	21-Mar-23	17:00	Daily	DCRM, Tandelta CT, CRM CB, Breaker Timing & Routine maintenance Work	MSETCL	MSETCL	N.A.
72	400 KV	BUS REACTOR (80 MVA) - 2 @ BABHALESHWAR	21-Mar-23	09:00	21-Mar-23	16:00	Daily	REF Relay,CT tan D	MSETCL	MSETCL	Reactor II is under break down
73	400 KV	NEW KOYNA-KARAD CKT - 1	21-Mar-23	08:00	21-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
74	400 KV	BUS REACTOR (125 MVA) - 2 @ KOLHAPUR (TALANDGE)	22-Mar-23	09:00	22-Mar-23	18:00	Daily	1. AM work 2. Main tank oil top up work	MSETCL	MSETCL	80 MVA Reactor will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
75	400 KV	NEW KOYNA-KARAD CKT - 2	22-Mar-23	08:00	22-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
76	400 KV	LONIKAND I - KOYNA STAGE-IV	23-Mar-23	08:00	23-Mar-23	18:00	Daily	PID faulty insulator strings replacement and Chemical cleaning	MSETCL	MSETCL	-
77	400 KV	JEJURI- KOYNA STAGE-IV	23-Mar-23	08:00	23-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
78	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	23-Mar-23	09:00	23-Mar-23	18:00	Daily	spacer replacement & earthwire stringing at location no. 455 to 457	MSETCL	MSETCL	-
79	400 KV	KHADKA - BABLESHWAR	23-Mar-23	08:00	24-Mar-23	18:00	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad , Dhule I&II will be in in service
80	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	23-Mar-23	11:00	23-Mar-23	17:30	Daily	ICT-2 Diagnostic Testing works	MSETCL	MSETCL	-
81	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	24-Mar-23	10:00	24-Mar-23	17:00	Daily	DCRM, Tandelta CT, CRM CB, Breaker Timing & Routine maintenance Work	MSETCL	MSETCL	Load will be shifted on ICT-01
82	400 KV	KORADI-NANDGAONPETH (RPL)	24-Mar-23	08:00	24-Mar-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
83	400 KV	400KV KORADI-KHADKA	25-Mar-23	08:00	25-Mar-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
84	400 KV	CHANDRAPUR-PARLI CKT-3	27-Mar-23	09:00	27-Mar-23	18:00	Daily	(1) C & tan delta measurement of CVTs. (2) Bay maintenance work.	MSETCL	MSETCL	-
85	400 KV	KARAD - TALANDGE CKT - 1	27-Mar-23	08:00	27-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
86	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	27-Mar-23	06:00	29-Mar-23	18:00	Daily	String replacement work will be carried out on 400 kv Akola- Nandgaonpeth line by engaging agency which are detected punctured in PID testing.	MSETCL	MSETCL	String replacement work will be carried out on 400 kv Akola- Nandgaonpeth line by engaging agency which are detected punctured in PID testing.
87	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	27-Mar-23	08:00	27-Mar-23	17:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
88	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	27-Mar-23	09:00	27-Mar-23	20:00	Daily	1. AM work. 2. OLTC oil filtration work.	MSETCL	MSETCL	1. Monday is load staggering day in Kolhapur. 2. Load will be managed on 315 MVA ICT -2 & 315 MVA ICT -3.
89	400 KV	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	28-Mar-23	10:00	28-Mar-23	17:00	Daily	DCRM, Tandelta CT, CRM CB, Breaker Timing & Routine maintenance Work	APTCL	APTCL	Tie Bay 418 Will be in service
90	400 KV	KARAD - TALANDGE CKT - 2	28-Mar-23	08:00	28-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
91	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	29-Mar-23	08:00	29-Mar-23	17:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
92	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	29-Mar-23	11:00	29-Mar-23	17:30	Daily	ICT-2 Diagnostic Testing works	MSETCL	MSETCL	-
93	400 KV	JEJURI- KOYNA STAGE-IV	30-Mar-23	08:00	30-Mar-23	18:00	Daily	PID faulty insulator strings replacement and Chemical cleaning	MSETCL	MSETCL	-
94	400 KV	LONIKAND I - KOYNA STAGE-IV	30-Mar-23	08:00	30-Mar-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work