

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of MARCH '2025

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
1	RQ236781	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	01/Mar/2025	08:00	15/Mar/2025	18:00	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)
2	RQ236780	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	01/Mar/2025	08:00	15/Mar/2025	18:00	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)
3	RQ237935	PLANNED	OCC_588	POWERGRID_WR2	BOISAR - 400KV - BUS 1	C	Continuous outage of 400 kV Bus-1 for Bus-bar relay retrofitting & testing	01/Mar/2025	07:00	10/Mar/2025	21:00	/PG-WR2- BOISAR///03
4	RQ239045	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-CHANDRAPUR-KHAPARKHEDA-1	C	Monopole tower erection work between tower No.34 &35	01/Mar/2025	06:00	10/Mar/2025	22:00	
5	RQ239581	PLANNED	OCC_588	MSLDC_OUTAGE	400KV/220KV KHARGHAR-ICT-3	C	Safety purpose for removing of Bus through jumper by Hotline Method. For the commissioning of the new ICT-4	01/Mar/2025	06:00	02/Mar/2025	18:00	
6	RQ237933	PLANNED	OCC_588	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	C	Simultaneous outage of 400KV-TARAPUR 3&4-PADGHE-1 &2 is required for Outage required for diversion of transmission line fouling to the Vadodara - Mumbai Expressway	01/Mar/2025	08:00	09/Mar/2025	18:00	/PG-WR2- BOISAR///01
7	RQ237934	PLANNED	OCC_588	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	C	Simultaneous outage of 400KV-TARAPUR 3&4-PADGHE-1 &2 is required for Outage required for diversion of transmission line fouling to the Vadodara - Mumbai Expressway	01/Mar/2025	08:00	09/Mar/2025	18:00	/PG-WR2- BOISAR///02
8	RQ239046	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	C	1) CB overhauling work by external agency & Bay maintenance & equipment testing at 220KV Boisar-II S/S. Line will be in service through TBC	01/Mar/2025	06:00	02/Mar/2025	19:00	
9	RQ239176	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	01/Mar/2025	09:00	01/Mar/2025	18:00	
10	RQ239207	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	01/Mar/2025	09:00	01/Mar/2025	18:00	
11	RQ239253	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	01/Mar/2025	08:00	01/Mar/2025	18:00	
12	RQ239238	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	01/Mar/2025	09:00	01/Mar/2025	18:00	
13	RQ239284	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLU-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	01/Mar/2025	09:00	01/Mar/2025	18:00	
14	RQ239575	PLANNED	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	D	Removing of A Bus through Jumper by Hotline Method. For the commissioning of new ICT-4	01/Mar/2025	09:00	01/Mar/2025	18:00	
15	RQ236655	PLANNED	OCC_588	POWERGRID_WR1	220KV-AURANGABAD-CHITGAON-2	D	AMP of Line terminal equipments at Aurangabad S/s.	01/Mar/2025	08:00	01/Mar/2025	18:00	AMP WORK
16	RQ236814	PLANNED	OCC_588	POWERGRID_WR1	400KV/220KV PUNE-GIS-ICT-2	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	01/Mar/2025	06:00	04/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
17	RQ236811	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 765KV/400KV PUNE-GIS-ICT-3 AND PUNE-GIS - 765KV - BUS 2 at Pune-GIS - 765KV	D	Tie bay LBB testing	01/Mar/2025	06:00	01/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
18	RQ237242	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 220KV - BUS 1 @PUNE-GIS - 220KV at Pune-GIS - 220KV	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	01/Mar/2025	07:00	04/Mar/2025	20:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
19	RQ237243	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 400KV - BUS 1 @PUNE-GIS - 400KV at Pune-GIS - 400KV	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	01/Mar/2025	07:00	04/Mar/2025	20:00	
20	RQ239047	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	02/Mar/2025	09:00	02/Mar/2025	18:00	
21	RQ239052	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1. Damaged T.NO 51 Replacement Related work. 2. PID Faulty Discs replacement works with PLRI. 3. To attend defects found in Monkey Patrolling 4. Diagnostic Testing work. 5. Replacement of LA under LES Scheme 6. Replacement of Distance Relay. 7. ITC of TWFL relay by M/s.GE.	02/Mar/2025	07:00	02/Mar/2025	19:00	
22	RQ239051	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Outage is required for safety purpose during bunching at Loc no. 18 and at Loc. No. 8 of 220kV PGCL(Boisar)-Panchali Line to dead ckt for 220kV Panchali S/S (For the replacement of Existing 0.4 ACSR Conductor by	02/Mar/2025	06:00	02/Mar/2025	19:00	
23	RQ239049	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during bunching at Loc no. 18 and at Loc. No. 8 of 220kV PGCL(Boisar)-Panchali Line to dead ckt for 220kV Panchali S/S (For the replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCL(Boisar)-Panchali Line).	02/Mar/2025	06:00	02/Mar/2025	19:00	
24	RQ239547	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	1) CB overhauling (make CGL) work by external agency & Bay maintenance & equipment testing at 220kV Boisar-II S/S. 2) For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor 3) Outage is required for safety purpose	02/Mar/2025	06:00	02/Mar/2025	19:00	
25	RQ239050	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	1) For bunching at Loc no. 18 and at Loc. No. 8 of 220kV PGCL(Boisar)-Panchali Line to dead ckt for 220kV Panchali S/S (For the replacement of Existing	02/Mar/2025	06:00	02/Mar/2025	19:00	
26	RQ239546	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	1) CB overhauling (make CGL) work by external agency & Bay maintenance & equipment testing at 220kV Boisar-II S/S. 2) For replacement of Existing 0.4	02/Mar/2025	06:00	02/Mar/2025	19:00	
27	RQ239177	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	02/Mar/2025	09:00	02/Mar/2025	18:00	
28	RQ239208	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	02/Mar/2025	09:00	02/Mar/2025	18:00	
29	RQ239254	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	02/Mar/2025	08:00	02/Mar/2025	18:00	
30	RQ239239	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	02/Mar/2025	09:00	02/Mar/2025	18:00	
31	RQ239285	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	02/Mar/2025	09:00	02/Mar/2025	18:00	
32	RQ239048	PLANNED	OCC_588	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance & Diagnostic Testing work.	02/Mar/2025	08:00	02/Mar/2025	17:00	
33	RQ239055	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	C	Chemical Washing work, Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	03/Mar/2025	06:00	06/Mar/2025	18:00	
34	RQ239056	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	1) CB Mechanism overhauling work. 2) Replacement of 29 D Isolator under LES Scheme. For replacement of line isolator IPS tube will be removed between 29 C & 29 D Isolator and line will be charge on TBC. 3) After replacement of 29D Isolator for reconnection of IPS tube between 29 C and 29 D Isolator 400KV BBLR-II H/t required for 03 hrs on dated 08.03.2025.	03/Mar/2025	00:01	08/Mar/2025	18:30	
35	RQ237586	PLANNED	OCC_588	TAPS12	220KV-TARAPUR 1&2-BOISAR-M-1	C	Outage is required for annual maintenance of feedre's equipments(CT,Breaker,Isolatpr,wave trap,CVT,LA etc).	03/Mar/2025	08:00	05/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
36	RQ237283	PLANNED	OCC_588	APML	400KV/11.5KV TIRODA-ST-1	C	Dia Equipment Maintenance	03/Mar/2025	09:00	05/Mar/2025	18:00	
37	RQ237525	PLANNED	OCC_588	MEGPTCL	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	03/Mar/2025	09:00	03/Mar/2025	18:00	Bay Outage
38	RQ239178	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	03/Mar/2025	09:00	03/Mar/2025	18:00	
39	RQ239209	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	03/Mar/2025	09:00	03/Mar/2025	18:00	
40	RQ239053	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	C	1)Shifting of Line on ERS for Erection & Conductor Stringing of Inline Towers under ORC work for the work of Diversion of 220KV Deoli - Pusad Line at Loc.	03/Mar/2025	08:00	11/Mar/2025	18:00	
41	RQ239255	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	03/Mar/2025	08:00	03/Mar/2025	18:00	
42	RQ239240	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	03/Mar/2025	09:00	03/Mar/2025	18:00	
43	RQ239054	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Quarterly maintenance work	03/Mar/2025	09:00	03/Mar/2025	18:00	
44	RQ239305	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	03/Mar/2025	09:00	03/Mar/2025	18:00	
45	RQ239286	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	03/Mar/2025	09:00	03/Mar/2025	18:00	
46	RQ239332	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	03/Mar/2025	07:00	03/Mar/2025	18:00	
47	RQ239299	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Replacement of faulty disc by Hot line Method found during the PID Testing	03/Mar/2025	09:00	03/Mar/2025	17:00	
48	RQ239577	PLANNED	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - TRANSFER BUS 1	D	Removing the C Bus through the Jumper by Hotline Method. For the commissioning of the new ICT-4	03/Mar/2025	09:00	03/Mar/2025	18:00	
49	RQ236836	PLANNED	OCC_588	POWERGRID_WR1	BUS COUPLER BAY - PUNE-PG - 220KV - BUS 1 AND PUNE-PG - 220KV - BUS 2 at PUNE-PG - 220KV	D	FOR AMP WORK	03/Mar/2025	09:00	03/Mar/2025	17:00	
50	RQ236731	PLANNED	OCC_588	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 1	D	Reactor AMP Works	03/Mar/2025	08:00	03/Mar/2025	18:00	80 MVar Bus reactor AMP , LBB Retrofitting and Relay testing works
51	RQ239063	PLANNED	OCC_588	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. 400KV STN TF-4 will be shifted on "400KV TBC-2" in order to remove IPS tube connecting PG-1 & PG-2 Isolators for disconnection the Bus jumpers and reconnect the same after completion of work. IPS tube will be reconnected after completion of work and feeder will be shifted back to its own bay. 3. Outage is not required as feeder will be in service	04/Mar/2025	15:00	05/Mar/2025	15:00	
52	RQ239062	PLANNED	OCC_588	MSLDC_OUTAGE	400KV/21KV CHANDRAPUR-GT-6	C	1. Replacement of old damaged quadraple Bus conductor of '400KV Main Bus-1' in span of 'HVDC CKT-1 to GTR-6' 2. GTR-6 will be in service via TBC-2	04/Mar/2025	04:00	06/Mar/2025	18:00	
53	RQ237373	PLANNED	OCC_588	MEGPTCL	MAIN BAY - 400KV-VINDHYANCHAL-IV-VINDHYACHAL(PS)-3 AND VINDHYANCHAL-IV - 400KV - BUS 7 at VINDHYANCHAL-IV - 400KV	D	Modification of CFC logic in Main bay BCU relay to for the protect CB circuit (Avoid Damage Aux multiplier relay in CRP panel.)	04/Mar/2025	10:00	04/Mar/2025	18:00	Modification of CFC logic in Main bay BCU relay to for the protect CB circuit (Avoid Damage Aux multiplier relay in CRP panel.)
54	RQ239336	PLANNED	OCC_588	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	04/Mar/2025	08:00	04/Mar/2025	18:00	
55	RQ239179	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	04/Mar/2025	09:00	04/Mar/2025	18:00	
56	RQ239210	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	04/Mar/2025	09:00	04/Mar/2025	18:00	
57	RQ239256	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	04/Mar/2025	08:00	04/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
58	RQ239068	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance work	04/Mar/2025	08:00	04/Mar/2025	18:00	
59	RQ239067	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	400kV Dhule II will be in service but only AR OUT is to be done for safety purpose	04/Mar/2025	08:00	04/Mar/2025	18:00	
60	RQ239241	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode.	04/Mar/2025	09:00	04/Mar/2025	18:00	
61	RQ239066	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	C	400kV Circuit breaker overhauling work will be done by agency	04/Mar/2025	09:00	08/Mar/2025	23:58	
62	RQ239306	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	04/Mar/2025	09:00	04/Mar/2025	18:00	
63	RQ239287	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	04/Mar/2025	09:00	04/Mar/2025	18:00	
64	RQ239333	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	04/Mar/2025	07:00	04/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
65	RQ239300	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Replacement of faulty disc by Hot line Method found during the PID Testing	04/Mar/2025	09:00	04/Mar/2025	17:00	
66	RQ239059	PLANNED	OCC_588	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Outage required for Main Bus -1 outage work.	04/Mar/2025	04:00	06/Mar/2025	18:00	
67	RQ239530	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-CHANDRAPUR-II-DHARIWAL-1 AND CHANDRAPU-II - 400KV - BUS 1 @CHANDRAPUR-II - 400KV at CHANDRAPUR-II - 400KV	D	Diagnostic testing and allied bay maintenance work	04/Mar/2025	09:00	04/Mar/2025	16:00	
68	RQ239057	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 @WARORA - 400KV at WARORA - 400KV	C	CB R, Y, B ph pole Overhauling, CB R, Y, B ph pole Mechanism overhauling Work.	04/Mar/2025	08:00	09/Mar/2025	22:00	
69	RQ237169	PLANNED	OCC_588	POWERGRID_WR1	400KV-KOLHAPUR GIS-MAPUSA-1	D	AMP	05/Mar/2025	08:00	05/Mar/2025	18:00	
70	RQ237526	PLANNED	OCC_588	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	05/Mar/2025	09:00	05/Mar/2025	18:00	Bay Outage
71	RQ239337	PLANNED	OCC_588	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	05/Mar/2025	08:00	05/Mar/2025	18:00	
72	RQ239072	PLANNED	OCC_588	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	05/Mar/2025	08:00	05/Mar/2025	18:00	
73	RQ239180	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	05/Mar/2025	09:00	05/Mar/2025	18:00	
74	RQ239211	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	05/Mar/2025	09:00	05/Mar/2025	18:00	
75	RQ239077	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	05/Mar/2025	09:00	05/Mar/2025	17:30	
76	RQ239073	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	05/Mar/2025	09:00	05/Mar/2025	18:00	
77	RQ239071	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	C	Replacement of 220KV CB of said line by new CB under LE scheme ,shifting of said line on TBC thereof.	05/Mar/2025	08:00	07/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
78	RQ239257	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	05/Mar/2025	08:00	05/Mar/2025	18:00	
79	RQ239075	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	400kv Dhule II will be in service but only AR OUT is to be done for safety purpose	05/Mar/2025	08:00	05/Mar/2025	18:00	
80	RQ239076	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance work	05/Mar/2025	08:00	05/Mar/2025	18:00	
81	RQ239242	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	05/Mar/2025	09:00	05/Mar/2025	18:00	
82	RQ239307	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	05/Mar/2025	09:00	05/Mar/2025	18:00	
83	RQ239288	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	05/Mar/2025	09:00	05/Mar/2025	18:00	
84	RQ239334	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	05/Mar/2025	07:00	05/Mar/2025	18:00	
85	RQ239301	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Replacement of faulty disc by Hot line Method found during the PID Testing	05/Mar/2025	09:00	05/Mar/2025	17:00	
86	RQ236861	PLANNED	OCC_588	POWERGRID_WR1	220KV-RAIPUR-URLA-CHHATTISGARH-1	D	AMP and LBB Relay retrofitting work at Raipur SS	05/Mar/2025	08:00	05/Mar/2025	18:00	AMP and LBB Relay retrofitting work at Raipur SS
87	RQ236816	PLANNED	OCC_588	POWERGRID_WR1	400KV/220KV PUNE-GIS-ICT-2	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	05/Mar/2025	06:00	08/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
88	RQ237620	PLANNED	OCC_588	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Line Bay AMP work.A/R of Ckt 2 is to be kept in non auto mode.	05/Mar/2025	08:00	05/Mar/2025	18:00	Line Bay AMP , LBB Retrofitting works
89	RQ236785	PLANNED	OCC_588	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-2	D	Fine tuning of CSD of ICT	05/Mar/2025	08:00	05/Mar/2025	18:00	Repeated closing/opening of ICT on NO Load will be done
90	RQ236784	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	WTI replacement in Yph LR of 765kv Pune-Padghe Line at Padghe SS	05/Mar/2025	08:00	05/Mar/2025	18:00	
91	RQ236838	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV/220KV PUNE-PG-ICT-2 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	FOR AMP WORK	05/Mar/2025	09:00	05/Mar/2025	17:00	
92	RQ236908	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV/38.5KV SOLAPUR-ICT-1 AND SOLAPUR - 400KV - BUS 1 at Solapur - 400KV	D	Annual Maintennace Plan work of Bay	05/Mar/2025	08:00	05/Mar/2025	18:00	
93	RQ236659	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	C	CB DM Overhauling work & AMP work at Aurangabd S/s.	05/Mar/2025	08:00	08/Mar/2025	18:00	AMP WORK
94	RQ237244	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 220KV - BUS 1 @PUNE-GIS - 220KV at Pune-GIS - 220KV	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	05/Mar/2025	06:00	08/Mar/2025	20:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
95	RQ237245	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 400KV - BUS 1 @PUNE-GIS - 400KV at Pune-GIS - 400KV	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	05/Mar/2025	06:00	08/Mar/2025	20:00	
96	RQ237938	PLANNED	OCC_588	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	D	Simultaneous outage of BOISAR - 400KV - BUS 1 For 400kV Busbar PU/LBB relay retrofitting	06/Mar/2025	07:00	06/Mar/2025	21:00	/PG-WR2- BOISAR///06
97	RQ237284	PLANNED	OCC_588	APML	400KV/11.5KV TIRODA-ST-3	C	Dia Equipment Maintenance	06/Mar/2025	09:00	08/Mar/2025	18:00	
98	RQ237527	PLANNED	OCC_588	MEGPTCL	TIE BAY - 400KV-KORADI-II-KORADI-III-1 AND FUTURE at KORADI-III - 400KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	06/Mar/2025	09:00	06/Mar/2025	18:00	Bay Outage
99	RQ239338	PLANNED	OCC_588	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	06/Mar/2025	08:00	06/Mar/2025	18:00	
100	RQ239181	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	06/Mar/2025	09:00	06/Mar/2025	18:00	
101	RQ239212	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	06/Mar/2025	09:00	06/Mar/2025	18:00	
102	RQ239258	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	06/Mar/2025	08:00	06/Mar/2025	18:00	
103	RQ239243	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	06/Mar/2025	09:00	06/Mar/2025	18:00	
104	RQ239078	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	Hardware tightening, string replacement and cold line washing	06/Mar/2025	09:00	06/Mar/2025	18:00	
105	RQ239080	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-1	D	Insulator String Replacement/ Cold washing. DT testing	06/Mar/2025	08:00	06/Mar/2025	18:00	
106	RQ239308	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	06/Mar/2025	09:00	06/Mar/2025	18:00	
107	RQ239289	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	06/Mar/2025	09:00	06/Mar/2025	18:00	
108	RQ239335	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPLL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	06/Mar/2025	07:00	06/Mar/2025	18:00	
109	RQ239302	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Replacement of faulty disc by Hot line Method found during the PID Testing	06/Mar/2025	09:00	06/Mar/2025	17:00	
110	RQ239536	PLANNED	OCC_588	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400KV	D	Replacement of 89A Bus PG isolator 3 Nos. with Hanger Rod of Bus coupler bay @400kV Chakan.	06/Mar/2025	06:00	06/Mar/2025	23:00	
111	RQ239079	PLANNED	OCC_588	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 1	D	Replacement of 89A Bus PG isolator 3 Nos. with Hanger Rod of Bus coupler bay @400kV Chakan.Cap & Tandelta testing of 400kV Bus CVT	06/Mar/2025	06:00	06/Mar/2025	23:00	
112	RQ239532	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	D	Diagnostic Testing and Routine Maintenance Works	06/Mar/2025	10:00	06/Mar/2025	18:00	
113	RQ239081	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	06/Mar/2025	09:00	06/Mar/2025	17:00	
114	RQ236864	PLANNED	OCC_588	POWERGRID_WR1	400KV-BHILAI-KORADI-1	C	For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE	06/Mar/2025	08:00	07/Mar/2025	18:00	For Construction of 400 kV Raipur Pool - Dhamtari Line
115	RQ239340	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	CT tan delta , Routine Line maintenance work	07/Mar/2025	08:00	07/Mar/2025	18:00	
116	RQ239085	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work	07/Mar/2025	08:00	07/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
117	RQ237528	PLANNED	OCC_588	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	07/Mar/2025	09:00	07/Mar/2025	18:00	Bay Outage
118	RQ239084	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Outage is required for safety purpose during Installation of saver Assembly at various Location of 220kV Tarapur - Borivali Line.	07/Mar/2025	08:00	07/Mar/2025	18:00	
119	RQ239182	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	07/Mar/2025	09:00	07/Mar/2025	18:00	
120	RQ239213	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	07/Mar/2025	09:00	07/Mar/2025	18:00	
121	RQ239083	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BORIVALI-1	D	Installation of saver Assembly at various Location.	07/Mar/2025	08:00	07/Mar/2025	18:00	
122	RQ239259	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	07/Mar/2025	08:00	07/Mar/2025	18:00	
123	RQ239244	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	07/Mar/2025	09:00	07/Mar/2025	18:00	
124	RQ239309	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	07/Mar/2025	09:00	07/Mar/2025	18:00	
125	RQ239290	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	07/Mar/2025	09:00	07/Mar/2025	18:00	
126	RQ239087	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Bus CVT-R-phase oil leakage attend work and isolator maintenance work and DCRM test of 400 kV Bhusawal Main Bay (410)	07/Mar/2025	09:00	07/Mar/2025	17:00	
127	RQ239303	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Replacement of faulty disc by Hot line Method found during the PID Testing	07/Mar/2025	09:00	07/Mar/2025	17:00	
128	RQ239086	PLANNED	OCC_588	MSLDC_OUTAGE	AURANGABAD-M (WALUJ) - 400KV - BUS 2	D	Diagnostic Testing and Routine Maintenance work.	07/Mar/2025	10:00	07/Mar/2025	18:00	
129	RQ236733	PLANNED	OCC_588	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Line Bay AMP work.A/R of Ckt 1 is to be kept in non auto mode.	07/Mar/2025	08:00	07/Mar/2025	18:00	CT Oil sample collecting, Line Bay AMP , LBB Retrofitting works
130	RQ238650	PLANNED	OCC_588	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-3	D	Fine tuning of CSD of ICT	07/Mar/2025	08:00	07/Mar/2025	18:00	
131	RQ236839	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-KALWA-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	FOR AMP WORK	07/Mar/2025	09:00	07/Mar/2025	17:00	
132	RQ236809	PLANNED	OCC_588	POWERGRID_WR1	PARLI - 220KV - BUS 2	C	Erection of Isolator for construction of 01 No of 220kV Bay for Renew Tej Shakti Power at Parli substation	07/Mar/2025	07:00	11/Mar/2025	18:00	Erection of Isolator for construction of 01 No of 220kV Bay for Renew Tej Shakti Power at Parli substation
133	RQ239548	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	08/Mar/2025	06:00	08/Mar/2025	19:00	
134	RQ239091	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	1. Damaged T.NO 51 Replacement Related work. 2. PID Faulty Discs replacement works with PLRI. 3. To attend defects found in Monkey Patrolling	08/Mar/2025	07:00	08/Mar/2025	19:00	
135	RQ239550	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose. During outage For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	08/Mar/2025	06:00	08/Mar/2025	19:00	
136	RQ239089	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For cold washing of disc insulator strings at TL No. 185, 186, 191, 192, 196, 197, 198, 199, 200, 201, 208, 214, 220 & 221.	08/Mar/2025	08:00	08/Mar/2025	17:00	
137	RQ239183	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	08/Mar/2025	09:00	08/Mar/2025	18:00	
138	RQ239214	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	08/Mar/2025	09:00	08/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
139	RQ239088	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BORIVALI-1	D	For cold washing of disc insulator strings at TL No. 185, 186, 191, 192, 196, 197, 198, 199, 200, 201, 208, 214, 220 & 221.	08/Mar/2025	08:00	08/Mar/2025	17:00	
140	RQ239260	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	08/Mar/2025	08:00	08/Mar/2025	18:00	
141	RQ239341	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	CT tan delta , Routine Line maintenance work	08/Mar/2025	08:00	08/Mar/2025	18:00	
142	RQ239090	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Main-I, CT tan delta routine line maintenance work	08/Mar/2025	08:00	08/Mar/2025	18:00	
143	RQ239245	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	08/Mar/2025	09:00	08/Mar/2025	18:00	
144	RQ239310	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	08/Mar/2025	09:00	08/Mar/2025	18:00	
145	RQ239092	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	C	Hardware tightening, string replacement and cold line washing	08/Mar/2025	22:00	09/Mar/2025	06:00	
146	RQ239291	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	08/Mar/2025	09:00	08/Mar/2025	18:00	
147	RQ239304	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Replacement of faulty disc by Hot line Method found during the PID Testing	08/Mar/2025	09:00	08/Mar/2025	17:00	
148	RQ239399	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	08/Mar/2025	07:00	08/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage
149	RQ239391	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	08/Mar/2025	07:00	08/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage
150	RQ239070	PLANNED	OCC_588	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Diagnostic Testing and Routine Maintenance Works	09/Mar/2025	0.458333	09/Mar/2025	0.666667	
151	RQ239551	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose. During outage For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	09/Mar/2025	06:00	09/Mar/2025	19:00	
152	RQ239549	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	09/Mar/2025	06:00	09/Mar/2025	19:00	
153	RQ239184	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	09/Mar/2025	09:00	09/Mar/2025	18:00	
154	RQ239215	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	09/Mar/2025	09:00	09/Mar/2025	18:00	
155	RQ239261	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	09/Mar/2025	08:00	09/Mar/2025	18:00	
156	RQ239094	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1. Damaged T.NO 51 Replacement Related work. 2. PID Faulty Discs replacement works with PLRI. 3. To attend defects found in Monkey Patrolling	09/Mar/2025	07:00	09/Mar/2025	19:00	
157	RQ239246	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	09/Mar/2025	09:00	09/Mar/2025	18:00	
158	RQ239093	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	09/Mar/2025	09:00	09/Mar/2025	18:00	
159	RQ239311	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	09/Mar/2025	09:00	09/Mar/2025	18:00	
160	RQ239292	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	09/Mar/2025	09:00	09/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
161	RQ239400	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	09/Mar/2025	07:00	09/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to Pune/ Padghe to Aurangabad. "
162	RQ239392	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	09/Mar/2025	07:00	09/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to Pune/ Padghe to Aurangabad. "
163	RQ236818	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	Outdoor GIB erection	09/Mar/2025	06:00	10/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
164	RQ236841	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - PUNE-PG - 400KV B/R 1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	FOR AMP WORK	09/Mar/2025	09:00	09/Mar/2025	17:00	
165	RQ239098	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	C	Chemical Washing work, Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	10/Mar/2025	06:00	12/Mar/2025	18:00	
166	RQ237587	PLANNED	OCC_588	TAPS12	220KV-TARAPUR 1&2-BHILAD-1	C	Outage is required for annual maintenance of feedre's equiements (CT, Breaker, isolator, wave trap, CVT, LA etc)	10/Mar/2025	08:00	12/Mar/2025	18:00	
167	RQ237580	PLANNED	OCC_588	DHARIWAL	400KV-CHANDRAPUR-II-DHARIWAL-1	D	Line & its Bay Equipment PM & Testing work	10/Mar/2025	09:00	10/Mar/2025	18:00	
168	RQ239185	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	10/Mar/2025	09:00	10/Mar/2025	18:00	
169	RQ239216	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	10/Mar/2025	09:00	10/Mar/2025	18:00	
170	RQ239095	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For replacement of SSN Insulator String into DSN Insulator String along with Hardwares at various Road/River/Nala/Canal crossing locations	10/Mar/2025	08:00	10/Mar/2025	18:00	
171	RQ239096	PLANNED	OCC_588	MSLDC_OUTAGE	400KV/20KV KORADI-GT-6	C	BREAKER TESTING (CRM, DCRM, TIMING) ,replacement WORK of 290 isolator mechanism box & alignment . Bay routine maintenance work.	10/Mar/2025	09:00	12/Mar/2025	18:00	
172	RQ239100	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Routine Maintenance work	10/Mar/2025	10:00	10/Mar/2025	17:00	
173	RQ239262	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	10/Mar/2025	08:00	10/Mar/2025	18:00	
174	RQ239247	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode.	10/Mar/2025	09:00	10/Mar/2025	18:00	
175	RQ239312	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	10/Mar/2025	09:00	10/Mar/2025	18:00	
176	RQ239293	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	10/Mar/2025	09:00	10/Mar/2025	18:00	
177	RQ239348	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	10/Mar/2025	07:00	10/Mar/2025	18:00	
178	RQ239342	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	10/Mar/2025	09:00	10/Mar/2025	17:00	
179	RQ239535	PLANNED	OCC_588	MSLDC_OUTAGE	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	D	Diagnostic testing & Relay testing work , Routine maint. Work & Chemical Washing work	10/Mar/2025	08:00	10/Mar/2025	18:00	
180	RQ239101	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine Maintenance work	10/Mar/2025	10:00	10/Mar/2025	13:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
181	RQ239102	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	10/Mar/2025	09:00	10/Mar/2025	17:00	
182	RQ239099	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Routine Maintenance work	10/Mar/2025	14:00	10/Mar/2025	17:00	
183	RQ239097	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	10/Mar/2025	09:00	10/Mar/2025	17:00	
184	RQ239533	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	D	Diagnostic Testing and Routine Maintenance Works	10/Mar/2025	10:00	10/Mar/2025	18:00	
185	RQ239534	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY OF 400KV-IEPL-WARORA-1 AND FUTURE @WARORA - 400KV at WARORA - 400KV	C	CB R, Y, B ph pole Overhauling, CB R, Y, B ph pole Mechanism overhauling Work.	10/Mar/2025	08:00	15/Mar/2025	22:00	
186	RQ236734	PLANNED	OCC_588	POWERGRID_WR1	400KV-KOLHAPUR-MS-ALKUD-1	D	Line Bay AMP works	10/Mar/2025	08:00	10/Mar/2025	18:00	Line Bay AMP , LBB Retrofitting and Relay testing works
187	RQ236800	PLANNED	OCC_588	POWERGRID_WR1	400KV-PARLI-SOLAPUR-2	D	For annual maintenace work of Line Bay at Parli substation	10/Mar/2025	07:00	10/Mar/2025	18:00	For annual maintenace work of Line Bay at Parli substation
188	RQ237138	PLANNED	OCC_588	POWERGRID_WR1	400KV-PARLI-SOLAPUR-2	D	Replacement of B.Ph CVT due to voltage drift (+2.3V)	10/Mar/2025	07:00	10/Mar/2025	18:00	
189	RQ239401	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS BY POWERGRID	10/Mar/2025	07:00	10/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to
190	RQ239393	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS BY POWERGRID	10/Mar/2025	07:00	10/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to
191	RQ236842	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	FOR AMP WORK	10/Mar/2025	09:00	10/Mar/2025	17:00	
192	RQ237943	PLANNED	OCC_588	POWERGRID_WR2	BOISAR - 400KV - BUS 2	C	Continuous outage of 400 kV Bus-2 for Bus-bar relay retrofitting & testing	11/Mar/2025	07:00	21/Mar/2025	21:00	/PG-WR2- BOISAR///11
193	RQ237581	PLANNED	OCC_588	DHARIWAL	400KV-CHANDRAPUR-II-DHARIWAL-1	D	Line & its Bay Equipment PM & Testing work	11/Mar/2025	09:00	11/Mar/2025	18:00	
194	RQ237530	PLANNED	OCC_588	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	11/Mar/2025	09:00	11/Mar/2025	18:00	Bay Outage
195	RQ239186	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	11/Mar/2025	09:00	11/Mar/2025	18:00	
196	RQ239217	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	11/Mar/2025	09:00	11/Mar/2025	18:00	
197	RQ239103	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintainance work	11/Mar/2025	08:00	11/Mar/2025	18:00	
198	RQ239263	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	11/Mar/2025	08:00	11/Mar/2025	18:00	
199	RQ239248	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	11/Mar/2025	09:00	11/Mar/2025	18:00	
200	RQ239313	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	11/Mar/2025	09:00	11/Mar/2025	18:00	
201	RQ239294	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	11/Mar/2025	09:00	11/Mar/2025	18:00	
202	RQ239349	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	11/Mar/2025	07:00	11/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
203	RQ239343	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	11/Mar/2025	09:00	11/Mar/2025	17:00	
204	RQ236663	PLANNED	OCC_588	POWERGRID_WR1	220KV-AURANGABAD-CHITEGAON-1	D	AMP of Line terminal equipments at Aurangabad S/s.	11/Mar/2025	08:00	11/Mar/2025	18:00	AMP WORK
205	RQ239402	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	11/Mar/2025	07:00	11/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (1.6 Hours) between Padgh to
206	RQ239394	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	11/Mar/2025	07:00	11/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage
207	RQ236942	PLANNED	OCC_588	POWERGRID_WR1	BUS COUPLER BAY - WARDHA - 220KV - BUS 1 AND WARDHA - 220KV - BUS 2 at Wardha - 220KV	C	Main bay 201 will remain out for O/H work for 7 days & For Bay AMP Works	11/Mar/2025	08:00	17/Mar/2025	20:00	201
208	RQ237089	PLANNED	OCC_588	POWERGRID_WR1	CHAMPA - 765KV B/R 2	D	To attend minor oil seepage from Radiator of Yph unit. Dia to be kept open.	11/Mar/2025	09:30	11/Mar/2025	17:30	
209	RQ236665	PLANNED	OCC_588	POWERGRID_WR1	DHULE-MS - 400KV B/R 2	C	CT REPLACEMENT & REACTOR AMP WORK At Dhule S/s.	11/Mar/2025	08:00	13/Mar/2025	18:00	CT REPLACEMENT & REACTOR AMP WORK
210	RQ236664	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 220KV-AURANGABAD-CHITEGAON-1 AND AURANGABAD - 220KV - BUS 1 at AURANGABAD - 220KV	D	AMP of BAY at Aurangabad S/s.	11/Mar/2025	08:00	11/Mar/2025	18:00	AMP WORK
211	RQ236820	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	Outdoor GIB erection	11/Mar/2025	06:00	12/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
212	RQ236843	PLANNED	OCC_588	POWERGRID_WR1	PUNE-PG - 220KV - BUS 2	D	FOR AMP WORK	11/Mar/2025	09:00	11/Mar/2025	17:00	Each bay will be taken on TBC bay
213	RQ238163	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	11/Mar/2025	08:00	11/Mar/2025	18:00	AR disable
214	RQ238184	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	11/Mar/2025	08:00	11/Mar/2025	18:00	AR disable
215	RQ236844	PLANNED	OCC_588	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	Rectification of conductor unwind	12/Mar/2025	09:00	12/Mar/2025	17:00	Line owned by MSETCL
216	RQ236735	PLANNED	OCC_588	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line Bay AMP works	12/Mar/2025	0.875	13/Mar/2025	0.25	Line Bay AMP , LBB Retrofitting and Relay testing works
217	RQ237582	PLANNED	OCC_588	DHARIWAL	400KV-CHANDRAPUR-II-DHARIWAL-2	D	Line & its Bay Equipment PM & Testing work	12/Mar/2025	09:00	12/Mar/2025	18:00	
218	RQ237531	PLANNED	OCC_588	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	12/Mar/2025	09:00	12/Mar/2025	18:00	Bay Outage
219	RQ239108	PLANNED	OCC_588	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	12/Mar/2025	08:00	12/Mar/2025	18:00	
220	RQ239109	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	12/Mar/2025	09:00	12/Mar/2025	18:00	
221	RQ239107	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	For routine maintenance work	12/Mar/2025	08:00	12/Mar/2025	18:00	
222	RQ239187	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	12/Mar/2025	09:00	12/Mar/2025	18:00	
223	RQ239218	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	12/Mar/2025	09:00	12/Mar/2025	18:00	
224	RQ239112	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line / s/sMaintenance	12/Mar/2025	09:00	12/Mar/2025	17:30	
225	RQ239105	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	12/Mar/2025	08:00	12/Mar/2025	18:00	
226	RQ239264	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	12/Mar/2025	08:00	12/Mar/2025	18:00	
227	RQ239111	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	C	Half yearly Routine Maintenance Work & Cap &Tandelta measurment of CT & CVT & testing work. Cold line washing of strings	12/Mar/2025	22:00	13/Mar/2025	06:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
228	RQ239249	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	12/Mar/2025	09:00	12/Mar/2025	18:00	
229	RQ239314	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	12/Mar/2025	09:00	12/Mar/2025	18:00	
230	RQ239295	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	12/Mar/2025	09:00	12/Mar/2025	18:00	
231	RQ239110	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening, string replacement and cold line washing	12/Mar/2025	09:00	12/Mar/2025	18:00	
232	RQ239350	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	12/Mar/2025	07:00	12/Mar/2025	18:00	
233	RQ239104	PLANNED	OCC_588	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Maintenance of isolator of all feeders connected to Main Bus 2	12/Mar/2025	08:00	12/Mar/2025	17:00	
234	RQ239403	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	12/Mar/2025	07:00	12/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage
235	RQ239395	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	12/Mar/2025	07:00	12/Mar/2025	18:00	
236	RQ236681	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND BHADRAWATI - 400KV - BUS 2 at BHADRAWATI - 400KV	D	Cleaning of polymer CT	12/Mar/2025	09:00	12/Mar/2025	18:00	Cleaning of polymer CT
237	RQ238164	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	12/Mar/2025	08:00	12/Mar/2025	18:00	AR disable
238	RQ238185	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	12/Mar/2025	08:00	12/Mar/2025	18:00	AR disable
239	RQ239118	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work	13/Mar/2025	08:00	13/Mar/2025	18:00	
240	RQ237583	PLANNED	OCC_588	DHARIWAL	400KV-CHANDRAPUR-II-DHARIWAL-2	D	Line & its Bay Equipment PM & Testing work	13/Mar/2025	09:00	13/Mar/2025	18:00	
241	RQ239188	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	13/Mar/2025	09:00	13/Mar/2025	18:00	
242	RQ239219	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	13/Mar/2025	09:00	13/Mar/2025	18:00	
243	RQ239114	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintainance work	13/Mar/2025	08:00	13/Mar/2025	18:00	
244	RQ239265	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	13/Mar/2025	08:00	13/Mar/2025	18:00	
245	RQ239250	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL, A/R function to be in non auto mode.	13/Mar/2025	09:00	13/Mar/2025	18:00	
246	RQ239315	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	13/Mar/2025	09:00	13/Mar/2025	18:00	
247	RQ239296	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	13/Mar/2025	09:00	13/Mar/2025	18:00	
248	RQ239113	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	To carry out maintenance work like disc repalcement and nut bolt tightining at various locations	13/Mar/2025	06:00	13/Mar/2025	18:00	
249	RQ239345	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	13/Mar/2025	09:00	13/Mar/2025	17:00	
250	RQ239115	PLANNED	OCC_588	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Maintenance of isolator of all feeders connected to Main Bus 2	13/Mar/2025	08:00	13/Mar/2025	17:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
251	RQ239117	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	13/Mar/2025	09:00	13/Mar/2025	17:00	
252	RQ239537	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	D	CB diagnostic testing and routine maintenance work	13/Mar/2025	11:00	13/Mar/2025	18:00	
253	RQ239116	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY OF 400KV-KALA-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	Annual Maintenance of bays equipment & Diagnostics Testing Work	13/Mar/2025	09:00	13/Mar/2025	17:00	
254	RQ239404	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	13/Mar/2025	07:00	13/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to
255	RQ239396	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	13/Mar/2025	07:00	13/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage
256	RQ238165	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	13/Mar/2025	08:00	13/Mar/2025	18:00	AR disable
257	RQ238186	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	13/Mar/2025	08:00	13/Mar/2025	18:00	AR disable
258	RQ239121	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Outage is required for safety purpose during Installation of saver Assembly at various Loction & Line maintenance work of 220kv Tarapur - Boisar Line.	14/Mar/2025	09:00	14/Mar/2025	18:00	
259	RQ239189	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	14/Mar/2025	09:00	14/Mar/2025	18:00	
260	RQ239220	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	14/Mar/2025	09:00	14/Mar/2025	18:00	
261	RQ239120	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	Installation of saver Assembly at various Location & Line maintenance work	14/Mar/2025	09:00	14/Mar/2025	18:00	
262	RQ239119	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintainance work	14/Mar/2025	08:00	14/Mar/2025	18:00	
263	RQ239266	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	14/Mar/2025	08:00	14/Mar/2025	18:00	
264	RQ239122	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work	14/Mar/2025	08:00	14/Mar/2025	18:00	
265	RQ239251	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode.	14/Mar/2025	09:00	14/Mar/2025	18:00	
266	RQ239316	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	14/Mar/2025	09:00	14/Mar/2025	18:00	
267	RQ239568	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	C	For erection of Towers and diversion of Ckt on newly erected Towers at Loc. No. 166A & 167A (including stringing from Loc. No. 165 to 168)	14/Mar/2025	22:00	15/Mar/2025	06:00	MRVCL project work
268	RQ239297	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. Only AR will be kept off. Line will be in service	14/Mar/2025	09:00	14/Mar/2025	18:00	
269	RQ239405	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	14/Mar/2025	07:00	14/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to Pune/ Padghe to Aurangabad. "
270	RQ239397	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	14/Mar/2025	07:00	14/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to Pune/ Padghe to Aurangabad. "
271	RQ238166	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	14/Mar/2025	08:00	14/Mar/2025	18:00	AR disable
272	RQ238187	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	14/Mar/2025	08:00	14/Mar/2025	18:00	AR disable

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
273	RQ237944	PLANNED	OCC_588	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	D	Simultaneous outage of BOISAR - 400KV - BUS 2 For 400kV Busbar PU/LBB relay retrofitting	15/Mar/2025	07:00	15/Mar/2025	21:00	/PG-WR2- BOISAR///12
274	RQ239124	PLANNED	OCC_588	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	C	220kV A-Bus Isolator routine maintenance works.	15/Mar/2025	07:00	16/Mar/2025	20:00	
275	RQ239556	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose. For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor.	15/Mar/2025	06:00	15/Mar/2025	19:00	
276	RQ239554	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor.	15/Mar/2025	06:00	15/Mar/2025	19:00	
277	RQ239190	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	15/Mar/2025	09:00	15/Mar/2025	18:00	
278	RQ239221	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	15/Mar/2025	09:00	15/Mar/2025	18:00	
279	RQ239125	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	LBB Relay	15/Mar/2025	09:00	15/Mar/2025	18:00	
280	RQ239252	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCL A/R function to be in non auto mode.	15/Mar/2025	09:00	15/Mar/2025	18:00	
281	RQ239317	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	15/Mar/2025	09:00	15/Mar/2025	18:00	
282	RQ239569	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	C	Shifted on ERS for Erection 2 tower from Loc 165 to 168 for MRVCL Work	15/Mar/2025	08:00	22/Mar/2025	20:00	MRVCL project work
283	RQ239298	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing. Only AR will be kept off. Line will be in service	15/Mar/2025	09:00	15/Mar/2025	18:00	
284	RQ239123	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	To carry out maintenance work like disc replacemnt and nut bolt tightening at various locations	15/Mar/2025	06:00	15/Mar/2025	18:00	
285	RQ239347	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	15/Mar/2025	09:00	15/Mar/2025	17:00	
286	RQ239406	PLANNED	OCC_588	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	15/Mar/2025	07:00	15/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage required (6 Hours) between Padgh to Pune/ Padghe to Aurangabad. "
287	RQ239398	PLANNED	OCC_588	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	15/Mar/2025	07:00	15/Mar/2025	18:00	"Rectification of OPGW between Tower no 492 to Tower no 494. 6 No of Fiber are in break down. Data Outage
288	RQ238167	PLANNED	OCC_588	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	15/Mar/2025	08:00	15/Mar/2025	18:00	AR disable
289	RQ238188	PLANNED	OCC_588	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	15/Mar/2025	08:00	15/Mar/2025	18:00	AR disable
290	RQ239267	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	16/Mar/2025	08:00	16/Mar/2025	18:00	
291	RQ239268	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	16/Mar/2025	08:00	16/Mar/2025	18:00	
292	RQ239126	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1. Damaged T.NO 51 Replacement Related work. 2. PID Faulty Discs replacement works with PLRI. 3. To attend defects found in Monkey Patrolling	16/Mar/2025	08:00	16/Mar/2025	18:00	
293	RQ237945	PLANNED	OCC_588	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	Simultaneous outage of BOISAR - 400KV - BUS 2 For 400kV Busbar PU/LBB relay retrofitting	16/Mar/2025	07:00	16/Mar/2025	21:00	/PG-WR2- BOISAR///13
294	RQ237159	PLANNED	OCC_588	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	Tower stub repair work and shutdown nature defect rectification	16/Mar/2025	08:00	16/Mar/2025	20:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
295	RQ237160	PLANNED	OCC_588	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	Tower stub repair work and shutdown nature defect rectification	16/Mar/2025	08:00	16/Mar/2025	20:00	
296	RQ236821	PLANNED	OCC_588	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 1	D	For HV test and PD measurement	16/Mar/2025	06:00	16/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
297	RQ237522	PLANNED	OCC_588	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Annual Maintenance of line	16/Mar/2025	08:00	16/Mar/2025	18:00	ANNUAL OUTAGE
298	RQ239557	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose. For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor.	16/Mar/2025	06:00	16/Mar/2025	19:00	
299	RQ239555	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor.	16/Mar/2025	06:00	16/Mar/2025	19:00	
300	RQ239191	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	16/Mar/2025	09:00	16/Mar/2025	18:00	
301	RQ239222	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	16/Mar/2025	09:00	16/Mar/2025	18:00	
302	RQ239318	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	16/Mar/2025	09:00	16/Mar/2025	18:00	
303	RQ239128	PLANNED	OCC_588	MSLDC_OUTAGE	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	D	1. Bay Maintenance Work. 2. Diagnostic Testing work. 3. Back up Relay replacement work. 4. Tie CB of HVDC will act as Bus coupler.	16/Mar/2025	09:00	16/Mar/2025	18:30	
304	RQ236847	PLANNED	OCC_588	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4 L/R@ PUNE-PG - 400KV	D	FOR AMP WORK	16/Mar/2025	09:00	16/Mar/2025	17:00	Line will be service without reactor
305	RQ237246	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 220KV - BUS 1 @PUNE-GIS - 220KV at Pune-GIS - 220KV	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	16/Mar/2025	06:00	18/Mar/2025	20:00	
306	RQ237247	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 400KV - BUS 1 @PUNE-GIS - 400KV at Pune-GIS - 400KV	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	16/Mar/2025	06:00	18/Mar/2025	20:00	
307	RQ236823	PLANNED	OCC_588	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 1	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	16/Mar/2025	06:00	18/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
308	RQ238168	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	16/Mar/2025	08:00	16/Mar/2025	18:00	AR disable
309	RQ238189	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	16/Mar/2025	08:00	16/Mar/2025	18:00	AR disable
310	RQ237946	PLANNED	OCC_588	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	D	Simultaneous outage of BOISAR - 400KV - BUS 2 For 400KV Busbar PU/LBB relay retrofitting	17/Mar/2025	07:00	17/Mar/2025	21:00	/PG-WR2- BOISAR///14
311	RQ239069	PLANNED	OCC_588	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Bus CVT Tan Delta	17/Mar/2025	08:00	17/Mar/2025	18:00	
312	RQ237535	PLANNED	OCC_588	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	17/Mar/2025	09:00	17/Mar/2025	18:00	Bay Outage
313	RQ239192	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	17/Mar/2025	09:00	17/Mar/2025	18:00	
314	RQ239223	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	17/Mar/2025	09:00	17/Mar/2025	18:00	
315	RQ239129	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For replacement of SSN Insulator String into DSN Insulator String along with Hardwares at various Road/River/Nala/Canal crossing locations	17/Mar/2025	08:00	17/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
316	RQ239269	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	17/Mar/2025	08:00	17/Mar/2025	18:00	
317	RQ239319	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	17/Mar/2025	09:00	17/Mar/2025	18:00	
318	RQ239374	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	17/Mar/2025	09:00	17/Mar/2025	18:00	
319	RQ239130	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	C	Chemical Washing work & Cold washing work	17/Mar/2025	06:00	20/Mar/2025	18:00	
320	RQ239363	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	17/Mar/2025	07:00	17/Mar/2025	18:00	
321	RQ239357	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	17/Mar/2025	09:00	17/Mar/2025	17:00	
322	RQ239351	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Replacement of faulty disc by Hot line Method found during the PID Testing	17/Mar/2025	09:00	17/Mar/2025	17:00	
323	RQ239131	PLANNED	OCC_588	MSLDC_OUTAGE	PADGHE - 400KV B/R 1	C	1) Areva CB Pole Overhauling work. 2) A & B Bus PG Isolator Maintenance work. 3) Diagnostic Testing work. 4) Replacement of Back Up Relay work. 5) NIFPS (CTR) maintenance work.	17/Mar/2025	09:00	23/Mar/2025	18:30	
324	RQ236668	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	C	CB DM Overhauling work & AMP work at Aurangabd S/s.	17/Mar/2025	08:00	20/Mar/2025	18:00	AMP WORK
325	RQ236782	PLANNED	OCC_588	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-2 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	AMP of Bay Equipment	17/Mar/2025	08:00	17/Mar/2025	18:00	
326	RQ238169	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	17/Mar/2025	08:00	17/Mar/2025	18:00	AR disable
327	RQ238190	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	17/Mar/2025	08:00	17/Mar/2025	18:00	AR disable
328	RQ237947	PLANNED	OCC_588	POWERGRID_WR2	400KV/220KV BOISAR-ICT-1	D	Simultaneous outage of BOISAR - 400KV - BUS 2 For 400KV Busbar PU/LBB relay retrofitting	18/Mar/2025	07:00	18/Mar/2025	21:00	/PG-WR2- BOISAR//15
329	RQ239193	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	18/Mar/2025	09:00	18/Mar/2025	18:00	
330	RQ239224	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	18/Mar/2025	09:00	18/Mar/2025	18:00	
331	RQ239270	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	18/Mar/2025	08:00	18/Mar/2025	18:00	
332	RQ239132	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Line maintenance works	18/Mar/2025	10:00	18/Mar/2025	17:00	
333	RQ239320	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	18/Mar/2025	09:00	18/Mar/2025	18:00	
334	RQ239134	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Routine Maintenance work	18/Mar/2025	10:00	18/Mar/2025	17:00	
335	RQ239375	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	18/Mar/2025	09:00	18/Mar/2025	18:00	
336	RQ239364	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	18/Mar/2025	07:00	18/Mar/2025	18:00	
337	RQ239358	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	18/Mar/2025	09:00	18/Mar/2025	17:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
338	RQ239352	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Replacement of faulty disc by Hot line Method found during the PID Testing	18/Mar/2025	09:00	18/Mar/2025	17:00	
339	RQ239135	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine Maintenance work	18/Mar/2025	10:00	18/Mar/2025	13:00	
340	RQ239133	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARORA-CHANDRAPU-II-2 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	C	Mechanism overhauling Work. of CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	18/Mar/2025	08:00	21/Mar/2025	18:00	
341	RQ239538	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE at ALKUD - 400KV	D	Routine Maintenance work	18/Mar/2025	14:00	18/Mar/2025	17:00	
342	RQ236783	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV-PADGHE-PG-KUDUS-2 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV	D	AMP of Bay Equipment	18/Mar/2025	08:00	18/Mar/2025	18:00	
343	RQ238170	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	18/Mar/2025	08:00	18/Mar/2025	18:00	AR disable
344	RQ238191	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	18/Mar/2025	08:00	18/Mar/2025	18:00	AR disable
345	RQ236817	PLANNED	OCC_588	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	C	Outdoor GIB erection	19/Mar/2025	06:00	19/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI
346	RQ237948	PLANNED	OCC_588	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	Simultaneous outage of BOISAR - 400KV - BUS 2 For 400kV Busbar PU/LBB relay retrofitting	19/Mar/2025	07:00	19/Mar/2025	21:00	/PG-WR2- BOISAR///16
347	RQ239138	PLANNED	OCC_588	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	For routine maintenance work	19/Mar/2025	08:00	19/Mar/2025	18:00	
348	RQ239194	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	19/Mar/2025	09:00	19/Mar/2025	18:00	
349	RQ239143	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line, s/s Maintenance	19/Mar/2025	09:00	19/Mar/2025	17:30	
350	RQ239225	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	19/Mar/2025	09:00	19/Mar/2025	18:00	
351	RQ239271	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	19/Mar/2025	08:00	19/Mar/2025	18:00	
352	RQ239321	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	19/Mar/2025	09:00	19/Mar/2025	18:00	
353	RQ239140	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	C	Half yearly Routine Maintenance Work & Testing work. Cold line washing of strings	19/Mar/2025	22:00	20/Mar/2025	06:00	
354	RQ239376	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	19/Mar/2025	09:00	19/Mar/2025	18:00	
355	RQ239365	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	19/Mar/2025	07:00	19/Mar/2025	18:00	
356	RQ239139	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening, string replacement and cold line washing	19/Mar/2025	09:00	19/Mar/2025	18:00	
357	RQ239359	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	19/Mar/2025	09:00	19/Mar/2025	17:00	
358	RQ239353	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Replacement of faulty disc by Hot line Method found during the PID Testing	19/Mar/2025	09:00	19/Mar/2025	17:00	
359	RQ239142	PLANNED	OCC_588	MSLDC_OUTAGE	KORADI - 400KV - BUS 1	D	BUS-1 CVT TESTING WORK	19/Mar/2025	05:00	19/Mar/2025	18:00	
360	RQ236952	PLANNED	OCC_588	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	AMP of Line Bay	19/Mar/2025	08:00	19/Mar/2025	20:00	202L
361	RQ236826	PLANNED	OCC_588	POWERGRID_WR1	400KV/220KV PUNE-GIS-ICT-2	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	19/Mar/2025	06:00	21/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
362	RQ236951	PLANNED	OCC_588	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Amp of Line Bay & Reactor Bay	19/Mar/2025	08:00	19/Mar/2025	20:00	BHI

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
363	RQ236848	PLANNED	OCC_588	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3 L/R@ PUNE-PG - 400KV	D	FOR AMP WORK	19/Mar/2025	09:00	19/Mar/2025	17:00	Line will be service without reactor
364	RQ236737	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR-MS - 400KV - BUS 1 AT KOLHAPUR-MS - 400KV	D	Main BAY AMP WORK	19/Mar/2025	08:00	19/Mar/2025	18:00	Main Bay AMP work
365	RQ237248	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 220KV - BUS 1 @PUNE-GIS - 220KV at Pune-GIS - 220KV	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	19/Mar/2025	06:00	21/Mar/2025	20:00	
366	RQ237249	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV/220KV PUNE-GIS-ICT-2 AND PUNE-GIS - 400KV - BUS 1 @PUNE-GIS - 400KV at Pune-GIS - 400KV	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	19/Mar/2025	06:00	21/Mar/2025	20:00	
367	RQ236788	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF PADGHE-PG - 400KV B/R 1 AND PADGHE-PG - 400KV - BUS 2 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	D	DCRM & Timing test of CB	19/Mar/2025	08:00	19/Mar/2025	18:00	
368	RQ236825	PLANNED	OCC_588	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	C	For bus bar interconnection work(internal conductor fixing) bus bar testing and bus stability	19/Mar/2025	06:00	21/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
369	RQ236955	PLANNED	OCC_588	POWERGRID_WR1	WARDHA - 220KV - BUS 1	D	For Amp of Bus Bar	19/Mar/2025	08:00	19/Mar/2025	20:00	2BB1
370	RQ238171	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	19/Mar/2025	08:00	19/Mar/2025	18:00	AR disable
371	RQ238192	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	19/Mar/2025	08:00	19/Mar/2025	18:00	AR disable
372	RQ239136	PLANNED	OCC_588	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	1) Maintenance of isolator of all feeders connected to Main Bus 1	20/Mar/2025	08:00	20/Mar/2025	17:00	
373	RQ239539	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARIAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	20/Mar/2025	0.916667	21/Mar/2025	0.208333	
374	RQ236819	PLANNED	OCC_588	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	C	Outdoor GIB erection	20/Mar/2025	06:00	21/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
375	RQ239195	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	20/Mar/2025	09:00	20/Mar/2025	18:00	
376	RQ239226	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	20/Mar/2025	09:00	20/Mar/2025	18:00	
377	RQ239145	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	20/Mar/2025	08:00	20/Mar/2025	18:00	
378	RQ239272	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	20/Mar/2025	08:00	20/Mar/2025	18:00	
379	RQ239144	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-2	D	Routine maintenance work (For replacement of Jumper at Location No. 314)	20/Mar/2025	08:00	20/Mar/2025	18:00	
380	RQ239146	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	D	Insulator String Replacement/ Cold washing. DT testing	20/Mar/2025	0.916667	21/Mar/2025	0.208333	
381	RQ239322	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	20/Mar/2025	09:00	20/Mar/2025	18:00	
382	RQ239366	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	20/Mar/2025	07:00	20/Mar/2025	18:00	
383	RQ239360	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	20/Mar/2025	09:00	20/Mar/2025	17:00	
384	RQ239354	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Replacement of faulty disc by Hot line Method found during the PID Testing	20/Mar/2025	09:00	20/Mar/2025	17:00	
385	RQ239540	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	20/Mar/2025	09:00	20/Mar/2025	17:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
386	RQ236849	PLANNED	OCC_588	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2 L/R@ PUNE-PG - 400KV	D	FOR AMP WORK	20/Mar/2025	09:00	20/Mar/2025	17:00	Line will be service without reactor
387	RQ237184	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	D	DCRM & Timing test of CB	20/Mar/2025	07:00	20/Mar/2025	18:00	
388	RQ238172	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	20/Mar/2025	08:00	20/Mar/2025	18:00	AR disable
389	RQ238193	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	20/Mar/2025	08:00	20/Mar/2025	18:00	AR disable
390	RQ237543	PLANNED	OCC_588	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	C	TOWER STRENGTHENING WORK- WZ-2	21/Mar/2025	08:00	30/Mar/2025	18:00	LINE OUTAGE
391	RQ236822	PLANNED	OCC_588	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	D	For HV test and PD measurement	21/Mar/2025	06:00	21/Mar/2025	20:00	Outage is being proposed for construction works under WRES-XXXI project
392	RQ239149	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Outage is required for safety purpose during Installation of saver Assembly at various Location & Line maintenance work on 220kV Tarapur - Boisar Line.	21/Mar/2025	09:00	21/Mar/2025	18:00	
393	RQ239196	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	21/Mar/2025	09:00	21/Mar/2025	18:00	
394	RQ239227	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	21/Mar/2025	09:00	21/Mar/2025	18:00	
395	RQ239148	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	Installation of saver Assembly at various Location & Line maintenance work	21/Mar/2025	09:00	21/Mar/2025	18:00	
396	RQ239147	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	21/Mar/2025	08:00	21/Mar/2025	18:00	
397	RQ239273	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	21/Mar/2025	08:00	21/Mar/2025	18:00	
398	RQ239323	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	21/Mar/2025	09:00	21/Mar/2025	18:00	
399	RQ239127	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	C	Hardware tightening, string replacement and cold line washing	21/Mar/2025	22:00	21/Mar/2025	06:00	
400	RQ239377	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	21/Mar/2025	22:00	21/Mar/2025	06:00	
401	RQ239378	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	21/Mar/2025	09:00	21/Mar/2025	18:00	
402	RQ239367	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	21/Mar/2025	07:00	21/Mar/2025	18:00	
403	RQ239361	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	21/Mar/2025	09:00	21/Mar/2025	17:00	
404	RQ239355	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Replacement of faulty disc by Hot line Method found during the PID Testing	21/Mar/2025	09:00	21/Mar/2025	17:00	
405	RQ239150	PLANNED	OCC_588	MSLDC_OUTAGE	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR -	C	For Replacement of 400kV R phase BUS Span of 400kV TBC & BC and Routine Maintenance Work	21/Mar/2025	08:00	23/Mar/2025	18:00	
406	RQ236850	PLANNED	OCC_588	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1 L/R@ PUNE-PG - 400KV	D	FOR AMP WORK	21/Mar/2025	09:00	21/Mar/2025	17:00	Line will be service without reactor
407	RQ236670	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	D	AMP of BAY at Waluj S/s.	21/Mar/2025	08:00	21/Mar/2025	18:00	AMP WORK

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
408	RQ237185	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	D	DCRM & Timing test of CB	21/Mar/2025	07:00	21/Mar/2025	18:00	
409	RQ237250	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY OF 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	D	Main BAY AMP WORK	21/Mar/2025	08:00	21/Mar/2025	18:00	
410	RQ238173	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	21/Mar/2025	08:00	21/Mar/2025	18:00	AR disable
411	RQ238194	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	21/Mar/2025	08:00	21/Mar/2025	18:00	AR disable
412	RQ236815	PLANNED	OCC_588	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 1	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/errection purpose)	22/Mar/2025	06:00	24/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
413	RQ239560	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conducto	22/Mar/2025	06:00	22/Mar/2025	19:00	
414	RQ239155	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220KV PGCIL(Boisar)-Panchali Line.	22/Mar/2025	06:00	22/Mar/2025	19:00	
415	RQ239562	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose .For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	22/Mar/2025	06:00	22/Mar/2025	19:00	
416	RQ239197	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	22/Mar/2025	09:00	22/Mar/2025	18:00	
417	RQ239228	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	22/Mar/2025	09:00	22/Mar/2025	18:00	
418	RQ239156	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	1) Bay strengthening of 220kv Tarapur Bay & 220kv Ghodbunder Bay. 2) Bay maintenance & equipment testing of 220kv B Bus.	22/Mar/2025	08:00	22/Mar/2025	18:00	
419	RQ239158	PLANNED	OCC_588	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-2	C	CB pole overhauling work. 400/220 KV ICT II HV will be in service through TBC	22/Mar/2025	08:00	26/Mar/2025	18:00	
420	RQ239274	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	22/Mar/2025	08:00	22/Mar/2025	18:00	
421	RQ239152	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Line maintenance works	22/Mar/2025	10:00	22/Mar/2025	17:00	
422	RQ239157	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	C	Circuit breaker overhauling work along with quarterly maintenance work. Line will be service through TBC at Karad end	22/Mar/2025	09:00	25/Mar/2025	17:00	
423	RQ239324	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	22/Mar/2025	09:00	22/Mar/2025	18:00	
424	RQ239379	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-2	D	PID testing. Only AR will be kept off. Line will be in service	22/Mar/2025	09:00	22/Mar/2025	18:00	
425	RQ239368	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	22/Mar/2025	07:00	22/Mar/2025	18:00	
426	RQ239362	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	22/Mar/2025	09:00	22/Mar/2025	17:00	
427	RQ239356	PLANNED	OCC_588	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Replacement of faulty disc by Hot line Method found during the PID Testing	22/Mar/2025	09:00	22/Mar/2025	17:00	
428	RQ239153	PLANNED	OCC_588	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARORA-CHANDRAPU-II-1 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	C	Mechanism overhauling Work. of CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	22/Mar/2025	09:00	25/Mar/2025	18:00	
429	RQ238174	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	22/Mar/2025	08:00	22/Mar/2025	18:00	AR disable

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
430	RQ238195	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	22/Mar/2025	08:00	22/Mar/2025	18:00	AR disable
431	RQ239159	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	23/Mar/2025	09:00	23/Mar/2025	18:00	
432	RQ239160	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220KV PGCL(Boisar)-Panchali Line.	23/Mar/2025	06:00	23/Mar/2025	19:00	
433	RQ239563	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose .For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	23/Mar/2025	06:00	23/Mar/2025	19:00	
434	RQ239561	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conducto	23/Mar/2025	06:00	23/Mar/2025	19:00	
435	RQ239198	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	23/Mar/2025	09:00	23/Mar/2025	18:00	
436	RQ239229	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	23/Mar/2025	09:00	23/Mar/2025	18:00	
437	RQ239161	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	D	For chemical washing of insulator strings at various locations.	23/Mar/2025	09:00	23/Mar/2025	18:00	
438	RQ239275	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	23/Mar/2025	08:00	23/Mar/2025	18:00	
439	RQ239325	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	23/Mar/2025	09:00	23/Mar/2025	18:00	
440	RQ239570	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	C	for diversion of Ckt from ERS Towers to newly erected Towers at Loc. No. 166A & 167A (including stringing from Loc. No. 165 to 168).	23/Mar/2025	22:00	24/Mar/2025	06:00	MRVCL project work
441	RQ239380	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	23/Mar/2025	09:00	23/Mar/2025	18:00	
442	RQ239369	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	23/Mar/2025	07:00	23/Mar/2025	18:00	
443	RQ238175	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	23/Mar/2025	08:00	23/Mar/2025	18:00	AR disable
444	RQ238196	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	23/Mar/2025	08:00	23/Mar/2025	18:00	AR disable
445	RQ237951	PLANNED	OCC_588	POWERGRID_WR2	400KV/220KV BOISAR-ICT-1	D	Simultaneous outages of 400KV/220KV BOISAR-ICT-1 and 400KV-PADGHE-BOISAR-1 I required For Tie bay LBB relay retrofitting & testing	24/Mar/2025	07:00	24/Mar/2025	21:00	/PG-WR2- BOISAR///19
446	RQ236827	PLANNED	OCC_588	POWERGRID_WR1	765KV/400KV PUNE-GIS-ICT-1	D	Spare change over work	24/Mar/2025	0.916667	25/Mar/2025	0.166667	Spare change over work (Last change over carried out on 11 th June 2024)
447	RQ237537	PLANNED	OCC_588	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	24/Mar/2025	09:00	24/Mar/2025	18:00	Bay Outage
448	RQ239163	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	24/Mar/2025	09:00	24/Mar/2025	18:00	
449	RQ239199	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	24/Mar/2025	09:00	24/Mar/2025	18:00	
450	RQ239230	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	24/Mar/2025	09:00	24/Mar/2025	18:00	
451	RQ239276	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work Only AR will be kept off. Line will be in service	24/Mar/2025	08:00	24/Mar/2025	18:00	
452	RQ239326	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	24/Mar/2025	09:00	24/Mar/2025	18:00	
453	RQ239162	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Quarterly maintenance work	24/Mar/2025	10:00	24/Mar/2025	18:00	
454	RQ239381	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	24/Mar/2025	09:00	24/Mar/2025	18:00	
455	RQ239370	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	24/Mar/2025	07:00	24/Mar/2025	18:00	
456	RQ236832	PLANNED	OCC_588	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-3 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	For attending SF6 Gas leakage work	24/Mar/2025	09:00	26/Mar/2025	18:00	For attending SF6 Gas leakage work

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
457	RQ238176	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	24/Mar/2025	08:00	24/Mar/2025	18:00	AR disable
458	RQ238197	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	24/Mar/2025	08:00	24/Mar/2025	18:00	AR disable
459	RQ239164	PLANNED	OCC_588	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Diagnostic Testing and Routine Maintenance Works	25/Mar/2025	0.5	25/Mar/2025	0.75	
460	RQ237954	PLANNED	OCC_588	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	D	Simultaneous outages of 400KV/220KV BOISAR-ICT-2 and 400KV-TARAPUR 3&4-BOISAR-1 is required for Tie bay LBB relay retrofitting & testing	25/Mar/2025	07:00	25/Mar/2025	21:00	/PG-WR2- BOISAR///22
461	RQ238019	PLANNED	OCC_588	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	D	Simultaneous outages of 400KV/220KV BOISAR-ICT-2 and 400KV-TARAPUR 3&4-BOISAR-1 is required for Tie bay LBB relay retrofitting & testing	25/Mar/2025	07:00	25/Mar/2025	21:00	/PG-WR2- BOISAR///23
462	RQ237097	PLANNED	OCC_588	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	D	AMP of Line Equipment	25/Mar/2025	08:00	25/Mar/2025	18:00	
463	RQ236813	PLANNED	OCC_588	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	C	For Bus extension-Old bus GIB to new bus GIB connection-w/o internal conductor fixing (for GIS modules alignment/erection purpose)	25/Mar/2025	06:00	27/Mar/2025	20:00	Outage is being proposed for construction works underWRES-XXXI project
464	RQ239200	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	25/Mar/2025	09:00	25/Mar/2025	18:00	
465	RQ239231	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	25/Mar/2025	09:00	25/Mar/2025	18:00	
466	RQ239582	PLANNED	OCC_588	MSLDC_OUTAGE	400KV/220KV KHARGHAR-ICT-3	C	Safety purpose for connecting of Bus through jumper by Hotline Method. For the commissioning of the new ICT-4	25/Mar/2025	06:00	26/Mar/2025	18:00	
467	RQ239277	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	25/Mar/2025	08:00	25/Mar/2025	18:00	
468	RQ239327	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator. A/R function required to be in non auto mode	25/Mar/2025	09:00	25/Mar/2025	18:00	
469	RQ239382	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	25/Mar/2025	09:00	25/Mar/2025	18:00	
470	RQ239371	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	25/Mar/2025	07:00	25/Mar/2025	18:00	
471	RQ239165	PLANNED	OCC_588	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Tightening of Hanger rod of assembly on 400 KV Main Bus-II by Hot Line Method	25/Mar/2025	09:00	25/Mar/2025	17:00	
472	RQ237293	PLANNED	OCC_588	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	C	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	25/Mar/2025	08:00	25/Mar/2025	20:00	204L
473	RQ236919	PLANNED	OCC_588	POWERGRID_WR1	400KV-KARAD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	Annual Maintennace Plan work of Line Reactor and Recator CB at 765kV Solapur Substation	25/Mar/2025	08:00	25/Mar/2025	18:00	
474	RQ236738	PLANNED	OCC_588	POWERGRID_WR1	KOLHAPUR GIS - 400KV B/R 1	C	Reactor AMP and turret CT oil leakage attending	25/Mar/2025	08:00	26/Mar/2025	18:00	125 MVar Bus reactor at Kolhapur GIS End
475	RQ238177	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	25/Mar/2025	08:00	25/Mar/2025	18:00	AR disable
476	RQ238198	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	25/Mar/2025	08:00	25/Mar/2025	18:00	AR disable
477	RQ239074	PLANNED	OCC_588	MSLDC_OUTAGE	KUDUS - 400KV - BUS 1	C	Maintenance of main Bus-I and bays equipment & Diagnostics Testing Work	26/Mar/2025	09:00	27/Mar/2025	18:00	
478	RQ238021	PLANNED	OCC_588	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	D	Simultaneous outages of 400KV-VAPI-BOISAR-1 and 400KV-TARAPUR 3&4-BOISAR-2 is required for Tie bay LBB relay retrofitting & testing	26/Mar/2025	07:00	26/Mar/2025	21:00	/PG-WR2- BOISAR///25
479	RQ237541	PLANNED	OCC_588	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Annual Maintenance of MCT & MCVT of ICT-1	26/Mar/2025	09:00	26/Mar/2025	18:00	ICT Outage
480	RQ239201	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	26/Mar/2025	09:00	26/Mar/2025	18:00	
481	RQ239167	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line, s/s Maintenance	26/Mar/2025	09:00	26/Mar/2025	17:30	
482	RQ239232	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	26/Mar/2025	09:00	26/Mar/2025	18:00	
483	RQ239278	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	26/Mar/2025	08:00	26/Mar/2025	18:00	
484	RQ239328	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator. A/R function required to be in non auto mode	26/Mar/2025	09:00	26/Mar/2025	18:00	
485	RQ239166	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KORADI-KHAPARKHEDA-2	D	CVT TESTING & BAY MNTC WORK	26/Mar/2025	10:00	26/Mar/2025	18:00	
486	RQ239383	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	26/Mar/2025	09:00	26/Mar/2025	18:00	
487	RQ239372	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	26/Mar/2025	07:00	26/Mar/2025	18:00	
488	RQ239579	PLANNED	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 2	D	Connecting of B Bus through Jumper by hotline method. For the commissioning of the new ICT-4	26/Mar/2025	09:00	26/Mar/2025	18:00	
489	RQ237548	PLANNED	OCC_588	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	FOR AMP WORK	26/Mar/2025	10:00	26/Mar/2025	17:00	Shutdown
490	RQ236674	PLANNED	OCC_588	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	AMP of Line REACTOR at Waluj S/s.	26/Mar/2025	08:00	26/Mar/2025	18:00	AMP WORK
491	RQ237098	PLANNED	OCC_588	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment	26/Mar/2025	08:00	26/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
492	RQ238178	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	26/Mar/2025	08:00	26/Mar/2025	18:00	AR disable
493	RQ238199	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	26/Mar/2025	08:00	26/Mar/2025	18:00	AR disable
494	RQ239202	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	27/Mar/2025	09:00	27/Mar/2025	18:00	
495	RQ239233	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	27/Mar/2025	09:00	27/Mar/2025	18:00	
496	RQ239169	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	27/Mar/2025	09:00	27/Mar/2025	18:00	
497	RQ239279	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	27/Mar/2025	08:00	27/Mar/2025	18:00	
498	RQ239170	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	PID Faulty insulator replacement work & cold line washing work	27/Mar/2025	09:00	27/Mar/2025	18:00	
499	RQ239329	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	27/Mar/2025	09:00	27/Mar/2025	18:00	
500	RQ239384	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	27/Mar/2025	09:00	27/Mar/2025	18:00	
501	RQ239373	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	27/Mar/2025	07:00	27/Mar/2025	18:00	
502	RQ239580	PLANNED	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - TRANSFER BUS 1	D	Connecting of C Bus through Jumper by hotline method. For the commissioning of the new ICT-4	27/Mar/2025	09:00	27/Mar/2025	18:00	
503	RQ239168	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	D	CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	27/Mar/2025	09:00	27/Mar/2025	17:00	
504	RQ237549	PLANNED	OCC_588	MUML	400KV-NAVI MUMBAI-VIKHROLI	D	FOR AMP WORK	27/Mar/2025	10:00	27/Mar/2025	15:00	Shutdown
505	RQ238179	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	27/Mar/2025	08:00	27/Mar/2025	18:00	AR disable
506	RQ238200	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	27/Mar/2025	08:00	27/Mar/2025	18:00	AR disable
507	RQ239578	PLANNED	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	D	Connecting of A Bus through Jumper by hotline method. For the commissioning of the new ICT-4	28/Mar/2025	09:00	28/Mar/2025	18:00	
508	RQ238162	PLANNED	OCC_588	WTPL	765KV-PUNE-GIS-AURANGABAD-1	D	AR disable for annual maintenance in 765 KV Pune-GIS-Padghe PG-1	28/Mar/2025	08:00	28/Mar/2025	18:00	AR disable
509	RQ238161	PLANNED	OCC_588	WTPL	765KV-PUNE-GIS-PADGHE-PG-1	D	Annual Maintenance	28/Mar/2025	08:00	28/Mar/2025	18:00	Outage work
510	RQ237542	PLANNED	OCC_588	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Annual Maintenance of MCT & MCVT of ICT-2	28/Mar/2025	09:00	28/Mar/2025	19:00	ICT Outage
511	RQ239172	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Outage is required for safety purpose during Installation of saver Assembly at various Location on 220KV Tarapur - Boisar Line.	28/Mar/2025	06:00	28/Mar/2025	19:00	
512	RQ239203	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	28/Mar/2025	09:00	28/Mar/2025	18:00	
513	RQ239234	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	28/Mar/2025	09:00	28/Mar/2025	18:00	
514	RQ239171	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	Installation of saver Assembly at various Location.	28/Mar/2025	06:00	28/Mar/2025	19:00	
515	RQ239280	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	28/Mar/2025	08:00	28/Mar/2025	18:00	
516	RQ239330	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	28/Mar/2025	09:00	28/Mar/2025	18:00	
517	RQ239385	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	28/Mar/2025	09:00	28/Mar/2025	18:00	
518	RQ237550	PLANNED	OCC_588	MUML	400KV-NAVI MUMBAI-PADGHE-PG	D	FOR AMP WORK	28/Mar/2025	10:00	28/Mar/2025	15:00	Shutdown
519	RQ238180	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	28/Mar/2025	08:00	28/Mar/2025	18:00	AR disable
520	RQ238201	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	28/Mar/2025	08:00	28/Mar/2025	18:00	AR disable
521	RQ236791	PLANNED	OCC_588	POWERGRID_WR1	PADGHE-PG - 765KV - BUS 1	C	For Conducting Impulse Test on Extended Main Bus without link connection.	29/Mar/2025	08:00	30/Mar/2025	18:00	
522	RQ236790	PLANNED	OCC_588	POWERGRID_WR1	PADGHE-PG - 765KV - BUS 1	C	For Installation of Connecting Chamber without Link for Extension of Main BUS, HV Test and PDM Test.	29/Mar/2025	08:00	30/Mar/2025	18:00	
523	RQ236792	PLANNED	OCC_588	POWERGRID_WR1	PADGHE-PG - 765KV - BUS 1	C	For Installation of Connecting Chamber with Link for Extension of Main BUS, Primary and Secondary Bus Stability of Complete Bus (New & Existing)	29/Mar/2025	08:00	30/Mar/2025	18:00	
524	RQ239566	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose. For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	29/Mar/2025	06:00	29/Mar/2025	19:00	
525	RQ239564	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	29/Mar/2025	06:00	29/Mar/2025	19:00	
526	RQ239204	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	29/Mar/2025	09:00	29/Mar/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
527	RQ239235	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	29/Mar/2025	09:00	29/Mar/2025	18:00	
528	RQ239281	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	29/Mar/2025	08:00	29/Mar/2025	18:00	
529	RQ239331	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	29/Mar/2025	09:00	29/Mar/2025	18:00	
530	RQ239386	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	29/Mar/2025	09:00	29/Mar/2025	18:00	
531	RQ239173	PLANNED	OCC_588	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work	29/Mar/2025	09:00	29/Mar/2025	17:00	
532	RQ237551	PLANNED	OCC_588	MUML	220KV-NAVI MUMBAI-TALOJA-1	D	FOR AMP WORK	29/Mar/2025	10:00	29/Mar/2025	12:00	Shutdown
533	RQ238181	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	29/Mar/2025	08:00	29/Mar/2025	18:00	AR disable
534	RQ238202	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	29/Mar/2025	08:00	29/Mar/2025	18:00	AR disable
535	RQ239174	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	For chemical washing of insulator strings at various locations.	30/Mar/2025	0.875	31/Mar/2025	0.25	
536	RQ236846	PLANNED	OCC_588	POWERGRID_WR1	PUNE-PG - 220KV - BUS 1	D	ISOLATOR Alignment works	30/Mar/2025	09:00	30/Mar/2025	17:00	Each bay will be taken on TBC bay
537	RQ239567	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose .For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	30/Mar/2025	06:00	30/Mar/2025	19:00	
538	RQ239565	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	.For replacement of Existing 0.4 ACSR Conductor by CCC HTLS Conductor	30/Mar/2025	06:00	30/Mar/2025	19:00	
539	RQ239205	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	30/Mar/2025	09:00	30/Mar/2025	18:00	
540	RQ239236	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	30/Mar/2025	09:00	30/Mar/2025	18:00	
541	RQ239282	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	30/Mar/2025	08:00	30/Mar/2025	18:00	
542	RQ239387	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	30/Mar/2025	09:00	30/Mar/2025	18:00	
543	RQ239541	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	Routine & Pre monsoon maintenance.	30/Mar/2025	09:00	30/Mar/2025	18:00	
544	RQ238182	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	30/Mar/2025	08:00	30/Mar/2025	18:00	AR disable
545	RQ238203	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	30/Mar/2025	08:00	30/Mar/2025	18:00	AR disable
546	RQ238158	PLANNED	OCC_588	WTPL	765KV-PUNE-GIS-AURANGABAD-1	D	Annual Maintenance	31/Mar/2025	08:00	31/Mar/2025	18:00	Outage work
547	RQ238160	PLANNED	OCC_588	WTPL	765KV-PUNE-GIS-PADGHE-PG-1	D	AR disable for annual maintenance in 765 KV -Pune- GIS-Aurangabad -1	31/Mar/2025	08:00	31/Mar/2025	18:00	AR disable
548	RQ237539	PLANNED	OCC_588	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	31/Mar/2025	09:00	31/Mar/2025	18:00	Bay Outage
549	RQ239206	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	31/Mar/2025	09:00	31/Mar/2025	18:00	
550	RQ239237	PLANNED	OCC_588	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID TESTING WORK	31/Mar/2025	09:00	31/Mar/2025	18:00	
551	RQ239283	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing work. Only AR will be kept off. Line will be in service	31/Mar/2025	08:00	31/Mar/2025	18:00	
552	RQ239175	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Quarterly maintenance work	31/Mar/2025	10:00	31/Mar/2025	18:00	
553	RQ239388	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. Only AR will be kept off. Line will be in service	31/Mar/2025	09:00	31/Mar/2025	18:00	
554	RQ238183	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	31/Mar/2025	08:00	31/Mar/2025	18:00	AR disable
555	RQ238204	PLANNED	OCC_588	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	31/Mar/2025	08:00	31/Mar/2025	18:00	AR disable

Maharashtra State Load Despatch Centre

Monthly Outage list Not Considered in WRLDC OCCM for the Month of MARCH '2025

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/Conti nous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time	Rpc Remarks
RQ239137	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 2	D	Removing of B Bus through Jumper by Hotline Method. For the commissioning of the new ICT-4	02/Mar/2025	09:00	02/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239141	OCC_588	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	Outage required for Main Bus -1 outage work.	04/Mar/2025	04:00	06/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239106	OCC_588	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	Outage required for Main Bus -1 outage work.	04/Mar/2025	04:00	06/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239082	OCC_588	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6'	04/Mar/2025	04:00	06/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239339	OCC_588	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. 400KV HVDC CKT-2 will be shifted on "400KV TBC-2" in order to remove IPS tube connecting PG-1 & PG-2 Isolators for disconnection the Bus jumpers and reconnect the same after completion of work. IPS tube will be reconnected after completion of work and feeder will be shifted back to its own bay. 3. Outage is not required as feeder will be in service via TBC-2 on Main Bus-2 during required period.	04/Mar/2025	15:00	05/Mar/2025	15:00	Not considered/as discussed in Pre_OCCM
RQ239065	OCC_588	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 2. Nut Bolts and hardware tightening work. 3. Hardware and jumper tightening of BUS CVT.	04/Mar/2025	04:00	06/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239064	OCC_588	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIJAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	06/Mar/2025	09:00	06/Mar/2025	17:00	Not Considered/Repeat entry.
RQ239060	OCC_588	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	CT tan delta , Routine Line maintenance work	06/Mar/2025	08:00	06/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239061	OCC_588	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Maintenance of isolator of all feeders connected to Main Bus 2	12/Mar/2025	08:00	12/Mar/2025	17:00	Not Considered/Repeat entry.
RQ239154	OCC_588	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	1) Maintenance of isolator of all feeders connected to Main Bus 1	19/Mar/2025	08:00	19/Mar/2025	17:00	Not Considered/Repeat entry.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time	Rpc Remarks
RQ239058	OCC_588	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	1) Maintenance of isolator of all feeders connected to Main Bus 1	19/Mar/2025	08:00	19/Mar/2025	17:00	Not Considered/Repeat entry.
RQ239151	OCC_588	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	C	For Replacement of 400kV R phase BUS Span of 400kV TBC & BC and Routine Maintenance Work	21/Mar/2025	08:00	23/Mar/2025	18:00	Not considered/as discussed in Pre_OCCM
RQ239576	OCC_588	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	C	1) Bay strengthening of 220kV Tarapur Bay & 220kV Ghodbunder Bay. 2) Bay maintenance & equipment testing of 220kV B Bus.	22/Mar/2025	07:00	23/Mar/2025	20:00	Not considered/as discussed in Pre_OCCM
RQ237547	OCC_588	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	FOR AMP WORK	25/Mar/2025	10:00	25/Mar/2025	17:00	Not considered/as discussed in Pre_OCCM

State Element outage list for the month of MARCH '2025

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	JEJURI- KOYNA STAGE-IV	1-Mar-25	09:00	15-Mar-25	18:00	Daily	PID Testing work & AR To be kept in non auto mode	MSETCL	MSETCL	PID Testing work & AR To be kept in non auto mode
2	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	1-Mar-25	08:00	2-Mar-25	18:00	Continuous	For LV bay shifting considering ICT-4 Commissioning	MSETCL	MSETCL	ICT 2 & 3 will be service
3	400 KV	WARORA - IEPL	3-Mar-25	09:00	8-Mar-25	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	NA
4	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	3-Mar-25	06:00	4-Mar-25	18:00	Continuous	Cold welding work	MSETCL	MSETCL	Planned outage
5	400 KV	KHADKA-AURANGABAD (WALUJ)	4-Mar-25	06:00	4-Mar-25	18:00	Daily	1 Broken Disc String replacement 2 Cold line washing 3 Nut-bolt tightening work	MSETCL	MSETCL	Necessary maintenance work, same was deferred in Jan 25
6	400 KV	400/220 KV 500 MVA ICT @ ALKUD	4-Mar-25	10:00	4-Mar-25	17:00	Daily	For routine Maintenance	MSETCL	MSETCL	Load will be managed on 400KV RS, Karad & 400KV Talandge
7	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	4-Mar-25	14:00	4-Mar-25	17:00	Daily	Routine Maint. work	MSETCL	MSETCL	--
8	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	4-Mar-25	10:00	4-Mar-25	13:00	Daily	Routine maintenance work	MSETCL	MSETCL	--
9	400 KV	KHADKA - BABLESHWAR	5-Mar-25	06:00	5-Mar-25	18:00	Daily	1. Broken Disc String Replacement 2. Cold line washing work 3. Nut-bolt tightening work	MSETCL	MSETCL	Necessary maintenance work, same was deferred in Jan 25
10	400 KV	500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	5-Mar-25	08:00	5-Mar-25	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
11	400 KV	PADGHE - NAGOTHANE CKT - 1	5-Mar-25	09:00	5-Mar-25	18:30	Daily	1) Replacement of old CT & CVT MK Box. 2) Bay Maintenance Work. 3) MTAMC Work. 4) Distance Relay replacement work	MSETCL	MSETCL	Weather condition should be clear.
12	400 KV	KHADKA- DEEPNAGAR CKT 1	6-Mar-25	10:00	6-Mar-25	17:00	Daily	For Diagnostic Testing of Main Bay, Tie Bay & Line Bay along with Chemical Washing	MSETCL	MSETCL	During outage, 400 kV Deepnagar - Khadka Ckt 2 remain in service.
13	400 KV	500 MVA 400/220 KV ICT - 2 @ CHANDRAPUR 2	6-Mar-25	08:00	6-Mar-25	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
14	400 KV	JEJURI- KOYNA STAGE-IV	6-Mar-25	09:00	6-Mar-25	17:00	Daily	PID Faulty insulator replacement work & cold line washing work	MSETCL	MSETCL	PID Faulty insulator replacement work & cold line washing work
15	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	6-Mar-25	10:00	6-Mar-25	17:00	Daily	Breaker maintenance work	MSETCL	MSETCL	--

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
16	400 KV	BUS REACTOR (125 MVar) @ ALKUD	6-Mar-25	09:00	6-Mar-25	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	--
17	400 KV	JEJURI - KARAD	6-Mar-25	09:30	6-Mar-25	18:00	Daily	For Line CT,CVT, OV relay testing and maintenance Work.	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-1 & 2 & 400 kV Jejuri-Koyna ST-IV Line will continue to remain in service.
18	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	6-Mar-25	08:00	6-Mar-25	18:00	Daily	DT & Relay Test	MSETCL	MSETCL	-
19	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	7-Mar-25	10:00	7-Mar-25	18:00	Daily	Diagnostic Testing and routine Maintenance work.	MSETCL	MSETCL	NIL
20	400 KV	KHADKA- DEEPNAGAR CKT 2	8-Mar-25	09:00	8-Mar-25	12:00	Daily	For Diagnostic Testing of Main Bay, Tie Bay & Line bay along with Chemical Washing	MSETCL	MSETCL	During outage, 400 kV Deepnagar - Khadka Ckt 1 will remain in service.
21	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	8-Mar-25	08:00	8-Mar-25	18:00	Daily	For verification of RRS Scheme along with Spare ICT.Differential HV ,LV Back up relay ,HV CB DCRM Timing ,Bushing /Winding tan delta, HV CT Tan D and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
22	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	8-Mar-25	08:00	9-Mar-25	18:00	Continuous	For LV bay shifting considering ICT-4 Commissioning	MSETCL	MSETCL	ICT 1 & 3 will be service
23	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	8-Mar-25	08:00	8-Mar-25	18:00	Daily	DT & Relay Test	MSETCL	MSETCL	-
24	400 KV	AKOLA - KHADKA (BHUSAWAL)	9-Mar-25	06:00	9-Mar-25	18:00	Daily	Cold line washing work & Nutbolt tightening work	MSETCL	MSETCL	Deferred in January 2025
25	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	9-Mar-25	09:00	9-Mar-25	18:00	Daily	Routine Line maintenance work,Main-1&2 Relay ,LBB relay,CVT Tan Delta Chemical Cleaning of Equipment & Quarterly Bay Maintenance	MSETCL	MSETCL	400 kV Bhusawal, Ektuni-I&II Dhule-I & II will be in service
26	400 KV	AKOLA - KHADKA (BHUSAWAL)	10-Mar-25	06:00	10-Mar-25	18:00	Daily	Cold line washing work & Nutbolt tightening work	MSETCL	MSETCL	Deferred in January 2025
27	400 KV	400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	10-Mar-25	09:00	10-Mar-25	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
28	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	10-Mar-25	08:00	10-Mar-25	18:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Maintenance and alignment of Isolators.	MSETCL	MSETCL	400KV CHD-2 CKT-2, K'kheda, Parli ckt-3, PGCIL CKT-1 to 4 will be in service.
29	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	10-Mar-25	09:00	10-Mar-25	23:59	Daily	Oil leakage attending work will be done by agency and Quaterly maintenance work	MSETCL	MSETCL	Load will be managed form ICT - 1 & 3
30	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	10-Mar-25	08:00	10-Mar-25	18:00	Daily	For restoration ICT -IV from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
31	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	10-Mar-25	08:00	10-Mar-25	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-IV

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
32	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	11-Mar-25	06:00	11-Mar-25	18:00	Daily	To increase ground clearance at span 202-203 and to carry out maintenance work like disc replacement, nut bolt tightening	MSETCL	MSETCL	Work to done by AMC agency
33	400 KV	MAIN BAY (403) of WALUJ @ TAPTITANDA	11-Mar-25	11:00	11-Mar-25	18:00	Daily	CB diagnostic testing work	MSETCL	MSETCL	Please approve outage for routine CB diagnostic testing work and routine maintenance work
34	400 KV	MAIN BAY (413) OF NANDGAON PETH CKT @ AKOLA (M)	11-Mar-25	09:00	11-Mar-25	17:00	Daily	Replacement of faulty disc by Hot line Method found during the PID Testing	MSETCL	MSETCL	Replacement of faulty disc by Hot line Method found during the PID Testing
35	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	11-Mar-25	08:00	11-Mar-25	18:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Maintenance and alignment of Isolators. 3. Replacement of faulty disc insulator string of Aux Bus (Section-1) in span of '400KV CHD-2 CKT-1'.	MSETCL	MSETCL	400KV CHD-2 CKT-2, K'kheda, Parli ckt-3, PGCIL CKT-1 to 4 will be in service.
36	400 KV	400/220/33KV SPARE ICT @ KORADI 2	11-Mar-25	08:00	11-Mar-25	17:00	Daily	1) Maintenance of isolator connected to Main Bus 2	MSETCL	MSETCL	1)Spare ICT is on no load, Space ICT is to be handtripped for Bus -II
37	400 KV	DHULE- - BABLESHWAR CKT - 1	11-Mar-25	09:00	11-Mar-25	18:00	Daily	CB DCRM /Timing, CT/CVT tan delta Routine Line maintenance work	MSETCL	MSETCL	400 kV Bhusawal, Ektuni-I&II, Dhule-II will be in service
38	400 KV	400/220 KV 3X105 MVA ICT - 1 @ PADGHE	11-Mar-25	09:00	11-Mar-25	18:00	Daily	1. For CB testing work. 2. A & B Bus PG Isolator Maintenance Work. 3. 315MVA ICT-I in service through TBC.	MSETCL	MSETCL	Weather Condition should be clear.
39	400 KV	DEEPNAGAR - THAPTI TANDA	12-Mar-25	06:00	12-Mar-25	18:00	Daily	To increase the ground clearance at span 202-203 and other maintenance work like disc replacement and nut-bolt tightening work	MSETCL	MSETCL	Work to be carried out by AMC agency
40	400 KV	DEEPNAGAR - THAPTI TANDA	12-Mar-25	10:00	12-Mar-25	14:00	Daily	For Diagnostic Testing of All Main , Tie and Line Bay Equipments.	MSETCL	MSETCL	NIL
41	400 KV	MAIN BAY (410) OF BHUSAWAL (KHADKA) @ AKOLA	12-Mar-25	09:00	12-Mar-25	17:00	Daily	Replacement of faulty disc by Hot line Method found during the PID Testing	MSETCL	MSETCL	Replacement of faulty disc by Hot line Method found during the PID Testing
42	400 KV	400/220/33KV SPARE ICT @ KORADI 2	12-Mar-25	08:00	12-Mar-25	17:00	Daily	1) Maintenance of isolator connected to Main Bus 2	MSETCL	MSETCL	1)Spare ICT is on no load, Space ICT is to be handtripped for Bus -II outage
43	400 KV	MAIN BAY (410) OF ICT-2 @ KUDUS	12-Mar-25	09:00	12-Mar-25	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	MSETCL	Annual Maintenance of bays equipment & Diagnostics Testing Work
44	400 KV	KHADKA - BABLESHWAR	12-Mar-25	08:00	12-Mar-25	18:00	Daily	CB DCRM/Timing	MSETCL	MSETCL	400kV Bhusawal will be in service through TBC
45	400 KV	KHADKA - BABLESHWAR	12-Mar-25	06:00	12-Mar-25	18:00	Daily	1. Broken Disc String Replacement 2. Fixing of repair sleeves 3. Cold line washing work	MSETCL	MSETCL	Necessary Maintenance work
46	400 KV	400/220/33KV SPARE ICT @ KORADI 2	13-Mar-25	08:00	13-Mar-25	17:00	Daily	1) Maintenance of isolator connected to Main Bus 2	MSETCL	MSETCL	1)Spare ICT is on no load, Space ICT is to be handtripped for Bus -II outage
47	400 KV	LONIKAND - JEJURI CKT - 2	13-Mar-25	09:30	13-Mar-25	18:00	Daily	For Line CT, CVT, OV relay testing and maintenance Work.	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-1, 400 kV Jejuri-Karad & 400 kV Jejuri-Koyna ST-IV

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
48	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	14-Mar-25	10:00	14-Mar-25	18:00	Daily	Diagnostic Testing & Routine Maintenance work.	MSETCL	MSETCL	NIL
49	400 KV	400/220 KV 500 MVA ICT - 5 @ PADGHE	14-Mar-25	05:00	15-Mar-25	23:59	Continuou	1) Dismantling of existing ICT-5 tower and erection of New DC dwarf tower and narrow base tower	MSETCL	MSETCL	Weather Condition should be clear.
50	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	15-Mar-25	08:00	16-Mar-25	18:00	Continuous	For LV bay shifting considering ICT-4 Commissioning	MSETCL	MSETCL	ICT 1 & 2 will be service
51	400 KV	LONIKAND I - KOYNA STAGE-IV	16-Mar-25	09:00	31-Mar-25	18:00	Daily	PID Testing work & AR To be kept in non auto mode	MSETCL	MSETCL	PID Testing work & AR To be kept in non auto mode
52	400 KV	400/220/20 KV 500MVA ICT - 3 @ KALWA	16-Mar-25	08:00	16-Mar-25	20:00	Daily	Oil Circulating Pump replacement work.MTCIL, A/R function to be in non auto mode.	MSETCL	MSETCL	Oil Circulating Pump replacement work.(both line)
53	400 KV	JAIGAD - NEW KOYNA CKT - 1	17-Mar-25	09:00	22-Mar-25	18:00	Daily	For Hotline washing work (Jaigad newkoyna ckt 1- AR Out)	JPTL	JPTL	For Hotline washing work (Jaigad newkoyna ckt 1- AR Out)
54	400 KV	JAIGAD - NEW KOYNA CKT - 2	17-Mar-25	09:00	22-Mar-25	18:00	Daily	For Hotline washing work (Jaigad newkoyna ckt 2- AR Out)	JPTL	JPTL	For Hotline washing work (Jaigad newkoyna ckt 2- AR Out)
55	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	17-Mar-25	09:00	17-Mar-25	23:59	Daily	Oil leakage attending work will be done by agency and quarterly maintenance work	MSETCL	MSETCL	Load will be managed on ICT -2 & 3
56	400 KV	TBC @ BABHALESHWAR	18-Mar-25	08:00	18-Mar-25	18:00	Daily	LBB Relay CT tan delta	MSETCL	MSETCL	TBC is already free
57	400 KV	AKOLA - KHADKA (BHUSAWAL)	19-Mar-25	06:00	19-Mar-25	18:00	Daily	Cold line washing work	MSETCL	MSETCL	Necessary work
58	400 KV	KHADKA-AURANGABAD (WALUJ)	20-Mar-25	06:00	20-Mar-25	18:00	Daily	1. Broken Disc String Replacement 2. Fixing of repair sleeves 3. Cold line washing work	MSETCL	MSETCL	Necessary maintenance work
59	400 KV	STATION TF No 4 @ CHANDRAPUR GCR	20-Mar-25	08:00	20-Mar-25	18:00	Daily	1. Measurement of tandelta & C of CT. 3. Maintenance and alignment of Isolators	MSETCL	MSETCL	1. 400KV STN TF-5 will be in service. 2. Diagnostic Testing and routine maintenance of
60	400 KV	JEJURI - KARAD	20-Mar-25	09:00	20-Mar-25	17:00	Daily	PID Faulty insulator replacement work & cold line washing work	MSETCL	MSETCL	PID Faulty insulator replacement work & cold line washing work
61	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	20-Mar-25	09:30	20-Mar-25	18:00	Daily	For Maintenance & Testing work.	MSETCL	MSETCL	ICT-II & ICT-III will continue to remain in service
62	408 KV	JAIGAD - KARAD CKT - 1	20-Mar-25	09:00	20-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 1- AR Out)	JPTL	JPTL	
63	409 KV	JAIGAD - KARAD CKT - 2	21-Mar-25	09:00	21-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 2- AR Out)	JPTL	JPTL	
64	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	23-Mar-25	08:00	23-Mar-25	20:00	Daily	Bay maintenance & Diagnostic testing work. Height raising of fire wall.	MSETCL	MSETCL	Bay maintenance & Diagnostic testing work. Height raising of fire wall.

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
65	410 KV	JAIGAD - KARAD CKT - 1	23-Mar-25	09:00	23-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 1- AR Out)	JPTL	JPTL	
66	400 KV	JAIGAD - KARAD CKT - 1	24-Mar-25	09:00	24-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 1- AR Out)	JPTL	JPTL	For Hotline washing work (Jaigad karad ckt 1- AR Out)
67	411 KV	JAIGAD - KARAD CKT - 2	24-Mar-25	09:00	24-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 2- AR Out)	JPTL	JPTL	
68	400 KV	NEW KOYNA - STAGE IV CKT - 1	24-Mar-25	06:00	24-Mar-25	18:00	Daily	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	Planned outage
69	401 KV	JAIGAD - KARAD CKT - 2	25-Mar-25	09:00	25-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 2- AR Out)	JPTL	JPTL	
70	400 KV	NEW KOYNA - STAGE IV CKT - 2	25-Mar-25	06:00	25-Mar-25	18:00	Daily	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	Planned outage
71	402 KV	JAIGAD - KARAD CKT - 1	26-Mar-25	09:00	26-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 1- AR Out)	JPTL	JPTL	
72	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	26-Mar-25	08:00	26-Mar-25	18:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Feeder will be in service via 400KV TBC-1.	MSETCL	MSETCL	'400KV CHD-2 CKT-2' will be in service via 400KV TBC-1
73	403 KV	JAIGAD - KARAD CKT - 2	27-Mar-25	09:00	27-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 2- AR Out)	JPTL	JPTL	For Hotline washing work (Jaigad karad ckt 2- AR Out)
74	400 KV	400KV 125 MVAR BUS REACTOR @ AKOLA	27-Mar-25	09:00	27-Mar-25	17:00	Daily	Routine maintenance, diagnostic testing work and Replacement of faulty disc by Hot line Method found during the PID Testing	MSETCL	MSETCL	Routine maintenance, diagnostic testing work and Replacement of faulty disc by Hot line Method found during the PID Testing
75	400 KV	DHULE- - BABLESHWAR CKT - 1	27-Mar-25	09:00	28-Mar-25	18:00	Continuous	Replacement of Grading Capacitor	MSETCL	MSETCL	Line will be in service through TBC
76	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	27-Mar-25	09:00	27-Mar-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
77	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	27-Mar-25	08:00	27-Mar-25	18:00	Daily	DT & Relay Test	MSETCL	MSETCL	-
78	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	27-Mar-25	09:00	27-Mar-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
79	400 KV	JEJURI - KARAD	27-Mar-25	10:00	27-Mar-25	18:00	Daily	Cold line washing of strings	MSETCL	MSETCL	-
80	404 KV	JAIGAD - KARAD CKT - 1	28-Mar-25	09:00	28-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 1- AR Out)	JPTL	JPTL	
81	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	28-Mar-25	10:00	28-Mar-25	18:00	Daily	Routine Maintenance and Diagnostic Testing Work.	MSETCL	MSETCL	NIL

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
82	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	28-Mar-25	08:00	28-Mar-25	18:00	Daily	CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	MSETCL	MSETCL	Only CB & Bus & Line CT Commissioned in Die
83	400 KV	TBC 1 @ CHANDRAPUR GCR	28-Mar-25	08:00	28-Mar-25	18:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Measurement of tandelta & C of CT. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.	MSETCL	MSETCL	Diagnostic Testing and routine maintenance of various equipment.
84	400 KV	400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	28-Mar-25	08:00	28-Mar-25	18:00	Daily	Bushing Tan Delta	MSETCL	MSETCL	-
85	405 KV	JAIGAD - KARAD CKT - 2	29-Mar-25	09:00	29-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 2- AR Out)	JPTL	JPTL	
86	400 KV	DHULE- - BABLESHWAR CKT - 2	29-Mar-25	09:00	30-Mar-25	18:00	Continuous	Replacement of Grading Capacitor	MSETCL	MSETCL	Line will be in service through TBC
87	406 KV	JAIGAD - KARAD CKT - 1	30-Mar-25	09:00	30-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 1- AR Out)	JPTL	JPTL	
88	407 KV	JAIGAD - KARAD CKT - 2	31-Mar-25	09:00	31-Mar-25	18:00	Daily	For Hotline washing work (Jaigad karad ckt 2- AR Out)	JPTL	JPTL	