

ANNEXURE 3.2 (WR OCC-493)													
Outage Planning of Transmission elements during the Month of April 2017													
Sr no.	WRPC OCCM-493 SN	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC Comments
				Date	Time	Date	Time						
1	28	400	Khandwa -Dhule 1&2	01.Apr.17	09:00	30.Apr.17	18:00	Daily	Online permit for PID testing of insulator strings. A/R for both ciruicts to be kept into non auto mode during PID testing.	WR-II	POWERGRID	R	
2	32	765	765 Shunt reactor of Ektuni - Akola-II line 2 at MSETCL 765/400 Ektuni SS(Aurangabad-III) (Non-switchable Reactor)	01.Apr.17	11:00	01.Apr.17	15:00	Daily	For dismantling the HV & nertural bushings from discharged reactor of 703-bay of 765KV Akola-II ektuni line-2 at Ektuni SS	MSETCL	MEGPTCL		Line can not be charged without line reactor
3	33	220	Wardha (PGCL) -Pusad Line	01.Apr.17	08:00	30.Apr.17	17:00	Daily	Shifting of Auto Reclose in Non AR Mode for stringing of OPGW work.	MSETCL	M/s KEC Ltd.		
4	34	400/220	315MVA, ICT 1 @ BBLR	01.Apr.17	09:00	01.Apr.17	17:00	Daily	Maintenance work	MSETCL	MSETCL	400/220 315MVA ICT-I, 315MVA ICT-II & 500MVA ICT-IV will be in service	Load management shall be done by Maharashtra
5	35	400	Busbar Protection testing [Without any outage on line/(ICT/CB) @Kalwa	01.Apr.17	10:00	01.Apr.17	17:00	Daily	Busbar Protection testing 400 Bus I and Bus II	MSETCL	MSETCL		Which Bus, Bus-1 or 2
6	36	220	Boisar (M) Bus A	01.Apr.17	08:00	02.Apr.17	18:00	Continuuous	Maintenance of bus Isolators	MSETCL	MSETCL		Load management and contingency plan to be submitted
7	39	400	400 BHILAI-KORADI	01.Apr.17	08:00	30.Apr.17	17:00	Daily	Online PID Works . A/R to be kept in Non Auto mode	WRTS-I	WRTS-I	C	At a time only one ckt to be given eith Raipur-Bhilai or Bhilai-Koradi or Bhilai-Bhadrawati or Raipur-Bhadrawati-I
8	40	400	400 KORADI-SATPURA	01.Apr.17	08:00	30.Apr.17	17:00	Daily	Online PID Works . A/R to be kept in Non Auto mode	WRTS-I	WRTS-I	C	Either Koradi-Satpura or Bhilai-Koradi to be given
9	41	400	400 BHADRAVATI-CHANDRAPUR I & II	01.Apr.17	08:00	30.Apr.17	17:00	Daily	Online PID Works . A/R to be kept in Non Auto mode	WRTS-I	WRTS-I	C	
10	46	400	400 Wardha-Parli #1	01.Apr.17	09:00	30.Apr.17	18:00	Daily	Auto Recloser of Wardha-Parli #1 & #2 to be kept in non Auto Mode for ONLINE OPGW works.	WRTS-I	WRTS-I	R	Either Wardha-Parli-I or Bhadrawati-Parli-I to be given
11	47	400	400 BHADRAVATI-PARLI I . AR In Non Auto Mode for Ckt-II	01.Apr.17	08:00	01.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
12	49	765	Wardha-1 Tie Bay 714 at Aurangabad	01.Apr.17	08:00	03.Apr.17	18:00	Continuuous	for construction of future Solapur-1 main bay 713	WRTS-I	WRTS-I	C	
13	52	765	765KV SEONI-WARDHA I	01.Apr.17	09:00	30.Apr.17	18:00	Daily	Autoreclosure to be kept OFF for OPGW work	WRTS-I	WRTS-I	c	
14	53	220	TAPS1&2-Borivali	01.Apr.17	08:00	03.Apr.17	19:00	Daily	Annual maintenance Works	MSETCL	NPCIL		Maharashtra conseent required
15	54	400	Padghe- Kalwa 1 @ Padgha	02.Apr.17	08:00	02.Apr.17	08:00	Daily	Routine R&M work	MSETCL	MSETCL		
16	56	400	400 DHARIWAL TPP-PARLI II	02.Apr.17	08:00	02.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
17	70	400	400 NEW KOYANA-I @ Karad	03.Apr.17	10:00	03.Apr.17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL		
18	71	765	Line Reactor of Koradi-Tiroda Line-1 at Koradi III SS	03.Apr.17	08:00	03.Apr.17	18:00	Daily	For Taking Spare into service in place of Y Phase	MEGPTCL	MEGPTCL		If reactor is not switchable line to be kept out during outage period of reactor
19	72	400	105MVA, 400/220/33kv Spare ICT @ 400 RS Akola	03.Apr.17	10:00	03.Apr.17	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL		
20	73	400	400 BHEL make CB of HVDC Ckt. No.-I bay @400 S/S Chandrapur	03.Apr.17	08:00	08.Apr.17	18:00	Daily	For attending the SF6 gas leakage & capital overhauling & servicing of Brekaer.	400 AC	MSETCL		Line shall be in servcie with TBC bay
21	74	400	400 DHL- SSNNL Line Ckt-I & II	03.Apr.17	09:00	03.Apr.17	17:00	Daily	PID testing During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		Khandwa-Dhule shall be deferred
22	75	400	400 Khadka-Akola	03.Apr.17	06:00	06.Apr.17	18:00	Daily	PID testing .During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
23	76	400/220	315MVA, ICT 2 @ Talandge	03.Apr.17	10:00	03.Apr.17	18:00	Daily	Annual Maintenance work and pre Monsoon Maintenance work	MSETCL	MSETCL		Contingency plan to be submitted by SLDC Maharashtra
24	77	220	Talandage -Chikodi	03.Apr.17	08:00	03.Apr.17	17:00	Daily	Bay Maintenance and testing work.				
25	81	400	Solapur NTPC 400 Bus bar-II & connected bays namely 410,402,403 and 416	03.Apr.17	08:00	04.Apr.17	18:00	Continuuous	required for stability checking and protection & Interlock checking of upcoming NTPC Solapur-PGCIL Solapur ckt #3 and ckt#4	NTPC	NTPC		
26	82	400	BUS REACTOR_400_80MVAR_DHULE	03.Apr.17	08:00	03.Apr.17	17:30	Daily	for BHEL Bushings C/Tan delta measurement & DGA , AMP Works	WRTS-I	WRTS-I	R	
27	84	400	400 PARLI(PG)-PARLI(MSETCL) II	03.Apr.17	10:00	03.Apr.17	16:00	Daily	For collection of CT Oil Sample (DGA Test) at MSETCL end	WRTS-I	WRTS-I	R	Maharashtra consent required
28	85	400	412 Bay (Main Bay of ICT # 2) at Talegaon	03.Apr.17	09:00	03.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
29	86	765	WARDHA1_MAIN_BAY_721 at Seoni	03.Apr.17	09:00	04.Apr.17	18:00	Daily	For AMP work.	WRTS-I	WRTS-I	R	
30	87	400	SOLAPUR_400_BUS#2	03.Apr.17	09:00	04.Apr.17	18:00	Continuuous	COMMISSIONING OF 400 NTPC#4	WRTS-1	POWERGRID	C	
31	88	400	SOLAPUR_ BAY429 _TIE BAY _765KV ICT#2- Future	03.Apr.17	09:00	04.Apr.17	18:00	Continuuous	COMMISSIONING OF 400 NTPC#4	WRTS-1	POWERGRID	C	
32	89	400	400 BHADRAVATI-DHARIWAL TPP II	03.Apr.17	08:00	03.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
33	90	400	400 422 bay at Wardha Future Bay of Aurangabad-I	03.Apr.17	09:00	03.Apr.17	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	
34	92	400	400 Parli-2 (MSETCL) Main Bay (418) at Parli	03.Apr.17	10:00	03.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	to be availed along with line
35	93	400	400 Parli (PG)-2 Main Bay(412) at MSETCL Girawli	03.Apr.17	10:00	03.Apr.17	18:00	Daily	For Bay AMP works at MSETCL Girawli	WRTS-I	WRTS-I	R	To be availed along with line shutdown
36	96	765	Wardha-3 Tie Bay 717 at Aurangabad	04.Apr.17	08:00	06.Apr.17	18:00	Continuuous	for construction of future Solapur-2 main bay 716	WRTS-I	WRTS-I	C	Changed from 1-8 to 8-14 april
37	107	400	400 TALANDAGE -II @ Karad	04.Apr.17	10:00	04.Apr.17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL		
38	108	220	220 KV WARDHA- Wardha (PGCIL)LINE	04.Apr.17	10:00	04.Apr.17	17:00	Daily	Outage for replacement of damaged disc insulators at loc no. 42 & 48 & nut bolt connecting work at loc no. 24, 43, 29 & 39	MSETCL	MSETCL		
39	109	400	Babhaleshwar-Dhule-Ckt-1 @ BBLR	04.Apr.17	09:00	04.Apr.17	17:00	Daily	PG Isolators alignment and servicing work.	MSETCL	MSETCL		
40	110	400/220	315MVA , ICT1@ 400 Parli	04.Apr.17	08:00	10.Apr.17	18:00	Continuuous	Replacement of R-PH sick unit by overhauled unit.	MSETCL	MSETCL		
41	113	220	220 KV PADURNA - KALMESHWAR	04.Apr.17	09:00	04.Apr.17	17:00	daily	LINE MAINTENANCE & TESTING WORKWORK	MPPTCL	MPPTCL	R	Chhattisgarh consent required
42	114	400	Mouda-Wardha Line-1	04.Apr.17	09:00	06.Apr.17	18:00	Continuuous	Annual Maintenance		NTPC		Mouda generation to be restricted to 1150 MW
43	121	400	400 Sholapur-1 Main Bay (409) at Parli	04.Apr.17	10:00	04.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	
44	122	400	415 Bay (Main Bay of 400 BUS Reactor) at Talegaon	04.Apr.17	09:00	04.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
45	123	400	400 PUNE(GIS)-PUNE(TALEGOAN)_1	04.Apr.17	08:00	04.Apr.17	18:00	Daily	For attending Tightening of Jumper. AR in Non Auto Mode for Other Ckt	WRTS-I	WRTS-I	R	
46	124	400	400 BHADRAVATI-PARLI I	04.Apr.17	08:00	04.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
47	129	400	400 Boisar-Magarwada	05.Apr.17	08:00	08.Apr.17	18:00	Daily	Outage for spacing and jumpering works in 400 D/C Auragabad-Boisar line in Multi circuit towers due to heavy induction.	POWER GRID	WR-II	C	Daily or contineous
48	140	765	765KV Main Bus-1 at BDTCL Dhule	05.Apr.17	08:00	06.Apr.17	18:00	Daily	For AMP Works	BDTDCL	BDTCL	R	
49	148	400	400 Kolhapur-Solapur(PGCIL) 1 line	05.Apr.17	09:00	05.Apr.17	14:00	Daily	For putting of 400/220 KV Alkud Substation in grid	MSETCL	MSETCL	The 400 Alkud line and 400 Switchyard of Alkud Substation has been test charged on 01.01.2017.	
50	149	765	Line reactor of Akola-Ektuni line 2 at MEGPTCL-765/400 Akola-II SS.	05.Apr.17	11:00	05.Apr.17	15:00	Daily	For taking spare reactor in service against 707-LR Yph shunt reactor of 707-bay of 765KV Akola-II ektuni Line-2 at Akola-II SS. (Switchable Reactor)	MEGPTCL	MEGPTCL		
51	150	765	765kv Tirora- Koradi-III Line -2	05.Apr.17	10:00	05.Apr.17	20:00	Daily	Line Shutdown required for removal of reactor IPS tube , bushing & LA/BPI structure.	MEGPTCL	MEGPTCL		
52	151	400	PID of insulator strings of New 400/220/33kv ICT -2 Gantry at 400 Rs Akola	05.Apr.17	10:00	05.Apr.17	17:00	Daily	PID of insulator string	MSETCL	MSETCL		
53	152	400	Tie Bay-426 only, of 400 Warora ckt-II @ 400 Chandrapur-II S/S	05.Apr.17	09:00	05.Apr.17	18:00	Daily	Diagnostic Testing & allied bay maintenance work	MSETCL	MSETCL		
54	153	220	Wardha (PGCL) -Badnera Line	05.Apr.17	08:00	06.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		Wardha-Pusad to be deferred
55	154	220	220 KV Deoli (PGCIL)-BADNERA LINE	05.Apr.17	10:00	05.Apr.17	17:00	Daily	Outage for replacement of damaged disc insulators at loc 76, 80, 82 .	MSETCL	MSETCL		

ANNEXURE 3.2 (WR OCC-493)														
Outage Planning of Transmission elements during the Month of April 2017														
Sr no.	WRPC OCCM-493 SN	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC Comments	
				Date	Time	Date	Time							
56	155	400	400 Parli - Solapur line	05.Apr.17	09:00	05.Apr.17	18:00	Daily	Line maintenance at loc no -15 earth wire fixing work is to be necessary as soon as possible	MSETCL	MSETCL	Parli- Solapur & Bay of parli parli cannot be given on same date		
57	156	400	400 New Koyna-Dabhol 4 Ckt 2 @New Koyna	05.Apr.17	08:00	05.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work					
58	157	400/220	300 MVA ICT-1@ Koradi-1	05.Apr.17	09:00	05.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
59	158	400	Khaperkheda- Chandrapur Bay-417 @Khaperkheda	05.Apr.17	10:00	05.Apr.17	14:00	Daily	DCRM,CRM,Timing, IR measurement of Circuit Breaker & RM work	MSETCL	MSETCL			
60	159	400	400 DHL- SSNNL Line Ckt-I & II	05.Apr.17	09:00	05.Apr.17	17:00	Daily	PID testing During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL			
61	160	400	Babhaleshwar-Padghe-Ckt-1 @ BBLR	05.Apr.17	09:00	05.Apr.17	17:00	Daily	PG Isolators alignment and servicing work.	MSETCL	MSETCL			
62	161	765	ICT4_765/400_CHAMPA	05.Apr.17	09:00	05.Apr.17	18:00	Daily	For Changeover of Spare Unit at Champa	WRTS-I	WRTS-I	C		
63	162	400	400 KORADI-SATPURA	05.Apr.17	09:00	05.Apr.17	18:00	Daily	For Optic Fibre termination works	WRTS-I	WRTS-I	C		
64	169	400	418 Bay (Main Bay of ICT # 3) at Talegaon	05.Apr.17	09:00	05.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
65	172	400	400 DHARIWAL TPP-PARLI II	05.Apr.17	08:00	05.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety	WRTS-I	WRTS-I	C		
66	176	765	765 Tiroda - Koradi Line-2 Reactor at Tiroda plant	06.Apr.17	07:00	21.Apr.17	21:00	Continuou	Replacement of 704 -LR - Yphase	MEGPTCL	MEGPTCL		Reactor is switchable	
67	177	400	Padghe Nagothane 1 @Padgha	06.Apr.17	08:00	06.Apr.17	08:00	Daily	Routine R&M work	MSETCL	MSETCL			
68	192	400	Chandrapur II(New GCR) - Parli Ckt-I	06.Apr.17	08:30	06.Apr.17	17:00	Daily	Corona ring fixing at loc. No. 850	MSETCL	MSETCL			
69	193	400	400 JAIGAD -II @ Karad	06.Apr.17	10:00	06.Apr.17	17:00	Daily	Quarterly, Maint. work	MSETCL	MSETCL			
70	194	400	400 TBC @ 400 Chakan SS	06.Apr.17	09:00	06.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
71	195	400	Jejuri-Koyna st IV @ Jejuri	06.Apr.17	09:30	06.Apr.17	17:30	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
72	196	765	765/400 ICT-2 at Koradi III SS	06.Apr.17	08:00	06.Apr.17	18:00	Daily	For Annual Maintenance of ICT-2	MEGPTCL	MEGPTCL			
73	197	400	400 Akola- Bhusawal Line	06.Apr.17	12:00	08.Apr.17	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Koradi-Bhusawal , 400 Akola-Nandgaonpeth & 400 Koradi-Nandgaonpeth are in service.		
74	198	400	Chandrapur-II - Nanded Line (Ckt-II)	06.Apr.17	08:00	06.Apr.17	18:00	Daily	For Routine Maintenance work	MSETCL	MSETCL			
75	199	220	220 KV PGCIL-BADNERA LINE	06.Apr.17	10:00	06.Apr.17	17:00	Daily	Outage for replacement of damaged disc insulators at loc 1,49,68 B	MSETCL	MSETCL			
76	200	400	400 PGCIL (BAY NO.- 420), TIEY BAY - 421 & FUTURE -II (BAY NO - 422) at 400 S/s. Warora.	06.Apr.17	08:00	06.Apr.17	17:00	Daily	DCRM OF TIEY CB & Future - II CB at 400 tie bay 421 at 400 S.stn. Warora.	MSETCL	MSETCL			
77	201	400	Nagothane-Padghe 1 Line @ Nagothane	06.Apr.17	09:00	06.Apr.17	17:00	Daily	To carry out Line Signature Analysis & Routine Maintenance	MSETCL	MSETCL			
78	202	400/220	80MVAR, Reactor @ Talandge	06.Apr.17	10:00	06.Apr.17	18:00	Daily	Annual Maintenance work and pre Monsoon Maintenance work	MSETCL	MSETCL			
79	203	400	420-Bay (Main bay)& 421-Bay (Tie bay) of 400 Interconnector-I) at Lonikand-II Substation	06.Apr.17	09:00	06.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
80	213	400	400 Parli-1 (MSETCL) Main Bay (415) at Parli	06.Apr.17	10:00	06.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R		
81	214	220	201 Bay (220 Side of ICT# 1) at Talegaon. ICT Will Remain in Service through TBC	06.Apr.17	09:00	06.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
82	215	400	400 BHADRAVATI-PARLI-1	06.Apr.17	08:00	06.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C		
83	216	400	400 Bus # 2 at Wardha	06.Apr.17	09:00	06.Apr.17	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R		
84	220	220	Bus 1 @Taps 3&4	06.Apr.17	08:00	07.Apr.17	17:00	Daily	Amp		TAPS	B		
85	229	765	765KV Main Bus-2 at BDTCL Dhule	07.Apr.17	08:00	08.Apr.17	18:00	Daily	For AMP Works		BDTDCL	BDTCL	R	
86	234	765	Line reactor of Akola-Ektuni line 2 at MEGPTCL-765/400 Akola-II SS.	07.Apr.17	08:00	07.Apr.17	15:00	Daily	For dismantling the HV & netural bushings from discharged reactor of 707 bay of Akola-II Ektuni line-2 at Akola-II SS (Switchable Reactor)	MEGPTCL	MEGPTCL			
87	235	400	315MVA, 400/220/33kV ICT -2 @ 400 RS Akola	07.Apr.17	08:00	07.Apr.17	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL			
88	236	400/220	501 MVA, ICT-III at 400 R.S. Dhule	07.Apr.17	08:00	07.Apr.17	18:00	Daily	Maintenance work & routine testing	MSETCL	MSETCL			
89	237	400	Babhaleshwar-Bhusawal @ BBLR	07.Apr.17	08:00	07.Apr.17	17:00	Daily	PG Isolators alignment and servicing work.	MSETCL	MSETCL			
90	242	400	AURANGABAD(MSETCL)-PUNE(GIS) I	07.Apr.17	08:00	07.Apr.17	17:00	Daily	Bay Eqpt AMP Works at Msetcl, Waluj SS	WRTS-I	WRTS-I	R		
91	246	220	202 Bay (Main bay of 220 Talegaon Line # 1) at Talegaon. The 220 Talegaon Line 1 will remain in service through Transfer Bus	07.Apr.17	08:00	07.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
92	250	400	400 DHARIWAL TPP-PARLI II	07.Apr.17	08:00	07.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C		
93	254	400	Main Bus-1 @400 Kumbhargao	08.Apr.17	09:00	08.Apr.17	12:00	Daily	Routine Maintenance Works as per annual outage plan & Meas. Of Bus CVT Tan-D.	MSETCL	MSETCL			
94	256	400	400/220 ICT - I at 400 Deepnagar	08.Apr.17	08:00	08.Apr.17	17:00	Daily	Diagnostic testing of ICT units and routine maintenance	MSETCL	MSETCL			
95	258	400	400 Boisar-Padghe Line	08.Apr.17	08:00	15.Apr.17	18:00	Daily	400 Boisar-padghe line will be in NON-AUTO Mode simultanuesly for HOT LINE WORK of 400 Augrangabad-Boisar Line crossing	POWER GRID	WR-II	C		
96	259	400	400 Boisar-Vapi Line	08.Apr.17	08:00	15.Apr.17	18:00	Daily	400 Boisar-padghe line will be in NON-AUTO Mode simultanuesly for HOT LINE WORK of 400 Augrangabad-Boisar Line crossing	POWER GRID	WR-II	C		
97	266	400	Bus Coupler @ BBLR	08.Apr.17	09:00	08.Apr.17	17:00	Daily	Maintenance work	MSETCL	MSETCL	Bus will be seperated		
98	267	400	80MVAR Reactor 1 @ BBLR	08.Apr.17	09:00	08.Apr.17	17:00	Daily	Maintenance work	MSETCL	MSETCL	80MVAR Reactor II will be in service		
99	268	400	AURANGABAD(MSETCL)-PUNE(GIS) II	08.Apr.17	09:00	08.Apr.17	18:00	Daily	Bay Eqpt AMP Works at Msetcl, Waluj SS	WRTS-I	WRTS-I	R		
100	269	765	765 Main Bay 815 of Wardha #1 at Durg PS	08.Apr.17	09:00	08.Apr.17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	R		
101	270	400	400 Bus-II at Parli PG	08.Apr.17	10:00	08.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	Date to be shifted same day parli line	Maharashtra consent required	
102	271	220	205 Bay (220 Side of ICT# 2) at Talegaon. ICT will Remain in Service through TBC	08.Apr.17	09:00	08.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
103	272	400	SOLAPUR_BAY 405_TIE BAY ICT#3 & FUTURE	08.Apr.17	09:00	08.Apr.17	18:00	DAILY	AMP 17-18	WRTS-1	POWERGRID	R		
104	273	220	220 KV Wardha- Pusad line	08.Apr.17	09:00	08.Apr.17	18:00	Daily	CT sampling work and AR testing work	WRTS-I	WRTS-I	R		
105	274	400	Chandrapur (Old GCR)-Parli ckt-III @400 Parli	09.Apr.17	08:00	09.Apr.17	17:00	Daily	Broken Disc replacement at loction No. 842, 873	MSETCL	MSETCL			
106	275	400	400 Bus Reactor-2 & Parli-2 (MSETCL) Tie Bay (417) at Parli	09.Apr.17	08:00	09.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R		
107	276	765	765kV Bus-1 at Aurangabad	09.Apr.17	08:00	09.Apr.17	18:00	Daily	for construction of future Solapur-1&2 main bays 713 & 716	WRTS-I	WRTS-I	C		
108	277	400	400 Kalwa-Talegaon Line	09.Apr.17	08:00	09.Apr.17	17:00	Daily	Line Maint work					
109	278	400/220	500 MVA, ICT - i @ Kalwa	09.Apr.17	08:00	09.Apr.17	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
110	284	400	Chandrapur-II - Parli Ckt-I	10.Apr.17	08:00	10.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
111	287	400	400 Boisar-kala	10.Apr.17	08:00	13.Apr.17	18:00	Daily	Outage for spacing and jumpering works in 400 D/C Auragabad-Boisar line in Multi circuit towers due to heavy induction.	POWER GRID	WR-II	C		
112	294	765	Vadodara Dhule Line	10.Apr.17	10:00	10.Apr.17	18:00	Daily	For Bushing RTV Cotting	POWERGRID	WR-II	C		
113	297	400	400 Main Bus-1 at BDTCL Dhule	10.Apr.17	08:00	11.Apr.17	18:00	Daily	For AMP Works		BDTCL	BDTCL	R	
114	299	765	706 Bus Reactor at Koradi III SS	10.Apr.17	10:00	10.Apr.17	13:00	Daily	For CSD commissioning. It requires 2 to 3 Switch OFF & ON opeartion of both Tie & Main CB (705 QS2 & 706 QS2)	MEGPTCL	MEGPTCL			
115	300	400	400 Akola-Yelwan Ckt-1 with Bay 414& 415 @ 400 RS Akola	10.Apr.17	10:00	10.Apr.17	18:00	Daily	Routine Maintenance & testing work of line and its associated bays Equipments	MSETCL	MSETCL			
116	301	400/220	105MVA, Spare unit ICT 1 @ BBLR	10.Apr.17	09:00	10.Apr.17	17:00	Daily	Maintenance work	MSETCL	MSETCL	NA		
117	302	400	400 New Koyna -Stage 4 Ckt 1 @New Koyna	10.Apr.17	08:00	10.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work					
118	303	400	400 Khadka Babhleshwar S/C line @400 Khadka	10.Apr.17	08:00	15.Apr.17	18:00	Daily	PID testing. During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL			
119	304	400/220	501MVA, ICT 3 @ Talandge	10.Apr.17	10:00	10.Apr.17	18:00	Daily	Annual Maintenance work and pre Monsoon Maintenance work	MSETCL	MSETCL			
120	305	220	Mudshingi- Chikodi	10.Apr.17	08:00	10.Apr.17	17:00	Daily	Bay Maintenance and testing work.	MSETCL	MSETCL			
121	310	765	AURANGABAD-SOLAPUR-I	10.Apr.17	08:00	12.Apr.17	18:00	Continuou	For Swapping of 765kV Solapur Line in Solapur Bays at Aurangabad.	WRTS-I	WRTS-I	C	ATC/TTC Revision required	
122	311	765	AURANGABAD-SOLAPUR-II	10.Apr.17	08:00	12.Apr.17	18:00	Continuou	For Swapping of 765kV Solapur Line in Solapur Bays at Aurangabad.	WRTS-I	WRTS-I	C	ATC/TTC Revision required	

ANNEXURE 3.2 (WR OCC-493)													
Outage Planning of Transmission elements during the Month of April 2017													
Sr no.	WRPC OCCM-493 SN	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC Comments
				Date	Time	Date	Time						
123	312	765	AURANGABAD (PG)_SOLAPUR_I_240 MVAR SWITCHABLE LR at Aurangabad	10.Apr.17	07:00	11.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
124	316	220	220 Bus # 2 at Talegaon	10.Apr.17	09:00	10.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
125	319	400	400 BHADRAVATI-PARLI I	10.Apr.17	08:00	10.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S,H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
126	322	220	220 KV Bus # 2 at Wardha	10.Apr.17	09:00	10.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
127	323	400	Akola-1 LR at Aurangabad	10.Apr.17	09:00	11.Apr.17	18:00	Continuou	for arresting oil leakages by replacing Radiator butterfly valves. Line shall remain in service after taking out L/R	WRTS-I	WRTS-I	R	
128	327	400	407 Vapi -Boisar line	11.Apr.17	09:00	11.Apr.17	17:00	Daily	Bay AMP work	POWERGRID	WR-II	R	
129	331	400	400 BHADRAVATI-PARLI I	11.Apr.17	08:00	11.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S,H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
130	334	400	400 DHL- SSNNL Line Ckt-I & II	11.Apr.17	09:00	12.Apr.17	17:00	Daily	PID testingDuring the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
131	351	400	400 NEW KOYANA-II @ Karad	11.Apr.17	10:00	11.Apr.17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL		
132	352	765	ICT- 1 at Koradi III SS	11.Apr.17	10:00	11.Apr.17	13:00	Daily	For CSD commissioning. It requires 4 to 5 Switch OFF & ON opeartion of both Tie & Main CB (701 Q52 & 702 Q52)	MEGPTCL	MEGPTCL		
133	353	765	ICT- 2 at Koradi III SS	11.Apr.17	14:00	11.Apr.17	18:00	Daily	For CSD commissioning. It requires 4 to 5 Switch OFF & ON opeartion of both Tie & Main CB (704 Q52 & 705 Q52)	MEGPTCL	MEGPTCL		
134	354	400	400 TBC Bay@ 400 Parli	11.Apr.17	09:00	11.Apr.17	17:00	Daily	Dignostic Testing work	MSETCL	MSETCL		
135	355	400	KORADI - BHUSAWAL	11.Apr.17	08:00	12.Apr.17	19:00	Daily	For restringing work, for increasing the low clearance SAG in the span between Loc No. 5 & 6 & Loc No. 111 & 112. The clearance between span 05 & 6 is below 8 meters & 111 & 112 is 8.20 metes.	MSETCL	MSETCL		
136	361	400	400 Parli (PG)-1 Main Bay(411) at MSETCL Girawli	11.Apr.17	10:00	11.Apr.17	18:00	Daily	For Bay AMP works at MSETCL Girawli	WRTS-I	WRTS-I	R	
137	363	765	BAY-Future 708_TIE BAY_765KV AURANGABAD#1@SOLAPUR	11.Apr.17	09:00	11.Apr.17	18:00	DAILY	AMP 17-18	WRTS-1	POWERGRID	R	
138	365	400	400 DHARIWAL TPP-PARLI II	11.Apr.17	08:00	11.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S,H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
139	370	400	400 DHARIWAL TPP-PARLI II	12.Apr.17	08:00	12.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S,H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
140	381	400	400 Main Bus-2 at BDTCL Dhule	12.Apr.17	08:00	13.Apr.17	18:00	Daily	For AMP Works	BDTDCL	BDTCL	R	
141	386	765	765KV Tirora- Koradi-3 Line -2	12.Apr.17	09:00	12.Apr.17	20:00	Daily	Line Shutdown required for restroration of reactor IPS tube , bushing & LA/BPI structure.	MEGPTCL	MEGPTCL		
142	387	400	Main Bay-410 only, of 400 Station Transformer -8A ckt @400 Switching Substation Chandrapur.	12.Apr.17	09:00	12.Apr.17	18:00	Daily	Diagnostic Testing & Allied Bay Maintenance work	MSETCL	MSETCL		
143	388	220	Wardha (PGCL)-Badnera Line	12.Apr.17	08:00	13.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
144	389	400	Chandrapur-II(New GCR)-Nanded -1	12.Apr.17	10:30	12.Apr.17	17:00	Daily	Tightening of U-Bolt of conductor at loc. No. 850, 854	MSETCL	MSETCL		
145	390	400	400 NewKoyna-Stage 4 Ckt 2 @New Koyna	12.Apr.17	08:00	12.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work				
146	391	400	Khaperkheda- Chandrapur Tie Bay-418 @Khaperkheda	12.Apr.17	10:00	12.Apr.17	14:00	Daily	DCRM,CRM,Timing, IR measurement of Circuit Breaker & RM work	MSETCL	MSETCL		
147	392	400	Nagothane-Padghe 2 Line @ Nagothane	12.Apr.17	09:00	12.Apr.17	17:00	Daily	To carry out Line Signature Analysis & Routine Maintenance	MSETCL	MSETCL		
148	399	765	AURANGABAD (PG)_SOLAPUR_II_240 MVAR Switchable LR at Aurangabad	12.Apr.17	07:00	13.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
149	400	400	400 BUS-1 at Talegaon	12.Apr.17	09:00	12.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
150	402	400	400 BHADRAVATI-PARLI I	12.Apr.17	08:00	12.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S,H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
151	403	400	400 Bus # 2 at Wardha	12.Apr.17	09:00	13.Apr.17	18:00	Continuou	for extension of 400 Wardha-Aurangabad bays	WRTS-I	WRTS-I	C	
152	404	765	Seoni (PG)_ Wardha I_240 MVAR SLR at Seoni SS	12.Apr.17	07:00	13.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
153	409	400	400 Bus # 1 at Wardha SS	13.Apr.17	09:00	14.Apr.17	18:00	Continuou	for extension of 400 Wardha-Aurangabad bays	WRTS-I	WRTS-I	C	
154	425	765	Bus Reactor at MEGPTCL-765/400 Akola-II SS.	13.Apr.17	11:00	13.Apr.17	15:00	Daily	For CSD commissioning. It requires 2 to 3 Switch OFF & ON opeartion of both Tie & Main CB (702 Q52 & 703 Q52)	MEGPTCL	MEGPTCL		
155	426	400	400 Akola- Nandgaonpeth Line	13.Apr.17	12:00	15.Apr.17	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Koradi-Bhusawal , 400 Akola-Bhusawal & 400 Koradi-Nandgao npeth are in service.	
156	427	400	PID of insulator strings of New 400/220/33kv ICT -2 Gantry at 400 Rs Akola	13.Apr.17	10:00	13.Apr.17	17:00	Daily	PID of insulator string	MSETCL	MSETCL		
157	428	400	400 CHD-I - CHD-II ckt. No.-I@400 S/S Chandrapur	13.Apr.17	08:00	14.Apr.17	18:00	Daily	1) Attending the Hot spot & Maintenance of PG isolator & CB Isolator. 2) Providing the Expansion flexible clamp to P1 side of R, Y & B-ph Ckt's	400 AC	MSETCL		
158	429	400	400 Parli -Lonikand ckt-I	13.Apr.17	09:00	13.Apr.17	18:00	Daily	Arcing horn & Quarter Pin replacement work at Loc No-54,57,58,59,63,47,49,50	MSETCL	MSETCL		
159	430	400	Chandrapur II(New GCR) - Parli Ckt-I	13.Apr.17	11:30	13.Apr.17	17:00	Daily	Hardware tightening at loc. 847, 848, 825, (Points Observed during Monkey Patrolling)	MSETCL	MSETCL		
160	431	400	400 Chandrapur-2 (402 Main Bay) and (403 TIE Bay) at 400 Kumbhargao	13.Apr.17	09:00	13.Apr.17	12:00	Daily	Routine maintenance work as per annual outage plan.	MSETCL	MSETCL		
161	432	400	Bus Coupler @ Talandge	13.Apr.17	10:00	13.Apr.17	18:00	Daily	Annual Maintenace work	MSETCL	MSETCL		
162	433	400	413-Bay (Main bay) & 412-Bay (Tie bay) of Lonikand-II -Parali ckt I at Lonikand-II Substation	13.Apr.17	09:00	13.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
163	446	400	400 DHARIWAL TPP-PARLI II	13.Apr.17	08:00	13.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S,H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
164	448	400	400 Akola-Aurangabad Main Bay 407 at Wardha	13.Apr.17	09:00	13.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
165	460	400	400 Dhule(BDTCL)-Dhule(MSETCL) Line 1	14.Apr.17	08:00	14.Apr.17	18:00	Daily	For AMP Works	BDTDCL	BDTCL	R	
166	463	765	ICT- 1 at MEGPTCL-765/400 Akola-II SS.	14.Apr.17	11:00	14.Apr.17	15:00	Daily	For CSD commissioning. It requires 2 to 3 Switch OFF & ON opeartion of both Tie & Main CB (702 Q52 & 701 Q52)	MEGPTCL	MEGPTCL		
167	464	400	400/220 ICT - II at 400 Deepnagar	14.Apr.17	09:00	14.Apr.17	17:00	Daily	Diagnostic testing of ICT units and routine maintenance	MSETCL	MSETCL		
168	467	765/400	AURANGABAD (PG)_ ICT1_765/400_1500 MVA	14.Apr.17	07:00	15.Apr.17	19:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	C	
169	470	400	400 BUS-2 at Talegaon	14.Apr.17	09:00	14.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
170	474	765	Seoni (PG)_ Wardha II_240 MVAR SLR at Seoni	14.Apr.17	07:00	15.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
171	475	765	765 Wardha-Aurangabad # 2 Main Bay 713 at Wardha	15.Apr.17	09:00	21.Apr.17	18:00	Continuou	Replacement of Mechanism boxes	WRTS-I	WRTS-I	R	Changed from 1-8 to 15-21 april
172	476	400	400 Boisar-Padghe	15.Apr.17	08:00	20.Apr.17	18:00	Daily	400 Boisar-Padghe,400 Boisar-Vapi,400 Tarapur-Boisar-I&II will be kept in non-auto mode simultanuesly for power line crossing work through HOT LINE of 400 D/C .Aurangabad-Boisar Line	POWERGRID	WR-II	C	Shall be availed along with unit outage schedule of TAPS from 15th April
173	477	400	400 Boisar-Vapi Line	15.Apr.17	08:00	20.Apr.17	18:00	Daily	400 Boisar-Padghe,400 Boisar-Vapi,400 Tarapur-Boisar-I&II will be kept in non-auto mode simultanuesly for power line crossing work through HOT LINE of 400 D/C .Aurangabad-Boisar Line	POWERGRID	WR-II	C	Shall be availed along with unit outage schedule of TAPS from 15th April
174	478	400	400 Tarapur-Boisar-I	15.Apr.17	08:00	20.Apr.17	18:00	Daily	400 Boisar-Padghe,400 Boisar-Vapi,400 Tarapur-Boisar-I&II will be kept in non-auto mode simultanuesly for power line crossing work through HOT LINE of 400 D/C .Aurangabad-Boisar Line	POWERGRID	WR-II	C	Shall be availed along with unit outage schedule of TAPS from 15th April
175	479	400	400 Tarapur-Boisar-II	15.Apr.17	08:00	20.Apr.17	18:00	Daily	400 Boisar-Padghe,400 Boisar-Vapi,400 Tarapur-Boisar-I&II will be kept in non-auto mode simultanuesly for power line crossing work through HOT LINE of 400 D/C .Aurangabad-Boisar Line	POWERGRID	WR-II	C	Shall be availed along with unit outage schedule of TAPS from 15th April
176	484	400	400 Dhule(BDTCL)-Dhule(MSETCL) Line 2	15.Apr.17	08:00	15.Apr.17	18:00	Daily	For AMP Works	BDTDCL	BDTCL	R	
177	489	400	A Bus with B/C @Kharghar	15.Apr.17	09:00	16.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
178	490	400	Babhaleshwar-Aurangabad @ BBLR	15.Apr.17	09:00	15.Apr.17	17:00	Daily	PG Isolators alignment and servising work.	MSETCL	MSETCL		
179	491	400	Chandrapur GCR - Parli Ckt-III	15.Apr.17	08:00	15.Apr.17	18:00	Daily	For Routine Maintenance work	MSETCL	MSETCL		
180	492	400	Busbar Protection testing [Without any outage on line/ICT/CB] @Jejuri	15.Apr.17	09:30	15.Apr.17	17:30	Daily	Busbar Protection testing 400 Bus I and Bus II	MSETCL	MSETCL	Bus bar protection will be out during testing.	
181	493	765	765 Bus-1 at Koradi III SS	15.Apr.17	08:00	15.Apr.17	18:00	Daily	For Annual Maintenace of Bus Equipments	MEGPTCL	MEGPTCL		
182	494	400	Babhaleshwar-Dhule-Ckt-2 @ BBLR	15.Apr.17	09:00	15.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	400 Babhaleshwar-Dhule-Ckt-1 will be in service	
183	497	765	SOLAPUR_BAY 717_TIE BAY_765KV RAICHUR#1 AND BUS REACTOR at Solapur	15.Apr.17	09:00	15.Apr.17	18:00	DAILY	REPLACEMENT OF FAULTY AUX. AND LIMIT SWITCHES	WRTS-1	POWERGRID	R	

ANNEXURE 3.2 (WR OCC-493)													
Outage Planning of Transmission elements during the Month of April 2017													
Sr no.	WRPC OCCM-493 SN	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC Comments
				Date	Time	Date	Time						
184	498	400	400 BHADRAVATI-PARLI I	15.Apr.17	08:00	15.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	R	
185	503	400	Padghe Kalwa 2 @Padgha	16.Apr.17	08:00	16.Apr.17	08:00	Daily	Routine R&M work	MSETCL	MSETCL		
186	504	765/400	AURANGABAD (PG)_ ICT2_ 765/400_ 1500 MVA	16.Apr.17	07:00	17.Apr.17	19:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	C	
187	510	400	Bay No-401 Main Bay of 400 Augrangabad-Boisar-II at Boisar	17.Apr.17	09:00	17.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
188	527	400	400/220 ICT-I @ Karad	17.Apr.17	10:00	17.Apr.17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	Load manage on ICT-II & III	
189	528	400	Jaigad-Karad Ckt-1	17.Apr.17	08:00	17.Apr.17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
190	529	765	Main Bay (707) of Tiroda -Koradi Line-2 at Koradi III SS	17.Apr.17	07:00	17.Apr.17	18:00	Daily	For Annual Maintenace of Bay Equipments	MEGPTCL	MEGPTCL		
191	530	400	400 Akola-Yelwan Ckt-2 with Bay 417& 418 @ 400 RS Akola	17.Apr.17	10:00	17.Apr.17	18:00	Daily	Routine Maintenance & testing work of line and its associated bays Equipments	MSETCL	MSETCL		
192	531	400	400 Koyna Stage 4 -Lonikand @ Koyna Stg IV	17.Apr.17	08:00	17.Apr.17	18:00	Daily	Routine Maintenance & Relay testing work				
193	532	400	400 DHL- BBLR line Ckt-I & II	17.Apr.17	09:00	17.Apr.17	17:00	Daily	PID testing .During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
194	533	400	400 Khadka Aurangabad S/C line @400 Khadka	17.Apr.17	08:00	22.Apr.17	18:00	Daily	PID testing During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
195	539	400	400 Wardha -2 & Pune-2 Tie Bay (405) at parli	17.Apr.17	10:00	17.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	
196	542	400	SOLAPUR_BAY 407_MAIN BAY ICT#2	17.Apr.17	09:00	18.Apr.17	18:00	Contin uous	SF6 LEAKAGE ARRESTING WORKS	WRTS-1	POWERGRID	R	
197	545	765	BUS REACTOR_765kV_330MVAR_WARDHA	17.Apr.17	09:00	18.Apr.17	18:00	Contin uous	for auxiliary bus construction work	WRTS-I	WRTS-I	C	
198	547	400	Akola-2 LR at Aurangabad	17.Apr.17	09:00	18.Apr.17	18:00	Contin uous	for arresting oil leakages by replacing Radiator butterfly values. Line shall remain in service after taking out L/R	WRTS-I	WRTS-I	R	
199	550	400	Bay No-402 Tie Bay of 400 Augrangabad-Boisar-II & Future bay at Boisar	18.Apr.17	09:00	18.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
200	567	400	Jaigad-Karad Ckt-2	18.Apr.17	08:00	18.Apr.17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
201	568	400/220	315MVA, ICT 3 @Kharghar	18.Apr.17	09:00	18.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
202	569	400	400 CHD-Parli ckt. - 3 @400 S/S Chandrapur	18.Apr.17	08:00	19.Apr.17	18:00	Daily	Attending the Hot spot & Maintenance of PG isolator & CB Isolator	400 AC	MSETCL		
203	570	400	Chandrapur (Old GCR)-Parli ckt-III @400 Parli	18.Apr.17	12:30	18.Apr.17	17:00	Daily	Armoring of conductor at Loc. No. 830	MSETCL	MSETCL		
204	571	400	400 DHL- BBLR line Ckt-I & II	18.Apr.17	09:00	18.Apr.17	17:00	Daily	PID testing.During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
205	572	400/220	167MVA, Spare ICT @ Talandge	18.Apr.17	10:00	18.Apr.17	18:00	Daily	Annual Maintenace work and pre Monsoon Maintenance work	MSETCL	MSETCL		
206	578	220	Kalwa-Ghatghar D/C Line	18.Apr.17	06:00	19.Apr.17	18:00	Contin uous	Powerline crossing works of 765kV D/C Aurangabad-Padghe between tower location Nos 343/0 & 344/0	MSETCL	WRTS-I	Line Nomenclature is not clear .Proper identification is required .	
207	579	400	400 Pune (future) bay (Bay no:409)	18.Apr.17	10:00	18.Apr.17	18:00	Daily	Bay AMP works	WRTML/ WRTS-I	WRTS-I	R	
208	580	400	400 Pune-2 Main Bay (406) at Parli	18.Apr.17	10:00	18.Apr.17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	
209	581	400	401 Bay (Main Bay of 400 Talegaon Chakan Line) at Talegaon	18.Apr.17	09:00	18.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	This outage to be availed on 20.04.2017 Thursday .	
210	583	765	765 719 bay Wardha-Aurangabad# 3 Main bay at Wardha	18.Apr.17	09:00	18.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
211	584	765	Main Bay 718 of 765 Wardha-Durg # 1 at Wardha	18.Apr.17	09:00	18.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
212	585	765	Solapur (PG)_Raichur_II_240 MVAR SLR at Solapur SS	18.Apr.17	07:00	19.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
213	590	400	Bay No-404 Main Bay of ICT-III at Boisar	19.Apr.17	09:00	19.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
214	603	400	Jaigad-Newkoyna Ckt-1	19.Apr.17	08:00	19.Apr.17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
215	604	400	Tie Bay-411 only, of 400 Station Transformer -8A ckt @400 Switching Substation Chandrapur	19.Apr.17	09:00	19.Apr.17	18:00	Daily	Diagnostic Testing & Allied Bay Maintenance work	MSETCL	MSETCL		
216	605	220	Wardha (PGCL) -Badnera Line	19.Apr.17	08:00	20.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
217	610	400	400 Khandwa-Dhule Ckt-I	19.Apr.17	09:00	20.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-I	WRTS-I	C	
218	611	400	405 Bay (Tie Bay of 400 Talegaon GIS Line 1 & ICT # 1) at Talegaon	19.Apr.17	09:00	19.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
219	614	400	SOLAPUR_BAY 412_ MAIN BAY KARAD LINE	19.Apr.17	09:00	20.Apr.17	18:00	Contin uous	SF6 LEAKAGE ARRESTING WORKS	WRTS-1	POWERGRID	R	
220	618	400	Bay No-405 Tie Bay of 400 Augrangabad-Boisar-II & ICT-III at Boisar	20.Apr.17	09:00	20.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
221	631	400	400 Parli-Lonikand ckt II @ 400 Parli	20.Apr.17	09:00	20.Apr.17	17:00	Daily	Bay maintenance and testing work at Parli and Line Maint.at Lonikand	MSETCL	MSETCL		
222	632	400	Jaigad-Newkoyna Ckt-2	20.Apr.17	08:00	20.Apr.17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
223	633	765	Main Bay (712) of Akola - Koradi Line-2 at Koradi III SS	20.Apr.17	07:00	20.Apr.17	18:00	Daily	For Annual Maintenace of Bay Equipments	MEGPTCL	MEGPTCL		
224	634	400	400 Koradi- Bhusawal Line	20.Apr.17	12:00	22.Apr.17	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Akola-Bhusawal , 400 Akola-Nandgaonpeth & 400 Koradi-Nandgaonpeth are in service.	
225	635	400	315MVA , ICT2 @ 400 Parli	20.Apr.17	09:00	20.Apr.17	17:00	Daily	Bay maintenance and testing work.	MSETCL	MSETCL		
226	636	400/220	501MVA ,ICT-2 (407 Main Bay) andTIE Bay (406 Bay) at 400Kumbhargaoon	20.Apr.17	11:00	20.Apr.17	17:00	Daily	Routine maintenance work as per annual outage plan.	MSETCL	MSETCL		
227	637	400	400/220 501 MVA ICT-III at 400 Khadka substation	20.Apr.17	09:00	29.Apr.17	17:30	Contin uous	Replacement of B-ph unit with New repaired spare Unit	MSETCL	MSETCL		
228	638	400/220	315 MVA, ICT 2 @ Nagothane	20.Apr.17	09:00	20.Apr.17	17:00	Daily	To carry out Routine Maintenance work	MSETCL	MSETCL		
229	644	765	Main Bay 706 of 765 ICT# 2 at Wardha	20.Apr.17	09:00	20.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
230	650	400	Bay No-406 Main Bay of 400 Augrangabad-Boisar-I at Boisar	21.Apr.17	09:00	21.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
231	662	220	220 KV Navsari-Nashik line no.1	21.Apr.17	09:00	21.Apr.17	18:00	Daily	Line maintenance & Tan delta testing work	GETCO	GETCO		
232	663	400	Chandrapur-II(New GCR)-Nanded	21.Apr.17	13:30	21.Apr.17	17:00	Daily	Tension plate n/b tightening at loc. No. 849, 848, 855	MSETCL	MSETCL		
233	664	400	Kharghar - Talegaon @ Kharghar	21.Apr.17	09:00	21.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
234	665	400	413-Bay (Main Bay of Nandgaon Ckt) at 400 RS Akola	21.Apr.17	10:00	21.Apr.17	17:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL		
235	666	400	Chandrapur-II - Nanded Line (Ckt-II)	21.Apr.17	08:00	22.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
236	667	400	Chandrapur GCR - Parli Ckt-III	21.Apr.17	08:00	22.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
237	668	400	Babhaleshwar-Padghe-Ckt-2 @ BBLR	21.Apr.17	09:00	21.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	400 Babhaleshwar-Padghe-Ckt-1 will be in service	
238	669	400	KORADI 2-IEPL	21.Apr.17	08:00	21.Apr.17	17:00	Daily	Line signature test, broken disc replacement work,tightning and fixing of jumper nutbolts & hardwares on line and earthwire	MSETCL	MSETCL		
239	670	400	400/11kV STN-4B at 400 Deepnagar	21.Apr.17	09:00	21.Apr.17	17:00	Daily	Bay routine maintenance	MSETCL	MSETCL		
240	674	400	400 Khandwa-Dhule Ckt-II	21.Apr.17	09:00	22.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-II	WRTS-I	C	

ANNEXURE 3.2 (WR OCC-493)													
Outage Planning of Transmission elements during the Month of April 2017													
Sr no.	WRPC OCCM-493 SN	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC Comments
				Date	Time	Date	Time						
241	675	400	Aurangabad-Aurangbaad-1 along with Main Bus-1 at Msetcl, Waluj SS	21.Apr.17	09:00	21.Apr.17	17:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers	MSETCL	WRTS-I	R	
242	676	400	400 AURANGABAD(PG)-AURANGABAD(MSETCL) I	21.Apr.17	08:00	21.Apr.17	17:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers	MSETCL	MSETCL	R	
243	679	400	SOLPAUR_BAY 415_ MAIN BAY KOLAHAPUR#1 LINE	21.Apr.17	09:00	22.Apr.17	18:00	Continu ous	SF6 LEAKAGE ARRESTING WORKS	WRTS-1	POWERGRID	R	
244	680	765	Tie Bay 708 of 765 ICT# 3- BR1 at Wardha	21.Apr.17	09:00	21.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
245	681	765	AURANGABAD (PG)_SOLAPUR_I_240 MVAR SWITCHABLE LR at Aurangabad	21.Apr.17	07:00	22.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
246	686	220	Bay no-201 Main Bay of ICT-I at Boisar	22.Apr.17	09:00	22.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
247	692	220	220 KV Navsari-Nashik line no.2	22.Apr.17	09:00	22.Apr.17	18:00	Daily	Line maintenance & Tandelta testing work	GETCO	GETCO		
248	693	400	Padghe Tarapur-1 @Padgha	22.Apr.17	08:00	22.Apr.17	08:00	Daily	Routine R&M work	MSETCL	MSETCL		
249	697	765	Main Bay 709 of 765 ICT# 3 at Wardha	22.Apr.17	09:00	22.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
250	700	220	Bay no-202 Main Bay of 220 Boisar-Boisar-III at Boisar	23.Apr.17	09:00	23.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
251	702	400	400 Padghe-Talegaon Line	23.Apr.17	08:00	23.Apr.17	17:00	Daily	Line Maint work				
252	703	400/220	600 MVA, ICT - II @ Kalwa	23.Apr.17	08:00	23.Apr.17	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
253	706	400	400 Khandwa-Dhule Ckt-I	23.Apr.17	09:00	24.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-II	WRTS-I	C	
254	707	765	AURANGABAD (PG)_SOLAPUR_II_240 MVAR SWITCHABLE LR at Aurangabad	23.Apr.17	07:00	24.Apr.17	19:00	Daily	for RTV coating on HV Bushings. Line shall remain in service	WRTS-I	WRTS-I	C	
255	719	400	Waluj-Khadka ckt @ Waluj	24.Apr.17	10:00	24.Apr.17	18:00	Daily	Fixing of repair sleeve at loc. No.43-44 of R-phase	MSETCL	MSETCL		
256	720	765	Tie Bay (705) of ICT-2 and Bus Reactor at Koradi III SS	24.Apr.17	07:00	24.Apr.17	13:00	Daily	For Gripper replacement at 705 Q52	MEGPTCL	MEGPTCL		
257	721	400	403-Bay (Tie Bay of ICT - 1 & Aurangabad Ckt-1) at 400 RS Akola	24.Apr.17	10:00	24.Apr.17	17:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL		
258	722	400	400 DHL- BBLR line Ckt-I & II	24.Apr.17	09:00	25.Apr.17	17:00	Daily	PID testing. During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
259	723	400/220	315MVA, ICT 1 @ Talandge	24.Apr.17	10:00	24.Apr.17	18:00	Daily	Annual Maintenace work and pre Monsoon Maintenance work	MSETCL	MSETCL		
260	728	400	406 Bay (Main Bay of 400 IC T# 1) at Talegaon	24.Apr.17	09:00	24.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
261	731	765	Tie Bay 714 of 765 Wardha-Durg # 2 at Wardha	24.Apr.17	09:00	24.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
262	732	400	Tarapur-Boisar ckt 1	24.Apr.17	08:00	25.Apr.17	18:00	Daily	for maintenance work	PGCIL	NPCIL		
263	744	400	400 CHD-I - CHD-II ckt. No.-II@400 S/S Chandrapur	25.Apr.17	08:00	26.Apr.17	18:00	Daily	1) Attending the Hot spot & Maintenance of PG Isolator & CB Isolator. 2) Providing the Expansion flexible clamp to P1 side of R, Y & B-ph CT's	400 AC	MSETCL		
264	745	400	Chandrapur-II(New GCR)-Nanded	25.Apr.17	14:30	25.Apr.17	17:00	Daily	Hardware tightening at loc. No.875, 873, 872, 868 (Points Observed during Monkey Patrolling)	MSETCL	MSETCL		
265	750	400	400 Khandwa-Dhule Ckt-II	25.Apr.17	09:00	26.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-II	WRTS-I	C	
266	752	400	410 Bay (Main Bay of 400 Talegaon GIS Line # 4) at Talegaon	25.Apr.17	09:00	25.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
267	753	400	Main Bay 418 of 400 Bus Reactor at Wardha	25.Apr.17	09:00	25.Apr.17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	
268	755	765/400	AURANGABAD (PG)_ ICT1_765/400_1500 MVA	25.Apr.17	07:00	26.Apr.17	19:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	C	
269	757	220	Bay no-203 Main Bay of 220 Boisar-Vasai Line at Boisar	26.Apr.17	09:00	26.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
270	767	400	Chandrapur - Khaperkheda Line	26.Apr.17	08:00	26.Apr.17	17:00	Daily	Conductor & E/W Hardware tightening work at various tower Locations	MSETCL	MSETCL		
271	768	220	Wardha (PGCL) -Badnera Line	26.Apr.17	08:00	27.Apr.17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
272	773	400	400 Tie bay of Kolhapur(MSETCL) Ckt #2 & 125 MVAR Bus reactor (Bay No: 411)	26.Apr.17	10:00	26.Apr.17	18:00	Daily	Bay AMP works	WRTML/ WRTS-I	WRTS-I	R	
273	774	220	211 BAY (Main bay of 220 Chakan Line # 2) at Talegaon. Presently 220 Chakan Line # 2 does not exists.	26.Apr.17	09:00	26.Apr.17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
274	777	220	Bay no-204 Main Bay of Bus Coupler of 220 Bus-I and Bus-II at Boisar	27.Apr.17	09:00	27.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
275	790	765	Main Bay (706) of Bus Reactor at Koradi III SS	27.Apr.17	07:00	27.Apr.17	13:00	Daily	For Gripper replacement at 706 Q52	MEGPTCL	MEGPTCL		
276	791	400	Chandrapur II - Parli Ckt - I Line	27.Apr.17	08:00	27.Apr.17	17:00	Daily	Conductor & E/W Hardware tightening work at various tower Locations	MSETCL	MSETCL		
277	792	400/220	315 MVA, ICT 1 @ Nagothane	27.Apr.17	09:00	27.Apr.17	17:00	Daily	To carry out Routine Maintenance work	MSETCL	MSETCL		
278	793	400	422-Bay (Main bay) & 421-Bay (Tie bay) of 400 Interconnector-II at Lonikand-II Substation	27.Apr.17	09:00	27.Apr.17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
279	796	220	TAPS1&2 -Vapi	27.Apr.17	08:00	29.Apr.17	19:00	Daily	Annual maintenance Works	GETCO	NPCIL		
280	797	400	400 Khandwa-Dhule Ckt-I	27.Apr.17	09:00	28.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-II	WRTS-I	C	
281	798	100	Padghe 7shahpur-1&2 Line	27.Apr.17	06:00	28.Apr.17	18:00	Continu ous	Powerline crossing works of 765kV D/C Aurangabad-Padghe between tower location Nos 354/0 & 355/0	MSETCL	WRTS-I	Proposal from SE ,EHV (O&M) Circle , MSETCL ,Panvel to be obtained	
282	799	220	Padghe-Jindal & Padghe-Nasik D/C Line	27.Apr.17	06:00	28.Apr.17	18:00	Continu ous	Powerline crossing works of 765kV D/C Aurangabad-Padghe between tower location Nos 354/0 & 355/0	MSETCL	WRTS-I	Proposal from SE ,EHV (O&M) Circle , MSETCL ,Panvel to be obtained	
283	800	765/400	AURANGABAD (PG)_ ICT2_765/400_1500 MVA	27.Apr.17	07:00	28.Apr.17	19:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	C	
284	802	220	Bay no-205 Main Bay of Transfer Bus at Boisar	28.Apr.17	09:00	28.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
285	810	400	Chandrapur (Old GCR)-Parli ckt- III @ Parli	28.Apr.17	15:30	28.Apr.17	17:00	Daily	Hardware tightening at loc. No.822, 826, 827, 855, 869 (Points Observed during Monkey Patrolling)	MSETCL	MSETCL		
286	811	400	Waluj-Deepnagar @ Waluj	28.Apr.17	10:00	28.Apr.17	18:00	Daily	Replacement of damaged discs of string insulator at Loc. No. 283	MSETCL	MSETCL		
287	812	400	400 Bus Coupler @ Karad	28.Apr.17	10:00	28.Apr.17	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on BUS I& II	
288	813	400	Chandrapur II - Warora Ckt - I Line	28.Apr.17	08:00	28.Apr.17	17:00	Daily	Conductor & E/W Hardware tightening work at various tower Locations	MSETCL	MSETCL		
289	814	400	400/11kV STN-4A at 400 Deepnagar	28.Apr.17	09:00	28.Apr.17	17:00	Daily	Bay routine maintenance	MSETCL	MSETCL		
290	815	400/220/33	315MVA ,ICT-3 @ Padgha	28.Apr.17	08:00	28.Apr.17	08:00	Daily	Routine R&M work	MSETCL	MSETCL		
291	816	400	Aurangabad-Aurangbaad-1 along with Main Bus-2 at Msetcl, Waluj SS	28.Apr.17	09:00	28.Apr.17	17:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers	MSETCL	WRTS-I	R	
292	817	400	400 AURANGABAD(PG)-AURANGABAD(MSETCL) I	28.Apr.17	09:00	28.Apr.17	17:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers	WRTS-I	WRTS-I	R	
293	820	400	Tarapur Boisar Ckt 2	28.Apr.17	08:00	29.Apr.17	17:00	Daily	AMP(To be taken along with unit s/d)				
294	821	220	Bay no-206 Main Bay of 220 Boisar-Boisar-I Line at Boisar	29.Apr.17	09:00	29.Apr.17	18:00	Daily	AMP	POWER GRID	WR-II	R	
295	825	400	B Bus with B/C @ Kharghar	29.Apr.17	09:00	30.Apr.17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
296	826	765	765 Shunt reactor of Ektuni - Akola-II line 2 at MSETCL 765/400 Ektuni SS(Aurangabad-II) (Non-switchable reactor)	29.Apr.17	11:00	29.Apr.17	17:00	Daily	For erection of HV & neutral bushing of discharged spare reactor of 703-bay of 765KV Akola-II ektuni line-2 at Ektuni SS.	MSETCL	MEGPTCL		
297	827	765	Main Bay (710) of Tiroda Line-1 at Koradi III SS	29.Apr.17	07:00	29.Apr.17	08:00	Daily	For Annual Maintenace of Bay Equipments	MEGPTCL	MEGPTCL		
298	828	400	400 Khandwa-Dhule Ckt-II	29.Apr.17	09:00	30.Apr.17	18:00	Daily	For Replacement of conventional insulators with Polymer Insulators in N.H, S.H, Rail crossings,etc. for Public safety. A/R of Other Ckt to be Kept in N/A Mode	WRTS-II	WRTS-I	C	
299	832	400	400 D/C Raipur Wardha Line	30.Apr.17	08:00	30.Apr.17	18:00	Daily	Power line crossing of 400 D/C Raipur-Wardha Line at Tower No. 284 & 285 by 765KV D/C Rajnandgaon-Warora Line at Loc No. AP92/0-AP93/0	PGCIL	RRWTL		