

Outage planning of transmission elements for the month of April 2018																
Sr no	OCCM Ref No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	Type				
				Date	Time	Date	Time									
1	1	400	400 Girwal-Solapur@ Girwali	01/Apr/18	8:00	01/Apr/18	18:00	Daily	Bay maintenance & LA Replacement work	MSETCL	MSETCL					
2	5	400	Dabhol-Nagonathane Ckt 1 Line@Dabhol	01/Apr/18	8:00	06/Apr/18	18:00	Daily	For Cold washing , insulator replacement ,Earth wire replacement	MSETCL	MSETCL					
3	7	400	Chandrapur -2 -Kumbhargaoon (Nanded) Ckt-I	01/Apr/18	6:00	15/Apr/18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL					
4	11	220	Deoli (PGCIL)- Pusad line	01/Apr/18	7:00	30/Apr/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL					
5	12	400	400 Jejuri - Lonikand	01/Apr/18	7:00	30/Apr/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL					
6	13	400	400 Warora -Chandrapur I& II	01/Apr/18	7:00	30/Apr/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off				
7	14	400	400 Koradi-1 -Khaperkheda I & II	01/Apr/18	7:00	30/Apr/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off				
8	15	400	Chandrapur GCR - Chandrapur -2 (Ckt-1 & 2)	01/Apr/18	7:00	30/Apr/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off				
9	16	400	Chandrapur -2 Chandrapur Switch (Ckt-1 & 2)	01/Apr/18	7:00	30/Apr/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off				
10	17	400	Ektuni - Thapthanda (Ckt-1 & ckt-2)	01/Apr/18	7:00	30/Apr/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off				
11	18	400	400 Parli -Lamboti	01/Apr/18	9:00	30/Apr/18	18:00	Daily	A/R in Non Auto mode at both ends for PID of Insulator strings .	MSETCL	MSETCL					
12	19	400	Padghe -Babhaleshwar 2	01/Apr/18	9:00	30/Apr/18	18:00	Daily	A/R in Non Auto mode at both ends for PID of Insulator strings .	MSETCL	MSETCL					
13	20	400	400 WARDHA-PARLI-I	01/Apr/18	9:00	30/Apr/18	18:00	Daily	A/R in Non-auto mode for OPGW work.	WRTS-I	WRTS-I	C	Line-AR			
14	30	400	400Khadka-Akola	02/Apr/18	6:00	02/Apr/18	18:00	Daily	PID Testing , Non Autoreclosure	MSETCL	MSETCL					
15	34	400	400 Dhule-SSNNL Ckt-1 & 2	02/Apr/18	8:00	02/Apr/18	18:00	Daily	Online PID Testing Work.	MSETCL	MSETCL					
16	36	400	Bay No-407 Main Bay of 400 Padghe-boisar Line at Boisar	02/Apr/18	8:30	02/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
17	38	765	765kV Padghe-1 Main bay (710) at Aurangabad	02/Apr/18	9:00	02/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
18	42	400	400Kalwa 1 @ Padghe	02/Apr/18	8:00	02/Apr/18	18:00	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe ICS				
19	46	765	765kV PUNE(GIS)-SOLAPUR	02/Apr/18	9:00	04/Apr/18	18:00	Cont?	For Inspection of Tie bay GIS module-Abnormal sound observed	WRTS-I	WRTS-I	R	Line			
20	48	220	PGCIL Deoli-Badnera Ckt @Badnera	02/Apr/18	8:00	07/Apr/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL					
21	51	400	Chandrapur II- Nanded Ckt-I	02/Apr/18	8:00	14/Apr/18	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL					
22	55	400	400 Kalwa-Padghe Line-1	02/Apr/18	8:00	02/Apr/18	18:00	Daily	Insulator Replacement work found faulty in PID testing and diagnostic testing work.	MSETCL	MSETCL			preponed and clubbed with other outage		
23	56	400/220	400Padghe I @ Kalwa	02/Apr/18	9:00	02/Apr/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL			preponed and clubbed with other outage		
24	63	400	400 Wardha-Warora & 400 IEPL Koradi-Warora	03/Apr/18	7:00	04/Apr/18	18:00	Cont?	For Power line crossing of UIC 765kV DC Warora-Parli line	MSETCL	WRTS-I	C	Line			Which section crossing is to be done ? Wether Koradi-IEPL or IEPL-Warora is required . Proposal fro SE EHV (OS&M) Circle required .
25	66	400	Bay No-408 Tie Bay of 400 Boisar-Padghe Line & ICT-I at Boisar	03/Apr/18	8:30	03/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
26	69	765	765kV Padghe-2 & Future Tie Bay (708) at Aurangabad	03/Apr/18	9:00	03/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
27	74	400	400 Bhadravati-I Main Bay (407) at Parli	03/Apr/18	10:00	03/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay			
28	88	400	400 Dhule-SSNNL Ckt-1 & 2	04/Apr/18	8:00	04/Apr/18	18:00	Daily	Online PID Testing Work.	MSETCL	MSETCL					
29	96	400	Bay No-409 Main Bay of 315 MVA ICT-1 at Boisar	04/Apr/18	8:30	04/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
30	98	220	220Bus-2 at Talegaon	04/Apr/18	9:00	04/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bus			Wednesday - To be availed on Thursday
31	99	400	ICT Main Bay 403 at Tiroda SS	04/Apr/18	9:00	04/Apr/18	18:00	Daily	Testing & Maintenance of Breaker and isolator	APML	APML					
32	101	765	765kV ICT-1 Main bay (703) at Aurangabad	04/Apr/18	9:00	04/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
33	106	220	220 PGCIL/Jeur Line @Jeur	04/Apr/18	10:00	04/Apr/18	16:00	Daily	Quarterly Maintenance & Dignostic testing work	MSETCL	MSETCL					
34	110	220	Bugaon - Wardha PGCIL line	04/Apr/18	10:00	04/Apr/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL					
35	122	400	400Chandrapur- Khumbhargaoon(Nanded) Ckt-1&08 Main bay & 407 Tie Bay) @ 400 Chandrapur-II s/s	05/Apr/18	9:00	05/Apr/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL					
36	124	220	220 South Solapur-PGCIL (Chincholi) Ckt-I @ South Solapur	05/Apr/18	11:00	05/Apr/18	16:00	Daily	Quarterly Maintenance & Dignostic testing work	MSETCL	MSETCL					
37	125	220	Wardha PGCIL -Badnera	05/Apr/18	10:00	05/Apr/18	18:00	Daily	Disc replacement	MSETCL	MSETCL					
38	129	220	Talegaon II - Talegaon PG Ckt I @Talegaon II	05/Apr/18	8:00	05/Apr/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL					
39	130	400	Bay No-410 Main Bay of 400 Tarapur-boisar ckt-II Line at Boisar	05/Apr/18	8:30	05/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
40	132	765	ICT 1_765/400_PUNE(GIS)	05/Apr/18	9:00	05/Apr/18	18:00	Daily	For Bay extension works- erection of Spare transformer bus module	WRTS-I	WRTS-I	C	ICT			
41	133	765	765kV Wardha-2 Main bay(712) at Aurangabad	05/Apr/18	9:00	05/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
42	141	400	400Akola- Bhusawal Line at 400Akola	05/Apr/18	12:00	07/Apr/18	18:00	Daily	PID testing of insulator strings by Hot line Unit Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	Bhusawal, 400Akola-Nandgaonpeth & 400Koradi-Nandgaonpeth				
43	142	400	Jajgad Karad Ckt - 1 & 2	05/Apr/18	9:00	10/Apr/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL					
44	144	400	400 ICT-3 Main bay (404) at Solapur	05/Apr/18	9:00	05/Apr/18	18:00	Daily	BAR AMP WORKS	WRTS-I	WRTS-I	R	BAF			
45	151	400	Babhaleshwar-Padghe -Ckt-2 @BBLR	06/Apr/18	9:00	06/Apr/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of JG isolators work	MSETCL	MSETCL	400 Babhaleshwar-Padghe-Ckt-I will be in service				
46	152	400	400 MAUDA_WARDHA-I & II	06/Apr/18	7:00	07/Apr/18	18:00	Cont?	For Power line crossing of UIC 765kV DC Gadawara-Warora line	WRTS-I	WRTS-I	C	Line	SPS at Mouda to be in service		
47	153	400	SSNL-Dhule-2	06/Apr/18	8:00	06/Apr/18	18:00	Daily	Maintenance work	PGCIL	GETCO	Auto reclose of SSP Dhule No.1 will require to be kept off.				
48	159	400	Bay No-411 Tie Bay of 400 Boisar-Vapi & 400 Boisar-Tarapur ckt-II Line at Boisar	06/Apr/18	8:30	06/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
49	164	765	765kV Wardha-4 & Future Tie bay (720) at Aurangabad	06/Apr/18	9:00	06/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
50	168	765/400	765/400,1500MVA ICT-I@ Ektuni	06/Apr/18	10:00	06/Apr/18	18:00	Daily	Routine Maintain & Diagnostic Testing of ICT, CT & CB	MSETCL	MSETCL	765/400,1500 MVA ICT-I will be in service				

Outage planning of transmission elements for the month of April 2018																
Sr no	OCCM No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	Type				
				Date	Time	Date	Time									
51	171	220	Bugaon - Wardha PGCL line	06/Apr/18	8:00	06/Apr/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL					
52	172	400	400Koradi-Bhusawal	06/Apr/18	8:00	07/Apr/18	19:00	Cont.	Restricting between location no 5-6 on all three phases to increase the clearance of cond from ground up to 8.9 meters . Presently clearance is 7.5 to 8 meters	MSETCL	MSETCL					
53	173	400	400 ICT-3 & Future Tie Bay (405) at Solapur	06/Apr/18	9:00	06/Apr/18	18:00	Daily	BAY AMP WORKS	WRTS-I	WRTS-I	R	Bay			
54	174	400	400 KDLHAPUR Main bay (418) at Solapur	06/Apr/18	9:00	06/Apr/18	18:00	Daily	BAY AMP WORKS	WRTS-I	WRTS-I	R	Bay	Clubbed with Bus outage		
55	177	400	SSNL-Dhule-1	07/Apr/18	8:00	07/Apr/18	18:00	Daily	Maintenance work	PGCIL	GETCO	Auto reclose of SSP: Dhule No. 2 will require to be kept off				
56	178	500	500kV HCVDC Chandrapur-Padghe line	07/Apr/18	7:00	08/Apr/18	18:00	Cont?	For Power line crossing of U/C 765kV DC Warora-Parli line	MSETCL	WRTS-I	C	Line	SLDC Maharashtra consent required	By hotline	
57	181	220	SOLAPUR_220(EUR) LINE	07/Apr/18	9:00	07/Apr/18	18:00	Daily	BAY AMP WORKS	MSETCL	WRTS-I	R	Line			
58	183	400	400 Khadka - Koradi line @ Khadka	07/Apr/18	6:00	07/Apr/18	18:00	Daily	Taking tan Delta, DCRM and C.B timing.	MSETCL	MSETCL					
59	184	400	Bay No-412 Main Bay of 400 Vapi-boisar Line at Boisar	07/Apr/18	8:30	07/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
60	185	220	220 Pusad Main Bay (202) at Wardha	07/Apr/18	9:00	07/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Line	Line to be inservice with TBC bay		
61	190	220	Wardha PGCL - PUSAD LINE	07/Apr/18	8:00	07/Apr/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL					
62	193	400	Dabhol-Nagonathane Ckt 2 @Dabhol	07/Apr/18	8:00	14/Apr/18	18:00	Daily	For Cold washing and insulator replacement & Hill cutting work.	MSETCL	MSETCL					
63	195	500	Chandrapur-Padghe HVDC Line Pole-I	07/Apr/18	6:00	08/Apr/18	18:00	Daily	For repairing of damaged OPGW Wire above Pole-I of Chandrapur-Padghe HVDC line .	MSETCL	MSETCL			Preponed and clubbed with other utility request on Saturday and Sunday		
64	202	400	ICT2_400/220_SOLAPUR	08/Apr/18	9:00	08/Apr/18	18:00	Daily	STACOM BAY COMMISSIONING and AMP WORKS	WRTS-I	WRTS-I	C	ICT			
65	205	220	Wardha PGCL - PUSAD LINE	08/Apr/18	8:00	08/Apr/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL					
66	216	400	Bus-I at Parli	09/Apr/18	9:00	10/Apr/18	18:00	Cont?	For Construction Works	WRTS-I	WRTS-I	C	Bus			
67	217	400	400 Tarapur 1 @ Padghe	09/Apr/18	8:00	09/Apr/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe SL				
68	221	400	400 Dhule-SSNML CKT-1 & 2	09/Apr/18	8:00	09/Apr/18	18:00	Daily	Online PID Testing Work.	MSETCL	MSETCL					
69	224	400	Babhaleswar-Bhusawal -@BBLR	09/Apr/18	9:00	10/Apr/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Aurangabad Dhule-Ckt-1&2, Ektuni-ckt-1&2, will be in				
70	231	400	400 Dhariwal Main Bay (410) at Parli	09/Apr/18	10:00	09/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay	Preponed and clubbed with bus outage		
71	233	220	PGCIL Deoli-Badnera Ckt @Badnera	09/Apr/18	8:00	14/Apr/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL					
72	234	400	400 Chandrapur-2 & 400 BR Tie Bay (408) at Bhadrawati	09/Apr/18	9:30	16/Apr/18	18:00	Cont?	overhauling of ABB CB Poles	WRTS-I	WRTS-I	R	Bay			
73	235	400	400 BR-II Main Bay (416) at Parli	09/Apr/18	10:00	09/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay	Preponed and clubbed with bus outage		
74	236	400	400 Wardha-I Main Bay (401) at Parli	09/Apr/18	10:00	09/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay	Preponed and clubbed with bus outage		
75	243	400	Bay No-413 Main Bay of 400 Tarapur-boisar ckt-I Line at Boisar	10/Apr/18	8:30	10/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
76	251	220	220Pandurna-Kalmeshwar	10/Apr/18	9:00	10/Apr/18	18:00	Daily	Line maintenance work	MPPTCL	MPPTCL	R				
77	259	400	400 CHD-I CHD-II CKT No.1 Bay @ 400 SS Chandrapur	10/Apr/18	8:00	10/Apr/18	18:00	Daily	1)Measurement of Tan delta & capacitance of CTV's. 2) For attending the Hot spot. 3) Routine maintenance of the bay.	MSETCL	MSETCL			Line to be inservice with TBC bay		
78	267	765	765kV Tirora Koradi III- Line 1 at Tiroda SS	10/Apr/18	11:00	10/Apr/18	19:00	Daily	For Bushing & IPS tube removal of Line reactor during replacement work	MEGPTCL	MEGPTCL					
79	268	765	765Tiroda - Koradi Line reactor 1(Switchable) at Tiroda SS	10/Apr/18	7:00	30/Apr/18	20:00	Cont.	For replacement work TO ENHANCE RELIABILITY OF THE LENGTH	MEGPTCL	MEGPTCL	Switchable LR				
80	269	765	765kV Tirora Koradi III- Line 1 at Tiroda SS	10/Apr/18	7:00	10/Apr/18	15:00	Daily	For Bushing & IPS tube erection of Line reactor after replacement.	MEGPTCL	MEGPTCL					
81	278	400	400 BHILAI-KORADI	11/Apr/18	7:00	18/Apr/18	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings-line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period.	WRTS-I	WRTS-I	C	line	AR off for which ckt?		
82	279	400	Bay No-414 Tie Bay of 400 Tarapur-Boisar-I Line & ICT-II at Boisar	11/Apr/18	8:30	11/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
83	281	400	Bus-II at Parli	11/Apr/18	9:00	12/Apr/18	18:00	Cont?	For Construction Works	WRTS-I	WRTS-I	C	Bus			
84	283	220	220 Kalmeshwar-Pandhurna	11/Apr/18	8:00	11/Apr/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL					
85	289	400	Babhaleswar-Ektuni-Ckt-1 @BBLR	11/Apr/18	9:00	11/Apr/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Aurangabad Dhule-Ckt-1&2, Ektuni-ckt-2 will be in				
86	290	400	STATION-SA Bay(416) @ Khaperkheda	11/Apr/18	9:00	11/Apr/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	STN SA will be in service.				
87	292	220	220side ICT -2 Main bay (205) at Talegaon	11/Apr/18	9:00	11/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay	ICT-2 to be inservice with TBC bay		
88	295	400	ICT2_400/200kv_AURANGABAD	11/Apr/18	9:00	11/Apr/18	18:00	Daily	For providing insulation sleeves on 33kV tertiary	WRTS-I	WRTS-I	R	ICT			
89	300	400	400 Dhariwal & Solapur-II Tie Bay (411) at Parli	11/Apr/18	10:00	11/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay			
90	303	220	Wardha PGCL -Badnera	11/Apr/18	10:00	11/Apr/18	18:00	Daily	Disc replacement	MSETCL	MSETCL					
91	307	400	400 Pune-1 Main Bay (403) at Parli	11/Apr/18	10:00	11/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay	Preponed and clubbed with bus outage		
92	308	765	ICT_2_765/400_PUNE(GIS)	12/Apr/18	9:00	12/Apr/18	18:00	Daily	NTAMC integration works-control operations	WRTS-I	WRTS-I	C	ICT			
93	312	400	400 Dhule-SSNML CKT-1 & 2	12/Apr/18	8:00	12/Apr/18	18:00	Daily	Online PID Testing Work.	MSETCL	MSETCL					
94	315	400	Bay No-415 Main Bay of 315 MVA ICT-2 at Boisar	12/Apr/18	8:30	12/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
95	320	220	Talegaon M - Talegaon PG Ckt II @Talegaon M	12/Apr/18	8:00	12/Apr/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL					
96	322	220	Bay No. 201 Main Bay of ICT-I at Boisar	12/Apr/18	8:30	12/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR	ICT-1 to be inservice with TBC bay		
97	323	400	Babhaleswar-Ektuni-Ckt-2 @BBLR	12/Apr/18	9:00	12/Apr/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Aurangabad Dhule-Ckt-1&2, Ektuni-ckt-1, will be in				
98	329	400	Bus Coupler @ Talandje	12/Apr/18	9:00	12/Apr/18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL					
99	330	220	Nasik - Navsari Ckt 1 @ Nasik	12/Apr/18	9:00	12/Apr/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL					
100	331	765	765Aurangabad-4 & Durgl Tie Bay (723) at Wardha	12/Apr/18	9:00	12/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay			

Outage planning of transmission elements for the month of April 2018																
Sr no	CCM No	Voltage	Line / Element	From Date	Time	To Date	Time	Basis	Reason	System	Agency	Type				
101	332	765	765KV AURABGABAD-1 Main bay (707) at Solapur	12/Apr/18	9:00	12/Apr/18	18:00	Daily	BAV AMP WORKS	WRTS-I	WRTS-I	R	BAV			
102	333	220	220Talegaon MSETCL Line-2 Main bay (207) at Talegaon	12/Apr/18	9:30	12/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
103	339	400	400Akola- Nandgaonpeth Line at 400Akola	12/Apr/18	12:00	14/Apr/18	18:00	Daily	PID testing of insulator strings by Hot line Unit Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	Bhusawal-400Akola-Bhusawal & 400Koradi-Nandgaonpeth				
104	341	400	Jalgad-Newkoyna Ckt- 1 & 2	12/Apr/18	9:00	17/Apr/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL					
105	342	400	(3*105) MVA ICT-II & It's Bay @ 400 S/S Chandrapur	12/Apr/18	8:00	18/Apr/18	18:00	Cont.	Replacement of B- ph ICT-II By repaired 105 MVA Spare ICT.	MSETCL	MSETCL					
106	344	400	400 Pune-2 main bay (406) at Parli	12/Apr/18	10:00	12/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay	Preponed and clubbed with bus outage		
107	346	400	400 Bhadravati-1 & Solapur-1 Tie Bay (408) at Parli	13/Apr/18	10:00	13/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay			
108	347	400	Babhaleswar-Aurangabad - @BBLR	13/Apr/18	9:00	13/Apr/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400Bhusawal-Hule-Ckt-1&2, Ektuni-ckt-2 will be in service.				
109	350	765	765kV Bus 1 at Pune-GIS	13/Apr/18	9:00	19/Apr/18	18:00	Cont.	For Bay extension works- erection of Busbar-1 module	WRTS-I	WRTS-I	C	Bus			
110	351	765	400 Bus-1 at Wardha SS	13/Apr/18	9:00	13/Apr/18	18:00	Daily	Bus Extension for 400 Aurangabad 1 & 2	WRTS-I	WRTS-I	C	Bus			
111	352	400	400 PARLI-2 & KOLHAPUR Tie bay (417) at Solapur	13/Apr/18	9:00	13/Apr/18	18:00	Daily	BAV AMP WORKS	WRTS-I	WRTS-I	R	BAV			
112	357	765	ICT1_765/400_AURANGABAD	13/Apr/18	9:00	13/Apr/18	18:00	Daily	For providing insulation sleeves on 33kV tertiary	WRTS-I	WRTS-I	R	ICT			
113	360	400	400 MAIN BUS II AT 400EJURI	13/Apr/18	9:30	13/Apr/18	17:30	Daily	Annual Maint & testing of bays equipment	MSETCL	MSETCL	400BUS I will be in service.				
114	365	220	Bay No. 202 Main Bay of 220Boisar-Boisar-III Line at Boisar	13/Apr/18	8:30	13/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR	Line to be inservice with TBC bay		
115	366	400	80MVAR Reactor @ Talande	13/Apr/18	9:00	13/Apr/18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL			if voltage less than 413kV		
116	367	220	Nasik - Navsari Ckt 2 @ Nasik	13/Apr/18	9:00	13/Apr/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL				Work by MSETCL	
117	368	765	765KV AURANGABAD-2 Main bay (710) at Solapur	13/Apr/18	9:00	13/Apr/18	18:00	Daily	BAV AMP WORKS	WRTS-I	WRTS-I	R	BAV			
118	370	400	400 Chakan main bay (401) at Talegaon	13/Apr/18	9:30	13/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
119	372	400	407 Bay (Main bay Aurangabad Ckt-2 Jst 400Akola	13/Apr/18	10:00	13/Apr/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL					
120	384	765	400 Bus-2 at Wardha SS	14/Apr/18	9:00	14/Apr/18	18:00	Daily	Bus Extension for 400 Aurangabad 1 & 2	WRTS-I	WRTS-I	C	Bus			
121	385	400	400Parli- Lonikand -I	14/Apr/18	8:00	14/Apr/18	17:00	Daily	Line Maintenance work by Lamboti Sidn	MSETCL	MSETCL					
122	387	400	Bus Coupler @ BBLR	14/Apr/18	9:00	14/Apr/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Bus will be seperated				
123	388	765	ICT2_765/400_AURANGABAD	14/Apr/18	9:00	14/Apr/18	18:00	Daily	For providing insulation sleeves on 33kV tertiary	WRTS-I	WRTS-I	R	ICT			
124	395	220	220 Wardha Main Bay (206) at Wardha	14/Apr/18	9:00	14/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay			
125	396	400	400 ICT-2 Main bay (412) at Talegaon	14/Apr/18	9:30	14/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
126	398	400	400 WARDHA-PARLI-I & II	15/Apr/18	7:00	25/Apr/18	20:00	Cont?	UILO at Warora under construction-substation, for final Tapping works.	WRTS-I	WRTS-I	C	Line	NLDC to be informed.		
127	401	400	400A Bus with Bus coupler @ Nagothane	15/Apr/18	8:00	15/Apr/18	18:00	Daily	Routine Maintenance work and PG iso overhauling	MSETCL	MSETCL	At Nagothane SS				
128	406	765	765Durg-1 Main Bay (724) at Wardha	15/Apr/18	9:00	15/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay			
129	407	765/400	765/400,1500MVA ICT-II@Ektuni	15/Apr/18	10:00	15/Apr/18	18:00	Daily	Routine Maintain & Diagnostic Testing of ICT, CT & CB	MSETCL	Self	765/400,1500 MVA ICT-I will be in service				
130	408	400	400 Kharghar- Talegaon@ 400 Kharghar	15/Apr/18	8:00	15/Apr/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL					
131	414	400	400B Bus with Bus coupler @ Nagothane	16/Apr/18	8:00	16/Apr/18	18:00	Daily	Routine Maintenance work and PG iso overhauling	MSETCL	MSETCL	At Nagothane SS				
132	422	220	Bay No. 203 Main Bay of 220Nalsopara-Boisar Line at Boisar	16/Apr/18	8:30	16/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR	Line to be inservice with TBC bay	Monday - To be availed on Friday .	
133	426	400	Yetwan Ckt -1 with bay 414 & 415 at 400Akola	16/Apr/18	9:00	16/Apr/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL					
134	427	400	765/400 ICT-II 400 side Main Bay (407) at wardha	16/Apr/18	9:00	16/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay			
135	430	400	400 Lonikand Main bay (413) at Talegaon	16/Apr/18	9:30	16/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
136	437	400	400Boisar @ Padgha	16/Apr/18	8:00	16/Apr/18	18:00	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padgha JS.				
137	439	220	PGCIL Deoli-Badnera Ckt @Badnera	16/Apr/18	8:00	21/Apr/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL					
138	442	400	Chandrapur II- Nanded Ckt- II	16/Apr/18	8:00	28/Apr/18	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL					
139	443	400	Chandrapur GCR- Parli Ckt-III	16/Apr/18	8:00	28/Apr/18	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL					
140	450	400	New Koyna -Dabhol Ckt 2@Dabhol	17/Apr/18	8:00	19/Apr/18	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL					
141	456	400	400 WARORA-CHANDRAPUR CKT-1(Bay No. 412 & Tie Bay no 413)@400 s/s warora end	17/Apr/18	7:00	17/Apr/18	17:00	Daily	Protection Relay testing works and Routine maintenance and diagnostic testing such as CT tandetha,CRM,IR values,isolator maintenance work.	MSETCL	MSETCL	LOB& will be managed on 400 Chandrapur Ckt-2				
142	457	220	Bay No.204 Main Bus coupler at Boisar	17/Apr/18	8:30	17/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
143	459	765	SWITCHABLE LR_765kV_RDGHE1_AURANGABAD	17/Apr/18	9:00	17/Apr/18	18:00	Daily	Spare reactor charging along with LR's	WRTS-I	WRTS-I	R	BR	if voltage less than 775kV		
144	463	400	400 BR Main bay (415) at Talegaon	17/Apr/18	9:30	17/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
145	482	220	Bay No. 206 Main Bay of 220Boisar-Boisar-I Line at Boisar	18/Apr/18	8:30	18/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR	Line to be inservice with TBC bay		
146	484	765	SWITCHABLE LR_765kV_PUNE(GIS)_SOLAPUR	18/Apr/18	9:00	18/Apr/18	18:00	Daily	CB timing mismatch rectification works on 712R bay at Solapur.	WRTS-I	WRTS-I	R	BR			
147	485	400	ICT3_765/400_WARDHA	18/Apr/18	9:00	18/Apr/18	18:00	Daily	commissioning of CSD in 400side of breaker	WRTS-I	WRTS-I	C	ICT			
148	488	400	400 ICT-3 Main bay (418) at Talegaon	18/Apr/18	9:30	18/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
149	493	400	New Koyna -Dabhol Ckt 1 @Dabhol	18/Apr/18	8:00	20/Apr/18	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL					
150	495	400/220	315MVA ICT-2 @ Khadka	18/Apr/18	8:00	26/Apr/18	18:00	Cont.	Oil Filtration Work.	MSETCL	MSETCL					

Outage planning of transmission elements for the month of April 2018																
Sr no	GCM No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	Type				
				Date	Time	Date	Time									
151	498	400	400 kV RPL Amravati-Akola III (Yelwan) Line-1	18/Apr/18	9:00	18/Apr/18	18:00	Daily	Premonsoon & Routine Maintenance.	APTCL	APTCL					
152	506	400	400Koradi-Bhusawal	19/Apr/18	8:00	20/Apr/18	19:00	Cont.	Restraining between location no 11-112 on all three phases to increase the clearance of cond from ground up to 8.9 meters . Presently clearance is below 8 meters	MSETCL	MSETCL					
153	513	220	Bay No. 207 Main Bay of 220 Tarapur-Boisar Line at Boisar	19/Apr/18	8:30	19/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR	Line to be inservice with TBC bay		
154	516	765	SWITCHABLE LR_765kV_PDGHE2_AURANGABAD	19/Apr/18	9:00	19/Apr/18	18:00	Daily	Spare reactor charging along with LRs	WRTS-I	WRTS-I	R	BR			
155	519	400	400 Pune-GIS-4 Main Bay (410) at Talegaon	19/Apr/18	9:30	19/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay			
156	520	400	400 ALKUD SOLAPUR LINE @ ALKUD	19/Apr/18	9:30	19/Apr/18	17:30	DAILY	Quarterly Maint. Work							
157	528	400	400Koradi- Bhusawal Line at 400Akola	19/Apr/18	12:00	21/Apr/18	18:00	Daily	PID testing of insulator strings by Hot line Unt Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	Bhusawal, 400Akola-Nandgaonpeth & 400Koradi-Nandgaonpeth				
158	530	400	KUDGI Kolhapur-I	19/Apr/18	7:00	19/Apr/18	19:00	DAILY	Construction:Providing insulation sleeves on conductor for system improvement		POWERGRID					
159	531	765	ICT2_765/400_WARDHA	20/Apr/18	9:00	20/Apr/18	18:00	Daily	commissioning of CSD in 400side of breaker	WRTS-I	WRTS-I	C	ICT			
160	534	400	Main Bus 2 @Talandage	20/Apr/18	9:00	24/Apr/18	22:00	Cont.	Bus String Replacement Work & All Bay's 'B' Bus Isolator alignment work by shifting these bay on TBC.	MSETCL	MSETCL					
161	543	220	Bay No. 208 Main Bay of ICT-II at Boisar	20/Apr/18	8:30	20/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR	Element to be inservice with TBC bay		
162	548	400	ICT1_400/220_PUNE	20/Apr/18	9:30	20/Apr/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	ICT			
163	552	400	414Bay (Main Bay of Yelwan Ckt-1 Jct 400Akola	20/Apr/18	10:00	20/Apr/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL					
164	559	400	KUDGI Kolhapur-II	20/Apr/18	7:00	20/Apr/18	19:00	DAILY	Construction:Providing insulation sleeves on conductor for system improvement		POWERGRID					
165	573	400	Bay No-401 Main Bay of 400 Aurangabad-Boisar-I Line at Boisar.	21/Apr/18	8:30	21/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
166	577	400	400Tarapur 2 @ Padgha	21/Apr/18	8:00	21/Apr/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padgahe RS				
167	583	400	400 kV RPL Amravati-Akola-II (Yelwan) Line-2	21/Apr/18	9:00	21/Apr/18	18:00	Daily	Premonsoon & Routine Maintenance.	APTCL	APTCL					
168	589	400	400D/C Koradi II to Koradi III line ckt-162	22/Apr/18	7:00	22/Apr/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II	C	CHHINDWARA			Based on Generation at Koradi-2.
169	591	400/220	400Kharghar @ Kalwa	22/Apr/18	9:00	22/Apr/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL					
170	605	400	400 Dhule-SSNML Ckt-1	23/Apr/18	8:00	23/Apr/18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	AR in Non Auto for Ckt 2				
171	606	400	400 KDLHAPUR (GIS)-MAPUSA I	23/Apr/18	8:00	23/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line			
172	607	400	Bay No-402 Tie Bay of 400 Aurangabad-Boisar Line-I & Furture Bay at Boisar	23/Apr/18	8:30	23/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
173	619	400	400Khadka-Babhaleswar	23/Apr/18	6:00	24/Apr/18	18:00	Daily	PID Testing . Non Autoreclosure	MSETCL	MSETCL					
174	623	220	PGCIL Deoli-Badnera Ckt @Badnera	23/Apr/18	8:00	28/Apr/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL					
175	624	400	400 KORADI-SATPURA	23/Apr/18	7:00	29/Apr/18	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period.	WRTS-I	WRTS-I	C	Line			
176	631	400	400D/C Koradi II to Koradi III line ckt-162	24/Apr/18	7:00	24/Apr/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II	C	CHHINDWARA			Based on Generation at Koradi-2 .
177	636	400	400 Dhule-SSNML Ckt-1	24/Apr/18	8:00	24/Apr/18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL					
178	637	400	400 KDLHAPUR (GIS)-MAPUSA I	24/Apr/18	8:00	24/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line			
179	643	765	SWITCHABLE LR_765kV_SOLAPUR-I_AURANGABAD	24/Apr/18	9:00	24/Apr/18	18:00	Daily	To take out spare reactor	WRTS-I	WRTS-I	R	BR			
180	656	400	Bay No-404 Main Bay of 500 MVA ICT-3 at Boisar	25/Apr/18	8:30	25/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR			
181	659	400	Chandrapur 2 - Warora Ckt-I	25/Apr/18	8:00	25/Apr/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware & replacement of faulty Disc Insulator	MSETCL	MSETCL					
182	660	400	400 Dhule-SSNML Ckt-1	25/Apr/18	8:00	25/Apr/18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	AR required to be Off For ckt 2				
183	662	400	400 KDLHAPUR (GIS)-MAPUSA I	25/Apr/18	8:00	25/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line			
184	673	220	220 South Solapur-PGCIL (Chincholi) Ckt-II @ South Solapur	25/Apr/18	11:00	25/Apr/18	16:00	Daily	Quarterly Maintenance & Dignostic testing work	MSETCL	MSETCL					
185	675	400	400 Main Bus-I @ 400 S/S Chandrapur	26/Apr/18	8:00	27/Apr/18	18:00	continuous	1) For checking the healthiness of R, Y & B ph. 400 Main BUS-I CVT's. At present there, is a difference of around 7-8 kV on primary side. 2) As per Partial Discharge test report, it is also necessary to confirm healthiness of 400 Main Bus-I CVTs.	MSETCL	MSETCL					
186	676	400	400 PUNE(GIS)-PUNE(TALEGOAN)_4	26/Apr/18	10:00	26/Apr/18	11:30	Daily	PMU integration works- for WRLCD.	WRTS-I	WRTS-I	C	Line	Already facilitated		
187	677	400	400 PUNE(GIS)-PUNE(TALEGOAN)_3	26/Apr/18	11:30	26/Apr/18	13:00	Daily	PMU integration works- for WRLCD.	WRTS-I	WRTS-I	C	Line	Already facilitated		
188	678	400	400 PARLI-PUNE(GIS)_2	26/Apr/18	14:30	26/Apr/18	16:00	Daily	PMU integration works- for WRLCD.	WRTS-I	WRTS-I	C	Line	Already facilitated		
189	679	400	400 Kalwa-Padgha Line-2	26/Apr/18	8:00	26/Apr/18	18:00	Daily	Faulty Insulator(Found in PID testing) replacement work .	MSETCL	MSETCL					
190	680	400/220	400Padgha II @ Kalwa	26/Apr/18	9:00	26/Apr/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL					
191	681	400	400 BR-II & Parli-II Tie Bay (417) at Parli	26/Apr/18	10:00	26/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay			
192	682	400	400Kalwa 2 @ Padgha	26/Apr/18	8:00	26/Apr/18	18:00	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padgahe RS				
193	683	765	765kV Bus 2 at Pune-GIS	26/Apr/18	9:00	30/Apr/18	18:00	Cont?	For Bay extension works- erection of Busbar-2 module	WRTS-I	WRTS-I	C	Bus			
194	684	400	400Akola-II & B/R Tie Bay (417) at wardha	26/Apr/18	9:00	26/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay			
195	685	765	765kV Solapur-1 Main bay (713) at Aurangabad	26/Apr/18	9:00	26/Apr/18	18:00	Daily	Post charge testing under warranty	WRTS-I	WRTS-I	R	Bay			

Outage planning of transmission elements for the month of April 2018															
Sr no	CCM No	Voltage	Line / Element	From Date	Time	To Date	Time	Basis	Reason	System	Agency	Type			
196	686	765	765KV AURANGABAD(PG)-SOLAPUR I	26/Apr/18	9:00	26/Apr/18	18:00	Daily	Post charge testing under warranty, spare reactor charging along with LRs and line defects rectification works	WRTS-I	WRTS-I	R	Line		
197	687	400	400 Boisar-Padghe at Boisar	26/Apr/18	9:00	26/Apr/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	R	BOISAR		
198	688	400	400 Boisar-Padghe at Boisar	26/Apr/18	14:00	26/Apr/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II	R	BOISAR		
199	692	400	400 Dhule-SSNNL CKT-2	26/Apr/18	8:00	26/Apr/18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	A/R required to be OFF For ckt 1			
200	694	400	400 KOLHAPUR (GIS)-MAPUSA I	26/Apr/18	8:00	26/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation, AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line		
201	699	400	400 MAIN BUS I AT 400(EJURI)	26/Apr/18	9:30	26/Apr/18	17:30	Daily	Annual Maint & testing of bays equipment	MSETCL	MSETCL	400BUS II will be in service			
202	707	400	400 Chandrapur-4 & Raipur-2 Tie Bay (417) at Bhadrawati	26/Apr/18	9:30	28/Apr/18	18:00	Cont?	overhauling mechanism of CGL CB	WRTS-I	WRTS-I	R	Bay		
203	709	400	Talegaon-Kharghar Line	27/Apr/18	8:00:00	27/Apr/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL				
204	710	400	400 PUNE(GIS)-PUNE(TALEGOAN)_1	27/Apr/18	11:30	27/Apr/18	13:00	Daily	PMU integration works- for WRLDCL	WRTS-I	WRTS-I	C	Line	Already facilitated	
205	711	400	400 PUNE(GIS)-PUNE(TALEGOAN)_2	27/Apr/18	14:30	27/Apr/18	16:00	Daily	PMU integration works- for WRLDCL	WRTS-I	WRTS-I	C	Line	Already facilitated	
206	712	400	400 PARLI-PUNE(GIS)_1	27/Apr/18	10:00	27/Apr/18	11:30	Daily	PMU integration works- for WRLDCL	WRTS-I	WRTS-I	C	Line	Already facilitated	
207	713	400	400 AURANGABAD(MSETCL)-PUNE(GIS) I	27/Apr/18	11:30	27/Apr/18	13:00	Daily	PMU integration works- for WRLDCL	WRTS-I	WRTS-I	C	Line	Already facilitated	
208	714	400	400 AURANGABAD(MSETCL)-PUNE(GIS) II	27/Apr/18	14:30	27/Apr/18	16:00	Daily	PMU integration works- for WRLDCL	WRTS-I	WRTS-I	C	Line	Already facilitated	
209	715	765	765KV Solapur-2 Main bay (716) at Aurangabad	27/Apr/18	9:00	27/Apr/18	18:00	Daily	Post charge testing under warranty	WRTS-I	WRTS-I	R	Bay		
210	720	400	400 Chandrapur-3 & Parli-1 Tie bay (420) at Bhadrawati	27/Apr/18	9:30	29/Apr/18	18:00	Cont?	overhauling mechanism of CGL CB	WRTS-I	WRTS-I	R	Bay		
211	721	400	400 BR-I & Parli-I Tie Bay (414) at Parli	27/Apr/18	10:00	27/Apr/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	Bay		
212	723	400	Bay No-405 Tie Bay of 400 Aurangabad-Boisar Line-I & Turtum Bay at Boisar	27/Apr/18	8:30	27/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR		
213	724	765	765KV AURANGABAD(PG)-SOLAPUR II	27/Apr/18	9:00	27/Apr/18	18:00	Daily	Post charge testing under warranty, spare reactor charging along with LRs and line defects rectification works	WRTS-I	WRTS-I	R	Line		
214	725	400	40kv Tarapur-Boisar-I at Boisar	27/Apr/18	9:00	27/Apr/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	R	BOISAR		
215	726	400	400Akola-I & ICT-I Tie Bay (420) at wardha	27/Apr/18	9:00	27/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay		
216	727	765	SWITCHABLE LR 765KV SOLAPUR2_AURANGABAD	27/Apr/18	9:00	27/Apr/18	18:00	Daily	To take out spare reactor	WRTS-I	WRTS-I	R	BR		
217	728	400	400Buccoupler @ Karad	27/Apr/18	10:00	27/Apr/18	17:00	Daily	Quarterly Maint. work	MSETCL	MSETCL	Load manage on BUS & II			
218	730	400	400S/C Koradi I -India Bull	27/Apr/18	7:00	27/Apr/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II	C	CHHINDWARA	Proposal from SE O 6M .	
219	734	400	400 Dhule-SSNNL CKT-2	27/Apr/18	8:00	27/Apr/18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	A/R required to be OFF For ckt 1			
220	736	400	400 KOLHAPUR (GIS)-MAPUSA I	27/Apr/18	8:00	27/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation, AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line		
221	744	400	40kv Tarapur-Boisar-I	27/Apr/18	14:00	27/Apr/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II	R	BOISAR		
222	748	400	402-Bay (Main Bay of Chandrapur Circuit-2) at 400 Nanded Substation	28/Apr/18	8:00	28/Apr/18	14:00	Daily	Quarterly Maintenance of bays equipment & Line CVT Tan-D Meas.	MSETCL	MSETCL				
223	749	400	403-Bay (Tie Bay of Chandrapur Circuit-2 and ICT-I) at 400 Nanded Substation	28/Apr/18	8:00	28/Apr/18	14:00	Daily	Quarterly Maintenance of bays equipment & Line CVT Tan-D Meas.	MSETCL	MSETCL				
224	750	400	Babhaleshwar-Padghe-Ckt-1 @BBLR	28/Apr/18	9:00	28/Apr/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Babhaleshwar Padghe-Ckt-2 will be in service			
225	751	400	400Chandrapur -Kumbhargaoon(Nanded) ckt-2(412 Main bay & 411 Tie Bay) @ 400 Chandrapur-II s/s	28/Apr/18	9:00	28/Apr/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL				
226	752	400	Chandrapur 2 - Kumbhargaoon (Nanded) Ckt-II	28/Apr/18	8:00	28/Apr/18	17:00	Daily	Fixing repair sleeves in Span 36-37 & tightening of conductor Hardware.	MSETCL	MSETCL				
227	753	400	Chandrapur II- Nanded Ckt- II @ 400 LM S/On, Tavatmal	28/Apr/18	8:00	28/Apr/18	18:00	Daily	For Routine line maint. work	MSETCL	MSETCL				
228	754	400	400Akola -I Main Bay (419) at wardha	28/Apr/18	9:00	28/Apr/18	18:00	Daily	For Amp Work	WRTS-I	WRTS-I	R	Bay		
229	756	400	400S/C Koradi I -Bhusawal	28/Apr/18	7:00	28/Apr/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II	C	CHHINDWARA	Proposal from SE O 6M .	
230	758	400	400 Dhule-SSNNL CKT-2	28/Apr/18	8:00	28/Apr/18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	A/R required to be OFF For ckt 1			
231	760	400	400 KOLHAPUR (GIS)-MAPUSA II	28/Apr/18	8:00	28/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation, AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line		
232	761	400	40kv Tarapur-Boisar-II at Boisar	28/Apr/18	9:00	28/Apr/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	R	BOISAR		
233	762	220	220 Bhugaon Main Bay(204)at Wardha	28/Apr/18	9:00	28/Apr/18	18:00	Daily	For Amp Work, Line will be in service through TBC	WRTS-I	WRTS-I	R	Bay		
234	770	400	400 Girwali-Nanded ckt 1@ Girwali	29/Apr/18	9:00	29/Apr/18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL				
235	772	400	400 Main BUS-I @Ekturi	29/Apr/18	10:00	29/Apr/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CVT	MSETCL	MSETCL	400 Main BUS-II will be in service			
236	774	400	400 KOLHAPUR (GIS)-MAPUSA II	29/Apr/18	8:00	29/Apr/18	18:00	Daily	Replacement of polymer insulators with glass insulators in TL and replacement of support insulators of line isolator and other isolators, wave trap, BPs at substation, AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	Line		
237	775	400/220	400Talegaon @ Kalwa	29/Apr/18	9:00	29/Apr/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL				
238	776	400	40kv Tarapur-Boisar-II at Boisar	29/Apr/18	14:00	29/Apr/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II	R	BOISAR		
239	780	400	400 AURANGABAD(MSETCL)-PUNE(GIS) I	30/Apr/18	9:00	30/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Line	Already facilitated	
240	781	400	400 AURANGABAD(MSETCL)-PUNE(GIS) II	30/Apr/18	9:00	30/Apr/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Line	Already facilitated	
241	782	400	405-Bay (Main Bay of Girwali Circuit-2) at 400 Nanded Substation	30/Apr/18	8:00	30/Apr/18	14:00	Daily	Quarterly Maintenance of bays equipment & Line CVT Tan-D Meas.	MSETCL	MSETCL				
242	783	400	406-Bay (Tie Bay of Girwali Circuit-2 and ICT-2) at 400 Nanded Substation	30/Apr/18	8:00	30/Apr/18	14:00	Daily	Quarterly Maintenance of bays equipment & Line CVT Tan-D Meas.	MSETCL	MSETCL				
243	784	400	400 Girwali- Nanded Ckt-2 @ Girwali	30/Apr/18	9:00	30/Apr/18	18:00	Daily	C & Tan Delta measurement of Bushing & Winding of 50MkV Line Reactor.	MSETCL	MSETCL				
244	786	400	Bay No-406 Main Bay of 400 Ausrangabad-Boisar-II Line at Boisar	30/Apr/18	8:30	30/Apr/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	R	BOISAR		
245	789	220	PGCIL Deoli-Badnera Ckt @Badnera	30/Apr/18	8:00	30/Apr/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL				

Outage planning of transmission elements for the month of April 2018														
Sr no	GCCM SIS Sr No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	Type		
				Date	Time	Date	Time							
246	792	400	400 AURANGABADI(PG)- AURANGABADI(MSETCL) II	30/Apr/18	8:00	30/Apr/18	18:00	Daily	Line AMP works & CT drop jumper replacement at Msetcl, waluj S/s	WRIS-I	WRIS-I	R	Line	

State Element outages for the month of April 2018

Sr. No.	Voltage/ Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
1	400/220 KV	600MVA, ICT II @ Kalwa	01-Apr-18	9:00	01-Apr-18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	
2	400KV	400KV Stage 4- Jejuri ckt	01-Apr-18	7:00	30-Apr-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
3	400KV	400KV Stage 4- Lonikand	01-Apr-18	7:00	30-Apr-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
4	400KV	400KV Khadka -Deepnagar	01-Apr-18	7:00	30-Apr-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
5	400 KV	400KV NEW KOYANA-I @Karad	02-Apr-18	10:00	02-Apr-18	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on 400 kV Koyana 2
6	400KV	Nagothane -Padgha 1 line	02-Apr-18	8:00	02-Apr-18	17:00	Daily	Insulator string replacement work	MSETCL	MSETCL	
7	400 KV	400KV TALANDAGE -II @Karad	03-Apr-18	10:00	03-Apr-18	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	Load manage on 400 kV Talandge 1
8	400KV	Talandge - Karad 2 @ Talandge	3-Apr-18	9:00	3-Apr-18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	
9	400KV	400/220/33KV ICT-2 (Bay No. 406 & TIE Bay no 407)@400kv s/s warora end	03-Apr-18	7:00	03-Apr-18	17:00	Daily	Protection Relay testing works Routine maintenance and diagnostic testing such as CT tandelta,CRM,IR values,isolater maintenance work.	MSETCL	MSETCL	(Bay No 407 charged upto line CT 400KV ICT No-2 handed over to 400kv Padgha)
10	400 KV	400 KV Deepnagar-Khadka-II	03-Apr-18	6:00	03-Apr-18	14:00	Daily	For Fixing of Damaged/Loosed spacers cum vibration damper	MSETCL	MSETCL	
11	400KV	Nagothane -Padgha 1 line	03-Apr-18	8:00	03-Apr-18	17:00	Daily	Insulator string replacement work	MSETCL	MSETCL	
12	400KV	TBC@ Talandge	4-Apr-18	9:00	4-Apr-18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	
13	400 KV	GT-5 Bay(409,410) @ KHAPEKHEDE	04-Apr-18	9:00	04-Apr-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Line not in service
14	400 KV	400 KV Deepnagar-Waluj	04-Apr-18	6:00	07-Apr-18	18:00	Daily Basis	For Fixing of Damaged/Loosed spacers cum vibration damper	MSETCL	MSETCL	
15	400KV	Nagothane -Padgha 1 line	04-Apr-18	8:00	04-Apr-18	17:00	Daily	Insulator string replacement work	MSETCL	MSETCL	
16	400 kv	3*100 MVA, ICT-1 at Koradi 1 S/S	04-Apr-18	10:00	04-Apr-18	17:00	Daily	400KV & 220KV Bushing Testing work	MSETCL	MSETCL	
17	400KV	TBC @ BBLR	05-Apr-18	9:00	05-Apr-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	TBC is free
18	400 KV	400KV JAIGAD -II@ karad	05-Apr-18	10:00	05-Apr-18	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on 400KV Jaigad-1
19	400KV	400kv Spare line bay-I @Thaptitanda	05-Apr-18	10:00	05-Apr-18	17:00	Daily	CT testing /Relay testing work	MSETCL	MSETCL	
20	400KV	400/220/33KV ICT-1 (Bay No. 403 & TIE Bay no 404)@400kv s/s warora end	05-Apr-18	7:00	05-Apr-18	17:00	Daily	Protection Relay testing works Routine maintenance and diagnostic testing such as CT tandelta,CRM,IR values,isolater maintenance work.	MSETCL	MSETCL	Bay No 404 charged upto line CT (400KV ICT No -1 handed over to 400kv Bableshwar)
21	400/220/33	500MVA ICT-3 @ Girwali	05-Apr-18	9:00	05-Apr-18	18:00	Daily	220kv Side CB DCRM & Timing Test	MSETCL	MSETCL	
22	400KV	315MVA ICT-3 @ Khadka	05-Apr-18	6:00	05-Apr-18	18:00	Daily	Taking DCRM, C.B timing and IR value of C.B	MSETCL	MSETCL	
23	400KV	Nagothane -Padgha 2 line	05-Apr-18	8:00	05-Apr-18	17:00	Daily	Insulator string replacement work	MSETCL	MSETCL	
24	400KV	400 kv Nagothane 1 @ Padgha	06-Apr-18	8:00 Hrs	06-Apr-18	18:00Hrs	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe RS
25	400KV	315 MVA ICT-1@ Padgha	06-Apr-18	8:00 Hrs	06-Apr-18	18:00Hrs	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe RS
26	400KV	Nagothane -Padgha 2 line @ Nagothane	07-Apr-18	8:00	07-Apr-18	17:00	Daily	Insulator string replacement work	MSETCL	MSETCL	
27	400/220/33 kv	400/220/33 kv ICT-II@Thaptitanda	09-Apr-18	10:00	09-Apr-18	17:00	Daily	Relay testing Auxiliary protection testing	MSETCL	MSETCL	
28	400/220/33kv	Spare ICT with bay 401 at 400 kv Akola	09-Apr-18	9:00	09-Apr-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
29	400 KV	400 KV Deepnagar-Thapthi-Tanda	09-Apr-18	6:00	10-Apr-18	18:00	Daily	For Fixing of Damaged/Loosed spacers cum vibration damper	MSETCL	MSETCL	
30	400KV	Babhaleshwar-Dhule-Ckt-2 @BBLR	10-Apr-18	9:00	10-Apr-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-1, Ektuni-ckt-1, Ektuni-ckt-2 will be in service
31	400 KV	400KV NEW KOYANA-II@Karad	10-Apr-18	10:00	10-Apr-18	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	Load manage on 400 kV Koyana 1
32	400KV	400KV Waluj-Deepnagar Line @ Waluj	10-Apr-18	6:00	10-Apr-18	18:00	Daily	Line Maintenance : 1) Faulty Disc replacement at Loc. No. 509. 2) Fixing of N/B fixing line Spacer.	MSETCL	MSETCL	Road crossing (Nagpur Ghoti)
33	400KV	400/220/33KV SPARE ICT (Bay no 401) @400kv s/s warora end	10-Apr-18	7:00	11-Apr-18	17:00	Daily	Routine Spare ICT unit tests such as Winding Resistance, SFRA ,tan delta ,IR Values etc and diagnostic testing such as CT tandelta,CRM,IR values,isolater maintenance work.	MSETCL	MSETCL	Spare ICT is on No Load
34	400 KV	GT-10 Main Bay 401 & Tie Bay 402 at Koradi 2	10-Apr-18	10:00	10-Apr-18	17:30	Daily	Tan delta measurement of Line CT of Bay 401	MSETCL	MSETCL	GT-8 & GT-9 will be service.
35	400KV	400KV Waluj-Thaptitanda Line @ Waluj	11-Apr-18	6:00	11-Apr-18	18:00	Daily	Line Maintenance : 1) Faulty Disc replacement at Loc. No. 508-509.	MSETCL	MSETCL	Road crossing (Nagpur Ghoti)
36	400 KV	STATION-5A Bay(416) @ Khaperkheda	11-Apr-18	9:00	11-Apr-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	STN 5B will be in service.
37	400KV	400KV Waluj-Thaptitanda Line @ Waluj end	12-Apr-18	6:00	12-Apr-18	18:00	Daily	Line Maintenance : 1) Faulty Disc replacement at Loc. No. 529,530,531.	MSETCL	MSETCL	220KV Waluj-Bhenda & Waluj-Devgaon rangari Line crossing
38	400KV	400kv Spare line bay-II @Thaptitanda	12-Apr-18	10:00	12-Apr-18	17:00	Daily	CT testing /Relay testing work	MSETCL	MSETCL	
39	400KV	400KV Deepnagar - Aurangabad Ckt @ Deepnagar	13-Apr-18	8:00	13-Apr-18	18:00	Daily	Annual Maintenance of bays equipment & diagnostic Testing work	MSETCL	MSETCL	
40	400KV	400 kv nagothane 2 @ Padgha	13-Apr-18	8:00 Hrs	13-Apr-18	18:00Hrs	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe RS
41	400KV	315 MVA ICT-2 @ Padgha	13-Apr-18	8:00 Hrs	13-Apr-18	18:00Hrs	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe RS
42	400KV	Lonikand-Karad Line	14-Apr-18	8:00:00 AM	14-Apr-18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	
43	400/220 KV	315 MVA ICT-I @Karad	16-Apr-18	10:00	16-Apr-18	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on other Two ICT'S
44	400/220KV	315 MVA, ICT 1 @ Talandge	16-Apr-18	9:00	16-Apr-18	20:00	Daily	Quarterly Maint work	MSETCL	MSETCL	
45	400KV	GCR Chandrapur - Khaperkheda Line	16-Apr-18	6:00	30-Apr-18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	

State Element outages for the month of April 2018

Sr. No.	Voltage/ Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
46	400 KV	400 kv Deepnagar-Waluj	16-Apr-18	6:00	17-Apr-18	18:00	Daily	Replacement of Damaged Insulator strings at cut point LOC 92 /Y Ph & 97/ B Ph	MSETCL	MSETCL	
47	400KV	400KV Dhule-BBLR CKT-1	16-Apr-18	8:00	16-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
48	400KV	400KV TBC @ Waluj	17-Apr-18	9:00	17-Apr-18	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	
49	220kv	TBC @Thapitanda	17-Apr-18	10:00	17-Apr-18	17:00	Daily	Relay Testing/ CB testing work	MSETCL	MSETCL	
50	400KV	407-Main Bay only (Main Bay of 400 KV Station 8 B) @ 400KV Switching s/s Chandrapur	17-Apr-18	9:00	17-Apr-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
51	400KV	400KV Dhule-BBLR CKT-1	17-Apr-18	8:00	17-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
52	400/220kV	501MVA, ICT1 @Lamboti.	18-Apr-18	8:00	18-Apr-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
53	400 KV	400KV Khaperkheda-Chandrapur ckt (417,418) at Khaperkeda	18-Apr-18	9:00	18-Apr-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
54	400 KV	400 KV Deepnagar-Thapthi-Tanda	18-Apr-18	6:00	19-Apr-18	18:00	Daily	Replacement of Damaged Insulator strings at cut point LOC 71 /R Ph & 87/ B Ph	MSETCL	MSETCL	
55	400KV	400KV Dhule-BBLR CKT-1	18-Apr-18	8:00	18-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
56	400/220 KV	315 MVA ICT-1 @ Waluj end	19-Apr-18	9:00	19-Apr-18	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	
57	220kv	Waluj- I bay @ Thapitanda	19-Apr-18	10:00	19-Apr-18	17:00	Daily	Relay Testing work	MSETCL	MSETCL	
58	400KV	400KV Dhule-BBLR CKT-2	19-Apr-18	8:00	19-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	AR in Non Auto for Ckt 1
59	400KV	Jaigad-Karad Ckt - 1	19-Apr-18	9:00	19-Apr-18	18:00	Daily	Overhead line maintenance activity	JPTL	JPTL	
60	400/220kV	315MVA, ICT 2 @ Lonikand-1	19-Apr-18	9:00	19-Apr-18	18:00	Daily	Routine Dignostic testing work	MSETCL	MSETCL	
61	400KV	400KV Future Line-II Main CB - Bay no 422 @400kv s/s warora end	20-Apr-18	7:00	20-Apr-18	17:00	Daily	Bay 422 CB DCRM ,CRM and IR Values Testing works	MSETCL	MSETCL	Only 400KV Bay Future Line-II Main CB -Bay 422 is charged on No Load. Presently No Line is ready .
62	400KV	400KV Dhule-BBLR CKT-2	20-Apr-18	8:00	20-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
63	400KV	400KV Deepnagar - Khadka - I Ckt @ Deepnagar	20-Apr-18	8:00	20-Apr-18	18:00	Daily	Annual Maintenance of bays equipment & diagnostic Testing work	MSETCL	MSETCL	
64	400KV	315 MVA ICT-3 @ Padgha	20-Apr-18	8:00 Hrs	20-Apr-18	18:00Hrs	Daily	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe RS
65	400KV	Jaigad-Karad Ckt - 2	20-Apr-18	9:00	20-Apr-18	18:00	Daily	Overhead line maintenance activity	JPTL	JPTL	
66	400KV	400KV Dhule-BBLR CKT-2	21-Apr-18	8:00	21-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
67	400KV	New Koyna-Stage 4 Ckt-1 @ N.Koyna	21-Apr-18	8:00	22-Apr-18	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL	
68	400KV	Jaigad-Newkoyna Ckt- 1	21-Apr-18	9:00	21-Apr-18	18:00	Daily	Overhead line maintenance activity	JPTL	JPTL	
69	400KV	Jaigad-Newkoyna Ckt- 2	22-Apr-18	9:00	22-Apr-18	18:00	Daily	Overhead line maintenance activity	JPTL	JPTL	
70	400/220kV	315 MVA, ICT 2 @ Talandge	23-Apr-18	9:00	23-Apr-18	20:00	Daily	Quarterly Maint work	MSETCL	MSETCL	
71	400KV	400KV Dhule-SSNNL CKT-1	23-Apr-18	8:00	23-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
72	400KV	New Koyna-Stage 4 Ckt-2 @ N.Koyna	23-Apr-18	8:00	24-Apr-18	17:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL	
73	400/220/33	315 MVA ICT-1 @ Girwali	24-Apr-18	9:00	24-Apr-18	18:00	Daily	ICT & Bay maintenance work	MSETCL	MSETCL	
74	400KV	400KV Dhule-SSNNL CKT-1	24-Apr-18	8:00	24-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	
75	400KV	408 Tie Bay only (Tie Bay of 400 KV Station 8 B) @ 400KV Switching s/s Chandrapur	25-Apr-18	9:00	25-Apr-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
76	400KV	400KV Dhule-SSNNL CKT-1	25-Apr-18	8:00	25-Apr-18	18:00	Daily	PID faulty string replacement Work	MSETCL	MSETCL	A/R required to be Off For ckt 2
77	220kv	Waluj- II bay @ Thapitanda	26-Apr-18	10:00	26-Apr-18	17:00	Daily	Relay Testing work	MSETCL	MSETCL	
78	400KV	400KV Deepnagar - Khadka - II Ckt @ Deepnagar	27-Apr-18	8:00	27-Apr-18	18:00	Daily	Annual Maintenance of bays equipment & diagnostic Testing work	MSETCL	MSETCL	
79	400KV	600 MVA ICT-4@ Padgha	27-Apr-18	8:00 Hrs	27-Apr-18	18:00Hrs	One Day	Routine R&M work	MSETCL	MSETCL	As per annual outage schedule proposed by Padghe RS
80	400/220kV	315MVA, ICT 1@ BBLR	28-Apr-18	8:00	28-Apr-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I &II , 500MVA ICT-IV will be in service
81	400/220/33	315MVA ICT-2 @ Girwali	26-Apr-18	9:00	26-Apr-18	18:00	Daily	400kv Side CT Tan Delta measurement	MSETCL	MSETCL	