

Maharashtra State Load Despatch Centre											
WRPC OCCM approved Monthly Outage list for the Month of April 2020											
SR NO.	OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Reason	Remarks	
1	2	220KV-PARLI-OSMANABAD-M-1	1-Apr-20	08:00	1-Apr-20	17:00	Daily	MSETCL	LINE maintenance	-	
2	4	400 kV-SSP-DHULE-MS-1	1-Apr-20	8:00	1-Apr-20	18:00	Daily	GETCO	PMM work.	Auto reclose of SSP - Dhule line No. 2 will remain out	
3	30	400KV-WARDHA-AKOLA-1	1-Apr-20	9:00	2-Apr-20	18:00	D	POWERGRID_WR 1	For pilot string replacement & 400KV-WARDHA-AKOLA-2 AR to be kept in non auto mode for safety precautions.Dia to be kept open for SS AMP works		
4	31	400KV-RGPPL-NAGOTHANE-1	1-Apr-20	08:00	3-Apr-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work	Planned Outgae	
5	32	400KV/220KV KARAD-ICT-2	1-Apr-20	08:00	3-Apr-20	18:00	Continuous	MSETCL	Erection of new 400 KV PG isolator & related work of Rapid restoration Scheme of ICT under Scheme	Load will be managed on other Two ICTs	
6	40	220KV-AURANGABAD-SHENDRA-2	1-Apr-20	09:00	4-Apr-20	18:00	Daily	MSETCL	Fixing of vibration dampers at various locations	shendra - pgcil ckt 1 will be in service	
7	42	400KV-KARAD-KOLHAPUR-MS-2	1-Apr-20	09:00	5-Apr-20	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK	
8	43	400KV-KARAD-KOLHAPUR-MS-1	1-Apr-20	09:00	5-Apr-20	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK	
9	44	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at Akola - 400KV	1-Apr-20	9:00	6-Apr-20	18:00	C	POWERGRID_WR 1	For Replacement of BHEL CB with GE CB at Akola (MSETCL) end.		
10	45	400KV-KALWA-PADGHE-1	1-Apr-20	09:00	9-Apr-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	
11	46	400KV-BABLESHWAR-PADGHE-PG-1	1-Apr-20	08:00	10-Apr-20	18:00	Daily	MSETCL	For Carrying out PID Work	-	
12	47	400KV-KOYNA STAGE IV-LONIKHAND-1	1-Apr-20	09:00	15-Apr-20	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK	
13	49	220KV-WARDHA-PUSAD-1	1-Apr-20	07:00	30-Apr-20	17:00	Daily	MSETCL	FOR PID WORK	NIL	
14	71	400KV-CHANDRAPU-II-NANDED-2	1-Apr-20	08:00	30-Apr-20	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	NIL	
15	72	400KV-CHANDRAPUR-GCR-PARLI-M-3	1-Apr-20	08:00	30-Apr-20	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	NIL	
16	74	400KV-JEJURI-KOYNA STAGE IV-1	1-Apr-20	09:00	30-Apr-20	17:00	Daily	MSETCL	PID TESTING WORK	AR REQUIRED IN NON AUTO MODE	
17	75	400KV-KALWA-KHARGHAR-1	1-Apr-20	09:00	30-Apr-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-	
18	79	400KV-PARLI-M-LONIKHAND-II-1	1-Apr-20	10:00	30-Apr-20	18:00	Daily	MSETCL	PID Testing work	PARLI - LONIKAND 2 CKT 2 will be in service	
19	93	400 kV-SSP-DHULE-MS-2	2-Apr-20	7:00	2-Apr-20	18:00	Daily	GETCO	PMM work.	Auto reclose of SSP - Dhule line No. 1 will remain out	
20	104	400KV-CHAKAN-PUNE-PG-1	2-Apr-20	09:00	2-Apr-20	18:00	Daily	MSETCL	Half yearly testing and maintenance activities.	---	
21	115	400KV-TARAPUR 3&4-PADGHE-2	2-Apr-20	10:00	2-Apr-20	17:00	D	POWERGRID_WR 1	For AMP of Tarapur Padghe 2 Line CVT at MSETCL Padghe SS.		
22	156	400KV-TARAPUR 3&4-PADGHE-1	3-Apr-20	10:00	3-Apr-20	17:00	D	POWERGRID_WR 1	For AMP of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.		
23	160	220KV-TARAPUR 1&2-BORIVALI-1	3-Apr-20	8:00	4-Apr-20	19:00	daily	TAPS 1&2, NPCIL	Annual maintenance	MSETCL	
24	164	400KV-WARDHA-AKOLA-2	3-Apr-20	9:00	4-Apr-20	18:00	D	POWERGRID_WR 1	for pilot string replacement & 400KV-WARDHA-AKOLA-1 AR to be kept in non auto mode for safety precautions.Dia may be kept open for SS AMP works		
25	175	JEJURI - 400KV - BUS 1	4-Apr-20	09:00	4-Apr-20	18:00	Daily	MSETCL	Annual maintenance work & testing work.	---	
26	184	220KV-BOISAR-BOISAR-M-1	4-Apr-20	09:00	4-Apr-20	13:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.	
27	197	400KV-RGPPL-NAGOTHANE-2	4-Apr-20	08:00	6-Apr-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work	Planned Outage	
28	198	400KV/220KV KARAD-ICT-1	4-Apr-20	08:00	6-Apr-20	18:00	Continuous	MSETCL	Erection of New 400 KV PG isolator & related works of Rapid Restoration Scheme under Scheme	Load will be managed on Other Two ICTs	
29	221	220KV-BOISAR-BOISAR-M-3	5-Apr-20	09:00	5-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.	
30	222	400KV-KALWA-PADGHE-2	5-Apr-20	09:00	5-Apr-20	18:00	Daily	MSETCL	Bay Maintenance & Testing work. Insulator Cleaning & Routine Maintenance work	Bay Maintenance & Testing work. Insulator Cleaning & Routine Maintenance work	
31	224	220KV-TALEGAON-PUNE-PG-2	5-Apr-20	10:00	5-Apr-20	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing	--	
32	243	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 LR @ WALUJ	6-Apr-20	9:00	6-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works. Line outage required for isolation of non switchable line reactor at Waluj end, take out/take in each operation 15 min.		
33	246	PARLI - 220KV - BUS 1	6-Apr-20	9:00	6-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works		
34	253	ALKUD - 400KV - BUS 1	6-Apr-20	10:00	6-Apr-20	17:30	Daily	MSETCL	Quarterly Maint. Work	Load will be managed on Bus II	

SR NO.	OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Reason	Remarks
35	266	220KV-MUDSHINGI-CHIKKODI-II-1	6-Apr-20	08:00	14-Apr-20	18:00	Continuous	MSETCL	Replacement of earth wire sanctioned under scheme	
36	267	220KV-TALANGADE(MS)-CHIKKODI-II-1	6-Apr-20	08:00	14-Apr-20	18:00	Continuous	MSETCL	Replacement of earth wire sanctioned under scheme	
37	271	400kV Partial Main Bus-II (from ektuni-2 to ICT-4 section) at 400kV Babhaleshwar SS	7-Apr-20	8:00	10-Apr-20	18:00	Continuous	MSETCL	Bus isolator alignment work for 400kV Kudus-I & 400kV Kudus-II bay at 400kV Babhaleshwar SS	1) Removing /reconnecting of 400kV main Bus 2 will be carried out by hot line unit 2) During outage i) 400kV Ektuni-II line will be shifted on bus-I and handtripped while removing /reconnecting of 400kV Main bus-II jumps by hot line unit ii) 400kV Ektuni-I to be shifted on bus-II iii) ICT-IV will remain on TBC till outage period
38	277	400KV-ALKUD-SOLAPUR-1	7-Apr-20	10:00	7-Apr-20	17:30	Daily	MSETCL	Quarterly Maint. Work & Diagnostic Testing Work	NA
39	278	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	7-Apr-20	10:00	7-Apr-20	17:30	Daily	MSETCL	Quarterly Maint. Work & Diagnostic Testing Work	NA
40	279	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	7-Apr-20	10:00	7-Apr-20	17:30	Daily	MSETCL	Quarterly Maint. Work & Diagnostic Testing Work	NA
41	284	220KV-PARLI-OSMANABAD-M-1	7-Apr-20	08:00	7-Apr-20	17:00	Daily	MSETCL	Line maintenance	-
42	286	400KV-RGPPL-NEW KOYNA-2	7-Apr-20	08:00	7-Apr-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work	Planned Outage
43	291	PARLI - 220KV - BUS 2	7-Apr-20	9:00	7-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works	
44	299	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	7-Apr-20	10:00	7-Apr-20	17:00	Daily	MSETCL	Maintenance of bays equipment & Diagnostics Testing Work	Maintenance of bays equipment & Diagnostics Testing Work
45	308	400KV-KHANDWA-DHULE-MS-1	7-Apr-20	9:00	8-Apr-20	18:00	D	WRTS-I	Replacement of Polymer Insulators in national High Way Crossing	
46	312	220KV-NASIK-NAVSARI-1	7-Apr-20	09:00	9-Apr-20	17:00	Daily	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.	-
47	314	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	7-Apr-20	9:00	12-Apr-20	18:00	C	POWERGRID_WR 1	For Replacement of BHEL CB with GE CB.	At Akola S/s
48	331	400KV-RGPPL-NEW KOYNA-2	8-Apr-20	08:00	8-Apr-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work	Planned Outage
49	332	220KV-PANDURNA-KALMESHVAR-1	8-Apr-20	08:00	8-Apr-20	18:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work restringing of bottom ph conductor.	-
50	336	132KV-PENCH-MP-KANHAN-1	8-Apr-20	09:00	8-Apr-20	17:00	Daily	MSETCL	Routine Maintenance work.	-
51	346	220KV-WARDHA-BHUGAON-1	8-Apr-20	10:00	8-Apr-20	18:00	Daily	MSETCL	Routine maintainace work	NA
52	347	400KV-PARLI-M-LONIKHAND-II-1	8-Apr-20	10:00	8-Apr-20	18:00	Daily	MSETCL	Hardware Tightening and Fitting Work.	-
53	348	220KV-SOLAPUR-KUMBARI-1	8-Apr-20	11:00	8-Apr-20	16:00	Daily	MSETCL	Quarterly Maintenance	Outage is required for QM work
54	349	KUMBARI - 220KV - BUS 1	8-Apr-20	11:00	8-Apr-20	16:00	Daily	MSETCL	Quarterly Maintenance work	Outage is required for QM work
55	371	220KV-PARLI-PARLI-M-1	9-Apr-20	08:00	9-Apr-20	17:00	Daily	MSETCL	Line maintenance	-
56	373	400KV-RGPPL-NEW KOYNA-2	9-Apr-20	08:00	9-Apr-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work	Planned outage
57	374	220KV-WARDHA-BHUGAON-1	9-Apr-20	09:00	9-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL Line is in ckt
58	383	400KV-KALA-KUDUS-1	9-Apr-20	10:00	9-Apr-20	17:00	Daily	MSETCL	Annual Maintenance of bays equipment & Diagnostics Testing Work	400KV Kala-2 & 400KV Bay No-405 (Respective Tie Bay of kala-1) will be in service at the time of Outage (Only Main bay of Kala-1 line outage proposed)
59	388	400KV-KARAD-KOLHAPUR-MS-2	9-Apr-20	09:00	30-Apr-20	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK
60	389	400KV-KARAD-KOLHAPUR-MS-1	9-Apr-20	09:00	30-Apr-20	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK
61	390	400KV-CHAKAN-PUNE-PG-1	9-Apr-20	9:00	9-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works & Replacement of Clamp & connectors at Pune-Talegaon	MSETCL-Ownership
62	414	220KV-BOISAR-NALASOPARA-1	10-Apr-20	09:00	10-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.
63	415	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	10-Apr-20	09:00	10-Apr-20	18:00	Daily	MSETCL	QM work	B/u relay testing & maintenance
64	421	220KV-WARDHA-BHUGAON-1	10-Apr-20	10:00	10-Apr-20	18:00	Daily	MSETCL	Routine maintainace work	NA
65	423	400KV-KARAD-JAIGAD-1	10-Apr-20	09:00	13-Apr-20	18:00	Daily	JPTL	HOTLINE INSULATOR WASHING WORKS	AR to be kept in Non-auto mode
66	424	400KV-KARAD-JAIGAD-2	10-Apr-20	09:00	13-Apr-20	18:00	Daily	JPTL	Hotline insulator washing	AR to be kept in Non-auto mode

SR NO.	OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Reason	Remarks
67	425	400KV-KALWA-PADGHE-2	10-Apr-20	09:00	18-Apr-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
68	434	400KV-KALWA-PUNE-PG-1	11-Apr-20	07:00	11-Apr-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
69	440	220KV-TARAPUR 3&4-BOISAR-1	11-Apr-20	9:00	11-Apr-20	17:30	D	POWERGRID_WR 2	LINE EQUIPMENT AMP. Line outage is required.	Boisar
70	448	BOISAR - 220KV - BUS 2	11-Apr-20	06:00	12-Apr-20	18:00	Continuous	MSETCL	1) B-Bus Isolator maintenance work. 2) Pilot string replacement identified in PID.	1) B-Bus Isolator maintenance work. 2) Pilot string replacement identified in PID.
71	451	400KV-BABLESHWAR-PADGHE-PG-1	11-Apr-20	09:00	11-Apr-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing	400kv Padghe ckt II will be in service
72	461	400KV-KALWA-PADGHE-1	12-Apr-20	09:00	12-Apr-20	18:00	Daily	MSETCL	Bay Maintenance & Testing work.	Bay Maintenance & Testing work.
73	463	220KV-TALEGAON-PUNE-PG-2	12-Apr-20	10:00	12-Apr-20	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing	---
74	464	400KV-BABLESHWAR-PADGHE-PG-2	12-Apr-20	09:00	12-Apr-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing	400KV Padghe ckt I will be in service
75	466	AURANGABAD-M (WALUJ) - 400KV - BUS 2	13-Apr-20	09:00	13-Apr-20	17:00	Daily	MSETCL	Quarterly maintenance of Khadka Bay	Quarterly maintenance of Khadka Bay
76	470	400KV-WARDHA-KORADI-II-1	13-Apr-20	09:00	13-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
77	497	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	13-Apr-20	9:00	18-Apr-20	18:00	C	POWERGRID_WR 1	For replacement of old BHEL CB with new GE CB & Line shall be shifted on to TBC during the period	
78	500	TBC @ KORADI-1	13-Apr-20	08:00	26-Apr-20	18:00	Continuous	MSETCL	CB pole and mechanism Overhauling & testing	Outages will be availed subject to weather conditions.
79	519	400KV-JAIGAD-NEW KOYNA-1	14-Apr-20	09:00	15-Apr-20	18:00	Daily	JPTL	Hotline insulator washing	AR to be kept in Non-auto mode
80	520	400KV-JAIGAD-NEW KOYNA-2	14-Apr-20	09:00	15-Apr-20	18:00	Daily	JPTL	Hotline insulator washing	AR to be kept in Non-auto mode
81	525	EKTUNI - 765KV - BUS 1	14-Apr-20	10:00	14-Apr-20	18:00	Daily	MSETCL	Relay & Daignostic Testing	765KV Main Bus-II will be in service
82	530	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	15-Apr-20	9:00	19-Apr-20	18:00	C	POWERGRID_WR 1	For Replacement of BHEL CB with GE CB.	At Akola S/s
83	536	Main Bay (428) of 400 KV Warora Ckt-I @ Chandrapur - 2	15-Apr-20	06:00	15-Apr-20	14:00	Daily	MSETCL	Diagnostic Testing Work	Line will be in service through Tie bay 429
84	537	400KV-RGPPL-NAGOTHANE-1	15-Apr-20	08:00	15-Apr-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
85	543	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	15-Apr-20	09:00	15-Apr-20	17:00	Daily	MSETCL	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	400KV PGCL Line will be charged through MAIN CB 420.
86	557	220KV-SOLAPUR-JEUR-1	15-Apr-20	10:00	15-Apr-20	17:00	Daily	MSETCL	Quarterly Maintenance	Outage is required for QM work
87	558	400KV-PARLI-M-SOLAPUR-M-1	15-Apr-20	10:00	15-Apr-20	18:00	Daily	MSETCL	Hardware Tightening and Fitting Work.	-
88	559	220KV-WARDHA-PUSAD-1	15-Apr-20	10:00	15-Apr-20	18:00	Daily	MSETCL	Routine maintainance work	NA
89	570	EKTUNI - 400KV - BUS 1	15-Apr-20	10:00	15-Apr-20	18:00	Daily	MSETCL	Relay & Daignostic Testing	400KV Main Bus-II will be in service
90	573	400KV-EKTUNI-BABLESHWAR-1	16-Apr-20	09:00	16-Apr-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing,PG Isolator works	400KV Ektuni ckt II,400kv Bhusawal and 400kv Aurangabad lines will be in in service
91	574	400KV-EKTUNI-BABLESHWAR-1	16-Apr-20	09:00	16-Apr-20	18:00	Daily	MSETCL	Disc insulators replacement at various locations Tightening Of Jumper Nut Bolts & Routine Maintenance work	
92	581	400KV-RGPPL-NAGOTHANE-2	16-Apr-20	08:00	16-Apr-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
93	583	400KV-LONIKHAND-CHAKAN-1	16-Apr-20	08:00	16-Apr-20	18:00	Daily	MSETCL	Half yearly testing and maintenance activities. Line Maintenance & Routine Diagnostic testing work	Insulator string replacement found in PID.
94	593	JEJURI - 400KV - BUS 2	16-Apr-20	09:00	16-Apr-20	18:00	Daily	MSETCL	Annual maintenance work & testing work.	---
95	596	400KV-AKOLA-AURANGABAD-1 L/R@ AKOLA - 400KV	16-Apr-20	9:00	16-Apr-20	18:00	D	POWERGRID_WR 1	For AMP Work, Line outage required for isolation of non switchable line reactor at Akola end, take out/in 15 min each operation.	
96	612	765KV/400KV EKTUNI-ICT-2	16-Apr-20	09:00	16-Apr-20	18:00	Daily	MSETCL	Relay Testing	765/400kv ICT-I will be in service.
97	614	400KV-EKTUNI-BABLESHWAR-2	17-Apr-20	09:00	17-Apr-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing,PG Isolator works	400KV Ektuni ckt I,400kv Bhusawal and 400kv Aurangabad lines will be in in service
98	615	400KV-EKTUNI-BABLESHWAR-2	17-Apr-20	09:00	17-Apr-20	18:00	Daily	MSETCL	Disc insulators replacement at various locations Tightening Of Jumper Nut Bolts & Routine Maintenance Work	Disc insulators replacement at various locations Tightening Of Jumper Nut Bolts
99	632	765KV/400KV EKTUNI-ICT-1	17-Apr-20	9:00	17-Apr-20	18:00	Daily	MSETCL	Relay Testing	765/400kv ICT-II will be in service.
100	636	400KV-AKOLA-AURANGABAD-2 L/R@ AKOLA - 400KV	17-Apr-20	9:00	17-Apr-20	18:00	D	POWERGRID_WR 1	For AMP Work, Line outage required for isolation of non switchable line reactor at Akola end, take out/in 15 min each operation.	
101	641	220KV-WARDHA-PUSAD-1	17-Apr-20	10:00	17-Apr-20	18:00	Daily	MSETCL	Routine maintainance work	NA
102	665	220KV-Pandhurna-MP-Kamleshwar	18-Apr-20	9:00	18-Apr-20	18:00	D	MP_SLDC	For line maintenance work	

SR NO.	OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Reason	Remarks
103	667	400KV-KORADI-SATPURA	18-Apr-20	9:00	18-Apr-20	18:00	D	POWERGRID_WR 1	For line side equipment AMP Worka at Koradi (MSETCL) end.	
104	672	CHANDRAPUR - 400KV - BUS 2	18-Apr-20	9:00	18-Apr-20	18:00	D	POWERGRID_WR 1	For Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2 at 400kv Chandrapur (MSETCL)	
105	673	220KV-BOISAR-BOISAR-M-2	19-Apr-20	09:00	19-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.
106	682	400KV-KHARGHAR-PUNE-PG-1	19-Apr-20	07:00	19-Apr-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
107	685	220KV-TALEGAON-PUNE-PG-1	19-Apr-20	10:00	19-Apr-20	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing	---
108	687	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at Akola - 400KV	19-Apr-20	9:00	24-Apr-20	18:00	C	POWERGRID_WR 1	For Replacement of BHEL CB with GE CB.	At Akola S/s
109	688	CHANDRAPUR - 400KV - BUS 1	19-Apr-20	9:00	19-Apr-20	18:00	D	POWERGRID_WR 1	For Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2 at 400kv Chandrapur (MSETCL)	
110	689	400KV-KHARGHAR-PUNE-PG-1	19-Apr-20	9:00	19-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works & Replacement of Clamp & connectors at Pune-Talegaon	MSETCL-Ownership
111	691	HVDC 500KV CHANDRAPUR HVDC POLE 1	20-Apr-20	06:00	27-Apr-20	18:00	Continuous	MSETCL	Stringing from loc no 278 to 294 of 500KV Chandrapur-Padghe HVDC Line Pole I due to construction of Kochi-Ambezari Dam under ORC scheme.	ORC work of Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambezari Dam.
112	703	TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV-BHUSAWAL-AKOLA-1	20-Apr-20	09:00	20-Apr-20	16:00	Daily	MSETCL	Routine Maintenance & Testing Work	Routine Maintenance & Testing Work
113	731	400KV-KALWA-PUNE-PG-1	20-Apr-20	09:00	25-Apr-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
114	732	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	20-Apr-20	9:00	25-Apr-20	18:00	C	POWERGRID_WR 1	For replacement of old BHEL CB with new GE CB & Line shall be shifted on to TBC during the period	
115	733	Main Bay - 400KV-PADGHE-BOISAR-1 AND PADGHE - 400KV - Bus 1 at PADGHE - 400KV	20-Apr-20	10:00	29-Apr-20	17:00	C	POWERGRID_WR 1	Retrofitting of old BHEL make CB with New GE make CB for 400 KV Boisar Line Bay at Padghe MSETCL. Line to be taken on TBC CB at Padghe MSETCL.	2) In case of any emergency in any other bay at Padghe MSETCL, MSETCL may consider as per system requirement to handtrip the 400KV MSETCLPadghe-PG BOISAR Line during which this Boisar Line shall be out of service. 3) In case during erection, if clearance is not met w.r.t live buses then emergency shutdown may be required for 01 or 02 days. Kindly request to concur the as proposed.
116	734	400KV-KHARGHAR-PUNE-PG-1	20-Apr-20	09:00	30-Apr-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
117	744	400KV-KALWA-PUNE-PG-1	21-Apr-20	9:00	21-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works & Replacement of Clamp & connectors at Pune-Talegaon	MSETCL-Ownership
118	748	220KV-PARLI-PARLI-M-1	21-Apr-20	08:00	21-Apr-20	17:00	Daily	MSETCL	Line maintenance	-
119	767	220KV-TARAPUR 3&4-BOISAR-1	21-Apr-20	9:00	23-Apr-20	18:00	C	NPCIL	S/D REQUESTED BY TARAPUR3&4/ NPCIL -CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	NPCIL
120	768	400KV-BABLESHWAR-PADGHE-PG-2	21-Apr-20	08:00	30-Apr-20	18:00	Daily	MSETCL	For Carrying PID Work	-
121	778	400KV-RGPPL-NAGOTHANE-1	22-Apr-20	08:00	22-Apr-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
122	783	132KV-MANSAR-MS-KANHAN-1	22-Apr-20	09:00	22-Apr-20	17:00	Daily	MSETCL	Routine Maintenance work.	---
123	796	KUMBARI - 220KV - BUS 2	22-Apr-20	11:00	22-Apr-20	16:00	Daily	MSETCL	Quarterly Maintenance	Outage is required for QM work
124	797	220KV-SOLAPUR-KUMBARI-2	22-Apr-20	11:00	22-Apr-20	16:00	Daily	MSETCL	Quarterly Maintenance	Outage is required for QM work
125	815	400KV-LONIKHAND-PUNE-PG-1	23-Apr-20	9:00	23-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works & Replacement of Clamp & connectors at Pune-Talegaon	MSETCL-Ownership
126	816	220KV-NASIK-NAVSARI-2	23-Apr-20	09:00	25-Apr-20	18:00	Daily	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.	-
127	821	400KV-RGPPL-NAGOTHANE-2	23-Apr-20	08:00	23-Apr-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
128	824	TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV	23-Apr-20	09:00	23-Apr-20	16:00	Daily	MSETCL	Routine maintenance and tedting work	Routine maintenance and tedting work
129	826	220KV-WARDHA-PUSAD-1	23-Apr-20	09:00	23-Apr-20	18:00	Daily	MSETCL	FOR ROUTINE MAINT.	NIL
130	833	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	23-Apr-20	10:00	23-Apr-20	18:00	D	POWERGRID_WR 1	Line AMP works, Dia should be kept open & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AR to be keet in Non-auto mode for safety precautions.	
131	840	AURANGABAD - 400KV - BUS 2	24-Apr-20	9:00	24-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works.	

SR NO.	OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Reason	Remarks
132	866	400KV/220KV CHANDRAPUR-ICT-2	25-Apr-20	05:00	26-Apr-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in ICT- II and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During, this outage 315MVA ICT-1 will be in service. The outage on 315MVA ICT-2 bay is required as the work of replacement of bus conductor of Main Bus-I is to be carried out in 315MVA ICT-2 bay.
133	867	CHANDRAPU-II - 400KV - BUS 1	25-Apr-20	05:00	26-Apr-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in ICT- II and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
134	868	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	25-Apr-20	05:00	26-Apr-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in ICT- II and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	The outage on Bus Coupler bay is required as the work of replacement of bus conductor of Main Bus-I is to be carried out in Bus Coupler bay.
135	873	400KV-KALWA-PADGHE-1	25-Apr-20	07:00	25-Apr-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
136	886	400KV-PARLI-M-LONIKHAND-II-2	25-Apr-20	10:00	25-Apr-20	18:00	Daily	MSETCL	Hardware Tightening and Fitting Work.	-
137	887	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	25-Apr-20	9:00	30-Apr-20	18:00	C	POWERGRID_WR 1	For Replacement of BHEL CB with GE CB.	
138	900	400KV-KALWA-PUNE-PG-1	26-Apr-20	09:00	26-Apr-20	18:00	Daily	MSETCL	Bay Maintenance & testing work.	Bay Maintenance & testing work.
139	901	AURANGABAD-M (WALUJ) - 400KV - BUS 2	27-Apr-20	09:00	27-Apr-20	17:00	Daily	MSETCL	Quarterly maintenance of Khadka bay	Quarterly maintenance of Khadka bay
140	908	NAGOTHANE - 400KV - BUS 1	27-Apr-20	08:00	27-Apr-20	17:00	Daily	MSETCL	Quarterly maintenance work	nil
141	924	400KV-KORADI-BHUSAWAL-1	27-Apr-20	09:00	9-May-20	18:00	Continuous	MSETCL	CB pole and mechanism Overhauling & testing	Proposal for 400kv Bhusawal line to be Shifted on TBC .Hence,400KV Bhusawal line will be in service through TBC.Outage will be availed subject to weather conditions.
142	927	AKOLA - 400KV - BUS 2	28-Apr-20	08:00	28-Apr-20	18:00	Daily	MSETCL	Routine Maintenance & Testing Work	Routine Maintenance & Testing Work
143	929	400KV-PARLI-M-LONIKHAND-II-1	28-Apr-20	08:00	28-Apr-20	18:00	Daily	MSETCL	Line Maintenance & Routine Diagnostic testing work.	Insulator string replacement found in PID.
144	930	TIE BAY -412 OF PARALI CKT-1 @ LONIKAND 2	28-Apr-20	09:00	28-Apr-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 2 will be in service for no supply interruption.
145	931	MAIN BAY -413 OF PARALI CKT-1 @ LONIKAND 2	28-Apr-20	09:00	28-Apr-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 2 will be in service for no supply interruption.
146	937	NAGOTHANE - 400KV - BUS 2	28-Apr-20	08:00	28-Apr-20	17:00	Daily	MSETCL	Quarterly maintenance work	nil
147	941	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	28-Apr-20	09:00	28-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
148	947	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	28-Apr-20	10:00	28-Apr-20	18:00	D	POWERGRID_WR 1	Line AMP works, Dia should be kept open & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AR to be keet in Non-auto mode for safety precautions.	
149	968	MAIN BAY - 400KV-BUS REACTOR AND DHULE-MS - at DHULE-MS - 400KV	29-Apr-20	8:00	29-Apr-20	18:00	D	POWERGRID_WR 1	For AMP works. Reactor load shall be shifted to TBC	
150	969	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	29-Apr-20	09:00	29-Apr-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
151	970	132KV-MANSAR-MS-PENCH-1	29-Apr-20	09:00	29-Apr-20	17:00	Daily	MSETCL	Routine Maintenance work.	-
152	979	400KV-SOLAPUR-M-SOLAPUR-1	29-Apr-20	10:00	29-Apr-20	18:00	Daily	MSETCL	Diagnostic Testing work	Load will be managed on 400kv Lamboti - Parali line

Not Considered Outage list in 529th WRPC OCCM

OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Name of Requesting Agency	Remarks	OCC-Remarks
573	HVDC 500KV CHANDRAPUR HVDC POLE 1 & HVDC 500KV CHANDRAPUR HVDC POLE 2	15-Apr-20	06:00	16-Apr-20	18:00	Continuous	MSETCL	To rectify bent bracing of Loc. no. 285 of 500KV Chandrapur-Padghe HVDC Line.	It is observed that there is bent bracing of Loc. No. 285 of 500KV Chandrapur-Padghe HVDC Line. It is urgent to rectify bent bracing as early as possible	Deferred due to high demand
866	HVDC 500KV CHANDRAPUR HVDC POLE 2	23-Apr-20	06:00	30-Apr-20	18:00	Continuous	MSETCL	Stringing from loc no 278 to 294 of 500KV Chandrapur-Padghe HVDC Line Pole II due to construction of Kochi-Ambezari Dam under ORC scheme	ORC work of Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambezari Dam	please plan for next OCC due to approved parallel corridor outages

Additional Outage list in 529th WRPC OCCM

OCCM SR. NO	Line / Element	From Date	From Time	To Date	To Time	D/C	Name of Requesting Agency	Name of Requesting Agency	Remarks	OCC-Remarks
AD11	MAIN BAY - 400kV KORADI-III-KORADI-II-LINE - 1 AND 400KV BUS-2 at KORADI - III -400 KV	3-Apr-20	9:00	3-Apr-20	18:00	Daily	MEGPTCL/AD ANI	Bay Maintenance Activities		Outage shall be facilitated subject to corridor availability and same shall be conveyed on D-2
AD16	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	6-Apr-20	9:00	6-Apr-20	18:00	Daily	MEGPTCL/AD ANI	Bay Maintenance Activities		Outage shall be facilitated subject to corridor availability and same shall be conveyed on D-2
AD19	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND FUTURE LINE-4 at KORADI-III - 400KV	7-Apr-20	9:00	7-Apr-20	18:00	Daily	MEGPTCL/AD ANI	Bay Maintenance Activities		Outage shall be facilitated subject to corridor availability and same shall be conveyed on D-2
AD22	765KV/400KV TIRODA-ICT-1	8-Apr-20	9:00	8-Apr-20	18:00	Daily	MEGPTCL/AD ANI	Maintenance of ICT		Outage shall be facilitated subject to corridor availability and same shall be conveyed on D-2
AD29	765KV/400KV AKOLA (2)-ICT-1	9-Apr-20	9:00	9-Apr-20	18:00	Daily	MEGPTCL/AD ANI	Maintenance of ICT		Outage shall be facilitated subject to corridor availability and same shall be conveyed on D-2
AD34	765KV-AKOLA (2)-EKTUNI-2 L/R@ AKOLA (2) - 765KV	11-Apr-20	9:00	11-Apr-20	18:00	Daily	MEGPTCL/AD ANI	Reactor Maintenance Activities		Outage shall be facilitated subject to corridor availability and same shall be conveyed on D-2

State Element Outage list for the month of April 2020

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
1	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	1-Apr-20	09:00	1-Apr-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	-
2	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	1-Apr-20	08:00	15-Apr-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	NIL
3	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	2-Apr-20	08:00	2-Apr-20	18:00	Daily	Routine Diagnostic testing work. Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 1 will be in service for no supply interruption.
4	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	2-Apr-20	08:00	2-Apr-20	14:00	Daily	Routine Maintenance & Relay Testing.	MSETCL	MSETCL	-
5	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	2-Apr-20	09:00	2-Apr-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 1 will be in service for no supply interruption.
6	400 KV	Akola II (Yelwan) - Akola I CKT - 2	3-Apr-20	08:00	3-Apr-20	17:00	Daily	ROUTINE MAINTENANCE &TESTING WORK	APTCL	APTCL	ROUTINE MAINTENANCE &TESTING WORK
7	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	3-Apr-20	06:00	3-Apr-20	14:00	Daily	Diagnostic Testing work and allied bay maintenance work	MSETCL	MSETCL	400KV Chandrapur2-GCR ckt-1 is in service
8	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	3-Apr-20	08:00	3-Apr-20	13:00	Daily	IR, Tan delta measurement of Bushing <u>Tan delta Measurement of Line of Bay 430</u>	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
9	400 KV	KORADI-KHAPERKHEDA I	3-Apr-20	09:00	3-Apr-20	18:00	Daily	Proposal for shifting of 400KV Koradi 1- Khaperkheda on TBC for Replacement of isolator 29A Y phase PG assembly	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
10	400 KV	TIE BAY (411) OF STATION TF 8A & CHANDRAPUR 2 CKT - 2 @ CHANDRAPUR SWG S/S	3-Apr-20	08:00	3-Apr-20	18:00	Daily	Diagnostic testing & Bay maint. work	MSETCL	MSETCL	Diagnostic testing & Bay maint. work
11	400 KV	400/220 125MVAr BUS REACTOR @ LAMBOTI	3-Apr-20	10:00	3-Apr-20	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Bus reactor will be in out of service
12	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	4-Apr-20	08:00	4-Apr-20	18:00	Daily	Quarterly Maintenance work & Relay Testing,HV&MV NIT switch replacement	MSETCL	MSETCL	400/220kv 315MVA ICT-I & 501 MVA ICT -III& 501 MVA ICT-IV will be in service
13	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	4-Apr-20	06:00	4-Apr-20	18:00	Daily	for routine bay maintenance and CTR servicing/overhauling works	MSETCL	MSETCL	nil
14	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	4-Apr-20	08:00	4-Apr-20	13:00	Daily	IR, Tan delta measurement of Bushing <u>Tan delta Measurement of Line of Bay 430</u>	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
15	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	4-Apr-20	09:00	4-Apr-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID works, Auto Reclosure out only
16	400 KV	KARAD - TALANDGE CKT 2	6-Apr-20	08:00	6-Apr-20	18:00	Daily	COLD LINE WASHING WORK & FAULTY STRING REPLACEMENT WORK	MSETCL	MSETCL	KARAD- TALANDGE CKT 1 WILL BE IN SERVICE
17	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	6-Apr-20	10:00	6-Apr-20	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Testing work will be carried out without interruption of load as it is of spare unit
18	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	7-Apr-20	08:30	7-Apr-20	17:00	Daily	501MVA ICT-I HV, LV, Tertiary Bushing & winding Tan delta LVCT Tan delta testing work	MSETCL	MSETCL	Load will be managed on 501MVA ICT-II
19	400 KV	KARAD - TALANDGE CKT 2	7-Apr-20	09:00	7-Apr-20	18:00	Daily	QM Work, COLD WASHING WORK	MSETCL	MSETCL	Load will be managed on 400kv Talandge-Karad ckt-1
20	400 KV	DHULE- - BABLESHWAR - I	7-Apr-20	09:00	7-Apr-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kv Dhule ckt II,400kv Bhusawal and 400kv Aurangabad lines will be in in service
21	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	7-Apr-20	09:00	7-Apr-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS, A/R out only
22	400 KV	Main Bay 412 of Chadrapur II ckt 2 @ C'pur Sw.	8-Apr-20	08:00	8-Apr-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Diagnostic testing work
23	400 KV	DHULE- - BABLESHWAR - II	8-Apr-20	09:00	8-Apr-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kv Dhule ckt I,400kv Bhusawal and 400kv Aurangabad lines will be in in service
24	400 KV	TBC @ KOLHAPUR(TALANDGE)	8-Apr-20	09:00	8-Apr-20	18:00	Daily	QM work	MSETCL	MSETCL	Testing & maintenance work
25	400 KV	KARAD - TALANDGE CKT 1	8-Apr-20	08:00	8-Apr-20	17:00	Daily	COLD LINE WASHING WORK	MSETCL	MSETCL	COLD LINE WASHING WORK
26	400 KV	NEW KOYNA -KARAD -CKT 2	9-Apr-20	08:00	11-Apr-20	18:00	Daily	COLD LINE WASHING WORK & PID FAULTY STRING REPLACEMENT WORK	MSETCL	MSETCL	KOYNA 1 WILL BE IN SERVICE
27	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	9-Apr-20	08:00	9-Apr-20	14:00	Daily	Routine Maintenance & Relay Testing.	MSETCL	MSETCL	-
28	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	9-Apr-20	08:00	9-Apr-20	17:00	Daily	For Replacement of Disc Insulator & Hardware tightening if found During PID Testing & MP	MSETCL	MSETCL	For Replacement of Disc Insulator & Hardware tightening if found During PID Testing & MP
29	400 KV	400/220/33KV SPARE ICT @ KORADI 2	9-Apr-20	08:00	9-Apr-20	13:00	Daily	IR,Tan Delta Measurement of Bushing	MSETCL	MSETCL	Outage will be availed subject to weather condition
30	400 KV	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	9-Apr-20	09:00	9-Apr-20	16:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Routine Maintenance & testing work
31	400 KV	MAIN BAY (409) OF CHANDRAPUR GCR CKT - 2 @ CHANDRAPUR 2	9-Apr-20	06:00	9-Apr-20	14:00	Daily	Daignostic testing work	MSETCL	MSETCL	Line will be in service through Tie bay 408
32	400 KV	SPARE LINE-1 BAY (401) @ TAPTITANDA	9-Apr-20	09:00	9-Apr-20	16:00	Daily	CT Tan delta measurement and quarterly maint. work	MSETCL	MSETCL	Nil

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
33	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	9-Apr-20	09:00	9-Apr-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption.
34	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	9-Apr-20	09:00	9-Apr-20	18:00	Daily	Half yearly testing and maintenance activities.	MSETCL	MSETCL	---
35	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	10-Apr-20	08:00	10-Apr-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Diagnostic testing work
36	400 KV	THAPTI TANDA - WALUJ	10-Apr-20	09:00	10-Apr-20	16:00	Daily	CT Tan delta measurement & routine maint. work	MSETCL	MSETCL	Nil
37	400 KV	WARORA - IEPL	10-Apr-20	09:00	10-Apr-20	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of Jumper Tightning work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
38	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	10-Apr-20	08:00	20-Apr-20	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	-
39	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	11-Apr-20	08:00	11-Apr-20	18:00	Daily	Quarterly Maintenance work & Relay Testing,NDR Relay PSL modification,PG Isolator works	MSETCL	MSETCL	400/220kv 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT-IV will be in servic
40	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	11-Apr-20	09:00	11-Apr-20	17:00	Daily	Quarterly maintenance ICT Bay	MSETCL	MSETCL	Quarterly maintenance ICT bay
41	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	11-Apr-20	09:00	11-Apr-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS,A/R OUT only
42	400 KV	NEW KOYNA - STAGE IV CKT 1	12-Apr-20	08:00	12-Apr-20	18:00	Daily	Cold washing, Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Planned outage
43	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	13-Apr-20	09:00	13-Apr-20	18:00	Daily	For Line Signature Analysis from Parli End	MSETCL	MSETCL	-
44	400 KV	NEW KOYNA - STAGE IV CKT 2	13-Apr-20	08:00	13-Apr-20	18:00	Daily	Cold washing, Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Planned Outage
45	400 KV	JAIGAD-NEW KOYNA-II	13-Apr-20	08:00	13-Apr-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
46	400 KV	KARAD - TALANDGE CKT 2	13-Apr-20	08:00	13-Apr-20	17:00	Daily	cold line washing work	MSETCL	MSETCL	karad - talandge ckt 1 will be in service
47	400 KV	PADGHE - NAGOTHANE 1	13-Apr-20	08:00	13-Apr-20	17:00	Daily	Faulty string and Jumper ,cold washing replacement work	MSETCL	MSETCL	nil
48	400 KV	125MVAr BUS REACTOR @ WARORA	13-Apr-20	09:00	13-Apr-20	17:00	Daily	Diagnotesting testing activity and maintenance work	MSETCL	MSETCL	Reactor is in OFF condition during outage.
49	400 KV	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	13-Apr-20	09:00	13-Apr-20	16:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Routine maintenance & testing work
50	400 KV	NEW KOYNA-KARAD -CKT 1	14-Apr-20	08:00	14-Apr-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
51	400 KV	PADGHE - NAGOTHANE 2	14-Apr-20	08:00	14-Apr-20	17:00	Daily	Faulty string and Jumper ,cold wasing replacement work	MSETCL	MSETCL	nil
52	400 KV	NEW KOYNA-KARAD -CKT 1	14-Apr-20	08:00	14-Apr-20	18:00	Daily	cold line washing work & PID faluty string replacement work	MSETCL	MSETCL	koyna - karad 2 will be in service
53	400 KV	NEW KOYNA -KARAD -CKT 2	15-Apr-20	08:00	15-Apr-20	18:00	Daily	cold line washing work	MSETCL	MSETCL	karad - koyna 1 will be in service
54	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	15-Apr-20	08:00	15-Apr-20	19:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Diagnostic testing work
55	400 KV	THAPTI TANDA - WALUJ	15-Apr-20	09:00	15-Apr-20	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	Quarterly maintenance
56	400 KV	125 MVAr BUS REACTOR @ TALANDGE	15-Apr-20	09:00	15-Apr-20	18:00	Daily	QM work	MSETCL	MSETCL	80MVAR Bus reactor remain in service.
57	400 KV	CHANDRAPUR - KHAPERKHEDA	15-Apr-20	09:00	15-Apr-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	_
58	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	15-Apr-20	08:30	15-Apr-20	17:00	Daily	501MVA ICT-I HV, LV, Tertiary Bushing & winding Tan delta LVCT Tan delta testing work	MSETCL	MSETCL	Load will be managed on 501MVA ICT-I
59	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	15-Apr-20	10:00	15-Apr-20	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500 MVA ICT - 2
60	400 KV	NEW KOYNA -KARAD -CKT 2	15-Apr-20	08:00	15-Apr-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
61	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	16-Apr-20	09:00	16-Apr-20	18:00	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
62	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	16-Apr-20	08:00	16-Apr-20	13:00	Daily	IR, Tan delta measurement of Bushing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
63	400 KV	SPARE LINE-2 BAY (404) @ TAPTITANDA	16-Apr-20	09:00	16-Apr-20	16:00	Daily	CT Tan delta measurement and quarterly maint. work	MSETCL	MSETCL	Nil
64	400 KV	KORADI-NANDGAONPETH (RPL)	16-Apr-20	09:00	16-Apr-20	18:00	Daily	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	MSETCL	MSETCL	_
65	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	16-Apr-20	08:00	16-Apr-20	17:00	Daily	For Conductor & Earthwire Hardware tightening work	MSETCL	MSETCL	For Conductor & Earthwire Hardware tightening work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
66	400 KV	DEEPNAGAR - THAPTI TANDA	16-Apr-20	09:00	16-Apr-20	16:00	Daily	CT Tan delta measurement and quarterly maint. work	MSETCL	MSETCL	Nil
67	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	16-Apr-20	09:00	16-Apr-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption
68	400 KV	LONIKAND 1 - KOYNA STAGE-IV	17-Apr-20	09:00	17-Apr-20	17:00	Daily	COLD WASHING WORK & PID FAULTY DISC REPLACEMENT WORK	MSETCL	MSETCL	NA
69	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	17-Apr-20	08:00	17-Apr-20	13:00	Daily	IR, Tan delta measurement of Bushing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
70	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	17-Apr-20	06:00	17-Apr-20	14:00	Daily	Diagnostic Testing work and allied bay maintenance work.	MSETCL	MSETCL	400KV Chandrapur2-nanded ckt-2 is in service.
71	400 KV	LONIKAND 1 - KOYNA STAGE-IV	17-Apr-20	09:00	30-Apr-20	17:00	Daily	PID TESTING WORK	MSETCL	MSETCL	AR REQUIRED IN NON AUTO MODE
72	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	18-Apr-20	09:00	18-Apr-20	18:00	Daily	Line Conductor and Earth wire hardware tightening work	MSETCL	MSETCL	-
73	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	18-Apr-20	09:00	18-Apr-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS, Auto Reclosure out only
74	400 KV	CHANDRAPUR - KHAPERKHEDA	18-Apr-20	08:00	18-Apr-20	17:00	Daily	For Replacement of Disc Insulator if found During PID Testing	MSETCL	MSETCL	For Replacement of Disc Insulator if found During PID Testing
75	400 KV	80 MVAr BUS REACTOR - 1 @ BABHALESHWAR	18-Apr-20	08:00	18-Apr-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	All 4 nos of ICT and 400kv Lines will be in service
76	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	20-Apr-20	08:00	20-Apr-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
77	400 KV	PADGHE - NAGOTHANE 1	20-Apr-20	08:00	20-Apr-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
78	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	20-Apr-20	09:00	20-Apr-20	18:00	Daily	Pre Monsoon Maintenance work	MSETCL	MSETCL	ICT 1 & ICT 2 are in service.
79	400 KV	PADGHE - NAGOTHANE 2	21-Apr-20	08:00	21-Apr-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
80	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	21-Apr-20	08:00	21-Apr-20	17:00	Daily	For measurement of CT Tan delta and Capacitance	MSETCL	MSETCL	During, this outage 400KV CHD-2 CKT.1 will be in service. The outage on 400KV CHD-2 CKT.2 bay is required as the work of measurement of CT Tan delta and Capacitance is to be carried out in 400KV CHD-2 CKT.2.
81	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	21-Apr-20	08:00	21-Apr-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
82	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	21-Apr-20	09:00	21-Apr-20	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
83	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	22-Apr-20	06:00	22-Apr-20	14:00	Daily	Diagnostic Testing work and allied bay maintenance work.	MSETCL	MSETCL	Line service through Tie bay
84	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	23-Apr-20	09:00	23-Apr-20	18:00	Daily	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	MSETCL	MSETCL	Outage proposed by LM S/dn, Koradi
85	400 KV	JEJURI- KOYNA STAGE-IV	23-Apr-20	09:00	23-Apr-20	17:00	Daily	PID FAULTY DISC REPLAMENT WORK & COLD WASHING WORK	MSETCL	MSETCL	NA
86	400 KV	CHANDRAPUR-PARLI CKT-3	24-Apr-20	09:00	24-Apr-20	18:00	Daily	Line Conductor and Earth wire hardware tightening work	MSETCL	MSETCL	-
87	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	24-Apr-20	06:00	24-Apr-20	14:00	Daily	Diagnostic Testing work and allied bay maintenance work.	MSETCL	MSETCL	400KV Chandrapur2-Switching ckt-1 is in service.
88	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	24-Apr-20	08:00	24-Apr-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	nil
89	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	25-Apr-20	08:00	25-Apr-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	nil
90	400 KV	KARAD - TALANDGE CKT 2	27-Apr-20	09:00	27-Apr-20	17:00	Daily	COLD LINE WASHING WORK	MSETCL	MSETCL	COLD LINE WASHING WORK
91	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	27-Apr-20	09:00	27-Apr-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	All other 400KV lines will be in service at 400kv BBLR End.
92	400 KV	400/220/33KV SPARE ICT @ KUDUS	27-Apr-20	10:00	27-Apr-20	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	MSETCL	167 MVA 1-Ph ICT Outage proposed for testing and Maintenance Work
93	400 KV	KHADKA - BABLESHWAR	28-Apr-20	09:00	28-Apr-20	17:00	Daily	Quarterly Maintenance work & Relay Testing,PG Isolator works	MSETCL	MSETCL	All other 400KV lines will be in service at 400kv BBLR End.
94	400 KV	NEW KOYNA - KARAD -CKT 2	28-Apr-20	08:00	28-Apr-20	18:00	Daily	COLD LINE WASHING WORK	MSETCL	MSETCL	COLD LINE WASHING WORK
95	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	29-Apr-20	08:00	29-Apr-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	nil
96	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	30-Apr-20	09:00	30-Apr-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 2 will be in service for no supply interruption.
97	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	30-Apr-20	09:00	30-Apr-20	18:00	Daily	Half yearly maintenance and diagnostic testing. Routine Diagnostic testing work.	MSETCL	MSETCL	Interconnector 2 will be in service for no supply interruption.