

Maharashtra State Load Despatch Centre										
Monthly Outage list approved in WRLDC OCCM for the Month of APRIL' 2022										
Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
1	1	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	Continuous	1) Replacement of CB under LES scheme 2) Replacement of PG Isolator 3) Diagnostic Testing work 4) MTAMC work	23-Mar-22	09:00	1-Apr-22	20:00	1) Hot line work for Hanger replacement 2) agency will be present on site
2	6	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	1-Apr-22	08:00	1-Apr-22	18:00	
3	33	MSETCL	SOLAPUR-M - 400KV - BUS 1	Daily	PID testing work	1-Apr-22	10:00	4-Apr-22	18:00	without load interruption
4	40	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Online PID work	1-Apr-22	08:00	13-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 2 to be on NonAuto mode.
5	41	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Online PID work	1-Apr-22	08:00	13-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 1 to be on NonAuto mode.
6	42	MSETCL	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND FUTURE at LONIKHAND-II - 400KV	Daily	To carry out PID.	1-Apr-22	08:00	13-Apr-22	18:00	---
7	43	MSETCL	400KV-BHUSAWAL-DEEPNAGAR-1	Daily	For replacement of earth wire by OPGW by MTCIL	1-Apr-22	06:00	15-Apr-22	18:00	During Online work A/R should be in Non-Auto mode
8	44	MSETCL	400KV-BHUSAWAL-DEEPNAGAR-2	Daily	For replacement of Earth wire by OPGW By MTCIL	1-Apr-22	06:00	15-Apr-22	18:00	During online work A/R should be in Non-Auto mode
9	47	MSETCL	MAIN BAY OF 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 AND CHANDRAPUR-GCR - 400KV - BUS 1 @CHANDRAPUR-GCR - 400KV at CHANDRAPUR-GCR - 400KV	Continuous	1) Capital overhauling and servicing of Mechanism Drive, SF6 gas monitoring assembly, Hydraulic pressure monitoring assembly and Poles and Interrupters. 2) Measurement of Timing, CRM and DCRM of CB. 3) Maintenance and alignments of PG-1 and PG-2 Isolators. During outage, HVDC ckt.- 2 will be in service via TBC-2 and there will not be any power restriction on Bi pole. i.e. HVDC Pole-1 & 2.	1-Apr-22	08:00	15-Apr-22	18:00	During outage, HVDC ckt.- 2 will be in service via TBC-2 and there will not be any power restriction on Bi pole. i.e. HVDC Pole-1 & 2.
10	48	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	To Off / Out Auto Reclose at Both Ends For Carrying PID Work on	1-Apr-22	08:00	15-Apr-22	18:00	-
11	53	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	Only AR to kept off during outage, for OPGW wire stringing work	1-Apr-22	7:00	30-Apr-22	19:00	
12	58	MSETCL	400KV-KARAD-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Apr-22	08:00	30-Apr-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
13	59	MSETCL	400KV-KARAD-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Apr-22	08:00	30-Apr-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
14	60	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Apr-22	08:00	30-Apr-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
15	61	MSETCL	400KV-CHANDRAPUR-II-NANDED-2	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Apr-22	08:00	30-Apr-22	17:00	.
16	62	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Apr-22	08:00	30-Apr-22	17:00	.
17	63	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard	1-Apr-22	08:00	30-Apr-22	17:00	.
18	65	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Apr-22	08:00	30-Apr-22	18:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
19	66	MSETCL	400KV-TAPTHITHANDA-EKTUNI-1	Daily	Stringing of OPGW cable. Only AR required in Non-auto mode.	1-Apr-22	08:00	30-Apr-22	19:00	Request from MTCIL received through mail dtd. 14.02.22

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
20	67	MSETCL	400KV-TAPTHITHANDA-EKTUNI-2	Daily	Stringing of OPGW cable. Only AR required in Non-auto mode.	1-Apr-22	08:00	30-Apr-22	19:00	Request from MTCIL received through mail dtd. 14.02.22
21	79	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID testing work, 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	1-Apr-22	09:00	30-Apr-22	17:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
22	80	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	PID testing work	1-Apr-22	09:00	30-Apr-22	18:00	-
23	83	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	PID Testing work	1-Apr-22	09:30	30-Apr-22	17:30	-
24	84	MSETCL	220KV-PARLI-PARLI-M-2	Daily	PID Testing work	1-Apr-22	09:30	30-Apr-22	17:30	-
25	86	POWERGRID_WRI	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	For AMP Work	2-Apr-22	9:00	2-Apr-22	18:00	
26	90	POWERGRID_WRI	220KV-AURANGABAD-SHENDRA-2	D	For Line Equipment AMP	2-Apr-22	7:00	2-Apr-22	18:00	
27	112	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continuous	Work of replacement of suspension tower(loc. no.121)of 500KV chandrapur-padghe hVdc Line and restringing from Loc.no.117-122 under hvdc TL O&M S/Dn. Chandrapur	2-Apr-22	06:00	4-Apr-22	18:00	Work of replacement of suspension tower(loc. no.121)of 500KV chandrapur-padghe hVdc Line and restringing from Loc.no.117-122 under hvdc TL O&M S/Dn. Chandrapur
28	115	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing, 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	2-Apr-22	09:00	30-Apr-22	17:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
29	142	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	4-Apr-22	08:00	4-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
30	154	MSETCL	220KV-MUDSHINGLI-CHIKKODI-II-1	Daily	Maintenance work	4-Apr-22	09:00	4-Apr-22	18:00	
31	164	MSETCL	KORADI - 400KV - BUS 1	Daily	Incorporating of 400KV Numerical Busbar Protection Scheme in MTAMC SCADA with IEC61850 protocol under MTAMC Project. All elements on bus 1 and bus 2 will be in service only bus bar protection will be out.	4-Apr-22	10:30	4-Apr-22	14:30	All elements on bus 1 and bus 2 will be in service only bus bar protection will be out.
32	165	MSETCL	KORADI - 400KV - BUS 2	Daily	Incorporating of 400KV Numerical Busbar Protection Scheme in MTAMC SCADA with IEC61850 protocol under MTAMC Project. All elements on bus 1 and bus 2 will be in service only bus bar protection will be out.	4-Apr-22	10:30	4-Apr-22	14:30	All elements on bus 1 and bus 2 will be in service only bus bar protection will be out.
33	168	POWERGRID_WRI	132KV-BHUGAON-DEOLI-1 (MSETCL line) & 132KV PULGAON-DEOLI-1 (MSETCL line)	C	Loc. 03-04 MSEDCL Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	4-Apr-22	7:00	5-Apr-22	18:00	
34	169	POWERGRID_WRI	132KV-BHUGAON-DEOLI-1 (MSETCL line) & 132KV PULGAON-DEOLI-1 (MSETCL line)	C	Loc. 03-04 MSEDCL Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	4-Apr-22	7:00	5-Apr-22	18:00	AC TRANSMISSION LINE CIRCUIT
35	173	MSETCL	220KV-NASIK-NAVSARI-1	Daily	Line maintenance and Bay maint. & any abnormalities observed attending, other works if any required to be carried out will be covered during this outage.	4-Apr-22	09:00	5-Apr-22	18:00	-
36	174	MSETCL	400KV-KARAD-JAIGAD-1	Daily	hot line insulator washing	4-Apr-22	09:00	5-Apr-22	18:00	AR to be disable
37	175	MSETCL	400KV-KARAD-JAIGAD-2	Daily	hot line insulator washing	4-Apr-22	09:00	5-Apr-22	18:00	AR to be disable
38	180	MSETCL	AKOLA - 400KV - BUS 1	Daily	PID Testing work of Insulator strings of 400kV Main Bus (Hot Line Work)	4-Apr-22	10:00	5-Apr-22	16:00	The Main Bus-1 will be in service only caution permit required.
39	183	MSETCL	400 KV AUX BUS @ CHANDRAPUR GCR	Continuous	PID Testing of Disc Insulator strings.	4-Apr-22	08:00	8-Apr-22	18:00	Work will be executed in live condition.
40	191	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	4-Apr-22	09:00	9-Apr-22	17:00	--
41	192	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	PID Testing Auto-Reclose function to be out of service.	4-Apr-22	09:00	9-Apr-22	18:00	PID Testing Auto-Reclose function to be out of service.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
42	193	MSETCL	NEW KOYNA-KARAD CKT - 2 ON TBC @ NEW KOYNA	Continuous	C.B. Overhauling work Shitting on TBC	4-Apr-22	08:00	11-Apr-22	18:00	Planned outage
43	197	POWERGRID_WRI	AURANGABAD - 220KV - Bus 2	D	For AMP works	5-Apr-22	7:00	5-Apr-22	18:00	
44	205	POWERGRID_WRI	AURANGABAD - 220KV - Bus 1	D	For AMP works	5-Apr-22	7:00	5-Apr-22	18:00	
45	208	MSETCL	MAIN BAY OF 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 @WARORA - 400KV at WARORA - 400KV	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	5-Apr-22	08:00	5-Apr-22	17:00	Line will charged through tie bay no 421.
46	212	MSETCL	400KV-KHANDWA-DHULE-MS-1	Daily	PG isolator Maint work	5-Apr-22	08:00	5-Apr-22	18:00	Servicing & overhauling of isolator
47	213	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	5-Apr-22	08:00	5-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
48	219	MSETCL	BALE - SOLAPUR (PG)	Daily	An outage is required for Quarterly Maintenance	5-Apr-22	09:00	5-Apr-22	15:00	Quarterly Maintenance
49	236	MSETCL	SOLAPUR-M - 400KV - BUS 1	Daily	PID testing work	5-Apr-22	10:00	5-Apr-22	18:00	All elements on Main Bus- 1 will be in service only cuation permit required.
50	245	MSETCL	AKOLA - 400KV - BUS 2	Daily	work of PID Testing Insulator strings of 400kV main Bus-II (Hot Line Work)	5-Apr-22	10:00	6-Apr-22	16:00	All elements on Bus-II will be in service only cuation permit required.
51	251	MSETCL	220KV-WARDHA-BADNERA-1	Daily	For Hot line Work, Replacement of Broken Disc , Shifting of auto reclose switch to non auto mode.	5-Apr-22	10:00	8-Apr-22	17:00	.
52	255	MSETCL	400KV-WARDHA-WARORA-1	Daily	Routine Maintenance & Dignostic testing work.	6-Apr-22	09:00	6-Apr-22	17:00	400KV WARORA-IEPL Line is in ckt
53	260	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND FUTURE at CHANDRAPUR-II - 400KV	Daily	Diagnostic testing and allied bay maintenance work	6-Apr-22	08:00	6-Apr-22	15:00	Line will be in service through main bay 425
54	261	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	6-Apr-22	08:00	6-Apr-22	17:00	Line will charged through tie bay no 421.
55	265	MSETCL	400KV-KHANDWA-DHULE-MS-2	Daily	PG isolator Servicing & overhauling work	6-Apr-22	08:00	6-Apr-22	18:00	PG isolator Servicing & overhauling work
56	274	MSETCL	220KV-PANDURNA-KALMESHVAR-1	Daily	Routine Maintenance & Dignostic testing work	6-Apr-22	09:00	6-Apr-22	17:00	NA
57	275	MSETCL	132KV-PENCH-KANHAN-1	Daily	Routine Maintenance work.	6-Apr-22	09:00	6-Apr-22	17:00	NA
58	280	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay equipment	6-Apr-22	09:00	6-Apr-22	18:00	Annual Maintenance of Bay equipment
59	281	MSETCL	400KV-JAIGAD-NEW KOYNA-1	Continuous	hot line insulator washing	6-Apr-22	09:00	6-Apr-22	18:00	AR to be disable
60	282	MSETCL	400KV-JAIGAD-NEW KOYNA-2	Continuous	hot line insulator washing	6-Apr-22	09:00	6-Apr-22	18:00	AR to be disable
61	287	MSETCL	220KV-PARLI-OSMANABAD-M-1	Continuous	LINE maintenance	6-Apr-22	09:30	6-Apr-22	17:30	-
62	293	MSETCL	TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND FUTURE at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	6-Apr-22	10:00	6-Apr-22	18:00	765/400kV 1500MVA ICT-I will be in service through its Main 710 Bay & Main Bus-II
63	296	MSETCL	220KV-SOLAPUR-KUMBARI-1	Daily	An outage is required for Quarterly Maintenance	6-Apr-22	11:00	6-Apr-22	17:00	Quarterly Maintenance
64	297	MSETCL	KUMBARI - 220KV - BUS 1	Daily	An outage is required for Quarterly Maintenance	6-Apr-22	11:00	6-Apr-22	17:00	Quarterly Maintenance

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
65	306	MSETCL	SOLAPUR-M - 400KV - BUS 2	Daily	PID Testing work	6-Apr-22	10:00	9-Apr-22	18:00	All elements on bus 2 will be in service, only caution permit will be required.
66	312	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Replacement of suspicious faulty string if found in PID testing.	7-Apr-22	08:00	7-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 2 to be kept on NonAuto mode.
67	319	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintenance Work	7-Apr-22	07:00	7-Apr-22	18:00	-
68	323	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	7-Apr-22	08:00	7-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
69	324	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	Half Yearly Bay Maintenance & DT work	7-Apr-22	08:00	7-Apr-22	18:00	---
70	325	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of suspicious faulty string if found in PID testing.A/R switch of 400KV DHL-BBLR 1 to be kept on NonAuto mode.	7-Apr-22	08:00	7-Apr-22	18:00	
71	332	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP works	7-Apr-22	9:00	7-Apr-22	17:30	PG-WR2-Boisar
72	333	POWERGRID_WRI	PUNE-PG - 220KV - BUS 2	D	For AMP Work	7-Apr-22	9:00	7-Apr-22	18:00	
73	334	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	Diagnostic testing and maintenance activities.	7-Apr-22	09:00	7-Apr-22	18:00	---
74	339	APML-ADANI	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	Daily	706-52 Breaker Maintenance	7-Apr-22	9:00	7-Apr-22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
75	345	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	7-Apr-22	10:00	7-Apr-22	18:00	765/400kV 1500MVA ICT-II will be in service through its TIE 712 Bay & Main Bus-1
76	352	MSETCL	220KV-NASIK-NAVSARI-2	Daily	Line maintenance and Bay maint. & any abnormalities observed attending, other works if any required to be carried out will be covered during this outage.	7-Apr-22	09:00	8-Apr-22	18:00	-
77	363	MSETCL	PADGHE - 400KV - BUS 1	Continuous	1) 400kV TBC Bay A Bus Hanger rod replacement work by Hot Line method	8-Apr-22	09:00	10-Apr-22	19:00	1) Agency will be present on site for the work 2) Hot line unit present on site 3) In any emergency other bay can be shifted on B Bus of TBC
78	364	MSETCL	TBC @ PADGHE	Continuous	1) A Bus PG isolator replacement work under LES scheme(project work) 2) Hanger rod replacement work by Hot line method	8-Apr-22	09:00	10-Apr-22	19:00	1)Agency will be present on site for the work
79	372	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	8-Apr-22	08:00	8-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
80	391	MSETCL	AKOLA - 400KV - BUS 1	Daily	Routine maintenance & testing work	8-Apr-22	10:00	8-Apr-22	17:00	All elements will be in service on 400 KV Main Bus -02
81	393	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Hotline washing of Equipments and Bus strings	8-Apr-22	10:00	8-Apr-22	18:00	Work of M/S Adani at 400KV kharghar substation is on going and hill cutting/Excavation at hill for erection of EHV line tower at Kharghar Hill near by 400KV kharghar Substation due to which dust formation of EHV equipment's is observed, hence hotline washing of said nearby bay is proposed.
82	408	MSETCL	BOISAR-M - 220KV - BUS 1	Continuous	Bus Maintenance works	9-Apr-22	07:00	10-Apr-22	19:00	Bus Maintenance works
83	409	MSETCL	400KV-KALWA-PADGHE-2	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	9-Apr-22	09:00	9-Apr-22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
84	425	MSETCL	220KV-BOISAR-BOISAR-M-1	Daily	"Pre Monsoon Maintenance of Line & Bay Maintenance works"	9-Apr-22	07:00	9-Apr-22	19:00	"Pre Monsoon Maintenance of Line & Bay Maintenance works"
85	427	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	9-Apr-22	08:00	9-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
86	428	MSETCL	400KV-KARAD-NEW KOYNA-2	Daily	Cold line washing work & PID Faulty disc insulator replacement work	9-Apr-22	08:00	9-Apr-22	18:00	Cold line washing work & PID Faulty disc insulator replacement work
87	441	MSETCL	KORADI-II - 400KV - BUS 1	Daily	Pre-commissioning & testing of 125 MVAR Bus reactor. Busbar protection scheme required out of service. Both bus will be in service.	9-Apr-22	9:30	9-Apr-22	20:00	Project work
88	442	MSETCL	KORADI-II - 400KV - BUS 2	Daily	Pre-commissioning & testing of 125 MVAR Bus reactor. Busbar protection scheme required out of service. Both bus will be in service.	9-Apr-22	9:30	9-Apr-22	20:00	Project work
89	448	POWERGRID_WRI	220KV-TALEGAON-PUNE-PG-1	D	For AMP Work	10-Apr-22	9:00	10-Apr-22	18:00	
90	452	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	"Pre Monsoon Maintenance of Line & Bay Maintenance works"	10-Apr-22	07:00	10-Apr-22	19:00	"Pre Monsoon Maintenance of Line & Bay Maintenance works"
91	454	MSETCL	400KV-KALWA-PADGHE-1	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	10-Apr-22	09:00	10-Apr-22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity
92	456	MSETCL	400KV-KALWA-PADGHE-1	Daily	1) Bay maintenance work 2) Replacement of 29C Bus PG isolator under LES scheme 3) Diagnostic Testing Work 4) MTAMC work	10-Apr-22	09:00	10-Apr-22	19:00	1) Agency will be present on site for the work.
93	457	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance, Relay Testing.	10-Apr-22	10:00	10-Apr-22	18:00	---
94	467	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work.	11-Apr-22	09:00	11-Apr-22	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
95	468	MSETCL	400KV-PARLI-M-KARJAT-1	Daily	(1) Main-2 distance relay testing work. (2) Bay maintenance work. (3) Line maintenance work.	11-Apr-22	09:00	11-Apr-22	18:00	-
96	478	GETCO	400KV-SSP-DHULE-MS-1	Daily	PMM. Auto reclose of SSP -Dhule 2 will remain out.	11-Apr-22	8:00	11-Apr-22	18:00	Non auto reclose code for 400kv SSP-Dhule no-2 is to be required.
97	480	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	11-Apr-22	08:00	11-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
98	487	MSETCL	BOISAR II MH - TARAPUR ON TBC @ BOISAR II	Daily	CB Maintenance works by shifting line on TBC	11-Apr-22	09:00	11-Apr-22	17:00	CB Maintenance works by shifting line on TBC
99	488	MSETCL	220KV-WARDHA-BADNERA-1	Daily	For replacement of PT selection relay	11-Apr-22	09:00	11-Apr-22	17:00	.
100	495	APML-ADANI	TIE BAY - 400KV-TIRODA-WARORA-2 AND 400KV/11.5KV TIRODA-ST-2 at TIRODA - 400KV	Daily	408-52 Breaker Maintenance and testing	11-Apr-22	9:00	11-Apr-22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
101	505	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Cold washing work	11-Apr-22	08:00	12-Apr-22	18:00	Planned outage
102	514	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	11-Apr-22	09:00	16-Apr-22	17:00	---
103	515	MSETCL	400KV-KALWA-PADGHE-1	Daily	PID Testing Auto-Reclose function to be out of service.	11-Apr-22	09:00	16-Apr-22	18:00	PID Testing Auto-Reclose function to be out of service.
104	516	MSETCL	400KV/220KV AKOLA-ICT-2	Continuous	1)Internal inspection of ICT by Agency 2)Routine maintenance work 3) Testing work	11-Apr-22	10:00	19-Apr-22	18:00	Load will be shifted on ICT-1

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
105	527	POWERGRID_WRI	400KV-PARLI-SOLAPUR-2	D	Line side equipments AMP and relay testing works.	12-Apr-22	7:00	12-Apr-22	18:00	
106	528	GETCO	400KV-SSP-DHULE-MS-2	Daily	PMM. Auto reclose of SSP -Dhule 1 will remain out.	12-Apr-22	7:00	12-Apr-22	18:00	Non auto reclose code for 400kv SSP-Dhule no-1 is to be required.
107	538	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Daily	Routine Maintenance & Diagnostic testing work.	12-Apr-22	09:00	12-Apr-22	17:00	Line will be charged through Tie CB 428.
108	553	APML-ADANI	MAIN BAY - 400KV-TIRODA-WARORA-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	Daily	406-52 Breaker Maintenance and testing	12-Apr-22	9:00	12-Apr-22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
109	568	MSETCL	ALKUD - 400KV - BUS 1	Daily	Quarterly Maintenance work	12-Apr-22	10:00	13-Apr-22	17:00	Load will be managed on 400KV Main Bus - 2
110	569	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	12-Apr-22	08:00	14-Apr-22	18:00	NA
111	577	MSETCL	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	Daily	QM Work	13-Apr-22	09:00	13-Apr-22	18:00	QM Work
112	580	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	13-Apr-22	08:00	13-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
113	582	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	D	For taking LR out of service	13-Apr-22	7:00	13-Apr-22	7:30	
114	586	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	"Pre Monsoon Maintenance of Line & Bay Maintenance works"	13-Apr-22	07:00	13-Apr-22	19:00	"Pre Monsoon Maintenance of Line & Bay Maintenance works"
115	597	MSETCL	400KV-TAPTHITHANDA-EKTUNI-1	Daily	Stringing of OPGW cable. Quarterly maintenance work	13-Apr-22	08:00	13-Apr-22	19:00	Request from MTCIL received through mail dtd. 14.02.22
116	601	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	13-Apr-22	09:00	13-Apr-22	17:00	NA
117	615	APML-ADANI	TIE BAY - 400KV/11.5KV TIRODA-ST-1 AND 400KV-TIRODA-WARORA-1 at TIRODA - 400KV	Daily	405-52 Breaker Maintenance and testing	13-Apr-22	9:00	13-Apr-22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
118	620	MSETCL	220KV-PARLI-PARLI-M-2	Continuous	LINE maintenance	13-Apr-22	09:30	13-Apr-22	17:30	-
119	626	MSETCL	220KV-AURANGABAD-CHITEGAON-2	Daily	Battery replacement of Distance protection relay	13-Apr-22	10:00	13-Apr-22	19:00	Indication of battery weak is observed on relay display hence need to be replaced
120	630	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	D	For taking LR into service	13-Apr-22	17:30	13-Apr-22	18:00	
121	631	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Cold washing work	13-Apr-22	08:00	14-Apr-22	18:00	Planned outage
122	644	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	14-Apr-22	08:00	14-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
123	655	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	Chemical cleaning of insulator strings, DT and Line maintenance.	14-Apr-22	08:00	14-Apr-22	18:00	---
124	656	MSETCL	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	14-Apr-22	08:00	14-Apr-22	18:00	--
125	659	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work.	14-Apr-22	09:00	14-Apr-22	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
126	663	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-JCT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay equipment	14-Apr-22	09:00	14-Apr-22	18:00	Annual Maintenance of Bay equipment
127	674	MSETCL	MAIN BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND LONIKHAND-II - 400KV - BUS 2 at LONIKHAND-II - 400KV	Daily	PID Testing work(Element will be in service)	14-Apr-22	08:00	15-Apr-22	18:00	Element will be in service

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
128	677	MSETCL	TIE BAY- 402 OF 400/220/33 KV 500 MVA ICT - 1 AND PARLI @ LAMBOTI (Element not found in WRLDC Software)	Daily	PID Testing work(Element will be in service)	14-Apr-22	10:00	15-Apr-22	18:00	Element will be in service
129	678	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintenance Work	14-Apr-22	07:00	16-Apr-22	18:00	.
130	694	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	15-Apr-22	08:00	15-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
131	695	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	15-Apr-22	08:00	15-Apr-22	18:00	NA
132	698	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	Routine Line maintenance work	15-Apr-22	09:00	15-Apr-22	17:00	400kV Padghe-II will be in in service
133	699	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	Daily	Routine Maintenance & Diagnostic testing work.	15-Apr-22	09:00	15-Apr-22	17:00	Line will be charged through Main CB 429.
134	701	APML-ADANI	MAIN BAY - 400KV/11.5KV TIRODA-ST-1 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	Daily	404-52 Breaker Maintenance and testing	15-Apr-22	9:00	15-Apr-22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
135	702	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	1) Bay maintenance work 2) Replacement of 29C Bus PG Isolator under LES scheme 3) MTAMC work	15-Apr-22	09:00	15-Apr-22	21:00	1) Agency will be present on site for the work
136	708	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	To carry out PID for insulator strings.	15-Apr-22	08:00	24-Apr-22	18:00	---
137	710	RGPL	400KV Bus 2	C	Annual maintenance of bus side equipment, Suspension string replcement, Isolators PM and Earth switch replacement	15-Apr-22	9:00	18-Apr-22	18:00	
138	713	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	Isolator Servicing	16-Apr-22	9:00	16-Apr-22	17:30	PG-WR2-Boisar
139	718	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	Routine Line maintenance work, CT & CVT Tan Delta, Quarterly Bay Maintenance Work	16-Apr-22	09:00	16-Apr-22	17:00	400kV Padghe-II will be in in service
140	719	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For AMP Work	16-Apr-22	9:00	16-Apr-22	18:00	
141	726	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	16-Apr-22	08:00	16-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
142	729	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	Pre Monsoon Maintenance of Line	16-Apr-22	09:00	16-Apr-22	17:00	Pre Monsoon Maintenance of Line
143	738	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance, Relay Testing.	16-Apr-22	10:00	16-Apr-22	18:00	---
144	742	MSETCL	BOISAR-M - 220KV - BUS 2	Continuous	Bus Maintenance works	16-Apr-22	07:00	17-Apr-22	19:00	Bus Maintenance works
145	746	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	To Off / Out Auto Reclose at Both Ends For Carrying PID Work on	16-Apr-22	08:00	30-Apr-22	18:00	-
146	756	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	17-Apr-22	08:00	17-Apr-22	18:00	NA
147	761	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Chemical cleaning of insulator strings, DT and Line maintenance.	17-Apr-22	08:00	17-Apr-22	18:00	---
148	762	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	Pre Monsoon Maintenance of Line	17-Apr-22	09:00	17-Apr-22	17:00	Pre Monsoon Maintenance of Line
149	763	MSETCL	BOISAR II - BOISAR (PG) CKT - 1 ON TBC @ BOISAR II END	Daily	CB Maintenance works by shifting line on TBC	17-Apr-22	09:00	17-Apr-22	17:00	CB Maintenance works by shifting line on TBC
150	764	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity. 2) Bay maintenance & testing work at 400KV RS Kalwa.	17-Apr-22	09:00	17-Apr-22	18:00	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity. 2) Bay maintenance & testing work at 400KV RS Kalwa.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
151	765	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	17-Apr-22	10:00	17-Apr-22	18:00	NA
152	766	MSETCL	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	17-Apr-22	09:00	17-Apr-22	17:00	Outages required on MAIN BAY (401) OF KALA CKT - 2 & Bay no 402 Tie bay simultaneously for line CT testing work.
153	767	MSETCL	MAIN BAY - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	17-Apr-22	09:00	17-Apr-22	17:00	Outages required on MAIN BAY (401) OF KALA CKT - 2 & Bay no 402 Tie bay simultaneously for line CT testing work.
154	777	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	18-Apr-22	08:00	18-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
155	805	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	18-Apr-22	10:00	18-Apr-22	18:00	NA
156	813	MSETCL	Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	Continuous	For Refurbishment & RTV Coating of AC Filter Air Core reactor through Expert Agency as per OEM M/s Trench Austria guidelines hence this work to be carried out on top priority to avoid Failure of Air Core Reactor	18-Apr-22	08:00	19-Apr-22	23:00	1. Both Pole will be in service without any Power restriction i.e. 1300 MW 2. Pole II Z3 AC Filter will be available
157	822	MSETCL	400KV-KALWA-PADGHE-2	Daily	PID Testing Auto-Reclose function to be out of service.	18-Apr-22	09:00	23-Apr-22	18:00	PID Testing Auto-Reclose function to be out of service.
158	829	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	19-Apr-22	08:00	20-Apr-22	18:00	Planned outage
159	834	NCA	SSP - DHULE-I	Daily	Pre-Monsoon maintenance & switchyard maintenance work	19-Apr-22	7:00	19-Apr-22	19:00	A/R swieth of Dhule-II is to be put on Non Auto
160	840	MSETCL	400KV-IEPL-KORADI-II-1	Daily	Line maintenance work	19-Apr-22	08:00	19-Apr-22	18:00	NA
161	841	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	19-Apr-22	08:00	19-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
162	849	MSETCL	TIE BAY OF 400KV-KALA-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	19-Apr-22	09:00	19-Apr-22	17:00	Outages required on MAIN BAY (404) OF KALA CKT - 1 & Bay no 405 Tie bay simultaneously for line CT testing work.
163	850	MSETCL	MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	19-Apr-22	09:00	19-Apr-22	17:00	Outages required on MAIN BAY (404) OF KALA CKT - 1 & Bay no 405 Tie bay simultaneously for line CT testing work.
164	855	MSETCL	400KV-PARLI-M-PARLI-2	Daily	Bay maintenance work.	19-Apr-22	09:00	19-Apr-22	18:00	-
165	856	MP_SLDC	220KV-PANDURNA-KALMESHVAR-1	D	FOR LINE MAINTENANCE WORK	19-Apr-22	9:00	19-Apr-22	18:00	
166	866	MSETCL	TIE BAY - 765KV-AKOLA (2)-EKTUNI-1 AND FUTURE at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	19-Apr-22	10:00	19-Apr-22	14:00	765kV Akola ckt-I will be in service through its Main 706 Bay & Main Bus-II
167	869	MSETCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	19-Apr-22	15:00	19-Apr-22	18:00	765kV Akola ckt-II will be in service through its TIE 702 Bay & Main Bus-I
168	873	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	Continuous	1) For replacement of old M-1 & M-2 distance relays, 86 master trip relays under MTAMC project. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	19-Apr-22	08:00	21-Apr-22	18:00	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1 & 2, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will not be available.
169	874	MSETCL	KOLHAPUR-MS - 400KV - BUS 1	Daily	PID testing work	19-Apr-22	09:00	23-Apr-22	18:00	Online Work
170	879	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	Relay testing work, Routine Maintenance & Diagnostic testing work etc.	20-Apr-22	08:00	20-Apr-22	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.
171	882	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Replacement of suspicious faulty string if found in PID testing.A/R switch of 400KV DHL-BBLR 2 to be on NonAuto mode	20-Apr-22	08:00	20-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 2 to be on NonAuto mode
172	886	MSETCL	400KV-TAPTHITHANDA-EKTUNI-2	Daily	Stringing of OPGW cable. Quarterly maint. work.	20-Apr-22	08:00	20-Apr-22	19:00	Request from MTCIL received through mail dtd. 14.02.22

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
173	892	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	20-Apr-22	09:00	20-Apr-22	17:00	NA
174	897	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	(1) Hardware Tightening & Fitting Work (2) Cold washing work	20-Apr-22	09:00	20-Apr-22	18:00	-
175	905	MSETCL	400KV-PADGHE-NAGOTHANE-1	Continuous	1) 29D Isolator replacement work under LES scheme(project work). 2) Nagothane -1 H/T require for 5hrs for removing IPS tube between 29D and 29C Isolator and after removing IPS tube line will be in service through TBC. 3) In case of any emergency for shifting of critical /loaded bay on TBC 400kV Nagothane -1 will be H/T. 4) After replacement of 29D isolator for re-connection of IPS tube Nagothane-1 required H/T for 5hrs.	20-Apr-22	09:00	20-Apr-22	19:00	1) Agency will be present on site for the work.
176	906	MSETCL	220KV-PARLI-OSMANABAD-M-1	Continuous	LINE maintenance	20-Apr-22	09:30	20-Apr-22	17:30	-
177	912	MSETCL	TIE BAY - 765KV-AKOLA (2)-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	20-Apr-22	10:00	20-Apr-22	14:00	765kV Akola ckt-II will be in service through its Main 703 Bay & Main Bus-II
178	916	MSETCL	TIE BAY - 765KV/400KV EKTUNI-CT-1 AND FUTURE at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	20-Apr-22	15:00	20-Apr-22	18:00	765/400kV 1500MVA ICT-I will be in service through its Main 710 Bay & Main Bus-II
179	917	MSETCL	Pole-2 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	Continuous	For Refurbishment & RTV Coating of AC Filter Air Core reactor through Expert Agency as per OEM M/s Trench Austria guidelines hence this work to be carried out on top priority to avoid Failure of Air Core Reactor	20-Apr-22	08:00	21-Apr-22	23:00	1. Both Pole will be in service without any Power restriction i.e. 1300 MW 2. Pole I Z3 AC Filter will be available
180	922	MSETCL	MAIN BAY OF 400KV-RGPPL-NEW KOYNA-2 AND NEW KOYNA - 400KV - BUS 1 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	Continuous	C.B. Overhauling work shifting TBC	20-Apr-22	08:00	25-Apr-22	18:00	If the outage not approved for line works then the work of C.B. Overhauling work will be avaiile by taking on TBC from 20.04.2022 to 25.04.2022
181	925	MSETCL	400KV-RGPPL-NEW KOYNA-2	Continuous	Hill cutting work & stay erection Excavation work for tower loc. No.94 & Cold washing work & Diagnostic testing & Relay testing work & C.B. Overhauling work shifting TBC	20-Apr-22	08:00	30-Apr-22	18:00	If the outage not approved for line works then the work of C.B. Overhauling work will be avaiile by taking on TBC from 20.04.2022 to 25.04.2022
182	926	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	21-Apr-22	09:00	25-Apr-22	17:00	---
183	927	MSETCL	400KV-RGPPL-NAGOTHANE-2	Continuous	cold washing and jumper tighting work	21-Apr-22	08:00	21-Apr-22	17:00	NA
184	936	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintenance Work	21-Apr-22	07:00	21-Apr-22	18:00	.
185	937	NCA	SSP - DHULE-II	Daily	Pre-Monsoon maintenance & switchyard maintenance work	21-Apr-22	7:00	21-Apr-22	19:00	A/R swicth of Dhule-I is to be put on Non Auto
186	939	POWERGRID_WRI	400KV-TARAPUR 3&4-PADGHE-1	D	AMP OF 400 KV Padghe Tarapur-1 Line Equipment/ CT Replacement at Padghe MSETCL SS.	21-Apr-22	8:00	21-Apr-22	18:00	
187	940	MSETCL	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND FUTURE at LONIKHAND-II - 400KV	Daily	DT & Line Maintenance.	21-Apr-22	08:00	21-Apr-22	18:00	---
188	941	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	21-Apr-22	08:00	21-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
189	968	POWERGRID_WRI	KOLHAPUR GIS - 400KV B/R 1	C	For attending Oil leakage in CT secondary terminal connections plate at neutral side.	21-Apr-22	9:00	22-Apr-22	18:00	
190	969	MSETCL	TIE BAY (405) OF PGCIL & ICT - 2 @ LAMBOTI	Daily	PID Testing work	21-Apr-22	10:00	22-Apr-22	18:00	without load interruption
191	974	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	earth wire Replacement and jumper tightening work	22-Apr-22	08:00	22-Apr-22	17:00	NA
192	977	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of suspicious faulty string if found in PID testing.A/R switch of 400KV DHL-BBLR 1 to be kept on NonAuto mode.	22-Apr-22	08:00	22-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 1 to be kept on NonAuto mode.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
193	986	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	22-Apr-22	08:00	22-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
194	994	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	Routine Line maintenance work , Main-I & LBB relay Testing,Quarterly Bay Maintenance Work	22-Apr-22	09:00	22-Apr-22	17:00	400kV Padghe-I will be in service
195	1011	MSETCL	KHARGHAR - 400KV - BUS 1	Continuous	For Replacement of R & B phase Bus CVT and Bus maintenance work	22-Apr-22	08:00	23-Apr-22	18:00	400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.
196	1012	MSETCL	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	Continuous	For Replacement of R & B phase Bus CVT and Bus maintenance work	22-Apr-22	08:00	23-Apr-22	18:00	400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.
197	1013	MSETCL	Pole-1 Non base AC filter Z4 (80 MVAR) @Chandrapur HVDC	Continuous	For Refurbishment & RTV Coating of AC Filter Air Core reactor through Expert Agency as per OEM M/s Trench Austria guidelines hence this work to be carried out on top priority to avoid Failure of Air Core Reactor	22-Apr-22	08:00	23-Apr-22	23:00	1. Both Pole will be in service without any Power restriction i.e. 1300 MW 2. Pole II Z4 AC Filter will be available
198	1017	MSETCL	400KV-WARORA-CHANDRAPUR-II-1	Daily	Relay testing work,Routine Maintenance & Diagnostic testing work etc.	23-Apr-22	08:00	23-Apr-22	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 2 Bay no 416
199	1022	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	23-Apr-22	08:00	23-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
200	1026	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	Routine Line maintenance work, LBB Testing & MTAMC work, Quarterly Bay Maintenance Work	23-Apr-22	09:00	23-Apr-22	17:00	400kV Ektuni ckt II,400kV Aurangabad, Bhusawal, Dhule I&II will be in service
201	1029	MSETCL	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	Daily	Bay maintenance & testing work	23-Apr-22	09:00	23-Apr-22	18:00	Bay maintenance & testing work
202	1032	MSETCL	400KV-PADGHE-NAGOTHANE-1	Continuous	After replacement of 29D isolator for re-connection of IPS tube Nagothane-1 required H/T for 5hrs. After the completion of work line will be taken in service on its own bay	23-Apr-22	09:00	23-Apr-22	19:00	1) Agency will be present on site for the work.
203	1039	POWERGRID_WRI	400KV-KHARGHAR-PUNE-PG-1	D	For Line AMP and relay testing works.	24-Apr-22	9:00	24-Apr-22	18:00	
204	1042	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	"Diagnostic and R&M Work. MTAMC project related work"	24-Apr-22	08:00	24-Apr-22	18:00	NA
205	1043	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Chemical cleaning of insulator strings, DT and Line maintenance.	24-Apr-22	08:00	24-Apr-22	18:00	---
206	1045	MSETCL	BOISAR II - BOISAR (PG) CKT - 2 ON TBC @ BOISAR II END	Daily	CB Maintenance works by shifting line on TBC	24-Apr-22	09:00	24-Apr-22	17:00	CB Maintenance works by shifting line on TBC
207	1046	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	24-Apr-22	09:00	24-Apr-22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity
208	1047	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	"Pre Monsoon Maintenance of Line & Bay Maintenance works"	24-Apr-22	09:00	24-Apr-22	18:00	"Pre Monsoon Maintenance of Line & Bay Maintenance works"
209	1048	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	Diagnostic Testing & Routine Maintenance	24-Apr-22	09:30	24-Apr-22	18:00	765/400kV 1500MVA ICT-II will be in service
210	1052	POWERGRID_WRI	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work, AR to be kept in non Auto mode for 400kV Wardha-Akola-2	25-Apr-22	7:00	25-Apr-22	18:00	
211	1053	POWERGRID_WRI	400KV-WARDHA-AKOLA-2 (NON-AUTO)	Daily	For BHEL Insulator Replacement Work	25-Apr-22	7:00	25-Apr-22	18:00	
212	1056	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	25-Apr-22	08:00	25-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
213	1085	MSETCL	Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	Continuous	For Refurbishment & RTV Coating of AC Filter Air Core reactor through Expert Agency as per OEM M/s Trench Austria guidelines hence this work to be carried out on top priority to avoid Failure of Air Core Reactor	25-Apr-22	08:00	26-Apr-22	23:00	1. Both Pole will be in service without any Power restriction i.e. 1300 MW 2. Pole I Z4 AC Filter will be available
214	1090	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Online PID work	25-Apr-22	08:00	30-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 1 to be kept on NonAuto mode.
215	1091	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Online PID work	25-Apr-22	08:00	30-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 2 to be kept on NonAuto mode.
216	1092	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	25-Apr-22	09:00	30-Apr-22	17:00	---
217	1093	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	PID Testing Auto-Reclose function to be out of service.	25-Apr-22	09:00	30-Apr-22	18:00	PID Testing Auto-Reclose function to be out of service.
218	1094	MSETCL	KOLHAPUR-MS - 400KV - BUS 2	Daily	PID testing work	25-Apr-22	09:00	30-Apr-22	18:00	online work
219	1109	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	26-Apr-22	08:00	26-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
220	1116	POWERGRID_WR2	220KV-BOISAR-NALASOPARA-1	D	LTE AMP works. Line outage is required.	26-Apr-22	9:00	26-Apr-22	17:30	PG-WR2-Boisar
221	1120	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Diagnostic Testing & Routine Maintenance	26-Apr-22	09:30	26-Apr-22	18:00	765/400KV 1500MVA ICT-1 will be in service
222	1124	MSETCL	400KV-KARAD-JAIGAD-1	Daily	hot line insulator washing	26-Apr-22	09:00	27-Apr-22	18:00	AR to be disable
223	1125	MSETCL	400KV-KARAD-JAIGAD-2	Daily	hot line insulator washing	26-Apr-22	09:00	27-Apr-22	18:00	AR to be disable
224	1127	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	Continuous	1) For replacement of old M-1 & M-2 distance relays, 86 master trip relays under MTAMC project. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	26-Apr-22	08:00	28-Apr-22	18:00	During outage, outage 400KV CHANDRAPUR-1 - CHANDRAPUR-2 ckt. No.-1, 400KV Parli Ckt.-3, 400KV Chandrapur-Khaparkheda ckt., 400KV Chandrapur - PGCIL Bhadravati ckt. No.- 1, 2, 3 & 4 will be in service
225	1135	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work	27-Apr-22	7:00	27-Apr-22	18:00	
226	1136	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work, AR to be kept in non Auto mode for 400KV Wardha-Akola-1	27-Apr-22	7:00	27-Apr-22	18:00	
227	1143	MSETCL	BOISAR II - BOISAR (PG) CKT - 3 ON TBC @ BOISAR II END	Daily	CB Maintenance works by shifting line on TBC	27-Apr-22	09:00	27-Apr-22	17:00	CB Maintenance works by shifting line on TBC
228	1146	GETCO	220KV-NASIK-NAVSARI-1	Daily	Bay Maintance	27-Apr-22	9:00	27-Apr-22	18:00	
229	1153	MSETCL	220KV-PARLI-PARLI-M-2	Continuous	LINE maintenance	27-Apr-22	09:30	27-Apr-22	17:30	-
230	1158	MSETCL	KUMBARI - 220KV - BUS 2	Daily	An outage is required for Quarterly Maintenance	27-Apr-22	11:00	27-Apr-22	17:00	Quarterly Maintenance
231	1159	MSETCL	220KV-SOLAPUR-KUMBARI-2	Daily	An outage is required for Quarterly Maintenance	27-Apr-22	11:00	27-Apr-22	17:00	Quarterly Maintenance
232	1167	MSETCL	MAIN BAY OF 400KV/220KV NEW KOYNA-ICT-2 AND NEW KOYNA - 400KV - BUS 1 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	Continuous	C.B. Overhauling work Shitting on TBC	27-Apr-22	08:00	3-May-22	18:00	Planned outage

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
233	1173	MSETCL	400KV-PADGHE-NAGOTHANE-2	Continuous	1) Replacement of 29D isolator under LES scheme. 2) Nagothane -2 H/T require for 5hrs for removing IPS tube between 29D and 29C Isolator and after removing IPS tube line will be in service through TBC. 3) In case of any emergency for shifting of critical /loaded bay on TBC 400kV Nagothane -2 will be H/T. 4) After replacement of 29D isolator for re-connection of IPS tube Nagothane-2 required H/T for 5hrs.	28-Apr-22	09:00	28-Apr-22	19:00	1) Agency will be present on site for the work
234	1177	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintenance Work	28-Apr-22	07:00	28-Apr-22	18:00	.
235	1179	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	28-Apr-22	08:00	28-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
236	1180	MSETCL	400KV-KARIAT-LONIKHAND-II-1	Daily	Half yearly maintenance and diagnostic testing .	28-Apr-22	08:00	28-Apr-22	18:00	400kV Karjat ckt-II will remain charged.
237	1186	GETCO	220KV-NASIK-NAVSARI-2	Daily	Bay Maintance	28-Apr-22	9:00	28-Apr-22	18:00	
238	1187	MSETCL	400KV-JAIGAD-NEW KOYNA-1	Continuous	hot line insulator washing	28-Apr-22	09:00	28-Apr-22	18:00	AR to be disable
239	1188	MSETCL	400KV-JAIGAD-NEW KOYNA-2	Continuous	hot line insulator washing	28-Apr-22	09:00	28-Apr-22	18:00	AR to be disable
240	1192	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	Replacement of damaged disc insulator, corona ring, damaged nut bolts	28-Apr-22	09:30	28-Apr-22	18:00	400kV Ektuni-Bhabaleshwar ckt-I will be in service
241	1197	MSETCL	MAIN BAY OF 400KV-SOLAPUR-M-SOLAPUR-1 AND SOLAPUR-M - 400KV - BUS 2 @SOLAPUR-M - 400KV at SOLAPUR-M - 400KV	Daily	PID Testing work	28-Apr-22	10:00	30-Apr-22	18:00	without load interruption
242	1203	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	29-Apr-22	08:00	29-Apr-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
243	1207	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	Routine Line maintenance work	29-Apr-22	09:00	29-Apr-22	17:00	400kV Padghe-I will be in in service
244	1212	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	Replacement of damaged disc insulator, corona ring, damaged nut bolts	29-Apr-22	09:30	29-Apr-22	18:00	400kV Ektuni-Bhabaleshwar ckt-II will be in service
245	1214	MSETCL	CHANDRAPUR-GCR - 400KV - BUS 1	Daily	PID Testing of Disc Insulator strings. All elements will be in service.	29-Apr-22	08:00	30-Apr-22	18:00	Work will be executed in live condition.
246	1230	MSETCL	220KV-BOISAR-BOISAR-M-3	Daily	"Pre Monsoon Maintenance of Line & Bay Maintenance works"	30-Apr-22	07:00	30-Apr-22	19:00	"Pre Monsoon Maintenance of Line & Bay Maintenance works"
247	1233	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	30-Apr-22	08:00	30-Apr-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
248	1236	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	Routine Line maintenance work, LBB Testing & MTAMC work, Quarterly Bay Maintenance Work	30-Apr-22	09:00	30-Apr-22	17:00	400kV Ektuni ckt I,400kV Aurangabad, Bhusawal, Dhule I&II will be in in service
249	1241	MSETCL	400KV-PADGHE-NAGOTHANE-2	Continuous	After replacement of 29D isolator for re-connection of IPS tube Nagothane-2 required H/T for 5hrs. Line will be taken in service on its own bay after the work completion.	30-Apr-22	09:00	30-Apr-22	19:00	1) Agency will be present on site for the work

Maharashtra State Load Despatch Centre

List of outages not considered by WRLDC OCCM for the Month of APRIL' 2022

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks	OCC-Remarks
						Date	Time	Date	Time		
1	26	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	Continuous	To attend the sag corection in tower no. 534, to stop the deforming of tower members in the first section.	1-Apr-22	08:00	2-Apr-22	18:00	To attend the sag corection in tower no. 534, to stop the deforming of tower members in the first section.	may plan along with unit outage at Tirora/Amravati. SLDC MH comment pl? pl plan in june, Amravati consent is required. MH demand is in higher side
2	27	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	Continuous	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	1-Apr-22	08:00	2-Apr-22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	may plan along with unit outage at Tirora/Amravati. SLDC MH comment pl? pl plan in june, Amravati consent is required. MH demand is in higher side
3	28	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	Continuous	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-2 is crossing in between T.No. 534 & 535 of 765kV Line.	1-Apr-22	08:00	2-Apr-22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-2 is crossing in between T.No. 534 & 535 of 765kV Line.	may plan along with unit outage at Tirora/Amravati. SLDC MH comment pl? pl plan in june, Amravati consent is required. MH demand is in higher side
4	142	POWERGRID_WR1	400KV-WARDHA-WARORA-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	2-Apr-22	7:00	19-Apr-22	18:00		STU MSETCL NOC to be taken by PGCIL. Not consented by SLDC MH for April, May
5	143	POWERGRID_WR1	400kV IEPL-WARORA-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	2-Apr-22	7:00	19-Apr-22	18:00		STU MSETCL NOC to be taken by PGCIL. Not consented by SLDC MH for April, May
6	144	POWERGRID_WR1	400KV-WARDHA-WARORA-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	2-Apr-22	7:00	19-Apr-22	18:00	AC TRANSMISSION LINE CIRCUIT	STU MSETCL NOC to be taken by PGCIL. Not consented by SLDC MH for April, May
7	145	POWERGRID_WR1	400kV IEPL-WARORA-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	2-Apr-22	7:00	19-Apr-22	18:00	AC TRANSMISSION LINE CIRCUIT	STU MSETCL NOC to be taken by PGCIL. Not consented by SLDC MH for April, May
8	284	POWERGRID_WR1	400KV-WARORA-PG-PARLI-2	D	For AMP of line & terminal equipments in SS. Dia to be kept open for relay testing at Parli SS. A/R of 400kV Warora-Parli-1 to be in non Auto.	5-Apr-22	7:00	6-Apr-22	18:00		Deferred by site
9	352	POWERGRID_WR1	220KV-PUSAD-PGCIL DEOLI (MSETCL line) & 220KV-BHUGAON-PGCIL DEOLI (MSETCL line)	C	Loc. 03-04 POWERGRID Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	6-Apr-22	7:00	7-Apr-22	18:00		STU MSETCL NOC to be taken by PGCIL , pl plan in next month
10	353	POWERGRID_WR1	220KV-PUSAD-PGCIL DEOLI (MSETCL line) & 220KV-BHUGAON-PGCIL DEOLI (MSETCL line)	C	Loc. 03-04 POWERGRID Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	6-Apr-22	7:00	7-Apr-22	18:00	AC TRANSMISSION LINE CIRCUIT	STU MSETCL NOC to be taken by PGCIL
11	659	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	12-Apr-22	7:00	19-Apr-22	18:00		STU MSETCL NOC to be taken by PGCIL . Not consented by SLDC MH for April, May due to high demand
12	660	POWERGRID_WR1	400KV-IEPL-KORADI-II-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	12-Apr-22	7:00	19-Apr-22	18:00		STU MSETCL NOC to be taken by PGCIL . Not consented by SLDC MH for April, May
13	661	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	12-Apr-22	7:00	19-Apr-22	18:00	AC TRANSMISSION LINE CIRCUIT	STU MSETCL NOC to be taken by PGCIL . Not consented by SLDC MH for April, May
14	662	POWERGRID_WR1	400KV-IEPL-KORADI-II-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	12-Apr-22	7:00	19-Apr-22	18:00	AC TRANSMISSION LINE CIRCUIT	STU MSETCL NOC to be taken by PGCIL . Not consented by SLDC MH for April, May
15	183	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Maintenance work	4-Apr-22	09:00	4-Apr-22	18:00		repeated entry

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks	OCC-Remarks
						Date	Time	Date	Time		
16	481	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	C	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme	8-Apr-22	7:00	23-Apr-22	18:00		Facilitated in March 22
17	482	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-2	C	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme	8-Apr-22	7:00	23-Apr-22	18:00		Facilitated in March 22
18	812	POWERGRID_WR1	WARDHA - 400KV - BUS 1	D	Bus Splitting for series reactor charging and protection changes in existing 400kV Bus Bar#01 (essential part of series reactor commissioning)	16-Apr-22	6:00	17-Apr-22	18:00		Pl plan in next month due 765KV Wardha-Aurangabad-1&2 from 10april to 30 April.
19	1172	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work, AR to be kept in non Auto mode for 400KV Wardha-Akola-1	26-Apr-22	7:00	26-Apr-22	18:00		In view of 765KV Wardha-Aurangabad-1 2, pl plan after revival of lines.
20	1173	POWERGRID_WR1	400KV-WARDHA-AKOLA-1 (NON-AUTO)	Daily	For BHEL Insulator Replacement Work	26-Apr-22	7:00	26-Apr-22	18:00		In view of 765KV Wardha-Aurangabad-1 2, pl plan after revival of lines.
21	1200	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Online PID work	26-Apr-22	08:00	30-Apr-22	18:00	A/R switch of 400KV DHL-BBLR 2 to be kept on NonAuto mode.	repeat entry
22	1247	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work	28-Apr-22	7:00	28-Apr-22	18:00		In view of 765KV Wardha-Aurangabad-1 2, pl plan after revival of lines.
23	1248	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work, AR to be kept in non Auto mode for 400KV Wardha-Akola-2	28-Apr-22	7:00	28-Apr-22	18:00		In view of 765KV Wardha-Aurangabad-1 2, pl plan after revival of lines.

State Element List for the month of APRIL'2022

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 500 MVA ICT - 2 @ DHULE	1-Apr-22	08:00	1-Apr-22	18:00	Daily	Routine testing & Maint work.	MSETCL	MSETCL	Routine testing & Maint work.
2	400 KV	NEW KOYNA - STAGE IV CKT - 2	1-Apr-22	08:00	1-Apr-22	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
3	400 KV	JEJURI- KOYNA STAGE-IV	3-Apr-22	09:00	3-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
4	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	4-Apr-22	10:00	4-Apr-22	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	without load interruption.
5	400 KV	GT-10 @ KORADI-2	4-Apr-22	10:00	4-Apr-22	13:00	Daily	Tan delta measurement of Line CT	MSETCL	MSETCL	NOC will be required from Mahagenco
6	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	4-Apr-22	09:00	4-Apr-22	17:00	Daily	HV B/U relay testing, Bushing Tan Delta, Quarterly Bay Maintenance Work	MSETCL	MSETCL	105 MVA Spare ICT-1 is not in service
7	400 KV	AKOLA - KHADKA (BHUSAWAL)	4-Apr-22	08:00	9-Apr-22	18:00	Daily	String replacement work will be carried out on 400 kV Akola- Khadka (Bhusawal) line. Also work of tightening of Spacers cum Vibration Dampers,	MSETCL	MSETCL	Work will be carried out by agency.
8	400 KV	KARAD - LONIKAND I	5-Apr-22	09:00	6-Apr-22	18:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
9	400 KV	KARAD - TALANDGE CKT - 2	5-Apr-22	09:00	5-Apr-22	18:00	Daily	QM Work	MSETCL	MSETCL	QM Work
10	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	5-Apr-22	08:00	5-Apr-22	15:00	Daily	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	400KV Chandrapur2 - GCR ckt.- II will be in service
11	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	6-Apr-22	08:00	6-Apr-22	17:00	Daily	HV B/U relay testing , HV LBB, CB Timing & DCRM, Quarterly Bay Maintenance Work	MSETCL	MSETCL	167 MVA Spare ICT-2 is not in service
12	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	6-Apr-22	08:00	6-Apr-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
13	400 KV	GT - 6 @ KORADI-1	6-Apr-22	09:00	6-Apr-22	18:00	Daily	DCRM, CRM, CB TIMING	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
14	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	6-Apr-22	09:00	6-Apr-22	18:00	Daily	(1) Hardware tightening & fitting work. (2) Cold washing	MSETCL	MSETCL	-
15	400 KV	WARORA - IEPL	6-Apr-22	09:00	6-Apr-22	17:00	Daily	Routine Maintenance & Dignostic testing work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
16	400 KV	GT-9 @ KORADI-2	6-Apr-22	10:00	6-Apr-22	13:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 414 & 413	MSETCL	MSETCL	NOC will be required from Mahagenco
17	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	7-Apr-22	08:00	7-Apr-22	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400/220kV 501 MVA ICT-1 will remain charged.
18	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	7-Apr-22	09:00	7-Apr-22	17:00	Daily	MTAMC Work, Quarterly Bay Maintenance Work	MSETCL	MSETCL	ICT 1,2, 4 will be in service
19	400 KV	TBC @ KOLHAPUR(TALANDGE)	7-Apr-22	09:00	7-Apr-22	18:00	Daily	QM Work	MSETCL	MSETCL	QM Work
20	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	7-Apr-22	08:00	7-Apr-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work.	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
21	400 KV	JEJURI- KOYNA STAGE-IV	7-Apr-22	09:00	7-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
22	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	7-Apr-22	10:00	8-Apr-22	18:00	Continuous	1) Line maintenance work & replacement of PID faulty String 2) PG Isolator overhauling work	MSETCL	MSETCL	NA
23	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	7-Apr-22	10:00	7-Apr-22	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Switching Circuit -2 will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
24	400 KV	Akola II (Yelwan) - Akola I CKT - 1	7-Apr-22	10:00	7-Apr-22	17:00	Daily	Routine maintenance & testing Work	APTCL	APTCL	Yelwan ckt -02 will be in service
25	400 KV	KHADKA - BABLESHWAR	7-Apr-22	09:00	7-Apr-22	17:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad, Dhule I&II will be in service
26	400 KV	400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	8-Apr-22	08:00	8-Apr-22	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
27	400 KV	MAIN BAY-401 OF GT-10 @ KORADI-2	8-Apr-22	10:00	8-Apr-22	16:00	Daily	Diagnostic testing of CT & CB at bay 401	MSETCL	MSETCL	GT#10 will remain in service through Tie Bay 402
28	400 KV	NEW KOYNA-KARAD CKT - 1	8-Apr-22	08:00	8-Apr-22	18:00	Daily	Cold line washing work & PID Faulty disc insulator replacement work	MSETCL	MSETCL	Cold line washing work & PID Faulty disc insulator replacement work
29	400 KV	400/220/33 KV 500 MVA ICT - 3 @ DHULE	8-Apr-22	08:00	8-Apr-22	18:00	Daily	Routine Testing & Maint work and NDR relay retrofitting testing work	MSETCL	MSETCL	Routine Testing & Maint work and NDR relay retrofitting testing work
30	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	9-Apr-22	09:00	9-Apr-22	17:00	Daily	HV LBB relay testing ,CB Timing & DCRM, Quarterly Bay Maintenance Work	MSETCL	MSETCL	ICT 1, 3, 4 will be in service
31	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	9-Apr-22	09:00	9-Apr-22	17:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I&II will be in service
32	400 KV	JEJURI- KOYNA STAGE-IV	10-Apr-22	09:00	10-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
33	400 KV	80 MVAr BUS REACTOR - 1 @ BABHALESHWAR	11-Apr-22	08:00	11-Apr-22	17:00	Daily	Bushing Tan Delta, Winding resistance, Excitation current, Quarterly Bay Maintenance Work quarterly Bay Maintenance Work	MSETCL	MSETCL	Reactor is in OFF condition during day time due to Low voltage in system
34	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	11-Apr-22	08:00	16-Apr-22	18:00	Daily	String replacement work will be carried out on 400 kV Akola- Nandgaonpeth line. Also work of	MSETCL	MSETCL	Work will be carried out by agency.
35	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	11-Apr-22	10:00	13-Apr-22	18:00	Daily	PID Testing work	MSETCL	MSETCL	without load interruption
36	400 KV	MAIN BAY (417) OF IEPL @ WARORA	12-Apr-22	08:00	12-Apr-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work	MSETCL	MSETCL	Line will charged through tie bay no 418
37	400 KV	80 MVAr Bus reactor @ Talandge	12-Apr-22	09:00	12-Apr-22	18:00	Daily	QM Work	POWERGRID	POWERGRID	QM Work
38	400 KV	MAIN BAY (409) OF CHANDRAPUR GCR CKT - 2 @ CHANDRAPUR 2	12-Apr-22	08:00	12-Apr-22	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Line will be in service through Tie bay 408
39	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	12-Apr-22	08:00	12-Apr-22	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	---
40	400 KV	PADGHE - NAGOTHANE CKT - 1	12-Apr-22	08:00	12-Apr-22	17:00	Daily	earth wire Replacement and jumper tightening work	MSETCL	MSETCL	NA
41	400 KV	CHANDRAPUR - KHAPERKHEDA	12-Apr-22	08:00	12-Apr-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
42	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	12-Apr-22	09:00	12-Apr-22	18:00	Daily	(1) Hardware Tightening & Fitting Work (2) Cold washing work	MSETCL	MSETCL	-
43	400 KV	TIE BAY-402 OF GT-10 @ KORADI-2	13-Apr-22	10:00	13-Apr-22	16:00	Daily	Diagnostic testing of CT & CB at bay 402	MSETCL	MSETCL	GT#10 will remain in service through Main Bay 402
44	400 KV	125 MVAr BUS REACTOR @ TALANDGE	13-Apr-22	09:00	13-Apr-22	18:00	Daily	1. MOG of conservator tank replacement work. 2. QM Work	MSETCL	MSETCL	1. MOG of conservator tank replacement work. 2. QM Work
45	400 KV	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	13-Apr-22	08:00	13-Apr-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work.	MSETCL	MSETCL	Line equipment will charged through tie bay no 418
46	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	13-Apr-22	08:00	13-Apr-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
47	400 KV	PADGHE - NAGOTHANE CKT - 2	13-Apr-22	08:00	13-Apr-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
48	400 KV	400/220 125MVA BUS REACTOR @ LAMBOTI	13-Apr-22	10:00	13-Apr-22	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	without effecting voltage profile
49	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	13-Apr-22	09:00	13-Apr-22	18:00	Daily	(1) Main-2 distance relay testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
50	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	14-Apr-22	08:00	14-Apr-22	18:00	Daily	Half Yearly Bay Maintenance & DT work	MSETCL	MSETCL	---
51	400 KV	KHADKA - BABLESHWAR	14-Apr-22	09:00	14-Apr-22	17:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad, Dhule I&II will be in in service
52	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	14-Apr-22	09:30	14-Apr-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-2 & ICT-3 will be in service.
53	400 KV	JEJURI- KOYNA STAGE-IV	14-Apr-22	08:00	14-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
54	400 KV	400/220 KV 500MVA ICT - 4 @ KALWA	15-Apr-22	09:00	15-Apr-22	18:00	Daily	Bay maintenance & testing work	MSETCL	MSETCL	Bay maintenance & testing work
55	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	16-Apr-22	09:00	16-Apr-22	17:00	Daily	HV B/U relay testing , Quarterly Bay Maintenance Work	MSETCL	MSETCL	ICT 2, 3, 4 will be in service
56	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	16-Apr-22	09:00	16-Apr-22	17:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I&II will be in in service
57	400 KV	JAIGAD - NEW KOYNA CKT - 1	16-Apr-22	08:00	16-Apr-22	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	---
58	400 KV	JEJURI- KOYNA STAGE-IV	17-Apr-22	08:00	17-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
59	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	18-Apr-22	09:00	18-Apr-22	18:00	Daily	1. 33 kV IPOS tube & BPI Coating work 2. 400kV D isolator Male-Female contact replacement work	MSETCL	MSETCL	Pre-monsoon Maintenance work
60	400 KV	403 main bay of parli ckt at lamboti	18-Apr-22	10:00	20-Apr-22	18:00	Daily	PID Testing work	MSETCL	MSETCL	Without load interruption
61	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	19-Apr-22	08:00	19-Apr-22	18:00	Daily	For MTAMC work and RM Work	MSETCL	MSETCL	NA
62	400 KV	GT-8 @ KORADI-2	19-Apr-22	10:00	19-Apr-22	13:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 425&426	MSETCL	MSETCL	NOC will be required from Mahagenco
63	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	19-Apr-22	08:00	19-Apr-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work.	MSETCL	MSETCL	Line equipment will charged through tie bay no 421.
64	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	20-Apr-22	10:00	20-Apr-22	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Without Load interruption. Load will be managed on 400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI
65	400 KV	STATION TF 8B @ CHANDRAPUR SWITCHING	20-Apr-22	08:00	20-Apr-22	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Station-8B will be in service through Tie bay
66	400 KV	MAIN BAY 416 OF STN TF 5A @ 400 KV KHAPARKHEDA 2	20-Apr-22	08:00	20-Apr-22	17:00	Daily	IR values of LA	MSETCL	MSETCL	NA
67	400 KV	MAIN BAY (407) OF ICT-1 @ KUDUS	20-Apr-22	09:00	20-Apr-22	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	MSETCL	Outages required on MAIN BAY (407) OF ICT- 1 & Bay no 408 Tie bay simultaneously for line ICT-1 Diagnostic testing work.
68	400 KV	TIE BAY (415) OF KORADI CKT - 2 & STN TF 5A @ KHAPERKHEDA	20-Apr-22	08:00	20-Apr-22	17:00	Daily	IR values of LA	MSETCL	MSETCL	NA
69	400 KV	TIE BAY OF (408) OF ICT-1 AND FUTURE CKT @ KUDUS	20-Apr-22	09:00	20-Apr-22	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	MSETCL	Outages required on MAIN BAY (407) OF ICT- 1 & Bay no 408 Tie bay simultaneously for line ICT-1
70	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	21-Apr-22	08:00	21-Apr-22	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400/220kV 501 MVA ICT-II will remain charge.
71	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	21-Apr-22	09:00	21-Apr-22	18:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
72	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	21-Apr-22	10:00	22-Apr-22	18:00	Continuous	Routine Line Maintenance work & PG Isolator overhauling work	MSETCL	MSETCL	PG iso. overhauling work will be carried out by M/S Bimco
73	400 KV	KHADKA - BABLESHWAR	21-Apr-22	09:00	21-Apr-22	17:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad, Dhule I&II will be in service
74	400 KV	TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	21-Apr-22	10:00	21-Apr-22	17:00	Daily	Routine maintenance & testing Work	APTCL	APTCL	Load will be shifted on Main Bay 417
75	400 KV	JEJURI- KOYNA STAGE-IV	21-Apr-22	09:00	21-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
76	400 KV	CHANDRAPUR-PARLI CKT-3	21-Apr-22	09:00	22-Apr-22	18:00	Daily	line maintainance	MSETCL	MSETCL	-
77	400 KV	KARAD - LONIKAND I	21-Apr-22	08:00	21-Apr-22	18:00	Daily	Chemical cleaning of insulator strings, DT and Line maintenance	MSETCL	MSETCL	---
78	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	21-Apr-22	09:30	21-Apr-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-1 & ICT-2 will be in service.
79	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	22-Apr-22	06:00	22-Apr-22	18:00	Daily	For Pre-Monsoon Maintenance work along with Bushing Tan delta testing work.	MSETCL	MSETCL	DURING OUTAGE LOAD WILL BE MANAGED ON ANOTHER 400/220/33 KV 500 MVA ICT NO. II.
80	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	23-Apr-22	08:00	23-Apr-22	18:00	Daily	Routine Testing & Maint work and for arresting oil leakage work.	MSETCL	MSETCL	Routine Testing & Maint work and for arresting oil leakage work.
81	400 KV	JEJURI- KOYNA STAGE-IV	24-Apr-22	08:00	24-Apr-22	18:00	Daily	Chemical washing & Cold line washing work	MSETCL	MSETCL	Chemical washing & Cold line washing work
82	400 KV	PADGHE - NAGOTHANE CKT - 1	25-Apr-22	08:00	25-Apr-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA
83	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	25-Apr-22	08:00	27-Apr-22	18:00	Daily	For replacement ofpolymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
84	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	25-Apr-22	09:00	25-Apr-22	18:00	Daily	(1) Winding resistance measurement ICT Units. (2) Bay maintenance work.	MSETCL	MSETCL	-
85	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	25-Apr-22	10:00	27-Apr-22	18:00	Daily	PID Testing work	MSETCL	MSETCL	Without Load interruption
86	400 KV	PADGHE - NAGOTHANE CKT - 2	26-Apr-22	08:00	26-Apr-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA
87	400 KV	MAIN BAY (417) OF CHANDRPUR CKT @ KHAPARKHEDA	27-Apr-22	08:00	27-Apr-22	17:00	Daily	Tan Delta & Capacitance of CTs	MSETCL	MSETCL	NA
88	400 KV	TIE BAY (418) OF CHANDRAPUR CKT & STATION TF - B @ KHAPARKHEDA	27-Apr-22	08:00	27-Apr-22	17:00	Daily	Tan Delta & Capacitance of CTs	MSETCL	MSETCL	NA
89	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	28-Apr-22	09:00	28-Apr-22	18:00	Daily	(1) HV breaker Testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
90	400 KV	KHADKA - BABLESHWAR	28-Apr-22	09:00	28-Apr-22	17:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad, Dhule I&II will be in service
91	400 KV	MAIN BAY (410) OF FUTURE BAY @ JEJURI	28-Apr-22	09:30	28-Apr-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	409 TIE Bay & 410 Hinjewadi Bay CB will be opened. 400/220/33kV ICT-3 will be in service through 408 Bay.
92	400 KV	TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI	28-Apr-22	09:30	28-Apr-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	409 TIE Bay & 410 Hinjewadi Bay CB will be opened. 400/220/33kV ICT-3 will be in service through 408 Bay.
93	400 KV	KARAD - LONIKAND I	28-Apr-22	09:00	28-Apr-22	18:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
95	400 KV	CHANDRAPUR-PARLI CKT-3	28-Apr-22	08:00	30-Apr-22	18:00	Daily	For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
96	400 KV	LONIKAND I -JEJURI	28-Apr-22	08:00	28-Apr-22	18:00	Daily	Half Yearly Bay Maintenance & DT work.	MSETCL	MSETCL	---

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
97	400 KV	LONIKAND I - KOYNA STAGE-IV	28-Apr-22	08:00	28-Apr-22	18:00	Daily	DT & Line Maintenance.	MSETCL	MSETCL	---
98	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	29-Apr-22	06:00	29-Apr-22	18:00	Daily	FOR PRE-MONSOON MAINTENACE ALONG WITH BUSHING TAN DELTA TESTING WORK.	MSETCL	MSETCL	DURING OUTAGE LOAD WILL BE MANAGE ON ANOTHER 400/220/33 KV 500 MVA ICT NO. 1.