

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of APRIL' 2024

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
1	29	PLANNED	OCC_577	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1. For Replacement of Flashover Disc 2. Fixing of Turbo Wind Bird Guard.	01/Apr/2024	09:00	01/Apr/2024	17:00	Outage
2	32	PLANNED	OCC_577	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	C	For attending SF6 gas leakage at Pune GIS and AMP works at Pune(T) end.	01/Apr/2024	06:00	03/Apr/2024	18:00	OUTAGE. Separate meeting will be proposed.
3	36	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/Apr/2024	08:00	03/Apr/2024	18:00	PID WORK
4	37	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. Line will be in service through TBC	01/Apr/2024	09:00	04/Apr/2024	18:00	400 KV Aurangabad will be in service through TBC
5	40	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	01/Apr/2024	05:00	06/Apr/2024	09:00	Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
6	41	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	01/Apr/2024	09:00	06/Apr/2024	18:00	PID testing of insulator A/R function required to be in non auto mode
7	44	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-JEJURI-KARAD-1	C	Replacement of complete Main 1 Main 2 Relay panel	01/Apr/2024	09:00	08/Apr/2024	17:00	New RP Panel will be received in the Last week of March 2024
8	45	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	C	Replacement of Main 1 main 2 Relay Panel by new one.	01/Apr/2024	09:00	08/Apr/2024	17:00	New RP Panel will be received in last week of March 2024
9	51	PLANNED	OCC_577	ATIL	400KV-TIRODA-WARORA-1	C	Additional Earthing Work. Only AR to be kept off. Line to be in service	01/Apr/2024	08:00	15/Apr/2024	18:00	AR IN NON AUTO
10	52	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	For PID testing.Only AR to be kept off. Line to be in service	01/Apr/2024	08:00	15/Apr/2024	18:00	AR out For PID testing
11	53	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing. AR in Non-auto mode.Line will be in service	01/Apr/2024	09:00	15/Apr/2024	17:00	AR in Non-auto mode.Line will be in service
12	62	PLANNED	OCC_577	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	D	For OPGW stringing under live line condition,A/R non auto required at both ends	01/Apr/2024	07:00	30/Apr/2024	18:00	PG-WR2-ULDC
13	70	PLANNED	OCC_577	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01/Apr/2024	07:00	30/Apr/2024	18:00	
14	71	PLANNED	OCC_577	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01/Apr/2024	07:00	30/Apr/2024	18:00	
15	74	PLANNED	OCC_577	ATIL	400KV-APL-MUNDRA-SAMI-1	D	OPGW REPLACEMENT WORK (Replacement of earthwire with OPGW). No outage is required. Work will be carried out online.	01/Apr/2024	07:30	30/Apr/2024	18:30	Auto reclosed mode off
16	75	PLANNED	OCC_577	ATIL	400KV-APL-MUNDRA-SAMI-2	D	OPGW REPLACEMENT WORK (Replacement of earthwire with OPGW). No outage is required. Work will be carried out online.	01/Apr/2024	07:30	30/Apr/2024	18:30	Auto reclosed mode off
17	77	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	01/Apr/2024	08:00	30/Apr/2024	18:00	AR disable
18	78	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	01/Apr/2024	08:00	30/Apr/2024	18:00	AR disable
19	79	PLANNED	OCC_577	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for replacement of insulator in live line method.	01/Apr/2024	08:00	30/Apr/2024	18:00	AR disable
20	80	PLANNED	OCC_577	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	01/Apr/2024	08:00	30/Apr/2024	18:00	AR disable
21	81	PLANNED	OCC_577	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for replacement of insulator in live line method.	01/Apr/2024	08:00	30/Apr/2024	18:00	AR disable
22	99	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-1	D	48F OPGW installation on Lonikand 2 -Karjat Ckt I . Only AR to be kept off. Line will be in service.	01/Apr/2024	08:00	30/Apr/2024	18:00	work is proposed by MTCIL
23	100	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	D	48F OPGW installation on Lonikand 2 -Karjat Ckt II	01/Apr/2024	08:00	30/Apr/2024	18:00	work is proposed by MTCIL
24	101	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2024	09:00	30/Apr/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
25	102	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2024	09:00	30/Apr/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
26	103	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2024	09:00	30/Apr/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
27	104	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2024	09:00	30/Apr/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
28	105	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2024	09:00	30/Apr/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
29	106	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2024	09:00	30/Apr/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
30	107	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work. Only AR to be kept off. Line to be in service	01/Apr/2024	09:00	30/Apr/2024	17:30	-
31	108	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work. Only AR to be kept off. Line to be in service	01/Apr/2024	09:00	30/Apr/2024	17:30	-
32	109	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID Testing Work. Only AR to be kept off. Line to be in service	01/Apr/2024	09:00	30/Apr/2024	18:00	PID Testing Work. Only AR to be kept off. Line to be in service
33	110	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID Testing Work. Only AR to be kept off. Line to be in service	01/Apr/2024	09:00	30/Apr/2024	18:00	Only AR to be kept off. Line to be in service
34	111	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID Testing Work. Only AR to be kept off. Line to be in service	01/Apr/2024	09:00	30/Apr/2024	18:00	-
35	112	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	A/R out of service for laying of new OPGW 48F by replacing earthwire by MTCIL.	01/Apr/2024	10:00	30/Apr/2024	18:00	NA
36	113	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	A/R out of service for laying of new OPGW 48F by replacing earthwire by MTCIL.	01/Apr/2024	10:00	30/Apr/2024	18:00	NA
37	114	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	01/Apr/2024	11:00	30/Apr/2024	15:00	For PID work

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
38	124	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	02/Apr/2024	07:00	02/Apr/2024	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
39	125	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARORA-PG-WARORA-2	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works	02/Apr/2024	07:00	02/Apr/2024	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL
40	140	PLANNED	OCC_577	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	02/Apr/2024	09:00	02/Apr/2024	17:30	Pune GIS Line_2 Line in service through the 408 TIE Bay
41	146	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-1	D	Flashover String replacement at Loc no.187 R Ph, Pilot String clamp fixing at Loc no. H1-Y Ph, 239 - Y & B Ph	02/Apr/2024	09:00	02/Apr/2024	17:00	220 kV PGCIL - Narangwadi Ckt II will be in service
42	147	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	02/Apr/2024	10:00	02/Apr/2024	12:00	Bay Outage
43	148	PLANNED	OCC_577	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	02/Apr/2024	15:00	02/Apr/2024	17:00	Bay Outage
44	151	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Cold Washing Work	02/Apr/2024	08:00	03/Apr/2024	18:00	---
45	156	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Old insulator replacement	02/Apr/2024	09:00	06/Apr/2024	18:00	Old insulator replacement work
46	157	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1.Diagnostic Testing Work 2.Replacement of all phase LA. 3. Replacement of Distance & Over Voltage Relay. 4.CB Mechanism Pole Overhauling Work. 5. A & B Bus PG Isolator Maintenance Work. 6.B Bus PG Isolator Replacement work under LES Scheme. 7.Replacement of 29 D Isolator Under LES Scheme. After removing IPS Tube Between 29 C & 29 D Isolator BBLR-2 line will be taken on TBC. 8.After Completion of work BBLR-2 line will required hand trip for 3 Hrs for reconnection of IPS Tube between 29C & 29D Isolator.	02/Apr/2024	09:30	07/Apr/2024	18:00	Weather Condition should be clear.
47	158	PLANNED	OCC_577	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.	02/Apr/2024	09:30	07/Apr/2024	18:30	1. Weather condition should be clear for Hot Line Work. 2. Hot Line Team will be present on site.
48	168	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	07/Apr/2024	07:00	07/Apr/2024	18:00	Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with
49	169	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARORA-PG-WARORA-2	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	07/Apr/2024	07:00	07/Apr/2024	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
50	170	PLANNED	OCC_577	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV B/R 1 at Wardha - 400KV	D	For Inspection of Breaker by OEM (CGL)	03/Apr/2024	07:00	03/Apr/2024	20:00	
51	208	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	03/Apr/2024	08:00	03/Apr/2024	18:00	Outage
52	209	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and cleaning	03/Apr/2024	09:00	03/Apr/2024	17:00	Load managed on 400kv lamboti-PGCIL line
53	210	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-2	D	Pilot String clamp fixing at Loc no.226 -R ph, H6-Y pH, H2-Y ph, 192- Y Ph	03/Apr/2024	09:00	03/Apr/2024	17:00	220 kV PGCIL - Narangwadi Ckt I will be in service
54	211	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	03/Apr/2024	09:00	03/Apr/2024	17:30	-
55	212	PLANNED	OCC_577	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	03/Apr/2024	09:00	03/Apr/2024	18:00	During 400KV Busbar Protection Relay testing works Outage , (1). 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking
56	213	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-SOLAPUR-KUMBARI-1	D	Outage is required for Quarterly Maintenance	03/Apr/2024	10:00	03/Apr/2024	17:00	Quarterly Maintenance
57	214	PLANNED	OCC_577	MSLDC_OUTAGE	KUMBARI - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	03/Apr/2024	11:00	03/Apr/2024	17:00	Quarterly Maintenance
58	223	PLANNED	OCC_577	MSLDC_OUTAGE	TIE BAY - 400KV/11.5KV KORADI-II-ST-1 AND FUTURE at KORADI-II - 400KV	C	Overhauling of Circuit breaker. Station Transformer-I will remain in service through Main bay 422	03/Apr/2024	09:00	09/Apr/2024	17:30	Station Transformer-I will remain in service through Main 422
59	259	PLANNED	OCC_577	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For AMP Work	04/Apr/2024	09:00	04/Apr/2024	17:30	Line Owned By MSETCL Trans
60	276	PLANNED	OCC_577	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Maintenance	04/Apr/2024	08:00	04/Apr/2024	18:00	-
61	277	PLANNED	OCC_577	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Maintenance	04/Apr/2024	08:00	04/Apr/2024	18:00	-
62	278	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	04/Apr/2024	08:00	04/Apr/2024	18:00	Outage
63	279	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	04/Apr/2024	10:00	04/Apr/2024	12:00	Bay Outage
64	280	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	04/Apr/2024	10:00	04/Apr/2024	13:00	Online work by Shifting on TBC
65	281	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	04/Apr/2024	14:00	04/Apr/2024	17:00	Online work by Shifting on TBC
66	282	PLANNED	OCC_577	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	04/Apr/2024	15:00	04/Apr/2024	17:00	Bay Outage
67	290	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Cold Washing Work	04/Apr/2024	08:00	05/Apr/2024	18:00	----
68	298	PLANNED	OCC_577	POWERGRID_WR2	400KV-KALA-KUDUS-2	D	Line Maintenance,A/R off of 400KV-KALA-KUDUS-1 is required.Dia to be kept open at both ends	23/Apr/2024	07:00	23/Apr/2024	17:30	PG-WR2- BOISAR
69	302	PLANNED	OCC_577	POWERGRID_WR1	AURANGABAD - 220KV - BUS 2	D	For AMP. All feeders after bus outage, will be Shifted on TBC one by one, for isolator Maintenance works.	05/Apr/2024	07:00	05/Apr/2024	18:00	220KV BUS_2

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
70	303	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Aerial Patrolling S/D defect and Annual defect Rectification Work. For Amp of Line Bay at Akola MSETCL	05/Apr/2024	07:00	05/Apr/2024	18:00	For Aerial Patrolling S/D defect and Annual defect Rectification Work
71	304	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	AR IN NON AUTO IN VIEW OF SHUTDOWN OF 400KV-WARDHA-AKOLA-2	05/Apr/2024	07:00	05/Apr/2024	18:00	For Aerial Patrolling S/D defect and Annual defect Rectification Work
72	310	PLANNED	OCC_577	WTPL	400KV-CHAKAN-PUNE-PG-1	D	Annual Maintenance	05/Apr/2024	08:00	05/Apr/2024	12:00	Outage
73	330	PLANNED	OCC_577	POWERGRID_WR1	765KV-WARDHA-RAIPUR-PS (DURG)-3	D	PRV,Buchholz,SOTF Modification works and Firmware upgradation works. Outage is required only Line Reactor. Line outage is proposed as per WR1DC.	05/Apr/2024	09:00	05/Apr/2024	14:00	721L
74	334	PLANNED	OCC_577	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	AMP works	05/Apr/2024	09:00	05/Apr/2024	17:30	PG-WR2- BOISAR
75	335	PLANNED	OCC_577	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	D	For AMP Work	05/Apr/2024	09:00	05/Apr/2024	17:30	Line Owned By MSETCL Trans
76	354	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage required for making 220k v half bus section dead for the work of hybrid pass bus sectionaliser work	05/Apr/2024	08:00	05/Apr/2024	20:00	Jumping work from 220kv bus sectionaliser to 220kv Main bus
77	360	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	C	Cold line washing, replacement of PID detected strings	05/Apr/2024	22:00	06/Apr/2024	06:00	-
78	362	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	05/Apr/2024	08:00	10/Apr/2024	18:00	PID WORK
79	377	PLANNED	OCC_577	WTPL	400KV-LONIKHAND-PUNE-PG-1	D	Annual Maintenance	06/Apr/2024	08:00	06/Apr/2024	16:00	Outage
80	378	PLANNED	OCC_577	WTPL	400KV-KALWA-PUNE-PG-1	D	AR disable for annual maintenance in 400kv lonikhand -Pune PG-1	06/Apr/2024	08:00	06/Apr/2024	16:00	AR disable
81	386	PLANNED	OCC_577	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AND KOLHAPUR-MS - 400KV - BUS 1 at KOLHAPUR-MS - 400KV	D	Bay AMP	06/Apr/2024	08:00	06/Apr/2024	18:00	Outage required on CB only. Line can be kept in service through TBC.
82	390	PLANNED	OCC_577	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-3 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP works	06/Apr/2024	09:00	06/Apr/2024	17:30	PG-WR2- BOISAR
83	402	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	To attend defects identified in patrolling & To replace PID faulty insulator string. Also, To replace normal type Disc Insulator string with Antifog PLRI at Junnar S/Dn with R&M Scheme.	06/Apr/2024	08:00	06/Apr/2024	18:00	400 KV BBLR-PDG CKT-1 will be available with A/R Enabled.
84	403	PLANNED	OCC_577	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	06/Apr/2024	10:00	06/Apr/2024	12:00	Bay Outage
85	404	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	Insulator string Cold washing	06/Apr/2024	16:00	06/Apr/2024	22:00	-
86	405	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	Hardware tightening and cleaning	06/Apr/2024	16:00	06/Apr/2024	22:00	load managed on 400kv parli-karjat ckt-2
87	406	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	C	1) For Erection of 3 nos. of Tower in between Loc no. 168-170 in r/o shifting/ height raising work for NHRCL. 2) The line will be shifted on ERS till erection and stringing of the conductor till 20.03.2024.	06/Apr/2024	22:00	07/Apr/2024	06:00	The Ine will be shifted on ERS till erection and stringing of the conductor till 20.03.2024.
88	409	PLANNED	OCC_577	WTPL	400KV-LONIKHAND-PUNE-PG-1	D	Annual Maintenance	07/Apr/2024	08:00	07/Apr/2024	16:00	Outage
89	410	PLANNED	OCC_577	WTPL	400KV-KALWA-PUNE-PG-1	D	AR disable for annual maintenance in 400kv lonikhand -Pune PG-1	07/Apr/2024	08:00	07/Apr/2024	18:00	AR disable
90	415	PLANNED	OCC_577	POWERGRID_WR1	PUNE-PG - 400KV - BUS 1	D	For AMP Work	07/Apr/2024	09:00	07/Apr/2024	18:00	
91	416	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in patrolling & To replace PID faulty insulator string. Also, To replace normal type Disc Insulator string with Antifog PLRI at Junnar S/Dn with R&M Scheme.	07/Apr/2024	08:00	07/Apr/2024	18:00	400 KV BBLR-PDG CKT-2 will be available with A/R Enabled.
92	417	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work	07/Apr/2024	08:00	07/Apr/2024	18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work
93	418	PLANNED	OCC_577	MSLDC_OUTAGE	BUS COUPLER BAY OF BOISAR-M - 220KV - BUS 1 AND BOISAR-M - 220KV - BUS 2 @BOISAR-M - 220KV at BOISAR-M - 220KV	D	CT & Breaker Diagnostic Testing.	07/Apr/2024	09:00	07/Apr/2024	13:00	CT & Breaker Diagnostic Testing.
94	419	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work. 4.Replacement of 29 C Bus PG Isolator under LES Scheme. 5.Replacement of all phase CT with new Ratio of 3000/1 A. 6. Replacement of Distance Relay & Over Voltage Relay	07/Apr/2024	09:30	07/Apr/2024	18:30	Weather condition should be clear.
95	420	PLANNED	OCC_577	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Changeover of R Ph Reactor with spare ph reactor (765 KV Akola -Ektuni Line-02 reactor) for Cable replacement of mechanical protection and CTs for Spare ph (Akola - Ektuni line-02 Reactor) at Ektuni.	07/Apr/2024	10:00	07/Apr/2024	18:00	Line Outage
96	424	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	1) For Erection of 3 nos. of Tower in between Loc no. 168-170 in r/o shifting/ height raising work for NHRCL. 2) The line will be shifted on ERS till erection and stringing of the conductor till 21.03.2024.	07/Apr/2024	22:00	08/Apr/2024	06:00	The Ine will be shifted on ERS till erection and stringing of the conductor till 21.03.2024.
97	449	PLANNED	OCC_577	APML	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	08/Apr/2024	09:00	08/Apr/2024	13:00	765KV B/R-1 WILL BE AVAILABLE THROUGH TIE BAY
98	456	PLANNED	OCC_577	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	AMP works	01/Apr/2024	05:00	06/Apr/2024	09:00	PG-WR2- BOISAR
99	473	PLANNED	OCC_577	APML	TIE BAY - 400KV/11.5KV TIRODA-ST-1 AND 400KV-TIRODA-WARORA-1 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	08/Apr/2024	14:00	08/Apr/2024	18:00	400KV/11.5KV ST-1 and 400KV Line-1 will be in service on main bay
100	474	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at Badnera S/s.	08/Apr/2024	09:00	08/Apr/2024	17:00	Outage
101	475	PLANNED	OCC_577	MSLDC_OUTAGE	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	D	Quarterly maintenance work	08/Apr/2024	09:00	08/Apr/2024	18:00	Load managed form 400kv Main Bus -1 & 2
102	476	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	08/Apr/2024	10:00	08/Apr/2024	12:00	Bay Outage

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continu us	Reason	From	To	Remarks	
103	477	PLANNED	OCC_577	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	08/Apr/2024	15:00	08/Apr/2024 17:00	Bay Outage
105	495	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work.ICT will be in service through TBC	08/Apr/2024	09:00	11/Apr/2024 18:00	400/220 KV ICT II HV will be in service through TBC
106	499	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	08/Apr/2024	09:00	13/Apr/2024 18:00	PID testing of insulator A/R function required to be in non auto mode
107	501	PLANNED	OCC_577	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	C	SF6 gas Leakage attending work in 7220Rph Gas compartment	08/Apr/2024	08:00	15/Apr/2024 18:00	OUTAGE
108	510	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	A/R out of service for Balance PID Work.	08/Apr/2024	08:00	20/Apr/2024 18:00	NA
109	535	PLANNED	OCC_577	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-2	D	FOR TAKING OIL SAMPLE FROM CT	09/Apr/2024	08:30	09/Apr/2024 11:30	FOR TAKING OIL SAMPLE FROM CT
110	536	PLANNED	OCC_577	APML	TIE BAY OF 765KV/21KV TIRODA-GT-5 AND 765KV-TIRODA-KORADI-III-1 @TIRODA - 765KV at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	09/Apr/2024	09:00	09/Apr/2024 13:00	GT-5 AND 765KV TIRODA-KORADI-III-1 WILL BE IN SERVICE ON MAIN BAY
111	548	PLANNED	OCC_577	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	For 400KV Wardha #1 Line Equipments AMP Work. 400KV-WARORA-PG-WARORA (MSETCL)-1 AR OFF	09/Apr/2024	09:00	09/Apr/2024 18:00	For 400KV Wardha #1 Line Equipments AMP Work. 400KV-WARORA-PG-WARORA (MSETCL)-1 AR OFF
112	553	PLANNED	OCC_577	APML	MAIN BAY - 400KV/11.5KV TIRODA-ST-4 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	09/Apr/2024	14:00	09/Apr/2024 18:00	ST-4 will be in service with main bay
113	554	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work .	09/Apr/2024	09:00	09/Apr/2024 17:00	400KV WARORA-IEPL Line is in ckt
114	559	PLANNED	OCC_577	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	To attend defects and cleaning of polluted insulator strings in Naneghat section.	09/Apr/2024	23:00	10/Apr/2024 06:00	CHANDRAPUR-PADGHE POLE 2 will be available.
115	562	PLANNED	OCC_577	MSLDC_OUTAGE	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	C	CB pole overhauling work;Back up relay testing	09/Apr/2024	09:00	12/Apr/2024 18:00	400 KV Main Bus I and II will be separated
116	563	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	09/Apr/2024	11:00	28/Apr/2024 15:00	For PID work
117	587	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3)String replacement work.	10/Apr/2024	08:00	10/Apr/2024 20:00	-
118	607	PLANNED	OCC_577	APML	TIE BAY OF 400KV/21KV TIRODA-GT-2 AND 400KV/11.5KV TIRODA-ST-4 @TIRODA - 400KV at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	10/Apr/2024	14:00	10/Apr/2024 18:00	400KV/11.5KV ST-4 and 400KV/21KV GT-2 will be in service on main bay
119	609	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	10/Apr/2024	08:00	10/Apr/2024 18:00	Outage
120	610	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	10/Apr/2024	09:00	10/Apr/2024 13:00	765KV-TIRODA-KORADI-III-2 LINE WILL BE IN SERVICE ON TIE BAY
121	611	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line / s/sMaintenance	10/Apr/2024	09:00	10/Apr/2024 17:30	-
122	612	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	10/Apr/2024	09:00	10/Apr/2024 18:00	The said work is very important
123	613	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	Routine Maint. Work	10/Apr/2024	09:00	10/Apr/2024 18:00	NA
124	614	PLANNED	OCC_577	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	Routine Maint. Work	10/Apr/2024	09:00	10/Apr/2024 18:00	NA
125	615	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	10/Apr/2024	10:00	10/Apr/2024 12:00	Bay Outage
126	616	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	D	Outage is required for Quarterly Maintenance	10/Apr/2024	10:00	10/Apr/2024 18:00	Quarterly Maintenance
127	617	PLANNED	OCC_577	MEGPTCL	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV at KORADI-I	D	DGA Test of Current Transformer at Koradi-III SS.	10/Apr/2024	15:00	10/Apr/2024 17:00	Bay Outage
128	620	PLANNED	OCC_577	POWERGRID_WR1	KOLHAPUR GIS - 400KV B/R 1	C	Turret CT oil leakage attending	10/Apr/2024	08:00	12/Apr/2024 18:00	125Mvar Bus Reactor
129	621	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 AND CHANDRAPUR-GCR - 400KV - BUS 1 @CHANDRAPUR-GCR - 400KV at CHANDRAPUR-GCR - 400KV	C	1.Maintenance of Circuit breaker. 2. Maintenance and alignment of PG-1 & PG-2 Isolator. 3. 400KV HVDC CKT-2 will be in service via TBC-2.	10/Apr/2024	06:00	12/Apr/2024 18:00	400KV HVDC CKT-2 will be in service via TBC-2.
130	622	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Insulator replacement work	10/Apr/2024	09:00	13/Apr/2024 18:00	Insulator replacement work
131	640	PLANNED	OCC_577	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	D	AMP of Line Equipment at MSETCL Kudus substation and Autoreclosure scheme checking at Padghe SS. AR IN NON AUTO MODE OF CKT#2	20/Apr/2024	09:00	20/Apr/2024 18:00	OUTAGE
132	644	PLANNED	OCC_577	APML	TIE BAY OF 400KV/21KV TIRODA-GT-3 AND FUTURE @TIRODA - 400KV at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	11/Apr/2024	14:00	11/Apr/2024 18:00	GT-3 will be in service on MAIN bay
133	645	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	11/Apr/2024	08:00	11/Apr/2024 18:00	Outage
134	646	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	In view of outage on 400 KV Dhule Ckt I for Line Maintenance work. Only AR will be in Non Auto.Line will be in service.	11/Apr/2024	08:00	11/Apr/2024 18:00	Only AR will be in Non Auto.Line will be in service.
135	647	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line Maintenance work;Distance main I and II relay testing	11/Apr/2024	08:00	11/Apr/2024 18:00	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule II will be in service
136	648	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	11/Apr/2024	09:00	11/Apr/2024 13:00	765KV-TIRODA-KORADI-III-1 LINE WILL BE IN SERVICE ON TIE BAY
137	649	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening and cleaning	11/Apr/2024	09:00	11/Apr/2024 17:00	load managed on 400kv lamboti-parli line
138	650	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	11/Apr/2024	09:00	11/Apr/2024 17:00	400 KV WARORA - DEOLI 2 Line is in ckt
139	651	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	11/Apr/2024	10:00	11/Apr/2024 13:00	Online work by Shifting on TBC
140	652	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	11/Apr/2024	14:00	11/Apr/2024 17:00	Online work by Shifting on TBC

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line /Element OCC_571	Daily / Continuous	Reason	From	To	Remarks	
141	662	PLANNED	OCC_577	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	A/R TO BE KEPT IN NON-AUTO MODE IN VIEW OF OUTAGE OF 765KV-AURANGABAD-PADGHE-PG-2.	19/Apr/2024	08:00	25/Apr/2024 18:00	AR NON AUTO MODE
142	689	PLANNED	OCC_577	APML	MAIN BAY OF 765KV/21KV TIRODA-GT-5 AND TIRODA - 765KV - BUS 1 @TIRODA - 765KV at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	12/Apr/2024	09:00	12/Apr/2024 13:00	GT-5 will be in service on TIE bay
143	691	PLANNED	OCC_577	GETCO	220KV-NASIK-NAVSARI-2	D	Routine bay maintenance	12/Apr/2024	09:00	12/Apr/2024 17:00	
144	705	PLANNED	OCC_577	POWERGRID_WR1	400KV-KALA-KUDUS-1	D	AMP of 404L at MSETCL Kudos Substation. 400KV-KALA-KUDUS-2 A/R to be kept in Non-Auto mode.	20/Apr/2024	09:00	20/Apr/2024 18:00	OUTAGE
145	710	PLANNED	OCC_577	APML	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	12/Apr/2024	14:00	12/Apr/2024 18:00	ICT-1 will be in service on TIE bay
146	712	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	220KV PGCIL - Borivali Line outage is required for safety purpose during Damaged Conductor replacement of 220KV Tarapur - Borivali at Loc. No. 76-77.	12/Apr/2024	04:00	12/Apr/2024 09:00	220KV PGCIL - Borivali Line outage is required for safety purpose during Damaged Conductor replacement of 220KV Tarapur - Borivali at Loc. No. 76-77.
147	713	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Damaged Conductor replacement at Loc. No. 76-77.	12/Apr/2024	04:00	12/Apr/2024 09:00	220KV PGCIL - Borivali Line outage is required for safety purpose.
148	714	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	In view of outage on 400 KV Dhule Ckt 2 for Line maintenance work. Only AR will be in Non Auto.Line will be in service.	12/Apr/2024	08:00	12/Apr/2024 18:00	Only AR will be in Non Auto.Line will be in service.
149	715	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance work	12/Apr/2024	08:00	12/Apr/2024 18:00	400KV Ektuni ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule I will be in service
150	716	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage required for making 220k v half bus section dead for the work of hybrid pass bus sectionaliser work	12/Apr/2024	08:00	12/Apr/2024 20:00	Jumping work from 220kV bus sectionaliser to 220kV Main bus
151	717	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	12/Apr/2024	09:00	12/Apr/2024 17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
152	718	PLANNED	OCC_577	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	12/Apr/2024	10:00	12/Apr/2024 12:00	Bay Outage
153	719	PLANNED	OCC_577	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	DGA Test of Current Transformer at Koradi-III SS.	12/Apr/2024	15:00	12/Apr/2024 17:00	Bay Outage
154	723	PLANNED	OCC_577	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator of Kalwa-1 by hot line method. 2. All feeders on B Bus will be in service.	12/Apr/2024	09:30	16/Apr/2024 17:00	Weather condition should be clear for hot line work. Hot line team will be present on site
155	724	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 400KV-KALWA-PADGHE-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	C	1.B Bus PG Isolator replacement work under LES Scheme. 2. 400KV Kalwa-I in service through TBC.	12/Apr/2024	09:30	16/Apr/2024 20:00	Weather condition should be clear.
156	725	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	12/Apr/2024	08:00	17/Apr/2024 18:00	PID WORK
157	732	PLANNED	OCC_577	WTPL	400KV-KALWA-PUNE-PG-1	D	Annual Maintenance	13/Apr/2024	08:00	13/Apr/2024 16:00	Outage
158	733	PLANNED	OCC_577	WTPL	400KV-LONIKHAND-PUNE-PG-1	D	AR disable for annual maintenance in 400KV kalwa - Pune PG-1	13/Apr/2024	08:00	13/Apr/2024 16:00	AR disable
159	740	PLANNED	OCC_577	GETCO	220KV-NASIK-NAVSARI-1	D	Routine bay maintenance	13/Apr/2024	09:00	13/Apr/2024 17:00	
160	753	PLANNED	OCC_577	APML	TIE BAY - 400KV/11.5KV TIRODA-ST-3 AND 400KV/11.5KV TIRODA-ST-5 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	13/Apr/2024	14:00	13/Apr/2024 18:00	400KV/11.5KV ST-3 and 400KV/11.5KV ST-5 will be in service on main bay
161	754	PLANNED	OCC_577	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	D	220KV B-Bus Isolator R/M Works. During the outage, all Elements / Lines will be in service through 220KV A-Bus.	13/Apr/2024	06:00	13/Apr/2024 20:00	220KV B-Bus connected line/equipment: Bsr2-PGCIL 1 Line :570A/ 210MW Bsr2-PGCIL 3 Line :694A/ 248MW Bsr2-Ghodb Line: 517A/ 173MW Bsr2,Versnva Line: 203A/ 62MW
162	755	PLANNED	OCC_577	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	D	Work of Broken Strands repairing of OPGW of 500 KV Chandrapur-Padghe HVDC Line POLE 1 at Span loc 88-89 & Span loc 97-98 of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur	13/Apr/2024	06:00	13/Apr/2024 23:00	Work of Broken Strands repairing of OPGW of 500 KV Chandrapur-Padghe HVDC Line POLE 1 at Span loc 88-89 & Span loc 97-98 of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur
163	756	PLANNED	OCC_577	MSLDC_OUTAGE	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND FUTURE at CHANDRAPUR-II - 400KV	D	Diagnostic testing and allied bay Maintenance work	13/Apr/2024	08:00	13/Apr/2024 15:00	Diagnostic testing and allied bay Maintenance work
164	757	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work	13/Apr/2024	08:00	13/Apr/2024 18:00	400KV Padghe II will be in in service
165	758	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in patrolling & To replace PID faulty insulator string. Also, To replace normal type Disc Insulator string with Antifog PLRI at Junnar S/Dn with R&M Scheme.	13/Apr/2024	08:00	13/Apr/2024 18:00	400 KV 8BLR-PDG CKT-2 will be available with A/R Enabled.
166	759	PLANNED	OCC_577	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Bus CVT tan D testing	13/Apr/2024	08:00	13/Apr/2024 18:00	All feeders and ICT on Main Bus II will be shifted on Main Bus I through TBC
167	760	PLANNED	OCC_577	MEGPTCL	TIE BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV B/R 1 at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	13/Apr/2024	09:00	13/Apr/2024 13:00	765KV B/R-1 AND 765KV TIRODA-KORADI-III-2 WILL BE IN SERVICE ON MAIN BAY
168	761	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Diagnostic Testing of Line CT	13/Apr/2024	09:00	13/Apr/2024 17:30	400KV Koradi-II-IEPL Ckt. Will be service as alternate source
169	762	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	Hardware tightening and cleaning	21/Apr/2024	16:00	21/Apr/2024 22:00	load managed on 400kv parli-karjat ckt 1
170	768	PLANNED	OCC_577	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	D	Work of Dismantling of bent tower as new inline tower is already erected of 500 KV Chandrapur-Padghe HVDC Line at Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur	14/Apr/2024	00:00	14/Apr/2024 23:59	Work of Dismantling of bent tower as new inline tower is already erected of 500 KV Chandrapur-Padghe HVDC Line at Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn.
171	769	PLANNED	OCC_577	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	D	Work of Dismantling of bent tower as new inline tower is already erected of 500 KV Chandrapur-Padghe HVDC Line at Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur	14/Apr/2024	00:00	14/Apr/2024 23:59	Work of Dismantling of bent tower as new inline tower is already erected of 500 KV Chandrapur-Padghe HVDC Line at Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur
172	770	PLANNED	OCC_577	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	D	220KV A-Bus Isolator R/M Works. 1) During the outage, all Elements / Lines will be in service through 220KV B-Bus. 2) Due to A-Bus Isolator alignment issue of 220KV PGCIL - Boisar Line No. 3, 220KV A-Bus outage is required prior to 220KV B-Bus.	14/Apr/2024	06:00	14/Apr/2024 20:00	220KV A-Bus connected line/equipment: Bsr2-PGCIL 2 Line :630A/ 239MW Bsr2-Viraj Line: 166A/ 46MW Bsr2-Tarapur Line: 95A/ 33MW Bsr2-Borivali Line: 473A/ 170MW 50MVA 220/33kV PTR1 : 66A/ 24MW
173	771	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work	21/Apr/2024	08:00	21/Apr/2024 18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
174	772	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	To attend defects identified in patrolling & To replace PID faulty insulator string. Also, To replace normal type Disc insulator string with Antifog PLRI at Junnar S/Dn with R&M Scheme.	20/Apr/2024	08:00	20/Apr/2024	18:00	400 KV BBLR-PDG CKT-1 will be available with A/R Enabled.
175	773	PLANNED	OCC_577	MSLDC_OUTAGE	KALWA - 400KV - BUS 1	D	PID testing	20/Apr/2024	08:00	20/Apr/2024	18:00	Work carried out through hot line method
176	774	PLANNED	OCC_577	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	D	Insulation Coating of 33KV Tertiary yard	14/Apr/2024	10:00	14/Apr/2024	18:00	ICT OUTAGE
177	775	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	CB pole overhauling work. 400 KV Padghe II will be in service through TBC	14/Apr/2024	09:00	17/Apr/2024	18:00	400 KV Padghe II will be in service through TBC
178	776	PLANNED	OCC_577	POWERGRID_WR2	400KV-KALA-KUDUS-1	D	Line Maintenance, A/R off of 400KV-KALA-KUDUS-2 is required.Dia to be kept open at both ends	20/Apr/2024	07:00	20/Apr/2024	17:30	PG-WR2- BOISAR
179	793	PLANNED	OCC_577	POWERGRID_WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI- 1	D	Line Bay AMP works & attending Shutdown nature defects.400KV-KOLHAPUR GIS-NARENDRA KUDGI-2 AR to be kept in Non-auto mode for safety in TLM works.	15/Apr/2024	08:00	15/Apr/2024	18:00	400KV-KOLHAPUR GIS-NARENDRA KUDGI-2 AR to be kept in Non-auto mode for safety in TLM works.
180	795	PLANNED	OCC_577	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS- SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Bay AMP Works	15/Apr/2024	08:00	15/Apr/2024	18:00	
181	797	PLANNED	OCC_577	APML	MAIN BAY OF 765KV/21KV TIRODA-GT-4 AND TIRODA - 765KV - BUS 1 @TIRODA - 765KV at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	15/Apr/2024	09:00	15/Apr/2024	13:00	GT-4 will be in service on Tie bay
182	818	PLANNED	OCC_577	APML	TIE BAY OF 400KV/21KV TIRODA-GT-1 AND 765KV/400KV TIRODA-ICT-1 @TIRODA - 400KV at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	15/Apr/2024	14:00	15/Apr/2024	18:00	765KV/400KV-ICT-1 and 400KV/21KV GT-1 will be in service on main bay
183	820	PLANNED	OCC_577	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI- III - 765KV	D	Annual Maintenance of CB at Koradi-III SS.	15/Apr/2024	08:00	15/Apr/2024	18:00	Bay Outage
184	821	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	15/Apr/2024	08:00	15/Apr/2024	18:00	NA
185	822	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	hot line washing	15/Apr/2024	08:00	15/Apr/2024	18:00	hot line unit
186	824	PLANNED	OCC_577	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	Routine Nut Bolt tightening & maintenance work	15/Apr/2024	10:00	15/Apr/2024	17:30	All feeders will remain in service through 400KV Main Bus-II
187	838	PLANNED	OCC_577	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	1. For attending the high CRM problem of CB by excuting the pole overhauling work. 2. Bay routine maintenance work	15/Apr/2024	06:00	20/Apr/2024	18:00	1. During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV PARLI CKT- 3, 400KV CHANDRAPUR-PGCIL Bhadrawati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will
188	839	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	15/Apr/2024	09:00	20/Apr/2024	18:00	PID testing of insulator A/R function required to be in non auto mode
189	841	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-1	D	for hotline washing work Only AR kept off. Line to be in service	15/Apr/2024	09:00	25/Apr/2024	18:00	for hotline washing work(jaigad-newkoyna ckt- 1 AR out)
190	842	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	for hotline washing work Only AR kept off. Line to be in service	15/Apr/2024	09:00	25/Apr/2024	18:00	for hotline washing work(jaigad-newkoyna ckt- 2 AR out)
191	848	PLANNED	OCC_577	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	SF6 gas Leakage attending work in 71368ph Gas compartment. AMP of Line Equipment & LR	19/Apr/2024	08:00	25/Apr/2024	18:00	OUTAGE
192	860	PLANNED	OCC_577	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	AMP, Dia to be kept open at both sides	16/Apr/2024	07:00	16/Apr/2024	21:00	PG-WR2- BOISAR
193	878	PLANNED	OCC_577	POWERGRID_WR1	TIE BAY - 400KV-PARLI-SOLAPUR-2 AND 400KV-KOLHAPUR-MS-SOLAPUR-1 at Solapur - 400KV	D	Bay AMP Works	16/Apr/2024	08:00	16/Apr/2024	18:00	
194	880	PLANNED	OCC_577	POWERGRID_WR1	220KV-PARLI-HARANGUL-1	D	FOR AMP WORK	16/Apr/2024	08:30	16/Apr/2024	18:00	FOR AMP WORK
195	881	PLANNED	OCC_577	APML	TIE BAY OF 765KV/21KV TIRODA-GT-4 AND 765KV/400KV TIRODA-ICT-1 @TIRODA - 765KV at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	16/Apr/2024	09:00	16/Apr/2024	13:00	765KV/400KV-ICT-1 and 765KV/21KV GT-4 will be in service on main bay
196	895	PLANNED	OCC_577	GETCO	220KV-TARAPUR 1&2-VAPI-1	D	PMIM work	16/Apr/2024	09:00	16/Apr/2024	18:00	
197	909	PLANNED	OCC_577	APML	TIE BAY - 400KV-TIRODA-WARORA-2 AND 400KV/11.5KV TIRODA-ST-2 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	16/Apr/2024	14:00	16/Apr/2024	18:00	400KV/11.5KV-ST-2 AND 400KV TIRODA- WARORA-2 WILL BE IN SERVICE ON MAIN BAY
198	910	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	16/Apr/2024	08:00	16/Apr/2024	18:00	NA
199	911	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	hot line washing.	16/Apr/2024	08:00	16/Apr/2024	18:00	hot line unit
200	913	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	16/Apr/2024	09:00	16/Apr/2024	17:00	Line will be charged through Tie CB 428.
201	914	PLANNED	OCC_577	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT tan delta & maintenance work	16/Apr/2024	09:00	16/Apr/2024	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. . 2) 400KV,125MVAR reactor kept off position during outage.
202	915	PLANNED	OCC_577	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	D	Overhauling of Circuit breaker	16/Apr/2024	10:00	16/Apr/2024	17:30	400KV Koradi-II -Wardha[PG] Ckt. will remain in service through Main Bay 412
203	919	PLANNED	OCC_577	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	To attend defects and cleaning of polluted insulator strings in Naneghat section	16/Apr/2024	23:00	17/Apr/2024	06:00	CHANDRAPUR-PADGHE POLE 1 will be available
204	925	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	AR disable for replacement of insulator in live line method.	16/Apr/2024	08:00	30/Apr/2024	18:00	AR disable
205	927	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	For PID testing. AR in Non-auto mode.Line will be in service	16/Apr/2024	08:00	30/Apr/2024	18:00	AR out For PID testing
206	928	PLANNED	OCC_577	ATIL	400KV-TIRODA-WARORA-2	D	Additional Earthing Work.AR in Non-auto mode.Line will be in service	16/Apr/2024	08:00	30/Apr/2024	18:00	AR IN NON AUTO
207	929	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing. AR in Non-auto mode.Line will be in service	16/Apr/2024	09:00	30/Apr/2024	17:00	Line will be in service

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
208	948	PLANNED	OCC_577	APML	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	17/Apr/2024	09:00	17/Apr/2024	13:00	ICT-1 will be in service on TIE bay
209	950	PLANNED	OCC_577	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	AMP works	17/Apr/2024	09:00	17/Apr/2024	17:30	PG-WR2- BOISAR
210	952	PLANNED	OCC_577	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	Line AMP works and CVT oil leakage arresting works.	17/Apr/2024	09:00	17/Apr/2024	17:30	Line Owned By MSETCL Trans
211	957	PLANNED	OCC_577	POWERGRID_WR1	MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	D	AMP of 404 bay at MSETCL Kudus	17/Apr/2024	09:00	17/Apr/2024	18:00	OUTAGE
212	965	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	17/Apr/2024	08:00	17/Apr/2024	18:00	Outage
213	966	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	17/Apr/2024	09:00	17/Apr/2024	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
214	967	PLANNED	OCC_577	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV B/R 1	D	Quarterly Maintenance work	17/Apr/2024	09:00	17/Apr/2024	18:00	Load affected nil
215	968	PLANNED	OCC_577	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	Routine Maint. Work	17/Apr/2024	09:00	17/Apr/2024	18:00	NA
216	976	PLANNED	OCC_577	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-1	C	Replacement of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS.	17/Apr/2024	09:00	19/Apr/2024	18:00	retrofitting of pantograph Isolator
217	1010	PLANNED	OCC_577	POWERGRID_WR2	MAIN BAY - 400KV-PADGHE-BOISAR-1 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	D	AMP works	18/Apr/2024	09:00	18/Apr/2024	17:30	PG-WR2- BOISAR
218	1020	PLANNED	OCC_577	POWERGRID_WR1	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	D	AMP of 402 bay at MSETCL Kudus	18/Apr/2024	09:00	18/Apr/2024	18:00	OUTAGE
219	1029	PLANNED	OCC_577	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Maintenance	18/Apr/2024	08:00	18/Apr/2024	18:00	-
220	1030	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARIAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II	D	Diagnostic testing and Maintenance	18/Apr/2024	08:00	18/Apr/2024	18:00	-
221	1031	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	18/Apr/2024	08:00	18/Apr/2024	18:00	Outage
222	1032	PLANNED	OCC_577	MEGPTCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	18/Apr/2024	09:00	18/Apr/2024	17:00	Line will be charged through Main CB 429.
223	1033	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line, s/s Maintenance	18/Apr/2024	09:00	18/Apr/2024	17:30	-
224	1034	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	18/Apr/2024	10:00	18/Apr/2024	13:00	Online work by Shifting on TBC
225	1035	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	18/Apr/2024	14:00	18/Apr/2024	17:00	Online work by Shifting on TBC
226	1036	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	(1) CT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work	18/Apr/2024	16:00	18/Apr/2024	22:00	-
227	1038	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	18/Apr/2024	08:00	19/Apr/2024	18:00	NA
228	1039	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	C	Cold line washing washing of insulator strings.	18/Apr/2024	22:00	19/Apr/2024	05:00	-
229	1041	PLANNED	OCC_577	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator of TBC by hot line method. 2. All feeders on B Bus will be in service.	18/Apr/2024	09:30	22/Apr/2024	17:00	Weather condition should be clear for hot line work. Hot line team will be present on site.
230	1042	PLANNED	OCC_577	MSLDC_OUTAGE	TBC BAY OF PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 @PADGHE - 400KV	C	1.B Bus PG Isolator replacement work under LES Scheme. 2. TBC Bay Will not be available during outage period.	18/Apr/2024	09:30	22/Apr/2024	18:30	Weather condition should be clear.
231	1062	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	19/Apr/2024	08:00	19/Apr/2024	18:00	Outage
232	1063	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	19/Apr/2024	08:00	19/Apr/2024	18:00	Outage
233	1083	PLANNED	OCC_577	POWERGRID_WR1	MAIN BAY - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	D	AMP of 401 bay at MSETCL Kudus	19/Apr/2024	09:00	19/Apr/2024	18:00	OUTAGE
234	1092	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	220KV Tarapur - Borivali Line outage required for safety purpose during String replacement due to Disc Insulator broken at Loc No. 107 Y-Ph PGCL side.	19/Apr/2024	05:00	19/Apr/2024	09:00	220KV Tarapur - Borivali Line outage required for safety purpose during String replacement due to Disc Insulator broken at Loc No. 107 Y-Ph PGCL side.
235	1093	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	String replacement due to Disc Insulator broken at Loc No. 107 Y-Ph PGCL side.	19/Apr/2024	05:00	19/Apr/2024	09:00	220KV Tarapur - Borivali Line outage required for safety purpose.
236	1094	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage required for making 220k v half bus section dead for the work of hybrid pass bus sectionaliser work	19/Apr/2024	08:00	19/Apr/2024	20:00	Jumping work from 220kV bus sectionaliser to 220kV Main bus
237	1095	PLANNED	OCC_577	MEGPTCL	765KV-TIRODA-KORADI-III-1	D	CT OIL SAMPLE COLLECTION FOR DGA	19/Apr/2024	09:00	19/Apr/2024	13:00	Metering CT oil sample collection to be done at Tiroda SS.
238	1096	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	Relay testing work & routine maintenance work.	19/Apr/2024	09:00	19/Apr/2024	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.
239	1098	PLANNED	OCC_577	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-3	C	Rapid Restoration Scheme work;DFRA/Quarterly bay maintenance work	19/Apr/2024	09:00	21/Apr/2024	18:00	315 MVA ICT I and II and 501 MVA ICT IV will be in service
240	1100	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	19/Apr/2024	08:00	24/Apr/2024	18:00	PID WORK
241	1107	PLANNED	OCC_577	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	D	Simultaneous outage of TIE BAY - 400KV-KHANDWA-DHULE-MS-1 , 400KV-KHANDWA-DHULE-MS-1 and 400KV/220KV KHANDWA-ICT-1 is required for LBB retrofitting work, Line Outage, Dia to be kept opened at both end, and Line-2 Auto Recloser Non-auto Mode	20/Apr/2024	07:00	20/Apr/2024	18:00	PG-WR2- Khandwa

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks		
242	1108	PLANNED	OCC_577	POWERGRID_WR2	400KV/220KV KHANDWA-ICT-1	D	Simultaneous outage of TIE BAY - 400KV-KHANDWA-DHULE-MS-1 , 400KV-KHANDWA-DHULE-MS-1 and 400KV/220KV KHANDWA-ICT-1 is required for LBB retrofitting work,Dia to be kept open at both sides	20/Apr/2024	07:00	20/Apr/2024	18:00	PG-WR2- Khandwa
243	1109	PLANNED	OCC_577	POWERGRID_WR2	765KV-JABALPUR-ORAI-2	D	FOR FIXING OF INSULATION SLEEVE at TP tower, Loc 324 in 765 kv Jabalpur-Orai C2. INSTALLATION OF PILOT IN FEW LOCATIONS. Dia to be kept open at	20/Apr/2024	07:00	20/Apr/2024	18:00	PG-WR2- SATNA/CHHATARPUR TLM/DAMOH TLM
244	1110	PLANNED	OCC_577	POWERGRID_WR2	765KV-JABALPUR-ORAI-1	D	A/R Non Auto of 765KV-JABALPUR-ORAI-1 is required for facilitating work in 765KV-JABALPUR-ORAI-2.	20/Apr/2024	07:00	20/Apr/2024	18:00	PG-WR2- SATNA/CHHATARPUR TLM
245	1111	PLANNED	OCC_577	POWERGRID_WR2	765KV-SATNA-ORAI-1	D	To Fix 4 Disc in a string of Loc. 238 and Other line Maintenance Work,Dia to be kept open at both ends	21/Apr/2024	07:00	21/Apr/2024	18:00	PG-WR2- SATNA/CHHATARPUR TLM
246	1112	PLANNED	OCC_577	POWERGRID_WR2	765KV-SATNA-GWALIOR-2	D	A/R Non Auto of 765KV-SATNA-GWALIOR-2 is required for facilitating work in 765KV-SATNA-ORAI-1.	21/Apr/2024	07:00	21/Apr/2024	18:00	PG-WR2- SATNA/CHHATARPUR TLM
247	1113	PLANNED	OCC_577	POWERGRID_WR2	765KV-GWALIOR-ORAI	D	A/R Non Auto of 765KV-GWALIOR-ORAI is required for facilitating work in 765KV-SATNA-ORAI-1.	21/Apr/2024	07:00	21/Apr/2024	18:00	PG-WR2- SATNA/CHHATARPUR TLM
248	1114	PLANNED	OCC_577	POWERGRID_WR2	400KV-VADODARA-PIRANA-2	D	FOR FIXING OF INSULATION SLEEVE AT TP TOWER, 400 KV VADODARA-PIRANA-1 TO BE KEPT IN NON AUTO MODE	20/Apr/2024	07:00	20/Apr/2024	18:00	PG-WR2- DEHGAM TLM
249	1115	PLANNED	OCC_577	POWERGRID_WR2	400KV-BINA-SHUJALPUR-1 L/R@ BINA - 400KV	D	for Shujalpur-1 switchable LR bay AMP work, Line reactor is switchable and will be out of service only. Dia will remain charged	20/Apr/2024	07:00	20/Apr/2024	18:00	PG-WR2- BINA
250	1116	PLANNED	OCC_577	POWERGRID_WR1	AURANGABAD - 400KV - BUS 2	D	For AMP	26/Apr/2024	07:00	26/Apr/2024	18:00	400KV BUS_2
251	1119	PLANNED	OCC_577	POWERGRID_WR2	220KV-BHILAD-VAPI-1	C	Simultaneous outage of 220KV Bus 1 and line for For busbar LBB relay retrofitting and testing	20/Apr/2024	08:00	20/Apr/2024	18:00	PG-WR2- VAPI
252	1120	PLANNED	OCC_577	POWERGRID_WR2	220KV-VAPI-MAGARWADA-1	C	Simultaneous outage of 220KV Bus 1 and line for For busbar LBB relay retrofitting and testing	20/Apr/2024	08:00	20/Apr/2024	18:00	PG-WR2- VAPI
253	1121	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	20/Apr/2024	08:00	20/Apr/2024	18:00	Outage
254	1122	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	20/Apr/2024	08:00	20/Apr/2024	18:00	Outage
255	1134	PLANNED	OCC_577	POWERGRID_WR2	400KV/220KV DEHGAM-ICT-3	D	For Backup Impedance relay Installation work. Dia to be kept open at both sides	20/Apr/2024	09:00	20/Apr/2024	18:00	PG-WR2- Dehgam
256	1137	PLANNED	OCC_577	POWERGRID_WR2	400KV-ITARSI-INDORE-MP-1	D	Simultaneous outage of MAIN BAY - 400KV-ITARSI-INDORE-MP-1 and 400KV-ITARSI-INDORE-MP-1 is required for joining Main Bay jumper after isolator replacement works	20/Apr/2024	09:00	20/Apr/2024	23:00	PG-WR2- ITARSI
257	1142	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	Insulator string Cold washing	20/Apr/2024	16:00	20/Apr/2024	22:00	-
258	1143	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	(1) CT & CVT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work	20/Apr/2024	16:00	20/Apr/2024	22:00	-
259	1144	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	1) CT & Breaker Diagnostic Testing. 2) Line Bay shifting at 220KV Boisar-II S/S. (From Bay No. 12 to Bay No. 14)	20/Apr/2024	07:00	20/Apr/2024	19:00	Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. After above work outage will be taken on 220kV PGCIL - Boisar Line No. 3 (Both outages Work carried out through hot line method
260	1145	PLANNED	OCC_577	MSLDC_OUTAGE	KALWA - 400KV - BUS 2	D	PID testing	20/Apr/2024	08:00	20/Apr/2024	18:00	220kV BUS_1
261	1146	PLANNED	OCC_577	MEGPTCL	765KV-TIRODA-KORADI-III-2	D	CT Oil Sample Collection for DGA	20/Apr/2024	09:00	20/Apr/2024	13:00	Metering CT Oil Sample Collection to be done at Tiroda SS.
262	1147	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	Hardware tightening and cleaning	20/Apr/2024	16:00	20/Apr/2024	22:00	Load managed on 400kv parli-karjat ckt-2
263	1149	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	C	Cold line washing work	20/Apr/2024	22:00	21/Apr/2024	06:00	-
264	1150	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	C	1) Restoration of the line through the newly erected 3 nos. of tower between loc no. 168-170 & dismantling of ERS.	20/Apr/2024	22:00	21/Apr/2024	06:00	1) Restoration of the line through the newly erected 3 nos. of tower between loc no. 168-170 & dismantling of ERS.
265	1151	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220KV Boisar-II S/S. (From Bay No. 13 to Bay No. 12)	20/Apr/2024	22:00	21/Apr/2024	22:00	Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.
266	1160	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	21/Apr/2024	08:00	21/Apr/2024	18:00	Outage
267	1165	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in patrolling & To replace PID faulty insulator string. Also, To replace normal type Disc Insulator string with Antifog PLRI at Junnar S/Dn with R&M Scheme.	21/Apr/2024	08:00	21/Apr/2024	18:00	400 KV BBLR-PDG CKT-2 will be available with A/R Enabled.
268	1166	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work	21/Apr/2024	08:00	21/Apr/2024	18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work
269	1167	PLANNED	OCC_577	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Cable Replacement of Bushing Cts for R, Y and B ph. Reactor at Akola SS.	21/Apr/2024	10:00	21/Apr/2024	18:00	Line Outage
270	1169	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	1) Restoration of the line through the newly erected 3 nos. of tower between loc no. 168-170 & dismantling of ERS.	21/Apr/2024	22:00	22/Apr/2024	06:00	1) Restoration of the line through the newly erected 3 nos. of tower between loc no. 168-170 & dismantling of ERS.
271	1171	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	21/Apr/2024	08:00	28/Apr/2024	18:00	Outage
272	1184	PLANNED	OCC_577	POWERGRID_WR1	AURANGABAD - 220KV - BUS 1	D	For AMP. All feeders after bus outage, will be Shifted on TBC one by one, for isolator Maintenance works.	22/Apr/2024	07:00	22/Apr/2024	18:00	220KV BUS_1
273	1185	PLANNED	OCC_577	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV B/R 1 at Wardha - 400KV	D	For Amp of Bay	22/Apr/2024	07:00	22/Apr/2024	20:00	
274	1197	PLANNED	OCC_577	POWERGRID_WR1	TIE BAY - 400KV-PARLI-M-PARLI-2 AND PARLI - 400KV B/R 2 at PARLI - 400KV	D	FOR AMP WORK	22/Apr/2024	08:30	22/Apr/2024	18:00	FOR AMP WORK
275	1209	PLANNED	OCC_577	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Annual Maintenance of ICT at Koradi-III SS.	22/Apr/2024	08:00	22/Apr/2024	18:00	ICT Outage
276	1210	PLANNED	OCC_577	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1. For Replacement of Flashover Disc. 2. Fixing of Turbo Wind Bird Guard.	22/Apr/2024	09:00	22/Apr/2024	17:00	Outage
277	1211	PLANNED	OCC_577	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	22/Apr/2024	09:00	22/Apr/2024	18:00	The said work is very important
278	1213	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	For carrying out routine maintenance work and defects observed during monkey patrolling works	22/Apr/2024	07:00	23/Apr/2024	18:00	Work to be done by AMC Agency

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continue as	Reason	From	To	Remarks		
279	1220	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-AURANGABAD-M (WALLUJ)-1 AND BABLESHWAR - 400KV - BUS 1	C	CB pole overhauling work Line to be in service through TBC	22/Apr/2024	09:00	25/Apr/2024	18:00	400 KV Aurangabad will be in service through TBC
280	1222	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCL (Dead Line). Outage required of 220kV PGCL - Boisar Line No. 1 for safety purpose only.	22/Apr/2024	05:00	27/Apr/2024	09:00	Outage required of 220kV PGCL - Boisar Line No. 1 for safety purpose only.
281	1223	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	22/Apr/2024	09:00	27/Apr/2024	18:00	PID testing of insulator A/R function required to be in non auto mode
282	1241	PLANNED	OCC_577	POWERGRID_WR1	WARDHA - 400KV - BUS 2	D	Erection of Bus earth switch 43389AE1 and its alignment (construction outage)	23/Apr/2024	07:00	23/Apr/2024	20:00	
283	1261	PLANNED	OCC_577	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP of 401L at MSETCL Kudus Substation. 400KV-KALA-KUDUS-1 A/R to be kept in Non-Auto mode.	23/Apr/2024	09:00	23/Apr/2024	18:00	OUTAGE
284	1266	PLANNED	OCC_577	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Testing of Metering CT & CVT of ICT-1 at Koradi-III SS.	23/Apr/2024	08:00	23/Apr/2024	18:00	ICT Outage
285	1270	PLANNED	OCC_577	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-2	C	Replacement of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS & CVT replacement at Bhadrawati end.	23/Apr/2024	09:00	25/Apr/2024	18:00	retrofitting of pantograph Isolator &
286	1281	PLANNED	OCC_577	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	For AMP	24/Apr/2024	07:00	24/Apr/2024	18:00	418
287	1291	PLANNED	OCC_577	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Winding Tan Delta, FDS, Moisture measurement of LR of 400KV-PADGHE-BOISAR-1	24/Apr/2024	08:00	24/Apr/2024	18:00	OUTAGE
288	1304	PLANNED	OCC_577	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Annual Maintenance of ICT at Koradi-III SS.	24/Apr/2024	08:00	24/Apr/2024	18:00	ICT Outage
289	1305	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	24/Apr/2024	08:00	24/Apr/2024	18:00	Outage
290	1306	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line, s/s Maintenance	24/Apr/2024	09:00	24/Apr/2024	17:30	-
291	1307	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	24/Apr/2024	09:00	24/Apr/2024	18:00	The said work is very important
292	1308	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Hardware tightening and cleaning	24/Apr/2024	09:00	24/Apr/2024	18:00	Load managed on 220kV jeur-tembhurni
293	1309	PLANNED	OCC_577	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	24/Apr/2024	09:00	24/Apr/2024	18:00	NA
294	1310	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-SOLAPUR-KUMBARI-2	D	Outage is required for Quarterly Maintenance	24/Apr/2024	10:00	24/Apr/2024	17:00	Quarterly Maintenance
295	1311	PLANNED	OCC_577	MSLDC_OUTAGE	KUMBARI - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	24/Apr/2024	11:00	24/Apr/2024	17:00	Quarterly Maintenance
296	1312	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-TAPHTHANDA-EKTUNI-2	D	For carrying out routine maintenance work and defects observed during monkey patrolling	24/Apr/2024	08:00	25/Apr/2024	18:00	Work to be attended by AMC Agency
297	1315	PLANNED	OCC_577	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1) Replacement of Hanger Assembly of A Bus All PG	24/Apr/2024	09:30	28/Apr/2024	17:00	Weather condition should be clear. Weather condition should be clear.
298	1316	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1)Replacement of A Bus All Phase PG Isolator under LES Scheme. 2) Line will be in service on TBC.	24/Apr/2024	09:30	28/Apr/2024	18:30	Weather condition should be clear.
299	1346	PLANNED	OCC_577	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Testing of Metering CT & CVT of ICT-2 at Koradi-III SS.	25/Apr/2024	08:00	25/Apr/2024	18:00	ICT Outage
300	1347	PLANNED	OCC_577	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot line method.	25/Apr/2024	09:00	25/Apr/2024	17:00	Hot Line Work
301	1348	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	25/Apr/2024	10:00	25/Apr/2024	13:00	Online work by Shifting on TBC
302	1349	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Routine maintenance and DT.	25/Apr/2024	10:00	25/Apr/2024	18:00	-
303	1350	PLANNED	OCC_577	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	25/Apr/2024	14:00	25/Apr/2024	17:00	Online work by Shifting on TBC.
304	1353	PLANNED	OCC_577	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	C	For attending SF6 gas leakage and AMP works at Pune(T) end.	25/Apr/2024	06:00	27/Apr/2024	18:00	For attending SF6 gas leakage and AMP works at Pune(T) end.
305	1354	PLANNED	OCC_577	MSLDC_OUTAGE	400KV/220KV WARORA-ICT-2	C	Relay testing work & routine maintenance work etc.	25/Apr/2024	09:00	27/Apr/2024	18:00	Presently both bay 407 and 406 in off condition.
306	1359	PLANNED	OCC_577	POWERGRID_WR1	AURANGABAD - 400KV - BUS 1	D	For AMP	26/Apr/2024	07:00	26/Apr/2024	18:00	400KV BUS_1
307	1365	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	26/Apr/2024	08:00	26/Apr/2024	18:00	Outage
308	1366	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	26/Apr/2024	08:00	26/Apr/2024	18:00	Outage
309	1387	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-AURANGABAD-CHITGAON-2	D	Outage required for making 220k v half bus section dead for the work of hybrid pass bus sectionaliser work	26/Apr/2024	08:00	26/Apr/2024	20:00	Jumping work from 220kV bus sectionaliser to 220kV Main bus
310	1398	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	26/Apr/2024	08:00	30/Apr/2024	18:00	PID WORK
311	1412	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	27/Apr/2024	08:00	27/Apr/2024	18:00	Outage
312	1413	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	27/Apr/2024	08:00	27/Apr/2024	18:00	Outage
313	1422	PLANNED	OCC_577	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	C	AMP WORKS of Line at both end	27/Apr/2024	09:00	27/Apr/2024	18:00	
316	1428	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in patrolling & To replace PID faulty insulator string. Also, To replace normal	27/Apr/2024	08:00	27/Apr/2024	18:00	400 KV BBLR-PDG CKT - 2 will be available with A/R Enabled.
317	1430	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	Cold line washing work	27/Apr/2024	22:00	28/Apr/2024	06:00	-
318	1435	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	28/Apr/2024	08:00	28/Apr/2024	18:00	Outage
319	1436	PLANNED	OCC_577	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	28/Apr/2024	08:00	28/Apr/2024	18:00	Outage
320	1441	PLANNED	OCC_577	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance work.	28/Apr/2024	08:00	28/Apr/2024	18:00	Bay maintenance work. .
321	1442	PLANNED	OCC_577	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work	28/Apr/2024	09:00	28/Apr/2024	18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work
322	1457	PLANNED	OCC_577	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	PRV NC contact modification	29/Apr/2024	08:00	29/Apr/2024	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
323	1467	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at Badnera S/s.	29/Apr/2024	09:00	29/Apr/2024	17:00	Outage
324	1468	PLANNED	OCC_577	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	29/Apr/2024	09:00	29/Apr/2024	18:00	The said work is very important
325	1488	PLANNED	OCC_577	POWERGRID_WR2	TBC BAY - BOISAR - 220KV - BUS 1 AND FUTURE at BOISAR - 220KV	D	AMP works	30/Apr/2024	9:00	30/Apr/2024	17:30	PG-WR2- BOISAR
326	1495	PLANNED	OCC_577	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot Line Method. Shifting of auto reclose switch to non auto	30/Apr/2024	09:00	30/Apr/2024	17:00	Hot Line Work

State Element outage list for the month of APRIL '2024

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	MAIN BAY (409) OF CHANDRAPUR GCR CKT - 2 @ CHANDRAPUR 2	01-Apr-24	08:00	01-Apr-24	16:00	Daily	Diagnostic testing and allied bay Maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay Maintenance work
2	400 KV	KARAD - TALANDGE CKT - 2	01-Apr-24	09:00	01-Apr-24	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Load will be managed from KARAD - TALANDGE CKT - 1
3	400 KV	NEW KOYNA - STAGE IV CKT - 1	01-Apr-24	08:00	01-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
4	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	01-Apr-24	09:00	30-Apr-24	18:00	Daily	PID Testing Work. Only AR to be kept off. Line to be in service	MSETCL	MSETCL	PID Testing Work. Only AR to be kept off. Line to be in service
5	400 KV	STATION TF No 5 @ CHANDRAPUR GCR	02-Apr-24	06:00	03-Apr-24	18:00	Daily	1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine maintenance work.	MSETCL	MSETCL	1. During outage 400KV STN TF-4 will be in service. 2. NOC from Unit-7 CSTPS, MSPGCL for the outage on STN TF-5 will be submitted for the same
6	400 KV	WARORA - IEPL	02-Apr-24	09:00	02-Apr-24	17:00	Daily	Line CT,CVT Tan delta ,IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
7	400 KV	500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	03-Apr-24	09:00	04-Apr-24	18:00	Daily	Diagnostic testing and allied bay maintenance works	MSETCL	MSETCL	Bushing Tandelta, Winding Tandelta, IR PI, SFRA, DFRA, Winding Resistance and relay testings
8	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	03-Apr-24	10:00	04-Apr-24	18:00	Continuous	Replacement of Neutral Bushing of R & Y Ph Unit	MSETCL	MSETCL	NA
9	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	04-Apr-24	09:30	04-Apr-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
10	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	04-Apr-24	09:00	04-Apr-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
11	400 KV	400KV 125MVAr BUS REACTOR @ 400KV KUMBHARGAON SS	04-Apr-24	10:30	04-Apr-24	18:00	Daily	Routine Bay maintenance & Relay testing work	MSETCL	MSETCL	-
12	400 KV	TBC @ KOLHAPUR(TALANDGE)	04-Apr-24	09:00	04-Apr-24	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	TBC is free
13	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	04-Apr-24	10:00	04-Apr-24	18:00	Daily	For Overhauling of SERGI NIFPS Fire system for ICT No.2, Routine Maintenance and DT.	MSETCL	MSETCL	-
14	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	04-Apr-24	08:00	04-Apr-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
15	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	05-Apr-24	09:00	05-Apr-24	18:00	Daily	1) REF relay & IV CT testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
16	400 KV	AKOLA - KHADKA (BHUSAWAL)	05-Apr-24	07:00	05-Apr-24	14:00	Daily	Diagnostic testing & Routine Maintenance work	MSETCL	MSETCL	Nandgaon Line will be service
17	400 KV	400 KV FUTURE BAY II @ WARORA	05-Apr-24	09:00	05-Apr-24	17:00	Daily	Relay testing work & routine maintenance work, Line CT,CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
18	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	05-Apr-24	09:00	05-Apr-24	18:00	Daily	Line Maintenance work and replacement of Insulators	MSETCL	MSETCL	NIL
19	400 KV	TBC @ BABHALESHWAR	05-Apr-24	09:00	05-Apr-24	16:00	Daily	CB DCRM/Timing testing work	MSETCL	MSETCL	TBC will be free for availing outage

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	06-Apr-24	09:00	06-Apr-24	16:00	Daily	For Premnsoon maintenance & routine bay maintenance works of ICT.	MSETCL	MSETCL	As per annual Outage plan.
21	400 KV	NEW KOYNA-KARAD CKT - 1	06-Apr-24	08:00	06-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
22	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	06-Apr-24	09:00	06-Apr-24	18:00	Daily	DFRA,SFRA Testing and Quarterly bay maintenance work	MSETCL	MSETCL	315 MVA ICT II and 501 MVA ICT III and IV will be in service
23	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	06-Apr-24	08:00	06-Apr-24	16:00	Daily	Diagnostic testing and allied bay Maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay Maintenance work
24	400 KV	NEW KOYNA - STAGE IV CKT - 2	08-Apr-24	08:00	08-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
25	400 KV	400/220/33 KV 315MVA ICT - 3 @ KARAD	09-Apr-24	08:00	09-Apr-24	18:00	Daily	Replacement of MOG & Buchholz relay . Diagnostic testing work.	MSETCL	MSETCL	Replacement of MOG & Buchholz relay . Diagnostic testing work.
26	400 KV	CHANDRAPUR - KHAPERKHEDA	10-Apr-24	10:00	10-Apr-24	17:00	Daily	CT Diagnostic Testing Work	MSETCL	MSETCL	NA
27	400 KV	WARORA - IEPL	10-Apr-24	09:00	10-Apr-24	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
28	400 KV	LONIKAND I - KOYNA STAGE-IV	11-Apr-24	08:00	11-Apr-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
29	400 KV	MAIN BAY (410) OF DHARIWAL CKT - 2 @ CHANDRAPUR - 2	11-Apr-24	08:00	11-Apr-24	16:00	Daily	Diagnostic testing and allied bay Maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay Maintenance work
30	400 KV	LONIKAND - JEJURI CKT - 2	11-Apr-24	08:00	11-Apr-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
31	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	11-Apr-24	08:00	11-Apr-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
32	400 KV	MAIN BAY (419) OF 400/220/33kv 500MVA ICT-I @ LONIKAND 2	11-Apr-24	08:00	11-Apr-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
33	400 KV	NEW KOYNA-KARAD CKT - 1	12-Apr-24	08:00	12-Apr-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
34	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	12-Apr-24	07:00	12-Apr-24	14:00	Daily	Diagnostic testing & Routine Maintenance work	MSETCL	MSETCL	Bhusawal Line will be in service
35	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	12-Apr-24	09:00	12-Apr-24	18:00	Daily	1) Diagnostic Testing and Routine Maintenance Work. 2) Line Maintenance Work and replacement of	MSETCL	MSETCL	NIL
36	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	13-Apr-24	09:00	13-Apr-24	17:00	Daily	For Premonsoon maintenance & routine ICTbay maintenance works.	MSETCL	MSETCL	As annual outage plan.
37	400 KV	NEW KOYNA-KARAD CKT - 2	13-Apr-24	08:00	13-Apr-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
38	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	13-Apr-24	09:00	13-Apr-24	18:00	Daily	(1) Reactor B/U testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work	MSETCL	MSETCL	-
39	400 KV	CHANDRAPUR-PARLI CKT-3	13-Apr-24	09:00	13-Apr-24	18:00	Daily	Broken Earth Wire replacement work loc.no.511-512	MSETCL	MSETCL	-
40	400 KV	KARAD - TALANDGE CKT - 1	15-Apr-24	08:00	15-Apr-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	400/220 KV 315MVA ICT - 1 @ KARAD	16-Apr-24	08:00	16-Apr-24	18:00	Daily	Replacement of MOG & Buchholz relay of R Phase Unit. Diagnostic testing work of ICT-1	MSETCL	MSETCL	Replacement of MOG & Buchholz relay of R Phase Unit. Diagnostic testing work of ICT-1
42	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	16-Apr-24	09:00	17-Apr-24	18:00	Continuous	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) String replacement work at location No 843	MSETCL	MSETCL	-
43	400 KV	105 MVA SPARE ICT @ AKOLA	16-Apr-24	07:00	16-Apr-24	14:00	Daily	Diagnostic testing & Routine maintenance Work	MSETCL	MSETCL	N.A.
44	400 KV	400KV RPL LINE REACTOR @ 400KV KORADI	16-Apr-24	09:00	16-Apr-24	18:00	Daily	DFRA,winding resistance & bushing tan delta	MSETCL	MSETCL	NA
45	400 KV	KARAD - TALANDGE CKT - 2	16-Apr-24	08:00	16-Apr-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
46	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	16-Apr-24	08:00	16-Apr-24	17:00	Daily	Diagnostic testing and allied bay Maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay Maintenance work
47	400 KV	LONIKAND - JEJURI CKT - 1	18-Apr-24	08:00	18-Apr-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
48	400 KV	LONIKAND - JEJURI CKT - 1	18-Apr-24	08:00	18-Apr-24	18:00	Daily	For Relay Retrofitting	MSETCL	MSETCL	400kV Jejuri - Lonikand Ckt-2, 400kVJejuri - Karad and 400kV Jejuri - Stage -IV lines will be in service.
49	400 KV	JEJURI- KOYNA STAGE-IV	18-Apr-24	08:00	18-Apr-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
50	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	18-Apr-24	10:30	18-Apr-24	18:00	Daily	Routine Bay maintenance & relay testing work	MSETCL	MSETCL	-
51	400 KV	KHADKA - BABLESHWAR	18-Apr-24	08:00	18-Apr-24	18:00	Daily	Routine Line maintenance work;LBB relay testing	MSETCL	MSETCL	400kV Aurangabad ,400kV Dhule ckt I&II, Ektuni I&II will be in service
52	400 KV	KORADI II - IEPL	18-Apr-24	06:00	18-Apr-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA
53	400 KV	TBC @ WALUJ	19-Apr-24	10:00	19-Apr-24	18:00	Daily	Diagnostic Testing and Routine Maintenance Work	MSETCL	MSETCL	Outage proposed on 400kV TBC Bay at 400kV Waluj
54	400 KV	SPARE LINE-1 BAY (401) @ TAPTITANDA	19-Apr-24	11:00	19-Apr-24	18:00	Daily	Routine maintenance work , diagnostic testing work and relay testing work	MSETCL	MSETCL	Outage required along with 400 kV Waluj line to avail relay testing work on bay 401, 402,
55	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	19-Apr-24	08:00	19-Apr-24	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
56	400 KV	CHANDRAPUR - KHAPERKHEDA	19-Apr-24	06:00	19-Apr-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA
57	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	19-Apr-24	11:00	19-Apr-24	18:00	Daily	Routine maintenance and Diagnostic testing work and relay testing work.	MSETCL	MSETCL	Outage required along with spare line bay 401 to avail relay testing work on bay 401, 402, 403 with ease
58	400 KV	NEW KOYNA-KARAD CKT - 2	19-Apr-24	08:00	19-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
59	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	22-Apr-24	08:00	22-Apr-24	18:00	Daily	Replacement of MOG & Buchholz relay of all 3 units. Diagnostic testing work.	MSETCL	MEGPTCL	Replacement of MOG & Buchholz relay of all 3 units. Diagnostic testing work.
60	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	22-Apr-24	08:00	22-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
61	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	23-Apr-24	08:00	23-Apr-24	18:00	Daily	Replacement of MOG & Buchholz relay of all 3 units. Diagnostic testing work.	MSETCL	MEGPTCL	Replacement of MOG & Buchholz relay of all 3 units. Diagnostic testing work.
62	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	23-Apr-24	07:00	23-Apr-24	14:00	Daily	Diagnostic testing & Routine Maintenance work	MSETCL	MSETCL	Load will be shifted on ICT-02 & ICT-03
63	400 KV	BUS REACTOR (125 MVA) - 2 @ KOLHAPUR (TALANDGE)	24-Apr-24	09:00	24-Apr-24	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Load affected nil

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
64	400 KV	JEJURI- KOYNA STAGE-IV	25-Apr-24	08:00	25-Apr-24	18:00	Daily	For Relay Retrofitting	MSETCL	MSETCL	400kV Jejuri - Lonikand Ckt-1 & 2 and 400kVJejuri -Karad lines will be in service.
65	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	25-Apr-24	06:00	25-Apr-24	18:00	Daily	REPLACEMENT OF FAULTY STRINGS AND LINES MAINT. WORKS	MSETCL	MSETCL	NA
66	400 KV	CHANDRAPUR-PARLI CKT-3	25-Apr-24	09:00	25-Apr-24	18:00	Daily	1) Main-2 distance relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
67	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	25-Apr-24	08:00	25-Apr-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
68	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	25-Apr-24	10:30	25-Apr-24	18:00	Daily	CVT Tan-d test , Routine Bay maintenance & relay testing work	MSETCL	MSETCL	-
69	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	25-Apr-24	08:00	25-Apr-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
70	400 KV	JEJURI - KARAD	25-Apr-24	08:00	25-Apr-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
71	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	25-Apr-24	08:00	25-Apr-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
72	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	26-Apr-24	07:00	26-Apr-24	14:00	Daily	Diagnostic testing & Routine Maintenance work	MSETCL	MSETCL	Load will be shifted on ICT-01 & ICT-03
73	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	26-Apr-24	09:00	28-Apr-24	18:00	Continuous	Rapid Restoration Scheme work, DFRA;Quarterly bay maintenance work	MSETCL	MSETCL	315 MVA ICT I and II and 501 MVA ICT III will be in service
74	400 KV	KHADKA-AURANGABAD (WALUJ)	26-Apr-24	10:00	26-Apr-24	18:00	Daily	1) Diagnostic Testing and Routine Maintenance Work. 2) Line Maintenance Work.	MSETCL	MSETCL	NIL
75	400 KV	KORADI-NANDGAONPETH (RPL)	26-Apr-24	06:00	26-Apr-24	18:00	Daily	REPLACEMENT OF FAULTY STRINGS AND LINES MAINT. WORKS	MSETCL	MSETCL	NA
76	400 KV	GT-10 @ KORADI-2	26-Apr-24	10:00	26-Apr-24	17:30	Daily	Diagnostic Testing of Line CT	MSETCL	MSETCL	NOC required from Mahagenco
77	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	29-Apr-24	09:00	29-Apr-24	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Load will be managed form 400/220kV ICT - 1 & 2
78	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	29-Apr-24	08:00	29-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
79	400 KV	CHANDRAPUR-PARLI CKT-3	29-Apr-24	09:00	29-Apr-24	18:00	Daily	Disc Repalcement work loc.no.495,496,583	MSETCL	MSETCL	-
80	400 KV	KORADI II - IEPL	29-Apr-24	10:00	29-Apr-24	17:30	Daily	Diagnostic Testing of Line CT	MSETCL	MSETCL	Koradi-II -Wardha(PG)Ckt will be in service
81	400 KV	TBC @ NEW KOYNA	30-Apr-24	08:00	30-Apr-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----