

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of APRIL '2025

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
1	RQ240683	PLANNED	OCC_589	POWERGRID_WR1	400KV-PARLI-SOLAPUR-2	D	Annual Maintenance Plan work of terminal equipments	01/Apr/2025	08:00	01/Apr/2025	18:00	
2	RQ241056	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	01/Apr/2025	08:00	01/Apr/2025	18:00	AR disable
3	RQ241086	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	01/Apr/2025	08:00	01/Apr/2025	18:00	AR disable
4	RQ242036	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	C	CB pole overhauling work	01/Apr/2025	08:00	05/Apr/2025	18:00	
5	RQ242173	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	01/Apr/2025	09:00	01/Apr/2025	18:00	
6	RQ242203	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	01/Apr/2025	07:00	01/Apr/2025	18:00	
7	RQ242221	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/Apr/2025	07:00	01/Apr/2025	18:00	
8	RQ242240	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	01/Apr/2025	08:00	01/Apr/2025	18:00	
9	RQ242244	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	01/Apr/2025	09:00	01/Apr/2025	18:00	
10	RQ242274	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	01/Apr/2025	09:00	01/Apr/2025	17:30	
11	RQ242304	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	01/Apr/2025	09:00	01/Apr/2025	17:30	
12	RQ242618	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	01/Apr/2025	07:00	01/Apr/2025	19:00	
13	RQ241800	PLANNED	OCC_589	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	C	Outage required for diversion of transmission line fouling to the Vadodara - Mumbai Expressway. Non auto mode of 400 KV TARAPUR - PADGHE-2 Shall be required.Dia to be kept open at both ends.	01/Apr/2025	08:00	07/Apr/2025	18:00	/PG-WR2- BOISAR/
14	RQ241809	PLANNED	OCC_589	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	201-Bay AMP WORK	01/Apr/2025	09:00	01/Apr/2025	17:00	/PG-WR2- BOISAR/
15	RQ240618	PLANNED	OCC_589	POWERGRID_WR1	MAIN BAY OF 400KV-KOLHAPUR-MS-ALKUD-1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	02/Apr/2025	08:00	02/Apr/2025	18:00	Main Bay AMP work
16	RQ240675	PLANNED	OCC_589	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	D	CVT Testing. AR of CKT 3 in non auto is required for safety.	02/Apr/2025	22:00	03/Apr/2025	6:00	Line Owned By ADANI Trans
17	RQ241057	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	02/Apr/2025	08:00	02/Apr/2025	18:00	AR disable
18	RQ241087	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	02/Apr/2025	08:00	02/Apr/2025	18:00	AR disable
19	RQ242037	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine maintenance and diagnostic testing such as CVT/ CT tandem, and, isolator maintenance work	02/Apr/2025	16:00	02/Apr/2025	23:59	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
20	RQ242038	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	02/Apr/2025	08:00	02/Apr/2025	18:00	
21	RQ242040	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	02/Apr/2025	09:00	02/Apr/2025	17:30	
22	RQ242174	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	02/Apr/2025	09:00	02/Apr/2025	18:00	
23	RQ242204	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	02/Apr/2025	07:00	02/Apr/2025	18:00	
24	RQ242222	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	02/Apr/2025	07:00	02/Apr/2025	18:00	
25	RQ242245	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	02/Apr/2025	09:00	02/Apr/2025	18:00	
26	RQ242275	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	02/Apr/2025	09:00	02/Apr/2025	17:30	
27	RQ242305	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	02/Apr/2025	09:00	02/Apr/2025	17:30	
28	RQ242334	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Insulator replacement & SSN to DSN conversion	02/Apr/2025	09:00	02/Apr/2025	17:00	
29	RQ241810	PLANNED	OCC_589	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-NALASOPARA-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	203-Bay Amp work	02/Apr/2025	09:00	02/Apr/2025	17:00	/PG-WR2- BOISAR/
30	RQ242619	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	02/Apr/2025	07:00	02/Apr/2025	19:00	
31	RQ240549	PLANNED	OCC_589	POWERGRID_WR1	PARLI - 220KV - BUS 1	C	For construction work of new 220kv bay at Parli substation_Bus Isolator erection	03/Apr/2025	09:00	07/Apr/2025	18:00	For construction work of new 220kv bay at Parli substation_Bus Isolator erection
32	RQ240619	PLANNED	OCC_589	POWERGRID_WR1	KOLHAPUR GIS - 400KV B/R 1	C	Reactor AMP and turret CT oil leakage attending	03/Apr/2025	08:00	04/Apr/2025	18:00	125 MV/Ar Bus reactor at Kolhapur GIS End
33	RQ240642	PLANNED	OCC_589	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	C	Outdoor GIB erection	03/Apr/2025	06:00	04/Apr/2025	20:00	Outage is being proposed for construction works under WRES-XXXXI project
34	RQ240684	PLANNED	OCC_589	POWERGRID_WR1	MAIN BAY - 220KV-SOLAPUR-JEUR-1 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV	D	Annual Maintenance Plan work of Bay; Note : 220KV JEUR Line shall be in service via TBC	03/Apr/2025	08:00	03/Apr/2025	18:00	
35	RQ241058	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	03/Apr/2025	08:00	03/Apr/2025	18:00	AR disable
36	RQ241088	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	03/Apr/2025	08:00	03/Apr/2025	18:00	AR disable
37	RQ241811	PLANNED	OCC_589	POWERGRID_WR2	TIE BAY - 400KV-PADGHE-BOISAR-1 AND 400KV/220KV BOISAR-ICT-1 at BOISAR - 400KV	D	408-Bay Amp Work	03/Apr/2025	09:00	03/Apr/2025	17:00	/PG-WR2- BOISAR/
38	RQ242041	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	03/Apr/2025	08:00	03/Apr/2025	18:00	
39	RQ242042	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	03/Apr/2025	08:00	03/Apr/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
40	RQ242045	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	C	1) Cold line washing of strings 2) Routine bay maintenance work	03/Apr/2025	22:00	04/Apr/2025	06:00	
41	RQ242047	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	C	SSN to DSN string replacement 18 Nos.	03/Apr/2025	18:00	04/Apr/2025	05:00	
42	RQ242175	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	03/Apr/2025	09:00	03/Apr/2025	18:00	
43	RQ242205	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	03/Apr/2025	07:00	03/Apr/2025	18:00	
44	RQ242223	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	03/Apr/2025	07:00	03/Apr/2025	18:00	
45	RQ242246	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	03/Apr/2025	09:00	03/Apr/2025	18:00	
46	RQ242276	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	03/Apr/2025	09:00	03/Apr/2025	17:30	
47	RQ242306	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	03/Apr/2025	09:00	03/Apr/2025	17:30	
48	RQ242335	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Insulator replacement & SSN to DSN conversion	03/Apr/2025	09:00	03/Apr/2025	17:00	
49	RQ242620	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	03/Apr/2025	07:00	03/Apr/2025	19:00	
50	RQ240676	PLANNED	OCC_589	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	D	CVT Testing	04/Apr/2025	22:00	05/Apr/2025	6:00	Line Owned By MSETCL Trans
51	RQ241059	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	04/Apr/2025	08:00	04/Apr/2025	18:00	AR disable
52	RQ241089	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	04/Apr/2025	08:00	04/Apr/2025	18:00	AR disable
53	RQ242049	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	04/Apr/2025	08:00	04/Apr/2025	18:00	
54	RQ242050	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	04/Apr/2025	08:00	04/Apr/2025	18:00	
55	RQ242051	PLANNED	OCC_589	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-5	D	1. For connection of gantry jumper between new ICT-6 bus and existing ICT-5 by hotline method (For safety Purpose)	04/Apr/2025	08:00	04/Apr/2025	17:00	
56	RQ242176	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	04/Apr/2025	09:00	04/Apr/2025	18:00	
57	RQ242224	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	04/Apr/2025	07:00	04/Apr/2025	18:00	
58	RQ242247	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	04/Apr/2025	09:00	04/Apr/2025	18:00	
59	RQ242277	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	04/Apr/2025	09:00	04/Apr/2025	17:30	
60	RQ242307	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	04/Apr/2025	09:00	04/Apr/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
61	RQ242336	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Insulator replacement & SSN to DSN conversion	04/Apr/2025	09:00	04/Apr/2025	17:00	
62	RQ242621	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLL-PUNE-PG-1	D	96 OPGW work by MTCIL	04/Apr/2025	07:00	04/Apr/2025	19:00	
63	RQ242920	PLANNED	OCC_589	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400KV	D	Hotline washing in all bay RYB-ph equipments.	04/Apr/2025	10:00	04/Apr/2025	18:00	
64	RQ242957	PLANNED	OCC_589	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	D	For connection of gantry jumper between new ICT-6 A Bus and existing ICT-5 by hotline method.	04/Apr/2025	08:00	04/Apr/2025	17:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
65	RQ243102	PLANNED	OCC_589	MSLDC_OUTAGE	KHAPARKHEDA - 400KV - BUS 1	D	Busbar Protection Relay Testing Work. Only Bus Bar protection will be out. Both Bus1 & 2 will be in service	04/Apr/2025	10:00	04/Apr/2025	18:00	
66	RQ243103	PLANNED	OCC_589	MSLDC_OUTAGE	KHAPARKHEDA - 400KV - BUS 2	D	Busbar Protection Relay Testing Work. Only Bus Bar protection will be out. Both Bus1 & 2 will be in service	04/Apr/2025	10:00	04/Apr/2025	18:00	
67	RQ240575	PLANNED	OCC_589	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	LINE Isolator Maintenance and Line BAY EQUIPMENT TIGHTNESS	05/Apr/2025	08:00	05/Apr/2025	18:00	AMP WORK
68	RQ240629	PLANNED	OCC_589	POWERGRID_WR1	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	D	AMP of 402 bay at MSETCL Kudus	05/Apr/2025	09:00	05/Apr/2025	18:00	OUTAGE
69	RQ240643	PLANNED	OCC_589	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	C	Outdoor GIB erection	05/Apr/2025	06:00	07/Apr/2025	20:00	Outage is being proposed for construction works under WRES-XXXI project
70	RQ240686	PLANNED	OCC_589	POWERGRID_WR1	SOLAPUR - 400KV - BUS 2	D	Replacement of R.Ph CVT due to voltage drift	05/Apr/2025	08:00	05/Apr/2025	18:00	
71	RQ241060	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	05/Apr/2025	08:00	05/Apr/2025	18:00	AR disable
72	RQ241090	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	05/Apr/2025	08:00	05/Apr/2025	18:00	AR disable
73	RQ241812	PLANNED	OCC_589	POWERGRID_WR2	MAIN BAY - 400KV-TARAPUR 3&4-BOISAR-2 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	D	410-Bay Amp Work	05/Apr/2025	09:00	05/Apr/2025	17:00	/PG-WR2- BOISAR/
74	RQ242052	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Line Maintenance work at various tower locations.	05/Apr/2025	06:00	05/Apr/2025	18:00	
75	RQ242053	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	C	(1) Bay equipments replacement work (CT,CVT,LA,WT, PG & HCB isolators) under LES. (2)Distance M1 & M2 relays retrofitting work.(3) Hardware tightening & fitting work	05/Apr/2025	09:00	15/Apr/2025	18:00	
76	RQ242055	PLANNED	OCC_589	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-5	D	1. For connection of gantry jumper between new ICT-6 bus and existing ICT-5 by hotline method (For safety Purpose)	05/Apr/2025	08:00	05/Apr/2025	17:00	
77	RQ242057	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	C	Chemical washing of insulator strings.	05/Apr/2025	22:00	06/Apr/2025	05:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
78	RQ242177	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	05/Apr/2025	09:00	05/Apr/2025	18:00	
79	RQ242248	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	05/Apr/2025	09:00	05/Apr/2025	18:00	
80	RQ242278	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	05/Apr/2025	09:00	05/Apr/2025	17:30	
81	RQ242308	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	05/Apr/2025	09:00	05/Apr/2025	17:30	
82	RQ242337	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Insulator replacement & SSN to DSN conversion	05/Apr/2025	09:00	05/Apr/2025	17:00	
83	RQ242622	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	05/Apr/2025	07:00	05/Apr/2025	19:00	
84	RQ242958	PLANNED	OCC_589	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	D	For connection of B Bus gantry jumper between ICT-6 and ICT-5 by hotline method.	05/Apr/2025	08:00	05/Apr/2025	17:00	
85	RQ241061	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	06/Apr/2025	08:00	06/Apr/2025	18:00	AR disable
86	RQ241091	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	06/Apr/2025	08:00	06/Apr/2025	18:00	AR disable
87	RQ242059	PLANNED	OCC_589	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance & Diagnostic testing work.	06/Apr/2025	08:00	06/Apr/2025	17:00	
88	RQ242060	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	C	1). Critical Hotspot attending, Critically bent vibration dampers replacement works, PID Faulty disc replacements, broken discs replacements and other critical line maintenance works. 2). Insulator discs replacements by PLRI under Junnar	06/Apr/2025	22:00	07/Apr/2025	06:00	
89	RQ242061	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	1) For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor. 2) Bus Maintenance and Diagnostic Testing.	06/Apr/2025	06:00	06/Apr/2025	19:00	
90	RQ242062	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	06/Apr/2025	06:00	06/Apr/2025	19:00	
91	RQ242063	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	C	Chemical washing of insulator strings.	06/Apr/2025	22:00	07/Apr/2025	05:00	
92	RQ242178	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	06/Apr/2025	09:00	06/Apr/2025	18:00	
93	RQ242249	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	06/Apr/2025	09:00	06/Apr/2025	18:00	
94	RQ242279	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	06/Apr/2025	09:00	06/Apr/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
95	RQ242309	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	06/Apr/2025	09:00	06/Apr/2025	17:30	
96	RQ242623	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLLI-PUNE-PG-1	D	96 OPGW work by MTCIL	06/Apr/2025	07:00	06/Apr/2025	19:00	
97	RQ240677	PLANNED	OCC_589	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-1	D	for AMP work	07/Apr/2025	22:00	08/Apr/2025	6:00	
98	RQ241062	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	07/Apr/2025	08:00	07/Apr/2025	18:00	AR disable
99	RQ241092	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	07/Apr/2025	08:00	07/Apr/2025	18:00	AR disable
100	RQ242064	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintainance work	07/Apr/2025	08:00	07/Apr/2025	18:00	
101	RQ242065	PLANNED	OCC_589	MSLDC_OUTAGE	WARORA - 400KV B/R 1	C	Filtration of Oil of 400KV, 125MVAR BUS REACTOR OF MAIN TANK with DGA Testing with allied test by AGENCY	07/Apr/2025	09:00	11/Apr/2025	17:00	
102	RQ242179	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	07/Apr/2025	09:00	07/Apr/2025	18:00	
103	RQ242250	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	07/Apr/2025	09:00	07/Apr/2025	18:00	
104	RQ242280	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	07/Apr/2025	09:00	07/Apr/2025	17:30	
105	RQ242310	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	07/Apr/2025	09:00	07/Apr/2025	17:30	
106	RQ242363	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	07/Apr/2025	09:00	07/Apr/2025	18:00	
107	RQ242369	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	07/Apr/2025	07:00	07/Apr/2025	18:00	
108	RQ242373	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Insulator replacement & SSN to DSN conversion	07/Apr/2025	09:00	07/Apr/2025	17:00	
109	RQ242624	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLLI-PUNE-PG-1	D	96 OPGW work by MTCIL	07/Apr/2025	07:00	07/Apr/2025	19:00	
110	RQ242959	PLANNED	OCC_589	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	D	Routine testing and Maintenance Works.	07/Apr/2025	10:00	07/Apr/2025	18:00	
111	RQ240620	PLANNED	OCC_589	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR-MS - 400KV - BUS 1 at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	08/Apr/2025	08:00	08/Apr/2025	18:00	Main Bay AMP work
112	RQ241063	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	08/Apr/2025	08:00	08/Apr/2025	18:00	AR disable
113	RQ241093	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	08/Apr/2025	08:00	08/Apr/2025	18:00	AR disable
114	RQ241801	PLANNED	OCC_589	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	C	Outage required for diversion of transmission line fouling to the Vadodara - Mumbai Expressway.Non auto mode of 400 KV TARAPUR - PADGHE-1 Shall be required.Dia to be kept open at both ends.	08/Apr/2025	08:00	15/Apr/2025	18:00	/PG-WR2- BOISAR/
115	RQ242066	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintainance work	08/Apr/2025	08:00	08/Apr/2025	18:00	
116	RQ242067	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	D	Outage is required for Quarterly Maintenance	08/Apr/2025	10:00	08/Apr/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
117	RQ242180	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	08/Apr/2025	09:00	08/Apr/2025	18:00	
118	RQ242251	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	08/Apr/2025	09:00	08/Apr/2025	18:00	
119	RQ242281	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	08/Apr/2025	09:00	08/Apr/2025	17:30	
120	RQ242311	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	08/Apr/2025	09:00	08/Apr/2025	17:30	
121	RQ242364	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	08/Apr/2025	09:00	08/Apr/2025	18:00	
122	RQ242370	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	08/Apr/2025	07:00	08/Apr/2025	18:00	
123	RQ242374	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Insulator replacement & SSN to DSN conversion	08/Apr/2025	09:00	08/Apr/2025	17:00	
124	RQ242625	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	08/Apr/2025	07:00	08/Apr/2025	19:00	
125	RQ240550	PLANNED	OCC_589	POWERGRID_WR1	PARLI - 220KV - BUS 2	C	For construction work of new 220kv bay at Parli substation_Bus Isolator erection	09/Apr/2025	09:00	14/Apr/2025	18:00	For construction work of new 220kv bay at Parli substation_Bus Isolator
126	RQ240678	PLANNED	OCC_589	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	for AMP work	09/Apr/2025	22:00	10/Apr/2025	6:00	Line owned by MSETCL
127	RQ241064	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	09/Apr/2025	08:00	09/Apr/2025	18:00	AR disable
128	RQ241094	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	09/Apr/2025	08:00	09/Apr/2025	18:00	AR disable
129	RQ242068	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	To carry out maintenance work like disc replacement and nut bolt tightening at various locations	09/Apr/2025	06:00	09/Apr/2025	18:00	
130	RQ242069	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHVAR-1	D	For routine maintenance work	09/Apr/2025	09:00	09/Apr/2025	18:00	
131	RQ242070	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	09/Apr/2025	09:00	09/Apr/2025	18:00	
132	RQ242071	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and cold line washing	09/Apr/2025	09:00	09/Apr/2025	18:00	
133	RQ242072	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line / s/sMaintenance	09/Apr/2025	09:00	09/Apr/2025	17:30	
134	RQ242073	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-SOLAPUR-KUMBARI-1	D	Outage is required for Quarterly Maintenance	09/Apr/2025	09:00	09/Apr/2025	16:00	
135	RQ242074	PLANNED	OCC_589	MSLDC_OUTAGE	KUMBARI - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	09/Apr/2025	10:00	09/Apr/2025	16:00	
136	RQ242181	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	09/Apr/2025	09:00	09/Apr/2025	18:00	
137	RQ242252	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	09/Apr/2025	09:00	09/Apr/2025	18:00	
138	RQ242282	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	09/Apr/2025	09:00	09/Apr/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
139	RQ242312	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	09/Apr/2025	09:00	09/Apr/2025	17:30	
140	RQ242365	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	09/Apr/2025	09:00	09/Apr/2025	18:00	
141	RQ242371	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	09/Apr/2025	07:00	09/Apr/2025	18:00	
142	RQ242375	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Insulator replacement & SSN to DSN conversion	09/Apr/2025	09:00	09/Apr/2025	17:00	
143	RQ242626	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	09/Apr/2025	07:00	09/Apr/2025	19:00	
144	RQ242921	PLANNED	OCC_589	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	D	Routine testing and Maintenance Works	09/Apr/2025	10:00	09/Apr/2025	18:00	
145	RQ240621	PLANNED	OCC_589	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AND KOLHAPUR-MS - 400KV - BUS 1 at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	10/Apr/2025	08:00	10/Apr/2025	18:00	Main Bay AMP work
146	RQ240630	PLANNED	OCC_589	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-2	D	Fine tuning of CSD of ICT, Body protection Modifications as per CC AM circulars.	10/Apr/2025	22:00	11/Apr/2025	6:00	Fine tuning of CSD of ICT, Repeated closing/opening of ICT required for CSD tuning.
147	RQ241065	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	10/Apr/2025	08:00	10/Apr/2025	18:00	AR disable
148	RQ241095	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	10/Apr/2025	08:00	10/Apr/2025	18:00	AR disable
149	RQ241483	PLANNED	OCC_589	POWERGRID_WR1	400KV-NAVI MUMBAI-VIKHROLI	D	For dismantalling of Wave Trap	10/Apr/2025	22:00	11/Apr/2025	6:00	For dismantalling of Wave Trap(Outage has been already proposed in the month of March, if work couldn't be done during the period, same is proposed for the month of April'25).
150	RQ242075	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	To carry out maintenance work like disc repalcement and nut bolt tightening at various locations	10/Apr/2025	06:00	10/Apr/2025	18:00	
151	RQ242076	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	C	(1) Bay maintenance work.(2) Hardware tightening & fitting work	10/Apr/2025	22:00	11/Apr/2025	06:00	
152	RQ242077	PLANNED	OCC_589	MSLDC_OUTAGE	JEJURI - 400KV - BUS 2	D	For Maintenance & Testing work	10/Apr/2025	09:30	10/Apr/2025	18:00	
153	RQ242079	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	C	Hardware tightening and cold line washing	10/Apr/2025	22:00	11/Apr/2025	06:00	
154	RQ242182	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	10/Apr/2025	09:00	10/Apr/2025	18:00	
155	RQ242253	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	10/Apr/2025	09:00	10/Apr/2025	18:00	
156	RQ242283	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	10/Apr/2025	09:00	10/Apr/2025	17:30	
157	RQ242313	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	10/Apr/2025	09:00	10/Apr/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
158	RQ242366	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	10/Apr/2025	09:00	10/Apr/2025	18:00	
159	RQ242372	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work	10/Apr/2025	07:00	10/Apr/2025	18:00	
160	RQ242376	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Insulator replacement & SSN to DSN conversion	10/Apr/2025	09:00	10/Apr/2025	17:00	
161	RQ242378	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	10/Apr/2025	09:00	10/Apr/2025	17:00	
162	RQ242627	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	10/Apr/2025	07:00	10/Apr/2025	19:00	
163	RQ240679	PLANNED	OCC_589	POWERGRID_WR1	BUS COUPLER BAY - PUNE-PG - 220KV - BUS 1 AND PUNE-PG - 220KV - BUS 2 at PUNE-PG - 220KV	D	for AMP work	11/Apr/2025	09:00	11/Apr/2025	17:30	Bus coupler Bay
164	RQ240690	PLANNED	OCC_589	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Annual Maintenance Plan work of Bay	11/Apr/2025	08:00	11/Apr/2025	18:00	
165	RQ241066	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	11/Apr/2025	08:00	11/Apr/2025	18:00	AR disable
166	RQ241096	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	11/Apr/2025	08:00	11/Apr/2025	18:00	AR disable
167	RQ241814	PLANNED	OCC_589	POWERGRID_WR2	TIE BAY - 400KV-TARAPUR 3&4-BOISAR-1 AND 400KV/220KV BOISAR-ICT-2 at BOISAR - 400KV	D	414-Bay Amp Work	11/Apr/2025	09:00	11/Apr/2025	17:00	/PG-WR2- BOISAR/
168	RQ242080	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	11/Apr/2025	08:00	11/Apr/2025	18:00	
169	RQ242083	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	Installation of Saver Assembly at various Locations.	11/Apr/2025	08:00	11/Apr/2025	18:00	
170	RQ242183	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	11/Apr/2025	09:00	11/Apr/2025	18:00	
171	RQ242254	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	11/Apr/2025	09:00	11/Apr/2025	18:00	
172	RQ242284	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	11/Apr/2025	09:00	11/Apr/2025	17:30	
173	RQ242314	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	11/Apr/2025	09:00	11/Apr/2025	17:30	
174	RQ242367	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	11/Apr/2025	09:00	11/Apr/2025	18:00	
175	RQ242377	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Insulator replacement & SSN to DSN conversion	11/Apr/2025	09:00	11/Apr/2025	17:00	
176	RQ242379	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	11/Apr/2025	09:00	11/Apr/2025	17:00	
177	RQ242628	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	11/Apr/2025	07:00	11/Apr/2025	19:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
178	RQ240647	PLANNED	OCC_589	POWERGRID_WR1	400KV/220KV PUNE-GIS-ICT-2	C	For bus bar interconnection work(Internal conductor fixing) bus bar testing and bus stability	12/Apr/2025	06:00	13/Apr/2025	20:00	Outage is being proposed for construction works underWRES-XXXXI project
179	RQ240680	PLANNED	OCC_589	POWERGRID_WR1	PUNE-PG - 220KV - BUS 2	D	For AMP Work .Each bay will be taken on TBC bay	12/Apr/2025	22:00	13/Apr/2025	06:00	Each bay will be taken on TBC bay
180	RQ240691	PLANNED	OCC_589	POWERGRID_WR1	SOLAPUR - 400KV - BUS 1	D	Replacement of B.Ph CVT due to voltage drift (- 2.34V)	12/Apr/2025	07:00	12/Apr/2025	18:00	Outage shall be availed considering the voltage drift
181	RQ241067	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	12/Apr/2025	08:00	12/Apr/2025	18:00	AR disable
182	RQ241097	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	12/Apr/2025	08:00	12/Apr/2025	18:00	AR disable
183	RQ242084	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	12/Apr/2025	08:00	12/Apr/2025	18:00	
184	RQ242085	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	LBB Relay Testing & Quarterly Bay Maintenance	12/Apr/2025	22:00	13/Apr/2025	6:00	
185	RQ242087	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	12/Apr/2025	06:00	12/Apr/2025	19:00	
186	RQ242088	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor.	12/Apr/2025	06:00	12/Apr/2025	19:00	
187	RQ242089	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	C	Half yearly maintenance work.	12/Apr/2025	22:00	13/Apr/2025	06:00	
188	RQ242184	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	12/Apr/2025	09:00	12/Apr/2025	18:00	
189	RQ242255	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	12/Apr/2025	09:00	12/Apr/2025	18:00	
190	RQ242285	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	12/Apr/2025	09:00	12/Apr/2025	17:30	
191	RQ242315	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	12/Apr/2025	09:00	12/Apr/2025	17:30	
192	RQ242368	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	12/Apr/2025	09:00	12/Apr/2025	18:00	
193	RQ242380	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	12/Apr/2025	09:00	12/Apr/2025	17:00	
194	RQ242629	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	12/Apr/2025	07:00	12/Apr/2025	19:00	
195	RQ241068	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	13/Apr/2025	08:00	13/Apr/2025	18:00	AR disable
196	RQ241098	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	13/Apr/2025	08:00	13/Apr/2025	18:00	AR disable
197	RQ242091	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	C	1). Critical Hotspot attending, Critically bent vibration dampers replacement works, PID Faulty disc replacements, broken discs replacements and other critical line maintenance works. 2). Insulator discs replacements by PLRI under Junnar	13/Apr/2025	22:00	14/Apr/2025	06:00	
198	RQ242092	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BORIVALI-1	D	For cold washing of disc insulator strings at TL No. 164, 165, 166, 167, 168, 169, 170, 177, 178, 179, 180, 181, 182, 183, 188, 189, 190, 191, 192, 200, 201, 202, 203, 204, 205, 233, 240 to avoid any future trippings.	13/Apr/2025	08:00	13/Apr/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
199	RQ242095	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	13/Apr/2025	06:00	13/Apr/2025	19:00	
200	RQ242096	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor.	13/Apr/2025	06:00	13/Apr/2025	19:00	
201	RQ242185	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	13/Apr/2025	09:00	13/Apr/2025	18:00	
202	RQ242256	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	13/Apr/2025	09:00	13/Apr/2025	18:00	
203	RQ242286	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	13/Apr/2025	09:00	13/Apr/2025	17:30	
204	RQ242316	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	13/Apr/2025	09:00	13/Apr/2025	17:30	
205	RQ242381	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	13/Apr/2025	09:00	13/Apr/2025	17:00	
206	RQ242630	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	13/Apr/2025	07:00	13/Apr/2025	19:00	
207	RQ240548	PLANNED	OCC_589	POWERGRID_WR1	220KV-PARLI-HARANGUL-1	D	For line bay annual maintenance work at Parli substation	14/Apr/2025	09:00	14/Apr/2025	18:00	For line bay annual maintenance work at Parli substation
208	RQ241069	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	14/Apr/2025	08:00	14/Apr/2025	18:00	AR disable
209	RQ241099	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	14/Apr/2025	08:00	14/Apr/2025	18:00	AR disable
210	RQ242186	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	14/Apr/2025	09:00	14/Apr/2025	18:00	
211	RQ242257	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	14/Apr/2025	09:00	14/Apr/2025	18:00	
212	RQ242287	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	14/Apr/2025	09:00	14/Apr/2025	17:30	
213	RQ242317	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	14/Apr/2025	09:00	14/Apr/2025	17:30	
214	RQ242382	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	14/Apr/2025	09:00	14/Apr/2025	17:00	
215	RQ242384	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	14/Apr/2025	09:00	14/Apr/2025	18:00	
216	RQ242631	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	14/Apr/2025	07:00	14/Apr/2025	19:00	
217	RQ240623	PLANNED	OCC_589	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Line Bay AMP work. AR of Ckt 2 in non auto is required	15/Apr/2025	08:00	15/Apr/2025	18:00	Line Bay AMP work. 400KV Kolhapur-Kolhapur ckt#2 Non-Auto required
218	RQ240631	PLANNED	OCC_589	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Retrofitting and Testing of Numerical LBB Protection	15/Apr/2025	22:00	16/Apr/2025	6:00	OUTAGE
219	RQ240681	PLANNED	OCC_589	POWERGRID_WR1	PUNE-PG - 220KV - BUS 1	D	Isolator Alignment Work . Each bay will be taken on TBC bay	15/Apr/2025	22:00	16/Apr/2025	06:00	Each bay will be taken on TBC bay
220	RQ241070	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	15/Apr/2025	08:00	15/Apr/2025	18:00	AR disable
221	RQ241100	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	15/Apr/2025	08:00	15/Apr/2025	18:00	AR disable

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
222	RQ241815	PLANNED	OCC_589	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-2 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	D	415-Bay Amp Work	15/Apr/2025	09:00	15/Apr/2025	17:00	/PG-WR2- BOISAR/
223	RQ242097	PLANNED	OCC_589	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	D	1. LBB Relay testing Work. 2. Diagnostic testing of Circuit Breaker. 3. Routine bay maintenance work.	15/Apr/2025	08:00	15/Apr/2025	18:00	
224	RQ242098	PLANNED	OCC_589	MSLDC_OUTAGE	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	D	Quarterly maintenance work	15/Apr/2025	09:00	15/Apr/2025	18:30	
225	RQ242099	PLANNED	OCC_589	MSLDC_OUTAGE	ALKUD - 400KV - BUS 1	D	Diagnostic Testing & Maintenance work	15/Apr/2025	17:00	15/Apr/2025	23:59	
226	RQ242100	PLANNED	OCC_589	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic Testing & Maintenance work	15/Apr/2025	17:00	15/Apr/2025	20:00	
227	RQ242101	PLANNED	OCC_589	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Diagnostic Testing & Maintenance work	15/Apr/2025	20:00	15/Apr/2025	23:59	
228	RQ242102	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Diagnostic Testing & Maintenance work	15/Apr/2025	17:00	15/Apr/2025	23:59	
229	RQ242187	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	15/Apr/2025	09:00	15/Apr/2025	18:00	
230	RQ242258	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	15/Apr/2025	09:00	15/Apr/2025	18:00	
231	RQ242288	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	15/Apr/2025	09:00	15/Apr/2025	17:30	
232	RQ242318	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	15/Apr/2025	09:00	15/Apr/2025	17:30	
233	RQ242383	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	15/Apr/2025	09:00	15/Apr/2025	17:00	
234	RQ242385	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	15/Apr/2025	09:00	15/Apr/2025	18:00	
235	RQ242632	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	15/Apr/2025	07:00	15/Apr/2025	19:00	
236	RQ242698	PLANNED	OCC_589	GETCO	400KV-SSP-DHULE-MS-1	D	PMM Work. A/R out of SSP-Dhule-2 is require	15/Apr/2025	06:30	15/Apr/2025	18:00	
237	RQ240632	PLANNED	OCC_589	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	D	Retrofitting and Testing of Numerical LBB Protection	16/Apr/2025	08:00	16/Apr/2025	18:00	OUTAGE
238	RQ241071	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	16/Apr/2025	08:00	16/Apr/2025	18:00	AR disable
239	RQ241101	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	16/Apr/2025	08:00	16/Apr/2025	18:00	AR disable
240	RQ241802	PLANNED	OCC_589	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	D	Simultaneous outage of 400KV-TARAPUR 3&4-PADGHE-1 & 2 is required for Outage required for facilitating the overhead stringing works of +/- 320 kV HVDC Kudus Aarey Line by M/s Adani, Dia to be kept open at both ends.	16/Apr/2025	08:00	16/Apr/2025	18:00	/PG-WR2- BOISAR/
241	RQ241803	PLANNED	OCC_589	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	D	Simultaneous outage of 400KV-TARAPUR 3&4-PADGHE-1 & 2 is required for Outage required for facilitating the overhead stringing works of +/- 320 kV HVDC Kudus Aarey Line by M/s Adani, Dia to be kept open at both ends.	16/Apr/2025	08:00	16/Apr/2025	18:00	/PG-WR2- BOISAR/
242	RQ241313	PLANNED	OCC_589	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	C	Tower Strengthening Work	16/Apr/2025	08:00	26/Apr/2025	18:00	Line Outage
243	RQ242104	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	16/Apr/2025	09:00	16/Apr/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
244	RQ242105	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line / s/sMaintenance	16/Apr/2025	09:00	16/Apr/2025	17:30	
245	RQ242188	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	16/Apr/2025	09:00	16/Apr/2025	18:00	
246	RQ242259	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	16/Apr/2025	09:00	16/Apr/2025	18:00	
247	RQ242289	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	16/Apr/2025	09:00	16/Apr/2025	17:30	
248	RQ242319	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	16/Apr/2025	09:00	16/Apr/2025	17:30	
249	RQ242386	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	16/Apr/2025	09:00	16/Apr/2025	18:00	
250	RQ242633	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	16/Apr/2025	07:00	16/Apr/2025	19:00	
251	RQ240581	PLANNED	OCC_589	POWERGRID_WR1	AURANGABAD - 220KV - BUS 2	D	AMP of BUS at Aurangabad S/s.	17/Apr/2025	08:00	17/Apr/2025	18:00	AMP WORK
252	RQ240624	PLANNED	OCC_589	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Line Bay AMP work. AR of Ckt 1 in non auto is required	17/Apr/2025	08:00	17/Apr/2025	18:00	CT Oil sample collecting, Line Bay AMP work. 400KV Kolhapur-Kolhapur ckt#1 Non-Auto required
253	RQ240633	PLANNED	OCC_589	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	Retrofitting and Testing of Numerical LBB Protection	17/Apr/2025	08:00	17/Apr/2025	18:00	OUTAGE
254	RQ240682	PLANNED	OCC_589	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-1 at PUNE-PG - 400KV	D	for AMP work	17/Apr/2025	10:00	17/Apr/2025	18:30	
255	RQ241072	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	17/Apr/2025	08:00	17/Apr/2025	18:00	AR disable
256	RQ241102	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	17/Apr/2025	08:00	17/Apr/2025	18:00	AR disable
257	RQ242109	PLANNED	OCC_589	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-1 by Hot Line Method	17/Apr/2025	09:00	17/Apr/2025	17:00	
258	RQ242110	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	C	Hardware tightening and cold line washing	17/Apr/2025	22:00	18/Apr/2025	06:00	
259	RQ242189	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	17/Apr/2025	09:00	17/Apr/2025	18:00	
260	RQ242260	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	17/Apr/2025	09:00	17/Apr/2025	18:00	
261	RQ242290	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	17/Apr/2025	09:00	17/Apr/2025	17:30	
262	RQ242320	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	17/Apr/2025	09:00	17/Apr/2025	17:30	
263	RQ242387	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	17/Apr/2025	09:00	17/Apr/2025	18:00	
264	RQ242405	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	17/Apr/2025	09:00	17/Apr/2025	17:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
265	RQ242634	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLL-PUNE-PG-1	D	96 OPGW work by MTCIL	17/Apr/2025	07:00	17/Apr/2025	19:00	
266	RQ242922	PLANNED	OCC_589	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARIJAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	17/Apr/2025	09:00	17/Apr/2025	17:00	
267	RQ242923	PLANNED	OCC_589	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIJAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	17/Apr/2025	10:00	17/Apr/2025	18:00	
268	RQ241073	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	18/Apr/2025	08:00	18/Apr/2025	18:00	AR disable
269	RQ241103	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	18/Apr/2025	08:00	18/Apr/2025	18:00	AR disable
270	RQ242111	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	Routine testing and Maintenance Works	18/Apr/2025	10:00	18/Apr/2025	18:00	
271	RQ242113	PLANNED	OCC_589	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-II by Hot Line Method	18/Apr/2025	09:00	18/Apr/2025	17:00	
272	RQ242190	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	18/Apr/2025	09:00	18/Apr/2025	18:00	
273	RQ242261	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	18/Apr/2025	09:00	18/Apr/2025	18:00	
274	RQ242291	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	18/Apr/2025	09:00	18/Apr/2025	17:30	
275	RQ242321	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	18/Apr/2025	09:00	18/Apr/2025	17:30	
276	RQ242388	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	18/Apr/2025	09:00	18/Apr/2025	18:00	
277	RQ242406	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	18/Apr/2025	09:00	18/Apr/2025	17:00	
278	RQ242635	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLL-PUNE-PG-1	D	96 OPGW work by MTCIL	18/Apr/2025	07:00	18/Apr/2025	19:00	
279	RQ241074	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	19/Apr/2025	08:00	19/Apr/2025	18:00	AR disable
280	RQ241104	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	19/Apr/2025	08:00	19/Apr/2025	18:00	AR disable
281	RQ242114	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	19/Apr/2025	06:00	19/Apr/2025	19:00	
282	RQ242115	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	1) Bay strengthening of 220kV Tarapur Bay & 220kV Ghodbunder Bay. 2) Bay Maintenance & Equipment Testing of 220kV B-Bus	19/Apr/2025	08:00	19/Apr/2025	18:00	
283	RQ242116	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor.	19/Apr/2025	06:00	19/Apr/2025	19:00	
284	RQ242119	PLANNED	OCC_589	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-1	C	CB pole overhauling work	19/Apr/2025	08:00	23/Apr/2025	18:00	
285	RQ242191	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	19/Apr/2025	09:00	19/Apr/2025	18:00	
286	RQ242262	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	19/Apr/2025	09:00	19/Apr/2025	18:00	
287	RQ242292	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	19/Apr/2025	09:00	19/Apr/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
288	RQ242322	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	19/Apr/2025	09:00	19/Apr/2025	17:30	
289	RQ242389	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	19/Apr/2025	09:00	19/Apr/2025	18:00	
290	RQ242407	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	19/Apr/2025	09:00	19/Apr/2025	17:00	
291	RQ242636	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	19/Apr/2025	07:00	19/Apr/2025	19:00	
292	RQ241075	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	20/Apr/2025	08:00	20/Apr/2025	18:00	AR disable
293	RQ241105	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	20/Apr/2025	08:00	20/Apr/2025	18:00	AR disable
294	RQ242120	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	20/Apr/2025	06:00	20/Apr/2025	19:00	
295	RQ242121	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor.	20/Apr/2025	06:00	20/Apr/2025	19:00	
296	RQ242122	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	1). Critical Hotspot attending, Critically bent vibration dampers replacement works, PID Faulty disc replacements, broken discs replacements and other critical line maintenance works. 2). Insulator discs replacements by PLRI under Junnar	20/Apr/2025	22:00	21/Apr/2025	06:00	
297	RQ242192	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	20/Apr/2025	09:00	20/Apr/2025	18:00	
298	RQ242263	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	20/Apr/2025	09:00	20/Apr/2025	18:00	
299	RQ242293	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	20/Apr/2025	09:00	20/Apr/2025	17:30	
300	RQ242323	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	20/Apr/2025	09:00	20/Apr/2025	17:30	
301	RQ242408	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	20/Apr/2025	09:00	20/Apr/2025	17:00	
302	RQ242637	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	20/Apr/2025	07:00	20/Apr/2025	19:00	
303	RQ242648	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	Routine & Pre monsoon maintenance	20/Apr/2025	09:00	20/Apr/2025	18:00	
304	RQ240583	PLANNED	OCC_589	POWERGRID_WR1	AURANGABAD - 400KV - BUS 1	D	AMP of BUS at Aurangabad S/s.	21/Apr/2025	08:00	21/Apr/2025	18:00	AMP WORK
305	RQ240650	PLANNED	OCC_589	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-2	D	Kallam II Line Reactor AMP works	21/Apr/2025	22:00	22/Apr/2025	6:00	Line Reactor AMP works
306	RQ240696	PLANNED	OCC_589	POWERGRID_WR1	400KV-KARAD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	Annual Maintenance Plan work of Line Reactor and Recator CB at 765kV Solapur Substation	21/Apr/2025	08:00	21/Apr/2025	18:00	
307	RQ241076	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	21/Apr/2025	08:00	21/Apr/2025	18:00	AR disable
308	RQ241106	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	21/Apr/2025	08:00	21/Apr/2025	18:00	AR disable

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
309	RQ241307	PLANNED	OCC_589	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Annual Maintenance of MCT & MCVT of ICT-1	21/Apr/2025	09:00	21/Apr/2025	19:00	ICT Outage
310	RQ242124	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-MUDSHINGLI-CHIKKODI-II-1	D	For Line maintenance work.	21/Apr/2025	08:00	21/Apr/2025	17:00	
311	RQ242125	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	1). Critical Hotspot attending, Critically bent vibration dampers replacement works, PID Faulty disc replacements, broken discs replacements and other critical line maintenance works. 2). Insulator discs replacements by PLRI under Junnar	21/Apr/2025	22:00	22/Apr/2025	06:00	
312	RQ242126	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	C	220kV Circuit breaker overhauling work will be done by agency	21/Apr/2025	08:00	21/Apr/2025	17:00	
313	RQ242193	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	21/Apr/2025	09:00	21/Apr/2025	18:00	
314	RQ242264	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	21/Apr/2025	09:00	21/Apr/2025	18:00	
315	RQ242294	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	21/Apr/2025	09:00	21/Apr/2025	17:30	
316	RQ242324	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	21/Apr/2025	09:00	21/Apr/2025	17:30	
317	RQ242409	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	21/Apr/2025	09:00	21/Apr/2025	17:00	
318	RQ242425	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	21/Apr/2025	07:00	21/Apr/2025	18:00	
319	RQ242638	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	21/Apr/2025	07:00	21/Apr/2025	19:00	
320	RQ242649	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	21/Apr/2025	09:00	21/Apr/2025	18:00	
321	RQ241077	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	22/Apr/2025	08:00	22/Apr/2025	18:00	AR disable
322	RQ241107	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	22/Apr/2025	08:00	22/Apr/2025	18:00	AR disable
323	RQ242127	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Quarterly maintenance work	22/Apr/2025	09:00	22/Apr/2025	18:30	
324	RQ242128	PLANNED	OCC_589	MSLDC_OUTAGE	ALKUD - 400KV - BUS 2	D	Diagnostic Testing & Maintenance work	22/Apr/2025	17:00	22/Apr/2025	23:59	
325	RQ242129	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic Testing & Maintenance work	22/Apr/2025	17:00	22/Apr/2025	23:59	
326	RQ242130	PLANNED	OCC_589	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic Testing & Maintenance work	22/Apr/2025	17:00	22/Apr/2025	20:00	
327	RQ242194	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	22/Apr/2025	09:00	22/Apr/2025	18:00	
328	RQ242265	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	22/Apr/2025	09:00	22/Apr/2025	18:00	
329	RQ242295	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	22/Apr/2025	09:00	22/Apr/2025	17:30	
330	RQ242325	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	22/Apr/2025	09:00	22/Apr/2025	17:30	
331	RQ242410	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Auto Reclose to be kept in Non auto mode for PID testing work	22/Apr/2025	09:00	22/Apr/2025	17:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
332	RQ242426	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	22/Apr/2025	07:00	22/Apr/2025	18:00	
333	RQ242639	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	22/Apr/2025	07:00	22/Apr/2025	19:00	
334	RQ242650	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	22/Apr/2025	09:00	22/Apr/2025	18:00	
335	RQ242924	PLANNED	OCC_589	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE at ALKUD - 400KV	D	Diagnostic Testing & Maintenance work	22/Apr/2025	20:00	22/Apr/2025	23:59	
336	RQ241078	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	23/Apr/2025	08:00	23/Apr/2025	18:00	AR disable
337	RQ241108	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	23/Apr/2025	08:00	23/Apr/2025	18:00	AR disable
338	RQ241308	PLANNED	OCC_589	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Annual Maintenance of MCT & MCVT of ICT-2	23/Apr/2025	09:00	23/Apr/2025	19:00	ICT Outage
339	RQ242131	PLANNED	OCC_589	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	For routine maintenance work	23/Apr/2025	09:00	23/Apr/2025	18:00	
340	RQ242132	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line, s/s Maintenance	23/Apr/2025	09:00	23/Apr/2025	17:30	
341	RQ242134	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening and cold line washing	23/Apr/2025	09:00	23/Apr/2025	17:00	
342	RQ242135	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-SOLAPUR-KUMBARI-2	D	Outage is required for Quarterly Maintenance	23/Apr/2025	09:00	23/Apr/2025	16:00	
343	RQ242136	PLANNED	OCC_589	MSLDC_OUTAGE	KUMBARI - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	23/Apr/2025	10:00	23/Apr/2025	16:00	
344	RQ242195	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	23/Apr/2025	09:00	23/Apr/2025	18:00	
345	RQ242266	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	23/Apr/2025	09:00	23/Apr/2025	18:00	
346	RQ242296	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	23/Apr/2025	09:00	23/Apr/2025	17:30	
347	RQ242326	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	23/Apr/2025	09:00	23/Apr/2025	17:30	
348	RQ242427	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	23/Apr/2025	07:00	23/Apr/2025	18:00	
349	RQ242640	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	23/Apr/2025	07:00	23/Apr/2025	19:00	
350	RQ242651	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	23/Apr/2025	09:00	23/Apr/2025	18:00	
351	RQ242720	PLANNED	OCC_589	GETCO	400KV-SSP-DHULE-MS-2	D	PMM Work. A/R out of 400 kV SSP-DHULE-2 is require	23/Apr/2025	06:30	23/Apr/2025	18:00	
352	RQ241079	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	24/Apr/2025	08:00	24/Apr/2025	18:00	AR disable
353	RQ241109	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	24/Apr/2025	08:00	24/Apr/2025	18:00	AR disable
354	RQ242021	PLANNED	OCC_589	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	D	AMP work , A/R off of ckt 2 is required. Dia to be kept open at both ends.	24/Apr/2025	08:00	24/Apr/2025	18:00	PG-WR2-KHANDWA
355	RQ242138	PLANNED	OCC_589	MSLDC_OUTAGE	400KV/220KV BABLASHWAR-ICT-2	C	CB pole overhauling work	24/Apr/2025	08:00	28/Apr/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
356	RQ242139	PLANNED	OCC_589	MSLDC_OUTAGE	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	D	Hotline washing in all bay RYB-ph equipments.	24/Apr/2025	10:00	24/Apr/2025	18:00	
357	RQ242140	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	C	Cold line washing of strings & online work of Hotline washing in all bay RYB-ph equipments.	24/Apr/2025	22:00	25/Apr/2025	06:00	
358	RQ242196	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	24/Apr/2025	09:00	24/Apr/2025	18:00	
359	RQ242267	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	24/Apr/2025	09:00	24/Apr/2025	18:00	
360	RQ242297	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	24/Apr/2025	09:00	24/Apr/2025	17:30	
361	RQ242327	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	24/Apr/2025	09:00	24/Apr/2025	17:30	
362	RQ242428	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	24/Apr/2025	07:00	24/Apr/2025	18:00	
363	RQ242641	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	24/Apr/2025	07:00	24/Apr/2025	19:00	
364	RQ242652	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	24/Apr/2025	09:00	24/Apr/2025	18:00	
365	RQ241080	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	25/Apr/2025	08:00	25/Apr/2025	18:00	AR disable
366	RQ241110	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	25/Apr/2025	08:00	25/Apr/2025	18:00	AR disable
367	RQ242141	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Outage is required for safety purpose during Installation of Saver Assembly at various Locations & Line Maintenance Work on 220kV Tarapur - Boisar Line .	25/Apr/2025	09:00	25/Apr/2025	18:00	
368	RQ242142	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	D	Installation of Saver Assembly at various Locations & Line Maintenance Work.	25/Apr/2025	09:00	25/Apr/2025	18:00	
369	RQ242143	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	Routine testing and Maintenance Works	25/Apr/2025	10:00	25/Apr/2025	18:00	
370	RQ242197	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	25/Apr/2025	09:00	25/Apr/2025	18:00	
371	RQ242268	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	25/Apr/2025	09:00	25/Apr/2025	18:00	
372	RQ242298	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	25/Apr/2025	09:00	25/Apr/2025	17:30	
373	RQ242328	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	25/Apr/2025	09:00	25/Apr/2025	17:30	
374	RQ242642	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	25/Apr/2025	07:00	25/Apr/2025	19:00	
375	RQ242653	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	25/Apr/2025	09:00	25/Apr/2025	18:00	
376	RQ241081	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	26/Apr/2025	08:00	26/Apr/2025	18:00	AR disable
377	RQ241111	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	26/Apr/2025	08:00	26/Apr/2025	18:00	AR disable
378	RQ242022	PLANNED	OCC_589	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	D	AMP work,A/R off of ckt 1 is required. Dia to be kept open at both ends.	26/Apr/2025	08:00	26/Apr/2025	18:00	PG-WR2-KHANDWA

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
379	RQ242146	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor.	26/Apr/2025	06:00	26/Apr/2025	19:00	
380	RQ242147	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	26/Apr/2025	06:00	26/Apr/2025	19:00	
381	RQ242148	PLANNED	OCC_589	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	D	To replace 220kV ABB Bus Bar Relay.	26/Apr/2025	10:00	26/Apr/2025	18:00	
382	RQ242149	PLANNED	OCC_589	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	D	To replace 220kV ABB Bus Bar Relay.	26/Apr/2025	10:00	26/Apr/2025	18:00	
383	RQ242150	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work	26/Apr/2025	08:00	26/Apr/2025	18:00	
384	RQ242151	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	C	1) Cold line washing of strings 2) Routine bay maintenance work	26/Apr/2025	22:00	27/Apr/2025	06:00	
385	RQ242198	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	26/Apr/2025	09:00	26/Apr/2025	18:00	
386	RQ242269	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	26/Apr/2025	09:00	26/Apr/2025	18:00	
387	RQ242299	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	26/Apr/2025	09:00	26/Apr/2025	17:30	
388	RQ242329	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	26/Apr/2025	09:00	26/Apr/2025	17:30	
389	RQ242643	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	26/Apr/2025	07:00	26/Apr/2025	19:00	
390	RQ242654	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	26/Apr/2025	09:00	26/Apr/2025	18:00	
391	RQ241082	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	27/Apr/2025	08:00	27/Apr/2025	18:00	AR disable
392	RQ241112	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	27/Apr/2025	08:00	27/Apr/2025	18:00	AR disable
393	RQ242152	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor.	27/Apr/2025	06:00	27/Apr/2025	19:00	
394	RQ242153	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage is required for safety purpose during replacement of existing 0.4 ACSR Conductor by CCC HTLS Conductor of 220kV PGCIL - Panchali Line.	27/Apr/2025	06:00	27/Apr/2025	19:00	
395	RQ242199	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	27/Apr/2025	09:00	27/Apr/2025	18:00	
396	RQ242270	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	27/Apr/2025	09:00	27/Apr/2025	18:00	
397	RQ242300	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	27/Apr/2025	09:00	27/Apr/2025	17:30	
398	RQ242330	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	27/Apr/2025	09:00	27/Apr/2025	17:30	
399	RQ242644	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	27/Apr/2025	07:00	27/Apr/2025	19:00	
400	RQ240586	PLANNED	OCC_589	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	C	CB DM Overhauling work & AMP work at Aurangabad S/s.	28/Apr/2025	08:00	30/Apr/2025	18:00	AMP WORK

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
401	RQ240640	PLANNED	OCC_589	POWERGRID_WR1	PADGHE-PG - 765KV B/R 1	D	Fine tuning of CSD of ICT, Modifications as per CC AM circulars	28/Apr/2025	10:00	28/Apr/2025	18:00	OUTAGE
402	RQ241083	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	28/Apr/2025	08:00	28/Apr/2025	18:00	AR disable
403	RQ241113	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	28/Apr/2025	08:00	28/Apr/2025	18:00	AR disable
404	RQ241470	PLANNED	OCC_589	TAPS34	220KV-TARAPUR 3&4-TARAPUR 1&2-1	C	SIMULTANEOUS OUTAGE WITH TAPS 1 & 2 FOR LINE PM	28/Apr/2025	08:00	30/Apr/2025	21:00	SIMULTANEOUS OUTAGE WITH TAPS 1 & 2 FOR LINE PM
405	RQ241482	PLANNED	OCC_589	TAPS12	220KV-TARAPUR 3&4-TARAPUR 1&2-1	C	1) TAPS 1&2 to TAPS 3&4 220kV tie line outages to carry out annual maintenance of tie line bay's equipments. 2) Remarks: BS#2 between 220 KV Zone-1 & Zone-III buses will remain open from 0800 hrs of 28/04/2025 to 1800 hrs of 30/04/2025.	28/Apr/2025	08:00	30/Apr/2025	18:00	
406	RQ242200	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	28/Apr/2025	09:00	28/Apr/2025	18:00	
407	RQ242271	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	28/Apr/2025	09:00	28/Apr/2025	18:00	
408	RQ242301	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	28/Apr/2025	09:00	28/Apr/2025	17:30	
409	RQ242331	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	28/Apr/2025	09:00	28/Apr/2025	17:30	
410	RQ242645	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	28/Apr/2025	07:00	28/Apr/2025	19:00	
411	RQ240614	PLANNED	OCC_589	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	D	AMP WORKS of Line terminal equipments at bhadrawati End. AR of Ckt 3 in non auto is required	29/Apr/2025	09:00	29/Apr/2025	18:00	
412	RQ241084	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	29/Apr/2025	08:00	29/Apr/2025	18:00	AR disable
413	RQ241114	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	29/Apr/2025	08:00	29/Apr/2025	18:00	AR disable
414	RQ242156	PLANNED	OCC_589	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT/ CT tan delta, and, isolator maintenance work	29/Apr/2025	16:00	29/Apr/2025	23:59	
415	RQ242201	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	29/Apr/2025	09:00	29/Apr/2025	18:00	
416	RQ242272	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	29/Apr/2025	09:00	29/Apr/2025	18:00	
417	RQ242302	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	29/Apr/2025	09:00	29/Apr/2025	17:30	
418	RQ242332	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	29/Apr/2025	09:00	29/Apr/2025	17:30	
419	RQ242646	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	29/Apr/2025	07:00	29/Apr/2025	19:00	
420	RQ241085	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	30/Apr/2025	08:00	30/Apr/2025	18:00	AR disable
421	RQ241115	PLANNED	OCC_589	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	30/Apr/2025	08:00	30/Apr/2025	18:00	AR disable
422	RQ242157	PLANNED	OCC_589	MSLDC_OUTAGE	BALE - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	30/Apr/2025	10:00	30/Apr/2025	18:00	
423	RQ242202	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work	30/Apr/2025	09:00	30/Apr/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
424	RQ242273	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	30/Apr/2025	09:00	30/Apr/2025	18:00	
425	RQ242303	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	30/Apr/2025	09:00	30/Apr/2025	17:30	
426	RQ242333	PLANNED	OCC_589	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	30/Apr/2025	09:00	30/Apr/2025	17:30	
427	RQ242647	PLANNED	OCC_589	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96 OPGW work by MTCIL	30/Apr/2025	07:00	30/Apr/2025	19:00	

Maharashtra State Load Despatch Centre

Monthly Outage list Not Considered in WRLDC OCCM for the Month of APRIL '2025

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242133	OCC_589	MSLDC_OUTAGE	765KV/400KV KORADI-III-ICT-2	D	Annual Maintenance of MCT & MCVT of ICT-2	23/Apr/2025	09:00	23/Apr/2025	19:00	Repeat entry
RQ242243	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	04/Apr/2025	08:00	04/Apr/2025	18:00	Repeat entry
RQ242242	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	03/Apr/2025	08:00	03/Apr/2025	18:00	Repeat entry
RQ242241	OCC_589	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode and for Fixing of non conductive turbo wing bird guard.	02/Apr/2025	08:00	02/Apr/2025	18:00	Repeat entry
RQ242123	OCC_589	MSLDC_OUTAGE	765KV/400KV KORADI-III-ICT-1	D	Annual Maintenance of MCT & MCVT of ICT-1	21/Apr/2025	09:00	21/Apr/2025	19:00	Repeat entry
RQ242106	OCC_589	MSLDC_OUTAGE	765KV-AKOLA (2)-EKTUNI-1	C	Tower Strengthening Work	16/Apr/2025	08:00	26/Apr/2025	18:00	Repeat entry
RQ242093	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Shifting of 220kV PGCIL - Boisar Line No. 1 on TBC for CB overhauling work.	13/Apr/2025	07:00	13/Apr/2025	19:00	not considered/As discussed in Pre_OCC.
RQ242056	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	C	Shifting of 220kV PGCIL - Boisar Line No. 2 on TBC for CB overhauling work.	05/Apr/2025	06:00	06/Apr/2025	19:00	not considered/As discussed in Pre_OCC.
RQ242082	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Outage is required for safety purpose during Installation of Saver Assembly at various Locations of 220kV Tarapur - Boisar Line.	11/Apr/2025	08:00	11/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242094	OCC_589	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For cold washing of disc insulator strings at TL No. 164, 165, 166, 167, 168, 169, 170, 177, 178, 179, 180, 181, 182, 183, 188, 1192, 200, 201, 202, 203, 204, 205, 233, 240 to avoid any future trippings.89, 190, 191,	13/Apr/2025	08:00	13/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242338	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	06/Apr/2025	08:00	06/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242112	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work	18/Apr/2025	08:00	18/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242044	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	CT Tan D & Quarterly Bay Maintenance	03/Apr/2025	09:00	03/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242362	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	30/Apr/2025	08:00	30/Apr/2025	18:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242361	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	29/Apr/2025	08:00	29/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242360	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	28/Apr/2025	08:00	28/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242359	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	27/Apr/2025	08:00	27/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242358	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	26/Apr/2025	08:00	26/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242357	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	25/Apr/2025	08:00	25/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242144	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	Routine Line maintenance work	25/Apr/2025	08:00	25/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242356	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	24/Apr/2025	08:00	24/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242355	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	23/Apr/2025	08:00	23/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242354	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	22/Apr/2025	08:00	22/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242353	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	21/Apr/2025	08:00	21/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242352	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	20/Apr/2025	08:00	20/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242351	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	19/Apr/2025	08:00	19/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242350	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	18/Apr/2025	08:00	18/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242349	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	17/Apr/2025	08:00	17/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242348	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	16/Apr/2025	08:00	16/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242347	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	15/Apr/2025	08:00	15/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242346	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	14/Apr/2025	08:00	14/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242345	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	13/Apr/2025	08:00	13/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242344	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	PID testing work	12/Apr/2025	08:00	12/Apr/2025	18:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242343	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	11/Apr/2025	08:00	11/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242342	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	10/Apr/2025	08:00	10/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242341	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	09/Apr/2025	08:00	09/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242340	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	08/Apr/2025	08:00	08/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242339	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID testing work	07/Apr/2025	08:00	07/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242118	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work	19/Apr/2025	08:00	19/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242107	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	1) Replacement of 29A bus PG isolator under LES scheme 2)A & B bus PG Isolator maintenance work. 3) line will be in service through TBC 4) CB mechanism O/H work	16/Apr/2025	07:00	20/Apr/2025	23:00	not considered/As discussed in Pre_OCC.
RQ242054	OCC_589	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	CT Tan D, Main-I Distance Relay Testing & Quarterly Bay Maintenance	05/Apr/2025	09:00	05/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242046	OCC_589	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	Hotline washing in all bay RYB-ph equipments.	03/Apr/2025	10:00	03/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242048	OCC_589	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Routine Line Maintenance works and bay maintenance works	04/Apr/2025	10:00	04/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242137	OCC_589	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Routine Line Maintenance works and bay maintenance works	24/Apr/2025	10:00	24/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242155	OCC_589	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Bay maintenance & Diagnostic testing work. CT MK box replacement work	27/Apr/2025	08:00	27/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242154	OCC_589	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	Routine & Pre monsoon maintenance	27/Apr/2025	09:00	27/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242145	OCC_589	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1.For termination of new 19cx2.5 sqmm cable lay between Kalwa-I CB and JB. 2. 400kV Kalwa-I in service through TBC.	25/Apr/2025	09:00	25/Apr/2025	19:00	not considered/As discussed in Pre_OCC.
RQ242206	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	01/Apr/2025	08:00	01/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242043	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	PID Faulty string replacement work & cold line washing work	03/Apr/2025	07:00	03/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242220	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	15/Apr/2025	08:00	15/Apr/2025	17:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242219	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	14/Apr/2025	08:00	14/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242218	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	13/Apr/2025	08:00	13/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242217	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	12/Apr/2025	08:00	12/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242216	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	11/Apr/2025	08:00	11/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242215	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	10/Apr/2025	08:00	10/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242214	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	09/Apr/2025	08:00	09/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242213	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	08/Apr/2025	08:00	08/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242212	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	07/Apr/2025	08:00	07/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242211	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	06/Apr/2025	08:00	06/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242210	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	05/Apr/2025	08:00	05/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242209	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	04/Apr/2025	08:00	04/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242208	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	03/Apr/2025	08:00	03/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242207	OCC_589	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	AR To be kept OFF for PID Testing work	02/Apr/2025	08:00	02/Apr/2025	17:00	not considered/As discussed in Pre_OCC.
RQ242078	OCC_589	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	Hotline washing in all bay RYB-ph equipments	10/Apr/2025	10:00	10/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242081	OCC_589	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	Hotline washing in all bay RYB-ph equipments	11/Apr/2025	10:00	11/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242058	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning	06/Apr/2025	09:00	06/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242090	OCC_589	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning	13/Apr/2025	09:00	13/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242039	OCC_589	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Hotline washing in all bay RYB-ph equipments.	02/Apr/2025	10:00	02/Apr/2025	18:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242158	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	01/Apr/2025	09:00	01/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242225	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	01/Apr/2025	09:00	01/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242172	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	15/Apr/2025	09:00	15/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242239	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	15/Apr/2025	09:00	15/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242171	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	14/Apr/2025	09:00	14/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242238	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	14/Apr/2025	09:00	14/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242170	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	13/Apr/2025	09:00	13/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242237	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	13/Apr/2025	09:00	13/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242169	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	12/Apr/2025	09:00	12/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242236	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	12/Apr/2025	09:00	12/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242168	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	11/Apr/2025	09:00	11/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242235	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	11/Apr/2025	09:00	11/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242167	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	10/Apr/2025	09:00	10/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242234	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	10/Apr/2025	09:00	10/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242166	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	09/Apr/2025	09:00	09/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242233	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	09/Apr/2025	09:00	09/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242165	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	08/Apr/2025	09:00	08/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242232	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	08/Apr/2025	09:00	08/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242164	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	07/Apr/2025	09:00	07/Apr/2025	18:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242231	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	07/Apr/2025	09:00	07/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242163	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	06/Apr/2025	09:00	06/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242230	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	06/Apr/2025	09:00	06/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242162	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	05/Apr/2025	09:00	05/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242229	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	05/Apr/2025	09:00	05/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242161	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	04/Apr/2025	09:00	04/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242228	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	04/Apr/2025	09:00	04/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242160	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	03/Apr/2025	09:00	03/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242227	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	03/Apr/2025	09:00	03/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242159	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work	02/Apr/2025	09:00	02/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242226	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	02/Apr/2025	09:00	02/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242411	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	17/Apr/2025	09:00	17/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242390	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	16/Apr/2025	09:00	16/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242108	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) Bay maintenance work.(3) Hardware tightening & fitting work	17/Apr/2025	09:00	17/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242404	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	30/Apr/2025	09:00	30/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242424	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	30/Apr/2025	09:00	30/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242403	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	29/Apr/2025	09:00	29/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242423	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	29/Apr/2025	09:00	29/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242402	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	28/Apr/2025	09:00	28/Apr/2025	18:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242422	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	28/Apr/2025	09:00	28/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242401	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	27/Apr/2025	09:00	27/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242421	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	27/Apr/2025	09:00	27/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242400	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	26/Apr/2025	09:00	26/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242420	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	26/Apr/2025	09:00	26/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242399	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	25/Apr/2025	09:00	25/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242419	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	25/Apr/2025	09:00	25/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242398	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	24/Apr/2025	09:00	24/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242418	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	24/Apr/2025	09:00	24/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242397	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	23/Apr/2025	09:00	23/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242417	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	23/Apr/2025	09:00	23/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242396	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	22/Apr/2025	09:00	22/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242416	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	22/Apr/2025	09:00	22/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242395	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	21/Apr/2025	09:00	21/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242415	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	21/Apr/2025	09:00	21/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242394	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	20/Apr/2025	09:00	20/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242414	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	20/Apr/2025	09:00	20/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242393	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	19/Apr/2025	09:00	19/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242413	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	19/Apr/2025	09:00	19/Apr/2025	18:00	not considered/As discussed in Pre_OCC.

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	Requested From Date	Requested From	Requested To Date	Requested To Time	Rpc Remarks
RQ242392	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	18/Apr/2025	09:00	18/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242412	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work	18/Apr/2025	09:00	18/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242391	OCC_589	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	17/Apr/2025	09:00	17/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242103	OCC_589	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	400 kV BUS CVT Tan D	15/Apr/2025	09:00	15/Apr/2025	18:00	not considered/As discussed in Pre_OCC.
RQ242086	OCC_589	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	C	220kV A-Bus Isolator R/M Works.	12/Apr/2025	07:00	13/Apr/2025	20:00	not considered/As discussed in Pre_OCC.
RQ242117	OCC_589	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	C	1) Bay strengthening of 220kV Tarapur Bay & 220kV Ghodbunder Bay. 2) Bay Maintenance & Equipment Testing of 220kV B-Bus.	19/Apr/2025	07:00	20/Apr/2025	20:00	not considered/As discussed in Pre_OCC.

State Element outage list for the month of APRIL '2025

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	02-Apr-25	08:00	02-Apr-25	18:00	Daily	1)Anti corrosive painting work of ICT-2 , 2)Quarterly Maintenance Work of ICT ₂ s & Bay Equipment 3)Diagnostic Testing Work 4)Premansoon maintenance work 5)Installation of Rugged Monitoring for pilot purpose	MSETCL	MSETCL	the load will be shifted on ICT 1 and ICT-3
3	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	02-Apr-25	16:00	02-Apr-25	22::00	Daily	Placing of Repair sleeve at loc 69-70 on damage conductor	MSETCL	MSETCL	Placing of Repair sleeve at loc 69-70 on damage conductor
4	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	02-Apr-25	09:00	02-Apr-25	18:00	Daily	Chemical Cleaning of Equipment & Quarterly Bay Maintenance	MSETCL	MSETCL	400 kV Bhusawal, Ektuni-I&IIDhule-I &II will be in service
5	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	02-Apr-25	10:00	02-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
6	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	03-Apr-25	08:00	03-Apr-25	18:00	Daily	1)Anti corrosive painting work of ICT-2 , 2)Quarterly Maintenance Work of ICT ₂ s & Bay Equipment 3)Diagnostic Testing Work 4)Premansoon maintenance work 5)Installation of Rugged Monitoring for pilot purpose	MSETCL	MSETCL	the load will be shifted on ICT 1 and ICT-3
7	400 KV	WARORA - IEPL	03-Apr-25	09:00	08-Apr-25	17:00	Daily	Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	NA
8	400 KV	400KV NANDED(KUMBHARGAON)-PARLY CKT 2	03-Apr-25	16:00	03-Apr-25	22:00	Daily	Placing of Repair sleeve at loc 41-40 on damage conductor	MSETCL	MSETCL	Placing of Repair sleeve at loc 41-40 on damage conductor
10	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	03-Apr-25	7:00	03-Apr-25	16:00	Daily	DT & Haly Yearly Mainte.	MSETCL	MSETCL	-
12	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	03-Apr-25	16:30	03-Apr-25	23:59	Daily	For Maintenance & Testing work., Cooling Pump replacement work	MSETCL	MSETCL	ICT-I & ICT-II will continue to remain in service
14	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	04-Apr-25	08:00	04-Apr-25	18:00	Daily	1)Anti corrosive painting work of ICT-2 , 2)Quarterly Maintenance Work of ICT ₂ s & Bay Equipment 3)Diagnostic Testing Work 4)Premansoon maintenance work 5)Installation of Rugged Monitoring for pilot purpose	MSETCL	MSETCL	the load will be shifted on ICT 1 and ICT-3
15	400 KV	DEEPNAGAR - THAPTI TANDA	04-Apr-25	06:00	04-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement Work	MSETCL	MSETCL	Necessary
19	400 KV	CHANDRAPUR-PARLI CKT-3	04-Apr-25	09:00	04-Apr-25	18:00	Daily	(1) CB tesing work. (2) Bay maintenance work.(3) Hardware tightening & fitting work	MSETCL	MSETCL	-
20	400 KV	BUS REACTOR (125 MVA) @ ALKUD	04-Apr-25	10:00	04-Apr-25	17:00	Daily	Diagnostic Testing & Maintenance work	MSETCL	MSETCL	--
21	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	04-Apr-25	10:00	04-Apr-25	17:00	Daily	Diagnostic Testing & Maintenance work	MSETCL	MSETCL	--
22	400 KV	NEW KOYNA-KARAD CKT - 2	04-Apr-25	08:00	04-Apr-25	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
23	400 KV	TBC @ CHAKAN	04-Apr-25	10:00	04-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
24	400 KV	DEEPNAGAR - THAPTI TANDA	05-Apr-25	06:00	05-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement Work	MSETCL	MSETCL	Necessary

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
25	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	05-Apr-25	06:00	05-Apr-25	20:00	Daily	For Diagnostic Testing of ICT with Routine Pre-Monsoon Maintenance Work on Both HV & LV Bay	MSETCL	MSETCL	During outage, Load of can be managed on 400/220 kV 501 MVA ICT 2
26	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	05-Apr-25	08:00	05-Apr-25	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV other lines will be in in service
27	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	05-Apr-25	10:00	05-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
28	400 KV	TBC @ CHAKAN	05-Apr-25	10:00	05-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
29	400 KV	DEEPNAGAR - THAPTI TANDA	07-Apr-25	06:00	07-Apr-25	18:00	Daily	Maintenance work like disc replacement and nut-bolt tightening work	MSETCL	MSETCL	Work to be carried out by AMC agency
30	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	07-Apr-25	06:00	07-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement Work	MSETCL	MSETCL	Necessary Work
31	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	07-Apr-25	08:00	08-Apr-25	18:00	Continuous	Transformer Oil Filtration of R Ph & B Ph Unit & Painting Work of R Y & B Ph Unit	MSETCL	MSETCL	NA
33	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	07-Apr-25	09:00	07-Apr-25	18:00	Daily	1) Winding Resistance, IR Value testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
34	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	07-Apr-25	09:00	07-Apr-25	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Load will be managed from ICT - 1 & 3
35	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	07-Apr-25	08:00	07-Apr-25	18:00	Daily	For verification of RRS Scheme along with Spare ICT. HV CB DCRM ,Timing and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
36	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	07-Apr-25	08:00	07-Apr-25	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -III.	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-III.
37	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	08-Apr-25	06:00	08-Apr-25	18:00	Daily	maintenance work like disc replacement, nut bolt tightening	MSETCL	MSETCL	Work to be carried out by AMC agency
38	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	08-Apr-25	08:00	08-Apr-25	17:00	Daily	1)Quarterly Maintenance Work of ICT's & Bay Equipment 2)Diagnostic Testing Work 3)Premonsoon maintenance work	MSETCL	MSETCL	ICT II & ICT III will be in service
39	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	08-Apr-25	06:00	08-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement Work	MSETCL	MSETCL	Necessary Work
40	400 KV	STATION TF No 4 @ CHANDRAPUR GCR	08-Apr-25	04:00	08-Apr-25	18:00	Daily	1. Measurement of tandelta & C of CT. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.	MSETCL	MSETCL	1. 400KV STN TF-5 will be in service. 2. Diagnostic Testing and routine maintenance of various equipment.
42	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	08-Apr-25	10:00	08-Apr-25	18:00	Daily	BUSHING TAN-DALTA	MSETCL	MSETCL	NA
43	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	08-Apr-25	17:00	08-Apr-25	23:59	Daily	Diagnostic Testing & Maintenance work	MSETCL	MSETCL	--
44	400 KV	400/220 KV 500 MVA ICT @ ALKUD	08-Apr-25	17:00	08-Apr-25	23:59	Daily	Diagnostic Testing & Maintenance work	MSETCL	MSETCL	Load will be managed on 400KV Talandge & Karad
45	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	09-Apr-25	06:00	09-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement Work	MSETCL	MSETCL	Necessary Work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
46	400 KV	CHANDRAPUR-PARLI CKT-3	09-Apr-25	16:00	09-Apr-25	23:59	Daily	1. Diagnostic testing of Circuit Breaker. 2. Maintenance and alignment of PG-1 & PG-2 Isolator. 3. 400KV Parli CKT-3 will be in service via 400KV TBC-1.	MSETCL	MSETCL	400KV Parli CKT-3 will be in service via 400KV TBC-1.
48	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	09-Apr-25	08:00	09-Apr-25	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-III
49	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	09-Apr-25	08:00	09-Apr-25	18:00	Daily	For restoration ICT -III from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
50	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	09-Apr-25	10:00	09-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
51	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	09-Apr-25	10:00	09-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipment	MSETCL	MSETCL	-
106	220 KV	220kV REL Life Science (GIS) -NASIK-1	09-Apr-25	09:00	11-Apr-25	19:00	Continuous	1. LILO connection on 220kV Ekhare-Reliance life science line for CPRI S/S 2. PLCC re-arrangement/re-tuning from Ekhare- Reliance life science into Ekhare- CPRI Reliance life science setup. 3. And charging of CPRI S/S Bus.	MSETCL	MSETCL	Outage is required for making LILO point connection on (at Loc. 19) at Loc. 1 in r/o new 220kV CPRI Line and charging of new 220kV CPRI Substation. This is OCCM Outage proposal. This outage be granted subject to permission from MSLDC Kalwa and fulfillment of all needful documents.
52	400 KV	400 KV SWITCHYARD @ DEEPNAGAR	10-Apr-25	09:00	10-Apr-25	17:00	Daily	for LA LCM OF ALL 400 KV LA	MSETCL	MSETCL	ONLINE WORK HENCE NO INTERRUPTION
53	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	10-Apr-25	10:00	10-Apr-25	18:00	Daily	DCRM OF 404 ICT-1 CB	MSETCL	MSETCL	DIAGNOSTIC WORK
54	400 KV	LONIKAND I - KOYNA STAGE-IV	10-Apr-25	09:00	10-Apr-25	17:00	Daily	PID Faulty string replacement work & cold line washing work	MSETCL	MSETCL	PIF Faulty string replacement work & cold line washing work
55	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	10-Apr-25	09:00	10-Apr-25	18:00	Daily	Diagnostic Testing & Maintenance work	MSETCL	MSETCL	--
56	400 KV	DHULE- - BABLESHWAR CKT - 1	10-Apr-25	09:00	10-Apr-25	18:00	Daily	CT & CVT Tan D, LBB Relay, CB DCRM Timing & Quarterly Bay Maintenance	MSETCL	MSETCL	400kv Aurgangabad, Bhusawal, Ektunin-I&II Dhule-II will be in service.
57	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	10-Apr-25	09:00	10-Apr-25	18:00	Daily	Routine Maintenance ,Oil leakages attending work	MSETCL	MSETCL	-
58	400 KV	MAIN BAY (419) OF 400/220/33KV 500MVA ICT-I @ LONIKAND 2	10-Apr-25	09:00	10-Apr-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
59	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	10-Apr-25	09:00	10-Apr-25	18:00	Daily	DT & Haly Yearly Mainte.	MSETCL	MSETCL	-
60	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	10-Apr-25	10:00	10-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
61	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	10-Apr-25	09:00	10-Apr-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
62	400 KV	TIE BAY (414) OF ICT-2 & FUTURE BAY @ TAPTITANDA	11-Apr-25	11:00	11-Apr-25	18:00	Daily	Routine maintenance and testing work of CB & CT	MSETCL	MSETCL	Outage required for Routine maintenance and testing work of CB & CT
63	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	11-Apr-25	10:00	11-Apr-25	18:00	Daily	1) Diagnostic Testing Work and Routine Maintenance Work. 2) Corona Ring Replacement, Spacer Replacement & Line Maintenance work.	MSETCL	MSETCL	Work to be carried out by AMC Agency for Line Work.

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
64	400 KV	STATION TF - 1 @ KORADI -2	11-Apr-25	08:00	11-Apr-25	17:00	Daily	Tan Delta measurement of Metering CT	MSETCL	MSETCL	STN TF 2 and 3 will serve as alternate supply
65	400 KV	400KV MAIN BAY 412 OF 125MVAr BUS REACTOR @400KV KUMBHARGAON SS	11-Apr-25	10:00	11-Apr-25	18:00	Daily	DCRM OF 412 REACTOR MAIN BAY CB	MSETCL	MSETCL	DIAGNOSTIC WORK
66	400 KV	KHADKA - BABLESHWAR	11-Apr-25	09:00	11-Apr-25	18:00	Daily	CB CRM, DCRM Timing	MSETCL	MSETCL	Line will be in service through TBC
67	400 KV	BUS REACTOR (125 MVAr) @ LONIKAND 2	11-Apr-25	10:00	11-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
68	400 KV	400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	12-Apr-25	08:00	12-Apr-25	18:00	Daily	Annual Maintenance of 500MVA ICT-1	KVTL	KVTL	ICT Outage
69	400 KV	KHADKA - BABLESHWAR	12-Apr-25	08:00	12-Apr-25	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV other lines will be in in service
70	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	12-Apr-25	10:00	12-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
71	400 KV	SPARE LINE @ LONIKAND 2	12-Apr-25	10:00	12-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
72	400 KV	400/220/20 KV 500MVA ICT - 3 @ KALWA	13-Apr-25	06:00	13-Apr-25	14:00	Daily	oil circulating pump replacement work	MSETCL	MSETCL	oil circulating pump replacement work
73	400 KV	JAIGAD - NEW KOYNA CKT - 1	14-Apr-25	09:00	19-Apr-25	18:00	Daily	HOTLINE WASHING WORK (AR OUT JAIGAD NEWKOYNA CKT 1)	JPTL	JPTL	HOTLINE WASHING WORK (AR OUT JAIGAD NEWKOYNA CKT 1)
74	400 KV	JAIGAD - NEW KOYNA CKT - 2	14-Apr-25	09:00	19-Apr-25	18:00	Daily	HOTLINE WASHING WORK (AR OUT JAIGAD NEWKOYNA CKT 2)	JPTL	JPTL	HOTLINE WASHING WORK (AR OUT JAIGAD NEWKOYNA CKT 2)
75	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	14-Apr-25	08:00	14-Apr-25	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -IV.	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-IV.
76	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	14-Apr-25	08:00	14-Apr-25	18:00	Daily	For verification of RRS Scheme along with Spare ICT.	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
77	400 KV	400/220/33KV SPARE ICT @ KORADI 2	15-Apr-25	08:00	15-Apr-25	17:00	Daily	Maintenance of isolators connected to main bus 2	MSETCL	MSETCL	Sppare ICT is on no load. Spare ICT is to be handtripped for Bus 2 Outage
78	400 KV	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	16-Apr-25	07:00	16-Apr-25	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
79	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	16-Apr-25	10:00	16-Apr-25	14:00	Daily	Diagnostic Testing of ICT,CT & CB	MSETCL	MSETCL	NA
80	400 KV	KORADI-NANDGAONPETH (RPL)	16-Apr-25	09:00	16-Apr-25	18:00	Daily	WINDING & BUSHING OF REACTOR . CVT TAN-DELTA& ROUTINE MNTC WORK.	MSETCL	MSETCL	NA
81	400 KV	400/220/33KV SPARE ICT @ KORADI 2	16-Apr-25	08:00	16-Apr-25	17:00	Daily	Maintenance of isolators connected to main bus 2	MSETCL	MSETCL	Sppare ICT is on no load. Spare ICT is to be handtripped for Bus 2 Outage
82	400 KV	LONIKAND I - KOYNA STAGE-IV	16-Apr-25	08:00	30-Apr-25	17:00	Daily	AR To be kept OFF for PID	MSETCL	MSETCL	AR To be kept OFF for PID Testing work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
83	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	16-Apr-25	08:00	16-Apr-25	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-IV
84	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	16-Apr-25	08:00	16-Apr-25	18:00	Daily	For restoration ICT -IV from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
85	400 KV	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	16-Apr-25	10:00	16-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments	MSETCL	MSETCL	-
86	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	16-Apr-25	10:00	16-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments	MSETCL	MSETCL	-
9	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	17-Apr-25	11:00	17-Apr-25	19:00	Daily	DCRM OF MAIN BAY 402 CB	MSETCL	MSETCL	DIAGNOSTIC WORK
87	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 1END)	17-Apr-25	08:00	17-Apr-25	18:00	Daily	1. Numerical Relay testing work. 2. LBB relay testing work. 3. Maintenance and alignment of Isolator. 4. Hardware and nutbolt tightening work of bay equipment, jumper etc. 5. Routine bay maintenance work.	MSETCL	MSETCL	400KV CHD-2 CKT-1, 400KV K'kheda, Parli ckt-3, HVDC CKT-1 & 2, PGCIL CKT-1 to 4 will be in service.
88	400 KV	400/220/33KV SPARE ICT @ KORADI 2	17-Apr-25	08:00	17-Apr-25	17:00	Daily	Maintenance of isolators connected to main bus 2	MSETCL	MSETCL	Sppare ICT is on no load. Spare ICT is to be handtripped for Bus 2 Outage
89	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	17-Apr-25	11:00	17-Apr-25	19:00	Daily	Earthwire stinging work Loc.no 497-498 & Nut bolt hardware tightning work	MSETCL	MSETCL	-
90	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	17-Apr-25	10:00	17-Apr-25	18:00	Daily	DCRM OF 405 MAIN BAY CB	MSETCL	MSETCL	DIAGNOSTIC WORK
91	400 KV	JEJURI- KOYNA STAGE-IV	17-Apr-25	09:00	17-Apr-25	17:00	Daily	PID Faulty string replacement work & cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work & cold line washing work
92	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	17-Apr-25	09:00	17-Apr-25	18:00	Daily	Routine Maintenance,Relay Testing work.	MSETCL	MSETCL	-
93	400 KV	MAIN BAY (403) OF LONIKAND CKT @ JEJURI	17-Apr-25	10:00	17-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
94	400 KV	TIE BAY (405) OF ICT -2 AND STG-4 @ JEJURI	17-Apr-25	10:00	17-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments	MSETCL	MSETCL	-
95	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	17-Apr-25	09:00	17-Apr-25	18:00	Daily	DT & Haly Yearly Mainte.	MSETCL	MSETCL	-
96	400 KV	LONIKAND - JEJURI CKT - 2	17-Apr-25	10:00	17-Apr-25	18:00	Daily	PID detected strings replacement and Cold line washing of strings	MSETCL	MSETCL	-
97	400 KV	MAIN BAY (408) OF ICT - 3 @ JEJURI	17-Apr-25	09:30	17-Apr-25	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-III will be in service through 409 Tie Bay.
134	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	17-Apr-25	08:00	17-Apr-25	18:00	Daily	For routine maintenance work	MSETCL	MSETCL	Outage
98	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	18-Apr-25	10:00	18-Apr-25	18:00	Daily	Relay Testing work & Routine Maintenance Work.	MSETCL	MSETCL	NIL
99	400 KV	KHADKA-AURANGABAD (WALUJ)	18-Apr-25	06:00	18-Apr-25	18:00	Daily	P&F of repair sleeves to damaged conductor & Cold line washing work	MSETCL	MSETCL	Necessary Work
100	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	18-Apr-25	06:00	18-Apr-25	18:00	Daily	Line Maintenance work at various tower locations.	MSETCL	MSETCL	NA
101	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	18-Apr-25	10:00	18-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
102	400 KV	400/220kv SPARE ICT @ JEJURI	18-Apr-25	10:00	18-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
103	400 KV	KHADKA - BABLESHWAR	19-Apr-25	06:00	19-Apr-25	18:00	Daily	P&F of repair sleeves to damaged conductor & cold line washing work	MSETCL	MSETCL	Necessary work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
104	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	19-Apr-25	06:00	19-Apr-25	20:00	Daily	For Diagnostic Testing of ICT with Routine Pre-Monsoon Maintenance Work on Both HV & LV Bay	MSETCL	MSETCL	During outage, Load can be managed on 400/220 kV 501 MVA ICT 1
105	400 KV	KORADI-NANDGAONPETH (RPL)	19-Apr-25	06:00	19-Apr-25	18:00	Daily	Line Maintenance work at various tower locations.	MSETCL	MSETCL	NA
107	400 KV	400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	19-Apr-25	08:00	19-Apr-25	18:00	Daily	Annual Maintenance of 500MVA ICT-2	KVTL	KVTL	ICT Outage
108	400 KV	TIE BAY (412) OF KARAD CKT @ JEJURI	19-Apr-25	10:00	19-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
109	400 KV	MAIN BAY (413) OF KARAD CKT @ JEJURI	19-Apr-25	10:00	19-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
110	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	20-Apr-25	08:00	20-Apr-25	20:00	Daily	Bay maintenace & Diagnostic testing. height raising of fire wall work .hot spot attending work	MSETCL	MSETCL	Bay maintenace & Diagnostic testing. height raising of fire wall work .hot spot attending work
111	400 KV	DEEPNAGAR - THAPTI TANDA	21-Apr-25	06:00	21-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement work	MSETCL	MSETCL	Necessary work
112	400 KV	JAIGAD - KARAD CKT - 1	21-Apr-25	09:00	26-Apr-25	18:00	Daily	HOTLINE WASHING WORK (AR OUT JAIGAD KARAD CKT 1)	JPTL	JPTL	HOTLINE WASHING WORK (AR OUT JAIGAD KARAD CKT 1)
113	400 KV	JAIGAD - KARAD CKT - 2	21-Apr-25	09:00	26-Apr-25	18:00	Daily	HOTLINE WASHING WORK (AR OUT JAIGAD KARAD CKT 2)	JPTL	JPTL	HOTLINE WASHING WORK (AR OUT JAIGAD KARAD CKT 2)
114	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	22-Apr-25	10:00	22-Apr-25	18:00	Daily	Corona Ring Replacement, Spacer Replacement & Line Maintenance work.	MSETCL	MSETCL	Work will be carried out under AMC.
115	400 KV	DEEPNAGAR - THAPTI TANDA	22-Apr-25	06:00	22-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement work	MSETCL	MSETCL	Necessary work
117	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	22-Apr-25	08:00	22-Apr-25	18:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Maintenance and alignment of Isolators. 3. Replacement of faulty disc insulator string of Aux Bus (Section-1) in span of '400KV CHD-2 CKT-1'.	MSETCL	MSETCL	1. Replacement of faulty disc insulator of 03No. Insulator string of Auxilliary Bus (Section-1) in span of 400KV CHD-2 CKT-1 bay. 2. Hardware tightening work of Aux Bus Section-1 in a span of 400KV CHD-2 CKT-1 bay.
118	400 KV	400 KV AUX BUS @ CHANDRAPUR	22-Apr-25	08:00	22-Apr-25	18:00	Daily	1. Replacement of faulty disc insulator of 03No. Insulator string of Auxilliary Bus (Section-1) in span of 400KV CHD-2 CKT-1 bay. 2. Hardware tightening work of Aux Bus Section-1 in a span of 400KV CHD-2 CKT-1 bay.	MSETCL	MSETCL	1. Replacement of 03No. faulty disc insulator of Auxilliary Bus (Section-1) in span of 400KV CHD-2 CKT-1 bay. 2. Disc Insulator 03No.s string found faulty during PID testing work.
119	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	23-Apr-25	08:00	23-Apr-25	18:00	Daily	For replacement of Insulator Disc	MSETCL	MSETCL	Outage. Work will be Carried out through Agency
120	400 KV	DEEPNAGAR - THAPTI TANDA	23-Apr-25	06:00	23-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement work	MSETCL	MSETCL	Necessary work
121	400 KV	MAIN BAY (403) OF CHANDRAPUR GCR CKT - 1 @ CHANDRAPUR - 2	23-Apr-25	10:00	23-Apr-25	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
122	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	23-Apr-25	10:00	23-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
123	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	23-Apr-25	10:00	23-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
124	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	24-Apr-25	08:00	24-Apr-25	18:00	Daily	For replacement of Insulator Disc	MSETCL	MSETCL	Outage. Work will be Carried out through Agency
125	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	24-Apr-25	06:00	24-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement work	MSETCL	MSETCL	Necessary work
126	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	24-Apr-25	10:00	24-Apr-25	18:00	Daily	DCRM OF 408 MAIN BAY CB	MSETCL	MSETCL	DIAGNOSTIC WORK
128	400 KV	400/220KV 315 MVA ICT - 3 @ NEW KOYNA	24-Apr-25	06:00	25-Apr-25	18:00	Continuous	Painting work & Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	Planned outage
129	400 KV	JEJURI - KARAD	24-Apr-25	08:00	24-Apr-25	17:00	Daily	PID Faulty string replacement work & cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work & cold line washing work
130	400 KV	TIE BAY (409) OF LONIKAND 2 AND ICT - 3 @ JEJURI	24-Apr-25	09:30	24-Apr-25	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-III will be in service through 408 Own Bay.
131	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	24-Apr-25	09:00	24-Apr-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
132	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	24-Apr-25	09:00	24-Apr-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
133	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	24-Apr-25	09:00	24-Apr-25	18:00	Daily	DT & Haly Yearly Mainte.	MSETCL	MSETCL	-
135	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	25-Apr-25	06:00	25-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement work	MSETCL	MSETCL	Necessary work
136	400 KV	GT-8 @ KORADI-2	25-Apr-25	08:00	25-Apr-25	17:00	Daily	Tan Delta measurement of Metering CT	MSETCL	MSETCL	GT 8 and GT 10 will remain in service
137	400 KV	TBC @ LONIKAND	25-Apr-25	10:00	25-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
138	400 KV	LONIKAND I - KOYNA STAGE-IV	25-Apr-25	10:00	25-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
139	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	26-Apr-25	10:00	26-Apr-25	18:00	Daily	Replacement of flash-over Discs and replacement of Nut Bolts	MSETCL	MSETCL	Work will be carried out in AMC.
140	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	26-Apr-25	06:00	26-Apr-25	18:00	Daily	Midspan Joint & Dead End Replacement work	MSETCL	MSETCL	Necessary work
141	400 KV	400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	26-Apr-25	08:00	26-Apr-25	18:00	Daily	Annual Maintenance of 500MVA ICT-3	KVTL	KVTL	ICT Outage
142	400 KV	LONIKAND - JEJURI CKT - 2	26-Apr-25	10:00	26-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments	MSETCL	MSETCL	-
143	400 KV	LONIKAND - JEJURI CKT - 1	26-Apr-25	10:00	26-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments	MSETCL	MSETCL	-
144	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	27-Apr-25	10:00	27-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
145	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	27-Apr-25	10:00	27-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments	MSETCL	MSETCL	-
146	400 KV	KHADKA-AURANGABAD (WALUJ)	28-Apr-25	06:00	28-Apr-25	18:00	Daily	P&F of repair sleeves to damaged conductor & Cold line washing work	MSETCL	MSETCL	Necessary work
147	400 KV	MAIN BAY-425 OF GT-8 @ KORADI-2	28-Apr-25	08:00	28-Apr-25	17:00	Daily	Diagnostic testing of CB 425-Q52	MSETCL	MSETCL	GT 8 will remain in service through tie bay 426
148	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	28-Apr-25	06:00	29-Apr-25	18:00	Continuous	Painting work & Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	Planned outage
149	400 KV	KHADKA - BABLESHWAR	29-Apr-25	06:00	29-Apr-25	18:00	Daily	P&F of repair sleeves to damaged conductor & Cold line washing work	MSETCL	MSETCL	Necessary work
150	400 KV	TBC @ BABHALESHWAR	29-Apr-25	09:00	29-Apr-25	18:00	Daily	LBB Relay CT Tan D & Quarterly Bay Maintenance	MSETCL	MSETCL	TBC is Free
151	400 KV	TIE BAY - 414 OF GT-9 @ KORADI-2	30-Apr-25	08:00	30-Apr-25	17:00	Daily	Diagnostic testing of CB 414-Q52	MSETCL	MSETCL	GT 9 will remain in service through tie bay
152	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	30-Apr-25	09:00	30-Apr-25	18:00	Daily	Bushing TanD & Quarterly Bay Maintenance	MSETCL	MSETCL	Outage in on spare ICT-I

Maharashtra State Load Despatch Centre

State Element outage list Not Considered for the month of APRIL '2025

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	CHANDRAPUR - KHAPERKHEDA	02-Apr-25	10:00	02-Apr-25	18:00	Daily	DCRM of Main CB & Tie CB	MSETCL	MSETCL	NA
2	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	03-Apr-25	10:00	03-Apr-25	18:00	Daily	Hotline washing in all bay RYB-ph equipments.	MSETCL	MSETCL	-
3	400 KV	KHADKA-AURANGABAD (WALUJ)	04-Apr-25	10:00	04-Apr-25	18:00	Daily	1) Diagnostic Testing and Routine Maintenance work. 2) Nut Bolt Tightening and Line Maintenance Work.	MSETCL	MSETCL	Work to be carried out by AMC Agency for Line Work
4	400 KV	400 KV FUTURE BAY II @ WARORA	04-Apr-25	08:00	04-Apr-25	18:00	Daily	CB DCRM/CRM/Timing, Routine maintenance and Line/Bus/Tie CT TAN DELTA, IR and isolator maintenance work etc .	MSETCL	MSETCL	400KV PGCIL (Nagri) will be charged through Tie CB 421.
5	400 KV	400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	04-Apr-25	07:00	04-Apr-25	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
6	400 KV	KORADI II - IEPL	04-Apr-25	06:00	04-Apr-25	18:00	Daily	Line Maintenance work at various tower locations.	MSETCL	MSETCL	NA
7	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	07-Apr-25	08:00	07-Apr-25	17:00	Daily	Diagnostic testing of ICT 1	MSETCL	MSETCL	Load will be shifted to ICT 2
8	400 KV	400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	08-Apr-25	07:00	08-Apr-25	13:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
9	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	09-Apr-25	08:00	09-Apr-25	17:00	Daily	Diagnostic testing of ICT 2	MSETCL	MSETCL	Load will be shifted to ICT 1
10	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	22-Apr-25	08:00	28-Apr-25	22:00	Continuous	CB R, Y, B ph pole Overhauling, CB R, Y, B ph pole Mechanism overhauling Work.	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
11	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	24-Apr-25	09:00	24-Apr-25	18:00	Daily	Earthwire stinging work Loc.no 499-500 & Nut bolt hardware tightening work	MSETCL	MSETCL	-