

WRPC OCCM approved Monthly Outage list for the Month of May'2018

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	REMARKS	SLDC Comments
				Date	Time	Date	Time							
1	1	400	400 S/C Koradi I -India Bull	01/May/18	7:00	02/May/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L part 2 at power line crossing section	MSETCL	WR-II	C	One by one	Whether D/C outage is required ?
2	2	400	400 S/C Koradi I -Bhuswal	01/May/18	7:00	02/May/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L part 2 at power line crossing section	MSETCL	WR-II	C	one by one	Whether D/C outage is required ?
3	23	220KV	Deoli (PGCIL)- Pusad line	01/May/18	7:00	07/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
4	27	400	Chandrapur 2 - Kumbhargaoon (Nanded) Ckt-I	01/May/18	6:00	15/May/18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
5	35	400	400 Jejuri - Lonikand	01/May/18	7:00	31/May/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
6	36	400	400 Warora -Chandrapur I& II	01/May/18	7:00	31/May/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
7	37	400	400 Koradi-1 -Khaparkheda I & II	01/May/18	7:00	31/May/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
8	38	400	Chandrapur GCR - Chandrapur -2 (Ckt-1 &2)	01/May/18	7:00	31/May/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
9	39	400	Chandrapur -2 Chandrapur Switch (Ckt-1 &2)	01/May/18	7:00	31/May/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
10	40	400	Ektuni - Thaptithanda (Ckt-1 & ckt-2)	01/May/18	7:00	31/May/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
11	43	400	400 N.Koyna-Karad Ckt 1 & 2	01/May/18	10:00	31/May/18	17:00	Daily	For PID testing work / Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	Auto-Reclose required to be OFF for PID as well as OPGW		
12	56	400	Solapur (PGCIL) @LAMBOTI	02/May/18	8:00	02/May/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
13	64	220KV	Mudshingi -chikodi @Mudshingi	02/May/18	9:00	02/May/18	17:00	Daily	Quarterly Maintenance work of Chikodi bay equipments.	MSETCL	MSETCL		NLDC consent required	
14	74	220	Wardha-Wardha (PGCIL)	02/May/18	10.00 AM	02/May/18	17:00	Daily	Disc replacement	MSETCL	MSETCL			
15	77	220KV	PGCIL Deoli-Badnera Ckt @Badnera	02/May/18	8:00	05/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	For PID Work		
16	79	400	Chandrapur II- Nanded Ckt-I	02/May/18	8:00	16/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	NIL		
17	83	400/220kV	315MVA, ICT-1 @ 400 Dhule	03/May/18	9:00	14/May/18	18:00	Continuous	Replacement of Y-ph unit & premonsoon Maint & testing	MSETCL	MSETCL		Replacement needed these many days?	
18	87	400	400 Khadka-Akola S/C @ 400 Khadka end	03/May/18	6:00	04/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
19	93	400/220/33KV	ICT-2 (Bay No. 406 & TIE Bay no 407)@400 s/s warora .	03/May/18	7:00	03/May/18	17:00	Daily	Protection Relay testing works Routine maintenance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintenance work.	MSETCL	MSETCL	(Bay No 407 charged upto line CT 400 ICT No-2 handed over to 400 Padghe)		
20	94	400	403-Bay (Tie Bay of 501MVA ICT-1 & 400 Chandarpur ckt-1) at 400 Nanded	03/May/18	8:00	03/May/18	11:00	Daily	Premonsoon Maintenance to cover PRV, Buchholz, OSR, Aux. protection trials etc. (Outage on Main & TIE bay is necessary for this work)	MSETCL	MSETCL			
21	109	220	PGCIL Deoli -Badnera @ Badnera	03/May/18	10.00 AM	03/May/18	17:00	Daily	Disc replacement	MSETCL	MSETCL			
22	117	400	Chakan-Talegaon Line by Lonikand 1	04/May/18	8:00	04/May/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL			
23	139	220	Bhugaon - PGCIL Deoli line @Bhugaon	04/May/18	10:00 AM	04/May/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL			
24	145	765	765 KV S/C Tirora-Koradi line ckt-1	05/May/18	7:00	05/May/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L part 2 at power line crossing section	MEGPTL	WR-II	C		Proposal from MEGPTCL
25	152	400	400 BHADRAVATI-CHANDRAPUR IV	05/May/18	6:00	05/May/18	18:00	Daily	Line Outage reuired for Cable Wiring in existing Panles, PMU Integration at Chandrapur Station	WRTS-II	WRTS-I	C		
26	155	220	TAPS 1&2- TAPP 3&4 tie line	05/May/18	8:00	05/May/18	19:00	one day	Annual maintenance Works	MSETCL	NPCIL			
27	163	220	Bugaon - PGCIL Deoli line	05/May/18	10.00 AM	05/May/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL			
28	167	765	765 KV S/C Tirora-Koradi line ckt-2	06/May/18	7:00	07/May/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L part 2 at power line crossing section	MEGPTL	WR-II	C		Proposal from MEGPTCL
29	181	220KV	220KV Boisar -Boisar PG Ckt 1 @Boisar M	06/May/18	9:00	06/May/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
30	201	400	Nandgaon Ckt with bay 412 & 413 at 400 Akola SS	07/May/18	9:00	07/May/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
31	211	220	PGCIL Deoli - PUSAD LINE @Pusad	07/May/18	10.00 AM	07/May/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL			

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	REMARKS	SLDC Comments
				Date	Time	Date	Time							
32	212	400	400 Dhule-SSNNL Ckt-1 & 2 @ 400 Dhule	07/May/18	8:00	08/May/18	17:00	Daily	Online PID Testing ,A/R in Non Auto Mode	MSETCL	MSETCL	400 Dhule-SSNNL Ckt-I & II switch to be kept on non-		
33	215	220	TAPS1&2-Bhilad	07/May/18	8:00	09/May/18	19:00	Daily basis	Annual maintenance (AM)Works	GETCO	NPCL			
34	216	132kV	132 KV Nepanagar-Dharni Line	07/May/18	9:00	09/May/18	17:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	NIL		
35	218	400	400 Akola- Bhusawal Line at 400 Akola SS	07/May/18	12:00	09/May/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Koradi- Bhusawal, 400 Akola-Nandgaonpeth & 400		
36	220	220KV	PGCIL Deoli-Badnera Ckt @Badnera	07/May/18	8:00	12/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	For PID Work		
37	221	400	428- Bay (Tie Bay of Warora- Wardha ckt)at PGCIL Deoli	07/May/18	9:00	12/May/18	17:00	continous	Routine Maintenance & Dignostic testing work and replacement of R-ph pole wiring.	MSETCL	MSETCL			
38	232	765	765 KV S/C Tirora-Koradi line ckt-1	08/May/18	7:00	08/May/18	18:00	Daily	For Stringing work of 765 D/C Gadarwara-Warora T/L ,part 2 at power line crossing section	MEGPTL	WR-II	C		Proposal from MEGPTCL
39	233	400	Koradi2- Wardha (PGCIL) ckt	08/May/18	8:00	08/May/18	17:00	Daily	Refixing of missing & tightening of loose nut bolt on conductor hardware at various location	MSETCL	MSETCL			
40	237	220	Bay No. 211 Main Bay of 220 Boisar-Boisar-II at Boisar	08/May/18	8:30	08/May/18	17:30	Daily	For Bay AMP	POWERGRID	WR-II	R		
41	242	400/220KV	315 MVA ICT-II @Karad	08/May/18	10:00	08/May/18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S		
42	244	220kV	Kalmeshwar Pandhurna Line	08/May/18	10:00	08/May/18	18:00	Daily	Erection of 02Nos of Beams for proposed 220kV Warud Kalmeshwar Line at 220kV Kalmeshwar Sub station.	MSETCL	MSETCL			
43	247	220	PGCIL Deoli - PUSAD LINE	08/May/18	10:00 AM	08/May/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL			
44	248	400	400 CHD-I CHD-II CKT No.I Bay @400 S/S Chandrapur	08/May/18	8:00 Hrs	08/May/18	18:00 Hrs.	Daily	1)Measurement of Tan delta & capacitance of CT, CTV's. 2) For Measurement of bkr timing, DCRM and CRM 3)Teting of Nume. Distance Relay. 4) Routine maintenance of the bay.	MSETCL	MSETCL	The outage is required on complete circuits. The mentioned work can not be carried out by shifting this bay on TBC. During outage period, The 400 CHD-I CHD-II CKT No. - II and 400 CHD-PARLI Ckt. No.-III line will be in service.		
45	254	400	Jaigad-Newkoyna Ckt- 1 & 2	08/May/18	9:00	14/May/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL			
46	265	400	GT#10 Main Bay 401 at 400 Koradi II s/s	09/May/18	10:00	09/May/18	18:00	Daily	1)DCRM,CRM & Timing IR of 401-QS2 2)Tan delta Maeasurement of Bus CT of Bay 401	MSETCL	MSETCL	GT#10 will remain in operation through Tie bay 402		
47	274	220KV	Kalmeshwar Pandhurna ckt	09/May/18	8:00	09/May/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
48	288	400	Girawali-Solapur line	09/May/18	10:00	09/May/18	18:00	Daily	For PID Work. A/R IN Non auto mode	MSETCL	MSETCL	Line will be in service only A/R in Non Auto mode		
49	292	400	400 Khadka-Akola S/C @ 400 Khadka end	09/May/18	6:00	10/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
50	294	220KV	Deoli (PGCIL)- Pusad line	09/May/18	7:00	31/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
51	304	400	Chandrapur 2 - Warora Ckt-I	10/May/18	7:00	10/May/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware & replacement of faulty Disc Insulator	MSETCL	MSETCL			
52	305	400	PARALI LONIKAND-II CKT I by Lamboti	10/May/18	8:00	10/May/18	17:00	Daily	LINE MAINTAINACE WORK	MSETCL	MSETCL			Thursday
53	315	400	400 Main BUS-I & BUS-II Bus bar Protection Scheme Testing at 400 Koradi II s/s	10/May/18	10:00	10/May/18	17:00	Daily	On line testing of400 BusBar Protection Scheme. Bus Bar protection Scheme will be out .	MSETCL		Bus bar protection will be out for testing.		
54	316	400	400 Kolhapur (MSETCL)--II Main bay (410) at Kolhapur-GIS	10/May/18	10:00	10/May/18	18:00	Daily	For bay AMP works.	WRTS-I	WRTS-I	R		
55	332	400	400 Parli - PGCIL ckt 1 @ Parli (M)	11/May/18	9:00	11/May/18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL			
56	333	400	400 Parli (MSETCL)-I Main Bay (415) at Parli	11/May/18	10:00	11/May/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R		
57	338	400	400 Kharghar -Kalwa bay @Kharghar	11/May/18	8:00	11/May/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			Friday .
58	340	220	TAPS1&2 -Borivali	11/May/18	8:00	11/May/18	19:00	one day	Annual maintenance Works	MSETCL	NPCL			
59	347	220KV	Nasik - Navsari Ckt 1 @ Nasik	11/May/18	9:00	11/May/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
60	362	400	Chandrapur II- Nanded Ckt-I	12/May/18	8:00	12/May/18	17:00	Daily	For Routine line maint. Work	MSETCL	MSETCL			
61	379	400	400 Talegaon-Lonikand Line	13/May/18	6:00	13/May/18	13:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Talegaon	MSETCL	WRTS-I	R		Thursday .May be Availled on Sunday.

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	REMARKS	SLDC Comments
				Date	Time	Date	Time							
62	380	400	400 Talegaon Kalwa Line	13/May/18	13:00	13/May/18	18:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Talegaon	MSETCL	WRTS-I	R		Friday . May be availed on 13.05.2018
63	382	400	400 Parli(Girwali)-Chandrapur-Ckt-III	13/May/18	9:00	13/May/18	17:00	Daily	Outage For hardware n/b tightening Work	MSETCL	MSETCL			
64	383	400	414 Bay (Main Bay of Yelwan Ckt-1) at 400 Akola SS	13/May/18	10:00	13/May/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
65	387	220KV	220KV Boisar -Boisar PG Ckt 2 @Boisar M	13/May/18	9:00	13/May/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
66	391	400	Lonikand-I - Lonikand-II Interconnector-II @Lonikand 1	14/May/18	8:00	14/May/18	18:00	Daily	Routine Dignostic testing work	MSETCL	MSETCL			
67	393	400	400 PUNE(GIS)-I Main Bay at Msetcl, Waluj S/s	14/May/18	9:00	14/May/18	18:00	Daily	for AMP works, line remains charged through transfer bus	WRTS-I	WRTS-I	R		
68	395	400	Chakan-Talegaon(PGCIL) line bay	14/May/18	8:00	14/May/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		line to be inservice through TBC bay	
69	409	400	400 ALKUD KOLHAPUR LINE @ ALKUD	14/May/18	9:30	14/May/18	17:30	DAILY	Quarterly Maint. Work	MSETCL	MSETCL			
70	413	400	415 Bay (Tie Bay of Yelwan Ckt-1) at 400 Akola SS	14/May/18	10:00	14/May/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
71	418	400	400 Dhule-SSNNL Ckt-1 & 2 @ 400 Dhule	14/May/18	8:00	15/May/18	17:00	Daily	Online PID Testing	MSETCL	MSETCL	400 Dhule-SSNNL Ckt-I & II switch to be kept on non-		
72	422	400	400 Akola- Nandgaonpeth Line at 400 Akola SS	14/May/18	12:00	16/May/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Koradi- Bhusawal, 400 Akola-Bhusawal & 400		
73	425	220KV	PGCIL Deoli-Badnera Ckt @Badnera	14/May/18	8:00	19/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	For PID Work		
74	433	400	Babhaleshwar-Padghe -Ckt-2 @BBLR	15/May/18	9:00	15/May/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Babhaleshwar-Padghe-Ckt-1 will be in service		
75	434	400	400 PUNE(GIS)-II Main Bay at Msetcl, Waluj S/s	15/May/18	9:00	15/May/18	18:00	Daily	for AMP works, line remains charged through transfer bus	WRTS-I	WRTS-I	R		
76	435	220KV	Talandage - Chikodi	15/May/18	10:00	15/May/18	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL			
77	440	220	400/220kV ICT-2 Main bay (205) 220KV Side at Talegaon	15/May/18	9:00	15/May/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
78	445	400	400 Akola-II Main Bay (416) at Wardha SS	15/May/18	9:00	15/May/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I			
79	448	400	400 Parli (MSETCL)-II Main Bay (418) at Parli	15/May/18	10:00	15/May/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R		
80	453	400	Jaigad-Karad Ckt - 1 & 2	15/May/18	9:00	21/May/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL			
81	458	400	400 Main Bus-I @ Waluj	16/May/18	9:00	16/May/18	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL			
82	464	220KV	Mudshingi -BELEWADI @Mudshingi	16/May/18	9:00	16/May/18	17:00:00 PM	Daily	Quarterly Maintenance work of Belewadi bay equipments.	MSETCL	MSETCL		Intra state line?	
83	476	400	400 Khadka-Akola S/C @ 400 Khadka end	16/May/18	6:00	17/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
84	478	400	315 MVA ICT-I & It's Bay @400 Chandrapur	16/May/18	8:00 Hrs	18/May/18	18:00 Hrs.	Continuos	1)Measurement of Tan delta & capacitance of 400 CTs., Bushing and WDG tandelta 2) For Measurement of bkr timing, DCRM and CRM 3)Teting of Nume. Backup Relay, 4) Routine maintenance of the bay.	MSETCL	MSETCL	The 3*105MVA ICT-II will be in service.		
85	485	220	220KV Talegaon-Talegaon-1	17/May/18	6:00	17/May/18	14:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Talegaon	MSETCL	WRTS-I	R		Saturday. May be availed on Thursday.
86	487	400	Babhaleshwar-Aurangabad - @BBLR	17/May/18	9:00	17/May/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in		
87	496	220KV	Talegaon M - Talegaon PG Ckt I @Talegaon M	17/May/18	8:00	17/May/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
88	499	400	400 Dhule-SSNNL Ckt-1 @ 400 Dhule with 400 SSNNL-2 A/R in non Auto mode	17/May/18	9:00	17/May/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400 SSNNL-2 A/R switch to be kept on non-auto mode		
89	506	400	400 Boisar-Padghe at Boisar	17/May/18	14:00	17/May/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	POWERGRID	WR-II	R		
90	510	400	Chandrapur II- Nanded Ckt-II	17/May/18	8:00	31/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	These lines are on DC tower so both lines require on		
91	511	400	Chandrapur GCR- Parli Ckt- III	17/May/18	8:00	31/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	These lines are on DC tower so both lines require on		
92	515	400	400 WARDHA-PARLI I & II	18/May/18	8:00	20/May/18	18:00	Conti..	For Construction LILO tapping at Warora (New)-SS	WRTS-I	WRTS-I	C		
93	530	400	400 Dhule-SSNNL Ckt-1 @ 400 Dhule end	18/May/18	9:00	18/May/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400 SSNNL-2 A/R switch to be kept on non-auto mode		

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	REMARKS	SLDC Comments
				Date	Time	Date	Time							
94	534	400	400 Akola- Bhusawal Line at 400 Akola SS	18/May/18	9:00	18/May/18	18:00	Daily	Work of replacement of punctured disc strings having 03 & above no. of punctured disc detected in PID by agency by availing outages.	MSETCL	MSETCL	400 Koradi- Bhusawal, 400 Akola-Nandgaonpeth & 400 Koradi-Nandgaonpeth are in service.		
95	535	220KV	Nasik - Navsari Ckt 2 @ Nasik	18/May/18	9:00	18/May/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
96	542	400	Babhaleshwar-Bhusawal -@BBLR	19/May/18	9:00	19/May/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Auranagabad Dhule-Ckt-1&2, Ektuni-ckt-1&2, will be		
97	545	400	400 Talegaon Kalwa & ICT # 3 Tie bay (417) at Talegaon	19/May/18	9:30	19/May/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
98	546	400	417 Bay (Main bay of Yelwan Ckt-2) at 400 Akola SS	19/May/18	10:00	19/May/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
99	554	400	40kv Tarapur-Boisar-I	19/May/18	14:00	19/May/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	POWERGRID	WR-II	R		
100	562	400	400 WARORA-CHANDRAPUR CKT-1(Bay No. 412 & Tie Bay no 413)@400 s/s Warora .	20/May/18	8:00	20/May/18	17:00	Daily	Protection Relay testing works and Routine maintenance and diagnostic testing such as CT tandelta,CRM,IR values,isolator maintenance work .	MSETCL	MSETCL	Load will be managed on 400 Chandrapur Ckt-2		
101	568	220KV	220KV Boisar -Boisar PG Ckt 3 @Boisar M	20/May/18	9:00	20/May/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
102	573	400	Babhaleshwar-Padghe-Ckt-1 @BBLR	21/May/18	9:00	21/May/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Babhaleshwar-Padghe-Ckt-2 will be in service		
103	576	400	GCR Chandrapur - Parli ckt- III Line	21/May/18	7:00	21/May/18	19:00	Daily	For Restrining of Earth wire at LOC No 36 to 38.	MSETCL	MSETCL			
104	585	400	Wardha Ckt 2 with bay 411 & 412 at 400 Akola SS	21/May/18	9:00	21/May/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
105	589	400	400 Main Bus - 1 @ 400 Dhule	21/May/18	9:00	21/May/18	18:00	Day	BUS CVT Testing work	MSETCL	MSETCL	Bays on Bus-1 will be shifted on Bus-2		
106	594	400	400 Koradi- Bhusawal Line at 400 Akola SS	21/May/18	12:00	23/May/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Akola- Bhusawal, 400 Akola-Nandgaonpeth & 400		
107	597	220KV	PGCIL Deoli-Badnera Ckt @Badnera	21/May/18	8:00	26/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	For PID Work		
108	610	400	Nagothane -Dabhol Ckt 1 @Nagothane	22/May/18	8:00	22/May/18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL			
109	617	400	400 Main Bus - 2 @ 400 Dhule	22/May/18	9:00	22/May/18	18:00	Day	BUS CVT Testing work	MSETCL	MSETCL	Bays on Bus-2 will be shifted on Bus-1		
110	631	400	Chandrapur II- Nanded Ckt-II	23/May/18	8:00	23/May/18	17:00	Daily	For Routine line maint. Work	MSETCL	MSETCL			
111	633	400	400 Bus-1 at Talegaon	23/May/18	9:00	23/May/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
112	636	400	400 Lonikand Line Main bay (413) at Talegaon	23/May/18	9:30	23/May/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R		
113	639	400	400 Main- Bus - 2 @ 400 Koradi 1 S/s	23/May/18	6:00	23/May/18	17:00	Daily	Bus outage on bus 2. All feeder to be shifted on Bus-1 (06:00 HRS TO 17:00Hrs) Routine Maintenance & 400 CVT Dignostic testing work	MSETCL	MSETCL			
114	640	400	Nagothane -Dabhol Ckt 1 @Nagothane	23/May/18	8:00	23/May/18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL			
115	653	400	400 SOLAPUR PGCIL @Karad	23/May/18	10:00	23/May/18	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on other ckt.		
116	662	220	220KV Talegaon-Talegaon-2	24/May/18	10:00	24/May/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Talegaon	MSETCL	WRTS-I	R		Monday. May be availed on Thursday.
117	663	400	Girawali-Lonikand II CKT-I line	24/May/18	10:00	24/May/18	18:00	Day	Hardware Tightening & Fitting Work At Loc No-154,170,183,198,210	MSETCL	MSETCL			
118	665	400	Lonikand- Talegaon PG Line @ Loikand 1	24/May/18	8:00	24/May/18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL			
119	667	400	Babhaleshwar-Ektuni-Ckt-1 @BBLR	24/May/18	9:00	24/May/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	400 Bhusawal, Auranagabad Dhule-Ckt-		
120	668	400	400 Khadka-Koradi S/C Line @ 400 Khadka	24/May/18	6:00	24/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
121	675	400	400 Khadka-Koradi S/C Line @ 400 Khadka	24/May/18	6:00	24/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
122	681	400	400 Dhule-SSNNL Ckt-2 @ 400 Dhule end	24/May/18	9:00	24/May/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400 SSNNL-1 A/R switch to be kept on non-auto mode		
123	682	400	405 CB (Koyna Stage-IV Tie Bay) at 400 Jejuri	24/May/18	9:00	24/May/18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	N.A.		
124	687	400	Talandge-Kolhapur PG 1@Talandge	24/May/18	9:00	24/May/18	18:00	Daily	Quarterly Maint work	PGCIL	MSETCL			
125	707	400	Chandrapur GCR- Parli Ckt- III	25/May/18	8:00	25/May/18	17:00	Daily	For Routine line maint. Work	MSETCL	MSETCL			
126	708	400/220	500MVA, ICT-2 (bay 405 & 406) at 400 Khaperkheda S/s	25/May/18	8:00	25/May/18	17:00	Daily	Premansoon Maintenance work. Bushing Tan delta and Capacitance.	MSETCL	MSETCL			

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	REMARKS	SLDC Comments
				Date	Time	Date	Time							
127	711	400	400 Dhule-SSNNL Ckt-2 @ 400 Dhule end	25/May/18	9:00	25/May/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400 SSNNL-1 A/R switch to be kept on non-auto mode		
128	713	400	400 Akola- Nandgaonpeth Line at 400 Akola SS	25/May/18	9:00	25/May/18	18:00	NA	Work of replacement of punctured disc strings having 03 & above no. of punctured disc detected in PID by agency by availing outages.	MSETCL	MSETCL	400 Koradi- Bhusawal, 400 Akola-Bhusawal & 400 Koradi-Nandgaonpeth are in service.		
129	714	400	Talandge-Kolhapur PG 2@ Talandge	25/May/18	9:00	25/May/18	18:00	Daily	Quarterly Maint work	PGCIL	MSETCL			
130	724	400	400 WARDHA-PARLI I & II	25/May/18	8:00	27/May/18	18:00	Conti..	For Construction LILO tapping at Warora (New)-SS	WRTS-I	WRTS-I	C		
131	734	400/220kV	400/220kV 315MVA, ICT-2 @ 400 Dhule	26/May/18	9:00	31/May/18	18:00	Continuous	Oil Filtration work due to abnormal DGA Gases & premonsoon Maint & testing	MSETCL	MSETCL			
132	735	400	418 Bay (Tie Bay of Yelwan Ckt-2) at 400 Akola SS	26/May/18	10:00	26/May/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
133	737	765	Solapur-Raichur-2	26/May/18	7:00	27/May/18	18:00	Daily	Spacers, hot spot, repair sleeves opened at many places	SRPC	RSTCL		350 MW TTC Curatilmnet.	
134	739	400	ICT1_400/200kv_AURANGABAD	26/May/18	6:00	26/May/18	19:00	Daily	for providing insulation sleeves on 33kV tertiary	WRTS-I	WRTS-I	C		
135	752	400	Nagothane -Dabhol Ckt 2 @Nagothane	27/May/18	8:00	27/May/18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL			
136	753	400	Nagothane -Dabhol Ckt 2 @Nagothane	27/May/18	8:00	27/May/18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL			
137	763	400	400 Main Bus-1 @ Parli	28/May/18	8:00	28/May/18	18:00	Daily	Bus maintenance work & 29A, Chandrapur-3 bay PG isolator scissor replacement work.	MSETCL	MSETCL			
138	766	400	Babhaleswar-Ektuni-Ckt-2 @BBLR	28/May/18	9:00	28/May/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Bhusawal, Auranagabad Dhule-Ckt-		
139	772	400	400 A Bus with Bus coupler @Nagothane	28/May/18	8:00	28/May/18	18:00	Daily	Maintenance of PG Isolaters	MSETCL	MSETCL			
140	782	220KV	PGCIL Deoli-Badnera Ckt @Badnera	28/May/18	8:00	31/May/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	For PID Work		
141	783	400	400 Kalwa-Padgha Line-1	29/May/18	8:00	29/May/18	18:00	Daily	Insulator Replacement work found faulty in PID testing.	MSETCL	MSETCL			
142	784	400	Chandrapur 2 - Kumbhargaoon (Nanded) Ckt-II	29/May/18	7:00	29/May/18	17:00	Daily	Fixing repair sleeves in Span 36-37 & tightening of conductor Hardware & Replacement of Disc	MSETCL	MSETCL			
143	791	400	400 B bus with Bus coupler @Nagothane	29/May/18	8:00	29/May/18	18:00	Daily	Maintenance of PG Isolates	MSETCL	MSETCL			
144	800	400	400 Padgha II @ Kalwa	30/May/18	9:00	30/May/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL			
145	801	400	400 Kalwa-Padgha Line-2	30/May/18	8:00	30/May/18	18:00	Daily	Faulty Insulator(Found in PID testing) replacement work .	MSETCL	MSETCL			
146	802	400	400 Parli(Girwali)-Nanded-Ckt-II	30/May/18	9:00	30/May/18	17:00	Daily	Outage For hardware n/b tightening Work	MSETCL	MSETCL			
147	804	400	400 Kalwa-Padgha Line-2	30/May/18	8:00	30/May/18	18:00	Daily	Faulty Insulator(Found in PID testing) replacement work .	MSETCL	MSETCL			
148	809	400	400 Khadka-Koradi S/C Line @ 400 Khadka	30/May/18	6:00	30/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
149	812	400	400 Parli(Girwali)-Nanded-Ckt-II	30/May/18	9:00	30/May/18	17:00	Daily	Outage For Earth wire clamp n/b tightening at loc. 802,803.	MSETCL	MSETCL			
150	821	400	400 Parli -Lonikand ckt 2 @Parli	31/May/18	9:00	31/May/18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL			
151	822	400	Bus Coupler @ BBLR	31/May/18	9:00	31/May/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Bus will be seperated		
152	826	400	400 Khadka-Koradi S/C Line @ 400 Khadka	31/May/18	6:00	31/May/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL			
153	831	400	Parali II Bay 409 and 410 at Lonikand-II	31/May/18	9:00	31/May/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Load will be manage on Parali I at 400 Lonikand II		

State Element outages for the Month of May 2018

Sr. No.	I/ U	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
1	1	400KV	400KV Stage 4- Jejuri ckt	01-May-18	7:00	31-May-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
2	1	400KV	400KV Stage 4- Lonikand	01-May-18	7:00	31-May-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
3	1	400KV	400KV Khadka -Deepnagar	01-May-18	7:00	31-May-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
4	1	400 KV	GT#10 Main Bay 401 & Tie Bay 402 at 400KV Koradi II s/s	3-May-18	10:00	3-May-18	18:00	Daily	1) Tan delta measurement of Line CT of Bay 401 & 2) Relay Testing of high teed & low teed relay at bay 401 & 402	MSETCL	MSETCL	1) GT#8 & GT#9 will be service.
5	1	400/220KV	315MVA, ICT 3 @ Lonikand-1	03-May-18	9:00	03-May-18	18:00	Daily	Routine Dignostic testing work	MSETCL	MSETCL	
6	1	400KV	404-Bay (Main Bay of 501MVA ICT-1) at 400KV Nanded	03-May-18	8:00	03-May-18	11:00	Daily	Premonsoon Maintenance to cover PRV, Buchholz, OSR, Aux. protection trials etc. (Outage on Main & TIE bay is necessary for this work)	MSETCL	MSETCL	
7	1	400KV	400kv Khadka-Deepnagar Ckt-I @ 400kv Deepnagar end	04-May-18	9:00	04-May-18	18:00	Day	Routine Maintenance work & Diagnostic Testing	MSETCL	MSETCL	
8	1	400kv	400kv Deepnagar-Tapthi-Tanda @ 400kv Deepnagar	05-May-18	6:00	05-May-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	
9	1	400/220KV	500MVA, ICT I @ Kalwa	06-May-18	9:00	06-May-18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	
10	1	400KV	400KV Bay Future Line-I Main/Tie CB - Bay 418 and 419 @400kv s/s Warora .	06-May-18	7:00	06-May-18	17:00	Daily	Protection Relay testing works Routine maintenance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintainance work.	MSETCL	MSETCL	Only 400KV Bay Future Line-I Main CB -Bay 418 is charged on No Load. Presently No Line is ready .
11	1	400KV	Babhaleshwar-Dhule-Ckt-1 @BBLR	06-May-18	9:00	06-May-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-2, Ektuni-ckt-1, Ektuni-ckt-2 will be in service
12	1	400/220kv	315MVA, ICT 1 @ Nagothane	07-May-18	8:00	07-May-18	18:00	Daily	Premansoon Maintenance work	MSETCL	MSETCL	
13	1	400KV	400KV Waluj-Thaptitanda Line @ Waluj HLU	07-May-18	8:00	19-May-18	16:00	Daily	PID work . A/R in Non -auto mode.	MSETCL	MSETCL	as per availibility of HLU A'bad & real time weather conditions.
14	1	400KV	TBC @ BBLR	07-May-18	9:00	07-May-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	TBC is free
15	1	400/220kv	315MVA, ICT 2 @ Nagothane	08-May-18	8:00	08-May-18	18:00	Daily	Premansoon Maintenance work	MSETCL	MSETCL	
16	1	400 KV	400KV TBC Bay @ 400 KV Koradi 1 S/s	08-May-18	6:00	08-May-18	17:00	Daily	Breaker CRM & DCRM, Tan delta measurment of CT & reactor bushings	MSETCL	MSETCL	
17	1	400/220kv	501 MVA, ICT 3 @ Nagothane	09-May-18	8:00	09-May-18	18:00	Daily	Premansoon Maintenance work	MSETCL	MSETCL	
18	1	400/220kv	3*167 MVA, ICT 2 @ LAMBOTI	09-May-18	8:00	09-May-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
19	1	400KV	Thaptitanda-Waluj @Thaptitanda and Waluj end	10-May-18	10:00	10-May-18	17:00	Daily	Routine Maintenance work of line	MSETCL	MSETCL	
20	1	400KV	Lonikand II -Parali- Ckt II Line By Lonikand 1	10-May-18	8:00	10-May-18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	
21	1	400KV	407-Bay (Main Bay of 501 MVA ICT-2) at 400KV Nanded .	10-May-18	8:00	10-May-18	11:00	Daily	Premonsoon Maintenance to cover PRV, Buchholz, OSR, Aux. protection trials etc. (Outage on Main & TIE bay is necessary for this work)	MSETCL	MSETCL	
22	1	400KV	403-Bay (Tie Bay of 501MVA ICT-1 & 400kv Chandarpur ckt-1) at 400kv Nanded	10-May-18	8:00	10-May-18	11:00	Daily	Premonsoon Maintenance to cover PRV, Buchholz, OSR, Aux. protection trials etc. (Outage on Main & TIE bay is nessary for this work)	MSETCL	MSETCL	
23	1	400KV	404 CB (ICT-II Main Bay) at 400kv Jejuri	10-May-18	9:00	10-May-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	N.A.
24	1	400KV	Thaptitanda-Deepnagar @Thaptitanda	11-May-18	10:00	11-May-18	17:00	Daily	Routine Maintenance work of line	MSETCL	MSETCL	
25	1	400KV	400kv Khadka-Deepnagar Ckt-II @ 400kv Deepnagar end	11-May-18	9:00	11-May-18	18:00	Day	Routine Maintenance work & Diagnostic Testing	MSETCL	MSETCL	

Sr. No.	I/ U	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
26	1	400KV	400kv Dhule-BBLR Ckt-1 @ 400kv Dhule end	11-May-18	9:00	11-May-18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400kv BBLR-2 A/R switch to be kept on non-auto mode
27	1	400KV	400kv Dhule-BBLR Ckt-2 @ 400kv Dhule end	12-May-18	9:00	12-May-18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400kv BBLR-1 A/R switch to be kept on non-auto mode
28	1	400kv	400kv Deepnagar-Tapthi-Tanda @ 400kv Deepnagar	12-May-18	6:00	12-May-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	
29	1	400KV	401-Bay (Main Bay of 167MVA Spare ICT) at 400kv Nanded	12-May-18	8:00	12-May-18	11:00	Daily	Premonsson Maintenance work	MSETCL	MSETCL	
30	1	400KV	Nagothane -Padgha Ckt 1 @Nagothane	14-May-18	8:00	14-May-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	
31	1	400 KV	400KV ALKUD KOLHAPUR LINE @ ALKUD	14-May-18	9:30	14-May-18	17:30	DAILY	Quarterly Maint. Work	MSETCL	MSETCL	
32	1	400KV	Nagothane -Padgha Ckt 1 @Nagothane	15-May-18	8:00	15-May-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	
33	1	400/220KV	315MVA, ICT 1 @ Kharghar	15-May-18	8:00	25-May-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
34	1	400KV	Nagothane -Padgha Ckt 1 @Nagothane	16-May-18	8:00	16-May-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	
35	1	400KV	GCR Chandrapur - Khaperkheda Line	16-May-18	6:00	31-May-18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
36	1	400KV	Nagothane -Padgha Ckt 2 @Nagothane	17-May-18	8:00	17-May-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	
37	1	400/220 KV	500MVA, ICT-1 (bay 402 & 403) at 400KV Khaperkheda S/s	17-May-18	8:00	17-May-18	17:00	Daily	Premansoon Maintenance work. Bushing Tan delta and Capacitance.	MSETCL	MSETCL	
38	1	400/220 KV	167 x 3 MVA ICT II (415 & 416) @Lonikand II	17-May-18	9:00	17-May-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Load will be manage on ICT I at 400KV Lonikand II substation
39	1	400 KV	400KV JAIGAD -I @ Karad	17-May-18	10:00	17-May-18	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	Load manage on 400KV JAIGAD -II
40	1	400/220KV	ICT-NO. I BHEL at 400KV Jejuri	17-May-18	9:00	17-May-18	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	400/220KV ICT-NO.II will feed total load
41	1	400KV	Nagothane -Padgha Ckt 2 @Nagothane	18-May-18	8:00	18-May-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	
42	1	400kv	ICT-III, 501 MVA @ Waluj	18-May-18	9:00	18-May-18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	
43	1	400KV	400kv Deepnagar-Thaptitanda Ckt @ 400kv Deepnagar end	18-May-18	9:00	18-May-18	18:00	Day	Routine Maintenance work & Diagnostic Testing	MSETCL	MSETCL	
44	1	400KV	Nagothane -Padgha Ckt 2 @Nagothane	19-May-18	8:00	19-May-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	
45	1	400/220KV	315MVA, ICT 2@ BBLR	19-May-18	8:00	19-May-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I ,ICT -III and ICT-IV will be in service
46	1	400kv	400kv Deepnagar-Tapthi-Tanda @ 400kv Deepnagar	19-May-18	6:00	19-May-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	
47	1	400/220KV	500 MVA, ICT III @ Kalwa	20-May-18	9:00	20-May-18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	
48	1	400KV	Babhaleshwar-Dhule-Ckt-2 @BBLR	20-May-18	9:00	20-May-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-1, Ektuni-ckt-1, Ektuni-ckt-2 will be in service
49	1	400KV	400KV Thaptitanda-Deepnagar Line @ Waluj HLU	21-May-18	8:00	31-May-18	16:00	Daily	PID work. A/R in Non -auto Mode .	MSETCL	MSETCL	as per availability of HLU A'bad & real time weather conditions.
50	1	400KV	Jaigad-Newkoyna Ckt- 1	22-May-18	9:00	22-May-18	18:00	Daily	Coldline washing	JPTL	JPTL	
51	1	400KV	Chandrapur-Khaperkheda ckt	22-May-18	8:00	22-May-18	17:00	Daily	Refixing of missing & tightening of loose nut bolt conductor on hardware at various location	MSETCL	MSETCL	
52	1	400KV	Jaigad-Newkoyna Ckt- 2	23-May-18	9:00	23-May-18	18:00	Daily	Coldline washing	JPTL	JPTL	
53	1	400KV	Jaigad-Karad Ckt - 1	24-May-18	9:00	24-May-18	18:00	Daily	Coldline washing	JPTL	JPTL	
54	1	400/220 KV	167 x 3 MVA ICT I (419 & 418) @ Lonikand II	24-May-18	9:00	24-May-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Load will be manage on ICT II at 400kv Lonikand II substation

Sr. No.	I/ U	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
55	1	400KV	Jaigad-Karad Ckt - 2	25-May-18	9:00	25-May-18	18:00	Daily	Coldline washing	JPTL	JPTL	
56	1	400/220 KV	500MVA, ICT-2 (bay 405 & 406) at 400KV Khaperkheda S/s	25-May-18	8:00	25-May-18	17:00	Daily	Premansoon Maintenance work. Bushing Tan delta and Capacitance.	MSETCL	MSETCL	
57	1	400/220kv	315MVA, ICT 2 @ Kharghar	25-May-18	8:00	25-May-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
58	1	400kv	400kv Deepnagar-Waluj Ckt @ 400kv Deepnagar end	25-May-18	9:00	25-May-18	18:00	Day	Routine Maintenance work & Diagnostic Testing	MSETCL	MSETCL	
59	1	400KV	400kv Deepnagar Bay @ Waluj	26-May-18	9:00	26-May-18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	
60	1	400kv	400kv Deepnagar-Tapthi-Tanda @400kv Deepnagar	26-May-18	6:00	26-May-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	
61	1	400/220kv	501 MVA, ICT 3 @ Talandge	28-May-18	8:00	28-May-18	20:00	Daily	Quarterly Maint work	MSETCL	MSETCL	Load will manage on ICT 1& ICT 2 Also 220kv Tilawani Miraj require to keep OFF to manage Excess load
62	1	400 KV	400 kv C bus @ Nagothane	30-May-18	8:00	30-May-18	18:00	Daily	Maintenance of PG Isolates	MSETCL	MSETCL	
63	1	400KV	402 Tie Bay only (Tie Bay of 400 KV Switching ckt-1(bay401) and 400KV GCR ckt-1 (bay403)) @ 400KV Chandrapur-II s/s	30-May-18	7:00	30-May-18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
64	1	400KV	Lonikand- Karad Line @ Lonikand 1	30-May-18	8:00	30-May-18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	