

Maharashtra State Load Despatch Centre										
WRPC OCCM approved Monthly Outage list for the Month of May 2020										
Sr.No.	OCCM Sr. No	Line / Element	From Date	Time (Hrs)	To Date	Time (Hrs)	Daily/Continuous	Name of Requesting Agency	Reason	Remarks
1	2	400KV-BABLESHWAR-PADGHE-1	1-May-20	09:00	10-May-20	18:00	Daily	MSETCL	PID testing work	-
2	12	400KV-KOYNA STAGE IV-LONIKHAND-1	1-May-20	08:00	31-May-20	18:00	Daily	MSETCL	PID WORK	AR is in off condition
3	13	400KV-JEJURI-KOYNA STAGE IV-1	1-May-20	08:00	31-May-20	18:00	Daily	MSETCL	PID WORK	AR is already OFF position
4	14	400KV-KARAD-KOLHAPUR-MS-1	1-May-20	08:00	31-May-20	18:00	Daily	MSETCL	PID work	AR to be required in non auto mode
5	15	400KV-KARAD-KOLHAPUR-MS-2	1-May-20	08:00	31-May-20	18:00	Daily	MSETCL	PID WORK	ar to be required in non auto mode
6	33	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	1-May-20	08:00	1-May-20	18:00	Daily	MEGPTCL	Reactor Maintenance Activities	
7	34	220KV-BOISAR-BOISAR-M-1	1-May-20	09:00	1-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.
8	39	400KV-KORADI-BHUSAWAL-1 ON TBC @ KORADI	1-May-20	00:00	9-May-20	18:00	Continuous	MSETCL	Shifting of 400kV Bhusawal line on TBC for CB pole and mechanism Overhauling & testing. Continued from 30.04.2020.	Outages will be availed subject to weather conditions.
9	41	400KV-KARAD-JAIGAD-2	2-May-20	09:00	5-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR required in Non auto mode for both ckt
10	42	400KV-KARAD-JAIGAD-1	2-May-20	09:00	5-May-20	18:00	Daily	JPTL	Hotline insulator washing	AR to be kept in Non auto mode for both circuit
11	55	400kv AKOLA-AURANGABAD-2 LR @ AKOLA - 400KV	2-May-20	9:00	2-May-20	18:00	D	POWERGRID WR1	For LR AMP Work & Line reactor in non switchable hence line outage required for take out/take in each operation 20 min.	
12	64	400KV-TARAPUR 3&4-PADGHE-1	2-May-20	10:00	2-May-20	17:00	D	POWERGRID WR1	For AMP works of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.	
13	71	400KV-KALWA-PADGHE-1	2-May-20	07:00	2-May-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
14	72	132KV-DHARNI-NEPANAGAR-1	2-May-20	10:00	2-May-20	16:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work	Already proposed in March but not approved due to Covid-19 lockdown period for maintaining uninterrupted power supply
15	84	KALWA - 400KV - BUS 1	3-May-20	09:00	3-May-20	18:00	Daily	MSETCL	Bus PT Maintenance & insulator cleaning work	Bus PT Maintenance & insulator cleaning work
16	86	765KV-AKOLA (2)-KORADI-III-1	4-May-20	8:00	6-May-20	18:00	Daily	MEGPTCL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	
17	87	400KV-KALWA-PADGHE-2	4-May-20	09:00	9-May-20	17:00	Daily	MSETCL	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
18	90	AURANGABAD-M (WALUJ) - 400KV - BUS 1	4-May-20	09:00	4-May-20	17:00	Daily	MSETCL	Qyarterly maintenance of 400kV Thaptitanda Bay	Qyarterly maintenance of 400kV Thaptitanda Bay
19	116	TIE BAY - 408 OF KOLHAPUR (TALANDGE) @ ALKUD	4-May-20	10:00	4-May-20	17:30	Daily	MSETCL	Quarterly maintenance work and diagnostic testing work	NA
20	117	400KV-KOLHAPUR-MS-ALKUD-1	4-May-20	10:00	4-May-20	17:30	Daily	MSETCL	Quarterly maintenance work and diagnostic testing work	NA
21	120	MAIN BAY - 407 OF KOLHAPUR (TALANDGE) @ ALKUD	4-May-20	10:00	4-May-20	17:30	Daily	MSETCL	Quarterly maintenance work and diagnostic testing work	NA
22	123	400KV-RGPPL-NEW KOYNA-1	4-May-20	9:00	5-May-20	18:00	C	RGPPPL	Bkr 402-52 A PM & testing.	
23	129	KHAPARKHEDA - 400KV - BUS 1	4-May-20	07:00	6-May-20	15:00	Daily	MSETCL	PID Testing of Insulator	Online Work
24	137	PARLI - 400KV - BUS 1	5-May-20	8:00	5-May-20	17:00	D	POWERGRID WR1	For AMP works	
25	145	ALKUD - 400KV - BUS 2	5-May-20	10:00	5-May-20	17:30	Daily	MSETCL	Quarterly maintenance work	Load will be managed on Main Bus II
26	177	400KV-WARDHA-AKOLA-1	5-May-20	9:00	6-May-20	18:00	D	POWERGRID WR1	For replacing existing porcelain/CLR pilot insulators with Glass insulators & 400KV- WARDHA-AKOLA-2 AR to be keep in non auto mode for safety measures.	
27	222	220KV-MUDSHINGLI-CHIKKODI-II-1	6-May-20	09:00	6-May-20	18:00	Daily	MSETCL	Quarterly maintenance	Quarterly maintenance
28	223	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	6-May-20	09:00	6-May-20	18:00	Daily	MSETCL	Quarterly maintenance	Quarterly maintenance
29	224	TIE BAY - 400KV-KALA-KUDUS-1 AND FUTURE at KUDUS - 400KV	6-May-20	10:00	6-May-20	17:00	Daily	MSETCL	Bay 405-(89-B) isolator alignment and 405-(89-A) B-ph isolator motor replacemmnt and maintenance work.	Line Bay 406 outage also required for safety purpose which is only charged upto line isolator. Line Bay- 404 (Kala ckt-1) will be in service with its main CB.
30	225	220KV-SOLAPUR-JEUR-1	6-May-20	10:00	6-May-20	18:00	Daily	MSETCL	Quarterly Maintenance work	Outage is required for QM work. Line CB of 220 kV PGCIL Incomer Line needs to be made off.
31	226	400KV-RGPPL-NEW KOYNA-1	6-May-20	9:00	7-May-20	18:00	C	RGPPPL	Bkr 402-52 T PM & testing.	
32	228	400KV-JAIGAD-NEW KOYNA-1	6-May-20	09:00	7-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR to kept in Non auto mode for both ckt
33	229	400KV-JAIGAD-NEW KOYNA-2	6-May-20	09:00	7-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt
34	231	765KV-AKOLA (2)-KORADI-III-2	7-May-20	08:00	9-May-20	18:00	Daily	MEGPTCL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	

Sr.No.	OCCM Sr. No	Line / Element	From Date	Time (Hrs)	To Date	Time (Hrs)	Daily/Continuous	Name of Requesting Agency	Reason	Remarks
35	255	400KV-CHAKAN-PUNE-PG-1	7-May-20	9:00	7-May-20	18:00	D	POWERGRID_WRI	For Line side equipment AMP Works	
36	256	400KV-JEPL-KORADI-II-1	7-May-20	09:00	7-May-20	18:00	Daily	MSETCL	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	Outage proposed by LMU Koradi
37	257	400KV-WARDHA-AKOLA-2	7-May-20	9:00	8-May-20	18:00	D	POWERGRID_WRI	For replacing existing porcelain/CLR pilot insulators with Glass insulators & 400KV-WARDHA-AKOLA-1 AR to be keep in non auto mode for safety measures.	
38	260	KHAPARKHEDA - 400KV - BUS 2	7-May-20	07:00	9-May-20	15:00	Daily	MSETCL	PID Testing of Insulator	Online Work
39	264	400KV-BABLESHWAR-PADGHE-1	8-May-20	09:00	8-May-20	17:00	Daily	MSETCL	PID Faulty String replacement work & Relay Testing	400KV Padghe ckt II will be in service
40	277	PARLI - 220KV - BUS 2	8-May-20	8:00	8-May-20	17:00	D	POWERGRID_WRI	For AMP works	
41	299	220KV-WARDHA-WARDHA-M-1	8-May-20	10:00	8-May-20	18:00	Daily	MSETCL	restringing of conductor from loc no 3-5 for mentaining clearance , Line maintainace, Broken disc replacement/flashover if any	NA
42	305	400KV-RGPPL-NEW KOYNA-1	8-May-20	9:00	13-May-20	18:00	C	RGPP	Bkr 402-52 B overhauling.	
43	308	400KV-WARDHA-WARORA-PG-2	9-May-20	9:00	9-May-20	18:00	D	POWERGRID_WRI	For Earth Wire Restoration & 400KV-WARDHA-Warora-1 AR to be keep in non auto mode for safety measures.	
44	315	400KV-PARLI-M-LONIKHAND-II-2	9-May-20	09:00	9-May-20	18:00	Daily	MSETCL	Reactor testing work, Bay maintenance work	-
45	328	Main Bay-400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 at WALUJ	9-May-20	9:00	9-May-20	18:00	D	POWERGRID_WRI	For AMP works & Load shall be shifted on to TBC	
46	338	220KV-TARAPUR 1&2-BORIVALI-1	9-May-20	09:00	9-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.
47	344	WARORA - 400KV - BUS 2	10-May-20	07:00	10-May-20	15:00	Daily	MSETCL	Routine maintenance and diagonastic testing such as CVT tandelta,IR values,isolater maintenance work etc	400KV MAIN BUS-1 WILL BE IN SERVICE
48	353	400KV-NANDGAONPETH-KORADI-1 ON TBC @ KORADI	10-May-20	09:00	23-May-20	08:00	Continuous	MSETCL	Shifting of 400kV RPL line on TBC for CB pole and mechanism Overhauling & testing	Outages will be availed subject to weather conditions.
49	354	400KV-KALWA-PADGHE-1	11-May-20	09:00	16-May-20	17:00	Daily	MSETCL	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
50	358	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	11-May-20	9:00	11-May-20	18:00	D	POWERGRID_WRI	For AMP works & 400KV Pune-GIS-Aurangabad-1 LINE WITH LINE REACTOR WILL BE OUT OF SERVICE DUE TO DOUBLE BUS SCHEME & 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 AR to be keep in non auto mode for safety measures.	
51	383	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 at WARORA - 400KV	11-May-20	07:00	11-May-20	15:00	Daily	MSETCL	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	400KV PGCIL Line will be charged through Tie CB 421.
52	384	400KV-EKTUNI-BABLESHWAR-1	11-May-20	09:00	11-May-20	17:00	Daily	MSETCL	Quarterly Maintenance work, Line maint. & Relay Testing	400kV Dhule cktI and II,400kV Bhusawal and 400kV Aurangabad,400kV Ektuni- 2 lines will be in in service
53	385	KORADI-III - 400KV - BUS 1	11-May-20	09:00	11-May-20	18:00	Daily	MEGPTCL	Maintenance of Bus Related Equipments	
54	386	220KV-WARDHA-BHUGAON-1	11-May-20	10:00	11-May-20	18:00	Daily	MSETCL	Routine maintainace work	NA
55	396	220KV-NASIK-NAVSARI-1	11-May-20	09:00	13-May-20	18:00	Daily	MSETCL	Line maintenance work	-
56	398	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	11-May-20	9:00	14-May-20	18:00	C	POWERGRID_WRI	For replacement of BHEL make CB	
57	402	Main Bay - 400KV-PADGHE-BOISAR-1 AND PADGHE - 400KV - Bus 1 at PADGHE-MS - 400KV	11-May-20	9:00	20-May-20	17:00	C	POWERGRID_WRI	Retrofitting of old BHEL make CB with New GE make CB for 400 KV Boisar Line Bay at Padghe MSETCL & 400 KV Boisar Line to be taken on TBC CB at Padghe MSETCL.	
58	403	220 kV Navsari-Nashik - 1	11-May-20	9:00	11-May-20	18:00	Daily	GETCO	Maintenance work	
59	407	400KV-TIRODA-WARORA-1	12-May-20	08:00	14-May-20	18:00	Daily	ATIL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	
60	411	AURANGABAD-M (WALUJ) - 400KV - BUS 1	12-May-20	09:00	12-May-20	17:00	Daily	MSETCL	Quarterly maintenance of 400kV Deepnagar Bay at Waluj end	Quarterly maintenance of 400kV Deepnagar Bay at Waluj end
61	433	400KV-BHILAI-KORADI-1	12-May-20	9:00	12-May-20	18:00	D	POWERGRID_WRI	For AMP of Line Reactor at Bhilai SS & Line AMP work permit shall be provided	
62	444	220KV-Pandurna-MP-Kamleshwar	12-May-20	9:00	12-May-20	18:00	D	MP_SLDC	For line maintenance work	
63	453	220KV-WARDHA-WARDHA-M-1	12-May-20	10:00	12-May-20	18:00	Daily	MSETCL	restringing of conductor from loc no 3-5 for mentaining clearance , Line maintainace, Broken disc replacement/flashover if any	NA
64	462	400 kV SSP - Dhule - 1	13-May-20	7:00	13-May-20	18:00	Daily	GETCO	Maintenance work	Auto reclose of SSP - Dhule - 2 will remain out
65	475	AURANGABAD - 220KV - BUS 1	13-May-20	9:00	13-May-20	18:00	D	POWERGRID_WRI	For AMP works	
66	489	220KV-WARDHA-BHUGAON-1	13-May-20	10:00	13-May-20	18:00	Daily	MSETCL	Routine maintainace work	NA
67	495	220KV-PANDURNA-KALMESHWAR-1	13-May-20	08:00	14-May-20	18:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work restringing of bottom ph conductor.	Outage proposed by LMU Mankapur
68	498	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	13-May-20	9:00	18-May-20	18:00	C	POWERGRID_WRI	For Replacement of BHEL CB with GE CB at Akola.	
69	506	400KV-LONIKHAND-PUNE-PG-1	14-May-20	9:00	14-May-20	18:00	D	POWERGRID_WRI	For Line side equipment AMP Works	
70	512	400 kV SSP - Dhule - 2	14-May-20	7:00	14-May-20	18:00	Daily	GETCO	Maintenance work	Auto reclose of SSP - Dhule - 1 will remain out

Sr.No.	OCCM Sr. No	Line / Element	From Date	Time (Hrs)	To Date	Time (Hrs)	Daily/Continuous	Name of Requesting Agency	Reason	Remarks
71	521	AURANGABAD - 220KV - BUS 2	14-May-20	9:00	14-May-20	18:00	D	POWERGRID_WRI	For AMP works	
72	523	400KV-KORADI-SATPURA-1	14-May-20	9:00	14-May-20	18:00	D	POWERGRID_WRI	For line AMP Works	At Koradi S/s
73	535	JEJURI - 400KV - BUS 1	14-May-20	09:00	14-May-20	18:00	Daily	MSETCL	Annual maintenance work & testing work.	---
74	536	400KV-PARLI-M-PARLI-1	14-May-20	09:00	14-May-20	18:00	Daily	MSETCL	CB testing, Bay maintenance work.	-
75	537	400KV-LONIKHAND-PUNE-PG-1	14-May-20	09:30	14-May-20	17:30	Daily	MSETCL	DT work & Half yearly Maint, work	Load will be managed by other 06 connecting lines to LK 1 S/stn.
76	538	220KV-WARDHA-BADNERA-1	14-May-20	10:00	14-May-20	18:00	Daily	MSETCL	Routine Line maintainace, Broken disc replacement/flashover if any	NA
77	545	220KV-NASIK-NAVSARI-2	14-May-20	09:00	16-May-20	18:00	Daily	MSETCL	Maintenance work	-
78	546	400KV-RGPPL-NAGOTHANE-2	14-May-20	9:00	18-May-20	18:00	C	RGPL	407-52 A bkr CT (R phase) replacement	
79	547	220 kV Navsari - Nashik - 2	14-May-20	9:00	14-May-20	18:00	Daily	GETCO	Maintenance work	
80	549	400KV-TIRODA-WARORA-2	15-May-20	08:00	17-May-20	18:00	Daily	ATIL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	
81	550	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	15-May-20	05:00	17-May-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC-1 and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During, this outage HVDC-2 will be in service. The outage on HVDC-1 bay is required as the work of replacement of bus conductor of Main Bus-I is to be carried out in HVDC-1 bay.
82	551	CHANDRAPUR-GCR - 400KV - BUS 1	15-May-20	05:00	17-May-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC-1 and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
83	552	400KV/21KV CHANDRAPUR-GT-6	15-May-20	05:00	17-May-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC-1 and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During, this outage GT-6 bay will be shifted on TBC-2. The outage on GT-6 bay is required as the work of replacement of bus conductor of Main Bus-I is to be carried out in GT-6 bay.
84	575	400KV-BHILAI-KORADI-1	15-May-20	9:00	15-May-20	18:00	D	POWERGRID_WRI	For line AMP Works	At Koradi S/s
85	588	400KV-WARORA-CHANDRAPU-II-1	15-May-20	07:00	15-May-20	17:00	Daily	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
86	589	TAPTHITHANDA - 400KV - BUS 2	15-May-20	09:00	15-May-20	16:00	Daily	MSETCL	BUS II 408 89 B isolator alignment work	Nil
87	590	400KV-EKTUNI-BABLESHWAR-2	15-May-20	09:00	15-May-20	17:00	Daily	MSETCL	Quarterly Maintenance work, Line maint. & Relay Testing	400kV Dhule cktl and II,400kV Bhusawal and 400kV Aurangabad,400kV Ektuni- I lines will be in in service
88	591	220KV-BOISAR-NALASOPARA-1	15-May-20	09:00	15-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.
89	592	220KV-WARDHA-PUSAD-1	15-May-20	10:00	15-May-20	18:00	Daily	MSETCL	Routine maintainace work	NA
90	595	HVDC 500KV CHANDRAPUR HVDC POLE 1 AND HVDC 500KV CHANDRAPUR HVDC POLE 2	15-May-20	06:00	17-May-20	18:00	Continuous	MSETCL	To rectify bent bracing of Loc. no. 285 of 500KV Chandrapur-Padghe HVDC Line.	It is observed that there is bent bracing of Loc. No. 285 of 500kV Chandrapur-Padghe HVDC Line. It is urgent to rectify bent bracing as much as possible.
91	596	HVDC 500KV CHANDRAPUR HVDC POLE 1	15-May-20	06:00	22-May-20	18:00	Continuous	MSETCL	Stringing from loc no 278 to 294 of 500KV Chandrapur-Padghe HVDC Line Pole 1 due to construction of Kochi-Ambazari Dam under ORC scheme.	ORC work of Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambazari Dam.
92	597	CHANDRAPUR - 400KV - BUS 1	15-May-20	9:00	17-May-20	18:00	D	POWERGRID_WRI	Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2	
93	623	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	16-May-20	9:00	16-May-20	18:00	D	POWERGRID_WRI	For AMP works	
94	624	220KV-TARAPUR 1&2-BORIVALI-1	16-May-20	08:00	16-May-20	17:00	Daily	MSETCL	Routine Maintenance & work	Routine Maintenance & work
95	628	220KV-TALEGAON-PUNE-PG-2	16-May-20	9:00	16-May-20	18:00	D	POWERGRID_WRI	For Line side equipment AMP Works at Pune-Talegaon end.	
96	634	220KV-BOISAR-BOISAR-M-3	17-May-20	09:00	17-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.	Routine Maintenance & Dignostic testing works.
97	636	400KV-KHARGHAR-PUNE-PG-1	18-May-20	09:00	23-May-20	17:00	Daily	MSETCL	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
98	637	400KV-KALWA-PUNE-PG-1	18-May-20	09:00	23-May-20	17:00	Daily	MSETCL	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing & Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
99	640	KHARGHAR - 400KV - BUS 2	18-May-20	08:00	21-May-20	18:00	Continuous	MSETCL	For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV 'B' bus	400kV 'B' bus load will be shifted to 400kV 'A' bus
100	641	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	18-May-20	08:00	21-May-20	18:00	Continuous	MSETCL	For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV 'B' bus	400kV 'B' bus load will be shifted to 400kV 'A' bus
101	642	400KV-WARORA-CHANDRAPU-II-2	18-May-20	07:00	18-May-20	17:00	Daily	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
102	668	MAIN BAY - 220KV-WARDHA-PUSAD-1 AND WARDHA - 220KV - BUS 1 at WARDHA - 220KV	18-May-20	14:00	18-May-20	18:00	D	POWERGRID_WRI	For AMP works	
103	669	220KV-WARDHA-PUSAD-1	18-May-20	10:00	18-May-20	18:00	Daily	MSETCL	Routine maintainace work	NA
104	684	400KV-RGPPL-NAGOTHANE-2	18-May-20	08:00	18-May-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil

Sr.No.	OCCM Sr. No	Line / Element	From Date	Time (Hrs)	To Date	Time (Hrs)	Daily/Continuous	Name of Requesting Agency	Reason	Remarks
105	693	400KV-RGPPL-NAGOTHANE-1	19-May-20	08:00	19-May-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
106	719	220KV-WARDHA-BADNERA-1	19-May-20	10:00	19-May-20	18:00	Daily	MSETCL	Routine Line maintainace, Broken disc replacement/flashover if any	NA
107	725	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at Akola - 400KV	19-May-20	9:00	24-May-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola.	
108	754	220KV-PANDURNA-KALMESHWAR-1	20-May-20	08:00	20-May-20	18:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work restringing of bottom ph conductor.	Outage proposed by LM S/dn Mankapur
109	755	220KV-TILLARI-AMONA-1	20-May-20	09:00	20-May-20	18:00	Daily	MSETCL	Quarterly maintenance	Quarterly maintenance
110	756	220KV-PARLI-OSMANABAD-M-1	20-May-20	09:00	20-May-20	18:00	Daily	MSETCL	Line maintenance	-
111	757	220KV-WARDHA-PUSAD-1	20-May-20	10:00	20-May-20	18:00	Daily	MSETCL	Routine maintainace work	NA
112	765	400KV-RGPPL-NAGOTHANE-2	20-May-20	08:00	20-May-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
113	772	400KV-DHULE-MS-BABLESHWAR-2	21-May-20	08:00	31-May-20	18:00	Daily	MSETCL	PID testing work	-
114	773	400KV-DHULE-MS-BABLESHWAR-1	21-May-20	09:00	31-May-20	18:00	Daily	MSETCL	PID testing work	-
115	783	400KV-RGPPL-NAGOTHANE-1	21-May-20	08:00	21-May-20	17:00	Daily	MSETCL	Emergency tree cutting work	nil
116	784	400KV-WARDHA-KORADI-II-1	21-May-20	09:00	21-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
117	805	TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV	21-May-20	08:00	21-May-20	14:00	Daily	MSETCL	ROUTINE MAINTENANCE AND TESTING WORK	CIRCUIT CHARGE THROUGH MAIN BAY
118	806	400KV-PARLI-M-PARLI-2	21-May-20	09:00	21-May-20	18:00	Daily	MSETCL	Distance relay testing, bay maintenance work.	-
119	817	400KV-KHARGHAR-PUNE-PG-1	22-May-20	07:00	22-May-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work. Diagnostic Testing work	Insulator Cleaning & Routine Maintenance work
120	826	400KV-WARDHA-WARORA-1	22-May-20	09:00	22-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL Line is in ckt
121	834	BUS COUPLER BAY - BOISAR - 220KV - BUS 1 AND BOISAR - 220KV - BUS 2 at BOISAR - 220KV	22-May-20	9:00	22-May-20	17:30	D	POWERGRID_WR2	BAY AMP	PG-Boisar
122	846	765KV/400KV AKOLA (2)-ICT-1	22-May-20	09:00	22-May-20	18:00	Daily	MEGPTCL	Maintenance of ICT	
123	859	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	23-May-20	6:00	23-May-20	18:00	D	POWERGRID_WR1	For AMP works	
124	860	400KV-EKTUNI-BABLESHWAR-2	23-May-20	09:00	23-May-20	17:00	Daily	MSETCL	Quarterly Maintenance work, Line maint. & Relay Testing	400kV Ektuni ckt 1,400kV Bhusawal and 400kV Aurangabad lines will be in service
125	867	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	23-May-20	08:00	25-May-20	18:00	Continuous	MSETCL	For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV 'A' bus	400kV 'A' bus load will be shifted on 'B' bus
126	868	KHARGHAR - 400KV - BUS 1	23-May-20	08:00	25-May-20	18:00	Continuous	MSETCL	For replacement of Qradraple conductor span between 400kV Talegaon and Kalwa line of 400kV 'A' bus	400kV 'A' bus load will be shifted on 'B' bus
127	881	400KV-PADGHE-BOISAR-1	23-May-20	11:00	23-May-20	12:30	D	POWERGRID_WR1	For CT oil samples at Padghe-MS end.	
128	883	400KV/220KV KORADI-ICT-1 ON TBC @ KORADI	23-May-20	09:00	31-May-20	00:00	Continuous	MSETCL	Shifting of 400/220kV 100MVA ICT 1 on TBC HV side for CB pole and mechanism Overhauling & testing	Outages will be availed subject to weather conditions.
129	887	AURANGABAD - 400KV - BUS 2	24-May-20	9:00	24-May-20	18:00	D	POWERGRID_WR1	For AMP works	
130	889	KORADI-III - 765KV - BUS 2	24-May-20	08:00	24-May-20	18:00	Daily	MEGPTCL	Maintenance of Bus Related Equipments	
131	899	TALEGAON - 220KV - BUS 1	24-May-20	9:00	24-May-20	18:00	D	POWERGRID_WR1	For AMP works	
132	901	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	25-May-20	9:00	25-May-20	18:00	D	POWERGRID_WR1	For AMP works & 400KV Pune-GIS-Aurangabad-1 LINE WITH LINE REACTOR WILL BE OUT OF SERVICE DUE TO DOUBLE BUS SCHEME & 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 AR to be keep in non auto mode for safety measures.	
133	912	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	25-May-20	09:00	25-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through Tie CB 428.
134	913	765KV-AKOLA (2)-EKTUNI-2 L/R@ AKOLA (2) - 765KV	25-May-20	09:00	25-May-20	18:00	Daily	MEGPTCL	Reactor Maintenance Activities	
135	916	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	25-May-20	9:00	31-May-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola.	
136	917	400KV-CHANDRAPUR-GCR-PARLI-M-3	25-May-20	08:00	27-May-20	17:00	Continuous	MSETCL	servicing & overhauling of S & S power make R & B-ph PG-2 Isolators	CHD-2 Ckt. No.- 1 & 2, 400KV CHD- Khaparkheda ckt. And HVDC ckt. No.- 1 & 2 will be in service.
137	922	KORADI-III - 765KV - BUS 1	26-May-20	09:00	26-May-20	18:00	Daily	MEGPTCL	Maintenance of Bus Related Equipments	
138	947	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	26-May-20	09:00	26-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
139	954	400KV-KARAD-JAIGAD-1	26-May-20	09:00	29-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt
140	955	400KV-KARAD-JAIGAD-2	26-May-20	09:00	29-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt

Sr.No.	OCCM Sr. No	Line / Element	From Date	Time (Hrs)	To Date	Time (Hrs)	Daily/Continuous	Name of Requesting Agency	Reason	Remarks
141	986	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	27-May-20	09:00	27-May-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
142	987	220KV-PARLI-PARLI-M-2	27-May-20	09:00	27-May-20	18:00	Daily	MSETCL	Line maintenance	-
143	996	AURANGABAD - 400KV - BUS 1	28-May-20	9:00	28-May-20	18:00	D	POWERGRID WR1	For AMP works	
144	1000	TALEGAON - 220KV - BUS 2	28-May-20	9:00	28-May-20	18:00	D	POWERGRID WR1	For AMP works	
145	1001	CHANDRAPUR - 400KV - BUS 2	28-May-20	9:00	30-May-20	18:00	D	POWERGRID WR1	Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2	
146	1017	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND FUTURE at LONIKHAND-II - 400KV	28-May-20	09:00	28-May-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 2 will be in service for no supply interruption.
147	1018	400KV-LONIKHAND-CHAKAN-1	28-May-20	09:00	28-May-20	18:00	Daily	MSETCL	Half yearly testing and maintenance activities.	---
148	1025	400KV-KALWA-PUNE-PG-1	29-May-20	12:00	29-May-20	14:00	Daily	WTPL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	
149	1033	MAIN BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND LONIKHAND-II - 400KV - BUS 2 at LONIKHAND-II - 400KV	29-May-20	09:00	29-May-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 2 will be in service for no supply interruption.
150	1043	400KV-LONIKHAND-PUNE-PG-1	29-May-20	10:00	29-May-20	12:00	Daily	WTPL	Planned Annual outage	
151	1045	400KV-KHANDWA-DHULE-MS-2	29-May-20	9:00	30-May-20	18:00	D	POWERGRID WR1	For replacing existing porcelain/CLR pilot insulators with Glass insulators & 400KV-KHANDWA-DHULE-MS-1 AR to be keep in non auto mode for safety measures.	
152	1048	400KV-LONIKHAND-PUNE-PG-1	30-May-20	12:00	30-May-20	14:00	Daily	WTPL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	
153	1049	400KV-KALWA-PUNE-PG-1	30-May-20	9:00	30-May-20	18:00	D	POWERGRID WR1	For Line side equipment AMP Works	
154	1062	400KV-KALWA-PUNE-PG-1	30-May-20	10:00	30-May-20	12:00	Daily	WTPL	Planned Annual outage	
155	1066	BOISAR-M - 220KV - BUS 2	30-May-20	06:00	31-May-20	18:00	Continuous	MSETCL	1) B-Bus Isolator maintenance work. 2) Pilot string replacement identified in PID.	1) During the outage on 220kV B-Bus, all lines/Bays will shifted from B-Bus to A-Bus through TBC. 2) Load affected NIL.
156	1067	400KV-JAIGAD-NEW KOYNA-1	30-May-20	09:00	31-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt
157	1068	400KV-JAIGAD-NEW KOYNA-2	30-May-20	09:00	31-May-20	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt
158	1070	400KV-PARLI-SOLAPUR-2	31-May-20	9:00	31-May-20	17:00	Daily	WTPL	A/R mode to be kept OFF for attending additional earthing in towers (Line will be in service)	
159	1073	400KV-KALWA-PADGHE-2	31-May-20	07:00	31-May-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
160	1082	400KV-PARLI-SOLAPUR-1	31-May-20	9:00	31-May-20	17:00	Daily	WTPL	Planned Annual outage	
161	1084	400KV-KALWA-PADGHE-2	31-May-20	09:00	31-May-20	18:00	Daily	MSETCL	Bay Maintenance & Testing work.	Bay Maintenance & Testing work.

Not Considered Outage list in 530th WRPC OCCM										
Sr.No.	OCCM Sr. No	Line / Element	From Date	Time (Hrs)	To Date	Time (Hrs)	Daily/Continuous	Name of Requesting Agency	Reason	Remarks
1	368	KALWA - 400KV - BUS 2	31-May-20	09:00	31-May-20	18:00	Daily	MSETCL	Bus PT Maintenance & insulator cleaning work	Bus PT Maintenance & insulator cleaning work
2	901	HVDC 500KV CHANDRAPUR HVDC POLE 2	23-May-20	06:00	31-May-20	18:00	Continuous	MSETCL	Stringing from loc no 278 to 294 of 500KV Chandrapur-Padghe HVDC Line Pole 1 due to construction of Kochi-Ambezari Dam under ORC scheme	ORC work of Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambezari Dam.
3	1066	400KV-KALWA-KHARGHAR-1	31-May-20	07:00	31-May-20	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work

State Element Outage list for the month of May 2020

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	DHULE - BABLESHWAR - I	2-May-20	09:00	2-May-20	17:00	Daily	Quarterly Maintenance work & Relay Testing and DCRM tests	MSETCL	MSETCL	400kV Dhule ckt II,400kV Bhusawal and 400kV Aurangabad,400kV Ektuni-1 and 2 lines will be in service
2	400 KV	MAIN BAY-401 OF GT-10 @ KORADI-2	2-May-20	07:00	2-May-20	13:00	Daily	Tan delta Measurement of Bus CT and DCRM, IR Measurement of CB at Bay 401	MSETCL	MSETCL	GT10 will remain in service through Tie bay 402
3	400 KV	TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	4-May-20	08:00	4-May-20	14:00	Daily	ROUTINE MAINTENANCE WORK	MSETCL	MSETCL	ROUTINE MAINTENANCE WORK
4	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	4-May-20	09:00	4-May-20	18:00	Daily	Premonsoon Maintenance	MSETCL	MSETCL	Monday is load Staggering Day
5	400 KV	DHULE - BABLESHWAR - II	4-May-20	09:00	4-May-20	17:00	Daily	Quarterly Maintenance work & Relay Testing and Diagnostic testing works of CTs	MSETCL	MSETCL	400kV Dhule ckt I,400kV Bhusawal and 400kV Aurangabad,400kV Ektuni-1 and 2 lines will be in service
6	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	4-May-20	07:00	5-May-20	13:00	Daily	IR, Tan delta measurement of Bushing Tan delta Measurement of Line of Bay 430	MSETCL	MSETCL	Load will shifted to 501MVA 400/220/33kv ICT II
7	400 KV	400/220/33 KV 500MVA ICT - 2 @ WARORA	4-May-20	07:00	4-May-20	15:00	Daily	Bus/Line/Tie CTs,Syn CVT Tan delta & Routine Maintenance & Diagnostic testing work etc	MSETCL	MSETCL	400KV ICT No -2handed over to 400kv PADGHA
8	400 KV	KARAD - TALANDGE CKT 2	5-May-20	08:00	6-May-20	20:00	Daily	For cold washing work	MSETCL	MSETCL	Talange 1 will be in service
9	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	5-May-20	09:00	5-May-20	18:00	Daily	Line signature analysis	MSETCL	MSETCL	-
10	400 KV	400 KV FUTURE BAY II @ WARORA	5-May-20	07:00	5-May-20	15:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	400KV Bay No 422 charged on No Load
11	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	5-May-20	08:00	5-May-20	18:00	Daily	Quarterly & pre-monsoon Maint. of ICT & Bay	MSETCL	MSETCL	Load will be managed on other Two ICTs
12	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	6-May-20	10:00	6-May-20	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500 MVA ICT - 1
13	400 KV	125 MVAr BUS REACTOR @ TALANDGE	6-May-20	09:00	6-May-20	18:00	Daily	Quarterly Maintenance Work Testing work	MSETCL	MSETCL	Wednesday is pick load day (lower Bus Voltage)
14	400 KV	NEW KOYNA -KARAD -CKT 2	6-May-20	08:00	9-May-20	17:00	Daily	Cold washing work	MSETCL	MSETCL	New koyna 1 will be in service
15	400 KV	400/220/33 KV 315MVA ICT - 3 @ KARAD	6-May-20	08:00	6-May-20	18:00	Daily	Quarterly & pre-monsoon Maint. of ICT & Bay	MSETCL	MSETCL	Load will be managed on other Two ICTs
16	400 KV	400/220 KV 315MVA ICT - 1 @ KARAD	7-May-20	08:00	7-May-20	18:00	Daily	Quarterly & pre-monsoon Maint. of ICT & Bay	MSETCL	MSETCL	Load will be managed on Other Two ICTs
17	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	7-May-20	09:30	7-May-20	17:30	Daily	"Both 400 kV & 220kV CB DT work & Half yearly Maint. work"	MSETCL	MSETCL	"Work carried out by shifting load on Respective TBC bay"
18	400 KV	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	8-May-20	08:00	8-May-20	17:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Yes, 400 KV STATION TF 8A @ CHANDRAPUR SWG S/S(through Tie bay 411) will be in service.
19	400 KV	400/220/33KV SPARE ICT @ KORADI 2	8-May-20	07:00	8-May-20	13:00	Daily	IR, Tan delta measurement of Bushing	MSETCL	MSETCL	Spare ICT is under no load contion
20	400 KV	MAIN BAY- 414 OF YELWAN CKT-1 @ AKOLA	8-May-20	08:00	8-May-20	14:00	Daily	ROUTINE MAINTENANCE AND TESTING WORK	MSETCL	MSETCL	CIRCUIT CHARGE THROUGH TIE BAY 415
21	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	9-May-20	08:00	9-May-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kV 315MVA ICT-1 & 315MVA ICT- II & 501 MVA ICT-IV will be in service
22	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	9-May-20	08:00	9-May-20	15:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS
23	400 KV	TIE BAY - 403 OF 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	11-May-20	10:00	11-May-20	12:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
24	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	11-May-20	07:00	12-May-20	13:00	Daily	IR, Tan delta measurement of Bushing	MSETCL	MSETCL	Load will shifted to 501 MVA, 400/220/33KV ICT I
25	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	11-May-20	08:00	11-May-20	18:00	Daily	ROUTINE MAINTENANCE,TESTING AND PRE-MONSOON WORK	MSETCL	MSETCL	ICT-2 WILL BE IN SERVICE
26	400 KV	KARAD - TALANDGE CKT 2	11-May-20	08:00	11-May-20	18:00	Daily	Cold washing work	MSETCL	MSETCL	Talange 1 will be in service
27	400 KV	PADGHE - NAGOTHANE 1	11-May-20	08:00	11-May-20	17:00	Daily	Jumper tightening and cold washing work	MSETCL	MSETCL	nil
28	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	11-May-20	07:00	11-May-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
29	400 KV	MAIN BAY - 402 OF 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	11-May-20	07:00	11-May-20	09:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
30	400 KV	MAIN BAY (405) OF 500MVA ICT - 2 @ KHAPARKHEDA	11-May-20	13:00	11-May-20	15:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
31	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	11-May-20	08:00	21-May-20	18:00	Daily	PID testing work	MSETCL	MSETCL	-
32	400 KV	MAIN BAY (410) OF GT-5 @ KHAPARKEDA	12-May-20	10:00	12-May-20	12:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
33	400 KV	PADGHE - NAGOTHANE 2	12-May-20	08:00	12-May-20	17:00	Daily	Jumper tightening and cold washing work	MSETCL	MSETCL	nil
34	400 KV	TIE BAY - 409 OF GT - 5 @KHAPARKHEDA S/s	12-May-20	13:00	12-May-20	15:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
35	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	12-May-20	08:00	12-May-20	18:00	Daily	Quarterly MAintenance	MSETCL	MSETCL	Quarterly MAintenance
36	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	12-May-20	07:00	12-May-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
37	400 KV	TIE BAY (406) OF 500MVA ICT - 2 @ KHAPARKHEDA	12-May-20	07:00	12-May-20	09:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
38	400 KV	NEW KOYNA -KARAD -CKT 2	12-May-20	08:00	12-May-20	17:00	Daily	Cold washing work	MSETCL	MSETCL	New koyna 1 will be serve
39	400 KV	CHANDRAPUR-PARLI CKT-3	13-May-20	09:00	13-May-20	18:00	Daily	Line signature analysis	MSETCL	MSETCL	-
40	400 KV	TIE BAY (412) OF KORADI-1 @ KHAPARKHEDA	13-May-20	10:00	13-May-20	12:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
41	400 KV	MAIN BAY (411) OF KORADI-1 @ KHAPARKHEDA	13-May-20	07:00	13-May-20	09:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
42	400 KV	CHANDRAPUR-PARLI CKT-3	13-May-20	07:00	13-May-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
43	400 KV	PADGHE - NAGOTHANE 1	13-May-20	08:00	13-May-20	17:00	Daily	Jumper tightening and cold washing work	MSETCL	MSETCL	nil
44	400 KV	NEW KOYNA-KARAD -CKT 1	13-May-20	08:00	13-May-20	18:00	Daily	Cold washing work	MSETCL	MSETCL	New koyna 2 will be service
45	400 KV	MAIN BAY (414) OF KORADI CKT - 2 @ KHAPARKHEDA 2	13-May-20	13:00	13-May-20	15:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
46	400 KV	MAIN BAY (410)OF BHUSAWAL (KHADKA) @ AKOLA	14-May-20	08:00	14-May-20	14:00	Daily	ROUTINE MAINTENANCE AND TESTING WORK	MSETCL	MSETCL	CIRCUIT WILL BE CHARGED THROUGH TIE BAY 409
47	400 KV	MAIN BAY (419) OF STATION T/F 5B @ KHAPARKHEDA	14-May-20	13:00	14-May-20	15:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
48	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	14-May-20	09:00	14-May-20	18:00	Daily	Half yearly testing and maintenance activities.	MSETCL	MSETCL	---
49	400 KV	MAIN BAY 416 OF STN TF 5A @ 400 KV KHAPARKHEDA 2	14-May-20	10:00	14-May-20	12:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
50	400 KV	PADGHE - NAGOTHANE 2	14-May-20	08:00	14-May-20	17:00	Daily	Jumper tightening and cold washing work	MSETCL	MSETCL	nil
51	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	14-May-20	07:00	14-May-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
52	400 KV	TIE BAY (415) OF KORADI CKT - 2 & STN TF 5A @ KHAPARKHEDA	14-May-20	07:00	14-May-20	09:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
53	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	15-May-20	09:00	15-May-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption
54	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	15-May-20	09:00	15-May-20	17:00	Daily	Quarterly maintenance	MSETCL	MSETCL	Quarterly maintenance
55	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	15-May-20	06:00	15-May-20	17:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Yes, 400 KV STATION TF 8B will be in service through Tie bay 408
56	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	15-May-20	09:00	15-May-20	16:00	Daily	1. Measurement of ICT-II B phase CT tan delta work. 2. 413 ICT II Bus isolator alignment work	MSETCL	MSETCL	Nil
57	400 KV	MAIN BAY (417) OF CHANDRPUR CKT @ KHAPARKHEDA	15-May-20	10:00	15-May-20	15:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
58	400 KV	TIE BAY (418) OF CHANDRAPUR CKT & STATION TF - B @ KHAPARKHEDA	15-May-20	07:00	15-May-20	09:00	Daily	PID Testing of Insulator	MSETCL	MSETCL	Online Work
59	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	16-May-20	08:00	16-May-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT- I & 315MVA ICT- II & 501 MVA ICT-III will be in service
60	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	18-May-20	09:00	18-May-20	23:59	Daily	Premonsoon Maintenance Work. 33kv IPS Coating Work 33kv Support insulator coating work	MSETCL	MSETCL	Monday is Load staggering day in Kolhapur
61	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	18-May-20	08:00	18-May-20	18:00	Daily	ROUTINE MAINTENANCE,TESTING AND PRE-MONSOON WORK	MSETCL	MSETCL	ICT-1 WILL BE IN SERVICE
62	400 KV	KARAD - TALANDGE CKT 2	18-May-20	08:00	18-May-20	18:00	Daily	Cold washing work	MSETCL	MSETCL	Talandge 1 will be in service
63	400 KV	KHADKA - BABLESHWAR	19-May-20	09:00	19-May-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kV Dhule ckt I and II, 400kV Aurangabad,400kV Ektuni-1 and 2 lines will be in service
64	400 KV	NEW KOYNA -KARAD -CKT 2	19-May-20	08:00	20-May-20	18:00	Daily	Cold washing work	MSETCL	MSETCL	New koyna -karad 1 will be service
65	400 KV	THAPTI TANDA - WALUJ	19-May-20	08:00	19-May-20	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
66	400 KV	WARORA - IEPL	19-May-20	09:00	19-May-20	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work,Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
67	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	20-May-20	08:00	20-May-20	17:00	Daily	Premonsoon Maintenance & Diagnostic Testing Work	MSETCL	MSETCL	-
68	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	20-May-20	09:00	20-May-20	18:00	Daily	Line Conductor and Earthwire hardware tightening work	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
69	400 KV	JEJURI- KOYNA STAGE-IV	21-May-20	08:00	21-May-20	18:00	Daily	Cold washing work and pid faulty insulator replacement work	MSETCL	MSETCL	Lonikand - Jejuri will be service
70	400 KV	MAIN BUS - 2 @ LONIKAND 2	21-May-20	09:00	21-May-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kV BUS 1 will be in service for no supply interruption.
71	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	21-May-20	09:00	21-May-20	18:00	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
72	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	21-May-20	09:00	21-May-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kV Dhule cktI and II,400kV Bhusawal ,400kV Ektumi- I lines will be in service
73	400 KV	KARAD - TALANDGE CKT 2	21-May-20	09:00	21-May-20	18:00	Daily	Cold washing work	MSETCL	MSETCL	Talandge 1 will be service
74	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	22-May-20	09:30	22-May-20	17:30	Daily	"DT work & Half yearly Maint. work"	MSETCL	MSETCL	Load will be managed by I/C II.
75	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	22-May-20	09:00	22-May-20	16:00	Daily	CT , tan delta measurement work	MSETCL	MSETCL	Nil
76	400 KV	400KV RPL LINE REACTOR @ 400KV KORADI	23-May-20	08:00	23-May-20	18:00	Daily	Winding resistance of reactor and distance relay testing.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
77	400 KV	KORADI-NANDGAONPETH (RPL)	23-May-20	08:00	23-May-20	18:00	Daily	Winding resistance of reactor and distance relay testing.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
78	400 KV	400/220/33 KV 315 MVA ICT - 1 @ KOLHAPUR	25-May-20	09:00	25-May-20	18:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	Monday is Load Staggering day in kolhapur
79	400 KV	NEW KOYNA -KARAD -CKT 2	25-May-20	08:00	26-May-20	19:00	Daily	Cold washing work	MSETCL	MSETCL	Koyna 1 will be servive
80	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	25-May-20	08:00	25-May-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	nil
81	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	26-May-20	08:00	26-May-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	nil
82	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	26-May-20	09:00	26-May-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	spare ICT
83	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	27-May-20	08:00	27-May-20	17:00	Daily	Premonsoon Maintenance & Diagnostic Testing Work	MSETCL	MSETCL	_
84	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	27-May-20	08:00	27-May-20	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
85	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	27-May-20	08:00	27-May-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	nil
86	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	28-May-20	09:00	28-May-20	18:00	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
87	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	28-May-20	08:00	28-May-20	14:00	Daily	Premonsoon maintenance work and relay testing work	MSETCL	MSETCL	-
88	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	28-May-20	09:00	28-May-20	18:00	Daily	HV backup relay testing work. Bay Maint. Work.	MSETCL	MSETCL	-
89	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	29-May-20	09:00	29-May-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.
90	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	29-May-20	08:00	29-May-20	18:00	Daily	For pre-monsoon maintenance and R&M work	MSETCL	MSETCL	315MVA ICT-2 & 3 will be in service
91	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	30-May-20	09:30	30-May-20	17:30	Daily	" CT Ratio change, DT work & Half yearly Maint. work"	MSETCL	MSETCL	Load will be managed by I/C I
92	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	30-May-20	08:00	30-May-20	14:00	Daily	Premonsoon maintenance and relay testing work	MSETCL	MSETCL	-
93	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	30-May-20	08:00	30-May-20	15:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS