

Maharashtra State Load Despatch Centre										
Monthly Outage list approved in WRLDC OCCM for the Month of May' 2021										
Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
1	11	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	PID Work	1-May-21	08:00	1-May-21	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III lines are on DC tower so both lines require on same day A/R out.
2	27	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	1-May-21	08:00	8-May-21	19:00	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
3	28	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	For Carrying PID Work	1-May-21	08:00	10-May-21	18:00	-
4	29	MSETCL	400KV-BHUSAWAL-AURANGABAD-M (WALUJ)-1	Continuous	Samruddhi Highway work & CB, CTs, relay testing work	1-May-21	09:00	10-May-21	17:00	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I&II and will be in in service
5	33	MSETCL	BABLESHWAR -400KV B/R 1 ON TBC @ BABHALESHWAR	Continuous	400kV CGL make CB pole overhauling work	1-May-21	09:00	15-May-21	18:00	400kV Reactor I on TBC
6	34	MSETCL	LONIKHAND-II - 400KV - BUS 1	Daily	Diagnostic testing. (PID)	1-May-21	10:00	15-May-21	18:00	One and half breaker system ,no line interruption .
7	35	ATIL	400KV-TIRODA-WARORA-2	Daily	Auto recloser to be kept in disable mode while carrying out PID testing in Ckt-2	1-May-21	08:00	25-May-21	18:00	AR Mode OFF
8	36	ATIL	400KV-TIRODA-WARORA-1	Daily	Auto recloser to be kept in disable mode while carrying out PID testing in Ckt-1	1-May-21	08:00	25-May-21	18:00	AR Mode OFF
9	48	MSETCL	400KV-CHANDRAPUR-II-NANDED-2	Daily	PID Work	1-May-21	08:00	31-May-21	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III lines are on DC tower so both lines require on same day A/R out.
10	49	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing work	1-May-21	08:00	31-May-21	17:00	400KV SSNNL I & II is to be kept on Nonauto mode
11	58	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-May-21	09:00	31-May-21	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
12	59	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-May-21	09:00	31-May-21	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
13	60	MSETCL	400KV-KARAD-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-May-21	09:00	31-May-21	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
14	61	MSETCL	400KV-KARAD-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-May-21	09:00	31-May-21	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
15	62	MSETCL	KALWA - 400KV - BUS 2	Daily	Bus CVT Maintenance & Testing work	1-May-21	09:00	1-May-21	18:00	Bus CVT Maintenance & Testing work
16	63	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	1-May-21	08:00	1-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
17	68	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	A) At HVDC TL O&M Sub-Division, Padghe:-2.Jumper Nut-Bolt Tightening of Cut-Point Location at 866, 867, 868, 869, 870, 871, 944, 945, 40, 41, 57 and 59- Total 12 tower locations. 1.To attend broken Disc Insulators replacement at Towers at Loc. No. 867, 869, 870, 871 & 874- Total 10 Strings in 05 locations. 3.Hardware Nut-Bolt Tightening at 866, 867, 868, 869, 870, 871, 944, 945, 40, 41, 57 and 59- Total 12 tower locations. 4.Fixing of Corona Ring at loc. No. 881. 5.Chemical Cleaning of insulator strings at Tower Locations , 866, 867, 868, 869, 870, 871, 40 & 41-Total 96 Strings in 08 locations. Out of 8 locations, 06 locations are in Naneghat area and 2 locations are at Railway crossing. B) At HVDC TL O&M Sub-Division, Junnar :- 1.To attend broken Disc Insulators replacement at Towers at Loc. No. 815, 824, 851- Total 06 strings in 03 locations. 2.Replacement of damaged Earth wire (Strand cut) between the span 840-841. 3.Jumper Nut-Bolt Tightening of Cut-Point Location at 737,741,751, 755,756,768,794,807,824,825,827,835,844,851,861, 865, 4 Total 16 tower loc.s. 4. Chemical Cleaning of insulator strings at Tower Locations - 738, 739, 740, 741, 755, 756, 779, 809, 812, 836, 837, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, Total 154 Strings in 27 locations in Bird shit /Dust pollution Area /NH road Crossing. work at 400kV Padghe S/s Bay maintenance work Diagnostic testing work	2-May-21	08:00	3-May-21	18:00	1.The work needs to be carried to avoid the occurrences at Naneghat- Manikdoh area which are critical locations before the peak load in the summer season. 2. The planned outage had proposed for above work on did. 06.03.2021, 07.03.2021 and 27.03.2021, 28.03.2021 on daily basis. However the outage has not approved by LD, Kalwa.
18	71	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Emergency tree cutting work	2-May-21	08:00	2-May-21	17:00	nil
19	75	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	2-May-21	08:00	2-May-21	17:00	400KV Dhule-SSNNL I is to be kept on NonAuto mode
20	85	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Online PID testing	3-May-21	08:00	3-May-21	17:00	400KV Dhule-Babhaleshwar II is to kept on Non-auto mode
21	106	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Cold washing , E/W replacement Work & Faulty string replacement Work	3-May-21	08:00	5-May-21	18:00	Planned outage
22	112	MSETCL	LONIKHAND - 400KV - TRANSFER BUS 1	Continuous	C.B OVERHAULING WORK (Pole & Mechanism)	3-May-21	08:00	8-May-21	20:00	Due to an unavailability of Agency unable to do work during Month March 2021 (01 to 06 March)
23	114	MSETCL	CHANDRAPUR-GCR - 400KV - TRANSFER BUS 1	Continuous	Overhauling & Servicing of Poles & Interrupter of all three phases.	3-May-21	09:00	8-May-21	18:00	TBC-2 bay will be available.
24	118	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID Testing work	3-May-21	08:00	30-May-21	17:00	400KV SSNNL I & II is to be kept on Nonauto mode

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
25	119	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Online PID testing work	3-May-21	08:00	31-May-21	17:00	400KV Dhule-Babhaleshwar I is to kept on Non-auto mode
26	135	MSETCL	400KV-IEPL-WARORA-1	Daily	Shifting of line on ERS at ch 27+400 for height raising work of Samrudhi highway	4-May-21	06:00	4-May-21	22:00	-
27	173	MSETCL	DHULE-MS - 400KV - BUS 1	Daily	For erection of hanger of PG Isolator for 125MVAR Bus Reactor Bay	5-May-21	07:00	5-May-21	18:00	Load can be shifted on Main Bus -II. Outage will be carried out by Project Dept.
28	178	MSETCL	400KV-IEPL-KORADI-II-1	Daily	For bunching of conductor by ERS between loc no 204 -205 ( for height raising work of Samrudhi highway)	5-May-21	06:00	5-May-21	21:00	-
29	179	MSETCL	400KV-IEPL-WARORA-1	Daily	For bunching of conductor by ERS between loc no 204 -205 ( for height raising work of Samrudhi highway)	5-May-21	06:00	5-May-21	21:00	-
30	180	MSETCL	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	5-May-21	07:00	5-May-21	17:00	Kala-2 line will be charged from Main line bay 401, no interruption to line
31	197	MSETCL	132KV-PENCH-KANHAN-1	Daily	Routine Maintenance work.	5-May-21	09:00	5-May-21	17:00	-
32	204	MSETCL	JEUR - 220KV - BUS 1	Daily	Outage required for Quarterly Maintenance	5-May-21	10:00	5-May-21	18:00	Quarterly Maintenance
33	205	MSETCL	132KV-DHARNI-NEPANAGAR-1	Daily	"1)Replacement of R-ph metering PT 2) Line Signature Analysis & Other Maintenance Works of Line "	5-May-21	11:00	5-May-21	17:00	Nil
34	211	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	5-May-21	08:00	5-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
35	220	MSETCL	220KV-PARLI-PARLI-M-1	Daily	Routine maintenance	6-May-21	10:00	6-May-21	16:00	-
36	221	MSETCL	DHULE-MS - 400KV - BUS 2	Daily	For erection of hanger of PG Isolator for 125MVAR Bus reactor bay.	6-May-21	07:00	6-May-21	18:00	Load can be shifted on main bus -1 Outage will carried out by project dept
37	222	MSETCL	WARORA - 400KV - BUS 1	Daily	Routine maintenance and diagnostics testing such as CVT tan delta & maintenance work	6-May-21	08:00	6-May-21	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV.125MVAR reactor kept off position during outage.
38	229	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Emergency tree cutting work	6-May-21	08:00	6-May-21	17:00	nil
39	234	MSETCL	400KV-CHAKAN-PUNE-PG-1	Daily	Routine Line Maintenance work.	6-May-21	08:00	6-May-21	18:00	WRLDC Outage.
40	235	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	6-May-21	08:00	6-May-21	18:00	NA
41	252	BDTCL	TIE BAY - 400KV-DHULE-DHULE-MS-2 AND 765KV/400KV DHULE-ICT-1 at DHULE - 400KV	Daily	AMP Works	6-May-21	13:00	6-May-21	18:00	
42	256	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Cold washing , E/W replacement Work & Faulty string replacement Work	6-May-21	08:00	8-May-21	18:00	Planned outage
43	259	MSETCL	220KV-NASIK-NAVSARI-1	Daily	For replacement of old disk insulator by porcelain long rod, Diagnostic testing,broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixing of issued.	7-May-21	09:29	8-May-21	18:33	-
44	260	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND 400KV-TIRODA-WARORA-1	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	7-May-21	08:00	7-May-21	17:00	Only Tie CB 412 is in OFF condition, respective ckt charged through its own main CB.
45	267	MSETCL	220KV-PARLI-PARLI-M-2	Daily	1. C & Tan delta measurement of CVTs. 2.Bay maintenance work.	7-May-21	09:00	7-May-21	18:00	-
46	268	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling	7-May-21	08:00	8-May-21	17:00	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling
47	276	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Maintenance Work if any	7-May-21	07:00	7-May-21	18:00	Nil
48	297	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	R&M Work at Borivali end	7-May-21	10:00	7-May-21	18:00	R&M Work at Borivali end
49	304	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance	8-May-21	08:00	8-May-21	17:00	-
50	320	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	A) HVDC TL O&M Sub-Division, Padghe:- 1.Jumper Nut-Bolt Tightening of Cut-Point Location at loc. No. 996, 40, 41, 59, 57, 57A-Total 06 tower locations. 2.Hardware Nut Bolt Tightening at loc. No. 996, 40, 41, 59, 57, 57A- Total 06 tower locations. 3.Chemical Cleaning of insulators at Tower Locations &#65533; 40, 41- Total 26 strings in 02 locations of Dust pollution Area of Railway Crossing at Khadavali.  B) HVDC TL O&M Sub-Division, Junnar:- 1. To attend broken Disc Insulators replacement at Towers at Loc. No. 867, 869, 870, 871 & 874- Total 5 locations-Total 10 Strings. 2. Jumper Nut-Bolt Tightening of Cut-Point Location no. 731, 732, 734, 735, 749, 760&#65533; Total 06 loc.s. 3.Fixing of Corona Ring at loc. No. 854. 4.Chemical Cleaning of insulator strings at Tower Locations &#65533; 733, 734, 747, 748, 791, 792, 801, 802, 827, 828- Total 53 Strings in 10 nos. of Bird shit Locs /Dust pollution Area /NH road Crossing. Work at 400KV padghe S/s. Bay maintenance work Diagnostic testing work	8-May-21	08:00	8-May-21	18:00	1.The work needs to be carried to avoid the occurrences at Naneghat- Manikdoh area which are critical locations before the peak load in the summer season. 2. The planned outage had proposed for above work on dtd. 13.03.2021 and 29.03.2021. However the outage has not approved by LD, Kalwa.
51	331	MSETCL	BOISAR-M - 220KV - BUS 2	Continuous	220kV B Bus Iso. r/m works.	8-May-21	07:00	9-May-21	19:00	220kV B Bus Iso. r/m works.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
52	332	POWERGRID_WR2	220KV-BOISAR-TARAPUR	D	AMP	8-May-21	9:00	8-May-21	17:30	PG-WR2-Boisar
53	333	MSETCL	400KV-KALA-KUDUS-2	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	9-May-21	07:00	9-May-21	17:00	Kala-2 line will be charged from Tie bay 402, no interruption to line
54	335	MSETCL	400KV-WARORA-CHANDRAPU-II-I	Daily	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling	9-May-21	08:00	9-May-21	17:00	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling
55	337	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTTING AT KUDUS END.	9-May-21	9:00	9-May-21	17:30	
56	340	MSETCL	220KV-NASIK-NAVSARI-2	Daily	For replacement of old disk insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixingif issued.	9-May-21	09:24	10-May-21	18:25	-
57	350	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Half yearly maintenance and diagnostic testing.	9-May-21	08:00	9-May-21	18:00	400kV Parali-Lonikand-II Ckt-I will be in service .
58	352	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing & E/W replacement Work	9-May-21	08:00	10-May-21	18:00	Planned outage
59	353	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	9-May-21	08:00	15-May-21	19:00	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
60	355	POWERGRID_WR2	400KV-KALA-KUDUS-2	D	AMP of Line/Bays. Dia to be kept at both end. Ckt#1 to be kept in non auto mode	9-May-21	9:30	9-May-21	18:00	PG-WR2-KALA
61	362	MSETCL	400KV-IEPL-WARORA-1	Daily	For debunching of conductor, shifting of line from ERS to newly erected tower at ch 27+400 ( for height raising work of Samrudhi highway)	10-May-21	06:00	10-May-21	22:00	-
62	363	MSETCL	400KV-IEPL-KORADI-II-I	Daily	For debunching of conductor, shifting of line from ERS to newly erected tower at ch 27+400 ( for height raising work of Samrudhi highway)	10-May-21	06:00	10-May-21	22:00	-
63	364	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	PRE MANSOON MAINTENANCE WORK	10-May-21	09:00	10-May-21	17:00	PRE MANSOON MAINTENANCE WORK
64	369	MSETCL	AKOLA - 400KV - BUS 2	Daily	Servicing & alignment of isolators /earth switches will be carried out by bimco isolators Ltd. Routine maint.& testing work	10-May-21	08:00	10-May-21	17:00	Bus-1 will be in service
65	370	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	10-May-21	08:00	10-May-21	17:00	NA
66	393	JPTL	400KV-KARAD-JAIGAD-2	Daily	Hotline Insulator washing	10-May-21	09:00	10-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both ciruicts to be kept into non auto mode during Hotline Washing.
67	394	JPTL	400KV-KARAD-JAIGAD-1	Daily	Hotline Insulator washing	10-May-21	09:00	10-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both ciruicts to be kept into non auto mode during Hotline Washing.
68	403	MSETCL	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2	Continuous	C.B OVERHAULING WORK (Pole & Mechanism)	10-May-21	08:00	15-May-21	20:00	Due to an unavailability of Agency unable to do work during Month March 2021 (08 to 13 March)
69	405	POWERGRID_WR2	220KV-BOISAR-NALASOPARA-1	D	AMP	10-May-21	9:00	10-May-21	17:30	PG-WR2-Boisar
70	440	JPTL	400KV-KARAD-JAIGAD-2	Daily	Hotline Insulator washing	11-May-21	09:00	11-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both ciruicts to be kept into non auto mode during Hotline Washing.
71	441	JPTL	400KV-KARAD-JAIGAD-1	Daily	Hotline Insulator washing	11-May-21	09:00	11-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both ciruicts to be kept into non auto mode during Hotline Washing.
72	444	MSETCL	ALKUD - 400KV - BUS 1	Daily	Diagnostic testing & QM work	11-May-21	10:00	11-May-21	17:00	Load will be managed on 400KV Main bus-2
73	445	MSETCL	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1	Daily	Diagnostic testing & QM work	11-May-21	10:00	11-May-21	17:00	Diagnostic testing & QM work
74	446	MSETCL	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2	Daily	Diagnostic testing & QM work	11-May-21	10:00	11-May-21	17:00	Diagnostic testing & QM work
75	447	MSETCL	400KV-ALKUD-SOLAPUR-1	Daily	Diagnostic testing & QM work	11-May-21	10:00	11-May-21	17:00	Load will be managed on Alkud-Kolhapur line
76	450	MSETCL	400KV-WARDHA-KORADI-II-I	Continuous	For erection of Monopole tower between loc 191-192 and Shifting of Koradi 2 Wardha ckt on ERS ( for height raising work of Samrudhi highway	11-May-21	06:00	12-May-21	22:00	-
77	456	MSETCL	400KV-IEPL-KORADI-II-I	Continuous	For erection of 03 no Monopole, dismantling of 01 no lattice tower & shifting of line on Monopole Tower at CH 23+650 ( for height raising work of Samrudhi highway) . Interim arrangement will be done as 400 kV Koradi-II-Warora	11-May-21	06:00	18-May-21	22:00	-
78	457	MSETCL	GTR - 4 ON TBC @ CHANDRAPUR	Continuous	1) Complete servicing & Overhauling of 400KV CGL make Breaker. 2) Measurement of DCRM & Timing & Contact resistance of breaker. 3) Supervisory trials of breaker. 4) Maintenance & Alignments of PG-1 & PG-2 Isolators.	11-May-21	09:00	19-May-21	18:00	Outage will be availed by shifting 400KV GT-4 bay on 400KV TBC-1 bay.
79	458	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	For Carrying PID Work	11-May-21	08:00	20-May-21	18:00	-
80	459	MSETCL	400KV-BHUSAVAL-BABLESHWAR-1	Continuous	Samrudhi Highway work & CB, CTs, relay testing work	11-May-21	09:00	20-May-21	17:00	400kV Ektuni ckt I&II,400kV , Dhule I&II and 400kV Aurangabad will be in in service

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
81	463	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	For Line AMP works Simultaneous outage of 400kV Pune-Parli#1 & 400kV Pune-Aurangabad -2 is required, due to multi circuit towers. 400kV Pune-Parli-2 & 400kV Pune-Aurangabad -1 A/R to be kept in non auto mode for safety measures.	12-May-21	8:00	12-May-21	18:00	
82	482	MSETCL	220KV-PANDURNA-KALMESHVAR-1	Daily	Routine Maintenance & Diagnostic testing work restringing of bottom ph conductor.	12-May-21	08:00	12-May-21	18:00	--
83	483	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	12-May-21	08:00	12-May-21	18:00	NA
84	489	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	12-May-21	09:00	12-May-21	17:00	--
85	498	JPTL	400KV-JAIGAD-NEW KOYNA-2	Daily	Hotline Insulator washing	12-May-21	09:00	12-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.
86	499	JPTL	400KV-JAIGAD-NEW KOYNA-1	Daily	Hotline Insulator washing	12-May-21	09:00	12-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.
87	502	MSETCL	TIE BAY - 400KV/20KV KORADI-II-GT-9 AND FUTURE	Daily	DCRM of CB 414-QS2& ROUTINE BAY MAINTENANCE	12-May-21	10:00	12-May-21	15:00	GT#9 WILL REMAIN SERVICE THROUGH MAIN BAY 413
88	504	MSETCL	220KV-AURANGABAD-CHITEGAON-2	Daily	Routine Maintenance & Diagnostic testing work	12-May-21	10:00	12-May-21	18:00	Routine Maintenance & Diagnostic testing work
89	516	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For Line AMP works Simultaneous outage of 400kV Pune-Parli#2 & 400kV Pune-Aurangabad -1 is required, due to multi circuit towers. 400kV Pune-Parli-1 & 400kV Pune-Aurangabad -2 A/R to be kept in non auto mode for safety measures.	13-May-21	8:00	13-May-21	18:00	
90	520	MSETCL	TIE BAY - 400KV-KALA-KUDUS-1 AND FUTURE	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	13-May-21	07:00	13-May-21	17:00	Kala-1 line will be charged from Main line bay 404, no interruption to line
91	523	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintenance Work	13-May-21	07:00	13-May-21	18:00	NIL
92	538	MSETCL	400KV-WARDHA-WARORA-1	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	13-May-21	09:00	13-May-21	17:00	1)400KV WARORA-IEPL Line is in ckt . 2) During this outage opportunity will be taken for DCRM of 420BAY CB at 400KV Warora s/stn. by Maintenance unit warora.
93	545	JPTL	400KV-JAIGAD-NEW KOYNA-2	Daily	Hotline Insulator washing	13-May-21	09:00	13-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.
94	546	JPTL	400KV-JAIGAD-NEW KOYNA-1	Daily	Hotline Insulator washing	13-May-21	09:00	13-May-21	18:00	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.
95	548	MSETCL	220KV-AURANGABAD-CHITEGAON-1 ON TBC @ CHITEGAON	Daily	Breaker CRM & timing measurement work.	13-May-21	11:00	13-May-21	16:00	he line will be in service through TBC
96	549	MSETCL	400 KV SWITCHYARD @ KHADKA	Daily	For taking LCM of all 400 KV LA which are in service	13-May-21	06:00	14-May-21	18:00	work will be carried online and no interruption
97	561	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance & Routine maintenance at 220kV Old GCR Parli SS	14-May-21	08:00	14-May-21	17:00	-
98	566	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	DT & Routine Maintenance work.	14-May-21	09:30	14-May-21	18:30	WRLDC Outage.
99	571	GETCO	400KV-SSP-DHULE-MS-1	Daily	PMM work. A/R of 400 KV SSP-Dhule-2 will remain out	14-May-21	7:00	14-May-21	18:00	
100	576	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	For Line bay AMP	14-May-21	8:00	14-May-21	18:00	
101	577	MSETCL	TIE BAY - 400KV/20KV KORADI-II-GT-9 AND FUTURE	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor	14-May-21	08:00	14-May-21	20:00	GT#9 WILL REMAIN SERVICE THROUGH MAIN BAY 413
102	582	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 2	Daily	Testing of Circuit Breaker	14-May-21	10:00	14-May-21	12:00	Bay Outage
103	583	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	Daily	Replacement of Metering CVT with new design CVTs as per OEM recommendation at Akola-2 SS	14-May-21	12:00	14-May-21	17:00	New CVT Replacement
104	584	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	R&M Work at Borivali end	14-May-21	10:00	14-May-21	18:00	R&M Work at Borivali end
105	586	POWERGRID_WR2	220KV-BOISAR-BORIVALI	D	AMP	14-May-21	9:00	14-May-21	17:30	PG-WR2-Boisar
106	587	NPCIL, TAPS 1&2	220kV Tarapur 1&2- Borivali	continuous	To carry maintenance works	15-May-21	8:00	16-May-21	20:00	Feeder outage is required
107	596	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	15-May-21	08:00	15-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
108	615	MSETCL	400KV-EKTUNI-BABLESHWAR-1 ON TBC @ BABHULESHWAR	Continuous	Isolator repairing and servicing work & quarterly maintenance work	15-May-21	09:00	17-May-21	17:00	400kV Ektuni ckt I on TBC
109	627	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	16-May-21	08:00	16-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
110	628	MSETCL	400KV-KALA-KUDUS-1	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	16-May-21	07:00	16-May-21	17:00	Kala-1 line will be charged from Tie bay 405, no interruption to line
111	633	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	PRE MANSOON MAINTENANCE WORK	16-May-21	09:00	16-May-21	17:00	For safety purpose outage is also required on 220KV PGCIL- BORIVALI LINE
112	635	MSETCL	400KV-KALWA-PADGHE-1	Daily	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	16-May-21	09:00	22-May-21	17:00	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
113	636	MSETCL	LONIKHAND - 400KV - BUS 2	Daily	Diagnostic testing. (PID)	16-May-21	10:00	31-May-21	18:00	One and half breaker system ,no line interruption.
114	640	POWERGRID_WR2	400KV-KALA-KUDUS-1	D	AMP of Line/Bays. Dia to be kept at both end. Ckt#2 to be kept in non auto mode	16-May-21	9:30	16-May-21	18:00	PG-WR2-KALA

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
115	656	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	17-May-21	08:00	17-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
116	671	MSETCL	TIE BAY-420 of ICT - 2 @ KORADI-2	Daily	DCRM of CB 420-Q52& ROUTINE BAY MAINTENANCE	17-May-21	10:00	17-May-21	15:00	ICT-II will remain in service through Main Bay 421
117	680	GETCO	400KV-SSP-DHULE-MS-2	Daily	PMM work. A/R of 400 KV SSP-Dhule-1 will remain out	17-May-21	7:00	17-May-21	18:00	
118	692	MSETCL	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2	Daily	1. LBB & Backup relay testing work. 2.Bay maintenance work.	18-May-21	09:00	18-May-21	18:00	-
119	693	MSETCL	KHAPARKHEDA - 400KV - BUS 2	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor (bay no. 408).	18-May-21	08:00	19-May-21	20:00	Outage proposed by project S/dn-II for connecting bus T connector
120	697	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	18-May-21	08:00	18-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
121	712	MSETCL	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1	Daily	Diagnostic testing & QM work	18-May-21	10:00	18-May-21	17:00	Diagnostic testing & QM work
122	713	MSETCL	ALKUD - 400KV - BUS 2	Daily	Diagnostic testing & QM work	18-May-21	10:00	18-May-21	17:00	Load will be managed on 400KV Main Bus-1
123	714	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	Daily	Diagnostic testing & QM work	18-May-21	10:00	18-May-21	17:00	Load will be managed on Alkud-Solpaur line
124	715	MSETCL	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	Daily	Diagnostic testing & QM work	18-May-21	10:00	18-May-21	17:00	Diagnostic testing & QM work
125	726	MSETCL	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV	Continuous	For outage on Bus-1	19-May-21	08:00	20-May-21	18:00	Planned outage
126	727	MSETCL	NEW KOYNA - 400KV - BUS 1	Continuous	Project work of ICT III & Routine maint. Work	19-May-21	08:00	20-May-21	18:00	Planned outage
127	729	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1	Daily	Routine Maintenance & Dignostic testing work .	19-May-21	09:00	19-May-21	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
128	732	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line Maintenance	19-May-21	08:00	19-May-21	17:00	-
129	740	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	19-May-21	09:00	19-May-21	17:00	_
130	749	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	For Shifting of Line from ERS to newly erected Monopoles at chainage 23+ 650 mtrs in respect of height raising work of Hindu Hrudaysamrat Balasaheb Thackeray Maharashtra Samruddhi Mahamarg.	19-May-21	10:00	19-May-21	17:00	Work will be carried out by MSRDC
131	750	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	TAN DELTA MEASUREMENT OF LINE CT & ROUTINE BAY MAINTENANCE	19-May-21	10:00	19-May-21	17:00	KORADI-II -IEPL WILL REMAIN IN SERVICE
132	751	MSETCL	400KV-EKTUNI-BABLESHWAR-2 ON TBC @ BABHALESHWAR	Continuous	Isolator repairing and servicing work & quartetly maintenance work	19-May-21	09:00	20-May-21	17:00	400kV Ektuni ckt II on TBC
133	760	MEGPTCL	KORADI-III - 765KV - BUS 1	Daily	Annual maintenance of Bus equipments	20-May-21	09:00	20-May-21	18:00	Bus Outage
134	767	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE	Daily	Routine Maintenance & Diagnostic testing work .	20-May-21	09:00	20-May-21	17:00	Line will be charged through main CB 429.
135	777	MSETCL	400KV-CHAKAN-PUNE-PG-1	Daily	Diagnostic testing and maintenance activities.	20-May-21	09:00	20-May-21	17:00	---
136	788	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	20-May-21	10:00	20-May-21	18:00	NA
137	792	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-1	C	Diversion of towers for Nagpur-Mumbai Samrudhi Express Highway crossing. Total 3 no of towers to be shifted & erection and stringing works.	21-May-21	7:00	31-May-21	18:00	
138	793	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-2	C	Diversion of towers for Nagpur-Mumbai Samrudhi Express Highway crossing. Total 3 no of towers to be shifted & erection and stringing works.	21-May-21	7:00	31-May-21	18:00	
139	794	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Outgae for replacement of faulty insulators if found in PID testing and other Line maintenance work	21-May-21	09:00	21-May-21	17:00	400KV Dhule-Babhaleshwar II to be kept on Non_auto mode
140	795	MEGPTCL	KORADI-III - 765KV - BUS 2	Daily	Annual maintenance of Bus equipments	21-May-21	09:00	21-May-21	18:00	Bus Outage
141	796	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Bay Maintenance & Testing work	21-May-21	09:00	21-May-21	18:00	Bay Maintenance & Testing work
142	820	MP_SLDC	220KV-PANDHURNA-MP-KALMESHWAR-MH	D	FOR LINE MAINTENANCE WORK	21-May-21	9:00	21-May-21	18:00	
143	833	MSETCL	KORADI-II - 400KV - BUS 2	Daily	1. 09 nos. BPI erection work 2. Fixing of IPS Tube between BPIs and CT with Connectors 3. Main Bus-II to Bus Isolator jumpering 4. Making arrangement of 3 nos DTT-450 Hardware with Conductors at existing Beam of Bay 415 for further Stringing activity between existing Bus gantry and new erected Reactor Gantry. 5. For 400KV, 125 MVAR Bus Shunt Reactor (bay no. 415).	22-May-21	08:00	23-May-21	20:00	The work will be carried out by M/s KEI Industries Ltd. under supervision of AdIEE, 400KV S/stn. Projects S/Dn, Nagpur
144	834	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	AMP	22-May-21	9:00	22-May-21	17:30	PG-WR2-Boisar
145	835	MSETCL	220KV-BOISAR-BOISAR-M-3	Daily	Bay Maint. works.	22-May-21	07:00	22-May-21	18:00	Bay Maint. works.
146	851	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	22-May-21	10:00	22-May-21	18:00	NA
147	860	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	Bay Maint. works.	23-May-21	07:00	23-May-21	18:00	Bay Maint. works.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
148	861	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	REPLACEMENT OF CVT AT TARAPUR SUB-STATION	23-May-21	09:00	23-May-21	17:00	REPLACEMENT OF CVT AT TARAPUR SUB-STATION
149	862	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Hardware Tightening and Fitting Work.	23-May-21	09:30	23-May-21	18:30	-
150	870	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of faulty insulators if found in PID testind and other Line maintenance work	24-May-21	09:00	24-May-21	17:00	400KV Dhule-Babhaleshwar I to be kept on Non-auto mode
151	873	MEGPTCL	KORADI-III - 400KV - BUS 1	Daily	Annual maintenance of Bus equipments	24-May-21	09:00	24-May-21	18:00	Bus Outage
152	881	MSETCL	KARAD - 400KV - BUS 2	Daily	Replacement of Bus-II old CVT which has completed working life i.e.34 years completed since commissioning i.e.from 21.03.1987	24-May-21	07:00	24-May-21	20:00	Load will be managed on Bus-I & Bus-II feeders will be shifted to Bus-I through online. Also during May wind Generation will be available.
153	901	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2	Daily	Attending of SF6 gas leakage at top of the Y-Phase pole of 429 Main CB at 400 KV PGCIL Deoli S/Stn. By complete O/H of Y-Pole.	24-May-21	09:00	29-May-21	17:00	Line will be charged through Tie CB 428.
154	902	MSETCL	400KV/220KV PARLI-M-ICT-2	Continuous	Overhauling of 400kv CB of ICT 2 @ parli is to be carried out. The ICT 2 will remain charged through 400KV TBC.	24-May-21	09:00	29-May-21	18:00	400kv TBC will be engaged
155	903	MSETCL	400KV/220KV CHANDRAPUR-ICT-1 ON TBC-1 @ CHANDRAPUR	Continuous	Replacement of old BHEL make 400KV Breaker by new Siemens make 400KV Breaker.	24-May-21	09:00	29-May-21	18:00	Outage will be availed by shifting 400KV ICT-1 bay on 400KV TBC-1 bay.
156	905	MSETCL	400KV-RGPPL-NEW KOYNA-2	Continuous	Dismantling of existing tilted old tower at location no 94 and erection of new tower ( B+95T) with foundation and stringing of conductor	24-May-21	08:00	31-May-21	18:00	Planned outage
157	906	MSETCL	400KV-KALWA-PADGHE-2	Daily	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	24-May-21	09:00	31-May-21	17:00	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
158	912	MSETCL	KORADI - 400KV - BUS 2	Daily	measurement of CVT tan delta	25-May-21	06:00	25-May-21	18:00	Outages will be availed subject to weather conditions.
159	913	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Replacement of faulty insulators if found in PID testing and other Line maintenance work	25-May-21	09:00	25-May-21	17:00	400KV Dhule-Babhaleshwar II is to be kept on Non-auto mode
160	916	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	CB Diagnostic & LBB relay testing work. Also 29D & 29C Isolator repairing work.	25-May-21	09:00	25-May-21	17:00	400kv Ektuni ckt II,400KV Bhusawal, Dhule I&II and 400kv Aurangabad will be in service
161	921	MSETCL	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	Daily	QM of Bay	25-May-21	09:00	25-May-21	18:00	Load will be managed on Kolhapur-Kolhapur PG Ckt-2
162	922	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	25-May-21	08:00	25-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
163	927	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	25-May-21	08:00	25-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
164	944	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	26-May-21	08:00	26-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
165	945	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	26-May-21	09:00	26-May-21	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
166	946	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of faulty insulators if found in PID testing and other Line maintenance work	26-May-21	09:00	26-May-21	17:00	400KV Dhule-Babhaleshwar I is to be kept on Non-auto mode
167	948	MSETCL	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	Daily	QM of Bay	26-May-21	09:00	26-May-21	18:00	Load will be managed on Kolhapur-Kolhapur Ckt-2
168	949	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	26-May-21	08:00	26-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
169	967	MEGPTCL	TIE BAY - 400KV-KORADI-II-KORADI-III-1 AND FUTURE	Daily	Bay Maintenance Activities	27-May-21	09:00	27-May-21	14:00	Bay Outage
170	968	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance, Diagnostic Testing & Pre-monsoon Maintenance.	27-May-21	10:00	27-May-21	17:00	---
171	971	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-1	D	Cleaning Copper Contacts	27-May-21	8:30	27-May-21	18:00	
172	978	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	27-May-21	08:00	27-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
173	980	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Maintainance Work if any	27-May-21	09:00	27-May-21	17:00	Nil
174	987	MSETCL	KORADI-II - 400KV - BUS 2	Daily	T-Connection of Bus isolator of Reactor bay For 400kv, 125 MVAR Bus Shunt Reactor (bay no. 415).	28-May-21	08:00	28-May-21	20:00	Outage proposed by AdIEEE, 400KV S/stn. Projects S/Dn, Nagpur
175	996	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	28-May-21	08:00	28-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
176	1005	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	AMP	29-May-21	9:00	29-May-21	17:30	PG-WR2-Boisar
177	1010	MSETCL	220KV-BOISAR-BOISAR-M-1	Daily	Bay Maint. works.	29-May-21	07:00	29-May-21	18:00	Bay Maint. works.
178	1019	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	29-May-21	08:00	29-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
179	1025	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	D	AMP	30-May-21	9:00	30-May-21	17:30	PG-WR2-Boisar
180	1026	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	30-May-21	08:00	30-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
181	1029	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	Cleaning Copper Contacts	30-May-21	8:30	30-May-21	18:00	
182	1031	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance	30-May-21	08:00	30-May-21	17:00	-
183	1034	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance, Diagnostic Testing & Pre-monsoon maintenance.	30-May-21	10:00	30-May-21	17:00	---

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
184	1035	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	Bay Maint. works.	30-May-21	07:00	30-May-21	18:00	Bay Maint. works.
185	1036	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Chemical Cleaning work.	30-May-21	08:00	30-May-21	18:00	---
186	1037	MSETCL	220KV-BOISAR-BORIVALI-I	Daily	FOR SAFETY PURPOSE for Maintenance work on 220KV TARAPUR - BORIVALI LINE	31-May-21	09:00	31-May-21	17:00	FOR SAFETY PURPOSE for Maintenance work on 220KV TARAPUR - BORIVALI LINE
187	1044	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	31-May-21	08:00	31-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode

Outages not considered in WRLDC OCCM for the Month of May' 2021										
Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
1	93	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	12-May-21	08:00	12-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
2	310	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Work of damaged earthwire replacement and replacement of faulty insulators if found in PID	11-May-21	08:00	11-May-21	17:00	400KV Dhule-SSNNL II is to be kept on NonAuto mode
3	331	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and Faulty insulators if found in PID testing.	12-May-21	08:00	12-May-21	17:00	400KV SSNNL I is to be kept on Nonauto mode
4	403	MSETCL	400KV-KALWA-PADGHE-1	Daily	Routine Maintenance work, Faulty Insulator Replacement & chemical cleaning of insulators	22-May-21	08:00	22-May-21	18:00	Routine Maintenance work, Faulty Insulator Replacement & chemical cleaning of insulators
5	409	MSETCL	KALWA - 400KV - BUS 1	Daily	Bus CVT Maitenance & Testing work	23-May-21	09:00	23-May-21	18:00	Bus CVT Maitenance & Testing work
6	548	MSETCL	AKOLA - 400KV - BUS 1	Daily	Servicing & alignment of isolators/Earth switches will be carried out by Binco Isolators Ltd. Routine maint. & testing work	28-May-21	08:00	28-May-21	17:00	Bus-2 will be in service
7	716	MSETCL	400KV-KALWA-PADGHE-2	Daily	Routine Maintanace work & chemical cleaning of insulators	23-May-21	08:00	23-May-21	18:00	Routine Maintanace work & chemical cleaning of insulators
8	913	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	29D & 29C Isolator repairing work	28-May-21	09:00	28-May-21	17:00	400kV Ektuni ckt I,400kV Bhusawal, Dhule I&II and 400kV Aurangabad will be in in service
9	924	MSETCL	BUS COUPLER @ PADGHE	Daily	Diagnostic Testing PG Isolator Replacement	21-May-21	09:00	21-May-21	19:00	Agency present on site
10	928	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Continuou s	Samruddhi Highway work & CB, CTs, relay testing work	21-May-21	09:00	30-May-21	17:00	Outage required on Dhule-Bamburdaeswar DC simultaneously. 400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Aurangabad will be in in service.
11	929	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Continuou s	Samruddhi Highway work & CB, CTs, relay testing work	21-May-21	09:00	30-May-21	17:00	Outage required on Dhule-Bamburdaeswar DC simultaneously. 400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Aurangabad will be in in service.
12	934	MSETCL	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2	Daily	CTs, CB, relay Testing and quarterly maintenance work	27-May-21	08:00	27-May-21	18:00	400KV Bus I&II will be separated.
13	952	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Routine Maintanace work & chemical cleaning of insulators	23-May-21	08:00	23-May-21	18:00	Routine Maintanace work & chemical cleaning of insulators
14	954	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Bay Maitenance & Testing work	23-May-21	09:00	23-May-21	18:00	Bay Maitenance & Testing work

### State Element List for the month of May'2021

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	01-May-21	08:00	02-May-21	18:00	Continuous	For ICT painting work and Routine Maintenance Work	MSETCL	MSETCL	For ICT painting work.
2	400 KV	LONIKAND 1 -JEJURI	01-May-21	09:00	15-May-21	18:00	Daily	PID testing of Insulator Strings.	MSETCL	MSETCL	---
3	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	03-May-21	09:00	03-May-21	17:00	Daily	TAN DELTA MEASUREMENT OF BUSHING & WINDING	MSETCL	MSETCL	400/220/33KV ICT2 WILL REMAIN IN SERVICE
4	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	03-May-21	09:00	03-May-21	18:00	Daily	QM Work, C & Tandelta of Bushing & Wdg.400kV D iso alignment work,Premonsoon Maintenance work	MSETCL	MSETCL	Monday is Load staggering day in Kolhapur
5	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	03-May-21	07:00	08-May-21	18:00	Daily	Work of strings replacement, detected faulty in PID testing are to be replaced by availing outage on 400 kV Akola-Nandgaonpeth line.	MSETCL	MSETCL	String replacement work will be done by agency.
6	400 KV	DEEPNAGAR - THAPTI TANDA	03-May-21	08:00	04-May-21	18:00	Daily	For On Line PID by PID Unit,Bhusawal	MSETCL	MSETCL	During the PID only A/R is in NON-AUTO mode
7	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	04-May-21	06:00	04-May-21	14:00	Daily	Diagnostic testing and allied buy maintenance work	MSETCL	MSETCL	Diagnostic testing and allied buy maintenance work
8	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	04-May-21	10:00	04-May-21	17:00	Daily	Diagnostic testing & QM work	MSETCL	MSETCL	Diagnostic testing & QM work
9	400 KV	400/220 KV 500 MVA ICT @ ALKUD	04-May-21	10:00	04-May-21	17:00	Daily	Diagnostic Testing & Quarterly Maintenance work	MSETCL	MSETCL	Tuesday is Load staggering day of Sangli district
10	400 KV	KHADKA-AURANGABAD	04-May-21	06:00	06-May-21	18:00	Daily	For replacement of Faulty insulator strings detected in PID & Monkey Patrolling.	MSETCL	MSETCL	NIL
11	400 KV	400KV RPL LINE REACTOR @ 400KV KORADI	05-May-21	09:00	05-May-21	18:00	Daily	Measurement of reactor bushing Tan Delta and SFRA test	MSETCL	MSETCL	After taking reactor out, line will be charged. Outages will be availed subject to weather conditions.
12	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 2	05-May-21	06:00	05-May-21	14:00	Daily	Diagnostic testing and allied buy maintenance work	MSETCL	MSETCL	Diagnostic testing and allied buy maintenance work
13	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	05-May-21	10:00	05-May-21	18:00	Daily	Diagnostic Testing work & Isolator Alignment & CTR Testing	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500 MVA ICT - 1
14	400 KV	CHANDRAPUR-PARLI CKT-3	05-May-21	09:00	05-May-21	18:00	Daily	Line Maintenance work	MSETCL	MSETCL	-
15	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	05-May-21	10:00	05-May-21	17:00	Daily	Diagnostic testing & QM work	MSETCL	MSETCL	Diagnostic testing & QM work
16	400 KV	MAIN BAY - 401 OF BUS REACTOR @ ALKUD	05-May-21	10:00	05-May-21	17:00	Daily	Diagnostic testing & QM work	MSETCL	MSETCL	Diagnostic testing & QM work
17	400 KV	MAIN BAY - 413 OF GT-9 @ KORADI-2	05-May-21	10:00	05-May-21	15:00	Daily	DCRM of CB 413-Q52 & ROUTINE BAY MAINTENANCE	MSETCL	MSETCL	GT#9 WILL REMAIN SERVICE THROUGH TIE BAY 414
18	400 KV	125 MVAr BUS REACTOR @ ALKUD	05-May-21	10:00	05-May-21	17:00	Daily	Diagnostic Testing & QM work	MSETCL	MSETCL	Voltage profile is low during this season
19	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	06-May-21	09:30	06-May-21	17:30	Daily	Annual Testing & pre monsoon Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-2 & ICT-3 will be in service.
20	400 KV	Akola II (Yelwan) - Akola I CKT - 1	06-May-21	10:00	06-May-21	16:00	Daily	Replacement of Protection CVT with new design CVTs as per OEM recommendation at Akola-2 SS	MEGPTCL	MEGPTCL	New CVT Replacement
21	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	06-May-21	09:30	06-May-21	17:30	Daily	Annual Testing & pre monsoon Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-1 & ICT-3 will be in service.
22	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	07-May-21	08:00	07-May-21	18:00	Daily	For Routine Maintenance Work & Diagnostic testing	MSETCL	MSETCL	Routine Maintenance Work & Diagnostic testing
23	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	07-May-21	09:00	07-May-21	17:00	Daily	TAN DELTA MEASUREMENT OF BUSHING & WINDING	MSETCL	MSETCL	400/220/33KV ICT-1 WILL REMAIN IN SERVICE
24	400 KV	FUTURE CKT - 1 @ WARORA	07-May-21	08:00	07-May-21	17:00	Daily	Routine maintenance and Line/Bus/Tie CT TAN DELTA,IR and isolater maintenance work etc .	MSETCL	MSETCL	400KV IEPL Line will be charged through MAIN CB 417.
25	400 KV	GTR - 9 @ CHANDRAPUR SWITCHING SS	07-May-21	06:00	08-May-21	22:00	Continuous	work of installation (CT & IVT) of dedicated metering arrangement ,buy maintenance work, replacement of the MIM-10 card in ABB REC 670 relay & AMR project commissioning work.	MSETCL	MSETCL	work of installation (CT & IVT) of dedicated metering arrangement ,buy maintenance work, replacement of the MIM-10 card in ABB REC 670 relay & AMR project commissioning work.
26	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	07-May-21	10:00	07-May-21	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
27	400 KV	KORADI-KHAPERKHEDA I	07-May-21	09:00	07-May-21	18:00	Daily	TBC Shifting of 400kV Khaperkheda 1 for Measurement of CB DCRM, CRM, timing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
28	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	07-May-21	09:00	07-May-21	16:00	Daily	Premonsoon maintenance and auxiliary protection trial.	MSETCL	MSETCL	Nil
29	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	08-May-21	08:00	08-May-21	18:00	Daily	For ICT HV LV wdg & bushing Tan delta testing work and ICT Preventive maintenance work	MSETCL	MSETCL	as per yearly plan
30	400 KV	Akola II (Yelwan) - Akola I CKT - 2	08-May-21	10:00	08-May-21	15:00	Daily	Replacement of Protection & metering CVT with new design CVTs as per OEM recommendation at Akola-2 SS	MEGPTCL	MEGPTCL	New CVT Replacement
31	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	10-May-21	09:00	10-May-21	16:00	Daily	Premonsoon maint. and auxiliary protection trial	MSETCL	MSETCL	Nil
32	400 KV	PADGHE - NAGOTHANE I	10-May-21	08:00	16-May-21	17:00	Daily	chemical washing of insulator	MSETCL	MSETCL	nil
33	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	10-May-21	09:00	10-May-21	18:00	Daily	For routine testing and maintenance work	MSETCL	MSETCL	501MVA ICT-II & 501MVA ICT-III are in service
34	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	10-May-21	08:00	10-May-21	17:00	Daily	premonsoon maint work	MSETCL	MSETCL	nil
35	400 KV	400/220/33KV 500 MVA ICT - 1 @ KUDUS	10-May-21	07:00	10-May-21	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	MSETCL	DGA or Standby Discom supply will Feed Substation Auxiliary Supply as 500 MVA ICT-1 is only on Humming
36	400 KV	400/220/33KV SPARE ICT @ KORADI 2	10-May-21	09:00	10-May-21	17:00	Daily	1)TAN DELTA MEASUREMENT OF BUSHING & WINDING 2)DCRM of CB 431-Q52 1)TAN DELTA MEAS. OF CT	MSETCL	MSETCL	Spare ICT is on No-Load
37	400 KV	AKOLA - KHADKA (BHUSAWAL)	10-May-21	07:00	15-May-21	18:00	Daily	Work of strings replacement detected faulty in PID testing are to be replaced by availing outage 400 kV Akola- Khadka (Bhusawal) line.	MSETCL	MSETCL	String replacement work will be done by agency.



Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
38	400 KV	DEEPNAGAR - THAPTI TANDA	10-May-21	08:00	10-May-21	18:00	Daily	Online PID By PID Unit,Khadka	MSETCL	MSETCL	During PID Only A/R is in NON-AUTO mode
39	400 KV	400/220/33 KV 500 MVA ICT - 3 @ DHULE	11-May-21	09:00	11-May-21	18:00	Daily	For routine testing and maintenance work	MSETCL	MSETCL	315MVA ICT-I & 501 MVA ICT-II are in service.
40	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	11-May-21	08:00	11-May-21	17:00	Daily	premonsoon maint work	MSETCL	MSETCL	NIL
41	400 KV	NEW KOYNA - STAGE IV CKT 2	11-May-21	08:00	11-May-21	18:00	Daily	Cold washing & Routine maint. Work	MSETCL	MSETCL	Planned outage
42	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	11-May-21	06:00	11-May-21	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
43	400 KV	KHADKA - BABLESHWAR	11-May-21	06:00	13-May-21	18:00	Daily	For replacement of Faulty insulator strings detected in PID & Monkey Patrolling	MSETCL	MSETCL	NIL
44	400 KV	CHANDRAPUR-PARLI CKT-3	12-May-21	08:00	12-May-21	17:00	Daily	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling
45	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	12-May-21	08:00	12-May-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
46	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	12-May-21	08:00	12-May-21	17:00	Daily	premonsoon maint work	MSETCL	MSETCL	NIL
47	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	12-May-21	07:00	12-May-21	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	-
48	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	13-May-21	08:00	13-May-21	17:00	Daily	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling
49	400 KV	JEJURI- KOYNA STAGE-IV	13-May-21	08:00	13-May-21	18:00	Daily	DT/Line Maintenance (Insulator String Replacement work).	MSETCL	MSETCL	---
50	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	13-May-21	09:00	13-May-21	17:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---
51	400 KV	CHANDRAPUR-PARLI CKT-3	13-May-21	10:00	13-May-21	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
52	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	13-May-21	08:00	13-May-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
53	400 KV	KARAD - LONIKAND 1	13-May-21	08:00	13-May-21	18:00	Daily	Cold line washing work of disc insulators	MSETCL	MSETCL	Cold line washing work of disc insulators
54	400 KV	CHANDRAPUR - KHAPERKHEDA	13-May-21	08:00	13-May-21	17:00	Daily	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work if found any during monkey Patrolling
55	400 KV	400 KV FUTURE BAY II @ WARORA	13-May-21	08:00	13-May-21	17:00	Daily	Routine maintenance and Line/Bus/Tie CT TAN DELTA,IR and isolator maintenance work etc .	MSETCL	MSETCL	400KV PGCIL Line will be charged through main CB 420.
56	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	14-May-21	06:00	14-May-21	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
57	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	14-May-21	08:00	14-May-21	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400/220kV 501 MVA ICT-I will remain in service.
58	400 KV	NEW KOYNA-KARAD -CKT 1	14-May-21	08:00	14-May-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
59	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	14-May-21	08:00	14-May-21	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.
60	400 KV	NEW KOYNA -KARAD -CKT 2	14-May-21	08:00	14-May-21	18:00	Daily	Cold line washing work of disc insulators	MSETCL	MSETCL	Cold line washing work of disc insulators
61	400 KV	NEW KOYNA-KARAD -CKT 1	15-May-21	08:00	15-May-21	18:00	Daily	Cold line washing work of disc insulators	MSETCL	MSETCL	Cold line washing work of disc insulators
62	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	15-May-21	09:00	15-May-21	18:00	Daily	Line Maintenance work	MSETCL	MSETCL	-
63	400 KV	NEW KOYNA -KARAD -CKT 2	14-May-21	08:00	14-May-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
64	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	15-May-21	08:00	15-May-21	18:00	Daily	For ICT-2 HV LV wdg & bushing Tan delta testing work and ICT Preventive maintenance work.	MSETCL	MSETCL	as per Yearly plan
65	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	15-May-21	07:00	15-May-21	15:00	Daily	For premonsoon maintenance and routine bay maintenance work	MSETCL	MSETCL	load will be shifted on 400/132 KV ICT-2
66	400 KV	400/220/20 KV 500MVA ICT - 3 @ KALWA	16-May-21	09:00	16-May-21	18:00	Daily	Bay Maintenance & Testing work	MSETCL	MSETCL	Bay Maintenance & Testing work
67	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	17-May-21	09:00	17-May-21	20:00	Daily	Premonsoon Maintenance work	MSETCL	MSETCL	Monday is load staggering day in Kolhapur
68	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	17-May-21	08:00	17-May-21	17:00	Daily	Premansoon maintenance & testing work	MSETCL	MSETCL	ICT-2 will be in service
69	400 KV	PADGHE - NAGOTHANE 2	17-May-21	08:00	23-May-21	17:00	Daily	chemical washing of insulator	MSETCL	MSETCL	nil
70	400 KV	DEEPNAGAR - THAPTI TANDA	17-May-21	08:00	17-May-21	18:00	Daily	Online PID By PID Unit,Khadka	MSETCL	MSETCL	During PID A/R is in NON-AUTO mode
71	400 KV	TIE BAY - 409 OF GT - 5 @KHAPARKHEDA S/s	17-May-21	08:00	17-May-21	20:00	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor (bay no. 408).	MSETCL	MSETCL	Outage proposed by project S/dn-II for connecting bus T connector
72	400 KV	AKOLA - KHADKA (BHUSAWAL)	17-May-21	10:00	31-May-21	15:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Akola-Khadka (Bhusawal) line shall be carried out by PID unit Akola.	MSETCL	MSETCL	PID of 400 kV Akola- Khadka (Bhusawal) line shall be carried out by PID unit Akola.
73	400 KV	DEEPNAGAR - THAPTI TANDA	18-May-21	06:00	20-May-21	18:00	Daily	For replacement of Faulty insulator strings detected in PID & Monkey Patrolling	MSETCL	MSETCL	NIL
74	400 KV	Akola II (Yelwan) - Akola 1 CKT - 1	18-May-21	08:00	18-May-21	17:00	Daily	Routine maintenance & testing work	APTCL	APTCL	Yelwan ckt-2 will be in service
75	400 KV	TIE BAY - 409 OF GT - 5 @KHAPARKHEDA S/s	18-May-21	08:00	18-May-21	20:00	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor (bay no. 408).	MSETCL	MSETCL	Outage proposed by project S/dn-II for connecting bus T connector
76	400 KV	KORADI-NANDGAONPETH (RPL)	18-May-21	08:00	18-May-21	18:00	Daily	For replacement of Insulator and routine maintenance work.	APTCL	APTCL	Outage is require For replacement of Insulator and routine maintenance work.
77	400 KV	KARAD - LONIKAND 1	18-May-21	08:00	18-May-21	18:00	Daily	Cold line washing work of disc insulators	MSETCL	MSETCL	Cold line washing work of disc insulators

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
78	400 KV	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	18-May-21	06:00	18-May-21	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
79	400 KV	NEW KOYNA - STAGE IV CKT 1	18-May-21	08:00	18-May-21	18:00	Daily	Cold washing & Routine maint. Work	MSETCL	MSETCL	Planned outage
80	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	19-May-21	07:00	19-May-21	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	-
81	400 KV	STATION TF - 1 @ KORADI -2	19-May-21	10:00	19-May-21	17:00	Daily	TAN DELTA MEASUREMENT OF LINE CT & ROUTINE BAY MAINTENANCE	MSETCL	MSETCL	Station Transformer II & III will remain in service as alternate source.
82	400 KV	Akola II (Yelwan) - Akola I CKT - 2	19-May-21	08:00	19-May-21	17:00	Daily	Routine maintenance & testing Work	APTCL	APTCL	Yelwan Ckt-1 will be in service
83	400 KV	JAIGAD-NEW KOYNA-I	19-May-21	09:00	19-May-21	18:00	Daily	Cold line washing/ Maintenance work	JPTL	JPTL	Load manage on 400 kV Jaigad-Newkoyna Ckt-2
84	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	19-May-21	09:00	19-May-21	18:00	Daily	Line Maintenance work	MSETCL	MSETCL	-
85	400 KV	KORADI-NANDGAONPETH (RPL)	19-May-21	06:00	20-May-21	22:00	Continuous	Restranging work for increasing ground clearance between tower No. 12-13 & 121-122	MSETCL	MSETCL	-
86	400 KV	JAIGAD-NEW KOYNA-I	19-May-21	08:00	19-May-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
87	400 KV	WARORA - IEPL	20-May-21	09:00	20-May-21	17:00	Daily	Routine Maintenance & Diagnostic testing work , Nut Bolt of jumper Tightening work.	MSETCL	MSETCL	1)400 KV KORADI 2-WARDHA PGCIL Line is in ckt. 2) During this outage opportunity will be taken for routine maintenance work at 400kV Warora s/sin. by Maintenance unit warora.
88	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	20-May-21	08:00	20-May-21	13:00	Daily	For Pre monsoon maintenance works. And Relay routine testing work.	MSETCL	MSETCL	-
89	400 KV	GTR - 9 @ CHANDRAPUR SWITCHING SS	20-May-21	06:00	21-May-21	22:00	Continuous	work of installation (CT & IVT) of dedicated metering arrangement ,bay maintenance work, replacement of the MIM-10 card in ABB REC 670 relay & AMR project commissioning work.	MSETCL	MSETCL	work of installation (CT & IVT) of dedicated metering arrangement ,bay maintenance work, replacement of the MIM-10 card in ABB REC 670 relay & AMR project commissioning work.
90	400 KV	JAIGAD-NEW KOYNA-II	20-May-21	09:00	20-May-21	18:00	Daily	Cold line washing/ Maintenance work	JPTL	JPTL	Load manage on 400 kV Jaigad-Newkoyna Ckt-1
91	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	20-May-21	09:30	20-May-21	17:30	Daily	Annual Testing & pre monsoon Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-1 & ICT-2 will be in service.
92	400 KV	DEEPNAGAR - THAPTI TANDA	20-May-21	09:00	20-May-21	18:00	Daily	Line routine maint. work	MSETCL	MSETCL	Nil
93	400 KV	LONIKAND 1 -JEJURI	20-May-21	08:00	20-May-21	18:00	Daily	DT/Line Maintenance (Insulator String Replacement work)	MSETCL	MSETCL	---
94	400 KV	JAIGAD-NEW KOYNA-II	20-May-21	08:00	20-May-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
95	400 KV	RPL(AMT) NANDGAON PETH - AKOLA II LINE I	21-May-21	08:00	22-May-21	18:00	Daily	For replacement of Insulator and routine maintenance work.	APTCL	APTCL	Outage require For replacement of Insulator and routine maintenance work.
96	400 KV	JAIGAD-KARAD-I	21-May-21	09:00	21-May-21	18:00	Daily	Cold line washing/ Maintenance work	JPTL	JPTL	Load manage on 400 kV Jaigad-Karad Ckt-2
97	400 KV	NEW KOYNA -KARAD -CKT 2	21-May-21	08:00	21-May-21	18:00	Daily	Cold line washing work of disc insulators	MSETCL	MSETCL	Cold line washing work of disc insulators
98	400 KV	DEEPNAGAR - THAPTI TANDA	21-May-21	09:00	21-May-21	18:00	Daily	Line routine maint. work	MSETCL	MSETCL	Nil
99	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	21-May-21	06:00	30-May-21	18:00	Daily	For replacement of faulty Dead end & Mid Span Joint	MSETCL	MSETCL	NIL
100	400 KV	JEJURI- KOYNA STAGE-IV	22-May-21	08:00	22-May-21	18:00	Daily	Cold line washing work of disc insulators	MSETCL	MSETCL	Cold line washing work of disc insulators
101	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	22-May-21	07:00	22-May-21	15:00	Daily	For premonsoon maintenance and routine bay maintenance work	MSETCL	MSETCL	Load will be shifted on 400/132 KV ICT-1
102	400 KV	JAIGAD-KARAD-II	22-May-21	09:00	22-May-21	18:00	Daily	Cold line washing/ Maintenance work	JPTL	JPTL	Load manage on 400 kV Jaigad-Karad Ckt-1
103	400 KV	CHANDRAPUR - KHAPERKHEDA	22-May-21	08:00	22-May-21	19:00	Daily	Jumper Nut Bolt Tightening work at various locations	MSETCL	MSETCL	-
104	400 KV	400/220 KV 500MVA ICT - 4 @ KALWA	23-May-21	09:00	23-May-21	18:00	Daily	Bay Maintenance & Testing work	MSETCL	MSETCL	Bay Maintenance & Testing work
105	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	24-May-21	08:00	24-May-21	17:00	Daily	Premonsoon maintenance & testing work	MSETCL	MSETCL	ICT-1 will be in service
106	400 KV	400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	24-May-21	08:00	24-May-21	13:00	Daily	For Pre monsoon maintenance works. And Relay routine testing work.	MSETCL	MSETCL	-
107	400 KV	DEEPNAGAR - THAPTI TANDA	24-May-21	08:00	24-May-21	18:00	Daily	For On Line PID by PID Unit,Khadka	MSETCL	MSETCL	During PID A/R is in NON-AUTO mode
108	400 KV	THAPTI TANDA - WALUJ	24-May-21	09:00	25-May-21	18:00	Daily	Line routine maint work	MSETCL	MSETCL	Nil
109	400 KV	RPL(AMT) NANDGAON PETH - AKOLA II LINE II	25-May-21	08:00	25-May-21	18:00	Daily	For replacement of Insulator and routine maintenance work.	APTCL	APTCL	Outage require For replacement of Insulator and routine maintenance work.
110	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	25-May-21	08:00	25-May-21	17:00	Daily	Routine maintenance and Line/Bus Tie CT TAN DELTA,IR and isolater maintenance work etc .	MSETCL	MSETCL	Bay No 404 charged upto line CT (400KV ICT No -1 handed over to 400kv Bableshtar )
111	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	25-May-21	06:00	26-May-21	22:00	Continuous	Restranging work for increasing ground clearance between tower No. 111-112	MSETCL	MSETCL	-
112	400 KV	125MVA BUS REACTOR @ WARORA	26-May-21	08:00	26-May-21	17:00	Daily	Pre-monsoon maintenance work	MSETCL	MSETCL	During outage reactor is in off condition
113	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	27-May-21	09:00	27-May-21	17:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---
114	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	27-May-21	08:00	27-May-21	13:00	Daily	For Pre monsoon maintenance works. And Relay routine testing work.	MSETCL	MSETCL	-
115	400 KV	KARAD - LONIKAND I	27-May-21	09:00	27-May-21	18:30	Daily	DT & Routine Maintenance work.	MSETCL	MSETCL	---

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
116	400 KV	400/220kV SPARE ICT @ JEJURI	27-May-21	09:30	27-May-21	17:30	Daily	Annual Testing & pre monsoon Maintenance work.	MSETCL	MSETCL	400/220/33KV, 167 MVA Spare ICT is on no load. No load will be affected.
117	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	28-May-21	07:00	28-May-21	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	-
118	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	29-May-21	08:00	29-May-21	18:00	Daily	CB Diagnostic testing	MSETCL	MSETCL	ICT 2, 3, 4 will be in service
119	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	29-May-21	07:00	29-May-21	18:00	Daily	For premonsoon maintenance and routine bay maintenance work	MSETCL	MSETCL	Nil
120	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	29-May-21	09:00	29-May-21	18:00	Daily	For protection trials of newly erected breaker.	MSETCL	MSETCL	(3x105MVA) ICT-2 and 220KV CHD-2 line will be in service.
121	400 KV	DEEPNAGAR - THAPTI TANDA	31-May-21	08:00	31-May-21	18:00	Daily	For on Line PID by PId Unit,Khadka	MSETCL	MSETCL	During PID A/R is in NON-AUTO mode