

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of May' 2022

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
								Date	Time	Date	time	
1	1	PLANNED	OCC_554	MSETCL	MAIN BAY OF 400KV/220KV NEW KOYNA-ICT-2 AND NEW KOYNA - 400KV - BUS 1 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	Continuous	C.B. Overhauling work Shitting on TBC	27/Apr/22	08:00	3/May/22	18:00	Planned outage
2	4	PLANNED	OCC_554	MSETCL	KORADI-II - 400KV - BUS 1	Daily	Tan delta measurement of Bus CVT	1/May/22	07:00	1/May/22	12:00	1) All the 400KV feeder will remain in service through 400kv Main Bus 2.
3	5	PLANNED	OCC_554	MSETCL	400KV-CHAKAN-PUNE-PG-1	Daily	Chemical cleaning of insulator strings, Routine maintenance and testing activities.	1/May/22	08:00	1/May/22	18:00	---
4	7	PLANNED	OCC_554	MSETCL	400KV-CHAKAN-PUNE-PG-1	Daily	Diagnostic testing and maintenance activities.	1/May/22	09:00	1/May/22	18:00	---
5	8	PLANNED	OCC_554	MSETCL	BOISAR-M - 220KV - BUS 2	Continuous	Bus Maintenance Works	1/May/22	07:00	2/May/22	19:00	Bus Maintenance Works
6	20	PLANNED	OCC_554	MSETCL	400KV-KARJAT-LONIKHAND-II-1	Daily	To carry out PID	1/May/22	8:00	10/May/22	18:00	Online work(PID/AR Out)
7	23	PLANNED	OCC_554	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	To Off / Out Auto Reclose at Both Ends For Carrying PID Work	1/May/22	08:00	15/May/22	18:00	-
8	24	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	PID Testing	1/May/22	09:00	17/May/22	17:00	PID Testing
9	44	PLANNED	OCC_554	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	Online Stringing of OPGW Cable	1/May/22	07:00	31/May/22	19:00	Online Stringing of OPGW Cable
10	56	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-KARJAT-1	Daily	PID testing	1/May/22	09:00	31/May/22	18:00	PID testing
11	63	PLANNED	OCC_554	MSETCL	400KV-KARAD-KOLHAPUR-MS-2	Daily	1. Replacement of B Bus 400kv PG isolator of TBC	2/May/22	07:00	2/May/22	18:00	Outage required along with 400kv Main Bus - 2
12	64	PLANNED	OCC_554	MSETCL	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	1. Replacement of B bus PG isolator 2. Replacement of B bus isolator of 400kv TBC.	2/May/22	07:00	2/May/22	18:00	Outage required along with 400kv Main Bus - 2 Monday is load staggering day in Kolhapur.
13	65	PLANNED	OCC_554	POWERGRID_WRI	220KV-AURANGABAD-SHENDRA-2	Daily	For AMP works	2/May/22	7:00	2/May/22	18:00	
14	70	PLANNED	OCC_554	MSETCL	KOLHAPUR-MS - 400KV - BUS 2	Daily	1. 400kv TBC PG isolator replacement work. 2. Replacement of 400kv PID faulty strings. 3. C & tan delta testing of Bus CVT	2/May/22	07:00	2/May/22	23:59	Monday is load staggering day in Kolhapur.
15	94	PLANNED	OCC_554	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR-II-1	Continuous	1) For replacement of old M-1 & M-2 distance relays, 86 master trip relays under MTAMC project. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	2/May/22	08:00	4/May/22	18:00	During outage, outage 400KV CHANDRAPUR-1 - CHANDRAPUR-2 ckt. No.-1, 400KV Parli Ckt.-3, 400KV Chandrapur-Khaparkheda ckt., 400KV Chandrapur -PGCIL Bhadrawati ckt. No.- 1, 2, 3 & 4 will be in service
16	99	PLANNED	OCC_554	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	PID Testing Auto-Reclose function to be out of service.	2/May/22	09:00	7/May/22	18:00	PID Testing Auto-Reclose function to be out of service.
17	104	PLANNED	OCC_554	MSETCL	400KV-WARORA-CHANDRAPUR-II-1	Daily	transmission line (from 400kv chandrapur s/s to 400kv warora s/s)by replacing existing earth wire in live line condition by keeping AR switch in Non-auto mode	2/May/22	08:00	15/May/22	19:00	Vinay from MTCIL team, mob no- 8828237979
18	106	PLANNED	OCC_554	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Continuous	Online PID work	2/May/22	8:00	31/May/22	18:00	AR swich of 400KV dhl-bblr 1 & 2 ckt will be kept on Nonauto mode
19	107	PLANNED	OCC_554	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Continuous	online PID work	2/May/22	8:00	31/May/22	18:00	AR swich of 400KV dhl-bblr 1 & 2 ckt will be kept on Nonauto mode

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
								Date	Time	Date	time	
20	108	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing testing work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	2/May/22	09:00	31/May/22	16:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
21	125	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID testing work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	3/May/22	09:00	31/May/22	16:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
22	127	PLANNED	OCC_554	POWERGRID_WR1	WARDHA - 400KV - BUS 1	Daily	Bus Bar#01 protection changes (converting half dia to full dia) for ICT#03 retermination to bay 433 under SS11 (essential part of series reactor commissioning)	4/May/22	6:00	4/May/22	18:00	
23	135	PLANNED	OCC_554	POWERGRID_WR1	TIE BAY - 400KV-CHAKAN-PUNE-PG-1 AND 400KV-KHARGHAR-PUNE-PG-1 at PUNE-PG - 400KV	Daily	For AMP Work	4/May/22	7:00	4/May/22	18:00	
24	150	PLANNED	OCC_554	POWERGRID_WR2	400KV-KORADI-SATPURA-1	Daily	FOR PRESUMMER PREPAREDNESS WORK. Dia to be kept opened.	4/May/22	8:00	4/May/22	19:00	PG-WR2-AM
25	153	PLANNED	OCC_554	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Quarterly maintenance work	4/May/22	09:00	4/May/22	17:00	It is very important work
26	156	PLANNED	OCC_554	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Hardware Tightening & Fitting work	4/May/22	09:00	4/May/22	18:00	-
27	164	PLANNED	OCC_554	MSETCL	400KV-PADGHE-BOISAR-1	Daily	1) Bay Maint work 2) Diagnostic testing work 3) MTAMC work 4) 50MVAR Bus reactor maint work ,	4/May/22	09:20	4/May/22	18:00	1) Agency present on site for the work
28	165	PLANNED	OCC_554	MSETCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	4/May/22	10:00	4/May/22	18:00	765kV Akola ckt-II will be in service through its TIE 702 Bay & Main Bus-1
29	182	PLANNED	OCC_554	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-3	Daily	Removal of trees by JCB in span 36- 37-38 in jungle tiger zone area. AR to be kept in non Auto mode for 400KV-CHANDRAPUR-BHADRAWATI-4	5/May/22	8:00	5/May/22	18:00	Removal of trees
30	183	PLANNED	OCC_554	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	Daily	Removal of trees by JCB in span 36- 37-38 in jungle tiger zone area AR to be kept in non Auto mode for 400KV-CHANDRAPUR-BHADRAWATI-3	5/May/22	8:00	5/May/22	18:00	Removal of trees
31	195	PLANNED	OCC_554	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	Daily	Updating Siemens Distance Relay to Comply IEC61850 and Resolving Front Port Communication Issue of M1 Relay of Padghe Boisar Line at Padghe MSETCL SS.	5/May/22	7:00	5/May/22	17:00	400 KV Padghe Boisar LINE will be out of service.
32	205	PLANNED	OCC_554	MSETCL	400KV-WARORA-CHANDRAPUR-II-1	Daily	Isolator maintenance work by Agency.	5/May/22	08:00	5/May/22	18:00	Load will managed by 400KV Warora-Chandrapur 2 Ckt. 2 .
33	206	PLANNED	OCC_554	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine Maintenance work	5/May/22	08:00	5/May/22	18:00	-
34	221	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-KARJAT-1	Daily	Hardware tightening	5/May/22	09:00	5/May/22	18:00	Hardware tightening
35	223	PLANNED	OCC_553	APML-ADANI	TIE BAY - 400KV-TIRODA-WARORA-2 AND 400KV/11.5KV TIRODA-ST-2 at TIRODA - 400KV	Daily	408-52 Breaker Maintenance and testing	5/May/22	9:00	5/May/22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.
36	227	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	5/May/22	09:30	5/May/22	18:30	Circuit Breaker SF6 gas analysis
37	228	PLANNED	OCC_554	MSETCL	KORADI - 400KV - BUS 1	Daily	Incorporating of 400KV Numerical Busbar Protection Scheme in MTAMC SCADA with IEC61850 protocol under MTAMC Project.	5/May/22	10:30	5/May/22	14:30	All elements will be in service, only Bus bar protection will be out
38	229	PLANNED	OCC_554	MSETCL	KORADI - 400KV - BUS 2	Daily	Incorporating of 400KV Numerical Busbar Protection Scheme in MTAMC SCADA with IEC61850 protocol under MTAMC Project.	5/May/22	10:30	5/May/22	14:30	All elements will be in service, only Bus bar protection will be out
39	234	PLANNED	OCC_554	MSETCL	400KV-KARAD-JAIGAD-1	Daily	INSULATOR HOT LINE WASHING WORK	5/May/22	09:00	6/May/22	18:00	INSULATOR HOT LINE WASHING WORK
40	235	PLANNED	OCC_554	MSETCL	400KV-KARAD-JAIGAD-2	Daily	INSULATOR HOT LINE WASHING WORK	5/May/22	09:00	6/May/22	18:00	INSULATOR HOT LINE WASHING WORK
41	257	PLANNED	OCC_554	MSETCL	400KV-WARDHA-WARORA-1	Daily	CVT Tan Delta testing work. Isolator maintenance work by Agency	6/May/22	08:00	6/May/22	18:00	400KV Warora -JEPL Ckt.is in service.

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
								Date	Time	Date	time	
42	258	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	6/May/22	08:00	6/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
43	282	PLANNED	OCC_554	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	Daily	2) Diagnostic testing work 3) Master trip relay retrofitting work and BI/BO Testing work under MTAMC Scheme work.	6/May/22	09:00	6/May/22	19:00	Agency will present on site
44	283	PLANNED	OCC_554	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	6/May/22	09:30	6/May/22	18:30	Circuit Breaker SF6 gas analysis
45	285	PLANNED	OCC_554	MSETCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	6/May/22	10:00	6/May/22	18:00	765kV Akola ckt-I will be in service through its TIE 705 Bay & Main Bus-I
46	290	PLANNED	OCC_554	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work ;CT and CVT testing; Bay maintenance work.	6/May/22	09:00	7/May/22	17:00	400kV Padghe II will be in in service
47	299	PLANNED	OCC_554	MEGPTCL	KORADI-III - 400KV - BUS 2	Daily	Annual Maintenance of Bus Equipments.	7/May/22	08:00	7/May/22	18:00	Annual Maintenance of Bus Equipments.
48	310	PLANNED	OCC_554	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	For pre-monsoon work of Pole2 converter transformer & SM. Reactor.	7/May/22	08:00	7/May/22	14:00	Pole-1 will be in service with 300MW in earth return mode due to padghe end problem
49	314	PLANNED	OCC_554	POWERGRID_WR2	220KV-BOISAR-NALASOPARA-1	Daily	LTE AMP	7/May/22	9:00	7/May/22	17:30	PG-WR2-Boisar
50	315	PLANNED	OCC_554	MSETCL	400KV-JAIGAD-NEW KOYNA-2	Daily	INSULATOR HOT LINE WASHING WORK	7/May/22	09:00	7/May/22	18:00	INSULATOR HOT LINE WASHING WORK
51	318	PLANNED	OCC_554	MSETCL	400KV-JAIGAD-NEW KOYNA-1	Daily	INSULATOR HOT LINE WASHING WORK	7/May/22	09:00	7/May/22	1800	INSULATOR HOT LINE WASHING WORK
52	319	PLANNED	OCC_554	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	7/May/22	09:30	7/May/22	18:30	Circuit Breaker SF6 gas analysis
53	321	PLANNED	OCC_554	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continuous	To carry out Following Test on Pole I Y Phase Converter Transformer: 1. Ratio Test 2. Tan Delta of A-B1B2 Winding 3. DFRA Test 4. Winding Resistance Measurement 5. IR & PI of AB1-B2 winding 6. Core Insulation Measurement	7/May/22	08:00	8/May/22	23:00	Above test to be carried out as per OEM recommendation due to abnormal result of DFRA & Winding Tan delta of A winding of Pole I Y Phase Converter Transformer
54	323	PLANNED	OCC_554	MEGPTCL	KORADI-III - 400KV - BUS 1	Daily	Annual Maintenance of Bus Equipments.	8/May/22	08:00	8/May/22	18:00	Annual Maintenance of Bus Equipments.
55	329	PLANNED	OCC_554	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	For pre-monsoon work of Pole-1 converter transformer & SM. Reactor.	8/May/22	08:00	8/May/22	14:00	Pole-2 will be in service with 300MW in earth return mode due to padghe end problem
56	330	PLANNED	OCC_554	MSETCL	220KV-BOISAR-BOISAR-M-1	Daily	1) Pre-Monsoon Maintenance of Line" 2) Bay Maintenance Works at 220KV Boisar-II S/stn.	8/May/22	09:00	8/May/22	17:00	1) Pre-Monsoon Maintenance of Line" 2) Bay Maintenance Works at 220KV Boisar-II S/stn.
57	331	PLANNED	OCC_554	MSETCL	MAIN BAY OF 220KV-TARAPUR 1&2-BOISAR-M-1 AND BOISAR-M - 220KV - BUS 1 @BOISAR-M - 220KV at BOISAR-M - 220KV	Continuous	CB Maintenance Works by shifting the line on TBC.	8/May/22	09:00	9/May/22	17:00	Line will be in service through TBC
58	341	PLANNED	OCC_554	POWERGRID_WR1	220KV-PARLI-OSMANABAD-M-2	Daily	AMP work line terminal equipment	9/May/22	7:00	9/May/22	18:00	
59	348	PLANNED	OCC_554	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	9/May/22	08:00	9/May/22	18:00	NA
60	362	PLANNED	OCC_554	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	9/May/22	09:30	9/May/22	18:30	Circuit Breaker SF6 gas analysis
61	364	PLANNED	OCC_554	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	9/May/22	10:00	9/May/22	14:00	765/400kV 1500MVA ICT-I will be in service though its TIE 709 Bay & Main Bus-I

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
62	366	PLANNED	OCC_554	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	Daily	QM work	9/May/22	10:00	9/May/22	18:00	Load will be managed on Alkud - Solapur Line
63	372	PLANNED	OCC_554	MSETCL	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	9/May/22	15:00	9/May/22	18:00	765kV 240Mvar Bus Reactor will be in service through its TIE 712 Bay & Main Bus-II
64	380	PLANNED	OCC_554	MSETCL	MAIN BAY - 400KV-PADGHE-NAGOTHANE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	Continuous	1) Replacement of B bus R & Y ph PG isolator under LES scheme . 2) A Bus PG isoaltor maint work 3) Nagothane -2 in service through TBC . 4) Hanger Assembly replacement by Hot line method.	9/May/22	09:20	11/May/22	18:00	1) Agency will be present on site
65	385	PLANNED	OCC_554	MSETCL	400KV-KALWA-PADGHE-1	Daily	PID Testing Auto-Reclose function to be out of service.	9/May/22	09:00	14/May/22	17:00	PID Testing Auto-Reclose function to be out of service.
66	386	PLANNED	OCC_554	MSETCL	MAIN BAY OF 400KV-KARAD-JAIGAD-2 AND KARAD - 400KV - BUS 1 @KARAD - 400KV at KARAD - 400KV	Continuous	BAY MAINTENANCE WORK AT MSETCL KARAD	9/May/22	09:00	14/May/22	18:00	JAIGAD KARAD CKT 2 BREAKER OH WORKS
67	409	PLANNED	OCC_554	MSETCL	MAIN BAY OF 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 @WARORA - 400KV at WARORA - 400KV	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	10/May/22	08:00	10/May/22	17:00	Only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
68	424	PLANNED	OCC_554	MSETCL	400KV-WARDHA-WARORA-1	Daily	Routine Maintenance & Dignostic testing work.	10/May/22	09:00	10/May/22	18:00	400KV WARORA-IEPL Line is in ckt
69	428	PLANNED	OCC_553	APML-ADANI	MAIN BAY - 400KV-TIRODA-WARORA-2 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	Daily	409-52 Breaker Maintenance and testing	10/May/22	9:00	10/May/22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.
70	430	PLANNED	OCC_554	MEGPTCL	TIE BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-AKOLA (2)-EKTUNI-1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	10/May/22	09:30	10/May/22	18:30	Circuit Breaker SF6 gas analysis
71	433	PLANNED	OCC_554	MSETCL	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	10/May/22	10:00	10/May/22	14:00	765/400kV 1500MVA ICT-II will be in service through its Main 713 Bay & Main Bus-II & 765kV 240Mvar will be in service through its Main Bay 711 Bay & Main Bus-I
72	437	PLANNED	OCC_554	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic Testing of CT & Routine Maintenance	10/May/22	15:00	10/May/22	18:00	765/400kV 1500MVA ICT-II will be in service through its TIE 712 Bay & Main Bus-I
73	441	PLANNED	OCC_554	MSETCL	BABLESHWAR - 400KV - BUS 1	Continuous	& 400kV ZIV Numerical Busbar .Bus Bar protection Out, outage required 400kV RADSS & 400kV Numerical Busbar@BBLR"	10/May/22	09:00	11/May/22	18:00	Outage proposed for 400kv Bus bar Scheme
74	442	PLANNED	OCC_554	MSETCL	BABLESHWAR - 400KV - BUS 2	Continuous	& 400kV ZIV Numerical Busbar .Bus Bar protection Out, outage required 400kV RADSS & 400kV Numerical Busbar@BBLR"	10/May/22	09:00	11/May/22	18:00	Outage proposed for 400kv Bus bar Scheme
75	470	PLANNED	OCC_554	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Replacement of Suspicious faulty string insulators if found in PID and Routine maintainance. AR swich of 400KV Dhule-Babhaleshwar ckt 2 will be kept on Non-auto mode	11/May/22	8:00	11/May/22	18:00	AR swich of 400KV dhl-bblr 2 ckt will be kept on Nonauto mode
76	471	PLANNED	OCC_554	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	11/May/22	08:00	11/May/22	18:00	NA
77	486	PLANNED	OCC_554	MSETCL	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	Daily	Quarterly maintenance work	11/May/22	09:00	11/May/22	17:00	It is very important work
78	487	PLANNED	OCC_554	MSETCL	220KV-PANDURNA-KALMESHWAR-1	Daily	Routine Maintenance & Dignostic testing work	11/May/22	09:00	11/May/22	17:00	NA
79	488	PLANNED	OCC_554	MSETCL	132KV-PENCH-KANHAN-1	Daily	Routine Maintenance work.	11/May/22	09:00	11/May/22	17:00	NA
80	491	PLANNED	OCC_554	POWERGRID_WR2	BOISAR - 220KV - TRANSFER BUS 1	Daily	AMP	11/May/22	9:00	11/May/22	17:30	PG-WR2-Boisar
81	492	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	(1) Hardware Tightening & Fitting Work	11/May/22	09:00	11/May/22	18:00	-
82	493	PLANNED	OCC_554	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Hardware Tightening & Fitting work	11/May/22	09:00	11/May/22	18:00	-

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
83	505	PLANNED	OCC_554	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	11/May/22	09:30	11/May/22	18:30	Circuit Breaker SF6 gas analysis
84	508	PLANNED	OCC_554	MSETCL	JEUR - 220KV - BUS 1	Daily	An outage is required for Quarterly Maintenance	11/May/22	10:00	11/May/22	17:00	Quarterly Maintenance
85	509	PLANNED	OCC_554	MSETCL	220KV-AURANGABAD-CHITEGAON-2	Daily	Diagonestic testing & routine maint. work is to be carried out.	11/May/22	10:00	11/May/22	18:00	Annual target to be completed
86	514	PLANNED	OCC_554	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	11/May/22	07:00	12/May/22	18:00	Planned outage
87	522	PLANNED	OCC_554	MSETCL	400KV-KARJAT-LONIKHAND-II-2	Daily	To carry out PID	11/May/22	8:00	20/May/22	18:00	Online work(PID/AR Out)
88	527	PLANNED	OCC_554	POWERGRID_WRI	400KV-TARAPUR 3&4-PADGHE-2	Daily	Relay Testing OF 400 KV Padghe Tarapur-2 at Padghe MSETCL SS.	12/May/22	7:00	12/May/22	17:00	400 KV Padghe Tarapur 2 will be out of service.
89	529	PLANNED	OCC_554	POWERGRID_WRI	400KV-KOLHAPUR-MS-SOLAPUR	Daily	Line side equipments AMP and relay testing works	12/May/22	7:00	12/May/22	18:00	
90	530	PLANNED	OCC_554	POWERGRID_WRI	400KV-KOLHAPUR-MS-SOLAPUR-2 L/R@ SOLAPUR - 400KV	Daily	Line Reactor AMP Works	12/May/22	7:00	12/May/22	18:00	
91	535	PLANNED	OCC_554	MSETCL	MAIN BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 at LONIKHAND-II - 400KV	Daily	Half yearly maintenance and diagnostic testing.	12/May/22	08:00	12/May/22	18:00	400kV Karjat ckt-I will remain charged.
92	536	PLANNED	OCC_554	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	Chemical cleaning of insulator strings, Routine maintenance and testing activities.	12/May/22	08:00	12/May/22	18:00	---
93	537	PLANNED	OCC_554	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of Suspicious faulty string insulators if found in PID and Routine maintainance. AR swich of 400KV Dhule-Babhaleshwar ckt 1 will be kept on Non-auto mode	12/May/22	8:00	12/May/22	18:00	AR swich of 400KV dhl-bblr 1 ckt will be kept on Nonauto mode
94	538	PLANNED	OCC_554	MSETCL	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND FUTURE at LONIKHAND-II - 400KV	Daily	Half yearly maintenance and diagnostic testing .	12/May/22	08:00	12/May/22	18:00	400kV Karjat ckt-I will remain charged
95	539	PLANNED	OCC_554	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine Maintenance work	12/May/22	08:00	12/May/22	18:00	-
96	554	PLANNED	OCC_554	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work ;Main I distance relay and LBB testing work; Bay maintenance work.	12/May/22	09:00	12/May/22	17:00	400kV Padghe I will be in in service
97	558	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-KARJAT-2	Daily	(1) Main-1 distance relay testing work. (2) Bay maintenance work.	12/May/22	09:00	12/May/22	18:00	-
98	559	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-KARJAT-2	Daily	Hardware tightening	12/May/22	09:00	12/May/22	18:00	Hardware tightening
99	560	PLANNED	OCC_554	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work .	12/May/22	09:00	12/May/22	18:00	400 KV WARORA - DEOLI 2 Line is in ckt
100	562	PLANNED	OCC_554	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	Daily	FOR LINE MAINTENANCE WORK	12/May/22	9:00	12/May/22	18:00	
101	567	PLANNED	OCC_553	APML-ADANI	MAIN BAY - 400KV/11.5KV TIRODA-ST-2 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	Daily	407-52 Breaker Maintenance and testing	12/May/22	9:00	12/May/22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.
102	571	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	12/May/22	09:30	12/May/22	18:30	Circuit Breaker SF6 gas analysis
103	572	PLANNED	OCC_554	MSETCL	220KV-PARLI-PARLI-M-1	Daily	Routine bay maintenance	12/May/22	10:00	12/May/22	16:00	-
104	602	PLANNED	OCC_554	POWERGRID_WRI	PARLI - 220KV - BUS 2	Daily	For Bus AMP	13/May/22	8:00	13/May/22	18:00	

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
105	609	PLANNED	OCC_554	POWERGRID_WR2	BOISAR - 220KV - BUS 2	Daily	Isolator Servicing	13/May/22	9:00	13/May/22	17:30	PG-WR2-Boisar
106	618	PLANNED	OCC_554	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	13/May/22	09:30	13/May/22	18:30	Circuit Breaker SF6 gas analysis
107	623	PLANNED	OCC_554	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	13/May/22	07:00	14/May/22	18:00	Planned outage
108	624	PLANNED	OCC_554	MSETCL	PADGHE - 400KV - BUS 2	Continuous	1) 400kV Nagothane -2 R & Yph B bus PG isolator Hanger Assembly replacement work by Hot line method. 2) All elements on B bus will be in service .3)Shifting of 400KV Nagothane ckt 2 on TBC	13/May/22	09:00	15/May/22	17:00	1) Weather condition should be clear
109	638	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	14/May/22	08:00	14/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
110	639	PLANNED	OCC_554	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	Pre-Monsoon Maintenance of Line	14/May/22	09:00	14/May/22	17:00	Pre-Monsoon Maintenance of Line
111	645	PLANNED	OCC_554	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	14/May/22	09:30	14/May/22	18:30	Circuit Breaker SF6 gas analysis
112	648	PLANNED	OCC_554	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	A] HVDC TL O&M Sub-Division, Padghe:- 1.Stringing of Earthwire at Loc. No. 919 - 920 (R-phase side). 2.To attend Broken/Faulty Disc Insulators replacement at Towers. Loc. No. 55, 951, 989, 884. 3.Fixing of Corona Rings at 6 Locs. (989, 981, 956, 916, 892, 884) 4.Jumper Nut-Bolt Tightening of Cut-Point Location � 40 locs. 5.Chemical Cleaning at Tower Locations � 21 nos. of Bird shit/ Dust pollution Area / Highway Raod Crossing. B] HVDC TL O&M Sub-Division, Junnar :- 1.To attend broken Disc Insulators replacement at Towers. Loc. No. 820,822,825,827 under HVDC Junnar Lines Sub Division. 2.Jumper Nut-Bolt Tightening of Cut-Point Location � 13 locs. Fixing of corona ring at Loc Nos.861,851,849.	14/May/22	08:00	15/May/22	18:00	Chemical cleaning are very necessary for avoiding the flashover of insulator string specially in hilly area of Naneghat/Manikdoh/Bota location and Potgaon Forest Area.
113	649	PLANNED	OCC_554	MSETCL	400KV-KALWA-PADGHE-2	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	14/May/22	09:00	15/May/22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity
114	654	PLANNED	OCC_554	POWERGRID_WR1	400KV-KALA-KUDUS-2	Daily	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTING AT KUDUS END.	15/May/22	7:00	15/May/22	17:00	400 KV KALA KUDUS LINE 2 will be out of service
115	657	PLANNED	OCC_554	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	cold washing and jumper tightening work	15/May/22	08:00	15/May/22	17:00	NA
116	660	PLANNED	OCC_554	MSETCL	400KV-KALWA-PADGHE-1	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	15/May/22	09:00	15/May/22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity
117	663	PLANNED	OCC_554	MSETCL	BOISAR-M - 220KV - BUS 2	Continuous	Bus Maintenance Works	15/May/22	07:00	16/May/22	19:00	Bus Maintenance Works
118	673	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	16/May/22	08:00	16/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
119	678	PLANNED	OCC_554	MSETCL	400KV-KORADI-II-KORADI-III-1	Daily	Line maintenance work	16/May/22	08:00	16/May/22	18:00	NA
120	685	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	16/May/22	09:30	16/May/22	14:30	Circuit Breaker SF6 gas analysis

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
121	688	PLANNED	OCC_554	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Cold washing work	16/May/22	07:00	17/May/22	18:00	Planned outage
122	689	PLANNED	OCC_554	MSETCL	CHAKAN - 400KV - BUS 1	Continuous	For Replacement of Bus A old 89 A Rph ,Y ph, B ph Isolator By new Isolaotor	16/May/22	09:00	18/May/22	18:00	---
123	690	PLANNED	OCC_554	MSETCL	MAIN BAY OF 400KV-JAIGAD-NEW KOYNA-1 AND NEW KOYNA - 400KV - BUS 1 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	Continuous	C.B. Overhauling work Shifting on TBC	16/May/22	08:00	21/May/22	17:00	Planned outage
124	691	PLANNED	OCC_554	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	PID Testing Auto-Reclose function to be out of service.	16/May/22	09:00	21/May/22	18:00	PID Testing Auto-Reclose function to be out of service.
125	692	PLANNED	OCC_554	MSETCL	BUS COUPLER @ CHAKAN (Element not found in WRLDC outage Software)	Continuous	For Replacement of Bus A and Bus B Old 89 A Rph ,Y ph, B ph Isolator and old 89B Rph ,Yph, Bph Isolator By new Isolaotor. Outage required alongwith Bus 1 and Bus 2	16/May/22	09:00	21/May/22	18:00	---
126	694	PLANNED	OCC_554	MSETCL	MAIN BAY OF 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 AND CHANDRAPUR-GCR - 400KV - BUS 1 @CHANDRAPUR-GCR - 400KV at CHANDRAPUR-GCR - 400KV	Continuous	1) Capital overhauling and servicing of Mechanism Drive, SF6 gas monitoring assembly, Hydraulic pressure monitoring assembly and Poles and Interrupters. 2) Measurement of Timing, CRM and DCRM of CB. 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	16/May/22	08:00	31/May/22	18:00	During outage, HVDC ckt.- 2 will be in service via TBC-2 and there will not be any power restriction on Bi pole. i.e. HVDC Pole-1 & 2.
127	695	PLANNED	OCC_554	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	To Off / Out Auto Reclose at Both Ends For Carrying PID Work	16/May/22	08:00	31/May/22	18:00	-
128	697	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	17/May/22	08:00	17/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
129	698	PLANNED	OCC_554	POWERGR D_WR1	400KV-ALKUD-SOLAPUR	Daily	Line side equipments AMP	17/May/22	7:00	17/May/22	18:00	
130	699	PLANNED	OCC_554	POWERGR D_WR1	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	Daily	Line Reactor AMP Works	17/May/22	7:00	17/May/22	18:00	
131	708	PLANNED	OCC_554	POWERGR D_WR1	PUNE-PG - 220KV - BUS 1	Daily	Replacement of Clamp and connectors	17/May/22	7:00	17/May/22	18:00	
132	710	PLANNED	OCC_554	MSETCL	400KV-KORADI-II-KORADI-III-2	Daily	Line maintenance work	17/May/22	08:00	17/May/22	18:00	NA
133	711	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	17/May/22	08:00	17/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
134	732	PLANNED	OCC_553	APML- ADANI	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	Daily	707-52 Breaker Maintenance and testing	17/May/22	9:00	17/May/22	18:00	Outage can be upload in WRLDC outage management portal in account of APML for D-3 readiness.
135	734	PLANNED	OCC_554	MSETCL	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	Daily	1. PID Faluty strings replacement work 2. QM Work 3. CB Testing work.	17/May/22	09:00	17/May/22	20:00	PID Faluty strings replacement work
136	738	PLANNED	OCC_554	MSETCL	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	17/May/22	10:00	17/May/22	18:00	765kV 240Mvar Bus Reactor will be in service through its TIE 712 Bay & Main Bus-II
137	739	PLANNED	OCC_554	MSETCL	400KV-ALKUD-SOLAPUR-1	Daily	QM work	17/May/22	10:00	17/May/22	18:00	Load will be managed on Alkud kolhapur line
138	746	PLANNED	OCC_554	MSETCL	CHANDRAPUR-GCR - 400KV - AUXILIARY BUS 1	Continuous	PID Testing of Disc Insulator strings.	17/May/22	08:00	19/May/22	18:00	Work will be executed in live condition.
139	767	PLANNED	OCC_554	POWERGR D_WR1	PUNE-PG - 220KV - BUS 2	Daily	Replacement of Clamp and connectors	18/May/22	7:00	18/May/22	18:00	

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
140	768	PLANNED	OCC_554	POWERGR D_WR1	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work. AR to be kept in non Auto mode for 400KV-WARDHA-AKOLA-2. Dia to be kept open.	18/May/22	7:00	18/May/22	18:00	
141	769	PLANNED	OCC_554	POWERGR D_WR1	400KV-WARDHA-AKOLA-2 (NON-AUTO)	Daily	For BHEL Insulator Replacement Work	18/May/22	7:00	18/May/22	18:00	
142	771	PLANNED	OCC_554	NCA	400KV SSP - Dhule-I	Daily	Main-I & II Distance protection Relay testing work with M/s HEIL(Formerly known as ABB)	18/May/22	7:00	18/May/22	19:00	A/R swithch of SSP Dhule-II line to be put on Non Auto mode.
143	772	PLANNED	OCC_554	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	cold washing and jumper tightening work	18/May/22	08:00	18/May/22	17:00	NA
144	774	PLANNED	OCC_554	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	Daily	Annual Maintenance of line	18/May/22	08:00	18/May/22	18:00	Annual Maintenance of line
145	775	PLANNED	OCC_554	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine Line Maintenance work under LM SDn Wardha	18/May/22	08:00	18/May/22	18:00	NA
146	779	PLANNED	OCC_554	POWERGR D_WR1	PARLI - 220KV - BUS 1	Daily	For Bus AMP	18/May/22	8:00	18/May/22	18:00	
147	786	PLANNED	OCC_554	MSETCL	220KV-TILLARI-AMONA-1	Daily	Quarterly maintenance work	18/May/22	09:00	18/May/22	17:00	It is very important work
148	787	PLANNED	OCC_554	MSETCL	132KV-PENCH-MANSAR-1	Daily	Routine Maintenance work.	18/May/22	09:00	18/May/22	17:00	NA
149	792	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Replacement of faulty string	18/May/22	09:00	18/May/22	18:00	Replacement of faulty string
150	793	PLANNED	OCC_554	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	18/May/22	09:00	18/May/22	18:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
151	794	PLANNED	OCC_554	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Hardware Tightening & Fitting work	18/May/22	09:00	18/May/22	18:00	-
152	804	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	18/May/22	09:30	18/May/22	14:30	Circuit Breaker SF6 gas analysis
153	805	PLANNED	OCC_554	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Routine bay maintenance	18/May/22	10:00	18/May/22	16:00	-
154	806	PLANNED	OCC_554	MSETCL	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	18/May/22	10:00	18/May/22	18:00	765/400kv 1500MVA ICT-II will be in service through its Main 713 Bay & Main Bus-II & 765kv 240Mvar will be in service through its Main Bay 711 Bay & Main Bus-I
155	809	PLANNED	OCC_554	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Cold washing work	18/May/22	07:00	19/May/22	18:00	Planned outage
156	817	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode.	19/May/22	08:00	19/May/22	18:00	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode.
157	819	PLANNED	OCC_554	GETCO	400KV-SSP-DHULE-MS-2	Daily	PMM. Auto reclose of 400 kV SSP - Dhule - 1 will remain out	19/May/22	7:00	19/May/22	18:00	Non auto reclose code for 400kv SSP-Dhule no-1 is to be required.
158	824	PLANNED	OCC_554	POWERGR D_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work. AR to be kept in non Auto mode for 400KV-WARDHA-AKOLA-1. Dia to be kept open.	19/May/22	7:00	19/May/22	18:00	
159	825	PLANNED	OCC_554	POWERGR D_WR1	400KV-WARDHA-AKOLA-1 (NON-AUTO)	Daily	For BHEL Insulator Replacement Work	19/May/22	7:00	19/May/22	18:00	
160	835	PLANNED	OCC_554	MSETCL	400KV-KARJAT-LONIKHAND-II-1	Daily	DT & Line Maintenance	19/May/22	08:00	19/May/22	18:00	---

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
161	845	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-KARJAT-1	Daily	(1) Hardware Tightening & Fitting Work	19/May/22	09:00	19/May/22	18:00	-
162	846	PLANNED	OCC_554	MSETCL	BUS COUPLER @ CHAKAN (Element not found in WRLDC outage Software)	Daily	Diagnostic testing and maintenance activities.	19/May/22	09:00	19/May/22	18:00	---
163	847	PLANNED	OCC_554	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	19/May/22	09:00	19/May/22	18:00	Line will be charged through Main CB 429.
164	853	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	19/May/22	09:30	19/May/22	14:30	Circuit Breaker SF6 gas analysis
165	859	PLANNED	OCC_554	MSETCL	CHAKAN - 400KV - BUS 2	Continuous	For Replacement of Bus A old 89 A Rph ,Y ph, B ph Isolator By new Isolaotor	19/May/22	09:00	21/May/22	18:00	---
166	862	PLANNED	OCC_554	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	Daily	PID Testing	19/May/22	09:00	31/May/22	18:00	PID Testing
167	866	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	20/May/22	08:00	20/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
168	867	PLANNED	OCC_554	GETCO	400KV-SSP-DHULE-MS-1	Daily	PMM. Auto reclose of 400 kV SSP - Dhule - 2 will remain out	20/May/22	8:00	20/May/22	18:00	Non auto reclose code for 400kv SSP-Dhule no-2 is to be required.
169	870	PLANNED	OCC_555	NCA	400KV SSP - Dhule-I	Daily	Main-I & II Distance protection Relay testing work with M/s HEIL(Formerly known as ABB)	20/May/22	7:00	20/May/22	19:00	A/R swieth of SSP Dhule-II line to be put on Non Auto mode.
170	874	PLANNED	OCC_554	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work	20/May/22	7:00	20/May/22	18:00	
171	875	PLANNED	OCC_554	POWERGRID_WR1	400KV-WARDHA-AKOLA-2 (NON-AUTO)	Daily	For BHEL Insulator Replacement Work	20/May/22	7:00	20/May/22	18:00	
172	879	PLANNED	OCC_554	NCA	400KV SSP -Dhule-II	Daily	Main-I & II Distance protection Relay testing work with M/s HEIL(Formerly known as ABB)	20/May/22	7:00	20/May/22	19:00	A/R swieth of SSP Dhule-I line to be put on Non Auto
173	884	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	20/May/22	08:00	20/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
174	885	PLANNED	OCC_554	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine Line Maintenance work under LM SDn Wardha	20/May/22	08:00	20/May/22	18:00	NA
175	894	PLANNED	OCC_554	POWERGRID_WR2	BOISAR - 400KV - BUS 1	Daily	AMP	20/May/22	9:00	20/May/22	17:30	PG-WR2-Boisar
176	906	PLANNED	OCC_554	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Cold line cleaning, Chemical cleaning of Insulators & addition jumpuring work by fire wedge connector	20/May/22	09:00	22/May/22	18:00	Cold line cleaning, Chemical cleaning of Insulators & addition jumpuring work by fire wedge connector
177	907	PLANNED	OCC_554	MSETCL	CHANDRAPUR-GCR - 400KV - BUS 2	Daily	PID Testing of Disc Insulator strings.	20/May/22	08:00	25/May/22	18:00	Work will be executed in live condition.
178	912	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	21/May/22	08:00	21/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
179	914	PLANNED	OCC_554	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-1	Daily	For CVT Testing	21/May/22	7:00	21/May/22	18:00	
180	920	PLANNED	OCC_554	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work	21/May/22	7:00	21/May/22	18:00	

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
								Date	Time	Date	time	
181	921	PLANNED	OCC_554	POWERGRID_WRI	400KV-WARDHA-AKOLA-1 (NON-AUTO)	Daily	For BHEL Insulator Replacement Work	21/May/22	7:00	21/May/22	18:00	
182	925	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	21/May/22	08:00	21/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
183	930	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-1 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	21/May/22	09:30	21/May/22	14:30	Circuit Breaker SF6 gas analysis
184	931	PLANNED	OCC_554	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	A] HVDC TL O&M Sub-Division, Padghe:- 1.To attend Broken/Faulty Disc Insulators replacement at Towers. Loc. No. 20 & 968. 2.Replacement of broken Earthwire Suspension clamps at Loc no. 939 & 940 (B-Phase side). 3.Fixing of Corona Rings at 2 Locs. 962, 968. 4.Fixing of Conductor Repair Sleeve at Loc 928, 967. 5 Jumper Nut-Bolt Tightening of Cut-Point Locations � 45 locs. 6.Chemical Cleaning at Tower Locations �21 nos. Of Bird shit/ Dust pollution Area / Highway Raod Crossing. B] HVDC TL O&M Sub-Division, Junnar:- 1.To attend Faulty Disc Insulators replacement at Towers. Loc. No. 750,761 & 763 under HVDC Junnar Lines Sub Division. 2.Jumper Nut-Bolt Tightening of Cut-Point Location � 21 locs. 3.Chemical Cleaning at Tower Locations � 22 nos. of Bird shit /Dust pollution Area /NH road Crossing.	21/May/22	08:00	22/May/22	18:00	Chemical cleaning are very necessary for avoiding the flashover of insulator string specially in hilly area of Naneghat/Manikdoh/Bota location and the Potgaon forest Area.
185	934	PLANNED	OCC_554	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	To carry out PID	21/May/22	8:00	31/May/22	18:00	Online work(PID/AR Out)
186	935	PLANNED	OCC_553	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-1	Continuous	For attending SF6 gas Leakage in GIB duct	21/May/22	22:00	22/May/22	2:00	For attending SF6 gas Leakage
187	938	PLANNED	OCC_554	POWERGRID_WRI	400KV-KHARGHAR-PUNE-PG-1	Daily	For CVT Testing	22/May/22	7:00	22/May/22	18:00	
188	939	PLANNED	OCC_554	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	Daily	Annual Maintenance of line	22/May/22	08:00	22/May/22	18:00	Annual Maintenance of line
189	941	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	22/May/22	08:00	22/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
190	942	PLANNED	OCC_555	NCA	400KV SSP -Dhule-II	Daily	Main-I & II Distance protection Relay testing work with M/s HEIL(Formerly known as ABB)	22/May/22	7:00	22/May/22	19:00	A/R swieth of SSP Dhule-I line to be put on Non Auto
191	945	PLANNED	OCC_554	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	For routine Maintenance work and relay testing work and Chemical cleaning of insulator strings, Routine maintenance and testing activities.	22/May/22	09:00	22/May/22	17:00	400kV Kharghar - Kalwa line will be in service.
192	946	PLANNED	OCC_554	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	Pre-Monsoon Maintenance of Line	22/May/22	09:00	22/May/22	17:00	Pre-Monsoon Maintenance of Line
193	948	PLANNED	OCC_554	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance.	22/May/22	10:00	22/May/22	18:00	---
194	949	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	23/May/22	08:00	23/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
								Date	Time	Date	time	
195	950	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	23/May/22	08:00	23/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
196	958	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	23/May/22	08:00	23/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
197	966	PLANNED	OCC_554	MSETCL	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2 at PARLI-M - 400KV	Daily	(1) LBB & Backup relay testing work. (2)Bay maintenance work.	23/May/22	09:00	23/May/22	18:00	-
198	975	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	23/May/22	09:30	23/May/22	14:30	Circuit Breaker SF6 gas analysis
199	981	PLANNED	OCC_554	TARAPUR 3&4	400KV-TARAPUR 3&4-PADGHE-1	Continuous	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	23/May/22	9:00	25/May/22	18:00	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
200	986	PLANNED	OCC_554	MSETCL	400KV-KALWA-PADGHE-2	Daily	PID Testing Auto-Reclose function to be out of service.	23/May/22	09:00	31/May/22	18:00	PID Testing Auto-Reclose function to be out of service.
201	988	PLANNED	OCC_554	POWERGRID_WRI	400KV-TARAPUR 3&4-PADGHE-1	Daily	AMP OF 400 KV Padghe Tarapur-1 Line Equipment/ CT Replacement at Padghe MSETCL SS.	24/May/22	7:00	24/May/22	19:00	400 KV Padghe Tarapur 1 will be out of service.
202	990	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	24/May/22	08:00	24/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
203	993	PLANNED	OCC_554	MSETCL	TIE BAY - 400KV/220KV AKOLA-ICT-1 AND 400KV-AKOLA-AURANGABAD-1 at AKOLA - 400KV	Daily	Routine maintenance & testing work	24/May/22	07:00	24/May/22	14:00	Main Bay 402 of ICT -01 & main Bay 404 of Aurangabad will be in service
204	998	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	24/May/22	08:00	24/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
205	1015	PLANNED	OCC_554	MEGPTCL	TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND 400KV-AKOLA-AKOLA (2)-2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	24/May/22	09:30	24/May/22	14:30	Circuit Breaker SF6 gas analysis
206	1019	PLANNED	OCC_554	MSETCL	MAIN BAY - 400KV-PADGHE-NAGOTHANE-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	Continuous	1) A bus Y & Bph PG Isolator replacement work under LES scheme 2) B bus PG isolator maint work 3) Hanger Assembly replacement work by Hot line Method 4) 400kV Nagothane -1 in service through TBC 5) In case of any emergency for shifting other bay on TBC Nagothane -1 can be charged on B bus	24/May/22	09:00	26/May/22	18:00	1) Agency will be present on site
207	1029	PLANNED	OCC_554	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Replacement of Suspicious faulty string insulators if found in PID and Routine maintainance. AR swich of 400KV Dhule-Babhaleshwar ckt 2 will be kept on Non-auto mode	25/May/22	8:00	25/May/22	18:00	AR swich of 400KV dhl-bblr 2 ckt will be kept on Nonauto mode
208	1038	PLANNED	OCC_554	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	Quarterly maintenance work	25/May/22	09:00	25/May/22	17:00	It is very important work
209	1039	PLANNED	OCC_554	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	25/May/22	09:00	25/May/22	17:00	NA
210	1041	PLANNED	OCC_554	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Hardware Tightening & Fitting work	25/May/22	09:00	25/May/22	18:00	-
211	1050	PLANNED	OCC_554	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	25/May/22	09:30	25/May/22	14:30	Circuit Breaker SF6 gas analysis
212	1058	PLANNED	OCC_554	POWERGRID_WRI	400KV-WARDHA-WARORA-PG-1	Continuous	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme	26/May/22	7:00	31/May/22	18:00	

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
213	1059	PLANNED	OCC_554	POWERGRID_WRI	400KV-WARDHA-WARORA-PG-2	Continuous	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme	26/May/22	7:00	31/May/22	18:00	
214	1061	PLANNED	OCC_554	POWERGRID_WRI	220KV-TARAPUR 3&4-BOISAR-1	Daily	AMP. Dia to be kept opened. Ckt#2 to be in non auto mode.	26/May/22	9:00	28/May/22	17:30	PG-WR2-Boisar
215	1066	PLANNED	OCC_554	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of Suspicious faulty string insulators if found in PID and Routine maintenance.AR swich of 400KV Dhule-Babhaleshwar ckt 1 will be kept on Non-auto mode	26/May/22	8:00	26/May/22	18:00	AR swich of 400KV dhl-bblr 1 ckt will be kept on Nonauto mode
216	1067	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	26/May/22	08:00	26/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
217	1068	PLANNED	OCC_554	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine Maintenance work	26/May/22	08:00	26/May/22	18:00	-
218	1075	PLANNED	OCC_554	MSETCL	400KV-PARLI-M-KARJAT-2	Continuous	(1) Hardware Tightening & Fitting Work	26/May/22	09:00	26/May/22	18:00	-
219	1085	PLANNED	OCC_554	MSETCL	400KV-KARAD-JAIGAD-2	Daily	INSULATOR HOT LINE WASHING WORK	26/May/22	09:00	27/May/22	18:00	INSULATOR HOT LINE WASHING WORK
220	1086	PLANNED	OCC_554	MSETCL	400KV-KARAD-JAIGAD-1	Daily	INSULATOR HOT LINE WASHING WORK	26/May/22	09:00	27/May/22	18:00	INSULATOR HOT LINE WASHING WORK
221	1094	PLANNED	OCC_554	MSETCL	MAIN BAY - 400KV/220KV AKOLA-ICT-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	Daily	Routine maintenance & testing work	27/May/22	07:00	27/May/22	14:00	Tie Bay 406 will be in service
222	1096	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	27/May/22	08:00	27/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
223	1101	PLANNED	OCC_554	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	1) Pre-Monsoon Maintenance of Line 2) Bay Maintenance Works at 220KV Boisar-II ss	27/May/22	09:00	27/May/22	17:00	1) Pre-Monsoon Maintenance of Line 2) Bay Maintenance Works at 220KV Boisar-II ss
224	1102	PLANNED	OCC_554	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	Routine Line maintenance work;LBB relay testing work; Bay maintenance work	27/May/22	09:00	27/May/22	17:00	400kV EKTUNI Ckt II,400kV Bhusawal, 400kV Aurangabad, 400kV Dhule I&II will be in service "
225	1116	PLANNED	OCC_554	MSETCL	PADGHE - 400KV - BUS 1	Continuous	1)400kV Nagothane -1 A bus Y & Bph PG isolator Hanger Assembly Replacement work by Hot line method 2) All elements on A Bus will be in service.3) TBC shfting of Nagothane 1 line on and remain on TBC	27/May/22	09:00	29/May/22	17:00	1) weather condition should be clear.
226	1117	PLANNED	OCC_554	POWERGRID_WRI	220KV-TALEGAON-PUNE-PG-2	Daily	For CVT Testing	28/May/22	7:00	28/May/22	18:00	
227	1121	PLANNED	OCC_554	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Chemical cleaning of insulator strings, Routine maintenance and testing activities.	28/May/22	08:00	28/May/22	18:00	---
228	1122	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	28/May/22	08:00	28/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
229	1125	PLANNED	OCC_554	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	Routine Line maintenance work;Bay maintenance work	28/May/22	09:00	28/May/22	17:00	400kV EKTUNI Ckt I,400kV Bhusawal, 400kV Aurangabad, 400kV Dhule I&II will be in service "
230	1126	PLANNED	OCC_554	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	Pre-Monsoon Maintenance of Line	28/May/22	09:00	28/May/22	17:00	Pre-Monsoon Maintenance of Line
231	1127	PLANNED	OCC_554	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	Diagnostic Testing & Routine Maintenance	28/May/22	09:00	28/May/22	18:00	765/400kV 1500MVA ICT-II will be in service

Sr.No.	OCC M Sr. No	Request Type	OCC Number	Name of Requestin g Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
								Date	Time	Date	time	
232	1128	PLANNED	OCC_554	MSETCL	400KV-JAIGAD-NEW KOYNA-2	Daily	INSULATOR HOT LINE WASHING WORK	28/May/22	09:00	28/May/22	18:00	INSULATOR HOT LINE WASHING WORK
233	1129	PLANNED	OCC_554	MSETCL	400KV-JAIGAD-NEW KOYNA-1	Daily	INSULATOR HOT LINE WASHING WORK	28/May/22	09:00	28/May/22	18:00	INSULATOR HOT LINE WASHING WORK
234	1133	PLANNED	OCC_554	MEGPTCL	TIE BAY - 765KV/400KV AKOLA (2)-ICT-1 AND 400KV-AKOLA (2)-FUTURE-5 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	28/May/22	09:30	28/May/22	14:30	Circuit Breaker SF6 gas analysis
235	1134	PLANNED	OCC_554	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance	28/May/22	10:00	28/May/22	18:00	---
236	1136	PLANNED	OCC_554	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Cold line cleaning, Chemical cleaning of Insulators & addition jumpering work by fire wedge connector	28/May/22	09:00	30/May/22	18:00	Cold line cleaning, Chemical cleaning of Insulators & addition jumpering work by fire wedge connector
237	1139	PLANNED	OCC_554	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	Pre-Monsoon Maintenance of Line	29/May/22	09:00	29/May/22	17:00	Pre-Monsoon Maintenance of Line
238	1140	PLANNED	OCC_554	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Diagnostic Testing & Routine Maintenance	29/May/22	09:00	29/May/22	18:00	765/400kV 1500MVA ICT-1 will be in service
239	1141	PLANNED	OCC_554	MSETCL	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	Daily	Bay maintenance & testing work	29/May/22	09:00	29/May/22	18:00	Bay maintenance & testing work
240	1143	PLANNED	OCC_554	MSETCL	220KV-BOISAR-BOISAR-M-3 ON TBC @ BOISAR - M END (Element not found in WRLDC outage Software)	Continuous	CB Maintenance Works after shifting the line on TBC.	29/May/22	09:00	30/May/22	17:00	Line will be in service through TBC
241	1147	PLANNED	OCC_554	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	30/May/22	08:00	30/May/22	17:00	only Tie CB 421 is in OFF condition, respective ckt charged through its own main CB.
242	1148	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	30/May/22	08:00	30/May/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
243	1156	PLANNED	OCC_553	WTPL - ADANI	400KV-SOLAPUR-M-SOLAPUR-1	Daily	Planned annual maintenance	30/May/22	9:00	30/May/22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
244	1157	PLANNED	OCC_553	WTPL - ADANI	220KV-SOLAPUR-JEUR-1	Daily	AR in non auto due to planned annual maintenance of 400KV-SOLAPUR-M-SOLAPUR-1	30/May/22	9:00	30/May/22	18:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
245	1167	PLANNED	OCC_554	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	31/May/22	08:00	31/May/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.

List of outages not considered by WRPC OCCM for the Month of May' 2022

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		OCC-Remarks
								Date	Time	Date	time	
1	118	PLANNED	OCC_554	POWERGRID_WRI	400kV IEPL-Warora & 400kV Warora-Wardha (MSETCL line)	Continuous	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme(New Constrction works)	2-May-22	7:00	19-May-22	18:00	SLDC MH:- Chandrapur-II-Chandrapur GCR D/C in HTLS conductor. PI plan in july month
2	312	PLANNED	OCC_554	POWERGRID_WRI	220kV Pusad-PGCIL Deoli & 220kV Bhugaon-PGCIL Deoli (MSETCL line)	Continuous	Loc. 03-04 POWERGRID Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	6-May-22	7:00	7-May-22	18:00	SLDC MH:-not consented by MH in view of high line loading and high demand in april and may
3	317	PLANNED	OCC_554	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continuous	work of replacement of Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line and restringing from Loc. no. 117-122 under HVDC TL O&M S/Dn. Chandrapur. Outage proposed on HVDC Pole-1 and 2 simultaneously.	6-May-22	06:00	8-May-22	18:00	Deferred by SLDC due to high demand
4	318	PLANNED	OCC_554	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Continuous	work of replacement of Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line and restringing from Loc. no. 117-122 under HVDC TL O&M S/Dn. Chandrapur. Outage proposed on HVDC Pole-1 and 2 simultaneously	6-May-22	06:00	8-May-22	18:00	Deferred by SLDC due to high demand
5	623	PLANNED	OCC_554	POWERGRID_WRI	400kV Koradi-II-PGCIL Wardha (MSETCL line)	Continuous	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	12-May-22	7:00	19-May-22	18:00	SLDC MH:-STU MSETCL NOC to be taken by PGCIL . Is it Koradi-II, pl plan in july
6	733	PLANNED	OCC_553	WTPL - ADANI	400KV-KHARGHAR-PUNE-PG-1	Continous	Shutdown required for Line diversion work due to MIDC road expansion. It will be taken as deemed availability.	16-May-22	9:00	31-May-22	18:00	SLDC MH:-Outage is not feasible in month of May due to high mumbai demand , plan in low mumbai demand season. PI plan in june
7	1101	PLANNED	OCC_554	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	Continuous	To attend the sag corection in tower no. 534, to stop the deforming of tower members in the first section.	26-May-22	08:00	27-May-22	18:00	SLDC MH consnet pl? generation to be reduced at Tiroda/Amrawati/Koradi-II. PI plan jun/july due to high demand and NOC from RIPL
8	1102	PLANNED	OCC_554	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	Continuous	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	26-May-22	08:00	27-May-22	18:00	SLDC MH consnet pl? generation to be reduced at Tiroda/Amrawati/Koradi-II. PI plan jun/july due to high demand and NOC from RIPL
9	1103	PLANNED	OCC_554	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	Continuous	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	26-May-22	08:00	27-May-22	18:00	SLDC MH consnet pl? generation to be reduced at Tiroda/Amrawati/Koradi-II. PI plan jun/july due to high demand and NOC from RIPL

State Element outage list for the month of May'2022

Sr.No.	Voltage	Element Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	AKOLA - KHADKA (BHUSAWAL)	03-May-22	08:00	07-May-22	18:00	Daily	String replacement work will be carried out on 400 kV Akola- Khadka (Bhusawal) line. Also work of tightening of Spacers cum Vibration Dampers, providing of corona ring & arcing horn will be carried out.	MSETCL	MSETCL	String replacement work will be carried out by Agency.
2	400 KV	GT-10 @ KORADI-2	04-May-22	10:00	04-May-22	13:00	Daily	Tan delta measurement of Line CT	MSETCL	MSETCL	NOC will be required from Mahagenco
3	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	04-May-22	10:00	04-May-22	14:00	Daily	Pre monsoon Maintenance activities	MSETCL	MSETCL	Load will be managed on 400 kv ICT-1
4	400 KV	MAIN BAY- 404 OF 400/220/33 KV 501 MVA ICT - 2 @ LAMBOTI	04-May-22	10:00	04-May-22	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Without load interruption. Load will be managed by ICT 1
5	400 KV	TIE BAY (406) OF BUS REACOTR AND FUTURE CKT @ LONIKAND 2	05-May-22	08:00	05-May-22	18:00	Daily	Half yearly maintenance and diagnostic testing	MSETCL	MSETCL	---
6	400 KV	TIE BAY (405) OF SWICHING SS CKT - 2 & NANDED - 1 @ CHANDRAPUR 2	05-May-22	10:00	05-May-22	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
7	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	05-May-22	09:00	05-May-22	17:00	Daily	CB testing work	MSETCL	MSETCL	Not in service
8	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	05-May-22	08:00	05-May-22	17:00	Daily	Pre monsoon maint work	MSETCL	MSETCL	NA
9	400 KV	MAIN BAY (401) OF ICT -1 @ JEJURI	05-May-22	09:30	05-May-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kv ICT-1 will be in service through 402 & 403 Bay.
10	400 KV	LONIKAND I -JEJURI	05-May-22	08:00	05-May-22	18:00	Daily	DT & Line Maintenance.	MSETCL	MSETCL	---
11	400 KV	MAIN BAY (407) OF BUS REACTOR @ LONIKAND 2	05-May-22	08:00	05-May-22	18:00	Daily	Half yearly maintenance and diagnostic testing .	MSETCL	MSETCL	---
12	400 KV	NEW KOYNA - STAGE IV CKT - 1	05-May-22	08:00	05-May-22	18:00	Daily	Routine maint. Work at New Koyna end and wave trap Jumper replacement work at stage IV end and Cold washing work	MSETCL	MSETCL	Planned outage
13	400 KV	TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	06-May-22	09:00	06-May-22	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
14	400 KV	GT-9 @ KORADI-2	06-May-22	10:00	06-May-22	13:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 414 & 413	MSETCL	MSETCL	NOC will be required from Mahagenco
15	400 KV	THAPTI TANDA - WALUJ	06-May-22	09:00	06-May-22	18:00	Daily	Routine maintenance Work & Diagnostic Testing Work	MSETCL	MSETCL	NA
16	400 KV	NEW KOYNA - STAGE IV CKT - 1	06-May-22	08:00	06-May-22	17:00	Daily	TBC Shitting for Routine maint. Work of A & B isolator	MSETCL	MSETCL	Planned outage
17	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	06-May-22	07:00	06-May-22	13:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
18	400 KV	400KV RPL LINE REACTOR @ 400KV KORADI	06-May-22	09:00	06-May-22	18:00	Daily	Bushings TAN Delta	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
19	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	06-May-22	08:00	06-May-22	17:00	Daily	Pre monsoon maint work	MSETCL	MSETCL	NA

Sr.No.	Voltage	Element Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	07-May-22	08:00	07-May-22	17:00	Daily	Pre monsoon maint work	MSETCL	MSETCL	NA
21	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	07-May-22	09:00	07-May-22	18:00	Daily	Premonsoon maintenance work;HV B/U Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 2, 3 and 4 will be in service
22	400 KV	WARORA - IEPL	07-May-22	08:00	07-May-22	18:00	Daily	Line CT's Tan Delta testing work.Relay testing work. Isolator maintenance by Agency.	MSETCL	MSETCL	400KV Warora -PGCIL(Wardha) Ckt.is in service.
23	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	07-May-22	08:00	07-May-22	18:30	Daily	for premonsoon maintenance testing and OLTC O/hauling work	MSETCL	MSETCL	OLTC /hauling will be carried by agency Engineer
24	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	09-May-22	11:00	09-May-22	17:00	Daily	Premansoon maint. work	MSETCL	MSETCL	Nil
26	400 KV	NEW KOYNA - STAGE IV CKT - 2	09-May-22	08:00	09-May-22	18:00	Daily	Routine maint. Work at New Koyna end and stage IV end and Cold washing work	MSETCL	MSETCL	Planned outage
27	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	09-May-22	08:00	13-May-22	18:00	Daily	String replacement work will be carried out on 400 kV Akola- Nandgaonpeth line. Also work of tightening of Spacers cum Vibration Dampers, providing of corona ring & arcing horn will be carried out.	MSETCL	MSETCL	Work will be carried out by agency.
28	400 KV	MAIN BAY-401 OF GT-10 @ KORADI-2	09-May-22	10:00	09-May-22	16:00	Daily	Diagnostic testing of CT & CB at bay 401	MSETCL	MSETCL	GT#10 will remain in service through Tie Bay 402
29	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	09-May-22	09:00	09-May-22	21:00	Daily	1. Pre monsoon Maintenance work. 2. C & Tan delta testing of ICT & CTs 3. Supervisory trails	MSETCL	MSETCL	Monday is load staggering day in Kolhapur
30	400 KV	400KV RPL-AKOLA2 CKT 1	10-May-22	06:00	10-May-22	17:00	Daily	Outage required for annual maintenance work of 400kV RPL to Akola 2 Line 1	APTCL	APTCL	Outage required for annual maintenance work of 400kV RPL to Akola 2 Line 1
31	400 KV	PADGHE - NAGOTHANE CKT - 2	10-May-22	08:00	10-May-22	17:00	Daily	jumper tightening work	MSETCL	MSETCL	NA
32	400 KV	NEW KOYNA - STAGE IV CKT - 2	10-May-22	08:00	10-May-22	17:00	Daily	TBC Shitting for R/M work of A & B isolator	MSETCL	MSETCL	Planned outage
33	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	10-May-22	07:00	10-May-22	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
34	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	10-May-22	09:00	10-May-22	18:00	Daily	Hardware Tightening & Fitting work	MSETCL	MSETCL	-
35	400 KV	400/220 KV 500 MVA ICT @ ALKUD	10-May-22	10:00	10-May-22	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	Tuesday is load staggering day for Sangli district
36	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	10-May-22	08:00	10-May-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
37	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	10-May-22	09:00	10-May-22	18:00	Daily	Bushings TAN Delta , CT TAN Delta	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
38	400 KV	TIE BAY-402 OF GT-10 @ KORADI-2	11-May-22	10:00	11-May-22	16:00	Daily	Diagnostic testing of CT & CB at bay 402	MSETCL	MSETCL	GT#10 will remain in service through Main Bay 401
39	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	11-May-22	07:00	11-May-22	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	NA
40	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	11-May-22	06:00	11-May-22	18:00	Daily	FOR PRE MONSOON MAINTENANCE WORK ALONGWITH DIGNOSTIC TESTING WORK CARRIED OUT.	MSETCL	MSETCL	LOAD WILL BE MANAGED ON ANOTHER ICT NO. II.
41	400 KV	WARORA - IEPL	11-May-22	08:00	11-May-22	18:00	Daily	1) Routine Maintenance & Dignostic testing work. 2) Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt

Sr.No.	Voltage	Element Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
42	400 KV	400KV RPL-AKOLA 2 CKT 2	12-May-22	06:00	12-May-22	17:00	Daily	Outage required for annual maintenance work of 400kV RPL to Akola 2 Line 2	APTCL	APTCL	Outage required for annual maintenance work of 400kV RPL to Akola 2 Line 2
43	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	12-May-22	07:00	12-May-22	16:00	Daily	For work of erection,testing of 'R' phase repaired Metering CT at 400KV Switching s/s Chandrapur.	MSETCL	MSETCL	For work of erection,testing of 'R' phase repaired Metering CT at 400KV Switching s/s Chandrapur.
44	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	12-May-22	08:00	13-May-22	18:00	Continuous	for Pre monsoon maintenance and testing work also OLTC o/hauling work	MSETCL	MSETCL	During outage any of 220KV CSN ckt 1/3 will be hand-tripped for load management
45	400 KV	MAIN BAY (404) OF ICT - 2 @ JEJURI	12-May-22	09:30	12-May-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33KV ICT-2 will be in service through 405 & 406 Bay.
25	400 KV	PADGHE - NAGOTHANE CKT - 1	13-May-22	08:00	13-May-22	17:00	Daily	jumper tightening work	MSETCL	MSETCL	NA
46	400 KV	GT - 6 @ KORADI-1	13-May-22	09:00	13-May-22	18:00	Daily	DCRM, CRM, CB TIMING	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
47	400 KV	KHADKA - BABLESHWAR	13-May-22	09:00	14-May-22	17:00	Continuous	Chemical Cleaning of Insulator string and Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad , Dhule I&II will be in in service
48	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	13-May-22	09:00	13-May-22	18:00	Daily	Routine maintenance Work & Diagnostic Testing Work	MSETCL	MSETCL	NA
49	400 KV	GT-8 @ KORADI-2	13-May-22	10:00	13-May-22	13:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 425&426	MSETCL	MSETCL	NOC will be required from Mahagenco
50	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	13-May-22	09:00	13-May-22	17:00	Daily	For routine Maintenance work and relay testing work	MSETCL	MSETCL	ICT 1 and 2 will be in service.
51	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	14-May-22	09:00	14-May-22	18:00	Daily	Premonsoon maintenance work;HV LBB,HV CB testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 3 and 4 will be in service
52	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	14-May-22	08:00	14-May-22	18:00	Daily	for Pre monsoon maintenance and testing work also OLTC o/hauling work	MSETCL	MSETCL	OLTC o/hauling work will be carried by agency engineer
53	400 KV	PADGHE - NAGOTHANE CKT - 1	16-May-22	08:00	16-May-22	17:00	Daily	jumper tightening work	MSETCL	MSETCL	NA
54	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	16-May-22	09:00	16-May-22	21:00	Daily	1. Pre monsoon Maintenance work. 2. C & Tan delta testing of ICT. 3. C & Tan delta testing of CT. 4.Supervisory trails of ICT.	MSETCL	MSETCL	Monday is load staggering day in Kolhapur.
55	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	16-May-22	08:00	31-May-22	19:00	Daily	To the 48F OPGW installation on 400kv chandrapur2-switching transmission line (from 400kv chandrapur 2 - chandrapur switchyard)by replacing existing earth wire in live line condition by keeping AR switch in Non-auto mode	MSETCL	MSETCL	Vinay from MTCIL team, mob no-8828237979
56	400 KV	MAIN BAY (417) OF IEPL @ WARORA	17-May-22	08:00	17-May-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Line will charged through Tie bay no 418
57	400 KV	PADGHE - NAGOTHANE CKT - 2	17-May-22	08:00	17-May-22	17:00	Daily	jumper tightening work	MSETCL	MSETCL	NA
58	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	18-May-22	09:00	18-May-22	18:00	Daily	(1) Reactor Backup relay testing work. (2)Bay maintenance work.	MSETCL	MSETCL	-
59	400 KV	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	18-May-22	08:00	18-May-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Line equipment will charged through Tie bay no 418

Sr.No.	Voltage	Element Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
60	400 KV	80 MVAr BUS REACTOR - 1 @ BABHALESHWAR	18-May-22	08:00	18-May-22	18:00	Daily	Premonsoon maintenance work;Winding resistance,Bushing tanD work and bay maintenance work	MSETCL	MSETCL	Reactor will be taken in service after 18:00 hrs i.e at peak voltage hours
61	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	18-May-22	07:00	18-May-22	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	NA
62	400 KV	CHANDRAPUR-PARLI CKT-3	19-May-22	09:00	19-May-22	18:00	Daily	Hardware Tightening & Fitting work	MSETCL	MSETCL	-
63	400 KV	TBC @ LONIKAND	19-May-22	10:00	19-May-22	18:00	Daily	Half Yearly DT & Bay Maintenance.	MSETCL	MSETCL	---
64	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	19-May-22	09:30	19-May-22	17:30	Daily	Annual Testing & Maintenance work	MSETCL	MSETCL	400/220/33kV ICT-I & ICT-III will be in service.
65	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	19-May-22	08:00	19-May-22	18:00	Daily	Half yearly maintenance and diagnostic testing .	MSETCL	MSETCL	---
66	400 KV	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	20-May-22	09:30	20-May-22	14:30	Daily	Circuit Breaker SF6 gas analysis	MEGPTCL	MEGPTCL	Circuit Breaker SF6 gas analysis
67	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	20-May-22	06:00	20-May-22	18:00	Daily	FOR PRE MONSOON MAINTENANCE WORK ALONG WITH DIAGNOSTIC TESTING WORK CARRIED OUT.	MSETCL	MSETCL	LOAD WILL BE MANAGED ON ANOTHER ICT NO. I
68	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	20-May-22	09:00	20-May-22	18:00	Daily	Routine maintenance Work & Diagnostic Testing Work	MSETCL	MSETCL	NA
69	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	20-May-22	09:00	20-May-22	17:00	Daily	For routine Maintenance and Diagnostic testing work	MSETCL	MSETCL	ICT 2 & 3 will be in service.
70	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	20-May-22	09:00	21-May-22	17:00	Continuous	Chemical Cleaning of Insulator string and Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I&II will be in in service
71	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	21-May-22	09:00	21-May-22	18:00	Daily	Premonsoon maintenance work;Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 4 will be in service
72	400 KV	KARAD - TALANDGE CKT - 2	23-May-22	09:00	23-May-22	20:00	Daily	1. QM Work 2. C & tan delta testing of CVT. 3. Replacement of CVT.	MSETCL	MSETCL	1.Monday is load staggering day in Kolhapur. 2. Load will be managed on 400kV karad Ckt-1
73	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	23-May-22	07:00	23-May-22	18:00	Daily	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance work	MSETCL	MSETCL	Planned outage
74	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	23-May-22	11:00	23-May-22	17:00	Daily	Premansoon maint. work	MSETCL	MSETCL	Nil
75	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	23-May-22	08:00	25-May-22	18:00	Daily	For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator.	MSETCL	MSETCL	-
76	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	23-May-22	07:00	23-May-22	14:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Load will be shifted on ICT-02
77	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	24-May-22	08:00	24-May-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Line equipment will charged through Tie bay no 421.
78	400 KV	400220kv 167MVA SPARE ICT @ DEEPNAGAR	24-May-22	06:00	24-May-22	18:00	Daily	FOR PRE MONSOON MAINTENANCE WORK ALONG WITH DIAGNOSTIC TESTING WORK CARRIED OUT.	MSETCL	MSETCL	THE SAID ICT UNIT IS KEPT AS SPARE.
79	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	25-May-22	07:00	25-May-22	18:00	Daily	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance	MSETCL	MSETCL	Planned outage

Sr.No.	Voltage	Element Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
80	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	25-May-22	07:00	25-May-22	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	NA
81	400 KV	125MVar BUS REACTOR @ WARORA	25-May-22	08:00	25-May-22	17:00	Daily	Premonsoon Maintenance work. Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Reactor & Tie CB(bay No.403) is in OFF conditions.
82	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	26-May-22	07:00	26-May-22	14:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Load will be shifted on ICT-01
83	400 KV	CHANDRAPUR-PARLI CKT-3	26-May-22	08:00	28-May-22	18:00	Daily	For replacement ofpolymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	-
84	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	26-May-22	09:00	26-May-22	18:00	Daily	(1) SFRA measurement ICT Units. (2) Bay maintenance work.	MSETCL	MSETCL	-
85	400 KV	KARAD - LONIKAND I	26-May-22	08:00	26-May-22	18:00	Daily	Chemical cleaning of insulator strings, Routine maintenance and testing activities. Half Yearly DT & Bay Maintenance.	MSETCL	MSETCL	---
86	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	27-May-22	07:00	27-May-22	18:00	Daily	TBC Shifting for Routine maint. Of A & B isolator	MSETCL	MSETCL	Planned outage
87	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	28-May-22	09:00	28-May-22	18:00	Daily	Premonsoon maintenance work;Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 3 will be in service
88	400 KV	FUTURE CKT - 1 @ WARORA	31-May-22	08:00	31-May-22	17:00	Daily	Routine maintenance and Relay testing work and isolater maintenance work .	MSETCL	MSETCL	IEPL Line charged through Main CB bay no 417.
89	400 KV	DHULE- - BABLESHWAR - I	31-May-22	09:00	31-May-22	17:00	Daily	LBB relay testing work; Bay maintenance work	MSETCL	MSETCL	"400kV Ektuni ckt I and II,400kV Bhusawal, 400kv Aurangabad, 400kV Dhule II will be in service "