

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDCC OCCM for the Month of MAY' 2023

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
1	18	PLANNED	OCC_566	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	C	Online testing of 400KV Bus Bar	1/May/23	08:00	2/May/23	19:00	1) SETCC Vashi instructed to test 400KV Busbar for future 400kv Kharghar-Vikhrol 2nos of 400kv bay provisions 2)All line lines and Transformers will be in service along with its own protection. 3) No any load will be affected.
2	21	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-2	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1/May/23	08:00	3/May/23	18:00	.
3	24	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	PID scanning of insulator strings AR in Non-auto mode	1/May/23	08:00	4/May/23	18:00	Nil
4	28	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Online PID Work 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode during Outage period.	1/May/23	09:00	5/May/23	14:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode during Outage period.
5	29	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Online PID Work 400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.	1/May/23	11:00	5/May/23	14:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.
6	30	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	1/May/23	09:00	6/May/23	17:00	PID Testing of Insulators Auto-Reclose function to be out of service.
7	31	PLANNED	OCC_566	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1) replacement of Hanger assembly of PG isolator by Hot line method of B bus R.Y. Bph 2) All elements of bus 2 will be in service, only hotline work of hanger replacement will be done. .	1/May/23	13:00	6/May/23	17:00	hot line team present on site
8	33	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-PARLI-M-3	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1/May/23	08:00	7/May/23	18:00	.
9	34	PLANNED	OCC_566	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-3	C	1) Replacement of HV side CB under LES scheme. 2) 315MVA ICT -3 in service through TBC on HV side 3) Replacement of 29B bus PG isolator under LES scheme.	1/May/23	09:00	7/May/23	23:00	agency will be present on site.
10	44	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1/May/23	08:00	15/May/23	18:00	only AR required non auto
11	46	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-1 AND PARLI-M - 400KV - BUS 1 at PARLI-M - 400KV	C	For CB foundation work	1/May/23	8:00	20/May/23	17:30	Line will be in Service through TBC. For ongoing project of "Upgradation of 400KV Line Bays (02 Nos) of Parli (PG) & Ill at Parli (MSETCL) from existing current
12	47	PLANNED	OCC_566	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	C	For reconductoring of Moose conductor with HTLS conductor for system improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1.(New Construction works)	1/May/23	7:00	30/May/23	17:00	For Stringing of Kolhapur- Kolhapur#2, outage will require on Kolhapur-Mapusa#1
13	93	PLANNED	OCC_566	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Online changing polymer faulty insulators.	1/May/23	9:00	31/May/23	18:00	AR disable required.
14	94	PLANNED	OCC_566	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	Online changing polymer faulty insulators.	1/May/23	9:00	31/May/23	18:00	AR disable required.
15	95	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-1	D	For PID Work, Shifting of auto reclose switch to non auto mode.	1/May/23	08:00	31/May/23	18:00	.
16	96	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	1/May/23	08:00	31/May/23	18:00	.
17	98	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	On line PID work.During PID 400 kv BBLR-2 AR switch should be kept on non auto mode.	1/May/23	09:00	31/May/23	16:00	400 kv BBLR-2AR switch should be kept on non auto mode.
18	99	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	On line PID work.During PID 400 kv BBLR-1 AR switch should be kept on non auto mode.	1/May/23	09:00	31/May/23	16:00	Only Auto reclose switch required on Non Auto mode
19	100	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/May/23	09:00	31/May/23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
20	101	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/May/23	09:00	31/May/23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
21	102	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/May/23	09:00	31/May/23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
22	103	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/May/23	09:00	31/May/23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
23	104	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	For PID work, Shifting of auto reclose switch to non auto mode	1/May/23	09:00	31/May/23	17:30	-
24	105	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/May/23	09:00	31/May/23	18:00	-
25	106	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/May/23	09:00	31/May/23	18:00	-
26	107	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	1/May/23	11:00	31/May/23	15:00	.
27	115	PLANNED	OCC_566	POWERGRID_WR1	PADGHE-PG - 400KV - BUS 1	C	Interconnection of 400 KV Extension Bus with the existing Bus 1 and HV testing at Padghe GIS.	2/May/23	7:00	6/May/23	17:00	400 KV Bus-1 will be out of service.
28	116	PLANNED	OCC_566	POWERGRID_WR2	TIE BAY - 400KV-VAPI-BOISAR-1 AND 400KV-TARAPUR 3&4-BOISAR-2 at BOISAR - 400KV	D	AMP WORKS	2/May/23	7:00	2/May/23	18:00	PG-WR2-BOISAR
29	120	PLANNED	OCC_566	POWERGRID_WR1	PARLI NEW - 400KV - BUS 2	D	AMP Works of 400KV BUS	2/May/23	7:00	2/May/23	18:00	.
30	155	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Diagnostic testing of Line Current transformer Routine nut bolt tightening by 400kv Koradi 2 substation	2/May/23	08:00	2/May/23	18:00	NA
31	156	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine Maintenance Work & Diagnostic Testing, outage is required on alkud solapur PG line	2/May/23	10:00	2/May/23	18:00	--

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
32	157	PLANNED	OCC_566	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Routine Maintenance Work & Diagnostic Testing ,outage is required on alkud solapur PG line	2/May/23	10:00	2/May/23	18:00	--
33	158	PLANNED	OCC_566	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	C	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works. AR to be kept in non Auto mode for 400KV-CHANDRAPUR-BHADRAWATI-3	2/May/23	7:00	3/May/23	18:00	Group Relay (Self-resetting) retrofitting works at GCR end.
34	159	PLANNED	OCC_566	POWERGRID_WR1	220KV-HAMIDWADA-TALANGADE(MS)-1 & 220KV-BELEWADI-MUDSHINGI-1	D	For Reconductoring work of Kolhapur(PG)- Kolhapur(MSETCL)#2	2/May/23	7:00	3/May/23	18:00	Crossing LI31-LI32
35	164	PLANNED	OCC_566	MSLDC_OUTAGE	KHARGHAR - 400KV - AUXILIARY BUS 1	C	Bus Extension Connection work along with charging of 2 nos of new 400KV Vihitoli Line Bay's at Kharghar(First time Charging).	2/May/23	07:00	4/May/23	18:00	First time Charging under 400 KV Vihitoli receiving station and associated transmission lines for strengthening of
36	168	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	D	Outage is required for PID testing work. Only AR to be kept off. Line to be in service	2/May/23	10:00	6/May/23	18:00	PID testing work
37	169	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of SRN CGL CB at Koradi SS. Line to be shifted on TBC bay	2/May/23	8:00	8/May/23	18:00	
38	171	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	2/May/23	08:00	22/May/23	18:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower hence non auto reqired on both ckt
39	172	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	2/May/23	08:00	22/May/23	18:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower hence non auto reqired on both ckt
40	173	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	C	Dismantling of existing tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor	2/May/23	08:00	31/May/23	18:00	---
41	178	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	FOR LINE BAY 412 LINE SIDE EQUIPMENTS AMP WORK.	3/May/23	10:00	3/May/23	18:00	Line side AMP Works
42	179	PLANNED	OCC_566	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1 LR@ BOISAR - 400KV	D	AMP WORKS	3/May/23	10:00	3/May/23	18:00	PG-WR2-BOISAR
43	183	PLANNED	OCC_566	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-2 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	For Taking Oil sample after first month of charging of 417 R & B Phase CT at Kudus SS.	3/May/23	10:00	3/May/23	18:00	400 KV PADGHE KUDUS LINE 2 WILL BE IN SERVICE THROUGH MAIN BAY 418
44	215	PLANNED	OCC_566	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc	3/May/23	10:00	3/May/23	18:00	-
45	216	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/a maintenance	3/May/23	10:00	3/May/23	18:00	-
46	217	PLANNED	OCC_566	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	D	DGA Test of Current Transformer	3/May/23	10:00	3/May/23	18:00	Bay Outage
47	218	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	3/May/23	10:00	3/May/23	18:00	NA
48	219	PLANNED	OCC_566	MEGPTCL	TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND 400KV-AKOLA-AKOLA (2)-2 at AKOLA (2) - 400KV	D	DGA Test of Current Transformer	3/May/23	10:00	3/May/23	18:00	Bay Outage
266		PLANNED	OCC_566	MSLDC_OUTAGE	Pole-1 Non base AC filter Z4 (80 MVAR) @Chandrapur HVDC (ELEMENT NOT FOUND)	D	To carry out DCRM & Timing of WA Z11 Q3 Breaker	4/May/23	10:00	4/May/23	18:00	Both Pole will be in service with 1500 MW Capacity & Pole #24 will be in Service as per System requirement
49	267	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	4/May/23	10:00	4/May/23	18:00	Line will be charged through Tie CB 428.
50	268	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-LONIKHAND-II-LONIKHAND-1	D	DT Work & Bay Maintenance	4/May/23	10:00	4/May/23	18:00	Nil
51	269	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	PID faulty insulator strings replacement & Half Yearly Maintenance @ Lonikand-II	4/May/23	10:00	4/May/23	18:00	Nil
52	270	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	4/May/23	10:00	4/May/23	18:00	-
53	271	PLANNED	OCC_566	MSLDC_OUTAGE	BUS COUPLER BAY - BHUSAWAL - 400KV - BUS 1 AND BHUSAWAL - 400KV - BUS 2 at BHUSAWAL - 400KV	D	400KV Bus Coupler C.B. compressor overhauling work one by one (main and standby) by agency.	4/May/23	10:00	4/May/23	18:00	As per outage plan.
54	272	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	4/May/23	10:00	4/May/23	18:00	NA
55	274	PLANNED	OCC_566	POWERGRID_WR1	220KV-TALANGADE(MS)-CHIKKODI-II-1 & 220KV- MUDSHINGI-CHIKKODI-II-1	D	For Reconductoring work of Kolhapur(PG)- Kolhapur(MSETCL)#2	4/May/23	10:00	5/May/23	18:00	Crossing 64-65
56	280	PLANNED	OCC_566	TAPS-3&4	400 KV TAPS-3&4 to BOISAR Ckt-1	C	Preventive Maintenance checks. Ckt-2 Air off	4/May/23	10:00	5/May/23	18:00	Sample Remarks
57	287	PLANNED	OCC_566	POWERGRID_WR2	MAIN BAY - 400KV-TARAPUR 3&4-BOISAR-1 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	D	AMP WORKS	5/May/23	7:00	5/May/23	17:30	PG-WR2-BOISAR
58	301	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-I-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	5/May/23	08:00	5/May/23	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
59	302	PLANNED	OCC_566	MEGPTCL	765KV-TIRODA-KORADI-II-1 LR@ KORADI-II - 765KV	D	Annual Maintenance of Reactor.	5/May/23	08:00	5/May/23	18:00	Only Line reactor outage required.
60	303	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1) Bay maint work 2) Replacement of LA of all phase under LES scheme 3) Diagnostic Testing work 4) MTATMC work 5) Replacement of 29C bus PG isolator under LES	5/May/23	09:00	5/May/23	19:00	Agency will be present on site.
61	304	PLANNED	OCC_566	MSLDC_OUTAGE	LONIKHAND - 400KV - TRANSFER BUS 1	C	400KV TBC 29-B PG Isolator mechanism box replacement and trials	5/May/23	08:00	6/May/23	23:30	Nil
62	305	PLANNED	OCC_566	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	D	The following work is planned on HVDC Pole # 1 under Junner, Padghe and Babhaleshwar S-On:- 1) Cold washing of Dust polluted Disc Insulator Strings at Naneghat Section and Samruddhi Highway crossing towers.	5/May/23	23:00	6/May/23	07:00	The HVDC Pole # 2 will be available.
63	306	PLANNED	OCC_566	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	C	1)Bus Extension Connexion work along with charging of 2 nos of new 400KV Vihitoli Line Bay's at Kharghar(First time Charging).	5/May/23	07:00	7/May/23	18:00	1) All Lines & ICT's will be on B bus, load will be shifted via TBC and Buscoupler will be off.
64	307	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	1. Replacement of conductor in span between loc. No. 33 - 34. 2. Replacement of disc type insulator with long rod insulators.	5/May/23	07:00	8/May/23	18:00	If conductor replacement outage would not be approved due to loading, then requested to approve the same for cold washing of insulator strings at night hours on 06.05.2023 and 07.05.2023.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
65	309	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	Replacement of existing conductor by HTLS conductor.	5/May/23	22:00	8/May/23	06:00	Replacement of existing conductor by HTLS conductor.
66	318	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI NEW-PARLI-M-1	D	(1) Bay maintenance work.	6/May/23	10:00	6/May/23	18:00	-
67	320	Planned	OCC_566	GETCO	400KV-SSP-DHULE-MS-1	D	PMM. A/R of 400 kV SSP - Dhule - 2 will remain out	6/May/23	8:00	6/May/23	18:00	Non auto reclose code for 400KV SSP Dhule No 2
68	326	PLANNED	OCC_566	POWERGRID_WR2	TIE BAY - 400KV-TARAPUR 3&4-BOISAR-1 AND 400KV/220KV BOISAR-ICT-2 at BOISAR - 400KV	D	AMP WORKS	6/May/23	7:00	6/May/23	17:30	PG-WR2-BOISAR
69	331	PLANNED	OCC_566	POWERGRID_WR1	TIE BAY - 400KV-CHAKAN-PUNE-PG-1 AND 400KV-KHARGHAR-PUNE-PG-1 at PUNE-PG - 400KV	D	AMP WORK	6/May/23	8:00	6/May/23	18:00	
70	333	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 220KV-AURANGABAD-CHITEGAON-2 AND AURANGABAD - 220KV - BUS 1 at AURANGABAD - 220KV	D	206 AMP works	6/May/23	8:00	6/May/23	18:00	206
71	352	PLANNED	OCC_566	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignosis testing work .	6/May/23	08:00	6/May/23	17:00	Line will be charged through Main CB 429.
72	353	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance and Insulator cleaning work,LBB relay testing	6/May/23	08:00	6/May/23	18:00	400KV Padghe II will be in in service
73	354	PLANNED	OCC_566	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	D	The following work is planned on HVDC Pole # 2 under Junner, Padghe and Babhaleshwar S-On:- 1. Cold line washing of Dust polluted Insulator Strings at Naneghat and Samruddhi Highway crossing lower locations.	6/May/23	23:00	7/May/23	07:00	The HVDC Pole # 1 will be available.
74	356	PLANNED	OCC_566	TAPS-3&4	400 KV TAPS-3&4 to BOISAR Ckt-2	C	Preventive Maintenance checks, Ckt-1 Air off	6/May/23	9:00	7/May/23	19:00	Sample Remarks
75	358	PLANNED	OCC_566	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	D	For Taking Oil sample after first month of charging of 415L R & B Phase Line CT at Kudus SS.	7/May/23	10:00	7/May/23	18:00	400 KV PADGHE KUDUS LINE-1 WILL BE OUT OF SERVICE
76	359	PLANNED	OCC_566	POWERGRID_WR1	400KV-KALWA-PUNE-PG-1	D	AMP WORK	7/May/23	10:00	7/May/23	18:00	Line Owned by MSETCL, Request for MSETCL Concern
77	360	PLANNED	OCC_566	POWERGRID_WR1	AURANGABAD - 400KV - BUS 2	D	Bus AMP Work	7/May/23	7:00	7/May/23	18:00	220KV - BUS-1
78	361	PLANNED	OCC_566	POWERGRID_WR1	220kV Talandage-Sawantwadi (D/C)	D	For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#2	7/May/23	7:00	8/May/23	18:00	L26-L27
79	362	PLANNED	OCC_566	MSLDC_OUTAGE	BUS COUPLER BAY OF NAGOTHANE - 400KV - BUS 1 AND NAGOTHANE - 400KV - BUS 2 @NAGOTHANE - 400KV at NAGOTHANE - 400KV	D	Regular Maint work and Dignosis testing work	7/May/23	8:00	7/May/23	17:00	
80	363	PLANNED	OCC_566	MSLDC_OUTAGE	POLE-2 BASE AC FILTER Z1- Z2(200MVAR) @ CHANDRAPUR HVDC (ELEMENT NOT FOUND)	D	to carry out Breaker CRM which is monitoring (R Ph) of Pole II Z1 & Z2 AC Filter as Circuit Breaker at HVDC Terminal Station, Chandrapu	7/May/23	08:00	7/May/23	14:00	Both Pole will be in service with 850 MW Capacity & Pole I Z1 & Z2 AC Filter will be in Service
81	364	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	1. Chemical cleaning of insulator strings, 2. Replacement of PID detected strings, 3. Spacers installation 4.Installation of SF6 gauge to CB pole. 5.Routine testing work	7/May/23	08:00	7/May/23	18:00	Nil
82	365	PLANNED	OCC_566	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	All diagnostic testing work, and Bay maintenance work.	7/May/23	08:00	7/May/23	18:00	All diagnostic testing work, and Bay maintenance work.
83	366	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	1) Installation of Saver assembly. 2) Line Iso. & B-Bus Iso. alignment work.	7/May/23	09:00	7/May/23	17:00	Simultaneously, outage is required on 220KV Tarapur-Boisar line will be availed for installation of saver assembly and Agency will be present on site.
84	367	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1) Bay Maint work 2) Diagnostic testing work 3) MTAMC work 4) Replacement of 29C Bus PG isolator under LES scheme	7/May/23	09:00	7/May/23	20:00	
85	368	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	Half yearly maintenance	7/May/23	10:00	7/May/23	18:00	Nil
86	369	PLANNED	OCC_566	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	C	To attend the sag correction in tower no. 534, to stop the deforming of tower members in the first section.	7/May/23	08:00	8/May/23	18:00	Line Outage Required
87	370	PLANNED	OCC_566	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	C	Auto recloser kept mode off . To attend the sag correction in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765KV Line.	7/May/23	08:00	8/May/23	18:00	Auto recloser kept mode off
88	371	PLANNED	OCC_566	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	C	Auto recloser kept mode off . To attend the sag correction in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765KV Line.	7/May/23	08:00	8/May/23	18:00	Auto recloser Kept mode off
89	372	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	1) Installation of Saver Assembly. 2) Replacement of rusted hardware and insulator. 3) Control & Relay Panel 220V DC Supply shifting from old charger to new DCDB.	7/May/23	09:00	10/May/23	17:00	1) On dated 07-05-2023, work of installation of saver assembly on both the lines i.e. 220KV Tarapur - Boisar Line & 220KV Boisar - PGCIL Line No. 03 is proposed to be carried out, as the lines
90	373	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-2	D	For PID Work, Shifting of auto reclose switch to non auto mode.	7/May/23	08:00	31/May/23	18:00	.
91	375	PLANNED	OCC_566	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-2 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	D	AMP WORKS	8/May/23	7:00	8/May/23	17:30	PG-WR2-BOISAR
92	376	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	D	Diamond Crossing of Earthwire over 765kV Wardha-Nizamabad Line at Tower No. 07 - 08 (Construction work)	8/May/23	7:00	8/May/23	18:00	
93	377	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-2 (NON-AUTO)	D	Diamond Crossing of Earthwire over 765kV Wardha-Nizamabad Line at Tower No. 07 - 08 (Construction work)	8/May/23	7:00	8/May/23	18:00	
94	383	Planned	OCC_566	GETCO	400KV-SSP-DHULE-MS-2	D	PMM. Auto reclose of 400 kV SSP - Dhule - 1 will remain out	8/May/23	8:00	8/May/23	18:00	Non auto reclose code for 400KV SSP Dhule No 1
95	386	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	AMP WORK	8/May/23	8:00	8/May/23	18:00	
96	410	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	8/May/23	08:00	8/May/23	18:00	400KV Padghe I will be in in service

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
97	411	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at Badnera S/s.	8/May/23	11:00	8/May/23	15:00	.
98	415	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance and Insulator cleaning work	8/May/23	08:00	9/May/23	18:00	400KV Ektuni ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule II will be in in service
99	416	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Replacement of damaged disc insulator, corona ring, damaged nut bolts.	8/May/23	09:00	9/May/23	18:00	400KV Ektuni-Bhabaleshwar ckt-II will be in service
100	420	PLANNED	OCC_566	APML-ADANI	MAIN BAY - 765KV-TIRODA-KORADI-II-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	C	For bay(707-52) breaker SF6 gas leakage attending work.	8/May/23	9:00	10/May/23	18:00	Bay Outage
101	422	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY OF 400KV-LONIKHAND-JEJURI-1 AND LONIKHAND - 400KV - BUS 1 @LONIKHAND - 400KV at LONIKHAND - 400KV	C	400KV CB O/H work by shifting on TBC	8/May/23	08:00	10/May/23	18:00	Line will be in service. Load will be shifted on TBC
102	430	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	Hotline washing work & AR to be disabled	8/May/23	09:00	13/May/23	13:00	Hotline washing work & AR to be disabled
103	431	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	8/May/23	09:00	13/May/23	17:00	PID Testing of Insulators Auto-Reclose function to be out of service.
104	432	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-1	D	Hotline washing work & AR to be disabled	8/May/23	09:00	13/May/23	18:00	Hotline washing work & AR to be disabled
105	436	PLANNED	OCC_566	BDTCL - IndGrid	400KV-DHULE-DHULE-MS-1	D	Line Bays Equipment annual maintenance & Testing	8/May/23	8:00	8/May/23	16:00	
106	438	PLANNED	OCC_566	POWERGRID_WR1	110kV Mudshingi-Dudhganga (S/C)	D	For Reconductoring work of Kohapur(PG)-Kohapur(MSETCL)#2	9/May/23	7:00	10/May/23	18:00	LI16-LI17
107	444	PLANNED	OCC_566	POWERGRID_WR1	PARLI - 220KV - BUS 1	D	For AMP. Each Feeder connected to Bus-1 to be shifted on TBC .	9/May/23	7:00	9/May/23	18:00	AMP OF BUS
108	445	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-2	D	Diamond Crossing of Earthwire over 765kV Wardha-Nizamabad Line at Tower No. 07 - 08 (Construction work)	9/May/23	7:00	9/May/23	18:00	
109	446	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1 (NON-AUTO)	D	Diamond Crossing of Earthwire over 765kV Wardha-Nizamabad Line at Tower No. 07 - 08 (Construction work)	9/May/23	7:00	9/May/23	18:00	
110	476	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	D	Diagnostic testing & allied bay maintenance work	9/May/23	07:00	9/May/23	13:00	Diagnostic testing & allied bay maintenance work
111	477	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	D	Outage is required for Diagnostic testing, Relay testing and maintenance work	9/May/23	09:00	9/May/23	20:00	Diagnostic testing, Relay testing and maintenance work
112	478	PLANNED	OCC_566	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-2	C	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works. AR to be kept in non Auto mode for 400KV-CHANDRAPUR-BHADRAWATI-1	9/May/23	7:00	10/May/23	18:00	Group Relay (Self-resetting) retrofitting works at GCR end.
113	486	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	9/May/23	08:00	10/May/23	18:00	NA
114	495	PLANNED	OCC_566	BDTCL - IndGrid	400KV-DHULE-DHULE-MS-2	D	Line Bays Equipment annual maintenance & Testing	9/May/23	10:00	9/May/23	18:00	
115	509	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Jumper lightning and cold washing work	10/May/23	8:00	10/May/23	17:00	
116	520	PLANNED	OCC_566	POWERGRID_WR2	KALA - 400KV B/R 1	D	AMP WORKS.	10/May/23	9:00	10/May/23	18:00	PG-WR2-KALA
117	536	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Only AR will be in Non Auto for outage on Babhaleshwar-Dhule ckt 1 of Routine Line maintenance and Insulator cleaning work	10/May/23	08:00	10/May/23	18:00	Only AR will be in Non Auto
118	538	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	10/May/23	09:00	10/May/23	17:30	-
119	539	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware Tightening & Fitting Work	10/May/23	09:00	10/May/23	18:00	-
120	540	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	Routine Maint. Work	10/May/23	09:00	10/May/23	18:00	NA
121	541	PLANNED	OCC_566	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	Routine Maint. Work	10/May/23	09:00	10/May/23	18:00	NA
122	542	PLANNED	OCC_566	MSLDC_OUTAGE	JEUR - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	10/May/23	10:00	10/May/23	17:00	Quarterly Maintenance
123	543	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Peak strengthening and Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme (New Construction works)	10/May/23	7:00	11/May/23	18:00	
124	544	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Peak strengthening and Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme (New Construction works)	10/May/23	7:00	11/May/23	18:00	
125	545	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance and Insulator cleaning work	10/May/23	08:00	11/May/23	18:00	400KV Ektuni ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule II will be in in service
126	546	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Replacement of damaged disc insulator, corona ring, damaged nut bolts,	10/May/23	09:00	11/May/23	18:00	400KV Ektuni-Bhabaleshwar ckt-I will be in service
127	550	PLANNED	OCC_566	POWERGRID_WR1	765KV-PUNE-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New Construction works)	10/May/23	7:00	30/May/23	18:00	765 KV PUNE PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
128	551	PLANNED	OCC_566	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New Construction works)	10/May/23	7:00	30/May/23	18:00	765 KV AURANGABAD PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continu ous	Reason	From		To		Remarks
129	563	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Jumper lightning and cold washing work	11/May/23	8:00	11/May/23	17:00	
	566	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For CT Oil Level and Bellows Check Work	11/May/23	8:00	11/May/23	18:00	
131	585	PLANNED	OCC_566	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	11/May/23	08:00	11/May/23	18:00	protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-1/Bus-II Bays, respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays Trippings etc. as per requirement prior to testing. (3) During the outage, On 400KV Bus I, Ckt's connected on Bus I i.e., 400KV Adani ckt- 1 & 2, PGCL-Nagari, IEPL and 400KV Bus Reactor remains charged through their respective Main CBs. No any CB or Isolator will be isolated /opened during the said outage (4) During the outage , On 400KV Bus II, Ckt's connected on Bus II i.e.,400KV Cpur-II ckt-1 & 2 , 400KV Future Line- 1/2 and ICT-1 remains charged through their respective Main CBs. No any CB or Isolator will be isolated /opened during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bay CBs/Isolator will be isolated /opened during the testing works. (6) On completion of 400KV Bus Relay testing work, normal of all NA
132	586	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	11/May/23	08:00	11/May/23	18:00	
133	587	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	11/May/23	08:00	11/May/23	18:00	
134	588	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Only AR will be in Non Auto for outage on Babhaleshwar-Dhule ckt 1 of Routine Line maintenance and Insulator cleaning work	11/May/23	08:00	11/May/23	18:00	Only AR will be in Non Auto
135	589	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Diagonestic testing work (CT Tandelta) & routine maint. work	11/May/23	10:00	11/May/23	16:00	-
136	593	PLANNED	OCC_566	APML-ADANI	TIE BAY OF 765KV/21KV TIRODA-GT-4 AND 765KV/400KV TIRODA-ICT-1 @TIRODA - 765KV at TIRODA - 765KV	C	For bay(702-52) breaker SF6 gas leakage attending work.	11/May/23	9:00	12/May/23	18:00	Bay Outage
137	600	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-PARLI-M-3	D	For PID Work, Shifting of auto reclose switch to non auto mode.	11/May/23	08:00	31/May/23	18:00	
138	606	PLANNED	OCC_566	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	D	AMP WORKS. DIA TO BE KEPT OPEN.	12/May/23	7:00	12/May/23	17:30	PG-WR2-BOISAR
139	608	PLANNED	OCC_566	POWERGRID_WR1	PARLI - 220KV - BUS 2	D	For AMP. Each Feeder connected to Bus-I to be shifted on TBC .	12/May/23	7:00	12/May/23	18:00	AMP OF BUS
140	609	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	Insulator replacement work, Jumper Rectification at Loc no 186 & Aerial patrolling defect rectification	12/May/23	7:00	12/May/23	18:00	
141	610	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AKOLA-2 (NON-AUTO)	D	Insulator replacement work, Jumper Rectification at Loc no 186 & Aerial patrolling defect rectification	12/May/23	7:00	12/May/23	18:00	
142	625	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-KALWA-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For CT Oil Level and Bellows Check Work	12/May/23	8:00	12/May/23	18:00	
143	643	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	12/May/23	08:00	12/May/23	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
144	644	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	12/May/23	08:00	12/May/23	18:00	NA
145	645	PLANNED	OCC_566	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-3	C	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works. AR to be kept in non Auto mode for 400KV-CHANDRAPUR-BHADRAWATI-4	12/May/23	7:00	13/May/23	18:00	Group Relay (Self-resetting) retrofitting works at GCR end.
146	646	PLANNED	OCC_566	MSLDC_OUTAGE	BUS COUPLER BAY - LONKHAND - 400KV - BUS 1 AND LONKHAND - 400KV - BUS 2 at LONKHAND - 400KV	C	400KV Bus Coupler 29-A & 29-B PG Isolator mechanism box replacement and trials	12/May/23	08:00	13/May/23	23:30	Nil
147	647	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Cold line washing of dust polluted Disc insulator strings at Naneghat section and Samrudhi Highway crossing towers.	12/May/23	23:00	13/May/23	07:00	The 400KV Babhaleshwar-Padghe ckt-2 will be available.
148	648	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	1. Replacement of conductor in span between loc. No. 33 - 34, 2. Replacement of discs type insulator with long rod insulators.	12/May/23	07:00	15/May/23	18:00	If conductor replacement outage would not be approved due to loading, then requested to approve the same for cold washing of insulator strings at night hours on 13.05.2023 and 14.05.2023.
149	649	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	Replacement of existing conductor by HTLS conductor	12/May/23	22:00	15/May/23	06:00	Replacement of existing conductor by HTLS conductor
150	651	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY OF 400KV-PADGHE HVDC-PADGHE-1 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1) Replacement of old Bhel make Quad CB with new siemens Quad CB 2) A & B bus PG isolator maint work 3) 400KV HVDC-1 in service through TBC . Power restriction of 1300MW	12/May/23	08:00	28/May/23	22:00	M/s siemens team will present on site .
151	652	PLANNED	OCC_566	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment.	13/May/23	7:00	13/May/23	17:00	400 KV Padghe Tarapur Line 2 will be out of service.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
152	656	PLANNED	OCC_566	TAPS-3&4	400 KV TAPS-3&4 to PADGHE Ckt-2	C	Preventive Maintenance checks, Ckt-1 Air off	13/May/23	9:00	14/May/23	19:00	Sample Remarks
153	658	PLANNED	OCC_566	POWERGRID_WR1	AURANGABAD - 400KV - BUS 1	D	Bus AMP Work	13/May/23	7:00	13/May/23	18:00	400KV - BUS-1
154	659	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	Insulator replacement work & Aerial patrolling defect rectification	13/May/23	7:00	13/May/23	18:00	
155	660	PLANNED	OCC_566	POWERGRID_WR1	400KV-WARDHA-AKOLA-1 (NON-AUTO)	D	Insulator replacement work & Aerial patrolling defect rectification	13/May/23	7:00	13/May/23	18:00	
156	680	PLANNED	OCC_566	MSLDC_OUTAGE	CHANDRAPUR HVDC - 400KV - TRANSFER BUS 1	D	to carry out CT tan delta which is under monitoring due increase in tan delta of Tie Bay Y Phase CT at HVDC Terminal Station, Chandrapur	13/May/23	08:00	13/May/23	14:00	Both Pole will be in service with 1500 MW Capacity without Tie Bay in service
157	682	PLANNED	OCC_566	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 2	C	Bus Extension Connection work along with charging of 2 nos of new 400KV Vikhroli Line Bay's at Kharghar(First time Charging).	13/May/23	07:00	14/May/23	18:00	1) All Lines & ICT's will be on B bus, load will be shifted via TBC and Bus coupler will be off. 2) First time Charging under 400 KV Vikhroli receiving station and associated transmission lines for strengthening of Mumbai Transmission System
158	683	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	C	CB Maint. Work by shifting the line on TBC.	13/May/23	10:00	14/May/23	17:00	1) Line will be in Service through TBC Breaker. 2) 220KV Boisar - Versova Line HT will be required for load relief as TBC bay has CTR 800/1A.
159	684	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Cold line washing of dust polluted Disc Insulator strings at Naneghat section and Samruddhi Highway crossing towers.	13/May/23	23:00	14/May/23	07:00	The 400KV Babhaleshwar-Padghe Ckt-1 will be available.
160	686	PLANNED	OCC_566	POWERGRID_WR2	220KV-BOISAR-NALASOPARA-1	D	AMP WORKS	14/May/23	7:00	14/May/23	17:30	PG-WR2-BOISAR
161	687	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For replacement of PID Suspecious string, Cold line washing & Missing Hardware replacement work.400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode during Outage period.	14/May/23	08:00	18/May/23	18:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode during Outage period.
162	691	PLANNED	OCC_566	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 2	D	Regular Maint work and Dignostic testing work	14/May/23	8:00	14/May/23	17:00	
163	692	PLANNED	OCC_566	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1(TAKEN ON TBC AT 400KV CHANDRAPUR SS)	D	to carry out CT tan delta which is under monitoring due increase in tan delta of Pole I Converter bay R Ph CT	14/May/23	08:00	14/May/23	14:00	Both Pole will be in service through Tie Bay with 950 MW capacity restriction due to constraint from 400 KV GCR, Chandrapur as only HVDC Ckt II will be avilable
164	693	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	1) BAY STRENGTHING WORK. 2)OVER VOLTAGE RELAY REPLACEMENT 3)Routine Maintenance Work (AMP)	14/May/23	08:00	14/May/23	18:00	400KV Talegaon Line will be in service
165	694	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	14/May/23	08:00	14/May/23	18:00	400KV Padghe I will be in in service
166	695	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	Routine Maintenance & Insulator cleaning work.	14/May/23	08:00	14/May/23	18:00	Routine Maintenance & Insulator cleaning work.
167	696	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	All diagnostic testing work, and Bay maintenance work.	14/May/23	08:00	14/May/23	18:00	All diagnostic testing work, and Bay maintenance work.
168	697	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-BOISAR-NALASOPARA-1	D	1) Replacement of Broken Insulator Strings. 2) Pre-Monsoon Maintenance Work.	14/May/23	09:00	14/May/23	17:00	1) Replacement of Broken Insulator Strings. 2) Pre-Monsoon Maintenance Work.
169	698	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) Reactor testing work. (2) Bay maintenance work.	14/May/23	09:00	14/May/23	18:00	-
170	699	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-I&2	C	1. Measurement of tandelta of CVT. 2. Bay routine maintenance work.	14/May/23	08:00	15/May/23	18:00	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No- 1, 400KV Chandrapur-Parli CKT-3, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadravali Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service.
171	701	PLANNED	OCC_566	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1	D	For Line ISO Contact and WT Clamp tightness work	14/May/23	7:00	14/May/23	18:00	Kept 400KV-PUNE-GIS-PUNE-PG-2 in Non Auto Mode (Line Owned By ADANI Trans)
172	702	PLANNED	OCC_566	POWERGRID_WR1	PARLIAM - 400KV - BUS 1	D	For dismantling of 88A Isolator of 400KV-PARLI-M-PARLI-1	14/May/23	7:00	14/May/23	19:30	For ongoing project of "Upgradation of 400KV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS"
173	739	PLANNED	OCC_566	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Changeover of Spare Line Reactor with B-ph Reactor at Ektuni SS as per CEA guideline	15/May/23	10:00	15/May/23	14:00	Non-Switchable Reactor at Ektuni SS. So Line Outage Required
174	747	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-AKOLA-NANDGAONPETH-1	D	String replacement work on 400 KV Akola- Nandgaonpeth Line will be carried out by engaging agency which are detected punctured in PID testing.	15/May/23	06:00	17/May/23	18:00	String replacement work on 400 KV Akola- Nandgaonpeth Line will be carried out by engaging agency which are detected punctured in PID testing.
175	748	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY OF 400KV-KOYNA STAGE IV- LONIKHAND-1 AND LONIKHAND - 400KV - BUS 1 @LONIKHAND - 400KV at LONIKHAND - 400KV	C	400KV CB OH work by shifting on TBC	15/May/23	08:00	17/May/23	18:00	Line will be in service. Load will be shifted on TBC
176	750	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Online PID Work.400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode during Outage period.	15/May/23	09:00	19/May/23	14:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode during Outage period.
177	751	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Online PID Work.400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.	15/May/23	11:00	19/May/23	14:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.
178	755	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	PID Testing of Insulators Auto-Restore function to be out of service.	15/May/23	09:00	20/May/23	17:00	PID Testing of Insulators Auto-Restore function to be out of service.
179	756	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	D	Hotline washing work & AR to be disabled	15/May/23	09:00	20/May/23	18:00	Hotline washing work & AR to be disabled

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continu ous	Reason	From		To		Remarks
180	757	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-2	D	Hotline washing work & AR to be disabled	15/May/23	09:00	20/May/23	18:00	Hotline washing work & AR to be disabled
181	765	PLANNED	OCC_566	POWERGRID_WR1	220KV-PARLI-HARANGUL-1	D	For AMP and relay testing works	16/May/23	7:00	16/May/23	18:00	AMP OF LINE CKT
182	800	PLANNED	OCC_566	MSLDC_OUTAGE	KORADI - 400KV - BUS 1	D	For measurement of CVT TAN Delta	16/May/23	06:00	16/May/23	21:00	Outages will be availed subject to weather & site conditions.
183	801	PLANNED	OCC_566	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-1	C	Group Relay (Self-resetting) retrofitting works at GCR end. Line TLM Works. AR to be kept in non Auto mode for 400KV-CHANDRAPUR-BHADRAWATI-2	16/May/23	7:00	17/May/23	18:00	Group Relay (Self-resetting) retrofitting works at GCR end.
184	804	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	C	For carrying out Premonsoon maintenance activities	16/May/23	21:00	17/May/23	06:00	Nil
185	806	PLANNED	OCC_566	MSLDC_OUTAGE	TIE BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND FUTURE @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	C	Circuit Breaker Overhauling by M/s CGL	16/May/23	11:00	19/May/23	18:00	Circuit Breaker Overhauling by M/s CGL through agency
186	808	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	PID work, AR to be disabled. Line will be in service.	16/May/23	08:00	31/May/23	18:00	-
187	836	PLANNED	OCC_566	MSLDC_OUTAGE	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	D	Diagnostic testing & Relay testing work, Routine maint. Work & Pre-Monsoon maintenance	17/May/23	08:00	17/May/23	17:00	---
188	837	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Chemical cleaning and bay maintenance work	17/May/23	08:00	17/May/23	18:00	400KV Ektuni ckt II,400KV Bhusawal,400kv Aurangabad and Dhule I& II. It will be in in service
189	838	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	17/May/23	09:00	17/May/23	17:30	-
190	839	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and washing	17/May/23	09:00	17/May/23	18:00	Load will be managed on 400kv lamboli-PGCI line
191	840	PLANNED	OCC_566	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	Routine Maint. Work	17/May/23	09:00	17/May/23	18:00	NA
192	842	PLANNED	OCC_566	MEGPTCL	TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND 400KV-AKOLA-AKOLA (2)-1 at AKOLA (2) - 400KV	D	DGA Test of Current Transformer	17/May/23	10:00	17/May/23	13:00	Bay outage required
193	843	PLANNED	OCC_566	MEGPTCL	TIE BAY - 765KV/400KV AKOLA (2)-ICT-1 AND 400KV-AKOLA (2)-FUTURE-5 at AKOLA (2) - 400KV	D	DGA Test of Current Transformer	17/May/23	15:00	17/May/23	17:00	Bay Outage required
194	852	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of CB with new Siemens make Quad CB along with its commissioning and testing. *400KV HVDC CKT-1* will be in service via 400KV TBC-2.	17/May/23	08:00	31/May/23	18:00	400KV HVDC CKT-1 will be in service via 400KV TBC-2.
195	891	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-LONKHAND-PUNE-PG-1	D	1. Cold washing of insulator, 2. PID Detected strings replacement	18/May/23	08:00	18/May/23	18:00	Nil
196	892	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	18/May/23	08:00	18/May/23	18:00	-
197	893	PLANNED	OCC_566	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	D	DGA Test of Current Transformer	18/May/23	10:00	18/May/23	12:00	Bay Outage required.
198	894	PLANNED	OCC_566	MSLDC_OUTAGE	EKTUNI - 765KV B/R 1	D	Diagnostic Testing & Routine Maintenance	18/May/23	10:30	18/May/23	18:00	The Bus Reactor will be out of service
199	895	PLANNED	OCC_566	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	DGA Test of Current Transformer	18/May/23	14:00	18/May/23	16:00	Bay outage required
200	900	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Re stringing work of Earth wire,Chemical cleaning and bay maintenance work	18/May/23	08:00	19/May/23	18:00	400KV Ektuni ckt I,400KV Bhusawal,400kv Aurangabad and Dhule I& II. It will be in in service
201	901	PLANNED	OCC_566	MSLDC_OUTAGE	400KV/220KV DHULE-MS-ICT-3	C	RRS scheme work and pre-monsoon activity	18/May/23	09:00	19/May/23	19:00	During the outage period 501MVA ICT-2 & 315MVA ICT-1 is in service
202	908	PLANNED	OCC_566	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	AMP WORKS. DIA TO BE KEPT OPEN.	19/May/23	7:00	19/May/23	17:30	PG-WR2-BOISAR
203	914	PLANNED	OCC_566	POWERGRID_WR1	TIE BAY - 400KV-KOLHAPUR GIS -BUS REACTOR AND 400KV-KOLHAPUR GIS-Kolhapur -2 at Kolhapur GIS - 400KV	D	Bay AMP	19/May/23	8:00	19/May/23	17:00	411 Bay
204	933	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Diagnostic testing work .	19/May/23	09:00	19/May/23	17:00	400KV WARORA-IEPL Line is in ckt
205	934	PLANNED	OCC_566	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	D	DGA Test of Current Transformer	19/May/23	10:00	19/May/23	12:00	Bay outage required
206	935	PLANNED	OCC_566	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-3(SPARE ICT UNIT)	D	Diagnostic Testing & Routine Maintenance	19/May/23	10:30	19/May/23	18:00	The Spare ICT is hot Standby, hence on No load.
207	936	PLANNED	OCC_566	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	DGA Test of Current Transformer	19/May/23	14:00	19/May/23	16:00	Bay Outage required
208	941	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Routine Maintenance Work & Diagnostic testing	20/May/23	10:00	20/May/23	18:00	Load will be managed on 400KV Alkud-Talande line
209	958	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	20/May/23	08:00	20/May/23	18:00	400KV Padghe I will be in in service
210	959	PLANNED	OCC_566	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	DGA Test of Current Transformer	20/May/23	10:00	20/May/23	12:00	Bay outage required
211	960	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For replacement of PID Suspectious string, Cold line washing & Missing Hardware replacement work,400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.	20/May/23	08:00	24/May/23	18:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode during Outage period.
212	961	PLANNED	OCC_566	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line terminal equipments AMP at 765KV Solapur Substation	21/May/23	7:00	21/May/23	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
213	962	PLANNED	OCC_566	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2 LR@ SOLAPUR - 400KV	D	Line Reactor AMP & PRD oil leakage attending works at 755KV Solapur Substation.	21/May/23	7:00	21/May/23	18:00	
214	963	PLANNED	OCC_566	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	D	AMP of Line Equipment and Oil Sampling of Line CT.	21/May/23	7:00	21/May/23	17:00	400 KV Padghe Tarapur Line 1 will be out of service.
215	964	PLANNED	OCC_566	POWERGRID_WR1	PARLI-M - 400KV - BUS 2	D	For dismantling of 80B Isolator of 400KV-PARLI-M-PARLI-1	21/May/23	7:00	21/May/23	19:30	For ongoing project of "Upgradation of 400KV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS"
216	969	PLANNED	OCC_566	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 1	D	Regular Maint work and Dignostic testing work	21/May/23	8:00	21/May/23	17:00	
217	971	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Hardware tieghting and washing	21/May/23	09:00	21/May/23	18:00	load will be managed on 400kv parli-karjat 2
218	972	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Diagnostic testing work .	21/May/23	09:00	21/May/23	18:00	400 KV WARORA - DEOLI 2 Line is in ckt
219	973	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	1) Bay Maint work 2) Replacement of old CT with New CT having ratio of 3000/1A 3) Diagnostic Testing Work 4)MTA/MC work 5) Replacement of 29C bus PG isolator under LES scheme	21/May/23	09:00	21/May/23	19:00	Agency will be present on site
220	974	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	1) Diagnostic Testing work 2) Replacement of Over voltage relay 3) Bay Maint work 4)MTA/MC work 5)Replacement of 29C Bus PG isolator under LES scheme .	21/May/23	09:00	21/May/23	20:00	Agency will be present on site .
221	978	PLANNED	OCC_566	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Routine Maintenance Work & Diagnostic Testing	22/May/23	10:00	22/May/23	17:00	-
222	979	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine Maintenance Work & Diagnostic Testing	22/May/23	10:00	22/May/23	17:00	-
223	980	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Routine Maintenance Work & Diagnostic Testing	22/May/23	10:00	22/May/23	17:00	Load will be managed on 400KV Solapur- Alkud Line
224	981	PLANNED	OCC_566	POWERGRID_WR2	BUS COUPLER BAY - BOISAR - 220KV - BUS 1 AND BOISAR - 220KV - BUS 2 at BOISAR - 220KV	D	AMP WORKS	22/May/23	7:00	22/May/23	17:30	PG-WR2-BOISAR
225	1017	PLANNED	OCC_566	APML-ADANI	MAIN BAY - 400KV-TIRODA-WARORA-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	C	For line main bay breaker ercing contact inspection and testing work	22/May/23	9:00	24/May/23	18:00	Bay Outage
226	1018	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY OF 400KV-LONIKHAND-JEJURI-2 AND LONIKHAND - 400KV - BUS 1 @LONIKHAND - 400KV at LONIKHAND - 400KV(ELEMENT NOT FOUND)	C	400kv CB O/H work by shifting on TBC	22/May/23	08:00	24/May/23	18:00	Line will be in service. Load will be shifted on TBC
227	1019	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID Testing of Insulators Auto-Restose function to be out of service.	22/May/23	08:00	24/May/23	18:00	Nil
228	1023	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	PID Testing of Insulators Auto-Restose function to be out of service.	22/May/23	09:00	27/May/23	17:00	PID Testing of Insulators Auto-Restose function to be out of service.
229	1028	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI NEW-PARLI-M-2	D	(1) Main-1 distance relay testing work. (2) Bay maintenance work.	23/May/23	09:00	23/May/23	18:00	-
230	1029	PLANNED	OCC_566	POWERGRID_WR2	MAIN BAY - 220KV-TARAPUR 3&4-BOISAR-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP WORKS. LINE WILL REMAIN IN SERICE THROUGH TBC BAY.	23/May/23	7:00	23/May/23	17:30	PG-WR2-BOISAR
231	1061	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance and Insulator cleaning work	23/May/23	08:00	23/May/23	18:00	400kv Ekturi ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule I will be in in service
232	1062	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Only AR will be in Non Auto for ouage on Babhaleshwar-Dhule ckt 2 Routine Line maintenance and Insulator cleaning work	23/May/23	08:00	23/May/23	18:00	Only AR will be in Non Auto
233	1065	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	For carrying out Premonsoon maintenance activities	23/May/23	21:00	24/May/23	06:00	Nil
234	1067	PLANNED	OCC_566	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	C	Circuit Breaker Overhauling by M/s CGL	23/May/23	11:00	26/May/23	18:00	Circuit Breaker Overhauling by M/s CGL through agency
235	1076	PLANNED	OCC_566	POWERGRID_WR1	PARLI - 400KV - BUS 2	D	For AMP	24/May/23	7:00	24/May/23	18:00	AMP OF BUS
236	1087	Planned	OCC_566	GETCO	220KV-NASK-NAVSARI-2	D	Routine bay maintenance & line maintenance	24/May/23	9:00	24/May/23	17:00	
237	1099	PLANNED	OCC_566	APTCL	400KV-AKOLA (2)-NANDGAONPETH-1	D	Outage required for routine maintenance and per-monsoon activity of 400kv RPL to Akola II Line I.	24/May/23	06:00	24/May/23	16:00	Outage required for routine maintenance and per-monsoon activity of 400kv RPL to Akola II Line I.
238	1100	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance and Insulator cleaning work	24/May/23	08:00	24/May/23	18:00	400kv Ekturi ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule II will be in in service
239	1101	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Only AR will be in Non Auto for outage on Babhaleshwar-Dhule ckt 1 of Routine Line maintenance and Insulator cleaning work	24/May/23	08:00	24/May/23	18:00	Only AR will be in Non Auto
240	1102	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	24/May/23	09:00	24/May/23	18:00	-
241	1103	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	String replacement Hardware tieghting and washing	24/May/23	09:00	24/May/23	18:00	Load will be managed on 200kv lamdhuni-malingar line
242	1104	PLANNED	OCC_566	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	24/May/23	09:00	24/May/23	18:00	NA
243	1108	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	C	Restringing of Conductor between Loc No 90-93 Due to low sag clearance	24/May/23	08:00	25/May/23	17:00	Restringing of Conductor between Loc No 90-93 Due to low sag clearance

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
244	1112	PLANNED	OCC_566	WTPL	220KV-SOLAPUR-JEUR-1	D	Annual maintenance of Lamboti line.	24/May/23	9:00	24/May/23	18:00	AR disable required.
245	1143	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-AKOLA-NANDGAONPETH-1	D	1. pre-monsoon maintenance work 2. Diagnostic testing work 3. isolator maintenance Work	25/May/23	07:00	25/May/23	14:00	Bhusawal ckt will be in service
246	1144	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-1	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	25/May/23	08:00	25/May/23	17:00	For PID Testing Work,shifting autoreclose switch to Non auto Mode .
247	1145	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	25/May/23	08:00	25/May/23	18:00	.
248	1146	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) Main-1 distance relay testing work. (2) Bay maintenance work.	25/May/23	09:00	25/May/23	18:00	.
249	1152	PLANNED	OCC_566	APML-ADANI	MAIN BAY - 400KV-TIRODA-WARORA-2 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	C	For line main bay breaker arcing contact inspection and testing work	25/May/23	9:00	27/May/23	18:00	Bay Outage
250	1183	PLANNED	OCC_566	APTCL	400KV-AKOLA (2)-NANDGAONPETH-2	D	Outage required for routine maintenance and per-monsoon activity of 400kV RPL to Akola II Line II.	26/May/23	06:00	26/May/23	16:00	Outage required for routine maintenance and per-monsoon activity of 400kV RPL to Akola II Line II.
251	1184	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	26/May/23	08:00	26/May/23	17:00	---
252	1185	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	26/May/23	08:00	26/May/23	17:00	For PID Testing Work,shifting autoreclose switch to Non auto Mode .
253	1187	PLANNED	OCC_566	MSLDC_OUTAGE	TIE BAY - 400KV-EKTUNI-BABLESHWAR-2 AND 765KV/400KV EKTUNI-CT-1 at EKTUNI - 400KV	D	Diagnostic Testing of CB, CT & Routine Maintenance	26/May/23	10:30	26/May/23	18:00	400KV Bhabaleshwar Ckt-II will be in service through its Main (408) Bay & Main Bus-I
254	1189	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	C	Resting of Conductor between Loc No 90-93 Due to low sag clearance	26/May/23	08:00	27/May/23	17:00	Resting of Conductor between Loc No 90-93 Due to low sag clearance
255	1190	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	C	For carrying out Premonsoon maintenance activities	26/May/23	21:00	27/May/23	06:00	Nil
256	1192	PLANNED	OCC_566	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1) Replacement of Hanger Assembly of B bus PG isolator of all phase by Hot line method .All elements on Bus 2 will be in service, only hanger rods will be replaced by hot line method	26/May/23	11:00	3/Jun/23	16:00	Hot line team will be present on site.
257	1193	PLANNED	OCC_566	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-2	C	1) Replacement of HV CB under LES scheme 2) ICT will be in service through TBC 3) Replacement of 29B bus PG isolator under LES scheme	26/May/23	08:00	4/Jun/23	21:00	1) Agency will be present on site
258	1209	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual maintenace.	27/May/23	9:00	27/May/23	18:00	line shut down required
259	1210	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual maintenance of circuit - III.	27/May/23	9:00	27/May/23	18:00	AR disable required.
260	1211	PLANNED	OCC_566	POWERGRID_WR2	MAIN BAY - 400KV/220KV BINA-ICT-1 AND BINA - 400KV - BUS 2 at BINA - 400KV	D	For AMP work.	27/May/23	9:15	27/May/23	18:00	PG-WR2-BINA
261	1213	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-2	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	27/May/23	08:00	27/May/23	17:00	400 KV switching ckt 1 & 400 KV switching ckt 2 on same D/C tower hence non auto required on both ckt
262	1214	PLANNED	OCC_566	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	CVT C and tanD testing	27/May/23	08:00	27/May/23	18:00	Feeders and ICTS from Bus I will be shifted to Bus II through TBC
263	1215	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1)Removing of Bunching work for ERS-3. Normalization of circuit. 2) Routine Maintenance & Insulator cleaning work	27/May/23	08:00	27/May/23	18:00	400KV PADGHE - KALWA CKT - 1 was proposed to be diverted in April-2023 on 400KV Kalwa-Padgha-2 line for HTLS of 400KV Kalwa-Padgha-1 line in its dead
264	1216	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	27/May/23	08:00	27/May/23	18:00	.
265	1217	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-1	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	27/May/23	08:00	27/May/23	19:00	400 KV switching ckt 1 & 400 KV switching ckt 2 on same D/C tower hence non auto required on both ckt
266	1218	PLANNED	OCC_566	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For SF6 Gas Leak Attend Work	28/May/23	7:00	28/May/23	18:00	207L Talegaon Line 2 Bay will be shift to 204 Transfer Bus Coupler Bay before Shutdown of Line
267	1222	PLANNED	OCC_566	MSLDC_OUTAGE	NAGOTHANE - 400KV - TRANSFER BUS 1	D	Regular Maint work and Dignostic testing work	28/May/23	8:00	28/May/23	17:00	
268	1223	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual maintenace.	28/May/23	9:00	28/May/23	18:00	Line shut down required
269	1224	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual maintenance of circuit - IV.	28/May/23	9:00	28/May/23	18:00	AR disable required.
270	1225	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Routine Maintenance & Insulator cleaning work	28/May/23	08:00	28/May/23	18:00	Routine Maintenance & Insulator cleaning work
271	1226	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	Removing of Bunching work for ERS-3. Normalization of circuit.	28/May/23	08:00	28/May/23	18:00	400KV PADGHE - KALWA CKT - 2 was proposed to be diverted in April-2023 on Dead line i.e 400KV Padgha-Kharghar line to facilitate diversion of 400KV Kalwa-Padgha-1 on dead portion of Ckt-2 for HTLS of 400KV Kalwa-Padgha-1 line. After completion of proposed work Ckt-2 to be normalized.
272	1227	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	28/May/23	08:00	28/May/23	18:00	.
273	1228	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware teightning and washing	28/May/23	09:00	28/May/23	18:00	Load will be managed on 400kv parli-karjat 1
274	1229	PLANNED	OCC_566	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance	28/May/23	10:00	28/May/23	18:00	Nil
275	1234	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual maintenace.	29/May/23	9:00	29/May/23	18:00	Line shut down required
276	1235	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual maintenace of circuit - II.	29/May/23	9:00	29/May/23	18:00	AR disable required.
277	1236	PLANNED	OCC_566	POWERGRID_WR2	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	D	AMP WORKS.LINE WILL REMAIN IN SERVICE THROUGH TBC BAY.	29/May/23	7:00	29/May/23	17:30	PG-WR2-BOISAR

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
278	1240	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR GIS-MAPUSA-2 at Kolhapur GIS - 400KV	D	Bay AMP	29/May/23	8:00	29/May/23	17:00	403 Bay
279	1254	PLANNED	OCC_566	WTPL	400KV-KARAD-SOLAPUR-1	D	Annual maintenance	29/May/23	9:00	29/May/23	18:00	Line shut down required
280	1259	PLANNED	OCC_566	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Changeover of B-ph Line Reactor with Spare Reactor as per CEA guideline at Akola SS	29/May/23	08:00	29/May/23	14:00	Only Reactor outage is required for changeover, since separate reactor outage is not provided line outage is proposed
281	1260	PLANNED	OCC_566	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1 L/R@ AKOLA (2) - 765KV	D	Changeover of B-ph Line Reactor with Spare Reactor as per CEA guideline at Akola SS	29/May/23	08:00	29/May/23	14:00	Switchable Line Reactor
282	1262	PLANNED	OCC_566	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode.	29/May/23	09:00	29/May/23	17:00	.
283	1264	PLANNED	OCC_566	MSLDC_OUTAGE	400KV/220KV LONIKHAND-ICT-1	C	400KV ICT-1 29-B PG Isolator mechanism box replacement and trials by shifting on TBC	29/May/23	08:00	30/May/23	23:30	ICT-1 will be in service. Load will be shifted on TBC
284	1270	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	For PID Testing Work,shifting autoreclose switch to Non auto Mode.	29/May/23	08:00	31/May/23	19:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower hence non auto reqired on both ckt
285	1271	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	29/May/23	09:00	31/May/23	17:00	PID Testing of Insulators Auto-Reclose function to be out of service.
286	1274	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual maintenace.	30/May/23	9:00	30/May/23	18:00	Line shut down required
287	1275	PLANNED	OCC_566	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual maintenace of circuit - L	30/May/23	9:00	30/May/23	18:00	AR disable required.
288	1276	PLANNED	OCC_566	POWERGRID_WR2	MAIN BAY OF 220KV-BOISAR-BORIVALI-1 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	D	AMP WORKS.LINE WILL REMAIN IN SERVICE THROUGH TBC BAY	30/May/23	7:00	30/May/23	17:30	PG-WR2-BOISAR
289	1289	PLANNED	OCC_566	POWERGRID_WR1	TIE BAY - 400KV-BHADRAWATI-PARLI-1 AND 400KV-CHANDRAPUR-BHADRAWATI-3 at BHADRAWATI - 400KV	D	Bay AMP works	30/May/23	8:00	30/May/23	18:00	Bay AMP works
290	1290	PLANNED	OCC_566	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV - BUS 1B at Wardha - 400KV	D	For Amp of Bay	30/May/23	8:00	30/May/23	18:00	
291	1301	PLANNED	OCC_566	MEGPTCL	765KV-TIRODA-KORADI-II-2 L/R@ KORADI-II - 765KV	D	Annual Maintenance of Reactor.	30/May/23	08:00	30/May/23	18:00	Only Line reactor outage required.
292	1320	PLANNED	OCC_566	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tieghning and washing	31/May/23	09:00	31/May/23	18:00	load will be managed on 400kv lambol-Parli line

State Element outage list for the month of MAY'2023

	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	CHANDRAPUR - KHAPERKHEDA	01-May-23	08:00	20-May-23	18:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	NA
2	400 KV	KARAD - TALANDGE CKT - 1	02-May-23	09:00	02-May-23	20:00	Daily	1. C bus isolator overhauling work. 2. Quarterly maintenance work.	MSETCL	MSETCL	400 kV Kolhapur- Karad ckt 2 will be in service.
3	400 KV	MAIN BAY (407) OF RPL CKT-1 @ AKOLA 2	02-May-23	14:00	02-May-23	16:00	Daily	DGA Test of Current Transformer	MEGPTCL	MEGPTCL	Bay Outage
4	400 KV	MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2	02-May-23	10:00	02-May-23	12:00	Daily	DGA Test of Current Transformer	MEGPTCL	MEGPTCL	Bay Outage requited
5	400 KV	CHANDRAPUR - KHAPERKHEDA	02-May-23	08:00	22-May-23	17:00	Daily	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	MSETCL	MSETCL	For PID Testing Work,shifting autoreclose switch to Non auto Mode .
6	400 KV	BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR	03-May-23	08:00	03-May-23	20:00	Daily	Faulty leakage PRV replacement	MSETCL	MSETCL	Reactor I is off during day hours
7	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	03-May-23	08:00	03-May-23	17:00	Daily	Pre-monsoon maintenance	MSETCL	MSETCL	NA
8	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	03-May-23	10:00	03-May-23	18:00	Daily	Diagnostic Testing Work.	MSETCL	MSETCL	Without Load interruption. Load will be managed on ICT I.
9	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	04-May-23	10:30	04-May-23	18:00	Daily	Premonsoon Maintenance of ICT	MSETCL	MSETCL	-
10	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	04-May-23	09:30	04-May-23	18:00	Daily	For Pre-Monsoon Maintenance & Testing work	MSETCL	MSETCL	During outage ICT 2 & ICT 3 will be in service.
11	400 KV	KHADKA - BABLESHWAR	04-May-23	08:00	04-May-23	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad , Dhule I&II will be in in service
12	400 KV	KORADI II - IEPL	04-May-23	08:00	04-May-23	16:00	Daily	Diagnostic testing of Line Current transformer Routine nut bolt tightening	MSETCL	MSETCL	400kV Koradi-II -Wardha (PG) Ckt. Will remain in service.
13	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	04-May-23	08:00	06-May-23	18:00	Daily	For replacement of polymer Insulator string	MSETCL	MSETCL	-
14	400 KV	BUS REACTOR (125MVA) @ WARORA	04-May-23	08:00	04-May-23	17:00	Daily	Routine and Premonsoon maintenance work.	MSETCL	MSETCL	Reactor kept in OFF position.,Tie Bay No. 403 also kept in OFF position.
15	400 KV	JEJURI- KOYNA STAGE-IV	04-May-23	08:00	04-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
16	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	05-May-23	08:00	05-May-23	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad , Dhule I&II will be in in service
17	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	05-May-23	09:00	05-May-23	18:00	Daily	Hardware Tightening & Fitting Work	MSETCL	MSETCL	-
18	400 KV	NEW KOYNA-KARAD CKT - 1	05-May-23	08:00	05-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
19	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	06-May-23	10:00	06-May-23	18:00	Daily	Routine Maintenance & Diagnostic Testing Work	MSETCL	MSETCL	NIL
20	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	06-May-23	07:00	06-May-23	21:00	Daily	for Pre-monsoon maint. work in all aspect. Also Tan delta testing of Bushings, Windings & MV Side CT's. Also SFRA & Winding Resistance measurement testing	MSETCL	MSETCL	Load will managed on ICT-2
21	400 KV	NEW KOYNA-KARAD CKT - 2	06-May-23	08:00	06-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
22	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	06-May-23	09:00	06-May-23	18:00	Daily	For premonsoon maintenance work	MSETCL	MSETCL	as per preventive maint plan
23	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	06-May-23	09:00	06-May-23	17:00	Daily	HV CB DCRM/Timing,SRA,REF,NDR relay testing;bay maintenance work	MSETCL	MSETCL	315 MVA ICT I,501 MVA ICT III and IV will be in service
24	400 KV	JAIGAD - NEW KOYNA CKT - 2	08-May-23	08:00	08-May-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
25	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	08-May-23	09:00	08-May-23	18:00	Daily	(1) IV breaker testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
26	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	08-May-23	09:00	08-May-23	20:00	Daily	1. Pre-monsoon and quarterly maintenance work 2. Oil leakage atteding work	MSETCL	MSETCL	Load will be managed on 315MVA ICT 2 and 501MVA ICT 3
27	400 KV	KARAD - TALANDGE CKT - 1	08-May-23	08:00	08-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
28	400 KV	AKOLA - KHADKA (BHUSAWAL)	08-May-23	06:00	13-May-23	18:00	Daily	String replacement work on 400 kV Akola- Bhusawal Line will	MSETCL	MSETCL	String replacement work on 400 kV Akola- Bhusawal Line will
29	400 KV	CHANDRAPUR-PARLI CKT-3	08-May-23	08:00	10-May-23	18:00	Daily	For replacement of polymer Insulator string	MSETCL	MSETCL	-
30	400KV	Nagothane -Padgha Ckt 1 @Nagothane	08-May-23	8:00	08-May-23	17:00	Daily	String replacement and earth wire restringing work	MSETCL	MSETCL	
31	400 KV	WARORA - IEPL	09-May-23	09:00	09-May-23	17:00	Daily	Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
32	400 KV	KARAD - TALANDGE CKT - 2	09-May-23	08:00	09-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
33	400 KV	400/220KV 105 MVA SPARE ICT @ DHULE	09-May-23	09:00	09-May-23	17:00	Daily	Pre-monsoon activity	MSETCL	MSETCL	Spare ICT is on No Load
34	400 KV	KHADKA- DEEPNAGAR CKT 2	09-May-23	08:00	09-May-23	18:00	Daily	bay maint work	MSETCL	MSETCL	during outage 400kVDeepnagar 1 A/R will be out
35	400 KV	LONIKAND - JEJURI CKT - 2	09-May-23	08:00	11-May-23	18:00	Daily	PID scanning of insulator strings	MSETCL	MSETCL	Nil
36	400KV	Nagothane -Padgha Ckt 2 @Nagothane	09-May-23	8:00	09-May-23	17:00	Daily	String replacement and earth wire restringing work	MSETCL	MSETCL	
37	400 KV	JAIGAD - NEW KOYNA CKT - 1	10-May-23	08:00	10-May-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	----
38	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	10-May-23	08:00	10-May-23	18:00	Daily	For taking NIPPS trials by M/s CTR Pune. Old 220KV PT will be remove from circuit due to non availability of Tan delta point.Bus PT extended through PT selector switch relay.	MSETCL	MSETCL	Outages will be availed subject to weather & site conditions.

	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
39	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	10-May-23	08:00	10-May-23	17:00	Daily	Pre-monsoon maintenance	MSETCL	MSETCL	NA
40	400 KV	400/220KV 167 MVA SPARE ICT @ DHULE	10-May-23	09:00	10-May-23	17:00	Daily	Pre-monsoon activity	MSETCL	MSETCL	167MVA Spare ICT is on NO Load
41	400 KV	LONIKAND - JEJURI CKT - 1	11-May-23	08:00	11-May-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	Nil
42	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	11-May-23	10:00	11-May-23	17:00	Daily	Half Yearly Maintenance	MSETCL	MSETCL	Nil
43	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	11-May-23	10:00	11-May-23	18:00	Daily	1.Overhauling of SERGI NIPPS attending oil leakage. 2.Routine testing work	MSETCL	MSETCL	Nil
44	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	11-May-23	09:30	11-May-23	18:00	Daily	For Pre-Monsoon Maintenance & Testing work	MSETCL	MSETCL	During outage ICT 1 & ICT 3 will be in service.
45	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	11-May-23	10:30	11-May-23	18:00	Daily	Premonsoon Maintenance of ICT	MSETCL	MSETCL	-
46	400 KV	JEJURI - KARAD	11-May-23	08:00	11-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
47	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	11-May-23	07:00	11-May-23	14:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
48	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	11-May-23	08:00	12-May-23	18:00	Daily	Maintenance work	MSETCL	MSETCL	.
49	400 KV	400KV 125 MVAR BUS REACTOR@400KV DHULE SS	11-May-23	09:00	11-May-23	17:00	Daily	Pre-Monsoon activity	MSETCL	MSETCL	Generally out of service during day time
50	400 KV	CHANDRAPUR-PARLI CKT-3	11-May-23	09:00	11-May-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
51	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	12-May-23	08:00	12-May-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
52	400 KV	NEW KOYNA-KARAD CKT - 1	12-May-23	09:00	12-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
53	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	12-May-23	10:00	12-May-23	18:00	Daily	Routine Maintenance & Diagnostic Testing Work	MSETCL	MSETCL	NIL
54	400 KV	GTR - 4 @ CHANDRAPUR	12-May-23	08:00	12-May-23	18:00	Daily	1. Measurement of CB timing, CRM, DCRM 2. Bay routine maintenance work.	MSETCL	MSETCL	Unit-4 (GTR-4) will be in service via 400KV TBC-1
55	400 KV	95 MVA STN TF - II @KORADI 2	12-May-23	08:00	12-May-23	16:00	Daily	Diagnostic testing of Metering Current transformer Routine nut bolt tightening	MSETCL	MSETCL	NA
56	400 KV	NEW KOYNA-KARAD CKT - 2	13-May-23	09:00	13-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
57	400 KV	CHANDRAPUR-PARLI CKT-3	13-May-23	08:00	13-May-23	18:00	Daily	1. Measurement of tandelta of CT and CVT. 2. Bay routine maintenance work.	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No- 1, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No-
58	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	13-May-23	07:00	13-May-23	21:00	Daily	for Pre-monsoon maint. work in all aspect. Also Tan delta testing of Bushings, Windings & MV Side CT's. Also SFRA & Winding Resistance measurement testing work. Also both HV & MV Bay maintenance work to be carried out.	MSETCL	MSETCL	load will be managed on ICT-1
59	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	13-May-23	09:00	13-May-23	17:00	Daily	Bushing C and tanD,MV CT C and tan D,Bay maintenance work.	MSETCL	MSETCL	315 MVA ICT I,315 MVA ICT II,501 MVA ICT IV will be in service
60	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	15-May-23	10:00	15-May-23	17:00	Daily	Premonsoon maintenance and relay testing work	MSETCL	MSETCL	Premonsoon maintenance activity and relay testing work
61	400 KV	NEW KOYNA - STAGE IV CKT - 1	15-May-23	08:00	15-May-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
62	400 KV	MAIN BAY-425 OF GT-6 @ KORADI-2	15-May-23	08:00	15-May-23	16:00	Daily	Diagnostic testing of Circuit Breaker	MSETCL	MSETCL	GT# 8 will remain in service through Tie Bay 426
63	400KV	400/220 KV 315 MVA ICT I	15-May-23	8:00	15-May-23	17:00	Daily	Regular Maint work and Dignostic testing work	MSETCL	MSETCL	
64	400 KV	400/220 KV 500 MVA ICT @ ALKUD	16-May-23	10:00	16-May-23	17:00	Daily	Routine Maintenance Work & Diagnostic Testing	MSETCL	MSETCL	Tuesday is load staggering day of Sangli district.
65	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	16-May-23	09:00	16-May-23	17:00	Daily	Pre-monsoon activity work	MSETCL	MSETCL	During the outage 501MVA ICT-2 & 3 is in service
66	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	16-May-23	10:00	16-May-23	17:00	Daily	Routine Maintenance Work & Diagnostic Testing	MSETCL	MSETCL	--
67	400 KV	TBC @ BABHALESHWAR	16-May-23	09:00	16-May-23	17:00	Daily	Chemical cleaning and bay maintenance work	MSETCL	MSETCL	400 KV TBC is free
68	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	16-May-23	10:00	16-May-23	17:00	Daily	Routine Maintenance Work & Diagnostic Testing	MSETCL	MSETCL	--
69	400 KV	400/220 KV SPARE 167 MVA ICT @ ALKUD	16-May-23	10:00	16-May-23	17:00	Daily	Routine Maintenance Work & Diagnostic Testing	MSETCL	MSETCL	--
70	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	16-May-23	08:00	16-May-23	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.
71	400KV	400/220 KV 315 MVA ICT II	16-May-23	8:00	16-May-23	17:00	Daily	Regular Maint work and Dignostic testing work	MSETCL	MSETCL	
72	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	17-May-23	09:00	17-May-23	18:00	Daily	(1) Main-2 distance relay testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
73	400 KV	400/220/33 KV 500 MVA ICT - 2 @ DHULE	17-May-23	09:00	17-May-23	17:00	Daily	Pre-monsoon activity work	MSETCL	MSETCL	During the outage period 501MVA ICT-3 & 315MVA ICT-1 is in service.
74	400 KV	FUTURE CKT - 1 @ WARORA	17-May-23	08:00	17-May-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
75	400KV	400/220 KV 315 MVA ICT III	17-May-23	8:00	17-May-23	17:00	Daily	Regular Maint work and Dignostic testing work	MSETCL	MSETCL	
76	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	18-May-23	09:30	18-May-23	18:00	Daily	For Pre-Monsoon Maintenance & Testing work	MSETCL	MSETCL	During outage ICT 1 & ICT 2 will be in service.
77	400 KV	400 KV FUTURE BAY II @ WARORA	18-May-23	08:00	18-May-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCL (NAGRI) ckt charged on its Main Bay CB.
78	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	18-May-23	10:00	18-May-23	18:00	Daily	1.Overhauling of SERGI NIPPS attending oil leakage. 2.Routine testing work	MSETCL	MSETCL	Nil
79	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	18-May-23	08:00	18-May-23	14:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work

	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
80	400 KV	LONIKAND I - KOYNA STAGE-IV	18-May-23	08:00	18-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
81	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	18-May-23	10:30	18-May-23	18:00	Daily	Premonsoon Maintenance of ICT	MSETCL	MSETCL	-
82	400 KV	LONIKAND I - KOYNA STAGE-IV	18-May-23	08:00	18-May-23	18:00	Daily	DT Work & Bay Maintenance & Cold Washing of insulator strings	MSETCL	MSETCL	Nil
83	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	18-May-23	10:00	18-May-23	17:00	Daily	Half Yearly Maintenance	MSETCL	MSETCL	Nil
84	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	18-May-23	09:00	18-May-23	18:00	Daily	Hardware Tightening & Fitting Work	MSETCL	MSETCL	-
85	400 KV	AKOLA - KHADKA (BHUSAWAL)	18-May-23	10:00	31-May-23	15:00	Daily	PID testing work will be carried out by PID Unit Akola & Hot Line Unit Akola of	MSETCL	MSETCL	PID testing work will be carried out by PID Unit Akola & Hot Line Unit Akola of
86	400 KV	LONIKAND I - KOYNA STAGE-IV	19-May-23	08:00	19-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
87	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALLUJ	19-May-23	10:00	19-May-23	19:00	Daily	Routine Maintenance & Diagnostic Testing work	MSETCL	MSETCL	NIL
88	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	19-May-23	07:00	19-May-23	18:00	Daily	Routine Maintenance Work (AMP)	MSETCL	MSETCL	ICT-1 & ICT-3 will be in service
89	400 KV	TBC @ NEW KOYNA	19-May-23	08:00	19-May-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
90	400 KV	BUS REACTOR (125 MVA) - 2 @ KOLHAPUR (TALANDGE)	19-May-23	09:00	19-May-23	20:00	Daily	1. Quarterly and pre monsoon maintenance work	MSETCL	MSETCL	80MVAr bus reactor will be in service
91	400 KV	KORADI-NANDGAONPETH (RPL)	19-May-23	08:00	19-May-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
92	400 KV	LONIKAND - JEJURI CKT - 2	20-May-23	08:00	20-May-23	18:00	Daily	1. Cold washing of insulator, 2. PID Detected strings replacement	MSETCL	MSETCL	Nil
93	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	20-May-23	10:00	20-May-23	17:00	Daily	DFRA,tap continuity,Bay maintenance work	MSETCL	MSETCL	315 MVA ICT I,315 MVA ICT II,501 MVA ICT III will be in service
94	400 KV	WARORA - IEPL	20-May-23	09:00	20-May-23	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
95	400 KV	KORADI-NANDGAONPETH (RPL)	21-May-23	08:00	30-May-23	18:00	Daily	PID Work	MSETCL	MSETCL	NIL
96	400 KV	400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	22-May-23	10:00	22-May-23	14:00	Daily	DFRA,tap continuity	MSETCL	MSETCL	Spare ICT is free
97	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	22-May-23	10:00	22-May-23	17:00	Daily	Premonsoon maintenance and relay testing work	MSETCL	MSETCL	Premonsoon maintenance activity and relay testing work
98	400 KV	NEW KOYNA - STAGE IV CKT - 2	22-May-23	08:00	22-May-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
99	400 KV	KARAD - TALANDGE CKT - 1	22-May-23	08:00	22-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
100	400 KV	TIE BAY-426 OF GT-8 @ KORADI-2	23-May-23	08:00	23-May-23	16:00	Daily	Diagnostic testing of Circuit Breaker	MSETCL	MSETCL	GT# 8 will remain in service through Main Bay 425
101	400 KV	BUS REACTOR (125 MVA) @ ALKUD	23-May-23	10:00	23-May-23	17:00	Daily	Routine Maintenance Work & Diagnostic Testing	MSETCL	MSETCL	--
102	400 KV	KARAD - TALANDGE CKT - 2	23-May-23	08:00	23-May-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
103	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	23-May-23	07:00	23-May-23	14:00	Daily	1. Pre-Mansoon maintenance work 2. Diagnostic testing work 3. Isolator maintenance work	MSETCL	MSETCL	load will be shift on ICT-02
104	400 KV	MAIN BAY - 401 OF BUS REACTOR @ ALKUD	23-May-23	10:00	23-May-23	17:00	Daily	Routine Maintenance Work & Diagnostic Testing	MSETCL	MSETCL	--
105	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	24-May-23	07:00	24-May-23	14:00	Daily	1. pre-mansoon maintenance work 2. Diagnostic testing work	MSETCL	MSETCL	load will be shifted on ICT-01
106	400 KV	400/220kv 105 MVA SPARE ICT @ NEW KOYNA	24-May-23	08:00	24-May-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
107	400 KV	CHANDRAPUR-PARLI CKT-3	24-May-23	09:00	24-May-23	18:00	Daily	Hardware Tightening & Fitting Work	MSETCL	MSETCL	-
108	400 KV	JEJURI - KARAD	25-May-23	08:00	25-May-23	18:00	Daily	1. Cold washing of insulator, 2. PID Detected strings replacement	MSETCL	MSETCL	Nil
109	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	25-May-23	09:00	25-May-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
110	400 KV	LONIKAND - JEJURI CKT - 2	25-May-23	08:00	25-May-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	Nil
111	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	25-May-23	10:00	25-May-23	18:00	Daily	1.Overhauling of CTR NIFPS attending oil leakage. 2.Routine testing work	MSETCL	MSETCL	Nil
112	400 KV	400/220KV SPARE ICT @ JEJURI	25-May-23	09:30	25-May-23	18:00	Daily	For Pre-Monsoon Maintenance & Testing work	MSETCL	MSETCL	During outage all ICTs (ICT-1,ICT-2,ICT-3) will be in service.
113	400 KV	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	26-May-23	07:00	26-May-23	14:00	Daily	1. pre-mansoon maintenance work 2. Diagnostic testing work 3. isolator maintenance work	APTCL	APTCL	Tie Bay 418 will be in service
114	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	29-May-23	06:00	29-May-23	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
115	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	31-May-23	06:00	31-May-23	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---