

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of MAY' 2024

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks	
1	39	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01-May-24	08:00	01-May-24 18:00	PID Work A/R Out
2	54	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY OF 400KV-BARLESHWAR-PADGHE-1 AND BARLESHWAR - 400KV - BUS 1 @BARLESHWAR - 400KV at BARLESHWAR - 400KV	C	CB pole overhauling work. Line will be in service through TBC	01-May-24	08:00	05-May-24 18:00	400 KV Padghe 1 will be in service through TBC
3	56	PLANNED	OCC_578	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of A Bus PG Isolator of 80MVAR Reactor by hot line method. 2.CB Pole overhauling work of all phase. 3.Diagnostic Testing Work. 3.Reactor can be taken on TBC if required.	01-May-24	09:30	07-May-24 17:00	Weather condition should be clear for hot line work. Hot line team will be present on site.
4	57	PLANNED	OCC_578	MSLDC_OUTAGE	PADGHE - 400KV B/R 1	C	1.CB Pole overhauling work of all phase. 2.Diagnostic Testing Work. 3.Reactor can be taken on TBC if required.	01-May-24	09:30	07-May-24 18:30	Weather condition should be clear.
5	61	PLANNED	OCC_578	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	01-May-24	8:00	10-May-24 18:00	AR disable
6	62	PLANNED	OCC_578	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	01-May-24	8:00	10-May-24 18:00	AR disable
7	64	PLANNED	OCC_578	MSLDC_OUTAGE	132KV-PENCHI-KANHAN-1	D	For earthwire replacement & routine maintenance work	01-May-24	06:00	10-May-24 18:00	Earthwire replacement work will be carried out by agency M/s OM Tech
8	69	PLANNED	OCC_578	ATIL	400KV-TIRODA-WARORA-1	D	Additional Earthing work. Only AR will be kept off. Line will be in service.	01-May-24	08:00	15-May-24 18:00	AR IN NON AUTO MODE. Line will be in service.
9	70	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing. Only AR will be kept of. line will be in service.	01-May-24	09:00	15-May-24 18:00	Line is in service
10	83	PLANNED	OCC_578	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	D	For OPGW stringing under live line condition. Non auto required at both ends.	01-May-24	7:00	31-May-24 18:00	PG-WR2-RHQ IT
11	86	PLANNED	OCC_578	POWERGRID_WRI	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-May-24	7:00	31-May-24 18:00	
12	87	PLANNED	OCC_578	POWERGRID_WRI	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-May-24	7:00	31-May-24 18:00	
13	89	PLANNED	OCC_578	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	01-May-24	8:00	31-May-24 18:00	AR disable
14	90	PLANNED	OCC_578	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	01-May-24	8:00	31-May-24 18:00	AR disable
15	106	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-B-1	D	For OPGW installation replacing existing earth wire. Only AR will be kept off. Line will be in service	01-May-24	07:00	31-May-24 19:00	Work is proposed by MITCL.
16	107	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-B-2	D	For OPGW installation replacing existing earth wire. Only AR will be kept off. Line will be in service	01-May-24	07:00	31-May-24 19:00	Work is proposed by MITCL.
17	108	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	For OPGW installation replacing existing earth wire	01-May-24	07:00	31-May-24 19:00	Work is proposed by MITCL.
18	109	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	For OPGW installation replacing existing earth wire	01-May-24	07:00	31-May-24 19:00	Work is proposed by MITCL.
19	110	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/JHJUR-KOYNASTAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-May-24	09:00	31-May-24 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
20	111	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KOYNASTAGE IV-LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-May-24	09:00	31-May-24 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
21	112	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-May-24	09:00	31-May-24 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
22	113	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-May-24	09:00	31-May-24 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
23	114	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNASTAGE	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-May-24	09:00	31-May-24 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
24	115	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work. Only AR will be kept off. Line will be in service	01-May-24	09:00	31-May-24 17:30	-
25	116	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work.	01-May-24	09:00	31-May-24 17:30	-
26	117	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID Testing Work. Only AR will be kept off. Line will be in service	01-May-24	09:00	31-May-24 18:00	Only AR will be kept off. Line will be in service
27	118	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNASTAGE	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-May-24	09:00	31-May-24 19:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
28	119	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-BADNERA-1	D	A/R out of service for laying of new OPGW 48F by replacing earthwire by MITCL.	01-May-24	10:00	31-May-24 18:00	NA
29	120	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-WARDHIA-M-1	D	A/R out of service for laying of new OPGW 48F by replacing earthwire by MITCL.	01-May-24	10:00	31-May-24 18:00	NA
30	121	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-BADNERA-1	D	For PID work. Shifting of Auto reclose switch to non auto mode.	01-May-24	11:00	31-May-24 15:00	PID work
31	135	PLANNED	OCC_578	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOBSAR/CT-2 AND BOBSAR - 400KV - BUS 2 at BOBSAR - 400KV	D	AMP	02-May-24	7:00	02-May-24 16:00	PG-WR2-BOBSAR
32	139	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARDHIA-WARORA-PG-1	D	Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	02-May-24	7:00	02-May-24 18:00	Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
33	140	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARORA (M)-WARORA-PG-2	D	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400V Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	02-May-24	7:00	02-May-24 18:00	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
34	141	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARDHIA-WARORA-PG-1	D	For 400KV Wardha #1 Line Equipments AMP Work	02-May-24	7:00	02-May-24 18:00	400KV-WARORA-PG-WARORA (MSE1CL)-1 AR OFF
35	170	PLANNED	OCC_578	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT	02-May-24	08:00	02-May-24 17:30	All feeders will remain in service through 400KV Main Bus II
36	171	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	Maintenance work	02-May-24	08:00	02-May-24 18:00	Outage
37	172	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line / S/S Maintenance.	02-May-24	09:00	02-May-24 17:30	-
38	174	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-5	D	1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine maintenance work.	02-May-24	06:00	05-May-24 18:00	During outage 400KV STN TF-4 will be in service. Load on STN TF-5 will be shifted on STN TF-4 at Generation end.
39	179	PLANNED	OCC_578	RGPTL	400KV/11.9KV RGPTL-ST-1	C	Cable shifting to new Microswitchgear	02-May-24	8:00	09-May-24 18:00	Cable shifting to new Microswitchgear
40	184	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-1	D	Online PID Work	02-May-24	08:00	16-May-24 18:00	Only Auto Reclose Switch Will Be Out Line Will Be In Service. Online PID Work
41	354	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Diagnostic testing work.	02-May-24	09:00	02-May-24 17:00	400KV WARORA-HEPL. Line is in ckt
42	210	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	03-May-24	9:00	03-May-24 17:30:00	Pune GIS Line, 2 Line in service through the 408 TIE Bay
43	226	PLANNED	OCC_578	MSLDC_OUTAGE	TIE BAY - 400KV-WARORA-CHANDRAPUR-II-2 AND FUTURE at CHANDRAPUR-II - 400KV	D	Diagnostic testing and allied maintenance work	03-May-24	07:00	03-May-24 13:00	Diagnostic testing and allied maintenance work
44	227	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BHUSAVAL-AKOLA-1	D	Routine Maintenance & testing Work	03-May-24	07:00	03-May-24 14:00	Nandgaon line will be in service
45	228	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-AURANGABAD-CHITGAON-2	D	For taking bus section 1 outage for the work of jumpstarting of hybrid switchgear	03-May-24	08:00	03-May-24 18:00	-
46	230	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Routine testing and Maintenance Works	03-May-24	10:00	03-May-24 18:00	1500MVA 765/400KV ICT 1 in service via 709 Tie bay and Main bus 1

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks	
47	235	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	03-May-24	08:00	08-May-24 18:00	PID Work A/R Out
48	237	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHIA-KORADI-II-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	C	Overhauling of Circuit breaker	03-May-24	08:00	10-May-24 17:30	Koradi-II Wardha(PG) ckt. will remain inservice through the Bay 411
49	246	PLANNED	OCC_578	POWERGRID_WRI2	TIE BAY - 400KV-TARAPUR-364-BOISAR-1 AND 400KV/220KV BOISAR-1CT-2 at BOISAR - 400KV	D	AMP	04-May-24	7:00	04-May-24 16:00	PG-WR2-BOISAR
50	257	PLANNED	OCC_578	WTPL	220KV-SOLAPUR-JEUR-1	D	Annual Maintenance	04-May-24	8:00	04-May-24 18:00	Outage
51	258	PLANNED	OCC_578	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	AR disable for annual maintenance in 220KV Solapur -Jeur Line	04-May-24	8:00	04-May-24 18:00	AR disable
52	277	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	1) For taking on ERS for shifting/ height rising work in between loc. 178-180 for NISERCL work under EHV Project Dn, Kalwa. 2) SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work. 3) Also For taking on ERS for shifting/ height rising work in between loc. 178-180 for NISERCL work under EHV Project Dn, Kalwa.	04-May-24	22:00	05-May-24 08:00	1) SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work. 2) Also For taking on ERS for shifting/ height rising work in between loc. 178-180 for NISERCL work under EHV Project Dn, Kalwa.
53	156	PLANNED	OCC_578	POWERGRID_WRI1	400KV/PADGHE-PG-KUDUS-1	D	AMP of Line Equipment at Padghe GIS & MSETCL Kudus substation and Autoreclosure scheme checking at Padghe SS. AR IN NON AUTO MODE OF CKT#2	05-May-24	9:00	05-May-24 17:00	
54	270	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-1	D	Routine Line maintenance work	05-May-24	08:00	05-May-24 18:00	400KV Padghe II will be in service
55	279	PLANNED	OCC_578	POWERGRID_WRI2	MAIN BAY OF 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	D	Simultaneous outage of BOISAR - 220KV - BUS 2 is required for Faulty Isolator Replacement work.	05-May-24	7:00	05-May-24 17:30	PG-WR2-BOISAR
56	280	PLANNED	OCC_578	POWERGRID_WRI2	BOISAR-M - 220KV - BUS 2	D	Simultaneous outage of MAIN BAY OF 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 2 for Faulty Isolator Replacement work.	05-May-24	7:00	05-May-24 17:30	PG-WR2-BOISAR
57	284	PLANNED	OCC_578	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	Annual Maintenance	05-May-24	8:00	05-May-24 18:00	Outage
58	285	PLANNED	OCC_578	WTPL	220KV-SOLAPUR-JEUR-1	D	AR disable for annual maintenance in 400V Solapur-M- Solapur 1	05-May-24	8:00	05-May-24 18:00	AR disable
59	293	PLANNED	OCC_578	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance and R & M work.	05-May-24	09:00	05-May-24 15:00	Bay maintenance and R & M work.
60	294	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Disc Insulator broken at Loc.No. 107 Y-Ph PGCL side.	05-May-24	09:00	05-May-24 17:00	Simultaneously outage is required on 220KV Tarapur - Borivali Line (for safety purpose)
61	295	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TARAPUR-1-2-BORIVALI-1	D	for safety purpose during replacement of Disc Insulator broken at Loc.No. 107 Y-Ph PGCL side of 220KV PGCL - Borivali Line.	05-May-24	09:00	05-May-24 17:00	for safety purpose during replacement of Disc Insulator broken at Loc.No. 107 Y-Ph PGCL side of 220KV PGCL - Borivali Line.
62	296	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-2	D	To attend defects identified in line patrolling and to replace PID faulty Isolator strings.	05-May-24	09:00	05-May-24 18:00	400KV BILR-PDG Ckt-1 will be in service.
63	297	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-1	D	1. Bay Maintenance Work. 2.Diagnostic Testing Work. 3.AT&MC Work. 4. Replacement of Distance relay & Over voltage relay.	05-May-24	09:30	05-May-24 18:30	Weather condition should be clear .
64	298	PLANNED	OCC_578	MEGTCL	765KV/400KV AKOLA (2)-ICT-1	D	ICT Changerover activity as per CEA guidelines, Yph ICT taken in to service in place of Rph ICT at Akola-II SS	05-May-24	10:00	05-May-24 20:00	ICT Outage
65	299	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware tightening and cold line Cleaning	05-May-24	16:00	05-May-24 23:00	Load managed on 400KV parli-karjat ckt-1
66	300	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	For taking on ERS for shifting/ height rising work in between loc. 178-180 for NISERCL work under EHV Project Dn, Kalwa.	05-May-24	22:00	06-May-24 5:00	For taking on ERS for shifting/ height rising work in between loc. 178-180 for NISERCL work under EHV Project Dn, Kalwa.
67	301	PLANNED	OCC_578	MSLDC_OUTAGE	BUS COUPLER BAY - BARLESHWAR - 400KV - BUS 1 AND BARLESHWAR - 400KV - BUS 2 at BARLESHWAR - 400KV	C	CB pole overhauling work,Back up relay testing	05-May-24	09:00	08-May-24 18:00	400KV Main Bus I and main Bus II will be separated
68	319	PLANNED	OCC_578	POWERGRID_WRI1	400KV-AURANGABAD-BOISAR-1 L/R @ AURANGABAD - 400KV	D	For AMP	06-May-24	7:00	06-May-24 18:00	430R
69	336	PLANNED	OCC_578	POWERGRID_WRI1	MAIN BAY - 400KV-CHAKAN AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	06-May-24	9:00	06-May-24 17:30:00	Chakan Line in service through the 402 TIE Bay
70	352	PLANNED	OCC_578	MSLDC_OUTAGE	BARLESHWAR - 400KV - BUS 1	D	for checking alignment of 400KV Main bus 1 isolator of 400KV Kudus-1 Bay at 400KV Babulnashwar R.S by HOT LINE METHOD	06-May-24	08:00	06-May-24 18:00	for checking alignment of 400KV Main bus 1 isolator of 400KV Kudus-1 Bay at 400KV Babulnashwar R.S by HOT LINE METHOD
71	353	PLANNED	OCC_578	MSLDC_OUTAGE	IEPT - & Future Tie Bay 418 at Warora	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work.	06-May-24	09:00	06-May-24 17:00	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
72	355	PLANNED	OCC_578	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For replacement of flashover disc. Fixing of turbo wind bird guard.	06-May-24	09:00	06-May-24 17:00	Outage
73	364	PLANNED	OCC_578	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 - Borivali	C	Feeder outage is required to carry out routine annual maintenance and replacement of 220kV Lightning arresters.	06-May-24	8:00	08-May-24 20:00	To carry out routine annual maintenance and replacement of 220kV Lightning arresters.
74	368	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY OF 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 AND CHANDRAPUR-GCR - 400KV - BUS 1 @CHANDRAPUR-GCR - 400KV at CHANDRAPUR-GCR - 400KV	C	1.Maintenance of Circuit breaker 2. Maintenance and alignment of PG-1 & PG-2 Isolator. 3. 400KV HVDC CKT-2 will be in service via TBC-2.	06-May-24	06:00	09-May-24 18:00	400KV HVDC CKT-2 will be in service via TBC-2.
75	372	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCL (Dead Line). Outage required of 220KV PGCL - Boisar Line No. 1 for safety purpose only.	06-May-24	05:00	10-May-24 09:00	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCL (Dead Line). Outage required of 220KV PGCL - Boisar Line No. 1 for safety purpose only.
76	373	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	C	Replacement of Main 1 and Main 2 disc prot.relay panels.	06-May-24	10:00	10-May-24 17:00	400 KV Karad solapur line is opened at loc no 403 from karad end and converted to 220 kv Jeur/Solapur PGCL line since 21.06.2013Now the 400 KV Karad Solapur PGCL line is closed.
77	376	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	For replacement of polymer by longrod	06-May-24	08:00	16-May-24 18:00	For replacement of polymer by longrod
78	379	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	06-May-24	09:00	31-May-24 18:00	PID testing of insulator A/R function required to be in non auto mode
79	405	PLANNED	OCC_578	POWERGRID_WRI1	TIE -BAY - 400 KV CHAKAN AND 400 KV KHARGHAR LINE at PUNE-PG - 400KV	D	For AMP Work	07-May-24	9:00	07-May-24 17:30:00	Chakan Line in service through the 401 bay and Kharghar Line will remain in service through 403 Bay.
80	428	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-BHUGAON-1	D	Routine line maintenance work	07-May-24	08:00	08-May-24 18:00	NA
81	433	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	C	OVERHAULING OF CB by agency	07-May-24	10:00	09-May-24 16:00	MAX 85 MIN- 15
82	431	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/SSP-DHULE-MS-1	D	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNI. CKT 2 Auto Reclose switchwill be kept on Non Auto mode during Outage	08-May-24	08:00	10-May-24 18:00	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNI. CKT 2 Auto Reclose switchwill be kept on Non Auto mode during Outage
83	432	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/SSP-DHULE-MS-2	D	For Awaiting Outage on 400 KV Dhule-SSNNI CKT 1 & Safe working. 400 KV Dhule-SSNNI. CKT 2 Auto Reclose switchwill be kept on Non Auto mode during Outage period	08-May-24	08:00	10-May-24 18:00	For Awaiting Outage on 400 KV Dhule-SSNNI CKT 1 & Safe working. 400 KV Dhule-SSNNI. CKT 2 Auto Reclose switchwill be kept on Non Auto mode during Outage period
84	432	PLANNED	OCC_578	POWERGRID_WRI1	MAIN BAY - 220KV-AURANGABAD-CHITGAON-2 AND AURANGABAD - 220KV - BUS 1 at AURANGABAD - 220KV	D	For AMP	08-May-24	7:00	08-May-24 18:00	206
85	469	PLANNED	OCC_578	POWERGRID_WRI1	TIE -BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND 400 KV ICT#1 at PUNE-PG - 400KV	D	For AMP Work	08-May-24	9:00	08-May-24 17:30:00	Pune -PG-1 in service through the 404 bay and 400 KV ICT#1 will remain in service through 406 Bay.
86	492	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-YAWATMAL-1	D	Maintenance work	08-May-24	08:00	08-May-24 18:00	Outage
87	493	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-WARDHIA-KORADI-II-1	D	Routine Maintenance & Dignotic testing work.	08-May-24	09:00	08-May-24 17:00	400 KV WARORA - DHOLI 2 Line is in ckt
88	494	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	Line / S/S Maintenance.	08-May-24	09:00	08-May-24 17:30	-
89	495	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and cold line Cleaning	08-May-24	09:00	08-May-24 18:00	Load managed on 400kv lambod-PGCL line

Sr.No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuous	Reason	From	To	Remarks	
90	496	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Replacement of faulty strings found in PID testing.	08-May-24	09:00	08-May-24 18:00	Outage is carried out for Replacement of faulty strings found in PID testing needs to be carried out every year to avoid decapping . 80% portion is charged on 400 KV Line
91	497	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	Routine Maint. Work	08-May-24	09:00	08-May-24 18:00	NA
92	498	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TILARI-AMONA-1	D	Maintenance work	08-May-24	09:00	08-May-24 18:00	The said work is very important
93	499	PLANNED	OCC_578	MSLDC_OUTAGE	JEUR - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	08-May-24	10:00	08-May-24 17:00	Breaker of PGCL line at Jeur End will be made off
94	537	PLANNED	OCC_578	POWERGRID_WRI	400KV-PADGHE-BOISAR-1	D	Winding Tan Delta, FDS, Moisture measurement of LR of 400KV-PADGHE-BOISAR-1. AR of CKT#2 in run auto mode.	09-May-24	9:00	09-May-24 17:00	
95	554	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-WARDHIA-KORADI-B-1	D	LINE MAINT. WORKS	09-May-24	06:00	09-May-24 18:00	NA
96	555	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	Maintenance work	09-May-24	08:00	09-May-24 18:00	Outage
97	556	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	Routine line maintenance work	09-May-24	08:00	09-May-24 18:00	NA
98	559	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	09-May-24	10:00	09-May-24 13:00	Online work by Shifting on TBC
99	560	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1	D	Routine testing and Maintenance Works	09-May-24	10:00	09-May-24 18:00	711 bay Testing work
100	561	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	09-May-24	14:00	09-May-24 17:00	Online work by Shifting on TB
101	562	PLANNED	OCC_578	NFCL, TAPS 162	220 KV-Tarapur162 - Vapi	C	Continuous feeder outage is required for Annual maintenance of feeder equipments (CT,Breaker,isolator,wave trap,CVT,LA etc.)	09-May-24	8:00	10-May-24 20:00	To carry out annual maintenance of feeder equipments.
102	564	PLANNED	OCC_578	POWERGRID_WRI	KOLHAPUR GS - 400KV B/R 1	C	Turret CT oil leakage attending work	09-May-24	8:00	11-May-24 18:00	125Mvar Bus Reactor CT Oil leakage attending work
103	565	PLANNED	OCC_578	RGPPIL	THE BAY OF 400KV-RGPPIL-NEW KOYNA-1 AND 400KV/15KV RGPPIL-GT-1A @RGPPIL - 400KV at RGPPIL - 400KV	C	Bay Maintenance and testing	09-May-24	8:00	11-May-24 18:00	Bay Maintenance and testing
104	566	PLANNED	OCC_578	RGPPIL	400KV-RGPPIL-NEW KOYNA-1	D	Bay Maintenance and testing	09-May-24	8:00	11-May-24 18:00	Bay Maintenance and testing
105	585	PLANNED	OCC_578	POWERGRID_WRI	AURANGABAD - 400KV - BUS 1	D	For AMP	10-May-24	7:00	10-May-24 18:00	400KV BUS_1
106	607	PLANNED	OCC_578	POWERGRID_WRI	THE BAY - 400KV-CHANDRAPUR-BHADRAWATI-4 AND 400KV-BHADRAWATI-RAIPUR-2 at BHADRAWATI - 400KV	D	Bay AMP works	10-May-24	9:00	10-May-24 17:00	AMP works
107	608	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-PUNE-GS-PUNE-PG-4 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	10-May-24	9:00	10-May-24 17:30:00	Pune GS Line_2 Line in service through the 411 THE Bay.
108	620	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-AURANGABAD-CHITGAON-2	D	For taking bus section 1 outage for work of jumpering of hybrid switchgear	10-May-24	08:00	10-May-24 18:00	-
109	621	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	Routine line maintenance work	10-May-24	08:00	10-May-24 18:00	NA
110	622	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-B-1	D	Relay testing work & routine maintenance work.	10-May-24	09:00	10-May-24 17:00	Load manage on 400KV Chandrapur 2 Ckt 2_parallel ckt
111	623	PLANNED	OCC_578	MSLDC_OUTAGE	THE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1	D	Outage required for routine testing and Maintenance Works	10-May-24	10:00	10-May-24 18:00	712 testing Works to be carried out
112	633	PLANNED	OCC_578	MSLDC_OUTAGE	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR 400KV	C	For overhauling of Circuit Breakers	10-May-24	16:00	12-May-24 23:59	For overhauling of Circuit Breakers
113	634	PLANNED	OCC_578	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.	10-May-24	09:30	13-May-24 18:30	1. Weather condition should be clear for Hot Line Work. 2. Hot Line Team will be present on site.
114	635	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY OF 400KV-BARLESHWAR-PADGHE-2 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1. B Bus PG Isolator Replacement work under LIS Scheme. 2. CB Diagnostic Testing Work.	10-May-24	09:30	13-May-24 18:30	Weather Condition should be clear.
115	638	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	For PID Work & third guard Connect for Shifting of auto reclose switch to run auto mode.	10-May-24	08:00	15-May-24 18:00	PID Work A/R Out
116	648	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	For AMP	11-May-24	7:00	11-May-24 18:00	418
117	656	PLANNED	OCC_578	POWERGRID_WRI	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment	11-May-24	9:00	11-May-24 17:00	
118	663	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-2	D	Routine Line maintenance work	11-May-24	08:00	11-May-24 18:00	400V Padghe 1 will be in service
119	669	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of bridge wedge connector at mid-span joint & insulator cleaning work	11-May-24	22:00	12-May-24 6:00	SSN to DSN insulator string Conversion work, and installation of bridge wedge connector at mid-span joint & insulator cleaning work
120	671	PLANNED	OCC_578	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for replacement of insulator in live line method.	11-May-24	8:00	20-May-24 18:00	AR disable
121	672	PLANNED	OCC_578	WTPL	220KV-SOLAPUR-JEUR-1	D	AR disable for replacement of insulator in live line method.	11-May-24	8:00	20-May-24 18:00	AR disable
122	673	PLANNED	OCC_578	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	To carry out the PID work of Disc Insulator at various location. Only AR will be kept off. Line will be in service	11-May-24	09:00	31-May-24 18:00	1) There will be no interruption, online work will be carried out by PID Unit, Nagpur. 2) Auto reclose to be made off at both the ends
123	674	PLANNED	OCC_578	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	To carry out the PID work of Disc Insulator at various location	11-May-24	09:00	31-May-24 18:00	1) There will be no interruption, online work will be carried out by PID Unit, Nagpur. 2) Auto reclose to be made off at both the ends
124	675	PLANNED	OCC_578	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	To carry out the PID work of Disc Insulator at various location. Only AR will be kept off. Line will be in service	11-May-24	09:00	31-May-24 18:00	1) There will be no interruption, online work will be carried out by PID Unit, Nagpur. 2) Auto reclose to be made off at both the ends
125	676	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 220KV-BOISAR-BOISAR-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP	12-May-24	7:00	12-May-24 16:00	PG-WR2-BOISAR
126	681	PLANNED	OCC_578	POWERGRID_WRI	PUNE-PG - 400KV - BUS 1	D	For AMP Work	12-May-24	9:00	12-May-24 18:00:00	
127	686	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Outage is required for safety purpose during applying repair sleeve for Damaged Conductor at Loc. No. 76-77.	12-May-24	09:00	12-May-24 17:00	Outage is required for safety purpose during applying repair sleeve for Damaged Conductor at Loc. No. 76-77.
128	687	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	For applying repair sleeve for work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220KV Boisar - PGCL (Dead Line) Change required of 220KV PGCL - Boisar Line No. 1 for safety purpose only.	12-May-24	09:00	12-May-24 17:00	Simultaneously outage is required on 220KV PGCL - Borivali Line (for safety purpose)
129	688	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-1	D	To attend defects identified in line patrolling and to replace PID faulty insulator string.	12-May-24	09:00	12-May-24 18:00	400V BBLR-PDG Ckt -2 will be in service.
130	690	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BARLESHWAR-ICT-2 AND BARLESHWAR - 400KV - BUS 1 @BARLESHWAR - 400KV at BARLESHWAR -	C	CB pole overhauling work. ICT HV will be in service through TBC	12-May-24	09:00	16-May-24 18:00	ICT HV will be in service through TBC
131	1576	Planned	OCC_578	MIEGPCL	765KV/400KV AKOLA (2)-ICT-1	Daily	Insulation Coating on Tertiary winding insulators	12-May-24	10:00	12-May-24 20:00	ICT OUTAGE
132	714	PLANNED	OCC_578	POWERGRID_WRI	PARLI NEW - 400KV - BUS 2	D	AMP OF BUS & ISOLATOR ALIGNMENT WORK	13-May-24	8:00	13-May-24 18:00	AMP OF BUS & ISOLATOR ALIGNMENT WORK
133	718	PLANNED	OCC_578	POWERGRID_WRI	THE BAY - 400KV-PUNE-GS-PUNE-PG-4 AND 400 KV ICT#2 at PUNE-PG - 400KV	D	For AMP Work	13-May-24	9:00	13-May-24 17:30:00	Pune PG-4 in service through the 410 bay and 400 KV ICT#2 will remain in service through 412 Bay.
134	729	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-EKTUNI-BARLESHWAR-1	D	Line Maintenance Works & Bay Maintenance Works	13-May-24	08:00	13-May-24 23:59	Line Maintenance Works & Bay Maintenance Works
135	730	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-WARDHIA-KORADI-B-1	D	Diagnostic Testing of Line CVT	13-May-24	08:00	13-May-24 17:30	400KV Konadi-II-HEPL Ckt. Will be service as alternate source

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continu ms	Reason	From	To	Remarks	
136	731	PLANNED	OCC_578	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT test delta & maintenance work	13-May-24	09:00	13-May-24 17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV/125MVAR reactor kept off position during outage.
137	732	PLANNED	OCC_578	MSLDC_OUTAGE	220KV/WARDHA-BADINERA-1	D	For replacement of flashover disc. Diagnostic testing of line Bay at Badnera SS.	13-May-24	09:00	13-May-24 17:00	Outage
138	733	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/ALKUD-SOLAPUR-1	D	Diagnostic testing & Maintenance work	13-May-24	10:00	13-May-24 23:59	Load will be managed on 400KV Kolhapur line
139	734	PLANNED	OCC_578	MSLDC_OUTAGE	TIE BAY - 400KV/ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-1CT-2 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	13-May-24	14:00	13-May-24 17:00	-
140	757	PLANNED	OCC_578	RGPPPL	MAIN BAY OF 400KV/11.9KV RGPPPL-ST-2 AND RGPPPL - 400KV - BUS 2 60RGPPPL - 400KV at RGPPPL 400KV	C	Bay Maintenance and testing	13-May-24	8:00	15-May-24 18:00	Bay Maintenance and testing
141	758	PLANNED	OCC_578	RGPPPL	400KV/11.9KV RGPPPL-ST-2	C	Bay Maintenance and testing	13-May-24	8:00	15-May-24 18:00	Bay Maintenance and testing
142	759	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	For all phases conductor restringing work between tower loc no. 271 to 280.	13-May-24	08:00	15-May-24 17:00	220 KV Mudshingi-Chikodi line is charged from Mudshingi end only and line is on No load condition.
143	760	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/65P/DHULE-MS-2	D	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work 400 KV Dhule-SSNNL CKT 1 Auto Reclose switchwill be kept on Non Auto mode during Outage period	13-May-24	08:00	15-May-24 18:00	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work 400 KV Dhule-SSNNL CKT 1 Auto Reclose
144	761	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/65P/DHULE-MS-1	D	For Availing Outage on 400 KV Dhule-SSNNL CKT 2 & Safe working, 400 KV Dhule-SSNNL CKT 1 Auto Reclose switchwill be kept on Non Auto mode during Outage period	13-May-24	08:00	15-May-24 18:00	For Availing Outage on 400 KV Dhule-SSNNL CKT 2 & Safe working, 400 KV Dhule-SSNNL CKT 1 Auto Reclose switchwill be kept on Non Auto mode during Outage period
145	765	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-NASHIK-NAVARSARI-1	C	To make the LJO point connection at Loc. 1 (Loc. 19 of 220KV Nashik - Navsari Line) of new 220KV CPRI Line & substation	13-May-24	10:00	16-May-24 18:00	To make the LJO point connection at Loc. 1 (Loc. 19 of 220KV Nashik - Navsari Line) of new 220KV CPRI Line & substation
146	808	PLANNED	OCC_578	POWERGRID_WRI	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element.	14-May-24	14:00	14-May-24 20:00	
147	810	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-II-2	D	Relay testing work & routine maintenance work.	14-May-24	09:00	14-May-24 17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.
148	811	PLANNED	OCC_578	MSLDC_OUTAGE	TIE BAY - 765KV-AKOLA (2)-EKTUNI-1 AND PUTURI at EKTUNI - 765KV	D	Outage required for routine testing and Maintenance Works	14-May-24	10:00	14-May-24 18:00	765KV Akola 1 in service via 708 Main bay
149	812	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-BADINERA-1	D	Routine Line Maintenance Work	14-May-24	10:00	14-May-24 18:00	NA
150	821	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/RGPPPL-NAGOTHANE-1	D	Cold Washing Work	14-May-24	08:00	15-May-24 18:00	Planned outage
151	832	PLANNED	OCC_578	GETCO	220KV-TAKAPUR 1&2-VAPL-1	D	PMM work	15-May-24	6:30	15-May-24 18:00	
152	834	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/SOLAPUR-M-SOLAPUR-1	D	Hardware tightening and cold line Cleaning	15-May-24	7:00	15-May-24 14:00	Load managed on 400KV lamboti-Parli Line
153	840	PLANNED	OCC_578	POWERGRID_WRI	TIE BAY - 400KV/KHANDWA-DHULE-MS-2 AND KHANDWA - 400KV B/R 2 at KHANDWA - 400KV	D	ILBB retrofitting work, Simultaneous outage of 400KV-KHANDWA-DHULE-MS-2 and KHANDWA - 400KV B/R 2 is required for tie bay ILBB testing.	15-May-24	7:00	15-May-24 18:00	PG-WR2-KHANDWA
154	841	PLANNED	OCC_578	POWERGRID_WRI	400KV/KHANDWA-DHULE-MS-2	D	ILBB retrofitting work, Simultaneous outage of 400KV-KHANDWA-DHULE-MS-2 and KHANDWA - 400KV B/R 2 is required for tie bay ILBB testing. Line AMP Dia to kept open at for replacement of Old BHEL Insulators on gantries of element.	15-May-24	7:00	15-May-24 18:00	PG-WR2-KHANDWA
155	845	PLANNED	OCC_578	POWERGRID_WRI	WARDHA - 220KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element.	15-May-24	7:00	15-May-24 20:00	
156	846	PLANNED	OCC_578	POWERGRID_WRI	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	15-May-24	7:00	15-May-24 20:00	
157	854	PLANNED	OCC_578	POWERGRID_WRI	220KV-PARLI-HARANGUL-1	D	AMP of Line Bay	15-May-24	8:00	15-May-24 18:00	AMP of Line Bay
158	877	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	C	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	15-May-24	15:00	15-May-24 23:00	-
159	878	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	15-May-24	08:00	15-May-24 18:00	Outage
160	879	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line / S/S Maintenance.	15-May-24	09:00	15-May-24 17:30	-
161	880	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	15-May-24	09:00	15-May-24 18:00	The said work is very important
162	890	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-2	C	Replacement of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSE/CT 56, AMP works & CVT replacement at Bhadrawati end	15-May-24	8:00	17-May-24 20:00	retrofitting of pantograph isolator, CVT replacement at BVT end
163	891	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-1	C	AR IN NON AUTO	15-May-24	8:00	17-May-24 20:00	retrofitting of pantograph isolator, CVT replacement at BVT end
164	947	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KORADI-II-KORADI-III-1	D	LINE MAINT. WORKS	16-May-24	06:00	16-May-24 18:00	NA
165	948	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-EKTUNI-BABLISHWAR-2	D	Line Maintenance Works & Bay Maintenance Works	16-May-24	08:00	16-May-24 23:59	Line Maintenance Works & Bay Maintenance Works
166	949	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	For all phases conductor restringing work between tower loc no. 271 to 280.	16-May-24	08:00	16-May-24 17:00	220 KV Talangade-Chikodi line is on NO LOAD condition. is charged from chikodi end only.
167	950	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-DHULE-MS-BABLISHWAR-1	D	400 KV Dhule -Babliwar ckt 1 Routine line maintenance work	16-May-24	08:00	16-May-24 18:00	400 KV Dhule -Babliwar ckt -2 AR required in non auto mode.
168	951	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-DHULE-MS-BABLISHWAR-1	D	Routine Line maintenance work	16-May-24	08:00	16-May-24 18:00	400KV Ektuni ckt 1&11,400KV Bhussawal,400KV Aurangabad and Dhule II will be in service
169	952	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-DHULE-MS-BABLISHWAR-2	D	In view of outage on 400 KV Dhule Ckt 1 for Line maintenance work Only AR will be in Non Auto	16-May-24	08:00	16-May-24 18:00	Only AR will be in Non Auto.Line will be in service.
170	953	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	16-May-24	08:00	16-May-24 18:00	Outage
171	954	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 220KV-TALGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	16-May-24	10:00	16-May-24 13:00	Online work by Shifting on TBC
172	955	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 220KV-TALGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	16-May-24	14:00	16-May-24 17:00	Online work by Shifting on TBC
173	964	PLANNED	OCC_578	ATIL	400KV-TRODA-WARORA-2	D	Additional Earthing work. Only AR will be kept off. Line will be in service.	16-May-24	08:00	31-May-24 18:00	AR IN NON AUTO MODE. Line will be in service.
174	970	PLANNED	OCC_578	POWERGRID_WRI	TIE BAY - 400KV/KHANDWA-DHULE-MS-1 AND 400KV/220KV KHANDWA-1CT-1 at KHANDWA - 400KV	D	ILBB retrofitting work, Simultaneous outage of 400KV-KHANDWA-DHULE-MS-1 and 400KV/220KV KHANDWA-1CT-1 is required for tie bay ILBB testing.	17-May-24	7:00	17-May-24 18:00	PG-WR2-KHANDWA
175	971	PLANNED	OCC_578	POWERGRID_WRI	400KV/KHANDWA-DHULE-MS-1	D	ILBB retrofitting work, Simultaneous outage of 400KV-KHANDWA-DHULE-MS-1 and 400KV/220KV KHANDWA-1CT-1 is required for tie bay ILBB testing. Line AMP Dia to kept open	17-May-24	7:00	17-May-24 18:00	PG-WR2-KHANDWA
176	978	PLANNED	OCC_578	POWERGRID_WRI	WARDHA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element.	17-May-24	7:00	17-May-24 18:00	
177	979	PLANNED	OCC_578	POWERGRID_WRI	WARDHA - 400KV - BUS 3	D	For Replacement of Old BHEL Insulators on gantries of element.	17-May-24	7:00	17-May-24 18:00	
178	992	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHAKAN-PUNE-PG-1	D	For Hotspot rectification on 89.1 Isolator	17-May-24	9:00	17-May-24 17:30:00	Line Owned By MSE/CT 56. Trans
179	1008	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/KORADI-II-KORADI-III-2	D	LINE MAINT. WORKS	17-May-24	06:00	17-May-24 18:00	NA
180	1009	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	For all phases conductor restringing work between tower loc no. 271 to 280.	17-May-24	08:00	17-May-24 17:00	220 KV Talangade-Chikodi line is on NO LOAD condition. is charged from chikodi end only.
181	1010	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Outage required for routine testing and Maintenance Works	17-May-24	10:00	17-May-24 18:00	765KV Akola 1 in service via 708 Tie bay
182	1018	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/RGPPPL-NAGOTHANE-2	D	Cold Washing Work	17-May-24	08:00	18-May-24 18:00	Planned outage
183	1019	PLANNED	OCC_578	MSLDC_OUTAGE	400KV/KHARGHAR-PUNE-PG-1	C	Cold line washing.	17-May-24	22:00	18-May-24 05:00	-
184	1023	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	17-May-24	08:00	22-May-24 18:00	PID Work A/R Out
185	1027	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BABLISHWAR-PADGHIL-2	D	Online PID Work	17-May-24	08:00	31-May-24 18:00	Only Auto Reclose Will Be Out Line Will Be In Service. Online PID Work
186	1028	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing	17-May-24	09:00	31-May-24 18:00	Line is in service
187	1375	Planned	OCC_578	MSE/PTCL	TIE BAY - 765KV/400KV KORADI-III-1CT-2 AND PUTURI at KORADI-III - 400KV	Daily	Annual Maintenance of Bay Equipment at Koradi-III SS.	17-May-24	8:00	17-May-24 18:00	Bay Outage
188	1039	PLANNED	OCC_578	POWERGRID_WRI	400KV-KOLHAPUR-GIS-NARENDRA KUDGI-2	D	Line Bay AMP works & attending Shutdown nature defects	18-May-24	8:00	18-May-24 18:00	400KV-KOLHAPUR-GIS-NARENDRA KUDGI-1 AR to be kept in Non-auto mode for safety in TLM works.
189	1040	PLANNED	OCC_578	POWERGRID_WRI	400KV-KOLHAPUR-GIS-NARENDRA KUDGI-1	D	AR IN NON AUTO	18-May-24	8:00	18-May-24 18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continu ms	Reason	From	To	Remarks	
150	1042	PLANNED	OCC_578	POWERGRID_WRI	TIE BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND BHADRAWATI - 400KV B/R 1 at BHADRAWATI - 400KV	D	Bay AMP works	18-May-24	9:00	18-May-24 17:00	AMP works
151	1055	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	1) CT & Breaker Diagnostic Testing. 2) Line Bay shifting at 220kV Boisar-II 5/S. (From Bay No. 12 to Bay No. 14)	18-May-24	07:00	18-May-24 19:00	1) Work under the scheme of "Providing permanent second source from 400kV PGCL (Boisar) 5/S to 220kV Nalasopara 5/S.
152	1056	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TALANGDE(MS)-CHIKKODI-II-1	D	For all phases conductor restringing work between tower loc no. 271 to 280.	18-May-24	08:00	18-May-24 17:00	220 kV Talangde-Chikodi line is on NO LOAD condition. Is charged from chikodi end only.
153	1057	PLANNED	OCC_578	MSLDC_OUTAGE	BARLESHWAR - 400KV - BUS 1	D	Bus CVT and Tan delta testing	18-May-24	08:00	18-May-24 18:00	all feeders and ICT will be shifted on Main Bus II through TBC
154	1058	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-1	D	Routine Line maintenance work	18-May-24	08:00	18-May-24 18:00	400kV Padghe II will be in service
155	1060	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware tightening and cold line Cleaning	18-May-24	16:00	18-May-24 23:00	Load managed on 400kv parli-karjat ckt-1
156	1062	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work	18-May-24	22:00	19-May-24 8:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work
157	1063	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II 5/S. (From Bay No. 13 to Bay No. 12)	18-May-24	22:00	19-May-24 22:00	1) Work under the scheme of "Providing permanent second source from 400kV PGCL (Boisar) 5/S to 220kV Nalasopara 5/S.
158	262	PLANNED	OCC_578	POWERGRID_WRI	400KV-KALA-KUDUS-1	D	AMP of 400L at MSETCL Kudus Substation. 400KV-KALA-KUDUS-2 A/R to be kept in Non-Auto mode.	19-May-24	9:00	19-May-24 17:00	
159	518	PLANNED	OCC_578	POWERGRID_WRI	765KV-PUNE-GIS-SOLAPUR-1	D	PRV NC contact modification in all 3 units and Line Reactor CB AMP works. Line outage is proposed after the requirement of R/LDC	19-May-24	7:00	19-May-24 18:00	
160	519	PLANNED	OCC_578	POWERGRID_WRI	765KV-PUNE-PG-SOLAPUR-1 L/R0 SOLAPUR - 765KV	D	PRV NC contact modification in all 3 units and Line Reactor CB AMP works at 765kV Solapur Substation.	19-May-24	7:00	19-May-24 18:00	
161	932	PLANNED	OCC_578	POWERGRID_WRI	220KV-TALEGAON-PUNE-PG-2	D	For AMP Work	19-May-24	9:00	19-May-24 17:30:00	Line Owned By MSETCL Trans
162	1079	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-DHULE-MS-BARLESHWAR-2	D	Routine Line maintenance work	19-May-24	08:00	19-May-24 18:00	400kV Ekturi ckt 1&L 400kV Bhusawal,400kV Aurangabad and Dhule I will be in service
163	1080	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-DHULE-MS-BARLESHWAR-2	D	400 KV Dhule-Babulshewar ckt 2 routine Line maintenance work.	19-May-24	08:00	19-May-24 18:00	400 KV Dhule-Babulshewar ckt 1 AR switch required in non auto mode.
164	1081	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-DHULE-MS-BARLESHWAR-1	D	In view of outage on 400 KV Dhule Ckt I for Line maintenance work.Only AR will be in Non Auto	19-May-24	08:00	19-May-24 18:00	Only AR will be in Non Auto.Line will be in service.
165	1082	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-2	D	TO attend defects identified in line patrolling and to replace PID facility insulator strings.	19-May-24	09:00	19-May-24 18:00	400kV BBLR-PDG ckt -I will be in service.
166	1083	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Hardware tightening and cold line Cleaning	19-May-24	16:00	19-May-24 23:00	Load managed on 400kV Parli-karjat ckt 2
167	208	PLANNED	OCC_578	POWERGRID_WRI	400KV-KALA-KUDUS-2	D	AMP of 400L at MSETCL Kudus Substation. 400KV-KALA-KUDUS-1 A/R to be kept in Non-Auto mode.	20-May-24	9:00	20-May-24 17:00	
168	1088	PLANNED	OCC_578	POWERGRID_WRI	400KV-AKOLA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	20-May-24	7:00	20-May-24 13:00	
169	1089	PLANNED	OCC_578	POWERGRID_WRI	400KV-AKOLA-AURANGABAD-2	D	AR IN NON AUTO MODE	20-May-24	7:00	20-May-24 13:00	
170	1099	PLANNED	OCC_578	POWERGRID_WRI	AKOLA - 400KV - BUS-1 at Akola	D	For Replacement of Old BHEL Insulators on gantries of element.	20-May-24	7:00	20-May-24 20:00	
171	1109	PLANNED	OCC_578	POWERGRID_WRI	PARLI - 220KV - BUS 1	D	AMP of 220kV Bus-1 & Relay Testing	20-May-24	8:00	20-May-24 18:00	AMP of 220kV Bus-1 & Relay Testing
172	1111	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND BHADRAWATI - 400KV - BUS 2 at BHADRAWATI - 400KV	D	Bay AMP works	20-May-24	9:00	20-May-24 17:00	AMP works
173	1112	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV/220KV BOISAR-ICT-4 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP	20-May-24	9:00	20-May-24 17:30	PG-WR2-BOISAR
174	1132	PLANNED	OCC_578	MSLDC_OUTAGE	132KV-DHARNI-NIPANAGAR-1	D	For replacement of flashover disc. For fixing of turbo wind bird guard.	20-May-24	09:00	20-May-24 17:00	Outage
175	1133	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-MUTHSHINGA-CHIKKODI-II-1	D	Maintenance work	20-May-24	09:00	20-May-24 18:00	The said work is very important
176	1135	PLANNED	OCC_578	POWERGRID_WRI	765KV-AURANGABAD-PADGHE-PG-2	C	Drive Mechanism Inspection Work by OEM. (Outage of Line is PROPOSED AS PER THE REQUIREMENT OF R/LDC)	20-May-24	7:00	21-May-24 18:00	
177	1136	PLANNED	OCC_578	POWERGRID_WRI	765KV-AURANGABAD-PADGHE-PG-2 L/R0 AURANGABAD - 765KV	C	Drive Mechanism Inspection Work by OEM	20-May-24	7:00	21-May-24 18:00	707LR
178	1138	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY OF 400KV-KOLHAPUR-MS-SOLAPUR-2 AND KOLHAPUR-MS - 400KV - BUS 1 400KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	C	Main Bay PG Isolators Overhauling work	20-May-24	8:00	21-May-24 18:00	Outage required on CB only. Line can be kept in service through TBC.
179	1142	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	To carry out maintenance work and attending the problems observed in the monkey patrolling	20-May-24	07:00	21-May-24 18:00	Work to be attended by AMC agency
180	1157	PLANNED	OCC_578	POWERGRID_WRI	765KV-AURANGABAD-PADGHE-PG-2	C	Sf6 gas Leakage attending work in 7136Bph Gas compartment. AMP of Line Equipment & LR Shutdown Defect rectification of Line. All of Pune-Padghe Line to be kept OFF	20-May-24	9:00	25-May-24 17:00	
181	1161	PLANNED	OCC_578	POWERGRID_WRI	765KV-PUNE-GIS-PADGHE-PG-1	D	AR TO BE KEPT IN NON AUTO MODE	20-May-24	9:00	25-May-24 18:00	
182	1162	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	20-May-24	09:00	25-May-24 18:00	PID testing of insulator A/R function required to be in non auto mode
183	1163	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-JAGAD-1	D	Hofline insulator washing works	20-May-24	08:00	26-May-24 17:00	AR of both ckt to be disable
184	1164	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-JAGAD-2	D	Hofline insulator washing works	20-May-24	08:00	26-May-24 17:00	Both CKT AR to be disable
185	1170	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element.	21-May-24	7:00	21-May-24 13:00	
186	1171	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARDHA-AKOLA-2	D	AR IN NON AUTO MODE	21-May-24	7:00	21-May-24 13:00	
187	1180	PLANNED	OCC_578	POWERGRID_WRI	AKOLA - 400KV - BUS-2 at Akola	D	For Replacement of Old BHEL Insulators on gantries of element.	21-May-24	7:00	21-May-24 20:00	
188	1214	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element.	21-May-24	14:00	21-May-24 20:00	
189	1215	PLANNED	OCC_578	POWERGRID_WRI	400KV-WARDHA-AKOLA-1	D	AR IN NON AUTO MODE	21-May-24	14:00	21-May-24 20:00	
190	1217	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-RGPPL-NEW KOPYA-1	D	for cold washing work	21-May-24	08:00	21-May-24 18:00	nil
191	1218	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work.	21-May-24	09:00	21-May-24 17:00	Line will be charged through Tie CB 428.
192	1219	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	21-May-24	10:00	21-May-24 13:00	--
193	1220	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic testing & Maintenance work	21-May-24	10:00	21-May-24 17:00	Load will be managed on 400kV
194	1221	PLANNED	OCC_578	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND PUTURI at EKTUNI - 765KV	D	Outage required for routine testing and Maintenance Works	21-May-24	10:00	21-May-24 18:00	1500MVA 765kV/400kV ICT 1 in service via 710 Main bay
195	1222	PLANNED	OCC_578	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND PUTURI	D	Diagnostic testing & Maintenance work	21-May-24	14:00	21-May-24 17:00	--
196	1226	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-RGPPL-NEW KOPYA-1	D	Cold Washing Work	21-May-24	08:00	22-May-24 18:00	---
197	1229	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	For replacement of polymer by longrod	21-May-24	08:00	23-May-24 17:00	For replacement of polymer by longrod
198	1235	PLANNED	OCC_578	WIPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for replacement of insulator in live line method.	21-May-24	8:00	31-May-24 18:00	AR disable
199	1216	PLANNED	OCC_578	APTCL	400KV-AKOLA-AKOLA (2)-1	D	Routine Maintenance & testing Work	22-May-24	07:00	22-May-24 14:00	Yelwan ckt-02 will be in service
200	1251	PLANNED	OCC_578	POWERGRID_WRI	WARDHA - 400KV - BUS 2	D	Erection of Bus earth switch 4358BHE1 and its alignment (construction outage)	22-May-24	7:00	22-May-24 20:00	
201	1281	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	for cold washing & JUMPER lightning work	22-May-24	08:00	22-May-24 17:00	nil
202	1282	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work.	22-May-24	08:00	22-May-24 18:00	Outage

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continu-ns	Reason	From	To	Remarks	
243	1283	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-I AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	22-May-24	09:00	22-May-24 17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
244	1284	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line / S/S Maintenance.	22-May-24	09:00	22-May-24 17:30	-
245	1285	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-SOLAPUR-JELUR-1	D	Hardware tightening and cold line Cleaning	22-May-24	09:00	22-May-24 18:00	Load managed on 220KV-jour-tomburni
246	1288	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-TAPTHIHANDA-EKTUNI-2	D	To carry out maintenance work and attending the problems observed in the monkey patrolling	22-May-24	07:00	23-May-24 18:00	Work to be attended by AMC agency
247	1307	PLANNED	OCC_578	POWERGRID_WRI	PARLI - 220KV - BUS 2	D	AMP of 220KV Bus-2 & Relay Testing	23-May-24	8:00	23-May-24 18:00	AMP of 220KV Bus-2 & Relay Testing
248	1311	PLANNED	OCC_578	POWERGRID_WRI	PUNE-PG - 220KV - BUS#1	D	For Hotspot rectification	23-May-24	9:00	23-May-24 17:30:00	Before S/D of 220KV BUS_1, ALL Load on 220 Kv BUS_1 will shift on 220 Kv BUS_2 by closing respective bay 89B Isolator and Opening the respective Bay 89A Isolator and
249	1318	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	DT Work & Bay Maintenance	23-May-24	08:00	23-May-24 18:00	-
250	1319	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	23-May-24	08:00	23-May-24 18:00	Outage
251	1320	PLANNED	OCC_578	MSLDC_OUTAGE	THE BAY - 400KV-WARDHA-WARORA-I AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	23-May-24	09:00	23-May-24 17:00	Line will be charged through Main CB 429.
252	1321	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 220KV-TALGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	23-May-24	10:00	23-May-24 13:00	Online work by Shifting on TBC
253	1323	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY - 220KV-TALGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	Bus Isolators maintenance by Hot Line Unit. Line will be in service through TBC	23-May-24	14:00	23-May-24 17:00	Online work by Shifting on TBC
254	1326	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-RGPTL-NEW KOYNA-2	D	Cold Washing Work	23-May-24	08:00	24-May-24 18:00	----
255	1329	PLANNED	OCC_578	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1) Replacement of Hanger Assembly of 29 A Bus Y & B Phase PG Isolator by Hotline method.	23-May-24	09:30	26-May-24 17:00	Weather Condition Should be Clear. Hot line team will be present on site.
256	1330	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	C	1)Replacement of 29 A Bus Y & B Phase PG Isolator under LIS Scheme. 2) Line will be in service on TBC.	23-May-24	09:30	26-May-24 18:30	Weather Condition Should be Clear.
257	1322	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Routine maintenance and DT.	24-May-24	10:00	24-May-24 18:00	-
258	1340	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-AURANGABAD-M (WALU)-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	For AMP	24-May-24	7:00	24-May-24 18:00	412
259	1364	PLANNED	OCC_578	APTCL	400KV-AKOLA-AKOLA (2)-2	D	Routine maintenance & testing Work	24-May-24	07:00	24-May-24 14:00	yellow ckt-01 will be in service
260	1365	PLANNED	OCC_578	MSEPTCL	THE BAY - 765KV/400KV KORADI-II-ICT-1 AND FUTURE at KORADI-II - 400KV	D	Annual Maintenance of Bay equipment at Koradi-II SS	24-May-24	08:00	24-May-24 18:00	Bay outage
261	1366	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-AURANGABAD-CHITGAON-2	D	CT Tandelta measurement to be carried out.	24-May-24	08:00	24-May-24 18:00	220KV PGCL ckt. 1 will be in service.
262	1367	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For replacment of flashover disc. Diagnostic testing of line Bay at Badnera SS.	24-May-24	09:00	24-May-24 17:00	Outage
263	1370	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	Cold line washing.	24-May-24	22:00	25-May-24 05:00	-
264	1373	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	24-May-24	08:00	29-May-24 18:00	PID Work A/R Out
265	752	PLANNED	OCC_578	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-3	C	For attending SF6 gas leakage	25-May-24	6:00	26-May-24 6:00	
266	1067	PLANNED	OCC_578	WITPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	25-May-24	20:00	26-May-24 6:00	Outage
267	1068	PLANNED	OCC_578	WITPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	25-May-24	20:00	26-May-24 6:00	Outage
268	1381	PLANNED	OCC_578	POWERGRID_WRI	AURANGABAD - 400KV - BUS 2	D	For AMP	25-May-24	7:00	25-May-24 18:00	400KV BUS_2
269	1382	PLANNED	OCC_578	POWERGRID_WRI	400KV-ALKUD-SOLAPUR-1	D	PRV NC contact modification OF 400KV-ALKUD-SOLAPUR-1 L/R0 SOLAPUR - 400KV	25-May-24	7:00	25-May-24 18:00	
270	1396	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.	25-May-24	00:00	25-May-24 12:00	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.
271	1397	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-2	D	Routine Line maintenance work	25-May-24	08:00	25-May-24 18:00	400KV Padghe 1 will be in service
272	1398	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	For Diagnostic and Testing Activities	25-May-24	16:00	25-May-24 23:59	For Diagnostic and Testing Activities
273	1143	PLANNED	OCC_578	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-4	C	For attending SF6 gas leakage	26-May-24	6:00	28-May-24 6:00	
274	1227	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-2	C	AR IN NON AUTO	26-May-24	8:00	29-May-24 20:00	retrofitting of pantograph Isolator
275	1228	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-4	C	Replacement of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSEITCL SS.	26-May-24	8:00	29-May-24 20:00	retrofitting of pantograph Isolator
276	1407	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.	26-May-24	00:00	26-May-24 12:00	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.
277	1408	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-BARLESHWAR-PADGHE-1	D	To attend defects identified in Line patrolling and to replace PID faulty insulator strings.	26-May-24	09:00	26-May-24 18:00	400KV BBLR-PDG Ckt -2 will be in service.
278	1409	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work.	26-May-24	09:00	26-May-24 18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint & insulator cleaning work.
279	1411	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY OF 400KV-BARLESHWAR-PADGHE-2 AND BARLESHWAR - 400KV - BUS 1 @BARLESHWAR - 400KV at BARLESHWAR - 400KV	C	CS pole overhauling. 400KV Padghe-II in service through TBC.	26-May-24	09:00	29-May-24 18:00	Page line will be service through through the
280	1423	PLANNED	OCC_578	POWERGRID_WRI	AURANGABAD - 220KV - BUS 1	D	For AMP	27-May-24	7:00	27-May-24 18:00	220KV BUS_1
281	1438	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	For taking on ERS for shifting/ height rising work in between loc.1113-1115 for NHSRCL work under Project Dn, Kalwa.	27-May-24	00:00	27-May-24 12:00	For taking on ERS for shifting/ height rising work in between loc.1113-1115 for NHSRCL work under Project Dn, Kalwa.
282	1439	PLANNED	OCC_578	MSLDC_OUTAGE	133KV-DHAUNI-NEPANAGAR-1	D	For replacment of flashover disc by Hot line method.	27-May-24	09:00	27-May-24 17:00	Hot line work.
283	1440	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-B-1	D	Maintenance work	27-May-24	09:00	27-May-24 18:00	The said work is very important
284	1447	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220KV Boisar - PGCL (Dead Line). Outage required for AMP	27-May-24	05:00	31-May-24 09:00	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220KV Boisar - 220KV BUS_2
285	1456	PLANNED	OCC_578	POWERGRID_WRI	AURANGABAD - 220KV - BUS 2	D	For AMP	28-May-24	7:00	28-May-24 18:00	
286	1470	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-TARAPUR 364-PADGHE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	D	AMP of Bay Equipment	28-May-24	9:00	28-May-24 17:00	
287	1480	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For taking on ERS for shifting/ height rising work in between loc. 1096-1099 for NHSRCL work under EHV Project Dn, Kalwa.	28-May-24	00:00	28-May-24 12:00	For taking on ERS for shifting/ height rising work in between loc. 1096-1099 for NHSRCL work under EHV Project Dn, Kalwa.
288	1488	PLANNED	OCC_578	POWERGRID_WRI	KOLHAPUR-M5 - 400KV B/R 1	C	Proposed Circuit Breaker Overhauling work	28-May-24	8:00	30-May-24 18:00	400KV Bus Reactor Main Bay at MSEITCL
289	1489	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-KARAD-JAGAD-1(Taken on TBC at Jaigad end)	C	Circuit breaker Overhauling. Line will be in service through TBC at Jaigad end	28-May-24	08:00	30-May-24 18:00	Outage required for Pole Overhauling
290	1223	PLANNED	OCC_578	POWERGRID_WRI	765KV-PUNE-GIS-AURANGABAD-1	C	Drive Mechanism Inspection Work by OEM. (Outage of Line is PROPOSED AS PER THE REQUIREMENT OF RLDC)	29-May-24	7:00	30-May-24 18:00	710L
291	1224	PLANNED	OCC_578	POWERGRID_WRI	765KV-PUNE-GIS-AURANGABAD-1 L/R0 AURANGABAD - 765KV	C	Drive Mechanism Inspection Work by OEM	29-May-24	7:00	30-May-24 18:00	710LR
292	1304	PLANNED	OCC_578	POWERGRID_WRI	MAIN BAY - 400KV-KALAKUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	D	AMP of 404 bay at MSEITCL Kudus	29-May-24	9:00	29-May-24 17:00	
293	1317	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	29-May-24	08:00	29-May-24 18:00	Outage
294	1351	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-3	D	AMP works at both end	30-May-24	8:00	30-May-24 20:00	AMP works at both end
295	1352	PLANNED	OCC_578	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-4	D	AR IN NON AUTO	30-May-24	8:00	30-May-24 20:00	AMP works at both end
296	1540	PLANNED	OCC_578	MSLDC_OUTAGE	BARLESHWAR - 400KV - BUS 1	D	Bus PT Capacitance and tan delta testing	30-May-24	08:00	30-May-24 18:00	all feeders and ICT on Main Bus will be shifted on Main Bus II

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks	
297	1541	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	Maintenance work	30-May-24	08:00	30-May-24 18:00	Outage
298	1542	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) CT & CVT testing, (2) Bay maintenance work, (3) Hardware tightening & fitting work	30-May-24	09:00	30-May-24 18:00	-
299	1543	PLANNED	OCC_578	MSLDC_OUTAGE	NANDED - 400KV - BUS 1	D	CVT Tan-d testing work	30-May-24	10:30	30-May-24 18:00	-
300	1548	PLANNED	OCC_578	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	C	Cold line washing.	30-May-24	22:00	31-May-24 05:00	-
301	1549	PLANNED	OCC_578	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1.Replacement of Hanger Assembly of All Phase A Bus PG Isolator of BBLR-1 by hot line method.	30-May-24	09:30	02-Jun-24 17:00	Weather condition should be clear for hot line work. Hot line team will be present on site.
302	1550	PLANNED	OCC_578	MSLDC_OUTAGE	MAIN BAY OF 400KV-BARLESHWAR-PADGHE-1 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1.A Bus PG Isolator replacement work under LIS Scheme. 2. 400KV BBLR-1 in service through TBC at Padghe end. 3. CB Diagnostic Testing Work.	30-May-24	09:30	02-Jun-24 18:30	Weather condition should be clear.
303	1564	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-AURANGABAD-CHITGAON-2	D	Outage required for taking 220KV Bus section 1 outage for work of jumping of hybrid switchgear.	31-May-24	08:00	31-May-24 18:00	220KV Chitgaon PGCL. ckt. 1 will be in service during the outage period.
304	1565	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	31-May-24	08:00	31-May-24 18:00	PID Work A/R Out
305	1566	PLANNED	OCC_578	MSLDC_OUTAGE	220KV-WARDHIA-BADNERA-1	D	For replacement of flashover disc by Hot line method. Shifting of Auto reclose switch to non auto mode.	31-May-24	09:00	31-May-24 17:00	Hot line work.

State Element outage list for the month of MAY'2024

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	01-May-24	09:00	31-May-24	18:00	Daily	PID Testing Work.	MSETCL	MSETCL	-
2	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	02-May-24	07:00	02-May-24	13:00	Daily	Daignostic testing and allied maintenance work	MSETCL	MSETCL	Daignostic testing and allied maintenance work
3	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	02-May-24	10:30	02-May-24	18:00	Daily	Bay maintenance & relay testing work	MSETCL	MSETCL	-
4	400 KV	WARORA - IEPL	02-May-24	09:00	02-May-24	17:00	Daily	Line CT,CVT Tan delta ,IR values & Routine maintenance and and isolater maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
5	400 KV	LONIKAND - JEJURI CKT - 2	02-May-24	22:00	03-May-24	05:00	Continuous	Cold line washing.	MSETCL	MSETCL	-
6	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	02-May-24	07:00	03-May-24	18:00	Continuous	Replacement of Neutral Bushing of R & Y Ph Unit and Premonsoon Maintenance Work	MSETCL	MSETCL	NA
7	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	02-May-24	16:00	02-May-24	23.59	Daily	For Pre Monsoon Maintenance & Testing work	MSETCL	MSETCL	ICT-2 & ICT-3 will continue to remain in service
8	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	02-May-24	16:00	02-May-24	23:59	Daily	For Diagnostic and Testing Activities	MSETCL	MSETCL	For Diagnostic and Testing Activities
9	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	03-May-24	09:00	03-May-24	18:00	Daily	1) Routine Maintenance and Diagnostic Testing. 2) Line Maintenance Work.	MSETCL	MSETCL	NIL
10	400 KV	JAIGAD - NEW KOYNA CKT - 2	03-May-24	08:00	03-May-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
11	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	04-May-24	08:00	04-May-24	18:00	Daily	For premonsoon maintenance & routine maintenance works of ICT	MSETCL	MSETCL	As per annual outage plan
12	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	04-May-24	09:00	04-May-24	18:00	Daily	Disc Repalcement work loc.no.495,496	MSETCL	MSETCL	-
13	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	04-May-24	09:00	04-May-24	18:00	Daily	DFRA SFRA testing, premonsoon maintenance and quarterly bay maintenancce work.	MSETCL	MSETCL	315MVA ICT II and 501MVA III ,IV V in service
14	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	06-May-24	09:00	06-May-24	18:00	Daily	1) IV B/U relay testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
15	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	07-May-24	09:00	08-May-24	18:00	Continuous	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
16	400 KV	400/220 KV SPARE 167 MVA ICT @ ALKUD	07-May-24	10:00	07-May-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
17	400 KV	400 KV FUTURE BAY II @ WARORA	07-May-24	09:00	07-May-24	17:00	Daily	Relay testing work & routine maintenance work, Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged or
18	400 KV	400/220 KV 500 MVA ICT @ ALKUD	07-May-24	10:00	07-May-24	17:00	Daily	Diagnostic Testing and routine maintenance	MSETCL	MSETCL	Load will be managed by 400KV Karad & 400KV
19	400 KV	WARORA - IEPL	07-May-24	09:00	07-May-24	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in c

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	07-May-24	10:00	07-May-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
21	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	07-May-24	06:30	07-May-24	14:00	Daily	Daignostic testing and allied maintenance work	MSETCL	MSETCL	Daignostic testing and allied maintenance work
22	400 KV	50 MVAR LINE REACTOR OF BHUSAWAL LINE @ 400 KV KORADI	08-May-24	06:00	08-May-24	15:00	Daily	BUSHING TAN-DALTA	MSETCL	MSETCL	The outage time may be varied as per site & we
23	400 KV	PADGHE - NAGOTHANE CKT - 2	08-May-24	09:30	08-May-24	18:30	Daily	1) Bay maint work 2) Replacement of O/V and Dist relay 3) replacement of L clamp of C bus PG isolator,	MSETCL	MSETCL	weather condition should be clear
24	400 KV	GT-8 @ KORADI-2	08-May-24	09:00	08-May-24	19:30	Daily	Diagnostic Testing of Line CT & Syn CVT	MSETCL	MSETCL	NOC required from Mahagenco
25	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	08-May-24	07:00	08-May-24	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	NA
26	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	08-May-24	15:00	08-May-24	15:30	Daily	For taking 400KV Bhusawal Reactor in service.	MSETCL	MSETCL	The outage time may be varied as per site & we
27	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	08-May-24	06:00	08-May-24	06:30	Daily	For Isolate 400KV Bhusawal Reactor for bushing TAN delta	MSETCL	MSETCL	The outage time may be varied as per site & we
28	400 KV	JAIGAD - NEW KOYNA CKT - 1	08-May-24	08:00	08-May-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
29	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	09-May-24	08:00	09-May-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
30	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	09-May-24	06:00	09-May-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
31	400 KV	MAIN Bay - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	09-May-24	06:00	09-May-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
32	400 KV	BUS REACTOR (125 MVar) @ ALKUD	09-May-24	10:00	09-May-24	18:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
33	400 KV	LONIKAND I - KOYNA STAGE-IV	09-May-24	09:00	09-May-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line w
34	400 KV	LONIKAND I - KOYNA STAGE-IV	09-May-24	08:00	09-May-24	18:00	Daily	DT Work & Bay Maintenance & Insulator Cold Washing	MSETCL	MSETCL	-
35	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	09-May-24	09:30	09-May-24	18:00	Daily	For Pre Monsoon Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-3 will continue to remain in service
36	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	09-May-24	10:30	09-May-24	18:00	Daily	Pre-monsoon maintenance work	MSETCL	MSETCL	-
37	400 KV	MAIN BAY (410) OF DHARIWAL CKT - 2 @ CHANDRAPUR - 2	09-May-24	07:00	09-May-24	13:00	Daily	Daignostic testing and allied maintenance work	MSETCL	MSETCL	Daignostic testing and allied maintenance work
38	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	09-May-24	10:00	09-May-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
39	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	09-May-24	10:00	09-May-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
40	400 KV	JEJURI - KARAD	09-May-24	22:00	10-May-24	05:00	Continuous	Cold line washing.	MSETCL	MSETCL	-

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	NEW KOYNA - STAGE IV CKT - 1	09-May-24	08:00	09-May-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
42	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	10-May-24	09:00	10-May-24	18:00	Daily	1) Routine Maintenance and Diagnostic Testing. 2) Line Maintenance Work.	MSETCL	MSETCL	NIL
43	400 KV	KHADKA - BABLESHWAR	10-May-24	08:00	10-May-24	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Aurangabad ,400kV Dhule ckt I&II, Ektuni
44	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	10-May-24	09:00	10-May-24	18:00	Daily	Earthwire Stringing Work loc. no.497-500 & Nut bolt hardware tightning work	MSETCL	MSETCL	-
45	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	10-May-24	07:00	10-May-24	14:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Bhusawal line will be in service
46	400 KV	NEW KOYNA-KARAD CKT - 1	10-May-24	08:00	10-May-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line w
47	400 KV	NEW KOYNA-KARAD CKT - 2	11-May-24	08:00	11-May-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Co
48	400 KV	KARAD - TALANDGE CKT - 1	13-May-24	08:00	13-May-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Co
49	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	13-May-24	08:00	13-May-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
50	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	13-May-24	09:00	13-May-24	18:00	Daily	(1) Main-1 distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work	MSETCL	MSETCL	-
51	400 KV	CHANDRAPUR-PARLI CKT-3	14-May-24	06:00	15-May-24	18:00	Daily	1. Measurement of Bushing and Winding tandelta of 50MVAr Shunt Reactor. 2. Maintenance of reactor.	MSETCL	MSETCL	During outage 400KV CHD-2 CKT-1 & CKT-2, 4
52	400 KV	JEJURI - KARAD	14-May-24	10:00	23-May-24	17:00	Daily	Replacement of Main 1 and Main 2 dist.prot.relay panels.	MSETCL	MSETCL	NIL
53	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	14-May-24	06:30	14-May-24	14:00	Daily	Daignostic testing and allied maintenance work	MSETCL	MSETCL	Daignostic testing and allied maintenance work
54	400 KV	KORADI - KHAPERKHEDA CKT - 2	15-May-24	07:00	15-May-24	15:00	Daily	Diagnostic Testing of CTs	MSETCL	MSETCL	NA
55	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	15-May-24	16:00	15-May-24	23:59	Daily	For Diagnostic and Testing Activities	MSETCL	MSETCL	For Diagnostic and Testing Activities
56	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	15-May-24	22:00	16-May-24	8:00	Daily	For Pre Monsoon Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
57	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	16-May-24	08:00	16-May-24	23:59	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
58	400 KV	MAIN BAY (419) OF 400/220/33kv 500MVA ICT-I @ LONIKAND 2	16-May-24	06:00	16-May-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
59	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	16-May-24	09:00	16-May-24	18:00	Daily	Earthwire Stringing Work loc.no.455-457 & Nut bolt hardware tightning work	MSETCL	MSETCL	-
60	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	16-May-24	07:00	16-May-24	13:00	Daily	Daignostic testing and allied maintenance work	MSETCL	MSETCL	Daignostic testing and allied maintenance work
61	400 KV	NEW KOYNA - STAGE IV CKT - 2	16-May-24	08:00	16-May-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
62	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	16-May-24	10:30	16-May-24	18:00	Daily	Pre-monsoon maintenance work	MSETCL	MSETCL	-
63	400 KV	JEJURI- KOYNA STAGE-IV	16-May-24	08:00	16-May-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Co

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
64	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	16-May-24	06:00	16-May-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
65	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	17-May-24	07:00	17-May-24	15:00	Daily	Premonsoon Maintenance Work	MSETCL	MSETCL	NA
66	400 KV	TBC @ BABHALESHWAR	17-May-24	09:00	17-May-24	16:00	Daily	CB DCRM/Timing test	MSETCL	MSETCL	TBC will be free for availing outage
67	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	17-May-24	16:00	17-May-24	23:59	Daily	For Diagnostic and Testing Activities	MSETCL	MSETCL	For Diagnostic and Testing Activities
68	400 KV	TIE BAY (405) OF ICT-2 & FUTURE CKT - 2 @ KORADI 3	17-May-24	08:00	17-May-24	18:00	Daily	Annual maintenance of Bay equipment at Koradi-III SS	MEGPTCL	MEGPTCL	Bay outage
69	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	20-May-24	08:00	20-May-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
70	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	21-May-24	08:00	21-May-24	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal, and Dhu
71	400 KV	GT-10 @ KORADI-2	22-May-24	08:00	22-May-24	17:30	Daily	Diagnostic Testing of Line CT & Syn CVT	MSETCL	MSETCL	NOC required from Mahagenco
72	400 KV	CHANDRAPUR-PARLI CKT-3	22-May-24	09:00	22-May-24	18:00	Daily	1) Reactor testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
73	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	23-May-24	10:30	23-May-24	18:00	Daily	Annual Bay maintenance & relay testing work	MSETCL	MSETCL	-
74	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	23-May-24	10:00	23-May-24	18:00	Daily	Routine Maintenance and DT.	MSETCL	MSETCL	-
75	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	24-May-24	10:00	24-May-24	15:00	Daily	Daignostic testing and allied maintenance work	MSETCL	MSETCL	Daignostic testing and allied maintenance work
76	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	25-May-24	09:00	25-May-24	18:00	Daily	DFRA AFRA testing, premonson maintenance and quaterly bay maintenance work	MSETCL	MSETCL	ICT I III IV And V will be service
77	400 KV	CHANDRAPUR-PARLI CKT-3	27-May-24	09:00	27-May-24	18:00	Daily	Nut bolt hardware tightning work/ Spacer Repalcement	MSETCL	MSETCL	-
78	400 KV	400/220 KV 105 MVA SPARE ICT	28-May-24	09:00	28-May-24	18:00	Daily	1) Bushing & winding testing of ICT Unit.2) Bay Maintenance work.	MSETCL	MSETCL	-
79	400 KV	400/220KV 500MVA ICT 3 @ AKOLA	28-May-24	07:00	28-May-24	14:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Load will be shifted on ICT-01 & 02
80	400 KV	400/220/33 KV 500MVA ICT - 2 @ WARORA	28-May-24	09:00	28-May-24	18:00	Daily	Relay testing work & routine maintenance work etc.	MSETCL	MSETCL	Presently both bay 407 and 406 in off condition.
81	400 KV	GT-9 @ KORADI-2	29-May-24	08:00	29-May-24	18:30	Daily	Diagnostic Testing of Line CT & Syn CVT	MSETCL	MSETCL	NOC required from Mahagenco
82	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	30-May-24	10:00	30-May-24	18:00	Daily	Routine Maintenance and DT.	MSETCL	MSETCL	-
83	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	30-May-24	07:00	30-May-24	15:00	Daily	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
84	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	30-May-24	08:00	30-May-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
85	400 KV	400/220KV SPARE ICT @ JEJURI	30-May-24	09:30	30-May-24	18:00	Daily	For Pre Monsoon Maintenance & Testing work	MSETCL	MSETCL	Spare ICT is on No Load condition. All 3 ICTs wi
86	400 KV	400KV 125 MVAR BUS REACTOR @ AKOLA	31-May-24	07:00	31-May-24	14:00	Daily	routine maintenance & testing work	MSETCL	MSETCL	N.A.