

Outage Planning of Transmission elements during the month of Jun-16											
SN	KV	Element Name (as per Element List)	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
1	400	400KV RAIPUR-WARDHA II	1-Jun-16	6:00	1-Jun-16	18:00	Daily	Insulator replacement work at NH and Railway crossing.	WRTS-I	WRTS-I	C
2	220	220 kV Amona ckt Bay - 203 Bay at Mapusa	1-Jun-16	9:00	4-Jun-16	17:30	Conti.	CB Overhauling works at Mapusa. Line will be in service through transfer bay	WRTS-I	WRTS-I	R
3	765	AURANGABAD_2 MAIN BAY 710 at Solapur	1-Jun-16	9:00	1-Jun-16	21:00	DAILY	AMP WORKS ON CT AND CB	WRTS-I	WRTS-I	R
4	400	400KV Bus-I at Parli	1-Jun-16	10:00	1-Jun-16	18:00	Daily	For AMP works at Parli (PGCIL)	WRTS-I	WRTS-I	R
5	765	765KV S/C ,Aurangabad-Dhule Line with Line Reactor	1-Jun-16	7:00	1-Jun-16	18:00	Daily	For Jumper modification of Ligtening arrester for Line Reactor B phase	BDTCL	BDTCL	R
6	400 KV	Circuit breaker of 400KV Spare ICT bay @ Chandrapur	01-Jun-16	9:00	01-Jun-16	17:00	Daily	1) Measurement of CRM of CB. 2) Routine maintenance of the CB.	MSETCL	MSETCL	At present, the 105MVA spare ICT is under repairing. The CB is not in charge condition. Only permission is
7	400 KV	400 kV Chandrapur Parali CKT III	01-Jun-16	8:00	01-Jun-16	18:00	Daily	Repalcement of Damaged Earthwire	MSETCL	MSETCL	400kv Chandrapur II - Parali Ckt. I &
8	HVDC	Chandrapur -Padghe HVDC line	2-Jun-16	8:00	2-Jun-16	18:00	Daily	Powerline crossing works of 765kv D/C Hyderabad-Wardha between tower location Nos 36/0 & 37/0 (Chandrapur - Padghe Line tower nos.272 to 273)	MSETCL	WRTS-I	C
9	765	TIE_PUNE_AURANGABAD 2 TIE BAY 711 at Solapur	2-Jun-16	9:00	2-Jun-16	21:00	DAILY	AMP WORKS ON CT AND CB	WRTS-I	WRTS-I	R
10	220	203 Bay - Main Bay of Vasai Line	2-Jun-16	9:00	4-Jun-16	18:00	Contineous	Overhauling of Pneumatice Drive of all three poles of ckt Breaker	PGCIL	WR-II	R
11	400 KV	Main Bay (409 Bay) of Chandrapur I - Chandrapur II ckt-2 @ Chandrapur II s/s	02-Jun-16	6:00	02-Jun-16	12:00	Daily	Daignostic Testing & allied Bay Maintenance work	MSETCL	MSETCL	Ckt will charge through tie bay
12	400KV	Karad - LONIKAND	02-Jun-16	10:00	02-Jun-16	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other ckt.
13	400 KV	400/220KV, 315 MVA ICT I @ Chakan	02-Jun-16	0900	02-Jun-16	1800	Daily	Half yearly testing & maintenance work.	MSETCL	MSETCL	Load will be shared by 400/220kv, 3 X 105 MVA ICT II at 400kv Chakan S/s
14	400/220/33KV	315 MVA ICT-I @ Kharghar	2-Jun-16	9:00	2-Jun-16	11:00	Daily	Premonsoon R.M WORK	MSETCL	MSETCL	400/220/33kv,1X315 MVA ICT-III & 400/220/33kv , 1X315MVA ICT-II will be in service
15	400kv	Lonikand-Chakan Line	2-Jun-16	9:00	2-Jun-16	17:00	Daily	Bay & line maintenance	MSETCL	MSETCL	Load will be shared by other 400kv lines
16	400kv	Girwali-Chandrapur –III	2-Jun-16	9:00	2-Jun-16	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Girwali -Chandrapur-I & II will be in service
17	400 kV	Koradi -Bhusawal Line	2-Jun-16	12:00	2-Jun-16	18:00	Daily	PID testing of insulator strings. By Hot line Uint Akola. A/R	MSETCL	MSETCL	400 kV Akola- Bhusawal , 400 kV
18	400 kV	Main (403) Bay of Chandrapur GCR ckt-I @ Chandrapur II s/s	2-Jun-16	6:00	2-Jun-16	12:00	Daily	Daignostic Testing & allied Bay Maintenance work	MSETCL	MSETCL	
19	400 KV	Waluj-Deepnagar	2-Jun-16	11:00	2-Jun-16	17:00	Daily	PID testing	MSETCL	MSETCL	1) Work to be carried out by Hot Line
20	765	765 KV Bus # 2 at Wardha	3-Jun-16	9:00	4-Jun-16	18:00	Conti.	Bus basr extension work for Durg 3 & 4 ckt at Wardha	WRTS-I	WRTS-I	R
21	400	AURANGABAD(MSETCL)-PUNE(GIS) II & 400kv PARLI-PUNE(GIS)_1	3-Jun-16	8:00	3-Jun-16	18:00	Daily	For jumper tightening works.	WRTS-I	WRTS-I	C
22	765	SWITCHABLE LR 765kv WARDHA 2_SEONI	3-Jun-16	7:00	3-Jun-16	17:00:00 PM	Daily	AMP works (DCRM & Timing test of CB) at Seoni	WRTS-I	WRTS-I	R
23	220	ICT3_315MVA MAIN BAY 211 at Solapur	3-Jun-16	9:00	3-Jun-16	21:00	DAILY	AMP WORKS ON CT AND CB	WRTS-I	WRTS-I	R
24	765	Vadodara-Dhule	3-Jun-16	10:00	3-Jun-16	16:00	Daily	AMP works and Y phase reactor swiching with spare unit	POWERGRID	WR-II	
25	400/220/33kv	500 MVA ICT-3 @ Aurangabad	03-Jun-16	7:30	7-Jun-16	17:00	Continuous	Recomissioning of removed R-ph unit	MSETCL	MSETCL	400/220/33kv 315MVA ICT-1 &
26	400/220/33kv	315MVA ICT-3 @ Padgha	03-Jun-16	8:30	03-Jun-16	17:30	Daily	Premonsoon maintenance	MSETCL	MSETCL	
27	400 kV	Tie Bay 409 Between Bhusawal Line and Wardha Ckt 01 at 400kv RS Akola	03-Jun-16	9:00	03-Jun-16	16:00	Daily	Quarterly Bay Maintenance and Testing Work	MSETCL	MSETCL	Wardha Ckt 01 and Bhusawal Line will be in service Through respective main bays.
28	500 KV	HVDC Pole-2 @ Padgha & Chandrapur both	03-Jun-16	22:00	03-Jun-16	6:00	continuous	Premansoon maintenance	MSETCL	MSETCL	Pole-1 will be in service
29	400	AKOLA/AURANGABAD-1 Bay at Aurangabad (MSETCL)	4-Jun-16	9:00	4-Jun-16	18:00	Daily	For AMP Works at Aurangabad, Load shall be shifted to Transfer Bus	MSETCL	WRTS-I	R
30	400/220/33KV	315 MVA ICT-II @ Dhule	4-Jun-16	8:00	4-Jun-16	18:00	Daily	Routine maintenance	MSETCL	MSETCL	Other ICTs will be in service
31	400 KV	Deepnagar-Waluj	4-Jun-16	6:00	4-Jun-16	17:00	Daily	Fixing of missing & tightening of loose N/B of conductor H/W, corona Ring,arcing horn & etc at various LOCs.	MSETCL	MSETCL	
32	400/11/6.6kv	80 MVA Station TF 4A @ Deepnagar	4-Jun-16	9:00	4-Jun-16	17:00	Daily	Relay testing, CB Timing, DCRM Measurement & routine bay Maintenance.	MSETCL	MSETCL	
33	400kv	Kharghar - Padgha LINE	4-Jun-16	9:00	4-Jun-16	11:00	Daily	Premonsoon R.M WORK	MSETCL	MSETCL	400kv kalwa line will be in service
34	400/220kv	500 MVA ICT-3 @ Babhaleshwar	5-Jun-16	8:00	5-Jun-16	18:00	Daily	Hotspot attaining, CT, CB Testing work. Pre-monsoon Maint. work.	MSETCL	MSETCL	ICT 1 & 2 will be in service
35	765	765KV AURANGABAD(PG)-SOLAPUR II	5-Jun-16	8:00	5-Jun-16	18:00	Daily	Insulator replacement work at NH and Railway crossing.	WRTS-I	WRTS-I	C
36	765	765kv DURG PS -WARDHA_2	6-Jun-16	9:00	6-Jun-16	18:00	Daily	Insulator replacement work at NH and Railway crossing.	WRTS-I	WRTS-I	C
37	220	206 Bay - Main Bay of Boisar - Boisar I Line	6-Jun-16	9:00	8-Jun-16	18:00	Contineous	Overhauling of Pneumatice Drive of all three poles of ckt Breaker	PGCIL	WR-II	R
38	400/220 KV	400/220 KV ICT-1 315 MVA @ Parli	6-Jun-16	7:00	15-Jun-16	17:00	Continuous	Bushing replacement works	MSETCL	MSETCL	315 &500 MVA at Parli and 500 MVA
39	400/220 KV	315 MVA ICT-III @ Karad	6-Jun-16	10:00	6-Jun-16	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S
40	400kv	400KV Dhule - Babhaleshwar D/C	6-Jun-16	10:00	8-Jun-16	17:00	Daily	on Line PID Testing work at various locations of 400kv BBLR -I&II line.	MSETCL	MSETCL	both line will be in service

SN	KV	Element Name (as per Element List)	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
41	400 kV	New Koyna – Koyna Stage 4 ckt – I	6-Jun-16	8:00	6-Jun-16	17:00	Daily	Routine maintenance and Relay Testing work.	MSETCL	MSETCL	New Koyna – Koyna Stage 4 ckt – II will be in service
42	400	Solapur(NTPC) # 2 Main bay at Solapur(PG)	7-Jun-16	8:00	7-Jun-16	18:00	DAILY	AMP WORKS AND RELAY TESTING at Solapur	WRTS-I	WRTS-I	R
43	400	400 KV Bus # 1 at Wardha	7-Jun-16	9:00	8-Jun-16	18:00	Conti.	Bus Extension work for upcoming Aurangabad 1 & 2	WRTS-I	WRTS-I	R
44	765	Tie Bay-705 of ICT2 & DHULE line	7-Jun-16	9:00	7-Jun-16	18:00	Daily	For commissioning of CSD at Aurangabad	WRTS-I	WRTS-I	C
45	765/400	ICT2_765/400kv_AURANGABAD	7-Jun-16	16:00	7-Jun-16	18:00	Daily	For commissioning of CSD at Aurangabad	WRTS-I	WRTS-I	C
46	220	Navsari-Nashik line - 1	7/Jun/16	9:00	8/Jun/16	18:00	Daily	Condition Monitoring, Bay maint. And Line Maint.	PGCIL	GETCO	
47	400KV	Karad - TALANDAGE -I	7-Jun-16	10:00	7-Jun-16	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kV Talandge 2
48	400/220/33KV	315MVA ICT-II @ Kharghar	7-Jun-16	9:00	7-Jun-16	17:00	Daily	Testing & R.M WORK	MSETCL	MSETCL	400/220/33kv,3X105 MVA ICT-I & 400/220/33kv , 1X315MVA ICT-III will be in service
49	400	AKOLA/AURANGABAD-2 Bay at Aurangabad (MSETCL)	8-Jun-16	9:00	8-Jun-16	18:00	Daily	For AMP Works at Aurangabad, Load shall be shifted to Transfer Bus	MSETCL	WRTS-I	R
50	400/220/20kV	600 MVA ICT4 @ Padgha	08-Jun-16	8:30	08-Jun-16	17:30	Daily	Premonsoon maintenance	MSETCL	MSETCL	
51	400	Solapur(NTPC) # 2 Tie bay at Solapur(PG)	8-Jun-16	8:00	8-Jun-16	18:00	DAILY	AMP WORKS AND RELAY TESTING at Solapur	WRTS-I	WRTS-I	R
52	400	KOLHAPUR 1 MAIN BAY 415 at Solapur	8-Jun-16	9:00	8-Jun-16	21:00	DAILY	SF6 GAS LEAKAGE ARRESTING WORKS	WRTS-I	WRTS-I	R
53	765	765KV PUNE(GIS)-SOLAPUR	8-Jun-16	9:00	8-Jun-16	18:00	Daily	For tightening of jumper	WRTS-I	WRTS-I	R
54	765	Vadodara -Dhule	8-Jun-16	10:00	8-Jun-16	16:00	Daily	AMP works and B phase reactor swiching with spare unit	POWERGRID	WR-II	
55	400	SSP-Dhule line - 1	8/Jun/16	8:00	9/Jun/16	18:00	Daily	For line maint. Work	PGCIL	GETCO	Non auto reclose code for 400kv SSP-
56	400/132kV	200MVA ICT-II @ Khadka	8-Jun-16	7:00	8-Jun-16	12:00	Daily	Premansoon maintenance work of ICT	MSETCL	MSETCL	
57	400kV	400kV Girwali-Solapur	8-Jun-16	9:00	8-Jun-16	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	PGCIL Solapur will be in service
58	400 KV	Main Bay (404 Bay) of Chandrapur switching ckt-1 @ Chandrapur II s/s	08-Jun-16	6:00	08-Jun-16	12:00	Daily	Daignostic Testing & allied Bay Maintenance work	MSETCL	MSETCL	Ckt will charge through tie bay
59	400 KV	Khaperkheda-Chandrapur	08-Jun-16	8:00	08-Jun-16	17:00	Daily	During the proposed outages line maint. works such as Line	MSETCL	MSETCL	Fixing of misplaced vibration damper
60	400 KV	Main Bay 413 only of Nandgaon Line at 400kV RS Akola	08-Jun-16	9:00	08-Jun-16	16:00	Daily	Quarterly Bay Maintenance and Testing Work	MSETCL	MSETCL	Akola - Nandgaon will be in service
61	765	SOLAPUR-1 (Tie bay-708) at Aurangabad	9-Jun-16	9:00	9-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
62	400	400 KV Bus # 2 at Wardha	9-Jun-16	9:00	10-Jun-16	18:00	Conti.	Bus Extension work for upcoming Aurangabad 1 & 2	WRTS-I	WRTS-I	R
63	400	KARAD (MSETCL) MAIN BAY 412 at Solapur	9-Jun-16	9:00	9-Jun-16	21:00	DAILY	SF6 GAS LEAKAGE ARRESTING WORKS	WRTS-I	WRTS-I	R
64	220	207 Bay - Main Bay of Tarapur Line	9-Jun-16	9:00	11-Jun-16	18:00	Contineous	Overhauling of Pneumatic Drive of all three poles of ckt Breaker	PGCIL	WR-II	R
65	400 KV	Lonikand- Jejuri line	09-Jun-16	0900	09-Jun-16	1800	Daily	MAINT WORK & CVT replacement at Jejuri.	MSETCL	MSETCL	
66	400 KV	400/220kV, 315 MVA ICT II @ Chakan	09-Jun-16	0900	09-Jun-16	1800	Daily	Half yearly testing & maintenance work.	MSETCL	MSETCL	Load will be shared by 400/220kV, 3 X
67	400 kV	Akola-Nandgaonpeth	09-Jun-16	12:00	09-Jun-16	18:00	Daily	PID testing of insulator strings. By Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal , 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service
68	400 KV	Tie Bay 412 and Main Bay 413 of 400 KV Chandrapur ckt-I @ Warora	9-Jun-16	8:00	9-Jun-16	17:00	Daily	C and Tandelta of 400KV Line CVT and CRM of CB	MSETCL	MSETCL	400KV Chandrapur Ckt-II will be in service
69	400 KV	Nagothane-Padghe Line 1	9-Jun-16	8:00	9-Jun-16	18:00	Daily	Replacing faulty disc's of insulatorstring as per the PID report. Tightening of jumper nut bolts at cut-point locations.	MSETCL	MSETCL	
70	400 KV	Waluj-Thaptitanda	9-Jun-16	11:00	9-Jun-16	17:00	Daily	PID testing	MSETCL	MSETCL	1) Work to be carried out by Hot Line
71	765	765kv AURANGABAD(PG)-SOLAPUR I	10-Jun-16	8:00	10-Jun-16	18:00	Daily	Insulator replacement work at NH and Railway crossing.	WRTS-I	WRTS-I	C
72	765	SOLAPUR-1 (Main Bay-707) at Aurangabad	10-Jun-16	9:00	10-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
73	400/220 Kv	500 MVA ICT 2 @ Lonikand II	10-Jun-16	09:00	10-Jun-16	18:00	Daily	Half yearly maintenance & diagnostic testing	MSETCL	MSETCL	Total Load can be managed by
74	400	ICT2_315MVA_MAIN BAY 407 at Solapur	10-Jun-16	9:00	10-Jun-16	21:00	DAILY	SF6 GAS LEAKAGE ARRESTING WORKS	WRTS-I	WRTS-I	R
75	400 KV	BBLR- Thapti Tanda 2 Line	10-Jun-16	09:00	10-Jun-16	17:00	Daily	Bay Maintenance work. Relay / CB / CT Testing	MSETCL	MSETCL	BBLR- Thapti Tanda 1 Line will be in service
76	400kV	Lonikand-Stage IV Line	10-Jun-16	9:00	10-Jun-16	17:00	Daily	Bay & line maintenance	MSETCL	MSETCL	Load will be shared by other 400kV lines
77	400 KV	Nagothane-Padghe Line 2	10-Jun-16	8:00	10-Jun-16	18:00	Daily	Replacing faulty disc's of insulatorstring as per the PID report. Tightening of jumper nut bolts at cut-point locations.	MSETCL	MSETCL	
78	400kV	Ramagundam-CHANDRAPUR-1	6/10/2016	8:00	6/10/2016	18:30	ODB	Bhadrawati pole -2 outage are also planned by WR 10th June, TTC/ATC curtailment upto 500 MW.	NTPC		
79	400	MAUDA_2 Main Bay (430) at Wardha	11-Jun-16	9:00	11-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
80	400	PARLI 2 Tie bay (408) at Wardha	11-Jun-16	9:00	11-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
81	400	SWITCHABLE LR_400KV_KARAD_SOLAPUR	11-Jun-16	9:00	11-Jun-16	21:00	DAILY	PRD OIL LEAKGAE AND COLLECTION OF BUSHING OIL SAMPLE at Solapur	WRTS-I	WRTS-I	R
82	400 KV	Deepnagar-Waluj	11-Jun-16	6:00	11-Jun-16	17:00	Daily	Fixing of missing & tightening of loose N/B of conductor H/W, corona Ring,arcing horn & etc at various LOCs.	MSETCL	MSETCL	
83	400/220/33KV	315MVA ICT-I @ Dhule	11-Jun-16	8:00	11-Jun-16	18:00	Daily	Routine maintenance	MSETCL	MSETCL	Other ICTs will be in service
84	400/11/6.6kV	80 MVA Station TF 4B @b Deepnagar	11-Jun-16	9:00	11-Jun-16	17:00	Daily	Relay testing, CB Timing, DCRM Measurement & routine bay Maintenance.	MSETCL	MSETCL	
85	400kV	Ramagundam-CHANDRAPUR-2	6/11/2016	7:00	6/19/2016	19:00	ODB	Bhadrawati pole outages are also planned alternately by WR during 10th June to 19th June, TTC/ATC curtailment upto 500 MW for each pole.	POWERGRID		

SN	KV	Element Name (as per Element List)	From		To		Basis	Reason	System	Agency	Type
			Date	Time	Date	Time					
86	400	SSP-Dhule line - 2	12/Jun/16	8:00	13/Jun/16	18:00	Daily	For line maint. Work	PGCIL	GETCO	Non auto reclose code for 400kv SSP-
87	400	MAUDA_2 Tie Bay (431) at Wardha	12-Jun-16	9:00	12-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
88	400 KV	Waluj-Thaptitanda	12-Jun-16	11:00	12-Jun-16	17:00	Daily	PID testing	MSETCL	MSETCL	1) Work to be carried out by Hot Line
89	400	Boisar-Padghe(including LILO portion)	12-Jun-16	8:00	13-Jun-16	18:00	Daily	Replacement of insulator discs by Polymer long rod insulators. A/R of Vapi-Boisar shall be remained in Non-Auto mode	POWERGRID	WR-II	C
90	400	Chandrapur -Parli D/C line	13-Jun-16	8:00	13-Jun-16	18:00	Daily	Powerline crossing works of 765kV D/C Hyderabad-Wardha between tower location Nos 23/0 & 24/0 (Chandrapur -Parli DC 400KV Line tower nos.226 to 227)	MSETCL	WRTS-I	C
91	400	MAUDA_1 Main Bay 433 at Wardha	13-Jun-16	9:00	13-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
92	765	Seoni # 2 Main Bay at Wardha	13-Jun-16	9:00	13-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
93	765	SOLAPUR-2 (Main Bay-710) at Aurangabad	13-Jun-16	9:00	13-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
94	400 KV	Tie Bay (411 Bay) of Station TF 8 A & Chandrapur II ckt-2 @ Switching s/s	13-Jun-16	6:00	13-Jun-16	12:00	Daily	Daignostic Testing & allied Bay Maintenance work	MSETCL	MSETCL	Ckt will charge through its main bay
95	400/220/20KV	300 MVA ICT-1 @ Koradi s/s	13-Jun-16	10:00	13-Jun-16	17:00	Daily	Tan delta measurement of bushing & predictive maintenance work	MSETCL	MSETCL	315MVA 400/220/33KV ICT-2 will be in service
96	400 kv	New Koyna – Koyna Stage 4 ckt – II	13-Jun-16	8:00	13-Jun-16	17:00	Daily	Routine maintenance and Relay Testing work.	MSETCL	MSETCL	New Koyna – Koyna Stage 4 ckt – I will be in service
97	400kv	400KV Dhule-SSNNL line D/C	14-Jun-16	10:00	16-Jun-16	17:00	Daily	on Line PID Testing work at various locations of 400kv SSNNL –I&II line.	MSETCL	MSETCL	both line will be in service
98	400	Akola # 1 Main Bay at Wardha	14-Jun-16	9:00	14-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
99	400	MAUDA_1 Tie Bay 434 at Wardha	14-Jun-16	9:00	14-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
100	220	Navsari-Nashik line - 2	14/Jun/16	9:00	15/Jun/16	18:00	Daily	Condition Monitoring, Bay maint. And Line Maint.	PGCIL	GETCO	
101	400/220/33kv,	105MVA, 1 ph. Spare ICT unit at 400KV RS Akola	14-Jun-16	8:00	14-Jun-16	16:00	Daily	Quarterly Bay Maintenance and Testing Work	MSETCL	MSETCL	This is Spare ICT unit on NO LOAD.
102	400	Akola # 2 Main Bay at Wardha	14-Jun-16	9:00	14-Jun-16	18:00	Daily	AMP work at Wardha	WRTS-I	WRTS-I	R
103	765	TIE_WARDHA 2 - SOLAPUR 2 (Tie Bay-711) at Aurangabad	14-Jun-16	9:00	14-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
104	400 KV	Main Bay (410 Bay) of station TF 8 A @ Chandrapur Switching s/s	15-Jun-16	6:00	15-Jun-16	12:00	Daily	Daignostic Testing & allied Bay Maintenance work	MSETCL	MSETCL	Ckt will charge through tie bay
105	400	AURANGABAD(MSETCL)-PUNE(GIS) I & 400kv PARLI-PUNE(GIS)_2	16-Jun-16	8:00	16-Jun-16	18:00	Daily	For jumper tightening works.	WRTS-I	WRTS-I	R
106	HVDC	HVDC_POLE1_BHADRAWATI	16-Jun-16	9:00	23-Jun-16	18:00	Conti.	Placement of new convertor transformer at Bhadrawati	WRTS-I	WRTS-I	C
107	400 KV	404 CB- MAIN CB OF ICT II @ Jejuri	16-Jun-16	0930	16-Jun-16	1730	Daily	ANNUAL TESTING AND MAINT WORK	MSETCL	MSETCL	NO FEEDER/ICT INTERRUPTION, ICT II WILL REMAIN IN SERVICE THROUGH TIE CB 405
108	400kv	Lonikand- Karad Line	16-Jun-16	9:00	16-Jun-16	17:00	Daily	Bay & line maintenance	MSETCL	MSETCL	Load will be shared by other 400kv lines
109	400kv	400KV Girwali-PGCIL Ckt I	16-Jun-16	9:00	16-Jun-16	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Girwali-PGCIL Ckt II will be in service
110	400kv	Tie Bay 415 and Main Bay 416 of 400 KV Chandrapur ckt-II @ Warora	16-Jun-16	8:00	16-Jun-16	17:00	Daily	C and Tandelta of 400KV Line CVT and CRM of CB	MSETCL	MSETCL	400KV Chandrapur Ckt-I will be in service
111	400kv	Main Bus – II @ Talandge	16-Jun-16	10:00	18-Jun-16	18:00	Continuous	1. Replacement of Pentagraph Isolator of a. Kolhapur PG-I 89B Y phase & b. Kolhapur PG-II 89B B phase, 2. Alignment & servicing of All 'B' Bus Pentagraph Isolators, 3. Annual Busbar Testing & Bus CVT Testing work.	MSETCL	MSETCL	Load will be managed on 400 kv Main Bus -I
112	400 kv	Akola-Bhusawal	16-Jun-16	12:00	18-Jun-16	18:00	Daily	PID testing of insulator strings. By Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal , 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in
113	400	400KV RAIPUR-WARDHA I & 400KV RAIPUR-WARDHA II	17-Jun-16	9:00	18-Jun-16	18:00	Daily	Construction work of 765 kv Raipur-Wardha Ckt-3&4	WRTS-I	WRTS-I	C
114	400	Vapi - Boisar	17-Jun-16	8:00	19-Jun-16	19:00	Daily	Replacement of all suspection porcelain disc insulator strings with Composite polymer insulators in entire line to prevent tripping of important line due to insulator flashover due to pollution. A/R of Boisar-Padge to kept in non auto mode while working in LILO poriton	POWERGRID	WR-II	C
115	400kv	Main Bus-2 @ Koradi s/s	17-Jun-16	9:00	17-Jun-16	17:00	Daily	Tan delta measurement of bushing & predictive maintenance work	MSETCL	MSETCL	Main bus-1 wil be available
116	400/220/33kv,	400/220/33kv, 315MVA, ICT No 01 at 400KV RS Akola	17-Jun-16	8:00	17-Jun-16	18:00	Daily	Quarterly Bay Maintenance and Diagnostic Testing Work	MSETCL	MSETCL	ICT will be out of service
117	400kv	Babhaleshwar-Dhule 1 ckt.	18-Jun-16	9:00	18-Jun-16	17:00	Daily	Bay Maintenance work. Relay / CB / CT Testing	MSETCL	MSETCL	Babhaleshwar-Dhule 2 ckt will be in service.
118	400kv	50MVAR Bus Reactor @ Khadka	18-Jun-16	7:00	18-Jun-16	12:00	Daily	Premansoon maintenance work of reactor.	MSETCL	MSETCL	

SN	KV	Element Name	From	To		Basis	Reason	System	Agency	Type	
119	400/220kV	500 MVA ICT No.2 @ Warora	20-Jun-16	8:00	20-Jun-16	17:00	Daily	Pre monsoon maintenance	MSETCL	MSETCL	Charged on No Load
120	400 KV	400 KV Dhariwal -Chandrapur-II 400 KV D/C Tr. Line	20-Jun-16	8:00 AM	30-Jun-16	18:00	Daily	For Puncture Insulator Detection Testing (PID) of insulator string of line(Both Ckt-I&II) by LIVE LINE METHOD only auto reclosure to be bypassed.	MSETCL	Dhariwal Infrastructure Ltd.	
121	400	400kV KORADI-SATPURA	20-Jun-16	6:00	25-Jun-16	18:00	Daily	Online OPGW work. A/R to be kept in Non auto mode	WRTS-I	WRTS-I	C
122	400	400kV KORADI-SATPURA	20-Jun-16	6:00	21-Jun-16	18:00	Daily	For stringing & crossing works of up-coming Mauda-Batul line	WRTS-I	WRTS-I	C
123	400	400kV PUNE(GIS)-Aurangabad_1 & 2	20-Jun-16	6:00	19-Jul-16	18:00	Daily	Online OPGW work. A/R to be kept in Non auto mode	WRTML/	WRTS-I	C
124	400	400kV WARDHA-MAUDA I & II	20-Jun-16	6:00	19-Jul-16	18:00	Daily	Online OPGW work & PID Testing . A/R to be kept in Non auto mode	WRTS-I	WRTS-I	C
125	765	765kV SEONI-WARDHA I	20-Jun-16	6:00	19-Jul-16	18:00	Daily	Online OPGW work. A/R to be kept in Non auto mode. For installation of 48 OPGW cable at repeater station.	WRTS-I	WRTS-I	C
126	400kV	Babhaleshwar - Dhule D/C	20-Jun-16	6:00	19-Jul-16	18:00	Daily	OPGW Work	MSETCL	MSETCL	
127	400KV	Dhule- Babhaleshwar ckt I & II	20-Jun-16	10:00	22-Jun-16	17:00	Daily	on Line PID Testing work at various locations of 400kV BBLLR -I&II line.	MSETCL	MSETCL	since PID is conducted online. Only auto reclosure switch is required to be kept in non auto mode.
128	400kV	Karad - Kolhapur D/C	20-Jun-16	6:00	19-Jul-16	18:00	Daily	OPGW Work	MSETCL	MSETCL	
129	400kV	Karad - Solapur (PG)	20-Jun-16	6:00	19-Jul-16	18:00	Daily	OPGW Work	MSETCL	MSETCL	
130	400KV	Main BAY (403) of ICT at APML Tiroda Plant	20-Jun-16	6:00	20-Jun-16	18:00	Daily	MAINTENANCE & TESTING WORK	MEGPTCL	MEGPTCL	
131	400kV	Parli-Solapur	20-Jun-16	6:00	19-Jul-16	18:00	Daily	OPGW Work	MSETCL	MSETCL	
132	400	Solapur-Kolhapur-1&2	20-Jun-16	6:00	19-Jul-16	18:00	Daily	Online OPGW work. A/R to be kept in Non auto mode	WRTML	WRTS-I	C
133	765KV	SWITCHABLE LR_765KV_RAICHUR_1_SOLAPUR	20-Jun-16	9:00	20-Jun-16	11:00	Daily	NGR bypass CB jumpering works at Solapur	WRTS-I	WRTS-I	C
134	400/220 Kv	167 MVA Spare ICT @ Warora	21-Jun-16	8:00	21-Jun-16	17:00	Daily	Pre monsoon maintenance	MSETCL	MSETCL	Charged on No Load
135	765	765kV DURG PS -WARDHA_1	21-Jun-16	9:00	21-Jun-16	9:30	Daily	To take out Wardha-Durg # 1 Line Reactor at Wardha for RTV Coating work (Line will be in service without Reactor & reactor will be taken in service at 18:00 hours)	WRTS-I	WRTS-I	C
136	400	Main Bus-2 at Koradi s/s	21-Jun-16	9:00	21-Jun-16	17:00	Daily	Tan delta measurement of CVT & predictive maintenance work	MSETCL	MSETCL	
137	400	SSNNL-Dhule -1	21/Jun/16	9:00	23/Jun/16	18:00	Daily	PMM work	PGCIL	GETCO	
138	765KV	SWITCHABLE LR_765KV_RAICHUR_2_SOLAPUR	21-Jun-16	9:00	21-Jun-16	11:00	Daily	NGR bypass CB jumpering works at Solapur	WRTS-I	WRTS-I	C
139	765	TIE BAY Aurangabad-1 (717) at Wardha S/S	21-Jun-16	9:00	21-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
140	765KV	Akola-II to Ektuni Line - 2	22-Jun-16	6:00	22-Jun-16	18:00	Daily	Faulty Y phase metering CVT Replacement work at Akola-II substation	MEGPTCL	MEGPTCL	
141	400kV	400kV Akola Yelwan Ckt 01 at 400kV RS Akola	22-Jun-16	9:00	22-Jun-16	18:00	Daily	APTCL work of ABT metering and Routine maintenance, Testing Works.	MSETCL	MSETCL	Line will be out of service. Ckt 02 will be in Service.
142	765	765kV DURG PS -WARDHA_2	22-Jun-16	9:00	22-Jun-16	9:30	Daily	To take out Wardha-Durg # 2 Line Reactor at Wardha for RTV Coating work (Line will be in service without Reactor & reactor will be taken in service at 18:00 hours)	WRTS-I	WRTS-I	C
143	400	BUS REACTOR_400kV_80MVAR_DHULE	22-Jun-16	9:00	30-Jun-16	18:00	Conti.	For overhauling of 80MVAR Bus Reactor and CB at Dhule MSETCL S/S.	WRTS-I	MSETCL	R
144	765/400	ICT2_765/400kv_AURANGABAD	22-Jun-16	9:00	22-Jun-16	11:00	Daily	for change of phase combination at Aurangabad for RTV coating	WRTS-I	WRTS-I	R
145	765KV	Main BAY (701) of ICT at APML Tiroda Plant	22-Jun-16	6:00	22-Jun-16	18:00	Daily	MAINTENANCE & TESTING WORK	MEGPTCL	MEGPTCL	
146	400	Solapur-2 Main Bay (412)	22-Jun-16	9:00	22-Jun-16	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R
147	765KV	SWITCHABLE LR_765KV_PUNE_SOLAPUR	22-Jun-16	9:00	22-Jun-16	11:00	Daily	NGR bypass CB jumpering works at Solapur	WRTS-I	WRTS-I	C
148	400 KV	TBC @ Karad	22-Jun-16	10:00	22-Jun-16	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	
149	400/220kV	Spare ICT @ Kolhapur	23-Jun-16	10:00	23-Jun-16	17:00	Daily	Quarterly Maint. Work	MSETCL	MSETCL	
150	400/220/33 KV	315 MVA ICT-I @ Chandrapur I	23-Jun-16	8:00	23-Jun-16	18:00	Daily	1) For checking the heathyness of OLTC 2) For attending the 04 nos. Hot spot on PG-II & PG-I Isolator. 3) Measurement of DCRM of CB. 4) Routine maintenance of the ICT.	MSETCL	MSETCL	During the outage period, 400/220/33kV, 315 MVA ICT-II will be in service. Outage will be availed considering the weather condition.
151	400kV	400kV Akola Yelwan Ckt 02 at 400kV RS Akola	23-Jun-16	9:00	23-Jun-16	18:00	Daily	APTCL work of ABT metering and Routine maintenance, Testing Works.	MSETCL	MSETCL	Line will be out of service. Ckt 01 will be in Service.
152	400	400kV BHADRAVATI-PARLI I & 400KV DHARIWAL TPP-PARLI II	23-Jun-16	8:00	23-Jun-16	18:00	Daily	Powerline crossing works of 765kV D/C Hyderabad-Wardha between tower location Nos 26/0 & 27/0 (400kV D/C Bhadravati-Parli Transmission line tower nos.215 to 216). Bhadravati-Dhariwal will remain in charged condition.	WRTS-I	WRTS-I	C
153	400KV	405 CB Tie-bay of Koyna stg-IV & ICT-2 @ jejuri	23-Jun-16	9:00	23-Jun-16	17:00	Daily	Annual testing & Maintenance	MSETCL	MSETCL	No interruption on any
154	765	765 KV Seoni # 2 Main Bay 701 at Wardha	23-Jun-16	9:00	23-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
155	765/400	ICT1_765/400kv_AURANGABAD	23-Jun-16	9:00	23-Jun-16	11:00	Daily	for change of phase combination at Aurangabad for RTV coating	WRTS-I	WRTS-I	R
156	400kV	Lamboti - Parli line	23-Jun-16	10:00	23-Jun-16	18:00	Daily	Quarterly. Maint. Work & Line signature	MSETCL	MSETCL	Load will be manage on
157	400	PUNE(GIS)-PUNE(TALEGOAN)_3 & 4	23-Jun-16	10:00	23-Jun-16	16:00	Daily	Maintenance work	Rinfra	Rinfra	R
158	220	Tarapur - Boisar S/C Line	23-Jun-16	7:00	24-Jun-16	18:00	Daily	Power Line crossing for Stringing work of Navsari Boisar Line (for AP 346-347 and Loc 354/0-355/0)	PGCIL	WR-II	C
159	400kV	Warora-IEPL Line	23-Jun-16	9:00	23-Jun-16	18:00	Daily	For Replacement of Corona ring	MSETCL	MSETCL	IEPL will be fed from
160	400/220/33	315 MVA ICT-2 @ Waluj	24-Jun-16	7:30	24-Jun-16	17:00	Daily	89C PGI overhauling work	MSETCL	MSETCL	400/220/33kv 315MVA
161	400KV	Kolhapur - Solapur(PG) - 1	24-Jun-16	10:00	24-Jun-16	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kv
162	765/400kV	1500 MVA ICT at APML Tiroda plant	24-Jun-16	6:00	24-Jun-16	18:00	Daily	MAINTENANCE & TESTING WORK	MEGPTCL	MEGPTCL	
163	400 KV	400 KV Nagothane - Padghe - 1	24-Jun-16	9:00	24-Jun-16	17:00	Daily	MAINTENANCE & TESTING WORK	MSETCL	MSETCL	

SN	KV	Element Name	From	To		Basis	Reason	System	Agency	Type	
164	765	765 KV Seoni # 2 Main Bay 702 at Wardha	24-Jun-16	9:00	24-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
165	400 kV	Akola- Bhusawal Line	24-Jun-16	12:00	29-Jun-16	18:00	Daily	PID testing of insulator strings by Hot line Unit Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola- Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service.
166	400	AURANGABAD(MSETCL)-PUNE(GIS) I & II	24-Jun-16	6:00	25-Jun-16	18:00	Conti.	Stringing of up-coming 765KV D/C Aurangabad – Padge Transmission Line	Reliance & WRTS-I	WRTS-I	C
167	765	BUS REACTOR Main Bay-701 at A'bad	24-Jun-16	9:00	24-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
168	400kV	Chandrapur - Nanded Line	24-Jun-16	8:00	24-Jun-16	18:00	Daily	For replacement of damaged earthwire	MSETCL		
169	400kV	Ektuni- Bableshtar- I Line	24-Jun-16	9:00	24-Jun-16	17:00	Daily	Bay Maintenance work. Relay / CB / CT Testing	MSETCL	MSETCL	400 kV Thapti Tanda –II
170	400	SSNNL-Dhule -2	24/Jun/16	9:00	27/Jun/16	18:00	Daily	PMM work	PGCIL	GETCO	
171	400KV	Khadka-Deepnagar -I	25-Jun-16	9:00	25-Jun-16	17:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
172	400KV	Kolhapur - Solapur(PG) - 2	25-Jun-16	10:00	25-Jun-16	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kV
173	400 KV	400 KV Nagothane - Padghe - 2	25-Jun-16	9:00	25-Jun-16	17:00	Daily	MAINTENANCE & TESTING WORK	MSETCL	MSETCL	
174	400	409 Parli # 2 Main Bay at Wardha	25-Jun-16	9:00	25-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
175	220	Dahanu Versova	25-Jun-16	7:00	26-Jun-16	18:00	Daily	Tower Erection of Navsari Boisar Line Loc 339 A/0. Outage is required due to heavy induction from line	Reliance	WR-II	C
176	220	Dhanau Ghodbunder Line 1	25-Jun-16	7:00	26-Jun-16	18:00	Daily	Tower Erection of Navsari Boisar Line Loc 339 A/0. Outage is required due to heavy induction from line	Reliance	WR-II	C
177	400KV	Dhule-SSNNL ckt - I	25-Jun-16	8:00	25-Jun-16	18:00	Daily	Replacement of string identify suspicious in PID at loc no 84 & 85	MSETCL	MSETCL	
178	132	Newasa – Bableshtar	25-Jun-16	6:00	26-Jun-16	18:00	Conti.	Stringing of up-coming 765KV D/C Aurangabad – Padge Transmission Line	WRTS-I	MSETCL	C
179	765	SWITCHABLE LR_765KV_PADGHE1_AURANGABAD	25-Jun-16	7:00	25-Jun-16	16:00	Daily	Solapur-1 line switchable Reactor for AMP Works at Aurangabad	WRTS-I	WRTS-I	R
180	400 KV	Kalwa - Padgha - II	26-Jun-16	9:00	26-Jun-16	18:00	Daily	RM work	MSETCL	MSETCL	
181	400/220/33 KV	315 MVA ICT-II @ Chandrapur I	26-Jun-16	8:00	26-Jun-16	18:00	Daily	1)For checking the heathyness of OLTC 2) For attending the 04 nos. Hot spot on PG-II & PG-I Isolator. 3) Measurement of DCRM of CB. 4) Routine maintenance of the ICT.	MSETCL	MSETCL	During the outage period, 400/220/33KV (3x 105) MVA ICT-I will be in service. Outage will be availed considering the weather condition.
182	HVDC	500KV CHANDRAPUR-PADGHE HVDC LINE	26-Jun-16	8:00	26-Jun-16	18:00	Daily	Powerline crossing works of 765kV D/C Hyderabad-Wardha between tower location Nos 36/0 & 37/0 (Chandrapur -Padghe Line tower nos.272 to 273)	MSETCL	WRTS-I	C
183	400	Boisar Vapi Line	26-Jun-16	7:00	27-Jun-16	18:00	Continuous	Power Line crossing for Stringing work of Navsari Boisar Line (AP 03 - 04)	PGCIL	WR-II	C
184	400	Boisar Padghe Line	26-Jun-16	7:00	27-Jun-16	18:00	Continuous	Power Line crossing for Stringing work of Navsari Boisar Line (AP 03 - 04)	PGCIL	WR-II	C
185	220	Dhanau Ghodbunder Line 1	26-Jun-16	7:00	27-Jun-16	18:00	Continuous	Power Line crossing for Stringing work of Navsari Boisar Line (AP 339/0 - 339 A/0)	Reliance	Reliance	C
186	220	Dhanau Ghodbunder Line 2	26-Jun-16	7:00	27-Jun-16	18:00	Continuous	Power Line crossing for Stringing work of Navsari Boisar Line (AP 339/0 - 339 A/0)	Reliance	Reliance	C
187	400	Tarapur Boisar Line 2	26-Jun-16	7:00	27-Jun-16	18:00	Continuous	Power Line crossing for Stringing work of Navsari Boisar Line (AP 03 - 04)	PGCIL	WR-II	C
188	400	Tarapur Boisar Line 1	26-Jun-16	7:00	27-Jun-16	18:00	Continuous	Power Line crossing for Stringing work of Navsari Boisar Line (AP 03 - 04)	PGCIL	WR-II	C
189	400/220/33	315 MVA ICT-2 on TBC @ Waluj	27-Jun-16	7:30	27-Jun-16	17:00	Daily	89A PGI overhauling work	MSETCL	MSETCL	Load on TBC
190	765	765KV PUNE(GIS)-SOLAPUR	27-Jun-16	9:00	27-Jun-16	18:00	Daily	For attending earthwire stringing work between Loc No 62B/0 to 62C/0	WRTS-I	WRTS-I	R
191	765	765KV SEONI-WARDHA I	27-Jun-16	9:00	27-Jun-16	14:00	Daily	To attend CVT connector problem at Wardha	WRTS-I	WRTS-I	R
192	400kV	Babhaleshtar- Khadka Line	27-Jun-16	9:00	27-Jun-16	17:00	Daily	Bay Maintenance work. Relay / CB / CT Testing	MSETCL	MSETCL	400KV Dhule 1, Dhule 2,
193	765	ICT1_1500MVA (Main Bay-703) at Aurangabad	27-Jun-16	9:00	27-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
194	400KV	New Koyna – Dabhol – II	27-Jun-16	8:30	27-Jun-16	17:30	Daily	Routine maintenance work	MSETCL	MSETCL	400KV NK – Dabhol – I will
195	765	Vadodara-Dhule Line Main Bay (701) at Vadodara	27-Jun-16	10:00	27-Jun-16	18:00	Daily	AMP works	PGCIL	WR-II	
196	400	400kV DHARIWAL TPP-PARLI II	28-Jun-16	9:00	29-Jun-16	18:00	Daily	For insulator replacement works in NH / SH & Railway crossing for public safety.	WRTS-I	WRTS-I	C
197	400	400 KV Khandwa-Dhule-2 line	28-Jun-16	9:00	28-Jun-16	16:00	Daily	Terminal equipoment AMP and bushing oil sampling -3rd Cycle at both ends	PGCIL	WR-II	R
198	400	400kV BHADRAVATI-PARLI I	28-Jun-16	9:00	28-Jun-16	18:00	Daily	For insulator replacement works in NH / SH & Railway crossing for public safety.	WRTS-I	WRTS-I	C
199	765	765 KV Bus Reactor # 2 Tie Bay 711 at Wardha	28-Jun-16	9:00	28-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
200	400 kV	Chandrapur - Nanded Line	28-Jun-16	8:00	28-Jun-16	18:00	Daily	For replacement of damaged earthwire	MSETCL	MSETCL	
201	400kV	Main Bay 404 only of A'Bad Ckt 01 at 400kV RS Akola	28-Jun-16	10:00	28-Jun-16	16:00	Daily	Quarterly Bay Maintenance and Testing Work	MSETCL	MSETCL	Akola - A'Bad Ckt 01 will
202	220kV	Mudshingi-Chikodi	28-Jun-16	8:00	28-Jun-16	18:00	Daily	MAINTENANCE & TESTING WORK	MSETCL	MSETCL	
203	765	Vadodara-Dhule Line Tie Bay (702) at Vadodara	28-Jun-16	10:00	28-Jun-16	18:00	Daily	AMP works	PGCIL	WR-II	R
204	400KV	400 KV Dhariwal-Chandrapur-II Ckt-I	29-Jun-16	09:00 AM	30-Jun-16	18:00	Continuous	Preventive maintenance 400KV Line-1 bay equipments at Dhariwal end s/stn.	MSETCL	Dhariwal	
205	400	400KV Parli-Solapur-1 Line	29-Jun-16	9:00	29-Jun-16	18:00	Daily	For AMP works of line terminating equipments at Parli	Reliance	WRTS-I	R
206	765	765 KV Durg # 2 Main Bay 715 at Wardha	29-Jun-16	9:00	29-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
207	400KV	C'pur Switching-Chandrapur-II ckt-II(Main Bay-412) at 400KV C'pur	29-Jun-16	9:00	29-Jun-16	14:00	Daily	Diagnostic Testing & allied Bay Maintenance work	MSETCL	MSETCL	During the outage period,
208	220	D/C Jalna – Waluj	29-Jun-16	6:00	30-Jun-16	18:00	Conti.	Stringing of up-coming 765KV D/C Aurangabad – Padge Transmission Line	WRTS-I	MSETCL	C
209	765	DHULE (Main Bay-704)	29-Jun-16	9:00	29-Jun-16	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R
210	400/220kV	500MVA ICT-III @ Parli	30-Jun-16	9:00	30-Jun-16	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	-
211	400KV	Chandrapur -Khaperkheda Line bay at Chandrapur	30-Jun-16	8:00	30-Jun-16	18:00	Daily	1) Measurement of Tan delta & capacitance of CT's & CVT's. 2)Measurement of CRM of CB. 2)	MSETCL	MSETCL	Outage will be availed

SN	KV	Element Name	From		To		Basis	Reason	System	Agency	Type
212	400KV	Khadka-Deepnagar -II	30-Jun-16	9:00	30-Jun-16	17:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
213	400kv	Lonikand-Jejuri Line	30-Jun-16	9:00	30-Jun-16	17:00	Daily	Bay & line maintenance	MSETCL	MSETCL	Load will be shared by
214	765	765 KV Aurangabad # 3 Main Bay 719 at Wardha	30-Jun-16	9:00	30-Jun-16	18:00	Daily	AMP work at Wardha S/S	WRTS-I	WRTS-I	R
215	400Kv	Lamboti- PGCIL Line	30-Jun-16	10:00	30-Jun-16	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load will be manage on
216	400Kv	Main Bay 407 only of A'Bad Ckt 02 at 400KV RS Akola	30-Jun-16	10:00	30-Jun-16	16:00	Daily	Quarterly Bay Maintenance and Testing Work	MSETCL	MSETCL	Akola - A'Bad Ckt 02 will