

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
1	15	400	400KV Bhadrawati - Chandrapur- 1	1-Jun-17	6:00	1-Jun-17	15:00	Daily	Replacement of CVT under R&M	WRTS-I	WRTS-I	R	LINE
2	16	765	765KV Solapur-Pune(GIS) line reactor at Pune GIS	1-Jun-17	6:00	1-Jun-17	15:00	Daily	For CSD works of line reactor as CSD is not working properly in some of the operations	WRTS-I	WRTS-I	C	LR
3	18	400	400KV SOLAPUR - KOLHAPUR # 1	1-Jun-17	6:00	1-Jun-17	19:00	Daily	power line crossing of solapur solapur ntpc 3,4	WRTS-I	WRTS-I		Maharashtra cosnent required
4	19	400	400KV SOLAPUR - KOLHAPUR # 2	1-Jun-17	6:00	1-Jun-17	19:00	Daily	power line crossing of solapur solapur ntpc 3,4	WRTS-I	WRTS-I		Maharashtra cosnent required
5	20	400	Wardha - Akola ckt - 1	1-Jun-17	6:00	1-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
6	21	400	400KV Khandwa-Dhule Ckt-I	1-Jun-17	6:00	5-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-II	WRTS-I	C	LINE
7	22	400	400 KV MAIN BUS II @Jejuri	1-Jun-17	9:30	1-Jun-17	17:30	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
8	23	500	HVDC Pole-1 Chandrapur	1-Jun-17	20:00	2-Jun-17	2:00	Continuous	For pre-monsoon maintenance	MSETCL	MSETCL		
9	24	400	400KV Dabhol -Nagothane -Ckt-2	1-Jun-17	6:00	3-Jun-17	18:00	Daily	Hill cutting work by Civil department	MSETCL	MSETCL		
10	25	400/220	167 MVA Spare ICT bay No 401 at Lonikand-II S/stn.	1-Jun-17	6:00	1-Jun-17	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
11	26	400/132	200 MVA ICT 1 at 400KV Khadka	1-Jun-17	8:30	1-Jun-17	12:00	Daily	Pre Monsoon Maintenance Work	MSETCL	MSETCL		
12	27	400/220	315 MVA ,ICT -1 @ Chakan	1-Jun-17	6:00	1-Jun-17	15:00	Daily	Half yearly Maint . Work	MSETCL	MSETCL		SLDC Maharashtra to manage the load.
13	37	400	400 kV Bhadrawati - Parli # 01.	1-Jun-17	8:00	1-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
14	48	400	Jaigad-Newkoyana Ckt - 1&2	1-Jun-17	6:00	15-Jun-17	15:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both ciruicts to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		subjected to schedule at JSW
15	49	220	Wardha PG-Pusad-S/c	1-Jun-17	8:00	30-Jun-17	16:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
16	50	400	Karad - New Koyna ckt 1	1-Jun-17	5:00	30-Jun-17	17:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL		
17	51	400	Lonikand - Koyna Stage-IV	1-Jun-17	5:00	30-Jun-17	17:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL		
18	62	400	Koyna Stage IV-jejuri	1-Jun-17	6:00	1-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		
19	67	400	New Koyna-Karad ckt 1	2-Jun-17	6:00	3-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		400 KV New Koyna-Karad ckt 2 will be in service
20	68	400	Chandrapur (Old GCR)-Parli Ckt-III line Reactor @ Parli	2-Jun-17	6:00	6-Jun-17	14:00	Daily	Reactor painting work. Only reactor will be taken out of circuit. Line will be charged subsequently.	MSETCL	MSETCL		
21	69	400	ICT-2 at Boisar	2-Jun-17	6:00	2-Jun-17	15:00	Daily	AMP	POWER GRID	WR-II	R	

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
22	81	400	400KV PARLI(PG)-PARLI(MSETCL) I	2-Jun-17	10:00	2-Jun-17	18:00	Daily	For AMP works of line terminating equipments at Parli	WRTS-I	WRTS-I	R	Line
23	82	765	BUS REACTOR_765KV_240MVAR_PUNE(GIS)	2-Jun-17	6:00	2-Jun-17	15:00	Daily	For CSD instaltn & commissioning works	WRTS-I	WRTS-I	C	BR
24	83	400	414 BAY (Tie Bay of 400KV Talegaon Lonikand Line & Bus Reactor) at Talegaon	2-Jun-17	6:00	2-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay
25	84	400	SOLAPUR_BAY 417_TIE BAY_PARLI#2 AND KOLHAPUR#2	2-Jun-17	6:00	2-Jun-17	15:00	Daily	AMP WORKS	WRTS-1	POWERGRID	R	BAY
26	85	220	220KV Bus Coupler 201 at Wardha	2-Jun-17	6:00	2-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Bay
27	88	400	Wardha - Akola ckt - 2	2-Jun-17	6:00	2-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
28	89	400	400/220/33 KV ICT-2 @ Koradi-1 S/S	2-Jun-17	8:00	2-Jun-17	17:00	Daily	Diagnostic Testing and Preventive Bay maintenance.	MSETCL	MSETCL		
29	90	765	Bus reactor of bay-703 at MEGPTCL 765/400KV Akola-II SS	2-Jun-17	7:00	2-Jun-17	15:00	Daily	For changeover of Spare reactor against Bph Bus reactor of 703bay at MEGPTCL-765/400KV Akola-II Substation	MEGPTCL	MEGPTCL		
30	91	400	Deepnagar-Waluj Ckt at 400kv Deepnagar	2-Jun-17	6:00	2-Jun-17	14:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
31	92	220	Chitegaon-Abad (PGCIL) Ckt.-I @Chitegaon	2-Jun-17	8:00	2-Jun-17	19:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL		
32	99	400	400 KV Parli-1 (MSETCL) Main Bay (415) at parli	2-Jun-17	10:00	2-Jun-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	to be done along with ckt outage
33	100	400	400 kv Dhariwal TPP- Parli # 02.	2-Jun-17	8:00	2-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
34	107	400	400 kv Parli-Nanded Ckt-II @ Parli	2-Jun-17	6:00	15-Jun-17	14:00	Daily	For Earthwire tightening work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
35	113	400	400kv KOLHAPUR (MSETCL)- KOLHAPUR (GIS) - I	3-Jun-17	10:00	3-Jun-17	18:00	Daily	For replacement of Mother board in PLCC channel-I.	WRTS-I	WRTS-I	R	LINE
36	115	400	Bus Coupler @ Padgha	3-Jun-17	8:00	3-Jun-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
37	119	400	400 KV BUS-2 at Talegaon	3-Jun-17	6:00	3-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bus
38	121	400	SOLAPUR_BAY 418_MAIN BAY_KOLHAPUR#2 at Solapur	3-Jun-17	6:00	3-Jun-17	15:00	Daily	AMP WORKS	WRTS-1	POWERGRID	R	BAY
39	122	765	ICT #2 Main Bay 706 at Wardha	3-Jun-17	6:00	3-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Bay
40	124	400	Wardha - Akola ckt - 1	3-Jun-17	6:00	3-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
41	127	400/220	501 MVA, ICT III @ BBLR	3-Jun-17	8:00	3-Jun-17	17:00	Daily	Quarterly/pre monsoon Maintenance work	MSETCL	MSETCL		400/220kv 315MVA ICT-I, ICT-II & 500MVA ICT-IV will be in service
42	128	400/132	200 MVA ICT 2 at 400kv Khadka	3-Jun-17	8:30	3-Jun-17	12:00	Daily	Pre Monsoon Maintenance Work	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
43	138	400	400kV Lonikand-Karad Line	4-Jun-17	8:00	4-Jun-17	16:00	Daily	Routine Maintenance work, Line Maint work	MSETCL	MSETCL		
44	142	765	TIE_SOLAPUR_1 bay-708 at Aurangabad	4-Jun-17	6:00	4-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
45	150	400	Kharghar-Talegaon-S/c	4-Jun-17	8:00	4-Jun-17	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
46	153	400	400kV NewKoyna-Dabhol -Ckt-2	4-Jun-17	6:00	5-Jun-17	18:00	Daily	Replacement of Faulty Insulator String found during PID test.	MSETCL	MSETCL		
47	156	765	765kV Solapur-1 Switchable Line Reactor at Aurangabad	5-Jun-17	6:00	5-Jun-17	15:00	Daily	For RTV coating on 765kV Trench Bushings of Reactors	WRTS-I	WRTS-I	C	Reactor
48	170	765	TIE_WARDHA_3 bay-717 at Aurangabad	5-Jun-17	6:00	5-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
49	175	400	400kV PUNE(GIS)-PUNE(TALEGOAN)_1	5-Jun-17	14:00	5-Jun-17	17:30	Daily	For attending the Hydraulic Oil Leakage in CB Compartment at Pune GIS.	WRTS-I	WRTS-I	R	BAY
50	176	400	ICT # 1 at Talegaon	5-Jun-17	6:00	5-Jun-17	15:00	Daily	For AMP and Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	ICT
51	177	220	SOLAPUR_220KV BUS#2	5-Jun-17	6:00	5-Jun-17	15:00	Daily	AMP WORKS	WRTS-1	POWERGRID	R	BUS
52	178	765	SOLAPUR_BAY 707_MAIN BAY_765KV AURANGABAD#1	5-Jun-17	6:00	5-Jun-17	15:00	Daily	AMP WORKS	WRTS-1	POWERGRID	R	BAY
53	179	765	Wardha - Nbad #2 Main bay 704 at Wardha	5-Jun-17	6:00	5-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Bay
54	181	400	Wardha - Akola ckt - 1	5-Jun-17	6:00	5-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
55	182	400	Solapur - Kolhapur - 2	5-Jun-17	9:30	5-Jun-17	11:30	Daily	CT/PT Integration for Feeder for PMU WORKS	WRTS-II	WRTS-I	C	LINE
56	186	400	Chandrapur - Khaperkheda	5-Jun-17	6:00	6-Jun-17	19:00	Daily	Replacement of broken / damaged disc insulators & tightening of conductor & earthwire hardware	MSETCL	MSETCL		
57	187	400/220/33	315 MVA ICT-III @KARAD	5-Jun-17	10:00	5-Jun-17	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL		Load manage on other Two ICT'S
58	188	400	400KV TBC-II Bay @400KV S/S Chandrapur	5-Jun-17	8:00	9-Jun-17	18:00	Continuous	1) Servicing & Overhauling of PG-I , PG-II & PG-III Isolator. 2) Alignment of Isolators.	400KV AC	MSETCL		
59	189	500	HVDC Pole-2 Chandrapur	5-Jun-17	20:00	6-Jun-17	2:00	Continuous	For pre-monsoon maintenance	MSETCL	MSETCL		
60	190	400	New Koyna-Karad ckt 2	5-Jun-17	6:00	6-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		400 KV New Koyna-Karad ckt 1 will be in service
61	191	400/220	315 MVA ICT 3 at 400kV Khadka	5-Jun-17	8:30	5-Jun-17	12:00	Daily	Pre Monsoon Maintenance Work	MSETCL	MSETCL		
62	192	220	Wardha PG-Badnera	5-Jun-17	10:00	5-Jun-17	17:00	Daily	Quarterly/ Routine Maintenance of Bays Equipment	MSETCL	MSETCL		
63	199	400	Kalwa-Padgha Ckt-2	5-Jun-17	8:00	5-Jun-17	17:00	Daily	Faulty insulator replacement ,Maintenance & Dignostic testing work	MSETCL	MSETCL		
64	200	400	400kV Khadka-Koradi at 400kV Khadka	5-Jun-17	6:00	5-Jun-17	18:00	Daily	During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
65	203	765	765kV Solapur-2 Switchable Line Reactor at Aurangabad	6-Jun-17	6:00	6-Jun-17	15:00	Daily	For RTV coating on 765kV Trench Bushings of Reactors	WRTS-I	WRTS-I	C	Reactor
66	209	400	400KV BUS -1 @ 400 kV Akola	6-Jun-17	8:00	6-Jun-17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
67	210	400	Talandge - Alkud @ Talandge	6-Jun-17	10:00	6-Jun-17	18:00	Daily	Quarterly Maintenance work	PGCIL	MSETCL		SLDC Maharashtra consent required.
68	211	400	407 Main Bay of ICT-1 at BDTCL Bhopal	6-Jun-17	7:00	6-Jun-17	18:00	Daily	For AMP	BDTCL	BDTCL	R	
69	222	765	Wardha-3 Main bay-718 at Aurangabad	6-Jun-17	6:00	6-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
70	225	400	400kv PARLI(PG)-PARLI(MSETCL) II	6-Jun-17	10:00	6-Jun-17	18:00	Daily	For AMP works of line terminating equipments at Parli	WRTS-I	WRTS-I	R	Line
71	226	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_2	6-Jun-17	9:30	6-Jun-17	13:00	Daily	For attending the Hydraulic Oil Leakage in CB Compartment	WRTS-I	WRTS-I	R	BAY
72	227	400	400kv Bus Coupler at Pune(GIS)	6-Jun-17	14:00	6-Jun-17	17:30	Daily	For attending the Hydraulic Oil Leakage in CB Compartment	WRTS-I	WRTS-I	R	BAY
73	228	765	SOLAPUR_BAY 710_MAIN BAY_765KV AURANGABAD#2	6-Jun-17	6:00	6-Jun-17	15:00	Daily	AMP WORKS	WRTS-2	POWERGRID	R	BAY
74	229	765	Wardha-Aur'bad # 1 Switchable Line Reactor at Wardha	6-Jun-17	6:00	6-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Line
75	230	400	Karad - TALANDAGE -I @ KARAD	6-Jun-17	10:00	6-Jun-17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL		
76	231	400	315 MVA 400 KV/ ICT 1@New Koyna	6-Jun-17	8:00	6-Jun-17	18:00	Daily	Routine Maintenance work & Relay testing Work	MSETCL	MSETCL		
77	232	400/220	315MVA, ICT 2 @ Kharghar	6-Jun-17	6:00	6-Jun-17	14:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
78	233	400	400 KV Tiroda - Warora Line-2	6-Jun-17	8:00	6-Jun-17	18:00	Daily	For Annual Maintenace of Transmission Line	ATIL	ATIL		SPS to be in service
79	244	400	Wardha - Parli - I	6-Jun-17	9:30	6-Jun-17	11:30	Daily	CT/PT Integartion for Feeder for PMU WORKS	WRTML	WRTS-I	R	TTC revision for WR-SR
80	245	400	Wardha - Parli - II	6-Jun-17	13:30	6-Jun-17	15:30	Daily	CT/PT Integartion for Feeder for PMU WORKS	WRTML	WRTS-I	R	TTC revision for WR-SR
81	246	400	400kV Dabhol -Nagothane -Ckt-1	6-Jun-17	6:00	7-Jun-17	18:00	Daily	Replacement of Faulty Insulator String found during PID test.	MSETCL	MSETCL		
82	253	400	ICT # 2 at Talegaon	7-Jun-17	6:00	7-Jun-17	15:00	Daily	For AMP & Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	ICT
83	254	400	Wardha - Akola ckt - 2	7-Jun-17	6:00	7-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
84	264	400	SSP - Dhule - 2	7-Jun-17	8:00	7-Jun-17	22:00	Continuous	Relay testing , New relay Retrofitting & Pre-Monsson maintenance work.	SSP	NCA		
85	265	765	TIE_WARDHA_4 bay-720 at Aurangabad	7-Jun-17	6:00	7-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
86	269	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_3	7-Jun-17	9:30	7-Jun-17	13:00	Daily	For attending the Hydraulic Oil Leakage in CB Compartment	WRTS-I	WRTS-I	R	BAY

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
87	270	400	400Kv PUNE(GIS)-PUNE(TALEGOAN)_4	7-Jun-17	14:00	7-Jun-17	17:30	Daily	For attending the Hydraulic Oil Leakage in CB Compartment	WRTS-I	WRTS-I	R	BAY
88	272	400	Wardha - Akola ckt - 1	7-Jun-17	6:00	7-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	R	LINE
89	273	765	Main bay of Bus reactor #2 712 at Wardha	7-Jun-17	6:00	10-Jun-17	15:00	Continuous	All 6 poles CB Mechanism Boxes Replacement Work	WRTS-I	WRTS-I		Bay
90	275	220	Nashik- Navsari ckt-1	7-Jun-17	8:00	10-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work Cold line insulator Washing work	MSETCL	MSETCL		
91	276	400	315 MVA 400 KV/ ICT 2@New Koyna	7-Jun-17	8:00	7-Jun-17	18:00	Daily	Routine Maintenance work & Relay testing Work	MSETCL	MSETCL		
92	277	220	220KV Wardha - PGCIL (DEOLI)	7-Jun-17	10:00	7-Jun-17	16:00	Daily	1)Measurement of Tan-Delta & Capacitance value of C.T.'s. & CC's 2) Measurement of Timing and CRM of C.B. 3) Bay Routine maintenance work.	MSETCL	MSETCL		
93	278	400	428-Bay (Tie Bay of 400kv Warora-Wardha line) at PGCIL-deoli Substation	7-Jun-17	6:00	7-Jun-17	15:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL		
94	279	400	400KV 50 MVAR Akola Line Reactor at 400KV Khadka	7-Jun-17	8:30	7-Jun-17	12:00	Daily	Pre Monsoon Maintenance Work	MSETCL	MSETCL		
95	286	400	Tarapur-Padghe-I	7-Jun-17	8:00	7-Jun-17	18:00	Daily	Powerline crossing work of Aurangabad-Boisar line	POWER GRID	WR-II	C	
96	291	400	400 kV Akola- Bhusawal Line	7-Jun-17	10:00	8-Jun-17	16:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL		
97	294	400	SSP - Dhule - 1	8-Jun-17	8:00	9-Jun-17	22:00	Daily	Relay testing , New relay Retrofitting & Pre-Monsson maintence work.	SSP	NCA		
98	299	400	ICT # 3 at Talegaon	8-Jun-17	6:00	8-Jun-17	15:00	Daily	For AMP & Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	ICT
99	309	400	AURANGABAD(PG) - AURANGABAD(MSETCL) _ 1	8-Jun-17	6:00	8-Jun-17	15:00	Daily	For line AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Line
100	311	400	400Kv PARLI-PUNE(GIS)_1	8-Jun-17	9:30	8-Jun-17	13:00	Daily	For attending the Hydraulic Oil Leakage in CB Compartment at Pune GIS.	WRTS-I	WRTS-I	R	BAY
101	312	400	400Kv PARLI-PUNE(GIS)_2	8-Jun-17	14:00	8-Jun-17	17:30	Daily	For attending the Hydraulic Oil Leakage in CB Compartment at Pune GIS.	WRTS-I	WRTS-I	R	BAY
102	313	400	400KV Talegaon Shikrapur GIS Line # 1 Reactor (Since the Reactor is switchable Line will remain in Service) at Talegaon	8-Jun-17	6:00	8-Jun-17	15:00	Daily	For AMP & Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	Switchable Reactor
103	315	400	400KV KOLHAPUR GIS-PUNE(FUTURE) MAIN BAY (409 BAY) AT KOLHAPUR(GIS)	8-Jun-17	10:00	8-Jun-17	18:00	Daily	For bay AMP works.	WRTS-I	WRTS-I	R	BAY
104	316	400	Wardha - Akola ckt - 2	8-Jun-17	6:00	8-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
105	318	400	401 CB BUS CB OF ICT I @ Jejuri	8-Jun-17	9:30	8-Jun-17	17:30	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		ICT I will be in service through tie CB 402
106	319	400	400KV Lonikand-Stg IV Line	8-Jun-17	8:00	8-Jun-17	16:00	Daily	Line Maint work by Lonikand	MSETCL	MSETCL		
107	320	400	Chandrapur 2 - Warora Ckt-2	8-Jun-17	6:00	9-Jun-17	19:00	Daily	Fitting & tightening of jumper cone bolts, conductor and earthwire hardware	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
108	321	400/220	315 MVA ,ICT -2 @ Chakan	8-Jun-17	6:00	8-Jun-17	15:00	Daily	Half yearly Maint . Work	MSETCL	MSETCL		
109	328	400	Tarapur-Boisar-I	8-Jun-17	8:00	8-Jun-17	18:00	Daily	Powerline crossing work of Aurangabad-Boisar line	POWER GRID	WR-II	C	
110	332	400	400KV Dhule-SSNNL Ckt-I & II	8-Jun-17	7:00	9-Jun-17	15:00	Daily	PID testing. A/R in Non Auto Mode .	MSETCL	MSETCL		
111	334	400	Padghe-Boisar @ Padgha	9-Jun-17	8:00	9-Jun-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
112	335	400	400 KV A Bus @Lonikand II	9-Jun-17	6:00	9-Jun-17	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
113	348	400	400KV Talegaon Shikrapur GIS Line # 2 Reactor (Since the Reactor is switchable Line will remain in Service) at Talegaon	9-Jun-17	6:00	9-Jun-17	15:00	Daily	For AMP & Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	Switchable Reactor
114	349	765	Wardha Aurangabad Ckt-3	9-Jun-17	6:00	9-Jun-17	15:00	Daily	Line Maintenance Works	WRTS-I	WRTS-I	R	Line
115	350	400	Wardha - Akola ckt - 1	9-Jun-17	6:00	9-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
116	351	400	400KV Stage 4 -New Koyna -Ckt-1 @Stage 4	9-Jun-17	8:00	9-Jun-17	18:00	Daily	Routine Maintenance work & replacement of faulty CVT's	MSETCL	MSETCL		
117	352	400	400 KV TBC Reactor @Koradi-1 S/S	9-Jun-17	8:00	9-Jun-17	17:00	Daily	Diagnostic Testing and Preventive Bay maintenance.	MSETCL	MSETCL		
118	353	400	400 kV Akola- Wardha Ckt-1 @ 400 kV Akola	9-Jun-17	8:00	9-Jun-17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
119	354	400	415-Bay (Tie Bay of 400kV Adani-2and Chandrapur-2) at Warora Substation	9-Jun-17	8:00	9-Jun-17	18:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL		
120	355	400	Deepnagar-Taptitanda Ckt at 400KV Deepnagar	9-Jun-17	6:00	9-Jun-17	14:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
121	356	400	50 MVAR Koradi Line Reactor at 400kV Khadka	9-Jun-17	8:30	9-Jun-17	12:00	Daily	Pre Monsoon Maintenance Work	MSETCL	MSETCL		
122	357	400	Babhaleshwar bay @ 400KV R.S. Waluj	9-Jun-17	6:00	9-Jun-17	14:00	Daily	Quarterly Maintenance	MSETCL	MSETCL		
123	358	400	Talandge - Karad 1 @ Talandge	9-Jun-17	10:00	9-Jun-17	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL		
124	359	400	3x200MVA ,ICT-4 @ Padgha	9-Jun-17	8:00	9-Jun-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
125	367	220	Bay no-205 Main Bay of 220 Transfer Bus at Boisar	9-Jun-17	6:00	9-Jun-17	15:00	Daily	AMP	POWER GRID	WR-II	R	
126	369	400	400 kV Bhadrawati - Parli # 01.	9-Jun-17	8:00	9-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
127	372	400	Boisar-Vapi	9-Jun-17	6:00	11-Jun-17	16:00	Daily	Online permit for power line crossing of Aurangabad-Boisa line.Auto Recloser in Non-Auto Mode	POWER GRID	WR-II	C	
128	373	400	Boisar-Padghe	9-Jun-17	6:00	11-Jun-17	16:00	Daily	Online permit for power line crossing of Aurangabad-Boisa line.Auto Recloser in Non-Auto Mode	POWER GRID	WR-II	C	
129	374	400	400 KV Bus 1 at Wardha SS	10-Jun-17	6:00	11-Jun-17	15:00	Continuous	Bus extension for Aurangabad bays	WRTS-I	WRTS-I	C	Bus

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
130	377	400	400KV Khandwa-Dhule Ckt-II	10-Jun-17	6:00	14-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-II	WRTS-I	C	LINE
131	379	400	Koyna Stage IV-jejuri	10-Jun-17	6:00	10-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		
132	380	400	Koyna Stage IV- Lonikand	10-Jun-17	6:00	11-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		
133	387	400	400KV Talegaon Shikrapur GIS Line # 3 Reactor (Since the Reactor is switchable Line will remain in Service) at Talegaon	10-Jun-17	6:00	10-Jun-17	15:00	Daily	For AMP & Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	Switchable Reactor
134	389	400	765/400 kV ICT #1 Main bay 404 at Wardha	10-Jun-17	6:00	10-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Bay
135	390	400	A Bus with B/C @Kharghar	10-Jun-17	6:00	11-Jun-17	14:00	Continuous	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
136	391	765	line reactor of bay-703 main bay of 765KV Akola-II Ektuni line-2 at MSETCL-765/400KV Ektuni SS (Aurangabad-II).	10-Jun-17	12:00	10-Jun-17	17:00	Daily	For taking 703-Bph reactor against spare reactor of 765KV Akola-II Ektuni Line-2 at Ektuni SS Aurangabad-II).	MSETCL	MEGPTCL		765KV Akola-II Ektuni line-2 interupption required for isolation of non switchable reactor
137	392	400	80 MVAR BUS Reactor-II @ BBLR	10-Jun-17	6:00	10-Jun-17	14:00	Daily	Maintenance work	MSETCL	MSETCL		80MVAR Reactor I will be in service
138	393	220	Bay no-211 Main Bay of 220 Boisar-Boisar-II at Boisar	10-Jun-17	6:00	10-Jun-17	15:00	Daily	AMP	POWER GRID	WR-II	R	
139	395	400	400 kV Dhariwal TPP- Parli # 02.	10-Jun-17	8:00	10-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
140	405	400	400 kV Bhadrawati - Parli # 01.	11-Jun-17	8:00	11-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
141	406	400	Kalwa-Padgha Ckt-2	11-Jun-17	8:00	11-Jun-17	17:00	Daily	Faulty insulator replacement	MSETCL	MSETCL		
142	410	400	AURANGABAD(PG) - AURANGABAD(MSETCL) _ 2	12-Jun-17	6:00	12-Jun-17	15:00	Daily	For line AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Line
143	411	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) I	12-Jun-17	9:30	12-Jun-17	13:00	Daily	For attending the Hydraulic Oil Leakage in CB Compartment at Pune GIS.	WRTS-I	WRTS-I	R	BAY
144	412	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) II	12-Jun-17	14:00	12-Jun-17	17:30	Daily	For attending the Hydraulic Oil Leakage in CB Compartment at Pune GIS.	WRTS-I	WRTS-I	R	BAY
145	414	400	Chandrapur 2 - Warora Ckt-1	12-Jun-17	6:00	12-Jun-17	19:00	Daily	Fitting & tightening of jumper cone bolts, conductor and earthwire hardware	MSETCL	MSETCL		
146	415	400	Koyna Stage IV-jejuri	12-Jun-17	6:00	12-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		
147	418	400	400KV SSNNL-Dhule-1	12-Jun-17	8:00	12-Jun-17	18:00	Daily	PMM work	GETCO	GETCO		
148	422	765	765kv Bus_1 at Aurangabad	12-Jun-17	6:00	12-Jun-17	15:00	Daily	For construction of new solpaur bays	WRTS-I	WRTS-I	C	Bus
149	424	400	400KV Talegaon Shikrapur GIS Line # 4 Reactor (Since the Reactor is switchable Line will remain in Service) at Talegaon	12-Jun-17	6:00	12-Jun-17	15:00	Daily	For AMP & Painting (Fire Fighting Pipe Line) works	WRTS-I	WRTS-I	R	Switchable Reactor
150	425	400	ICT3_400/220kv_SOLAPUR	12-Jun-17	6:00	12-Jun-17	15:00	Daily	CSD COMMISSIONING WORKS	WRTS-1	POWERGRID	C	ICT

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRDLC/SLDC Comments
				Date	Time	Date	Time						
151	426	400	765/400 KV ICT #3 Main bay 410 at Wardha	12-Jun-17	6:00	12-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
152	429	220	Nashik- Navsari ckt-2	12-Jun-17	8:00	15-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work Cold line insulator Washing work	MSETCL	MSETCL		
153	430	400	400kV NewKoyna-Karad -Ckt-2 @New koyna	12-Jun-17	8:00	12-Jun-17	18:00	Daily	Routine Maintenance work & Relay testing Work	MSETCL	MSETCL		
154	431	400	400kV 50 MVAR Bus Reactor at 400kV Khadka	12-Jun-17	8:30	12-Jun-17	12:00	Daily	Pre Monsoon Maintenance Work	MSETCL	MSETCL		
155	432	400/220	315 MVA, ICT 2 @ Talandge	12-Jun-17	10:00	12-Jun-17	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL		
156	442	400	Aurangabad line Reactor-I at Boisar	12-Jun-17	8:00	13-Jun-17	18:00	Daily	Jumper work of 400KV Aurangabad-Boisar Line Equipment	POWER GRID	WR-II	C	
157	444	400	400 kV Dhariwal TPP- Parli # 02.	12-Jun-17	8:00	12-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
158	450	400	400 kV Akola- Nandgaonpeth Line	12-Jun-17	10:00	14-Jun-17	16:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL		
159	451	400	400KV Dhule-SSNNL Ckt-I & II	12-Jun-17	7:00	13-Jun-17	15:00	Daily	PID testing. A/R in Non Auto Mode .	MSETCL	MSETCL		
160	452	400	Parli-Solapur line @ Parli	13-Jun-17	10:00	13-Jun-17	18:00	Daily	Fixing of hardware at Loc No-40,28,11.	MSETCL	MSETCL		
161	453	400	Parli -Solapur(M) ckt @ Parli (Line reactor at Parli)	13-Jun-17	6:00	16-Jun-17	14:00	Daily	Reactor painting work. Only reactor will be taken out of circuit. Line will be charged subsequently.	MSETCL	MSETCL		Line will be on outage for whole day on 1st day of proposed outage date. Bay maintenance will be done at Girawali s/s. After bay maintenance
162	454	400	AURANGABAD(PG) - AKOLA - 1	13-Jun-17	6:00	13-Jun-17	15:00	Daily	For line AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Line
163	457	400	Jaigad-Newkoyna Ckt- 1	13-Jun-17	8:00	13-Jun-17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
164	459	400	400KV SSNNL - Dhule - 2 & A/r in N/a of Ckt-1	13-Jun-17	8:00	13-Jun-17	18:00	Daily	PMM work	GETCO	GETCO		
165	466	400	ICT-1 Main bay-401 at Aurangabad	13-Jun-17	6:00	13-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
166	468	400	400 KV Parli (PG)-2 Main Bay(412) at MSETCL Girawli	13-Jun-17	10:00	13-Jun-17	18:00	Daily	For Bay AMP works at MSETCL Girawli	WRTS-I	WRTS-I	R	Bay
167	469	400	403 BAY (Main Bay of 400kv Talegaon Kharghar Line) at Talegaon	13-Jun-17	6:00	13-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay
168	470	400	Main Bay of Akola #2 416 at Wardha	13-Jun-17	6:00	13-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
169	472	400	ICT2_400/220kv_SOLAPUR	13-Jun-17	6:00	14-Jun-17	15:00	Daily	33KV AUX SUPPLY EXTENSION WORKS	WRTS-1	POWERGRID	C	ICT
170	473	400	Jaigad-Newkoyna Ckt -2	13-Jun-17	8:00	13-Jun-17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
171	483	400	400 kV Bhadravati - Parli # 01.	13-Jun-17	8:00	13-Jun-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
172	485	400	400kV Deepnagar-Waluj Line	13-Jun-17	6:00	13-Jun-17	18:00	Daily	During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
173	487	400	Wardha - Akola ckt - 2	14-Jun-17	6:00	14-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
174	498	400	Wardha-2 Main bay-410 at Aurangabad	14-Jun-17	6:00	14-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
175	499	400	400kv PARLI-PUNE(GIS)_1	14-Jun-17	10:00	14-Jun-17	18:00	Daily	For AMP works of line terminating equipments at Parli	WRTS-I	WRTS-I	R	Line
176	500	400	411 Bay (TIE bay of 400kv Talegaon GIS Shikrapur Line # 4 & ict # 2) at Talegaon	14-Jun-17	6:00	14-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay
177	501	400	400/ ICT #1 Main Bay 421 at Wardha	14-Jun-17	6:00	14-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
178	502	400	400 KV Bus-B @ Nagothane	14-Jun-17	6:00	14-Jun-17	14:00	Daily	To carry out Routine Maintenance work	MSETCL	MSETCL		
179	503	400	Jaigad-Karad Ckt -1	14-Jun-17	8:00	14-Jun-17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
180	517	400	400kV Deepnagar-Khadka- I	14-Jun-17	6:00	14-Jun-17	18:00	Daily	During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL		
181	520	400	400 KV Bus-II at Parli	15-Jun-17	6:00	16-Jun-17	15:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bus
182	522	400	400KV Khandwa-Dhule Ckt-I	15-Jun-17	6:00	19-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-II	WRTS-I	C	LINE
183	525	400	Wardha - Akola ckt - 1	15-Jun-17	6:00	15-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
184	536	400	416 BAY (Main Bay of 400kV Talegaon Kalwa Line) at Talegaon	15-Jun-17	6:00	15-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay
185	538	765	SOLAPUR_BAY 711_TIE BAY_765KV AURANGABAD#2& PUNE	15-Jun-17	6:00	15-Jun-17	15:00	Daily	AMP WORKS	WRTS-1	POWERGRID	R	BAY
186	539	765	ICT#1 Main bay 703 at Wardha	15-Jun-17	6:00	15-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
187	540	400	Wardha - Akola ckt - 1	15-Jun-17	6:00	15-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
188	541	400	402 CB TIE CB OF ICT I @ Jejuri	15-Jun-17	9:30	15-Jun-17	17:30	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		ICT I will be in service through main CB 401
189	542	400/220	315MVA, ICT 1 Bay @ Lonikand 1	15-Jun-17	8:00	15-Jun-17	16:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
190	543	400	Jaigad-Karad Ckt -2	15-Jun-17	8:00	15-Jun-17	18:00	Daily	Coldline washing & Maintenance work	JPTL	JPTL		
191	544	400	Parli-Lonikand-Ckt-I line@ Parli	15-Jun-17	10:00	15-Jun-17	18:00	Daily	Fixing of arcing horns at loc. No. 47, 49, 50, 54, 57, 58, 59, and 63.	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
192	545	400	Parli -Lonikand ckt I@ Parli-Line reactor	15-Jun-17	6:00	19-Jun-17	14:00	Daily	Reactor painting work. Only reactor will be taken out of circuit. Line will be charged subsequently.	MSETCL	MSETCL		Line will be on outage for whole day on 1st day of proposed outage date. Bay maintenance will be done at Girgaoli s/s. After bay maintenance
193	550	400	Khandwa -Dhule -Ckt-1	15-Jun-17	6:00	15-Jun-17	15:00	Daily	Terminal Equipment maintenance work and AMP of line. A/R of Ckt.2 to be kept in non auto mode during the outage period	POWERGRID	WR-II	R	
194	559	400	Koyna Stage IV-jejuri	15-Jun-17	6:00	15-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		
195	560	400	GCR Chandrapur - Chandrapur 2 Ckt-2	16-Jun-17	6:00	16-Jun-17	19:00	Daily	Replacement of bolted type clamp by crimping clamp at LULO tower loc. No. 02 & Replacement of broken / damaged disc insulators	MSETCL	MSETCL		
196	562	400	Wardha - Akola ckt - 2	16-Jun-17	6:00	16-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
197	569	400	417 Bay (TIE bay of 400kv Talegaon Kalwa Line & ict # 3) at Talegaon	16-Jun-17	6:00	16-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay
198	572	400	400KV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) II (MAIN BAY 410) AT KOLHAPUR (GIS)	16-Jun-17	10:00	16-Jun-17	18:00	Daily	For bay AMP works.	WRTS-I	WRTS-I	R	BAY
199	573	400	Wardha - Akola ckt - 2	16-Jun-17	6:00	16-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
200	574	400	407 Bay (Main Bay of Aurangabad Ckt-2) at 400 kV Akola	16-Jun-17	6:00	16-Jun-17	14:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
201	575	400	416-Bay (Main Bay of 400kv Chandrapur-2) at Warora Substation	16-Jun-17	8:00	16-Jun-17	18:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL		
202	576	400	Deepnagar-Khadka Ckt-1 at 400KV Deepnagar	16-Jun-17	6:00	16-Jun-17	14:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
203	577	400	Talandge - Karad 2 @ Talandge	16-Jun-17	10:00	16-Jun-17	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL		
204	578	400/220	315MVA, ICT-3 @ Padgha	16-Jun-17	8:00	16-Jun-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
205	582	400	Khandwa -Dhule -Ckt-2	16-Jun-17	6:00	16-Jun-17	15:00	Daily	Terminal Equipment maintenance work and AMP of line. A/R of Ckt.1 to be kept in non auto mode during the outage period	POWERGRID	WR-II	R	
206	586	220	Bhaveghar-Wada	16-Jun-17	8:00	17-Jun-17	18:00	Daily	Powerline crossing work of Kala-Kudus line at loc No. 82-83	MSETCL	WR-II	C	hotline work suggested by SLDC Maharashtra
207	587	220	Padghe-Wada	16-Jun-17	8:00	17-Jun-17	18:00	Daily	Powerline crossing work of Kala-Kudus line at loc No. 82-83	MSETCL	WR-II	C	hotline work suggested by SLDC Maharashtra
208	591	400	Jaigad-Karad Ckt -1&2	16-Jun-17	7:00	30-Jun-17	16:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both ciruicts to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
209	593	400	Chandrapur 2 - Nanded Ckt-I	17-Jun-17	6:00	17-Jun-17	19:00	Daily	Replacement of broken / damaged disc insulators	MSETCL	MSETCL		
210	602	220	208 BAY (Main bay of 220KV Urse Line # 2) at Talegaon. Presently 220KV Urse Line # 2 does not exists.	17-Jun-17	6:00	17-Jun-17	15:00	Daily	For AMP works	WRTS-I	WRTS-I	R	Bay
211	603	400/220	501 MVA, ICT IV @ BBLR	17-Jun-17	8:00	17-Jun-17	17:00	Daily	Quarterly/pre mansoon Maintenance work	MSETCL	MSETCL		400/220kv 315MVA ICT-I, ICT-II & 500MVA ICT-III will be in service
212	614	500	500KV Chandrapur-Padghe HVDC Pole II Line	18-Jun-17	5:00	18-Jun-17	19:00	Daily	Insulator string replacement work at Location No. 355, 356 & 357	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
213	621	400	Wardha - Akola ckt - 2	18-Jun-17	6:00	18-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
214	623	400	400KVBus_1 at Aurangabad	18-Jun-17	6:00	18-Jun-17	15:00	Daily	For STATCOM works at Aurangabad	WRTS-I	WRTS-I	C	Bus
215	629	400	Kalwa-Padgha Ckt-1	18-Jun-17	8:00	18-Jun-17	17:00	Daily	Maintenance work & Dignostic testing work	MSETCL	MSETCL		
216	633	400	SOLAPUR_400KV BUS#2	19-Jun-17	6:00	19-Jun-17	15:00	Daily	STATCOM CONSTRUCTION WORKS	WRTS-1	POWERGRID	C	BUS
217	637	400	400KV Khandwa-Dhule Ckt-II	19-Jun-17	6:00	23-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-II	WRTS-I	C	LINE
218	638	765	Wardha-4 Main bay-721 at Aurangabad	19-Jun-17	6:00	19-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	C	Bay
219	639	400	Wardha - Akola ckt - 1	19-Jun-17	6:00	19-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
220	644	400	400KV Wardha -2 & Pune-2 Tie Bay (405) at Parli	19-Jun-17	10:00	19-Jun-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bay
221	645	400	400KV 50MVARs Bus Reactor at Wardha	19-Jun-17	6:00	19-Jun-17	15:00	Daily	For Bushing Tan delta Measurement	WRTS-I	WRTS-I	R	Bay
222	647	400	KORADI 2-WARDHA	19-Jun-17	8:00	19-Jun-17	17:00	Daily	Line signature test, broken disc replacement work,tightning and fixing of jumper nutbolts & hardwares on line and earthwire	MSETCL	MSETCL		
223	648	400	400 KV Koradi- Khaperkheda-1 @ Koradi-1 S/S	19-Jun-17	8:00	19-Jun-17	17:00	Daily	Diagnostic Testing and Preventive Bay maintenance.	MSETCL	MSETCL		
224	649	220	Nashik- Navsari ckt-1	19-Jun-17	8:00	22-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work Cold line insulator Washing work	MSETCL	MSETCL		
225	650	400	400KV NewKoyna-Dabhool -Ckt-2 @New koyna	19-Jun-17	8:00	19-Jun-17	18:00	Daily	Routine Maintenance work & Relay testing Work	MSETCL	MSETCL		
226	651	220	Talandge - Chikkodi @ Talandge	19-Jun-17	10:00	19-Jun-17	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL		
227	662	400	Chandrapur (Old GCR)-Parli Ckt-III @ Parli	19-Jun-17	6:00	31-06-2017	14:00	Daily	For Earthwire tightening work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
228	663	400	400 kV Koradi- Bhusawal Line	19-Jun-17	10:00	21-Jun-17	16:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL		
229	664	400	400KV Dhule-BBLR Ckt-I & II	19-Jun-17	7:00	20-Jun-17	15:00	Daily	PID testing. A/R in Non Auto Mode .	MSETCL	MSETCL		
230	665	400	400KV CHD- Parli Ckt-III Bay @400KV S/S Chandrapur	20-Jun-17	8:00	24-Jun-17	18:00	Daily	1) Hot Spot Attending of PG-I , PG-II & CBI Isolator . 2) Replacement of damaged scissor assembly of Y-ph PG-I Isolator. 3) Routine maint. Bay.	MSETCL	MSETCL		
231	666	400	400 KV Main Bus-I (401-52 C.B & 404-52C.B is to be made off) @ Lamboti	20-Jun-17	10:00	20-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
232	669	765	Wardha-1 Main bay-715 at Aurangabad	20-Jun-17	6:00	20-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
233	670	400	Wardha - Akola ckt - 1	20-Jun-17	6:00	20-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
234	671	400	400KV Main Bus-1 @ 400 KV Koradi II S/S	20-Jun-17	6:00	20-Jun-17	15:00	Daily	During the proposed outage dew point measurement of 12nos. of 420KV SF6 CB connected to bus-1 side, will be carried out.	MSETCL	MSETCL		
235	681	400	400KV Pune-2 Main Bay (406) at Parli	20-Jun-17	10:00	20-Jun-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bay
236	682	765	Tie bay of ICT #3 708 at Wardha	20-Jun-17	6:00	20-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
237	691	400	Chandrapur II - Nanded CKT-I	20-Jun-17	6:00	20-Jun-17	16:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
238	693	400	400 KVBus_2 at Aurangabad	21-Jun-17	6:00	21-Jun-17	15:00	Daily	For STATCOM works at Aurangabad	WRTS-I	WRTS-I	C	Bus
239	701	400	400/ ICT#1 Main Bay 203 at Wardha	21-Jun-17	6:00	21-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
240	702	400	(3*105) MVA ICT-II & It's Bay @400KV S/S Chandrapur	21-Jun-17	8:00	28-Jun-17	18:00	Continuous	Replacement of B- ph ICT-II By repaired 105 MVA Spare ICT.	400KV AC	MSETCL		
241	703	400	412 Main Bay (Chandrapur-2-Nanded ckt-2) at 400 KV Chandrapur-2 Substation	21-Jun-17	8:00	21-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
242	712	400	Parli-Lonikand ckt I@ Parli	22-Jun-17	6:00	22-Jun-17	15:00	Daily	Reactor Bushing& winding Tan Delta measurement work, CB DCRM & timing Test.	MSETCL	MSETCL		
243	713	400	Wardha - Akola ckt - 2	22-Jun-17	6:00	22-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
244	715	220	200 KV PADURNA-KALMESHVAR	22-Jun-17	6:00	22-Jun-17	15:00	Daily	FOR RECTIFICATION OF DEFECT OBSERVED DURING ROUTIN PETROLLING & TO ATTEND DAMPER ARCHING HORN FO & BROKEN DISK REPLACEMENT WORK	MPPTCL	MPPTCL	R	
245	718	400	400KV KOLHAPUR (GIS)-MAPUSA I & 400KV KUDGI-KOLHAPUR(GIS) II TIE BAY (BAY No.405) AT KOLHAPUR (GIS)	22-Jun-17	10:00	22-Jun-17	18:00	Daily	For bay AMP works.	WRTS-I	WRTS-I	R	BAY
246	721	400/220	501 MVA ICT 1 @Jejuri	22-Jun-17	9:30	22-Jun-17	17:30	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		Load will be managed on ICT -II
247	722	400	Lonikand-Chakan Line	22-Jun-17	8:00	22-Jun-17	16:00	Daily	Line Maint work by Lonikand	MSETCL	MSETCL		
248	723	400	406-Bay (Tie Bay of Girwali-2 Line-2 and ICT-1) at Kumbhargaoon (Nanded)	22-Jun-17	12:00	22-Jun-17	16:00	Daily	Quarterly Maintenance of bays equipment	MSETCL	MSETCL		
249	732	765	SOLAPUR_765KV BUS1	22-Jun-17	8:00	22-Jun-17	18:00	Daily	AMP WORKS	WRTS-1	POWERGRID	R	NLDC consent required.
250	733	765	AURANGABAD - SOLAPUR - 1	22-Jun-17	8:00	26-Jun-17	18:00	Continuous	For swapping of 765KV Solapur line in solapur bays at Aurangabad	WRTS-I	WRTS-I	C	Line
251	735	400	400KV WARDHA-PARLI-II	22-Jun-17	10:00	22-Jun-17	18:00	Daily	For AMP works of line terminating equipments at Parli	WRTS-I	WRTS-I	R	Line
252	736	400	400KV Chandrapur(New GCR)-Nanded ckt-II	22-Jun-17	6:00	22-Jun-17	15:00	Daily	Junper hard ware nut bolt tating at loc no.547	MSETCL	MSETCL		
253	737	400	Koyna Stage IV-jejuri	22-Jun-17	6:00	22-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
254	738	400	Wardha - Akola ckt - 1	23-Jun-17	6:00	23-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
255	739	400	Wardha - Akola ckt - 2	23-Jun-17	6:00	23-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
256	747	400	407-Bay (Main Bay of 501MVA ICT-1) at Kumbhargaoon (Nanded)	23-Jun-17	12:00	23-Jun-17	16:00	Daily	Quarterly Maintenance of bays equipment	MSETCL	MSETCL		
257	748	400	400 KV Bus-C @ Nagothane	23-Jun-17	6:00	23-Jun-17	14:00	Daily	To carry out Routine Maintenance work	MSETCL	MSETCL		
258	749	400	Deepnagar-Khadka Ckt-II at 400KV Deepnagar	23-Jun-17	6:00	23-Jun-17	14:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
259	750	400/220	315MVA , ICT-2 @ Padgha	23-Jun-17	8:00	23-Jun-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
260	757	400	400KV Main Bus-I @400KV S/S Chandrapur	23-Jun-17	8:00	24-Jun-17	18:00	Continuous	Replacement of 400KV Main Bus-I of R-Ph Y-ph & B-ph Bus CVT's.	400KV AC	MSETCL		High demand in Maharashtra. Contingency plan to be given.
261	758	765	Bus_2 at Aurangabad	23-Jun-17	6:00	23-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	C	Bus
262	761	400	Parli-Lonikand-Ckt-II @ Parli	23-Jun-17	10:00	23-Jun-17	18:00	Daily	Hardware tightening & fitting work at loc no-01,02,03 & Bay Maint at Parli	MSETCL	MSETCL		
263	762	400	Parli-Parli(PGCL)ckt I @ Parli	23-Jun-17	6:00	23-Jun-17	15:00	Daily	C & Tan Delta measurement of CVTs	MSETCL	MSETCL		
264	763	400	Chandrapur II - Nanded Ckt-II	23-Jun-17	6:00	24-Jun-17	16:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
265	770	400	TIE_WARDHA I - AKOLA(MSETCL) - I at Aurangabad	24-Jun-17	6:00	24-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
266	771	400	400/ ICT#2 Main Bay 205 at Wardha	24-Jun-17	6:00	24-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I	R	Bay
267	772	400	Wardha - Akola ckt - 2	24-Jun-17	6:00	24-Jun-17	15:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	C	LINE
268	773	400	Babhaleshwar-Bhusawal @BBLR	24-Jun-17	6:00	24-Jun-17	14:00	Daily	Quarterly Maintenance, Dignostic testing work & Servicing and alignment of PG isolators work	MSETCL	MSETCL		400kv Babhaleshwar-Aurangabad will be in service
269	779	400	400KV CHD-I CHD-II CKT NO.II BaY @400KV S/S Chandrapur	25-Jun-17	8:00	26-Jun-17	18:00	Daily	1) Hot Spot Attending of PG-I , PG-II & CBI Isolator . 2) Reactor Side IPS Tube Removing work.	MSETCL	MSETCL		ckt to be in service via TBC
270	785	400	Kharghar-Talegaon Line	25-Jun-17	8:00	25-Jun-17	17:00	Daily	Maintenance work	MSETCL	MSETCL		
271	786	400	SOLAPUR_400KV BUS#1	25-Jun-17	6:00	26-Jun-17	15:00	Daily	STATCOM CONSTRUCTION WORKS	WRTS-1	POWERGRID	C	BUS
272	787	400	400 KV Bus 2 at Wardha SS	25-Jun-17	6:00	26-Jun-17	15:00	Continuous	Bus extension for Aurangabad bays	WRTS-I	WRTS-I	C	Bus
273	790	400	400KV Main Bus-2 @ 400 KV Koradi II S/S	26-Jun-17	6:00	26-Jun-17	15:00	Daily	During the proposed outage dew point measurement of 12nos. of 420KV SF6 CB connected to bus-1 side, will be carried out.	MSETCL	MSETCL		
274	794	220	Nashik- Navsari ckt-2	26-Jun-17	8:00	29-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work Cold line insulator Washing work	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRDLC/SLDC Comments
				Date	Time	Date	Time						
275	799	400	400KV Dhule-BBLR Ckt-I & II	26-Jun-17	7:00	27-Jun-17	15:00	Daily	PID testing. A/R in Non Auto Mode .	MSETCL	MSETCL		
276	807	400	Akola-1 Main bay-415 at Aurangabad	27-Jun-17	6:00	27-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
277	808	400	Non S/W Line Reactor of A'Bad # 1 at Akola Line will be in Service without LR.	27-Jun-17	6:00	27-Jun-17	15:00	Daily	For Tan delta Measurement of Reactor Bushings	WRTS-I	WRTS-I		Reactor
278	814	400	400KV Main Bus -1 @ 400KV R.S. Waluj	27-Jun-17	6:00	28-Jun-17	14:00	Daily	Quarterly Maintenance	MSETCL	MSETCL		
279	816	400	400KV PARLI-SOLAPUR-I	27-Jun-17	10:00	27-Jun-17	18:00	Daily	For PMU Works	WRTS-I	WRTS-I	C	Line
280	817	765	AURANGABAD - SOLAPUR - 2	27-Jun-17	8:00	28-Jun-17	18:00	Continuous	For swapping of 765kv Solapur line in solapur bays at Aurangabad	WRTS-I	WRTS-I	C	Line
281	819	400	Chandrapur - Parli Ckt-3	28-Jun-17	6:00	28-Jun-17	19:00	Daily	Replacement of broken / damaged disc insulators & tightening of conductor & earthwire hardware	MSETCL	MSETCL		
282	821	400	400kv PARLI-PUNE(GIS)_2	28-Jun-17	10:00	28-Jun-17	18:00	Daily	For AMP works of line terminating equipments at Parli	WRTS-I	WRTS-I	R	Dia to be closed after shutdown.
283	822	400	400 KV Main Bus-II (403-52 C.B & 406-52C.B off) @ Lamboti	28-Jun-17	10:00	28-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
284	827	400	Aurangabad-2 Main bay-412 at Aurangabad	28-Jun-17	6:00	28-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
285	829	400	Non S/W Line Reactor of A'Bad # 2 at Akola Line will be in Service without LR.	28-Jun-17	6:00	28-Jun-17	15:00	Daily	For Tan delta Measurement of Reactor Bushings	WRTS-I	WRTS-I	R	Reactor
286	830	400	400KV TBC @ Karad	28-Jun-17	10:00	28-Jun-17	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL		
287	831	400	425 Main Bay (Chandrapur-2-Warora ckt-2) at 400 KV Chandrapur-2	28-Jun-17	8:00	28-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
288	832	400/220	501MVA, ICT 1 @ 400 KV LAMBOTI.	28-Jun-17	10:00	28-Jun-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
289	833	400	400KV TBC@ Karad	28-Jun-17	10:00	28-Jun-17	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL		
290	838	400	400KV PARLI-SOLAPUR-II	28-Jun-17	10:00	28-Jun-17	18:00	Daily	For PMU Works	WRTS-I	WRTS-I	C	Line
291	846	400	TIE_WARDHA II -AURANGABAD(MSETCL) I bay-411at Aurangabad	29-Jun-17	6:00	29-Jun-17	15:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay
292	847	400	Tie Bay of Akola-A'Bad #2 406 at Akola SS	29-Jun-17	6:00	29-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Bay
293	848	400	400KV KOLHAPUR (GIS)-MAPUSA II & 400KV KUDGI-KOLHAPUR(GIS) I TIE BAY (BAY No:402) AT KOLHAPUR(GIS)	29-Jun-17	10:00	29-Jun-17	18:00	Daily	For bay AMP works.	WRTS-I	WRTS-I	R	BAY
294	849	400	JEJURI-LONIKAND LINE @ Jejuri & Lonikand	29-Jun-17	9:30	29-Jun-17	17:30	Daily	Routine Maintenance & Dignostic testing work at Both ends.	MSETCL	MSETCL		400 KV Jejuri-Koyna st IV will be in service .
295	850	400/220	3 X105MVA , ICT-1 @ Padgha	29-Jun-17	8:00	29-Jun-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
296	851	400	Lonikand -Chakan @ Chakan	29-Jun-17	6:00	29-Jun-17	15:00	Daily	Bay maintenance and testing work.	MSETCL	MSETCL		
297	859	400	Chandrapur II - Nanded Ckt-I	29-Jun-17	6:00	30-Jun-17	16:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		

LIST OF TRANSMISSION ELEMENTS OUTAGES PROPOSALS FOR THE MONTH OF JUNE 2017

Sr.No.	OCCM Sr No.	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Type	WRLDC/SLDC Comments
				Date	Time	Date	Time						
298	860	400	Koyna Stage IV-jejuri	29-Jun-17	6:00	29-Jun-17	15:00	Daily	Replacement of Faulty strings	MSETCL	MSETCL		
299	867	400	Koradi - Bhilai Line	30-Jun-17	6:00	30-Jun-17	15:00	Daily	For AMP works related to Bay	WRTS-I	WRTS-I		Line
300	868	400	CHANDRAPUR - KHAPERKHEDA	30-Jun-17	8:00	30-Jun-17	17:00	Daily	Line signature test, broken disc replacement work,tightning and fixing of jumper nutbolts & hardwares on line and earthwire	MSETCL	MSETCL		