

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018													
Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
1	5	400 kV	400kV S/C Chandrapur-Khaparkhedha Transmission Line	01/Jun/18	6:00	01/Jun/18	20:00	Daily	Power line crossing of 400kV S/C Chandrapur-Khaparkhedha Transmission Line at Tower No.245 & 246 by 765 KV D/C Rajnandgaon-Warora Line	MSETCL	RRWTL		Proposal from SE (O&M) Circle required .
2	11	400	Bay No-407 Main Bay of 400kv Paghe-boisar Line at Boisar	01/Jun/18	8:30	01/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
3	12	400KV	Babhaleshwar-Bhusawal -@BBLR	01/Jun/18	9:00	01/Jun/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL		
4	17	765	ICT1_765/400kv_WARDHA	01/Jun/18	9:00	01/Jun/18	18:00	Daily	Commissioning of 400 Kv Side ICT-1 CSD in Bay 404 and On line Switching Trials from 400 KV side with CSD.	WRTS-I	WRTS-I		
5	20	400	400kV Padghe GIS-1 MAIN BAY (415) at MSETCL KUDUS	01/Jun/18	10:00	01/Jun/18	12:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I		
6	22	400	400kV Padghe-1 TIE BAY (414) at MSETCL KUDUS	01/Jun/18	13:00	01/Jun/18	15:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I		
7	25	400	400kV PADGHE GIS- KUDUS I	01/Jun/18	15:30	01/Jun/18	17:30	Daily	for taking Oil Sample of Line CT.	WRTS-I	WRTS-I		
8	31	220 KV	PUSAD - WARDHA (PG)	01/Jun/18	7:00	05/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
9	34	400KV	401-52 (400 KV ICT-I is in service through 402-52 Tie C.B) @ Lamboti	01/Jun/18	8:00	06/Jun/18	18:00	Continuous	Overhauling of C.B	MSETCL	MSETCL		
10	38	400 KV	CHANDRAPUR-PARLI CKT-3	01/Jun/18	8:00	15/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
11	49	400	400KV-KALA-KUDUS # 1 & 2 (A/R TO BE KEPT IN N/A MODE)	01/Jun/18	9:00	30/Jun/18	18:00	Daily	For PID Work	PGCIL	WR-II		
12	50	400KV	400 KV N.Koyna-Karad Ckt 1 & 2 A/R in Non Auto mode	01/Jun/18	10:00	30/Jun/18	17:00	Daily	For PID testing work. Auto-Reclose required to be OFF	MSETCL	MSETCL		
13	51	400 KV	PARLI-SOLAPUR (LAMBOTI) A/R in Non Auto mode	01/Jun/18	10:00	30/Jun/18	18:00	Daily	For PID Work	MSETCL	MSETCL		
14	57	400 KV	Ramagundam Chandrapur I& II	01/Jun/18	8:00	09/Jun/18	18:00	C	To enable de-stringing of 2 spans (one Indian railway & MGR), erection of 1 tower (DD+18) and stringing of 2 spans (one Indian railway & MGR) as part of rerouting of lines at NTPC, Ramagundam"	SRPC	NTPC	TTC/ATC of WR-SR/SR Import would be reduced by 1000MW	
15	69	765/400kv	1500 MVA ICT-1 @ EKTUNI	02/Jun/18	10:00	02/Jun/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL		
16	71	400KV	Koradi -Khaperkheda Ckt 1 & 2	02/Jun/18	9:00	16/Jun/18	18:00	Continuous	Outage is required for shifting of towers	MSETCL	MSETCL		Due to the outage on 400kV S/C Chandrapur-Khaparkhedha
17	73	400	Bay No-408 Tie Bay of 400kv Boisar-Padghe Line & ICT-I at Boisar	02/Jun/18	8:30	02/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
18	75	765	ICT2_765/400kv_WARDHA	02/Jun/18	9:00	02/Jun/18	18:00	Daily	Commissioning of 400 Kv Side ICT-2 CSD in Bay 407 and On line Switching Trials from 400 KV side with CSD.	WRTS-I	WRTS-I		
19	76	765	765kv AURANGABAD-1 & Future Tie bay (708) at Solapur	02/Jun/18	9:00	02/Jun/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I		
20	78	400	400kV PADGHE-2 MAIN BAY (418) at MSETCL KUDUS	02/Jun/18	10:00	02/Jun/18	12:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I		
21	80	400	400kV PADGHE-2 TIE BAY (417) at MSETCL KUDUS	02/Jun/18	13:00	02/Jun/18	15:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I		
22	82	400	400kV PADGHE GIS- KUDUS II	02/Jun/18	15:30	02/Jun/18	17:30	Daily	for taking Oil Sample of Line CT.	WRTS-I	WRTS-I		
23	94	400KV	New Koyna-Dabhol-Ckt-1 @ N.Koyna	04/Jun/18	8:00	04/Jun/18	17:00	one day	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
24	98	400 kV	Tirora Warora Line 2 Main Bay 409 at Tiroda SS	04/Jun/18	8:00	04/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	ATIL	ATIL		
25	100	400 KV	MAIN BUS - 1 @ AKOLA	04/Jun/18	9:00	04/Jun/18	18:00	Daily	Isolator Maintenance work of 418 89 Isolator and routine maintenance & testing work	MSETCL	MSETCL		
26	103	765	ICT3_765/400kv_WARDHA	04/Jun/18	9:00	04/Jun/18	18:00	Daily	Commissioning of 400 Kv Side ICT-3 CSD in Bay 410 and On line Switching Trials from 400 KV side with CSD.	WRTS-I	WRTS-I		
27	109	765	ICT1_765/400kv_PADGHE	04/Jun/18	14:00	04/Jun/18	18:00	Daily	PRE-MONSSON MAINTENANCE AND TAKING OUT SPARE UNIT OUT OF SERVICE AND TAKING MAIN Y-PHASE UNIT IN SERVICE AND CSD COMMISSIONING TIE BREAKER(702)	WRTS-I	WRTS-I		

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018

Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
28	119	220 KV	PUSAD - WARDHA (PG) line on TBC	04/Jun/18	8:00	07/Jun/18	17:00	Continuous	Main breaker O/H work.	MSETCL	MSETCL		
29	120	220 KV	DEOLI(PGCIL)-BADNERA	04/Jun/18	8:00	09/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
30	130	400KV	Babhaleshwar-Ektuni-Ckt-1 @BBLR	05/Jun/18	9:00	05/Jun/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL		
31	135	400 KV	CHANDRAPUR-PARLI CKT-3	05/Jun/18	8:00	05/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL		
32	138	400 KV	WARORA - Wardha(PG) @ WARORA	05/Jun/18	9:00	05/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
33	145	400	400KV KOLHAPUR(MSETCL)-I MAIN BAY (407) At Kolhapur-GIS	05/Jun/18	10:00	05/Jun/18	18:00	Daily	BAY AMP WORKS	WRTS-I	WRTS-I		
34	150	400 KV	AKOLA - KHADKA (BHUSAWAL)	05/Jun/18	12:00	07/Jun/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL		
35	156	400 KV	CHANDRAPUR 2 - WARORA CKT-1	06/Jun/18	7:00	06/Jun/18	19:00	Daily	Tightening of conductor ,Earthwire Hardware & replacement of faulty disc insulators.	MSETCL	MSETCL		
36	162	400	400KV PUNE(GIS)-I Bay at Msetcl, Waluj S/s	06/Jun/18	8:00	06/Jun/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	Line to be inservice	
37	163	400 kv	400 KV Tirora Warora Line 1 Main Bay 406 at Tiroda SS	06/Jun/18	8:00	06/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	ATIL	ATIL		
38	164	132 KV	KANHAN-PENCH	06/Jun/18	9:00	06/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
39	172	220 KV	BHUGAON - WARDHA (PG)	06/Jun/18	10:00	06/Jun/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL		
40	174	220 KV	DEOLI(PGCIL)-BADNERA	06/Jun/18	8:00	08/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
41	178	400	400KV Talegaon Chakan Line at Talegaon	07/Jun/18	9:00	07/Jun/18	16:00	Daily	AMP of Line Equipments	MSETCL	WRTS-I		Friday . Outage to be availed on Thursday.
42	182	400KV	400 KV Lamboti-Parli @ Lamboti.	07/Jun/18	8:00	07/Jun/18	17:00	Daily	Overhauling, Servicing & Maintenance of Centre Break Isolators.	MSETCL	MSETCL		
43	184	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	07/Jun/18	9:00	07/Jun/18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL		
44	186	220 KV	PUSAD - WARDHA (PG)	07/Jun/18	10:00	07/Jun/18	18:00	Daily	For Line Signiture test and Other Diagnostic Work	MSETCL	MSETCL		
45	189	400 KV	TIE BAY (428) OF WARORA - WARDHA(PG) @ WARDHA (PG)	07/Jun/18	9:00	10/Jun/18	17:00	Continuous	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
46	198	400kv	Bus Coupler @ BBLR	07/Jun/18	9:00	07/Jun/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL		
47	202	400KV	Koyna Stage IV-Jejuri	07/Jun/18	9:00	07/Jun/18	18:00	Daily	Cold washing of Insulators & Insulator replacement work	MSETCL	MSETCL		
48	208	765	ICT2_765/400kv_PADGHE	07/Jun/18	10:00	07/Jun/18	14:00	Daily	PRE-MONSSON MAINTENANCE	WRTS-I	WRTS-I		
49	210	765 KV	TIE BAY - 705 OF EKTUNI-AKOLA II ckt-1 @ EKTUNI	07/Jun/18	10:00	07/Jun/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL		
50	214	400KV	Jaigad-Newkoyna Ckt- 1 & 2	07/Jun/18	9:00	09/Jun/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both ciruits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
51	216	220 KV	PUSAD - WARDHA (PG)	07/Jun/18	7:00	30/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
52	229	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	08/Jun/18	7:00	08/Jun/18	19:00	Daily	Tightening of conductor ,Earthwire Hardware & Fixing Repaire Sleves between Loc. No. 36-37.	MSETCL	MSETCL		
53	231	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_2	08/Jun/18	9:00	08/Jun/18	16:00	Daily	For line Isolator Alignment & AMP of Line Equipments	WRTS-I	WRTS-I		
54	233	400 KV	400 KV Lamboti-PGCIL @ Lamboti	08/Jun/18	8:00	08/Jun/18	17:00	Daily	Overhauling, Servicing & Maintenance of Centre Break Isolators.	MSETCL	MSETCL		
55	236	400	400KV SSNL-Dhule-1 & ckt-2 AR off	08/Jun/18	8:00	08/Jun/18	18:00	Daily	PMM work	NCA	GETCO		
56	239	400	400KV PUNE(GIS)-II Bay at Msetcl, Waluj S/s	08/Jun/18	8:00	08/Jun/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	Line to be inservice	
57	240	400 kv	400 KV Tirora Warora Line 1 Tie bay 405 at Tiroda SS	08/Jun/18	8:00	08/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	ATIL	ATIL		
58	245	400 KV	Akola II - Akola I CKT - 1 @ Akola I	08/Jun/18	9:00	08/Jun/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
59	246	220 KV	CHITEGAON- CHITEPIMPALGAON (PG) CKT-I @ Chitegaon	08/Jun/18	9:00	08/Jun/18	18:00	Daily	Routine Maintainance work	MSETCL	MSETCL		

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018

Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
60	254	220 KV	BHUGAON - WARDHA (PG)	08/Jun/18	10:00	08/Jun/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL		
61	263	400 KV	CHANDRAPUR-PARLI CKT-3	09/Jun/18	7:00	09/Jun/18	19:00	Daily	For Replacement Missing of Earth wire at LOC No 36 to 38.	MSETCL	MSETCL		
62	265	400KV	403-52 (400 KV Parli Line is in service through 402-52 Tie C.B) @ Lamboti.	09/Jun/18	8:00	13/Jun/18	18:00	Continuous	Overhauling of C.B	MSETCL	MSETCL		
63	269	765/400kV	1500MVA , ICT-2 @ EKTUNI	09/Jun/18	10:00	09/Jun/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL		
64	272	220KV	Nasik - Navsari Ckt 2 @ Nasik	09/Jun/18	9:00	09/Jun/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
65	274	400	400kV Kolhapur MAIN BAY _418 at Solapur	09/Jun/18	9:00	09/Jun/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I		
66	278	400KV	400KV Partial B bus @ Padgha	09/Jun/18	0:00	10/Jun/18	24:00hrs	Continuous	Commissioning of 400KV Bus Section Breaker	MSETCL	MSETCL		
67	295	400	400KV SSNL-Dhule-2 & ckt-1 AR off	10/Jun/18	8:00	10/Jun/18	18:00	Daily	PMM work	NCA	GETCO		
68	297	765 KV	TIE BAY - 702 OF EKTUNI-AKOLA II ckt-2 @ EKTUNI	10/Jun/18	10:00	10/Jun/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL		
69	306	400 KV	Dhariwal- Parli 400 KV Tr. Line	11/Jun/18	8:00:00	11/Jun/18	18:00	Daily	Outage for fixing of line Spacer cum Damper, Suspension Pilot clamp and Jumper Pad n&bs tightening works.	WRTS-I	Dhariwal Infrastruct ure Ltd.	Dhariwal Shall not bid in PX	
70	309	400KV	400KV Kharghar-Talegaon @ Kharghar	11/Jun/18	8:00	11/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
71	310	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	11/Jun/18	9:00	11/Jun/18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL		
72	341	400KV	Jaigad-Karad Ckt - 1 & 2	11/Jun/18	9:00	13/Jun/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both ciruits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
73	343	765	765KV AURANGABAD-PADGHE I	11/Jun/18	10:00	15/Jun/18	17:00	Conti?	FOR ATTENDING LEAKAGE IN GAS CHAMBER OF LINE DUCT	WRTS-I	WRTS-I		
74	344	220 KV	DEOLI(PGCIL)-BADNERA	11/Jun/18	8:00	16/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
75	351	400KV	Parali I (Bay 412 and 413) @ Lonikand-II S/stn.	12/Jun/18	9:00	12/Jun/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL		
76	352	400 KV	KHADKA - BABLESHWAR @ Khadka end .	12/Jun/18	6:00	12/Jun/18	18:00	Daily	Repairer of PG Isolator of AUX Bus.CT,CVT,Relat testing.DCRM	MSETCL	MSETCL		
77	354	400 KV	AKOLA - AURANGABAD(PG) CKT - 1 @Akola	12/Jun/18	9:00	12/Jun/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
78	356	400 KV	DHULE - SSNNL I @ Dhule end	12/Jun/18	8:00	13/Jun/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
79	360	400 KV	KHADKA - BABLESHWAR	12/Jun/18	6:00	12/Jun/18	18:00	Daily	For PID works. Autoreclose to be off.	MSETCL	MSETCL		
80	361	400 KV	CHANDRAPUR 2 - WARORA CKT-2	12/Jun/18	7:00	12/Jun/18	19:00	Daily	Tightening of conductor ,Earthwire Hardware & replacement of faulty disc insulators.	MSETCL	MSETCL		
81	365	400 kV	400 kV Tirora Warora Line 2 Tie bay 408 at Tiroda SS	12/Jun/18	8:00	12/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	ATIL	ATIL		
82	369	220	400/220KV ICT-2 Main bay (205) 220KV side at Talegaon	12/Jun/18	9:00	12/Jun/18	17:00	Daily	AMP WORK	WRTS-I	WRTS-I	line to be inservice	
83	373	220	220kV Jeur BAY 211 at Solapur	12/Jun/18	9:00	12/Jun/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I	line to be inservice	
84	381	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	12/Jun/18	12:00	14/Jun/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL		
85	391	400 KV	CHANDRAPUR GCR - CHANDRAPUR HVDC - I	13/Jun/18	8:00	13/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL		

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018

Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
86	392	400	Aurangabad-Aurangabad-1 along with Main Bus-1 at Msetcl, Waluj SS	13/Jun/18	8:00	13/Jun/18	18:00	Daily	For repairing of damaged strands of Bus conductors & CT drop jumpers replacement	WRTS-I	WRTS-I		
87	393	400 KV	WARORA - IEPL @Warora	13/Jun/18	9:00	13/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
88	396	220 KV	KALMESHVAR-PANDHURNA @ Kalmeshwar	13/Jun/18	8:00	13/Jun/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
89	400	220	220KV Talegaon MSETCL Line-2 Main bay (207) at Talegaon	13/Jun/18	9:00	13/Jun/18	17:00	Daily	AMP WORK	WRTS-I	WRTS-I	line to be inservice	
90	404	400	ICT3_400/220kv_SOLAPUR	13/Jun/18	9:00	13/Jun/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I		
91	409	220 KV	PUSAD - WARDHA (PG)	13/Jun/18	10:00	13/Jun/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL		
92	415	400 KV	MAIN BUS - 1 @ WALUJ	13/Jun/18	9:00	13/Jun/18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	preponed and	
93	417	400	400KV Bus-1 at Talegaon	14/Jun/18	9:00	14/Jun/18	17:00	Daily	Rectification of Conductor Unwinding problem	WRTS-I	WRTS-I		Saturday . Outage to be availed on Thursday .
94	424	400KV	400 KV Main Bus-I @ Lamboti	14/Jun/18	8:00	14/Jun/18	18:00	Daily	Overhauling, Servicing & Maintenance of Centre Break Isolators.	MSETCL	MSETCL		
95	425	400 KV	KORADI 2-WARDHA PGCIL @ Koradi 2	14/Jun/18	9:00	14/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
96	426	132 KV	MANSAR-PENCH	14/Jun/18	9:00	14/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
97	431	400 KV	DHULE - SSNNL II @Dhule end	14/Jun/18	8:00	15/Jun/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
98	445	400KV	Koyna Stage IV-Jejuri	14/Jun/18	9:00	14/Jun/18	18:00	Daily	Cold washing of Insulators & Insulator replacement work	MSETCL	MSETCL		
99	459	220KV	220KV Boisar -Boisar PG Ckt 2 @Boisar M	15/Jun/18	9:00	15/Jun/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
100	462	400	Aurangabad-Aurangabad-1 along with Main Bus-2 at Msetcl, Waluj SS	15/Jun/18	8:00	15/Jun/18	18:00	Daily	For repairing of damaged strands of Bus conductors & CT drop jumpers replacement	WRTS-I	WRTS-I		
101	470	400KV	400 KV Main Bus-II @ Lamboti	15/Jun/18	8:00	15/Jun/18	18:00	Daily	Overhauling, Servicing & Maintenance of Centre Break Isolators.	MSETCL	MSETCL		
102	471	400	ICT2_400/220kv_PUNE	15/Jun/18	9:00	15/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
103	476	400 KV	CHANDRAPUR 2 - WARORA CKT-2 @ Warora end	15/Jun/18	8:00	15/Jun/18	17:00	Daily	Routine maintainance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM	MSETCL	MSETCL		
104	477	400 KV	ST5 418 Main Bay at Tiroda SS	15/Jun/18	8:00	15/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	APML	APML		
105	480	220	400/220KV ICT-3 Main bay (209) at Talegaon	15/Jun/18	9:00	15/Jun/18	17:00	Daily	Taking CT oil sample for DGA	WRTS-I	WRTS-I	element to be	
106	485	400 KV	MAIN BAY (409) of EKTUNI CKT-1 @ Taptitanda	15/Jun/18	10:00	15/Jun/18	17:00	Daily	Relay testing work	MSETCL	MSETCL		
107	488	220 KV	PUSAD - WARDHA (PG)	15/Jun/18	10:00	15/Jun/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL		
108	494	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16/Jun/18	8:00	30/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
109	495	400 KV	KORADI-KHADKA A/R in Non Auto Mode	16/Jun/18	8:00	30/Jun/18	19:00	Daily	PID Testing work . A/R in Non Auto Mode	MSETCL	MSETCL		
110	502	400 KV	402- 52 Tie C.B (400 kv ICT-I is in service through 401-52 & 400 kv Parli Line is in service through 403-52 @Lamboti	16/Jun/18	8:00	21/Jun/18	18:00	Continuous	Overhauling of C.B	MSETCL	MSETCL		
111	505	400 KV	MAIN BAY (407) OF AURANGABAD (PG) - 2@ Akola	16/Jun/18	10:00	16/Jun/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
112	508	400KV	Babhaleshwar-Padghe -Ckt-2 @BBLR	16/Jun/18	9:00	16/Jun/18	9:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL		
113	509	400	400 Boisar-Padghe at Boisar	16/Jun/18	9:00	16/Jun/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II		
114	518	400KV	400KV Partial A bus @ Padgha	16/Jun/18	0:00	17/Jun/18	24:00hrs	Continuous	Commissioning of 400KV Bus Section Breaker	MSETCL	MSETCL		
115	520	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16/Jun/18	6:00	30/Jun/18	16:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
116	521	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	16/Jun/18	8:00	30/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL		
117	531	400	400 KV Sarni Bay at Koradi (MSETCL)	17/Jun/18	9:00	17/Jun/18	18:00	Daily	AMP work at Koradi Substation	WRTS-I	WRTS-I	line to be inservice	
118	541	400	400 Boisar-Padghe at Boisar	17/Jun/18	14:00	17/Jun/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II		

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018

Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
119	544	400 KV	MAIN BUS - 1 @ CHANDRAPUR	18/Jun/18	5:00	19/Jun/18	2:00	Continuous	1) For checking the healthiness of R, Y & B-ph 400KV Main BUS-I CVT's. At present there, is a difference of around 7-8 kV on primary side. 2) As per Partil Discharge test report , it is also necessary to confirm healthiness of 400kV Main Bus-1 CVTs.	MSETCL	MSETCL		
120	545	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_3	18/Jun/18	9:00	18/Jun/18	16:00	Daily	For line Isolator Alignment & AMP of Line Equipments	WRTS-I	WRTS-I		
121	552	400	400KV AURANGABAD(PG)-AURANGABAD(MSETCL) II	18/Jun/18	8:00	18/Jun/18	18:00	Daily	Line AMP works & CT drop jumper replacement at Msetcl. waluj S/s	WRTS-I	WRTS-I		
122	559	400/220KV	400 KV Kharghar @ Kalwa	18/Jun/18	9:00	18/Jun/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL		
123	560	400 KV	DHULE - SSNNL I & II A/R in Non Auto mode	18/Jun/18	8:00	18/Jun/18	17:00	Daily	On Line PID Testing	MSETCL	MSETCL		
124	563	400	40kv Tarapur-Boisar-I at Boisar	18/Jun/18	9:00	18/Jun/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II		
125	573	400 KV	TIE BAY (409) OF WARDHA CKT-1 & BHUSAWAL @ AKOLA	18/Jun/18	10:00	18/Jun/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
126	581	220 KV	DEOLI(PGCIL)-BADNERA	18/Jun/18	8:00	23/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
127	597	400 KV	MAIN BUS - 2 @ KHADKA	19/Jun/18	6:00	19/Jun/18	18:00	Daily	Bus II R Ph CVT Replacement	MSETCL	MSETCL		
128	602	400 KV	DHULE - SSNNL I & II A/R in Non Auto mode	19/Jun/18	8:00	19/Jun/18	17:00	Daily	On Line PID Testing	MSETCL	MSETCL		
129	603	400 KV	CHANDRAPUR - BHADRAVATI CKT - 1	19/Jun/18	8:00	19/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL		
130	604	400 kv	ST4 412 Main Bay at Tiroda SS	19/Jun/18	8:00	19/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	APML	APML		
131	605	220	Bay No. 201 Main Bay of ICT-I at Boisar	19/Jun/18	8:30	19/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
132	606	765	765kv PUNE(GIS)-SOLAPUR	19/Jun/18	8:00	19/Jun/18	10:00	Daily	RECTIFICATION OF HANGING OPGW ON CROSSARM AT LOC NO. 69	WRTS-I	WRTS-I		
133	607	400 KV	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	19/Jun/18	9:00	19/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
134	620	400	40kv Tarapur-Boisar-I at Boisar	19/Jun/18	14:00	19/Jun/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II		
135	622	400 KV	KORADI-KHADKA	19/Jun/18	12:00	21/Jun/18	18:00	Daily	PID testing of insulator strings by Hot line Unit Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL		
136	626	400KV	Babhaleshwar-Padghe-Ckt-1 @BBLR	20/Jun/18	9:00	20/Jun/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL		
137	629	400	Khandwa-Dhule ckt-1 with Khandwa -Dhule #2 A/R in Non-Auto mode	20/Jun/18	10:00	20/Jun/18	18:00	Daily	for terminal equipment AMP work at Khandwa	PGCIL	WR-II		
138	634	220	Bay No. 202 Main Bay of 220kv Boisar-Boisar-III Line at Boisar	20/Jun/18	8:30	20/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
139	636	400	400KV Kalwa & ICT-3 Tie bay (417) at Talegaon	20/Jun/18	9:00	20/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
140	642	400	400KV PARLI-1 & ALKUD Tie bay (414) at Solapur	20/Jun/18	9:00	20/Jun/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I		
141	645	400 KV	MAIN BUS - 1 and Main Bus 2 - 400KV BusBar Protection testing @ KORADI 2.	20/Jun/18	10:00	20/Jun/18	17:00	Daily	On line testing of 400KV BusBar Protection Scheme. 400KV Bus bar Protection will be out.	MSETCL	MSETCL		
142	650	400KV	Jaigad-Newkoyana Ckt- 1 & 2	20/Jun/18	9:00	23/Jun/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both ciruits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
143	651	400	400kv khandwa 1 mainbay at Dhule (Msetcl)	20/Jun/18	8:00	20/Jun/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I		
144	655	220	220KV Bus-2 at Talegaon	21/Jun/18	9:00	21/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		Tuesday. Outage to be availed on Thursday.
145	659	400 KV	CHANDRAPUR GCR - CHANDRAPUR HVDC - II	21/Jun/18	8:00	21/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL		
146	660	400	Khandwa-Dhule ckt-2 with Khandwa -Dhule #1 A/R in Non-Auto mode	21/Jun/18	10:00	21/Jun/18	18:00	Daily	for terminal equipment AMP work at Khandwa	PGCIL	WR-II		
147	661	400KV	Babhaleshwar-Aurangabad - @BBLR	21/Jun/18	9:00	21/Jun/18	9:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL		

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018

Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
148	667	400 KV	CHANDRAPUR 2 - WARORA CKT-1 @ Warora S/stn.	21/Jun/18	7:00	21/Jun/18	17:00	Daily	Protection Relay testing works and Routine maintainance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintenance work .	MSETCL	MSETCL		
149	671	220	Bay No. 203 Main Bay of 220kv Nalasopara-Boisar Line at Boisar	21/Jun/18	8:30	21/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
150	672	400	40kv Tarapur-Boisar-II at Boisar	21/Jun/18	9:00	21/Jun/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II		
151	673	400KV	406-Bay (Main CB of Koyna Stg IV line) @Jejuri	21/Jun/18	9:00	21/Jun/18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL		
152	675	400	400KV Pune GIS-1 Main bay (404) at Talegaon	21/Jun/18	9:00	21/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
153	679	400KV	Koyna Stage IV-Jejuri	21/Jun/18	9:00	21/Jun/18	18:00	Daily	Cold washing of Insulators & Insulator replacement work	MSETCL	MSETCL		
154	680	400KV	Talandge-Alkud @ Talandge	21/Jun/18	9:00	21/Jun/18	18:00	Daily	Quarterly Maint work	PGCIL	MSETCL		
155	686	400 KV	406- 52 (400 KV PGCIL Line is in service through 405-52 C.B @ Lamboti	21/Jun/18	8:00	26/Jun/18	18:00	Continuous	Overhauling of C.B	MSETCL	MSETCL		
156	692	400KV	Interconnector I -Lonikand II- Lonikand I Bay No 420 and Bay 421 @ Lonikand II S/Stn.	22/Jun/18	9:00	22/Jun/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL		
157	694	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	22/Jun/18	9:00	22/Jun/18	17:00	Daily	Outage For hardware/Earth wire clamp n/b tightening Work Loc. No. 851, 861,871	MSETCL	MSETCL		
158	695	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	22/Jun/18	9:00	22/Jun/18	17:00	Daily	maintenance and testing work	MSETCL	MSETCL	clubbed with other	
159	700	400 KV	CHANDRAPUR - BHADRAVATI CKT - 2	22/Jun/18	8:00	22/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL		
160	702	400 kv	ST3 416 Main Bay at Tiroda SS	22/Jun/18	8:00	22/Jun/18	19:00	Daily	Testing & Maintenance of Breaker and Isolator	APML	APML		
161	704	400KV	Babhaleshwar-Ektuni-Ckt-2 @BBLR	22/Jun/18	9:00	22/Jun/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL		
162	706	400	400KV Pune GIS-1 & ICT-1 Tie bay (405) at Talegaon	22/Jun/18	9:00	22/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
163	709	400KV	Talandge-Solapur PG @ Talandge	22/Jun/18	9:00	22/Jun/18	18:00	Daily	Quarterly Maint work	PGCIL	MSETCL		
164	713	400	400KV Akola-2 Main bay (416) at Wardha	22/Jun/18	9:00	22/Jun/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I		
165	722	400	400kv khandwa 2 mainbay at Dhule (Msetcl)	22/Jun/18	8:00	22/Jun/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I		
166	727	400	400kv Bhadrawati-Chandrapur-3 (GCR side) Main bay at (Chandrapur MSETCL)	23/Jun/18	9:00	26/Jun/18	18:00	Conti..	Overhauling mechanism of CGL CB	WRTS-I	WRTS-I	line to be inservice	
167	730	400 KV	MAIN BAY (412) OF EKTUNI CKT - 2 @ TAPTITANDA	23/Jun/18	8:00	23/Jun/18	17:00	Daily	Relay testing work	MSETCL	MSETCL		
168	731	400 KV	MAIN BAY (408) OF WARDHA(PG) CKT - 1 @ AKOLA	23/Jun/18	10:00	23/Jun/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
169	732	400 KV	PARLI - LONIKAND 2 CKT 1	23/Jun/18	10:00	23/Jun/18	18:00	Daily	Hardware Tightening & Fitting Work At Loc No-154,170,183,198,210	MSETCL	MSETCL		
170	735	220	Bay No. 206 Main Bay of 220kv Boisar-Boisar-I Line at Boisar	23/Jun/18	8:30	23/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II	line to be inservice	
171	746	400	400KV Talegaon Kharghar Line at Talegaon	24/Jun/18	9:00	24/Jun/18	16:00	Daily	For line Isolator Alignment & AMP of Line Equipments	MSETCL	WRTS-I		Saturday . To be availed on Sunday .
172	753	400KV	400 kv Chakan-Lonikand Line bay @ 400 kv Chakan	24/Jun/18	8:00	24/Jun/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
173	754	220	Bay No.204 Main Bus coupler at Boisar	24/Jun/18	8:30	24/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
174	765	400KV	400 KV Padgha II @ Kalwa	25/Jun/18	9:00	25/Jun/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL		
175	767	400 KV	DHULE- BABLESHWAR - I & II A/R in Non Auto	25/Jun/18	8:00	25/Jun/18	17:00	Daily	On Line PID Testing	MSETCL	MSETCL		
176	773	220	Bay No. 208 Main Bay of ICT-II at Boisar	25/Jun/18	8:30	25/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
177	774	400	400kv Boisar-Padghe at Boisar	25/Jun/18	9:00	25/Jun/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II		
178	776	400	400KV Kalwa Main bay (416) at Talegaon	25/Jun/18	9:00	25/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
179	780	400	400 KV AURANGABAD-2 Tie Bay 406 at Akola	25/Jun/18	9:00	25/Jun/18	18:00	Daily	AMP work at Akola end	WRTS-I	WRTS-I		

507th WRPC OCCM approved Monthly Outage list for the Month of Jun'2018

Sr. No	OCC-507 Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
180	783	400 KV	TIE BAY (406) OF AURANGABAD (PG) - 2 & ICT - 2 @ Akola	25/Jun/18	10:00	25/Jun/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
181	792	400KV	Jaigad-Karad Ckt - 1 & 2	25/Jun/18	9:00	28/Jun/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
182	795	220 KV	DEOLI(PGCIL)-BADNERA	25/Jun/18	8:00	30/Jun/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
183	803	400 KV	AKOLA - KHADKA (BHUSAWAL)	26/Jun/18	6:00	28/Jun/18	20:00	Daily	For replacement of faulty disc insulator string	MSETCL	MSETCL		
184	805	400 KV	CHANDRAPUR - BHADRAVATI CKT - 3	26/Jun/18	8:00	26/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL		
185	806	220	Bay No. 205 Transfer Bus at Boisar	26/Jun/18	8:30	26/Jun/18	17:30	Daily	For Bay AMP	PGCIL	WR-II		
186	808	400	400KV Pune GIS-4 & ICT-2 Tie bay (411) at Talegaon	26/Jun/18	9:00	26/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
187	815	400	400kv Boisar-Padghe at Boisar	26/Jun/18	14:00	26/Jun/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II		
188	818	400	400 KV Koradi Main bay at Bhilai SS	27/Jun/18	9:30	27/Jun/18	17:30	Daily	AMP work at Bhilai SS	WRTS-I	WRTS-I		
189	822	400	400kv Bhadrawati-Chandrapur-4 (GCR side) Main bay at (Chandrapur MSETCL)	27/Jun/18	9:00	30/Jun/18	18:00	Conti..	Overhauling mechanism of CGL CB	WRTS-I	WRTS-I		
190	825	400	40kv Tarapur-Boisar-I at Boisar	27/Jun/18	9:00	27/Jun/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II		
191	826	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	27/Jun/18	9:00	27/Jun/18	17:00	Daily	Outage For hardware/Earth wire clamp n/b tightening Work Loc.No.925, 949, 947	MSETCL	MSETCL		
192	845	400	400KV Talegaon Lonikand Line at Talegaon	28/Jun/18	9:00	28/Jun/18	16:00	Daily	For line Isolator Alignment & AMP of Line Equipments	MSETCL	WRTS-I		Friday . To be availed on Thursday
193	857	400 KV	Main Bay (428) of 400 KV Warora Ckt-I @ Chandrapur - 2	28/Jun/18	9:00	28/Jun/18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
194	859	220	220KV Urse Line-2 Main bay (208) at Talegaon	28/Jun/18	9:00	28/Jun/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
195	861	400KV	Koyna Stage IV-Jejuri	28/Jun/18	9:00	28/Jun/18	18:00	Daily	Cold washing of Insulators & Insulator replacement work	MSETCL	MSETCL		
196	862	400	400 KV Bus -1 at Wardha	28/Jun/18	9:00	28/Jun/18	18:00	Daily	Aligment of newly erected bus isolator	WRTS-I	WRTS-I		
197	865	400	40kv Tarapur-Boisar-I at Boisar	28/Jun/18	14:00	28/Jun/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II		
198	866	400 KV	KORADI-KHADKA	28/Jun/18	6:00	30/Jun/18	20:00	Daily	For replacement of faulty disc insulator string,CT Tan delta,DCRM,Reactor Tan delta.	MSETCL	MSETCL		
199	872	400 KV	CHANDRAPUR - BHADRAVATI CKT - 4 @ Chandrapur	29/Jun/18	8:00	29/Jun/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT	MSETCL	MSETCL		
200	874	400	40kv Tarapur-Boisar-II at Boisar	29/Jun/18	9:00	29/Jun/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II		
201	878	400	400 KV BUS -2 at Wardha	29/Jun/18	9:00	29/Jun/18	18:00	Daily	Aligment of newly erected bus isolator	WRTS-I	WRTS-I	will be facilitated	
202	882	400 KV	PARLI - LONIKAND 2 CKT 2	29/Jun/18	10:00	29/Jun/18	18:00	Daily	Hardware Tightening & Fitting Work At Loc No-137,149,157	MSETCL	MSETCL		
203	890	400	40kv Tarapur-Boisar-II at Boisar	30/Jun/18	14:00	30/Jun/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	PGCIL	WR-II		

State Element outages for the Month of Jun 2018

Sr. No.	I/ U	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
1	1	400 KV	DHULE- - BABLESHWAR - I	1-Jun-18	08:00	4-Jun-18	18:00	Daily	Replacement of PID suspicious disc insulator string	MSETCL	MSETCL	400kv BBLR-2 A/R switch to be kept on non-auto mode
2	1	400 KV	DEEPNAGAR -AURANGABAD	2-Jun-18	08:00	2-Jun-18	16:00	Daily	String replacement at Loc No. 508 DTN work as per availability of agency	MSETCL	MSETCL	-
3	1	400/220KV	600MVA, ICT II @ Kalwa	03-Jun-18	9:00	03-Jun-18	18:00	Daily	Bay Maintenance & Testing work. Premonsoon maintainece.	MSETCL	MSETCL	-
4	1	400 kv	Nagothane - Padgha 1 @ Nagothane	04-Jun-18	9:00	06-Jun-18	18:00	Daily	Faulty Insulator string replacement	MSETCL	MSETCL	-
5	1	400 KV	THAPTI TANDA - WALUJ	4-Jun-18	08:00	4-Jun-18	16:00	Daily	String replacement at Loc No. 508 DTN work as per availability of agency	MSETCL	MSETCL	--
6	1	400 KV	DEEPNAGAR - THAPTI TANDA	5-Jun-18	06:00	10-Jun-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	--
7	1	400 KV	400KV TALANDGE -I @Karad	05-Jun-18	10:00	05-Jun-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kv Talandge 2
8	1	400/220kv	315MVA, ICT 3 @ Kharghar	05-Jun-18	8:00	05-Jun-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
9	1	400 KV	TBC @ PARLI	5-Jun-18	09:00	5-Jun-18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL	-
10	1	400 KV	MAIN BAY-401 OF GT-10 @ KORADI-2	5-Jun-18	10:00	5-Jun-18	17:00	Daily	1)DCRM,CRM & Timing IR of 401-Q52	MSETCL	MSETCL	GT#10 will remain in operation through Tie bay 402
11	1	400 KV	DHULE- - BABLESHWAR - II	5-Jun-18	08:00	8-Jun-18	18:00	Daily	Replacement of PID suspicious disc insulator string	MSETCL	MSETCL	400kv BBLR-1 A/R switch to be kept on non-auto mode
12	1	400 KV	THAPTI TANDA - WALUJ	5-Jun-18	08:00	5-Jun-18	16:00	Daily	String replacement at Loc No. 509 DTN work as per availability of agency	MSETCL	MSETCL	-
13	1	400KV	Talandge-Karad 1@ Talandge	5-Jun-18	9:00	5-Jun-18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	Load manage on 400 kv KARAD 1I
14	1	400/220 KV	315 MVA ICT-III @Karad	06-Jun-18	10:00	06-Jun-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S
15	1	400 KV	GTR BAY 409 & 410 @KHAPARKHEDA S/s	6-Jun-18	08:00	6-Jun-18	14:00	Daily	DCRM, Timing and IR value of CB.	MSETCL	MSETCL	-
16	1	400 KV	TIE BAY-402 OF GT-10 @ KORADI-2	6-Jun-18	10:00	6-Jun-18	17:00	Daily	1)DCRM,CRM & Timing IR of 402-Q52	MSETCL	MSETCL	GT#10 will remain in operation through Main bay 401
17	1	400/220/20 KV	300 MVA ICT - 1 @ KORADI	6-Jun-18	09:00	6-Jun-18	18:00	Daily	diagnostic testing of HV, LV Bushing and preventive maintenance work.	MSETCL	MSETCL	--
18	1	400 KV	THAPTI TANDA - WALUJ	6-Jun-18	08:00	8-Jun-18	16:00	Daily	PID Test	MSETCL	MSETCL	As per availibility of HLU A'bad & real time weather conditions
19	1	400 KV	400KV LONIKAND @Karad	06-Jun-18	10:00	06-Jun-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other 400 kv Ckts
20	1	400 kv	Nagothane - Padgha 2 @ Nagothane	07-Jun-18	9:00	09-Jun-18	18:00	Daily	Faulty Insulator string replacement	MSETCL	MSETCL	-
21	1	400/220/33 KV	500 MVA ICT - 3 @ DHULE	7-Jun-18	08:00	7-Jun-18	18:00	Daily	Routine Maintenance & Dignostic testing work.	MSETCL	MSETCL	-
22	1	400KV	New Koyna- KOYNA Stg IV Ckt-1 @ N.Koyna	07-Jun-18	8:00	07-Jun-18	17:00	one day	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
23	1	400/220kv	500MVA, ICT 1 @ Lamboti	08-Jun-18	8:00	08-Jun-18	18:00	Daily	Overhauling, Servicing & Maintenance of Centre Break Isolators.	MSETCL	MSETCL	-
24	1	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2 at Chandrapur GCR	8-Jun-18	08:00	8-Jun-18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work	MSETCL	MSETCL	400KV CHD-I CHD-II CKT No.I & 400 KV CHD-PARLI ckt No.-III will be in service.
25	1	400/220kv	500MVA, ICT 2 @ Lamboti	09-Jun-18	8:00	09-Jun-18	18:00	Daily	Overhauling, Servicing & Maintenance of Centre Break Isolators.	MSETCL	MSETCL	-
26	1	400 KV	DEEPNAGAR AURANGABAD	9-Jun-18	08:00	9-Jun-18	16:00	Daily	Line Signature Test	MSETCL	MSETCL	-
27	1	400 kv	315MVA ICT 1 @ Nagothane	11-Jun-18	9:00	11-Jun-18	18:00	Daily	Premansoon Maintenance work	MSETCL	MSETCL	-

Sr. No.	I/ U	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
28	1	400 KV	THAPTI TANDA - WALUJ	11-Jun-18	08:00	11-Jun-18	16:00	Daily	Line Signature Test	MSETCL	MSETCL	-
29	1	400 KV	DEEPNAGAR AURANGABAD	11-Jun-18	06:00	16-Jun-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	--
30	1	400/220/33 KV	167 MVA SPARE ICT @ KHAPARKHEDA	11-Jun-18	08:00	11-Jun-18	15:00	Daily	Pre monsoon Maintenance work. HV,MV,LV bushing Tan delta & cap. Winding Tan delta & Cap and IR value.	MSETCL	MSETCL	--
31	1	400KV	400 KV N.Koyna-Karad Ckt 1	11-Jun-18	9:00	13-Jun-18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	400 KV N.Koyna-Karad Ckt 2 will be in service
32	1	400KV	New Koyna- KOYNA Stg IV Ckt-2 @ N.Koyna	11-Jun-18	8:00	11-Jun-18	17:00	one day	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
33	1	400 kv	315MVA ICT 2 @ Nagothane	12-Jun-18	9:00	12-Jun-18	18:00	Daily	Premonsoon Maintenance work	MSETCL	MSETCL	
34	1	400 KV	GT-10 @ KORADI-2	12-Jun-18	10:00	12-Jun-18	18:00	Daily	1) Tan delta measurement of Line CT of Bay 401 & 2) Relay Testing of high teed & low teed relay at bay 401 & 402 3) Tan delta measurement of Bus CT of Bay 401 & 402	MSETCL	MSETCL	1)NOC will be required from Mahagenco. 2) GT#8 & GT#9 will be service.
35	1	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	12-Jun-18	09:00	12-Jun-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
36	1	400 kv	500 MVA ICT 3 @ Nagothane	13-Jun-18	9:00	13-Jun-18	18:00	Daily	Premonsoon Maintenance work	MSETCL	MSETCL	
37	1	400 KV	TBC @ KORADI - 2 S/S	13-Jun-18	09:00	13-Jun-18	17:00	Daily	Diagnostic Testing and Preventive Bay maintenance work will be carried out	MSETCL	MSETCL	--
38	1	400/220kv	315MVA, ICT 1 @ 400 KV Chakan	14-Jun-18	8:00	14-Jun-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	
39	1	400KV	Jaigad-Newkoyna Ckt- 1	14-Jun-18	9:00	14-Jun-18	18:00	Daily	Coldline washing	JPTL	JPTL	
40	1	400/220kv	501 MVA, ICT 2 at 400kv Jejuri S/stn.	14-Jun-18	9:00	14-Jun-18	18:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load will be on 400/220 KV 501 MVA ICT 1
41	1	400KV	New Koyna-Karad-Ckt-1 @ N.Koyna	14-Jun-18	8:00	14-Jun-18	17:00	one day	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
42	1	400KV	Jaigad-Newkoyna Ckt- 2	15-Jun-18	9:00	15-Jun-18	18:00	Daily	Coldline washing	JPTL	JPTL	
43	1	400 KV	DEEPNAGAR - AURANGABAD @ Deepnagar	15-Jun-18	08:00	15-Jun-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
44	1	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	15-Jun-18	08:00	15-Jun-18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL	400KV CHD-I CHD-II CKT No.II & 400 KV CHD-PARLI ckt No.-III will be in service.
45	1	400/220/33 KV	315 MVA ICT - 2 @ WALUJ	15-Jun-18	09:00	15-Jun-18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	-
46	1	400 KV	CHANDRAPUR - KHAPERKHEDA	16-Jun-18	08:00	30-Jun-18	19:00	Daily	PID Testing work	MSETCL	MSETCL	Line required in Non-auto mode.
47	1	400KV	Jaigad-Karad Ckt - 1	18-Jun-18	9:00	18-Jun-18	18:00	Daily	Coldline washing	JPTL	JPTL	
48	1	400 KV	THAPTI TANDA - WALUJ	18-Jun-18	08:00	23-Jun-18	16:00	Daily	PID Test	MSETCL	MSETCL	As per availiblty of HLU A'bad & real time weather conditions
49	1	400 KV	DEEPNAGAR - THAPTI TANDA	18-Jun-18	06:00	20-Jun-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	--
50	1	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	18-Jun-18	06:00	18-Jun-18	18:00	Daily	Bushing(400 KV & 132 KV) ,winding,SFRA ,Relay Testing(Differential,LBB ,Backup relay),RTCC Panel commissioning	MSETCL	MSETCL	--
51	1	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	19-Jun-18	06:00	19-Jun-18	18:00	Daily	Bushing(400 KV & 132 KV) ,winding,SFRA ,Relay Testing(Differential,LBB ,Backup relay),RTCC Panel commissioning	MSETCL	MSETCL	--

Sr. No.	I/ U	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
52	1	400KV	Jaigad-Karad Ckt - 2	19-Jun-18	9:00	19-Jun-18	18:00	Daily	Coldline washing	JPTL	JPTL	
53	1	400 KV	TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	20-Jun-18	09:00	20-Jun-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
54	1	400/220kV	315MVA, ICT 2 @ 400 kV Chakan	21-Jun-18	8:00	21-Jun-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	
55	1	400 KV	DEEPNAGAR AURANGABAD	21-Jun-18	06:00	23-Jun-18	20:00	Daily	For Replacement of Faulty Mid sapn joint & dead end	MSETCL	MSETCL	--
56	1	400 KV	400/11kV STN-4B @ DEEPNAGAR	22-Jun-18	08:00	22-Jun-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
57	1	400 KV	400KV TBC @Karad	27-Jun-18	10:00	27-Jun-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	
58	1	400 KV	TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	27-Jun-18	09:00	27-Jun-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
59	1	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	28-Jun-18	07:00	28-Jun-18	17:00	Daily	Bay 422 CB DCRM ,CRM and IR Values Testing works isolater maintainance work .	MSETCL	MSETCL	Only 400KV Bay Future Line-II Main CB -Bay 422 is charged on No Load. Presently No Line is ready .
60	1	400/220/33 KV	500MVA ICT - 1 @ DEEPNAGAR	29-Jun-18	08:00	29-Jun-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	--