

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of Jun 2020

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
1	41	765KV-AKOLA (2)-KORADI-III-1	1-Jun-2020	08:00	3-Jun-2020	18:00	Daily	MEGPTCL	A/R mode to be kept OFF for attending additional earthing in towers	A/R mode to be kept OFF for attending additional earthing in towers
2	46	400KV-BABLESHWAR-PADGHE-1	1-Jun-2020	08:00	10-Jun-2020	18:00	Daily	MSETCL	For Carrying PID Work	-
3	47	TBC @ KORADI-1	1-Jun-2020	08:00	14-Jun-2020	18:00	Continuous	MSETCL	CB pole and mechanism Overhauling & testing	Outages will be availed subject to weather conditions.
4	48	400KV-LONIKHAND-PUNE-PG-1	1-Jun-2020	09:30	15-Jun-2020	17:30	Daily	MSETCL	PID testing.	---
5	74	220KV-WARDHA-PUSAD-1	1-Jun-2020	07:00	30-Jun-2020	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	nil
6	75	400KV-JEJURI-KOYNA STAGE IV-1	1-Jun-2020	08:00	30-Jun-2020	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK
7	76	400KV-CHANDRAPUR-II-NANDED-2	1-Jun-2020	08:00	30-Jun-2020	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	nil
8	77	400KV-KOYNA STAGE IV-LONIKHAND-1	1-Jun-2020	08:00	30-Jun-2020	17:00	Daily	MSETCL	[PID TESTING WORK	[PID TESTING WORK
9	78	CHANDRAPUR-PARLI CKT-3400KV-CHANDRAPUR-GCR-PARLI-M-3	1-Jun-2020	08:00	30-Jun-2020	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	These times are on DC tower so both times require on same day A/R out.
10	79	400KV-KARAD-KOLHAPUR-MS-1	1-Jun-2020	09:00	30-Jun-2020	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK
11	130	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	2-Jun-2020	09:00	2-Jun-2020	17:00	Daily	MSETCL	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	400KV PGCIL Line will be charged through MAIN CB 420.
12	133	400KV-SSP-DHULE-MS-1	2-Jun-2020	08:00	3-Jun-2020	18:00	Daily	MSETCL	Replacement of PID suspicious disc insulator and maintenance work	400kV SSNNL-2 A/R switch kept on non auto mode
13	134	400KV-SSP-DHULE-MS-2	2-Jun-2020	09:00	3-Jun-2020	18:00	Daily	MSETCL	Online PID testing work	400kV SSNNL-2 A/R switch kept on non auto mode
14	137	400KV-RGPPL-NEW KOYNA-1	2-Jun-2020	09:00	4-Jun-2020	18:00	c	RGPPPL	Bkr 402-52 A PM & testing.	
15	139	220KV-NASIK-NAVSARI-1	2-Jun-2020	09:00	4-Jun-2020	18:00	Daily	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixing if issued.	-
16	140	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-1 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	2-Jun-2020	09:00	6-Jun-2020	18:00	C	POWERGRID WR1	For replacement of BHEL make CB.	
17	142	400KV-KARAD-KOLHAPUR-MS-2	2-Jun-2020	08:00	30-Jun-2020	17:00	Daily	MSETCL	PID TESTING WORK	PID TESTING WORK
18	143	400KV-KALWA-KHARGHAR-1	2-Jun-2020	09:00	30-Jun-2020	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service	-
19	185	220KV-PARLI-OSMANABAD-M-1	3-Jun-2020	08:00	3-Jun-2020	17:00	Daily	MSETCL	Line maintenance work	-
20	186	132KV-PENCH-KANHAN-1	3-Jun-2020	09:00	3-Jun-2020	17:00	Daily	MSETCL	Routine Maintenance work.	-
21	187	400KV-IEPL-KORADI-II-1	3-Jun-2020	09:00	3-Jun-2020	18:00	Daily	MSETCL	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	-
22	188	400KV-PARLI-M-SOLAPUR-M-1	3-Jun-2020	09:00	3-Jun-2020	18:00	Daily	MSETCL	String replacement work	-
23	189	MAIN BAY - 413 OF GT-9 @ KORADI-2	3-Jun-2020	10:00	3-Jun-2020	13:00	Daily	MSETCL	Tan delta Measurement of Bus CT of Bay 413	GT 09 will remain in service through tie bay 414
24	190	132KV-DHARNI-NEPANAGAR-1	3-Jun-2020	10:00	3-Jun-2020	16:00	Daily	MSETCL	Routine maintenance & Dignostic testing work and Line signature analysis	NIL
25	191	400KV-PARLI-M-SOLAPUR-M-1	3-Jun-2020	10:00	3-Jun-2020	18:00	Daily	MSETCL	Diagnostic Testing work	Load will be Managed on 400KV Lamboti PGCIL Line
26	239	400KV-PADGHE-BOISAR-1	4-Jun-2020	11:00	4-Jun-2020	12:30	D	POWERGRID WR1	For CT oil samples at Padghe (MS) end	
27	242	400KV-LONIKHAND-PUNE-PG-1	4-Jun-2020	09:30	4-Jun-2020	17:30	Daily	MSETCL	DT & Line maintenance work.	---
28	243	TIE BAY - 414 OF GT-9 @ KORADI-2	4-Jun-2020	10:00	4-Jun-2020	13:00	Daily	MSETCL	Tan delta Measurement of Bus CT of Bay 414	GT 09 will remain in service through main bay 413

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
29	244	TIE BAY - 400KV-KALA-KUDUS-1 AND FUTURE at KUDUS - 400KV	4-Jun-2020	10:00	4-Jun-2020	17:00	Daily	MSETCL	Bay 405-(89-B) isolator alignment and 405-(89-A) B-ph isolator motor replacement and maintenance work. Line Bay 406 for safety purpose which is only charged upto line isolator	Line Bay- 404 (Kala ckt-1) will be in service with its main CB at the time of Bay No. 405 and Bay No. 406 outage.
30	245	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	4-Jun-2020	10:00	4-Jun-2020	17:00	Daily	MSETCL	Bay 405-(89-B) isolator alignment and 405-(89-A) B-ph isolator motor replacement and maintenance work. Line Bay 406 for safety purpose which is only charged upto line isolator	Line Bay- 404 (Kala ckt-1) will be in service with its main CB at the time of Bay No. 405 and Bay No. 406 outage.
31	249	400KV-SSP-DHULE-MS-2	4-Jun-2020	08:00	5-Jun-2020	18:00	Daily	MSETCL	Replacement of PID suspicious disc insulator and maintenance work	400kV SSNNL-1 A/R switch kept on non-auto mode
32	254	765KV-AKOLA (2)-KORADI-III-2	4-Jun-2020	08:00	6-Jun-2020	18:00	Daily	MEGPTCL	A/R mode to be kept OFF for attending additional earthing in towers	A/R mode to be kept OFF for attending additional earthing in towers
33	257	400KV-SSP-DHULE-MS-1	4-Jun-2020	09:00	13-Jun-2020	18:00	Daily	MSETCL	Online PID testing work	400kV SSNNL-1 A/R switch kept on non-auto mode
34	261	PARLI-M - 400KV - BUS 2	5-Jun-2020	09:00	5-Jun-2020	18:00	Daily	MSETCL	29B Y phase isolator scissor replacement of 400kV CHD-III line	-
35	265	400 kV-SSP-Dhule-MS-2	5-Jun-2020	07:00	5-Jun-2020	18:00	Daily	GETCO	PMM work.	Auto Reclose out of SSP - Dhule - 1 will remain out
36	286	400KV-TARAPUR 3&4-PADGHE-1	5-Jun-2020	09:00	5-Jun-2020	18:00	D	POWERGRID WR1	For AMP of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.	
37	294	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	5-Jun-2020	08:00	5-Jun-2020	18:00	Daily	MEGPTCL	Reactor Maintenance Activities	Reactor Maintenance Activities
38	299	400KV-RGPPL-NAGOTHANE-1	5-Jun-2020	09:00	6-Jun-2020	18:00	Daily	MSETCL	Routine maint. Work	Planned outage
39	311	AURANGABAD-M (WALUJ) - 400KV - BUS 2	6-Jun-2020	09:00	6-Jun-2020	17:00	Daily	MSETCL	400 kV Waluj Babhaleshwar bay quarterly maintenance	400kV waluj Babhaleshwar bay quarterly maintenance
40	312	400 kV-SSP-Dhule-MS-1	6-Jun-2020	07:00	6-Jun-2020	18:00	Daily	GETCO	PMM work.	Auto Reclose out of SSP - Dhule - 2 will remain out
41	333	220KV-BOISAR-BOISAR-M-1	6-Jun-2020	09:00	6-Jun-2020	17:00	Daily	MSETCL	Premonsoon maintenance work	Premonsoon maintenance work
42	334	BABLESHWAR - 400KV B/R 1	6-Jun-2020	09:00	6-Jun-2020	18:00	Daily	MSETCL	quarterly maintenance work	-
43	335	220KV-TALEGAON-PUNE-PG-1	6-Jun-2020	10:00	6-Jun-2020	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing.	---
44	336	400KV-SSP-DHULE-MS-2	6-Jun-2020	08:00	13-Jun-2020	17:00	Daily	MSETCL	online PID testing work	400kV SSNNL-2 A/R switch kept on non auto mode
45	353	220KV-BOISAR-BOISAR-M-2	7-Jun-2020	09:00	7-Jun-2020	17:00	Daily	MSETCL	Premonsoon maintenance work	Premonsoon maintenance work
46	354	KALWA - 400KV - BUS 2	7-Jun-2020	09:00	7-Jun-2020	18:00	Daily	MSETCL	Bus PT Maintenance & insulator cleaning work	Bus PT Maintenance & insulator cleaning work
47	355	400KV-RGPPL-NEW KOYNA-1	7-Jun-2020	09:00	7-Jun-2020	18:00	Daily	MSETCL	Routine maint. Work	Planned outage
48	395	220KV-PARLI-OSMANABAD-M-1	8-Jun-2020	08:00	8-Jun-2020	17:00	Daily	MSETCL	Vibration damper fixing work	-
49	396	KORADI-III - 765KV - BUS 2	8-Jun-2020	09:00	8-Jun-2020	18:00	Daily	MEGPTCL	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
50	397	400KV-RGPPL-NEW KOYNA-2	8-Jun-2020	09:00	8-Jun-2020	18:00	Daily	MSETCL	Routine maint. Work	Planned Outage
51	407	400KV-TIRODA-WARORA-1	8-Jun-2020	08:00	11-Jun-2020	18:00	Daily	MEGPTCL	A/R mode to be kept OFF for attending additional earthing in towers	A/R mode to be kept OFF for attending additional earthing in towers
52	408	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	8-Jun-2020	09:00	11-Jun-2020	18:00	C	POWERGRID WR1	For replacement of BHEL make CB.	
53	411	400KV-KALWA-PADGHE-2	8-Jun-2020	09:00	13-Jun-2020	17:00	Daily	MSETCL	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	Hotline washing work of line insulator strings at various locations. Auto-Reclose function to be out of service.
54	415	400KV-RGPPL-NAGOTHANE-2	9-Jun-2020	09:00	10-Jun-2020	18:00	Daily	MSETCL	Routine maint. Work	Planned outage
55	454	TIE BAY-402 OF GT-10 @ KORADI-2	9-Jun-2020	10:00	9-Jun-2020	17:00	Daily	MSETCL	Tan delta Measurement of Bus CT and DCRM, IR Measurement of CB of Bay 402	GT10 will remain in service through main bay 401
56	458	220KV-NASIK-NAVSARI-2	9-Jun-2020	09:00	11-Jun-2020	18:00	Daily	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.	-
57	497	400KV-KORADI-SATPURA	10-Jun-2020	09:00	10-Jun-2020	18:00	D	POWERGRID WR1	For Bay equipments and terminal equipments at Koradi end & line AMP works	
58	510	220KV-PARLI-OSMANABAD-M-1	10-Jun-2020	08:00	10-Jun-2020	17:00	Daily	MSETCL	Line maintenance work	-
59	511	MAHALAXMI - AMONA220KV-MAHALAXMI(KONALKATTA)-AMONA-1	10-Jun-2020	09:00	10-Jun-2020	17:00	Daily	MSETCL	quarterly maintenance	-

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
60	512	132KV-MANSAR-MS-PENCH-1	10-Jun-2020	09:00	10-Jun-2020	17:00	Daily	MSETCL	Routine Maintenance work.	--
61	513	KORADI-III - 765KV - BUS 1	10-Jun-2020	09:00	10-Jun-2020	18:00	Daily	MEGPTCL	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
62	514	400KV-PARLI-M-SOLAPUR-M-1	10-Jun-2020	09:00	10-Jun-2020	18:00	Daily	MSETCL	String replacement work	-
63	515	400KV-WARDHA-KORADI-II-1	10-Jun-2020	09:00	10-Jun-2020	18:00	Daily	MSETCL	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	--
64	516	SOLAPUR-M - 400KV - BUS 2	10-Jun-2020	10:00	10-Jun-2020	18:00	Daily	MSETCL	Diagnostic Testing Work	Load will be managed on 400KV Main Bus I
65	517	220KV-WARDHA-WARDHA-M-1	10-Jun-2020	10:00	10-Jun-2020	18:00	Daily	MSETCL	restringing of conductor from loc no 3-5 for mentaining clearence , Line maintainace, Broken disc replacement/flashover if any	NA
66	520	220KV-PANDURNA-KALMESHWAR-1	10-Jun-2020	08:00	11-Jun-2020	18:00	Daily	MSETCL	Routine Maintenance & conductor restringing work.	--
67	548	400KV-BHILAI-KORADI	11-Jun-2020	09:00	11-Jun-2020	18:00	D	POWERGRI D WR1	For Bay equipments and Terminal equipments AMP works with LR at Koradi end & line AMP works	
68	556	220KV-WARDHA-PUSAD-1	11-Jun-2020	07:00	11-Jun-2020	17:00	Daily	MSETCL	For Routine Maintenance Work	nil
69	557	400KV-WARDHA-WARORA-1	11-Jun-2020	09:00	11-Jun-2020	17:00	Daily	MSETCL	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	400KV WARORA-IEPL Line is in ckt
70	558	400KV-LONIKHAND-CHAKAN-1	11-Jun-2020	09:30	11-Jun-2020	17:30	Daily	MSETCL	DT & Line maintenance work.	---
71	567	400KV-WARDHA-WARORA-PG-1	12-Jun-2020	09:00	12-Jun-2020	18:00	D	POWERGRI D WR1	For Earth Wire Restoration & 400KV-WARDHA-Warora-2 AR to be keep in non auto mode for safety measures.	
72	571	400KV-PARLI-M-PARLI-1	12-Jun-2020	09:00	12-Jun-2020	18:00	Daily	MSETCL	(1) CB and CVT testing work. (2) Bay Maint. Work.	-
73	602	220KV-TARAPUR 1&2-BORIVALI-1	12-Jun-2020	09:00	12-Jun-2020	17:00	Daily	MSETCL	Premonsoon maintenance work	Premonsoon maintenance work
74	603	220KV-BOISAR-NALASOPARA-1	12-Jun-2020	09:00	12-Jun-2020	17:00	Daily	MSETCL	Premonsoon maintenance work	Premonsoon maintenance work
75	604	KORADI-III - 400KV - BUS 1	12-Jun-2020	09:00	12-Jun-2020	18:00	Daily	MEGPTCL	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
76	605	220KV-WARDHA-BADNERA-1	12-Jun-2020	10:00	12-Jun-2020	18:00	Daily	MSETCL	Routine Line maintainace, Broken disc replacement/flashover if any	NA
77	606	400KV-TAPTHITHANDA-EKTUNI-1	12-Jun-2020	11:00	12-Jun-2020	17:00	Daily	MSETCL	Quarterly maintenance , CT Tan d measurement	Nil
78	609	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	12-Jun-2020	08:00	14-Jun-2020	18:00	Continuous	MSETCL	For replacement of quadruple conductor span between 400kV Talegaon and Kalwa line of 400kV A bus	400kV A bus load will be shifted on B bus
79	610	KHARGHAR - 400KV - BUS 1	12-Jun-2020	08:00	14-Jun-2020	18:00	Continuous	MSETCL	For replacement of quadruple conductor span between 400kV Talegaon and Kalwa line of 400kV A bus	400kV A bus load will be shifted on B bus
80	612	400KV-TIRODA-WARORA-2	12-Jun-2020	08:00	15-Jun-2020	18:00	Daily	MEGPTCL	A/R mode to be kept OFF for attending additional earthing in towers	A/R mode to be kept OFF for attending additional earthing in towers
81	630	400KV-KHANDWA-DHULE-MS-2	13-Jun-2020	09:00	13-Jun-2020	18:00	D	POWERGRI D WR2	For Line AMP Works by Khandwa TLM. A/R OFF of ckt-1 and dia to be kept open at both ends.	PG-Khandwa
82	631	400KV-WARDHA-KORADI-II-1	13-Jun-2020	09:00	13-Jun-2020	17:00	Daily	MSETCL	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	400 KV WARORA - DEOLI 2 Line is in ckt
83	632	220KV-TALEGAON-PUNE-PG-2	13-Jun-2020	10:00	13-Jun-2020	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing.	---
84	644	220KV-TARAPUR 1&2-BOISAR-M-1	14-Jun-2020	09:00	14-Jun-2020	17:00	Daily	MSETCL	Premonsoon maintenance work	Premonsoon maintenance work
85	665	220KV-MUDSHINGI-CHIKKODI-II-1	15-Jun-2020	09:00	15-Jun-2020	17:00	Daily	Maharashtra	Half yearly maint. Of 220 kV Bus section II & III ,PT-II and Quarterly maint. Of 220 kV Chikodi bay equipment at 220 kV Mudshingi s/stn	
86	688	400KV-RGPPL-NAGOTHANE-1	15-Jun-2020	08:00	15-Jun-2020	17:00	Daily	MSETCL	Emergency tree cutting work	nil
87	689	220KV-MUDSHINGI-CHIKKODI-II-1	15-Jun-2020	09:00	15-Jun-2020	17:00	Daily	MSETCL	quarterly maintenance	-
88	695	400KV-KARAD-JAIGAD-1	15-Jun-2020	09:00	18-Jun-2020	18:00	Daily	JPTL	Hotline insulator washing work	AR to be kept in Non auto mode for both circuit
89	696	400KV-KARAD-JAIGAD-2	15-Jun-2020	09:00	18-Jun-2020	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both circuit
90	697	400KV-KALWA-KHARGHAR-1	15-Jun-2020	09:00	20-Jun-2020	17:00	Daily	MSETCL	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
91	698	400KV-KALWA-PUNE-PG-1	15-Jun-2020	09:00	20-Jun-2020	17:00	Daily	MSETCL	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
92	736	400KV-RGPPL-NAGOTHANE-2	16-Jun-2020	08:00	16-Jun-2020	17:00	Daily	MSETCL	Emergency tree cutting work	nil
93	737	765KV/400KV AKOLA (2)-ICT-1	16-Jun-2020	09:00	16-Jun-2020	18:00	Daily	MEGPTCL	Annual Maintenance of 1500MVA ICT	Annual Maintenance of 1500MVA ICT
94	738	PARLI-M - 400KV - BUS 1	16-Jun-2020	09:00	16-Jun-2020	18:00	Daily	MSETCL	29 A Y Phase isolator replacement work of PG-1 Bay	-
95	742	220KV-WARDHA-PUSAD-1	16-Jun-2020	10:00	18-Jun-2020	18:00	Daily	MSETCL	Routine maintenance work	NA
96	745	400KV-LONIKHAND-CHAKAN-1	16-Jun-2020	09:30	30-Jun-2020	17:30	Daily	MSETCL	PID Testing.	---
97	789	400KV-RGPPL-NAGOTHANE-1	17-Jun-2020	08:00	17-Jun-2020	17:00	Daily	MSETCL	Emergency tree cutting work	nil
98	790	220KV-PARLI-PARLI-M-1	17-Jun-2020	08:00	17-Jun-2020	17:00	Daily	MSETCL	Line maintenance work	-
99	791	220KV-PANDURNA-KALMESHWAR-1	17-Jun-2020	08:00	17-Jun-2020	18:00	Daily	MSETCL	Routine Maintenance & conductor restringing work.	-
100	792	220KV-TILLARI-AMONA-1	17-Jun-2020	09:00	17-Jun-2020	17:00	Daily	MSETCL	quarterly maintenance	-
101	793	KORADI-III - 400KV - BUS 2	17-Jun-2020	09:00	17-Jun-2020	18:00	Daily	MSETCL	For replacement of B phase rotary of 29 B isolator of 400kV koradi-Khaperkheda ckt 2	Outages will be availed subject to weather conditions.
102	794	400KV-PARLI-M-SOLAPUR-M-1	17-Jun-2020	09:00	17-Jun-2020	18:00	Daily	MSETCL	String replacement work	-
103	803	TALEGAON - 220KV - BUS 2	18-Jun-2020	09:00	18-Jun-2020	18:00	D	POWERGRID WRI	For AMP works	
104	805	SOLAPUR-M - 400KV - BUS 1	18-Jun-2020	10:00	18-Jun-2020	18:00	Daily	MSETCL	Diagnostic Testing Work	Load will be managed on 400KV Main Bus II
105	833	MAIN BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND LONIKHAND-II - 400KV - BUS 2 at LONIKHAND-II - 400KV	18-Jun-2020	06:00	18-Jun-2020	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 2 will be in service for no supply interruption
106	834	400KV-RGPPL-NAGOTHANE-2	18-Jun-2020	08:00	18-Jun-2020	17:00	Daily	MSETCL	Emergency tree cutting work	nil
107	835	400KV-PARLI-M-PARLI-2	18-Jun-2020	09:00	18-Jun-2020	18:00	Daily	MSETCL	(1) Distance relay testing work. (2) Bay Maint. Work.	-
108	851	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-1 AND FUTURE at LONIKHAND-II - 400KV	19-Jun-2020	06:00	19-Jun-2020	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 2 will be in service for no supply interruption
109	883	765KV-AKOLA (2)-EKTUNI-2 L/R@ AKOLA (2) - 765KV	19-Jun-2020	09:00	19-Jun-2020	18:00	Daily	MEGPTCL	Reactor Maintenance Activities	Reactor Maintenance Activities
110	884	400KV-TAPTHITHANDA-EKTUNI-2	19-Jun-2020	11:00	19-Jun-2020	17:00	Daily	MSETCL	Quarterly maintenance , CT Tan d measurement	Nil
111	887	400KV-JAIGAD-NEW KOYNA-1	19-Jun-2020	09:00	20-Jun-2020	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt
112	888	400KV-JAIGAD-NEW KOYNA-2	19-Jun-2020	09:00	20-Jun-2020	18:00	Daily	JPTL	Hotline insulator washing works	AR to be kept in Non auto mode for both ckt
113	889	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	19-Jun-2020	08:00	21-Jun-2020	18:00	Continuous	MSETCL	For replacement of quadruple conductor span between 400kV Talegaon and Kalwa line of 400kV B bus	400kV B bus load will be shifted on A bus
114	890	KHARGHAR - 400KV - BUS 2	19-Jun-2020	08:00	21-Jun-2020	18:00	Continuous	MSETCL	For replacement of quadruple conductor span between 400kV Talegaon and Kalwa line of 400kV B bus	400kV B bus load will be shifted on A bus
115	898	220KV-PARLI-HARANGUL-M-1	20-Jun-2020	08:00	20-Jun-2020	17:00	D	POWERGRID WRI	For bay AMP works	
116	911	400KV-KHARGHAR-PUNE-PG-1	20-Jun-2020	07:00	20-Jun-2020	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
117	912	220KV-TALEGAON-PUNE-PG-1	20-Jun-2020	10:00	20-Jun-2020	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing.	---
118	917	400KV-KALWA-PADGHE-2	21-Jun-2020	07:00	21-Jun-2020	18:00	Daily	MSETCL	Bay Maintenance & Testing work.	Bay Maintenance & Testing work.
119	932	400KV-DHULE-MS-BABLESHWAR-2	21-Jun-2020	08:00	30-Jun-2020	18:00	Daily	MSETCL	For Carrying PID Work	-
120	933	400KV-DHULE-MS-BABLESHWAR-1	21-Jun-2020	08:00	30-Jun-2020	18:00	Daily	MSETCL	For Carrying PID Work	-
121	970	CHANDRAPUR - 400KV - BUS 1	22-Jun-2020	09:00	24-Jun-2020	18:00	C	POWERGRID WRI	For Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2	
122	971	400KV-KALWA-PADGHE-2	22-Jun-2020	09:00	27-Jun-2020	17:00	Daily	MSETCL	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	Hotline washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
123	983	220KV-PARLI-PARLI-M-1	23-Jun-2020	08:00	23-Jun-2020	17:00	D	POWERGRID WRI	For bay AMP works	
124	992	220KV-Pandhurna-MP-Kamleshwar	23-Jun-2020	09:00	23-Jun-2020	18:00	D	MP_SLDC	For line maintenance work	
125	1010	220KV-WARDHA-BHUGAON-1	23-Jun-2020	10:00	25-Jun-2020	18:00	Daily	MSETCL	Routine maintenance work	NA
126	1033	220KV-PARLI-PARLI-M-2	24-Jun-2020	08:00	24-Jun-2020	17:00	Daily	MSETCL	Line maintenance work	-
127	1034	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	24-Jun-2020	09:00	24-Jun-2020	17:00	Daily	MSETCL	Routine Maintenance & Diagnostic testing work .	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
128	1035	400KV-PARLI-M-SOLAPUR-M-1	24-Jun-2020	09:00	24-Jun-2020	18:00	Daily	MSETCL	String replacement work	-
129	1036	BUS COUPLER BAY - KORADI - 400KV - BUS 1 AND KORADI - 400KV - BUS 2 at Koradi - 400KV	24-Jun-2020	09:00	24-Jun-2020	18:00	Daily	MSETCL	CT tan delta measurement and testing work	
130	1037	400KV-SOLAPUR-M-SOLAPUR-1	24-Jun-2020	10:00	24-Jun-2020	18:00	Daily	MSETCL	Line Maintenance Work	Load will be managed on 400KV Lamboti - Parali Line
131	1044	AURANGABAD-M (WALUJ) - 400KV - BUS 1	25-Jun-2020	09:00	25-Jun-2020	17:00	Daily	MSETCL	Quarterly maintenance	Quarterly maintenance
132	1070	MAIN BAY (410) OF PARLI CKT - 2 @ LONIKAND 2	25-Jun-2020	06:00	25-Jun-2020	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 1 will be in service for no supply interruption.
133	1071	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND FUTURE at LONIKHAND-II - 400KV	25-Jun-2020	06:00	25-Jun-2020	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	Parali Ckt 1 will be in service for no supply interruption.
134	1072	220KV-WARDHA-PUSAD-1	25-Jun-2020	07:00	25-Jun-2020	17:00	Daily	MSETCL	For Routine Maintenance Work	nil
135	1073	TIE BAY (428) OF WARORA - WARDHA(PG) @ WARDHA (PG)TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	25-Jun-2020	09:00	25-Jun-2020	17:00	Daily	MSETCL	Routine Maintenance & Diagnostic testing work .	Line will be charged through main CB 429
136	1074	400KV-LONIKHAND-CHAKAN-1	25-Jun-2020	09:30	25-Jun-2020	17:30	Daily	MSETCL	DT & Line maintenance work.	---
137	1086	CHANDRAPUR - 400KV - BUS 2	26-Jun-2020	09:00	28-Jun-2020	18:00	C	POWERGRID WRI	For Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2	
138	1096	220 kV Navsari-Nashik Line No.1	26-Jun-2020	09:00	26-Jun-2020	18:00	Daily	GETCO	maintenance work	
139	1115	220 kV Navsari-Nashik Line No.2	27-Jun-2020	09:00	27-Jun-2020	18:00	Daily	GETCO	maintenance work	
140	1121	400KV-BABLESHWAR-PADGHE-1	27-Jun-2020	09:00	27-Jun-2020	18:00	Daily	MSETCL	quarterly maintenance work	-
141	1122	220KV-TALEGAON-PUNE-PG-2	27-Jun-2020	10:00	27-Jun-2020	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostic Testing.	---
142	1127	400KV-KALWA-PADGHE-1	28-Jun-2020	07:00	28-Jun-2020	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
143	1151	400KV-KALWA-KHARGHAR-1	29-Jun-2020	07:00	29-Jun-2020	18:00	Daily	MSETCL	Insulator Cleaning & Routine Maintenance work	Insulator Cleaning & Routine Maintenance work
144	1152	400KV-KALWA-KHARGHAR-1	29-Jun-2020	08:00	29-Jun-2020	18:00	Daily	MSETCL	RM & Diagnostic testing work	400kV Talegaon line will be in service
145	1169	400KV-BABLESHWAR-PADGHE-2	29-Jun-2020	09:00	29-Jun-2020	18:00	Daily	MSETCL	quarterly maintenance work	-

Maharashtra State Load Despatch Centre											
State Element Outage list for the month of Jun 2020											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	KARAD - TALANDGE CKT 2	01-Jun-20	08:00	01-Jun-20	18:00	Daily	PID Faulty string replacement work	MSETCL	MSETCL	PID Faulty string replacement work
2	400 KV	KARAD - TALANDGE CKT 1	02-Jun-20	09:00	02-Jun-20	18:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	Quarterly Maintenance Work
3	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	02-Jun-20	10:00	02-Jun-20	14:00	Daily	Premonsoon maintenance work and relay testing work.	MSETCL	MSETCL	-
4	400 KV	KARAD - TALANDGE CKT 1	02-Jun-20	08:00	02-Jun-20	17:00	Daily	PID FAULTY STRING INSULATOR REPLACEMENT WORK	MSETCL	MSETCL	PID FAULTY STRING INSULATOR REPLACEMENT WORK
5	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	03-Jun-20	09:00	03-Jun-20	18:00	Daily	Pre-pre Monsoon maint. Work	MSETCL	MSETCL	Planned outage
6	400 KV	NEW KOYNA -KARAD -CKT 2	03-Jun-20	08:00	03-Jun-20	18:00	Daily	PID FAULTY INSULATOR STRING REPLACEMENT WORK	MSETCL	MSETCL	PID FAULTY INSULATOR STRING REPLACEMENT WORK
7	400 KV	KORADI-KHAPERKHEDA I	03-Jun-20	09:00	03-Jun-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	-
8	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	04-Jun-20	10:00	04-Jun-20	14:00	Daily	Premonsoon maintenance work and relay testing work.	MSETCL	MSETCL	-
9	400 KV	CHANDRAPUR-PARLI CKT-3	04-Jun-20	09:00	04-Jun-20	18:00	Daily	29B Y phase isolator scissor replacement of 400kV CHD-III line	MSETCL	MSETCL	Either 400kV CHD ckt-3 or Nanded ckt-I at Girwali outage is required
10	400 KV	105 MVA SPARE ICT @ CHAKAN	04-Jun-20	09:00	04-Jun-20	18:00	Daily	Half yearly testing and maintenance activities.	MSETCL	MSETCL	---
11	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	04-Jun-20	09:00	04-Jun-20	18:00	Daily	Pre-pre Monsoon maint. Work	MSETCL	MSETCL	Planned outage
12	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	04-Jun-20	06:00	04-Jun-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption.
13	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	04-Jun-20	09:00	04-Jun-20	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	----
14	400 KV	MAIN BAY (419) OF 400/220/33kV 500MVA ICT-I @ LONIKAND 2	04-Jun-20	06:00	04-Jun-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption.
15	400 KV	JEJURI- KOYNA STAGE-IV	04-Jun-20	08:00	04-Jun-20	18:00	Daily	PID FAULTY STRING REPLACEMENT WORK	MSETCL	MSETCL	PID FAULTY STRING REPLACEMENT WORK
16	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	04-Jun-20	09:00	04-Jun-20	17:00	Daily	Hardware tightening work at loc No. 411,423	MSETCL	MSETCL	-
17	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	04-Jun-20	10:00	04-Jun-20	14:00	Daily	Premonsoon maintenance work,Line CTR chance i.e enhance	MSETCL	MSETCL	-
18	400 KV	125MVAr BUS REACTOR @ WARORA	04-Jun-20	09:00	04-Jun-20	17:00	Daily	Pre-monsoon activity maintenance work	MSETCL	MSETCL	Reactor is in OFF condition during outage.
19	400 KV	NEW KOYNA-KARAD -CKT 1	05-Jun-20	08:00	05-Jun-20	18:00	Daily	PID FAULTY STRING REPLACEMENT WORK	MSETCL	MSETCL	PID FAULTY STRING REPLACEMENT WORK
20	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	06-Jun-20	08:00	06-Jun-20	18:00	Daily	For RM and Diagnostic testing work	MSETCL	MSETCL	ICT-1&2 will be in service
21	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	06-Jun-20	10:00	06-Jun-20	17:00	Daily	Line maintenance work	MSETCL	MSETCL	-
22	400 KV	NEW KOYNA -KARAD -CKT 2	06-Jun-20	08:00	06-Jun-20	18:00	Daily	PID FAULTY STRING REPLACEMENT WORK	MSETCL	MSETCL	PID FAULTY STRING REPLACEMENT WORK
23	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	08-Jun-20	06:00	08-Jun-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	spare ICT.
24	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	08-Jun-20	08:30	08-Jun-20	17:30	Daily	HV LV Tertiary Bushing & Winding Tan delta measurement also Pre monsoon maintenance activity & 200KV LV bay maintenance work	MSETCL	MSETCL	During outage load will be managed on 501 MVA ICT-2 unit.
25	400 KV	KARAD - TALANDGE CKT 2	08-Jun-20	08:00	09-Jun-20	18:00	Daily	PID FAULTY STRING REPLACEMENT WORK	MSETCL	MSETCL	PID FAULTY STRING REPLACEMENT WORK
26	400 KV	PADGHE - NAGOTHANE I	08-Jun-20	08:00	08-Jun-20	17:00	Daily	Jumper tightening and cold washing work	MSETCL	MSETCL	nil
27	400 KV	400 KV FUTURE BAY II @ WARORA	09-Jun-20	09:00	09-Jun-20	17:00	Daily	Routine bay maintenance	MSETCL	MSETCL	400 KV Bay No 422 charged on No Load
28	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	09-Jun-20	09:00	09-Jun-20	18:00	Daily	quarterly maintenance work	MSETCL	MSETCL	-
29	400 KV	NEW KOYNA - STAGE IV CKT 1	09-Jun-20	09:00	09-Jun-20	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
30	400 KV	CHANDRAPUR-PARLI CKT-3	09-Jun-20	10:00	09-Jun-20	17:00	Daily	Line maintenance work	MSETCL	MSETCL	-
31	400 KV	PADGHE - NAGOTHANE 2	09-Jun-20	08:00	09-Jun-20	17:00	Daily	Jumper tighting and cold wasing work	MSETCL	MSETCL	nil
32	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	10-Jun-20	08:30	10-Jun-20	17:30	Daily	HV LV Tertiary Bushing & winding Tan delta testing work pre monsoon maint activity & LV Bay Maint	MSETCL	MSETCL	during outage load will be managed on ICT-I unit
33	400 KV	400/220/33KV 500 MVA ICT - 1 @ KUDUS	10-Jun-20	10:00	10-Jun-20	17:00	Daily	Diagnostic testing and pre monsoon maintenace work	MSETCL	MSETCL	1. Simultaneously outage is required on corresponding Tie Bay no. 408 which is not mentioned in list above.
34	400 KV	FUTURE CKT - 1 @ WARORA	10-Jun-20	09:00	10-Jun-20	17:00	Daily	Routine bay maintenance	MSETCL	MSETCL	400KV Bay No 419 charged on No Load
35	400 KV	NEW KOYNA - STAGE IV CKT 2	10-Jun-20	09:00	10-Jun-20	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned Outage
36	400 KV	KORADI-KHAPERKHEDA II	10-Jun-20	09:00	10-Jun-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	..
37	400 KV	PADGHE - NAGOTHANE 1	10-Jun-20	08:00	10-Jun-20	17:00	Daily	Jumper tighting and cold wasing work	MSETCL	MSETCL	nil
38	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	11-Jun-20	10:00	11-Jun-20	14:00	Daily	Pemonsoon maintenance work, Relay testing work	MSETCL	MSETCL	-
39	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	11-Jun-20	06:00	11-Jun-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.
40	400 KV	MAIN Bay - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	11-Jun-20	06:00	11-Jun-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.
41	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	11-Jun-20	09:30	11-Jun-20	17:30	Daily	DT work and Half yearly maintenance work.	MSETCL	MSETCL	Load will be managed by other 2 no. of ICTs and 220kV Interconnector.
42	400 KV	MAIN BAY (408) OF ICT - 3 @ JEJURI	11-Jun-20	09:00	11-Jun-20	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	ICT-III will be in service through 409 Tie bay.
43	400 KV	PADGHE - NAGOTHANE 2	11-Jun-20	08:00	11-Jun-20	17:00	Daily	Jumper tighting and cold wasing work	MSETCL	MSETCL	nil
44	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	11-Jun-20	08:00	20-Jun-20	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	-
45	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	12-Jun-20	09:00	12-Jun-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	..
46	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	12-Jun-20	09:00	12-Jun-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
47	400 KV	WARORA - IEPL	12-Jun-20	09:00	12-Jun-20	17:00	Daily	Routine Maintenance & Diagnostic testing work , Nut Bolt of jumper Tightening work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
48	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	12-Jun-20	10:00	12-Jun-20	13:00	Daily	Tan delta measurement of Bus CT at Bay 429	MSETCL	MSETCL	ICT 1 will remain in service through main bay 430
49	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	12-Jun-20	09:00	12-Jun-20	17:00	Daily	Quarterly maintenance of ICT 2 Bay	MSETCL	MSETCL	Quarterly maintenance of ICT 2 bay
50	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	13-Jun-20	09:00	13-Jun-20	18:00	Daily	quarterly maintenance work	MSETCL	MSETCL	-
51	400 KV	400/220/33KV 500 MVA ICT - 2 @ KUDUS	15-Jun-20	10:00	15-Jun-20	17:00	Daily	Diagnostic testing and pre monsoon maintenace work	MSETCL	MSETCL	1. Outage also required on Tie Bay 411 corresponding to ICT-II.
52	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	15-Jun-20	09:00	15-Jun-20	18:00	Daily	For line signature analysis at Parli end	MSETCL	MSETCL	-
53	400 KV	KHADKA- DEEPNAGAR CKT 1	15-Jun-20	08:30	15-Jun-20	14:00	Daily	Line CT tan delta testing also CVT tan delta testing work	MSETCL	MSETCL	nil
54	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	16-Jun-20	08:00	16-Jun-20	18:00	Daily	For routine maintenance work.	MSETCL	MSETCL	nil
55	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	17-Jun-20	09:00	17-Jun-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	..
56	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	17-Jun-20	08:00	17-Jun-20	17:00	Daily	For routine maintenance work.	MSETCL	MSETCL	nL
57	400 KV	DEEPNAGAR - THAPTI TANDA	17-Jun-20	11:00	17-Jun-20	17:00	Daily	Quarterly maintenance , CT Tan d measurement	MSETCL	MSETCL	Nil
58	400 KV	TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI	18-Jun-20	09:00	18-Jun-20	18:00	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	ICT-III will be in service through 408 Main bay.
59	400 KV	LONIKAND 1 - KOYNA STAGE-IV	18-Jun-20	09:30	18-Jun-20	17:30	Daily	DT & Line maintenance work.	MSETCL	MSETCL	---
60	400 KV	CHANDRAPUR-PARLI CKT-3	18-Jun-20	08:00	18-Jun-20	17:00	Daily	For routine maintenance work.	MSETCL	MSETCL	NA
61	400 KV	KHADKA- DEEPNAGAR CKT 2	18-Jun-20	08:30	18-Jun-20	14:00	Daily	Line CT & CVT tan delta testing work	MSETCL	MSETCL	nil
62	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	18-Jun-20	10:00	18-Jun-20	14:00	Daily	Premonsoon maintenance work,Relay testing work	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
63	400 KV	KORADI-NANDGAONPETH (RPL)	19-Jun-20	09:00	19-Jun-20	18:00	Daily	Distance relay testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
64	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	20-Jun-20	09:00	20-Jun-20	17:00	Daily	quarterly maintenance work	MSETCL	MSETCL	400/220KV 315MVA ICT-1 & 300 MVA ICT-1V & 301 MVA ICT-III will be in service
65	400 KV	LONIKAND 1 - KOYNA STAGE-IV	20-Jun-20	08:00	20-Jun-20	17:00	Daily	[PID TESTING WORK	MSETCL	MSETCL	[PID TESTING WORK
66	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	22-Jun-20	08:00	22-Jun-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	NIL
67	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	22-Jun-20	09:00	22-Jun-20	18:00	Daily	Line conductor and Earthwire hardware tightening work	MSETCL	MSETCL	-
68	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	23-Jun-20	08:00	23-Jun-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	NIL
69	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	23-Jun-20	09:00	23-Jun-20	18:00	Daily	CT testing work and bay maint work.	MSETCL	MSETCL	-
70	400 KV	CHANDRAPUR - KHAPERKHEDA	24-Jun-20	09:00	24-Jun-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	-
71	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	24-Jun-20	08:00	24-Jun-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	NIL
72	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	24-Jun-20	10:00	24-Jun-20	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Without Interruption of load, as it is a Spare Unit
73	400 KV	MAIN BAY (410) OF FUTURE BAY @ JEJURI	25-Jun-20	09:00	25-Jun-20	18:00	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
74	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	25-Jun-20	09:00	25-Jun-20	18:00	Daily	(1) HV CT C & Tan delta measurement work. (2) Bay Maint. Work.	MSETCL	MSETCL	-
75	400 KV	CHANDRAPUR-PARLI CKT-3	29-Jun-20	09:00	29-Jun-20	18:00	Daily	Line signature analysis at Parli end	MSETCL	MSETCL	-
76	400 KV	400/220 KV 167 MVA ICT @ PARLI	29-Jun-20	09:00	29-Jun-20	18:00	Daily	(1) Backup relay testing work. (2) Bay Maint. Work.	MSETCL	MSETCL	-