

Maharashtra State Load Despatch Centre										
Monthly Outage list approved in WRLDC OCCM for the Month of June' 2021										
Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
1	6	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-1	C	Diversion of towers for Nagpur-Mumbai Samrudhi Express Highway crossing. Total 3 no of towers to be shifted & erection and stringng works. (New Construction works)	1-Jun-21	7:00	20-Jun-21	18:00	
2	7	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-2	C	Diversion of towers for Nagpur-Mumbai Samrudhi Express Highway crossing. Total 3 no of towers to be shifted & erection and stringng works. (New Construction works)	1-Jun-21	7:00	20-Jun-21	18:00	
3	12	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND 400KV-WARDHA-AURANGABAD-2 at AURANGABAD - 400KV	D	FOR AMP WORKS	1-Jun-21	7:00	1-Jun-21	18:00	
4	13	POWERGRID_WR1	400KV-PARLI-SOLAPUR-2	Daily	Line side equipments AMP, Relay testing & CVT checking	1-Jun-21	7:00	1-Jun-21	18:00	
5	24	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2	D	Rectification of condcutor unwind problem and Relay testing works	1-Jun-21	8:30	1-Jun-21	18:00	
6	26	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP	1-Jun-21	9:00	1-Jun-21	17:30	Bay AMP
7	42	JPTL	400KV-KARAD-JAIGAD-1	Daily	Hotline insulator washing	1-Jun-21	09:00	2-Jun-21	18:00	Both AR to be kept off
8	43	JPTL	400KV-KARAD-JAIGAD-2	Daily	Hotline insulator washing	1-Jun-21	09:00	2-Jun-21	18:00	Both AR to be kept disable
9	47	MSETCL	400KV/220KV CHANDRAPUR-ICT-2	Continu ous	1) Overhauling & Servicing of OLTC of R & B-ph Unit of ICT-2. 2) Pre monsoon maintenance work of R, Y & B-ph Unit of Ict-2. 3) Measurement of Tan delta & capacitance of HV, IV & LV1, LV2 bushings of R, Y & B-ph units of ICT-2.	1-Jun-21	09:00	4-Jun-21	17:00	During outage, ICT-1 & 220KV CHD-2 ckt. Will be in service.
10	48	POWERGRID_WR1	400kv Chandrapur- Bhadrawati Ckt#2	c	03 NOS. OF ISOLATOR REPLACEMENT. Ar TO BE KEPT OPEN IN NON AUTO MODE FOR CHANDRAPUR-BVT-I. DIA to be kept Open	1-Jun-21	8:30	6-Jun-21	18:00	
11	49	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	1-Jun-21	08:00	7-Jun-21	19:00	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
12	50	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	Daily	PID Testing	1-Jun-21	10:00	8-Jun-21	18:00	PID Testing
13	51	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	For Carrying PID Work	1-Jun-21	08:00	10-Jun-21	18:00	-
14	52	MSETCL	BABLESHWAR - 400KV B/R 1 ON TBC @ BABHALESHWAR	Continu ous	400kv CGL make CB pole overhauling work	1-Jun-21	09:00	10-Jun-21	18:00	400kv Reactor I on TBC
15	56	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	To carrying Out PID test of insulator strings.	1-Jun-21	08:00	15-Jun-21	18:00	--
16	57	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Jun-21	08:00	19-Jun-21	18:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
17	58	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Jun-21	09:00	19-Jun-21	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
18	74	POWERGRID_WR2	Tarapur-Padghe Ckt-1	D	OPGW Stringing	1-Jun-21	7:00	30-Jun-21	18:00	For OPGW stringing under live line condition
19	82	MSETCL	400KV-CHANDRAPU-II-NANDED-2	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Jun-21	08:00	30-Jun-21	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III are on DC tower so both lines require on same day A/R out.
20	83	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Jun-21	08:00	30-Jun-21	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III are on DC tower so both lines require on same day A/R out.
21	105	POWERGRID_WR1	PARLI NEW - 400KV - BUS 1	D	AMP	2-Jun-21	8:30	2-Jun-21	18:00	AMP
22	107	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	CVT checking Due to Secondary Voltage Drift.	2-Jun-21	7:00	2-Jun-21	18:00	
23	108	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	Diagnostic testing and allied bay maintenance work	2-Jun-21	07:00	2-Jun-21	15:00	Diagnostic testing and allied bay maintenance work
24	132	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Quarterly maint. Of bay equipments	2-Jun-21	10:00	2-Jun-21	14:00	
25	133	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Quarterly maint. Of bay equipments	2-Jun-21	10:00	2-Jun-21	14:00	

26	135	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Replacement of faulty string	2-Jun-21	10:00	2-Jun-21	18:00	Replacement of faulty string
27	150	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	3-Jun-21	07:00	3-Jun-21	18:00	
28	163	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	Daily	Half yearly maintenance and diagnostic testing.	3-Jun-21	08:00	3-Jun-21	18:00	400kV Parali-Lonikand-II Ckt-II will be in service.
29	165	POWERGRID_WR1	PARLI NEW - 400KV - BUS 2	D	AMP	3-Jun-21	8:30	3-Jun-21	18:00	AMP
30	176	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	Daily	DT & Chemical cleaning Work.	3-Jun-21	09:30	3-Jun-21	17:30	--
31	181	MSETCL	132KV-DHARNI-NEPANAGAR-1	Daily	1)Replacement of R-ph metering PT 2) Line Signature Analysis & Other Maintenance Works of Line	3-Jun-21	11:00	3-Jun-21	16:00	..
32	186	JPTL	400KV-JAIGAD-NEW KOYNA-1	Daily	Insulator Hotline washing	3-Jun-21	09:00	4-Jun-21	18:00	Both AR to be kept disable
33	187	JPTL	400KV-JAIGAD-NEW KOYNA-2	Daily	hotline insulator washing	3-Jun-21	09:00	4-Jun-21	18:00	Both AR to be kept disable
34	233	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-1	D	Cleaning Copper Contacts	5-Jun-21	8:30	5-Jun-21	18:00	
35	235	POWERGRID_WR2	220KV-BOISAR-BORIVALI	D	AMP	5-Jun-21	9:00	5-Jun-21	17:30	Line Equip. AMP
36	237	NCA	400 kV SSP Dhule Line # 1	D	For B-phase TC-1, Faulty attending work	5-Jun-21	8:00	5-Jun-21	18:00	
37	250	WTPL	400KV-ALKUD-SOLAPUR-1	Daily	Outage required for replacement of polymer insulator at tower No: 24 & 142	5-Jun-21	9:00	5-Jun-21	17:00	Outage
38	251	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	For safety purpose AR to be disable while replacing insulators in 400 kV Alkud - Solapur -1	5-Jun-21	9:00	5-Jun-21	17:00	AR Mode OFF
39	259	MEGPTCL	AKOLA - 765KV - BUS 1	Daily	Rectification of bend tower member at Bus gantry	5-Jun-21	09:00	5-Jun-21	18:00	Rectification of bend tower member at Bus gantry
40	264	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance.	5-Jun-21	10:00	5-Jun-21	18:00	---
41	266	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	AMP	6-Jun-21	9:00	6-Jun-21	17:30	Line Equip. AMP
42	270	MSETCL	400KV-KALWA-PADGHE-2	Daily	Routine Maintanace work & chemical cleaning of insulators	6-Jun-21	08:00	6-Jun-21	18:00	Routine Maintanace work & chemical cleaning of insulators
43	282	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	Outage required for replacement of polymer insulator at tower No: 118	6-Jun-21	9:00	6-Jun-21	14:00	Outage
44	283	WTPL	400KV-ALKUD-SOLAPUR-1	Daily	For safety purpose AR to be disable while replacing insulators in 400 kV Kolhapur-MS-Solapur -2	6-Jun-21	9:00	6-Jun-21	14:00	AR Mode OFF
45	286	MSETCL	220KV-BOISAR-BOISAR-M-1	Daily	Diagnostic testing & Bay maintenance	6-Jun-21	09:00	6-Jun-21	12:00	Diagnostic testing & Bay maintenance
46	287	MSETCL	400KV-KALWA-PADGHE-2	Daily	1) Diagnostic testing work 2) Bay Maintenance work 3) PG Isolator replacement work	6-Jun-21	09:30	6-Jun-21	18:30	Weather condition should be clear
47	288	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Pre Monsoon Maintenance Work	7-Jun-21	08:00	7-Jun-21	16:00	For Pre monsoon work like PRV covering, MB covering etc.
48	293	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	C	Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam {Similar Line Outages proposed/approved for work to be done in May/21 can not be taken up due to Covid19 and delay in supply of towers}	7-Jun-21	8:00	10-Jun-21	18:00	Line Outage
49	294	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	C	Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam {Similar Line Outages proposed/approved for work to be done in May/21 can not be taken up due to Covid19 and delay in supply of towers}	7-Jun-21	8:00	10-Jun-21	18:00	Line Outage
50	295	POWERGRID_WR1	400 KV BUS-1 at GCR MSETCL CHANDRAPUR	c	REPLACEMENT OF PG-1 ISOLATORS OF BHADRAWATI-MSEB CKT 01 AND BHADRAWATI-MSEB CKT 02	7-Jun-21	8:30	10-Jun-21	18:00	
51	296	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continu ous	Annual Maintenance & Testing Work	7-Jun-21	08:00	12-Jun-21	17:00	From 07.06.2021 to 09.06.2021, outage is required by HVDC TL O&M Lines Division Chandrapur, Hence Line can't be taken into Metallic Return Mode from 07.06.2021 to 09.06.2021
52	298	MSETCL	KOLHAPUR-MS - 400KV - BUS 2	Continu ous	Replacement of B Bus isolators of 400kV TBC, 400kV Solapur & 400kV Alkud Bays	7-Jun-21	09:00	13-Jun-21	22:00	one by one TBC shifting of 400kV Solapur & 400kV Alkud required for replacement of B bus PG isolators.
53	301	POWERGRID_WR2	BUS COUPLER BAY - BOISAR - 220KV - BUS 1 AND BOISAR - 220KV - BUS 2 at BOISAR - 220KV	D	AMP	7-Jun-21	9:00	7-Jun-21	17:30	Bay AMP
54	320	POWERGRID_WR1	PARLI - 400KV - BUS 1	D	For Bus AMP works	7-Jun-21	8:30	7-Jun-21	17:30	

55	333	MSETCL	TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV-BHUSAWAL-AKOLA-1 at AKOLA - 400KV	Daily	Routine maintenance & testing work	7-Jun-21	09:00	7-Jun-21	17:00	Both main bays 408 & 410 will be in service
56	343	MSETCL	400KV/220KV CHANDRAPUR-ICT-1	Continuous	1) Overhauling & Servicing of 03 nos. OLTC of ICT-1. 2) Pre monsoon maintenance work of ICT-1. 3) Measurement of Tan delta & capacitance of HV, IV & LV1, LV2 bushings of R, Y & B-ph units of ICT-1. 4) Measurement of Tan delta & capacitance of 400KV HV R, Y & B-ph CTs of ICT-1.	7-Jun-21	09:00	10-Jun-21	17:00	During outage, ICT-2 & 220KV CHD-2 ckt. Will be in service.
57	353	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	AMP	8-Jun-21	9:00	8-Jun-21	17:30	Line Equip. AMP
58	373	POWERGRID_WR1	TIE BAY - 400KV-CHAKAN-PUNE-PG-1 AND 400KV-KHARGHAR-PUNE-PG-1 at PUNE-PG - 400KV	D	For AMP Work	8-Jun-21	8:30	8-Jun-21	18:00	
59	383	MSETCL	NEW KOYNA - 400KV - BUS 1	Continuous	Project work of ICT III	8-Jun-21	08:00	9-Jun-21	18:00	Planned outage
60	388	MSETCL	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV at NEW KOYNA - 400KV	Continuous	Project work of ICT III	8-Jun-21	08:00	11-Jun-21	18:00	Planned outage
61	389	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Live line installation of OPGW by MTCIL, and PID Testing & Hot Line washing work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	8-Jun-21	08:00	15-Jun-21	19:00	nil
62	391	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	For Conductor & Earthwire H/W tightening work	9-Jun-21	08:00	9-Jun-21	17:00	For Conductor & Earthwire H/W tightening work
63	399	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	Daily	Replacement of M1 REL521 Relay of Padghe Tarapur 1 line at Padghe MSETCL SS.	9-Jun-21	8:00	9-Jun-21	17:00	400 KV Padghe Tarapur 1 Line will be out of service.
64	404	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	Daily	AMP and Relay testing works	9-Jun-21	8:00	9-Jun-21	18:00	
65	410	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance	9-Jun-21	08:00	9-Jun-21	17:00	-
66	411	MSETCL	KHAPARKHEDA - 400KV - BUS 1	Daily	Centre Break Bus Isolator Maintenance Work	9-Jun-21	08:00	9-Jun-21	18:00	
67	412	MSETCL	220KV-PANDURNA-KALMESHWAR-1	Daily	Routine Maintenance & Diagnostic testing work restringing of bottom ph conductor.	9-Jun-21	08:00	9-Jun-21	18:00	-
68	420	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BORIVALI AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP	9-Jun-21	9:00	9-Jun-21	17:30	Bay AMP
69	425	MSETCL	TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV	Daily	Routine maintenance & testing work	9-Jun-21	09:00	9-Jun-21	17:00	Both main bays 411 & 413 will be in service
70	426	MSETCL	132KV-PENCH-KANHAN-1	Daily	Routine Maintenance work.	9-Jun-21	09:00	9-Jun-21	17:00	-
71	431	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	Daily	Replacement of faulty string	9-Jun-21	10:00	9-Jun-21	18:00	Replacement of faulty string
72	432	MSETCL	TIE BAY OF 400KV-TAPTHITHANDA-EKTUNI-2 AND FUTURE @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	Daily	To carry out CB diagnostic testing	9-Jun-21	11:00	9-Jun-21	17:00	Nil
73	445	POWERGRID_WR1	400KV WARDHA-AURANGABAD-1	C	For line diversion work due to samrudhi express way near Aurangabad.(New Construction)	10-Jun-21	7:00	20-Jul-21	18:00	
74	466	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV B/R 1 at Wardha - 400KV	Daily	For AMP of Bay	10-Jun-21	8:00	10-Jun-21	18:00	
75	470	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	For Conductor & Earthwire H/W tightening work	10-Jun-21	08:00	10-Jun-21	17:00	For Conductor & Earthwire H/W tightening work
76	483	MSETCL	400KV-PARLI-M-PARLI-2	Daily	1. C & Tan delta measurement of CVTs. 2.Bay maintenance work.	10-Jun-21	09:00	10-Jun-21	18:00	-
77	487	MSETCL	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-2 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	Daily	To carry out CB diagnostic testing	10-Jun-21	11:00	10-Jun-21	17:00	Nil
78	491	MSETCL	NEW KOYNA - 400KV - BUS 2	Continuous	Project work of ICT III	10-Jun-21	08:00	11-Jun-21	18:00	Planned outage
79	496	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	PID Testing	10-Jun-21	10:00	19-Jun-21	18:00	PID Testing
80	498	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	D	AMP	11-Jun-21	9:00	11-Jun-21	17:30	Line Equip. AMP
81	500	MEGPTCL	KORADI-III - 400KV - BUS 1	Daily	Annual Maintenance of Bus Equipment's	11-Jun-21	08:00	11-Jun-21	18:00	Annual Maintenance of Bus Equipment's
82	503	MSETCL	400KV-WARDHA-WARORA-1	Daily	Volatage ratio test and Routine maintainance and diagonastic testing such as CVT/ CT tandelta,and ,isolater maintainance work	11-Jun-21	09:00	11-Jun-21	18:00	Load will be managed on 400KV IEPL Ckt

83	504	MSETCL	PADGHE - PADGHE HVDC CKT- 1 ON TBC @ PADGHE END	Continuous	400kV HVDC 1 on TBC 1.CB overhauling work 2.PG isolator replacement work	11-Jun-21	09:30	22-Jun-21	18:30	400kV HVDC 1 on TBC Agency will present on site for the work subject to weather condition should be clear
84	505	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	D	AMP Works	11-Jun-21	8:30	11-Jun-21	18:00	
85	513	POWERGRID_WR1	MAIN BAY - 400KV-KHANDWA-DHULE-MS-2 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	FOR AMP WORKS	11-Jun-21	7:00	11-Jun-21	18:00	
86	521	POWERGRID_WR1	PARLI - 220KV - BUS 1	D	For Bus AMP works	11-Jun-21	8:30	11-Jun-21	17:30	
87	534	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	For Routine Maintenance Work & Diagnostic testing	11-Jun-21	09:00	11-Jun-21	18:00	400kV Kharghar-Kalwa line will be in service
88	544	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	For Carrying PID Work	11-Jun-21	08:00	20-Jun-21	18:00	-
89	545	NPCIL, TAPS 1&2	220kV Tarapur 1&2- Boisar-M1	continuous	Maintenance of line equipments	12-Jun-21	8:00	14-Jun-21	20:00	Feeder outage is required
90	546	MEGPTCL	KORADI-III - 765KV - BUS 1	Daily	Annual Maintenance of Bus Equipment's	12-Jun-21	08:00	12-Jun-21	18:00	Annual Maintenance of Bus Equipment's
91	547	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	Cleaning Copper Contacts	12-Jun-21	8:30	12-Jun-21	18:00	
92	553	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	Daily	Replacement of M1 REL521 Relay of Padghe Tarapur 2 line at Padghe MSETCL SS.	12-Jun-21	8:00	12-Jun-21	17:00	400 KV Padghe Tarapur 2 Line will be out of service.
93	561	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	Daily	For AMP of Line Bay and Relay testing works. AR to be kept in non Auto mode for 400kV Wardha-Warora-II	12-Jun-21	8:00	12-Jun-21	18:00	
94	563	MSETCL	BABLESHWAR - 400KV - BUS 2	Daily	Bus CVT testing work	12-Jun-21	08:00	12-Jun-21	18:00	400KV Bus 1 will be in service
95	574	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance.	12-Jun-21	10:00	12-Jun-21	18:00	-
96	575	MSETCL	BOISAR-M - 220KV - BUS 2	Continuous	Annual Bus isolator maintenance work	12-Jun-21	07:00	13-Jun-21	18:00	1) During the outage on 220kV B-Bus, all lines/Bays will shifted from B Bus to A-Bus through TBC. 2) Load affected NIL.
97	576	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Cold washing , E/W replacement Work & Faulty string replacement Work	12-Jun-21	08:00	13-Jun-21	18:00	Planned outage
98	579	MEGPTCL	KORADI-III - 765KV - BUS 2	Daily	Annual Maintenance of Bus Equipment's	13-Jun-21	08:00	13-Jun-21	18:00	Annual Maintenance of Bus Equipment's
99	582	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Continuous	Outage required on 400kV BBLR-Dhule (D/C) Simultaneously for Samruddhi expressway crossing 400kV line Diversion work	13-Jun-21	09:00	22-Jun-21	17:00	400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Aurangabad lines will be in in service
100	583	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Continuous	Outage required on 400kV BBLR-Dhule (D/C) Simultaneously for Samruddhi expressway crossing 400kV line Diversion work	13-Jun-21	09:00	22-Jun-21	17:00	400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Aurangabad lines will be in in service
101	588	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Earthwire stringing B/w Loc. no. 13-14, routine maintenance & Insulator cleaning work	13-Jun-21	08:00	13-Jun-21	18:00	Earthwire stringing B/w Loc. no. 13-14, routine maintenance & Insulator cleaning work .
102	589	MSETCL	BABLESHWAR - 400KV - BUS 1	Daily	Bus CVT testing work	13-Jun-21	08:00	13-Jun-21	18:00	400KV Bus 2 will be in service
103	592	MSETCL	400KV-WARDHA-WARORA-1	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	13-Jun-21	09:00	13-Jun-21	17:00	400KV WARORA-IEPL Line is in ckt
104	593	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	Premonsoon Maintenance work.	13-Jun-21	09:00	13-Jun-21	17:00	Premonsoon Maintenance work.
105	594	MSETCL	KALWA - 400KV - BUS 2	Daily	Bus PT maintenance	13-Jun-21	09:00	13-Jun-21	18:00	Bus PT maintenance
106	595	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Hardware Tightening and Fitting Work.	13-Jun-21	09:30	13-Jun-21	18:30	-
107	596	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Pre monsoon Work	14-Jun-21	08:00	14-Jun-21	16:00	Pre monsoon work like PRV covering, MB Covering etc.
108	597	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Hardware Tightening, and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole II.	14-Jun-21	06:00	16-Jun-21	19:00	Annual maintenance work of Hardware Tightening, and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole II.
109	619	OWERGRID_ODISH	PARLI - 220KV - BUS 2	D	For Bus AMP works	14-Jun-21	8:30	14-Jun-21	17:30	
110	622	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1	D	For checking of CVT and relay testing works	14-Jun-21	8:30	14-Jun-21	18:00	
111	637	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing , E/W replacement Work & Faulty string replacement Work	14-Jun-21	08:00	15-Jun-21	18:00	Planned outage
112	640	POWERGRID_WR1	400 KV BUS-2 at GCR MSETCL ,CHANDRAPUR	c	REPLACEMENT OF PG-2 ISOLATORS OF BHADRAWATI-MSEB CKT 01 AND BHADRAWATI-MSEB CKT 02	14-Jun-21	8:30	17-Jun-21	18:00	
113	643	MSETCL	CHANDRAPUR - 400KV - TRANSFER BUS 2	Continuous	Replacement of problematic old ELPRO make PG-1 & PG-3 Isolators by new GR power make PG Isolators	14-Jun-21	09:00	20-Jun-21	17:00	TBC-2 bay will not be available. TBC-1 will be available.

114	646	MSETCL	400KV-IEPL-KORADI-II-1	Continu ous	For erection of Monopole Tower (02 nos)for height raising work of 400kV Koradi 2 IEPL & 400kV Koradi 2 Warora for height raising work at chainage 27+400. 400 kV IEPL - Warora line shall feed 400kV IEPL S/stn which shall be shifted on ERS during shutdown on line.	15-Jun-21	6:00	19-Jun-21	22:00	
115	653	GETCO	400KV-SSP-DHULE-MS-1	Daily	PMM work. Auto reclose of 400 KV SSP-Dhule-2 will remain out	15-Jun-21	7:00	15-Jun-21	18:00	Auto reclose of 400 KV SSP-Dhule-2 will remain out
116	668	MSETCL	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	Daily	Diagnostic Testing CT CB	15-Jun-21	08:00	15-Jun-21	18:00	400KV Buus 1 & 2 seperated
117	679	MSETCL	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	Daily	Quarterly Maint. Work & Diagnostic Testing Work	15-Jun-21	09:00	15-Jun-21	18:00	Tesday is staggering day for Sangli District
118	680	APML	400KV/11.5KV TIRODA-ST-1	Daily	Main & Tie Bay of ST - 1 required for Maintenance & Testing Activities	15-Jun-21	09:00	15-Jun-21	18:00	Station Transformer with Main & tie Bay outage Required
119	684	MSETCL	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	Daily	CB Diagnostic Testing	15-Jun-21	10:30	15-Jun-21	18:00	"1) Bus Reactor will be in service throgh its Main (711) Bay & Main Bus-I. 2) ICT-II will be in service through its Main (713) bay & Main Bus-II."
120	717	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance	16-Jun-21	08:00	16-Jun-21	17:00	-
121	718	POWERGRID_WR1	MAIN BAY -220KV-PARLI-HARANGUL-M-1 (208)	D	For bay AMP works	16-Jun-21	8:30	16-Jun-21	17:30	
122	725	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	16-Jun-21	09:00	16-Jun-21	17:00	-
123	726	APML	400KV/11.5KV TIRODA-ST-3	Daily	Main & Tie Bay of ST - 3 required for Maintenance & Testing Activities	16-Jun-21	09:00	16-Jun-21	18:00	Station transformer with Main & Tie Bay outage required
124	730	MSETCL	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	Daily	CB Diagnostic Testing	16-Jun-21	10:30	16-Jun-21	18:00	Bus Reactor will be in service throgh its TIE (712) Bay & Main Bus-II.
125	733	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Cold washing , E/W replacement Work & Faulty string replacement Work	16-Jun-21	08:00	17-Jun-21	18:00	Planned outage
126	738	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	Continu ous	For attending Leakage and complete overhauling of Breaker	16-Jun-21	09:00	18-Jun-21	19:00	For attending Leakage and complete overhauling of Breaker
127	739	MSETCL	400KV-KALWA-PADGHE-1	Daily	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	16-Jun-21	09:00	22-Jun-21	17:00	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
128	742	MSETCL	LONIKHAND-II - 400KV - BUS 1	Daily	Diagnostic testing. (PID).	16-Jun-21	10:00	30-Jun-21	18:00	One and half breaker system ,no line interruption .
129	748	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	FOR AMP WORKS	17-Jun-21	7:00	17-Jun-21	18:00	
130	760	MSETCL	KHAPARKHEDA - 400KV - BUS 2	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor (bay no. 408).	17-Jun-21	08:00	17-Jun-21	20:00	The above work will be carried out by M/s KEI Industries Ltd. under supervision of AdIEE, 400KV S/stn. Projects S/Dn, Nagpur
131	767	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	Daily	QM work	17-Jun-21	09:00	17-Jun-21	18:00	Load will be managed on 400kV Solapur line
132	770	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	DT & Routine Maintenance Work	17-Jun-21	09:30	17-Jun-21	17:30	
133	772	MSETCL	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	Daily	Diagnostic testing of CB 411-Q52	17-Jun-21	10:00	17-Jun-21	15:00	outage will be availed subject to weather condition
134	776	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routin line maintenance work	17-Jun-21	08:00	18-Jun-21	18:00	220 kV Purti - Bhugaon Ckt and 220 kV Bhugaon - Wardha Ckt is available for supply durin outage period.
135	788	POWERGRID_WR1	MAIN BAY - 400KV-KHANDWA-DHULE-MS-1 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	FOR AMP Works	18-Jun-21	7:00	18-Jun-21	18:00	
136	797	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2	Daily	For AMP works , relay testing works & attending hotspot	18-Jun-21	8:00	18-Jun-21	18:00	
137	798	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	Daily	For AMP of Line Bay	18-Jun-21	8:00	18-Jun-21	18:00	

138	804	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPUR-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	18-Jun-21	08:00	18-Jun-21	17:00	only Tie CB 412 is in OFF condition ,respective ckt charged through its own main CB.
139	805	POWERGRID_WR1	MAIN BAY -220KV-PARLI-PARLI-M-1 (206)	D	For bay AMP works	18-Jun-21	8:30	18-Jun-21	17:30	
140	811	MSETCL	CHANDRAPUR-GCR - 400KV - BUS 1	Daily	To remove hanger rod assembly of PG-1 Isolators (R, Y & B-ph Poles) of TBC-2 bay by Hot line Technique require for replacement of Isolators.	18-Jun-21	09:00	18-Jun-21	17:00	During this, the work will be executed by hot line technique, hence no need to shift the bays/feeders connected to 400KV Main Bus-1.
141	812	MSETCL	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	QM work	18-Jun-21	09:00	18-Jun-21	18:00	Load will be managed on 400kV Alkud Line
142	815	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Cold washing , E/W replacement Work & Faulty string replacement Work	18-Jun-21	08:00	19-Jun-21	18:00	Planned Outage
143	822	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	19-Jun-21	07:00	19-Jun-21	18:00	...
144	826	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-2	Daily	For AMP of Line Bay and Relay testing works. AR to be kept in non Auto mode for 400kV Wardha-Warora-1	19-Jun-21	8:00	19-Jun-21	18:00	
145	840	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 -Borivali	Daily	Maintenance of line equipments	20-Jun-21	8:00	20-Jun-21	20:00	Simultaneous outage of 220kV Tarapur 1&2- Boisar and 220kV Tarapur 1&2Borivali Line is required for debris removal under the D/C 220KV MSETCL lines at INRP PROJECT, BARC, Tarapur before the onset of monsoon
146	841	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	(1) Bushing & winding C & Tan delta & IR measurement of reactor. (2)Bay maintenance work. Line maint work.	20-Jun-21	09:00	20-Jun-21	18:00	-
147	842	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	DT & Chemical cleaning Work.	20-Jun-21	09:30	20-Jun-21	17:30	--
148	843	POWERGRID_WR1	400KV-WARORA-PG-PARLI-1	C	For new construction works due to upcoming railway diversion work.	20-Jun-21	8:00	30-Jun-21	18:00	
149	844	POWERGRID_WR1	400KV-WARORA-PG-PARLI-2	C	For new construction works due to upcoming railway diversion work.	20-Jun-21	8:00	30-Jun-21	18:00	
150	847	MSETCL	400KV-IEPL-WARORA-1	Daily	For shifting of line from ERS to Monopole tower for height raising work at chainage 27+400 for Samrudhhi Mahamarg	20-Jun-21	6:00	20-Jun-21	22:00	
151	849	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Routine Maintanace work & chemical cleaning of insulators	20-Jun-21	08:00	20-Jun-21	18:00	Routine Maintanace work & chemical cleaning of insulators
152	850	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	Safety Purpose	20-Jun-21	09:00	20-Jun-21	17:00	Safety Purpose
153	851	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	Spacer Fixing	20-Jun-21	09:00	20-Jun-21	17:00	Spacer Fixing
154	852	MSETCL	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	Continu ous	Samrudhhi expressway crossing 400kV line Diversion work	21-Jun-21	09:00	30-Jun-21	17:00	400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Dhule I&II lines will be in in service
155	853	MSETCL	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	Continu ous	Routine Maintenance Relay retrofitting work	21-Jun-21	10:00	24-Jun-21	18:00	Routine Maintenance Relay retrofitting work
156	854	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	Daily	Updating Siemens Distance Relay M1 7SA522(EN100 Module) to comply for IEC61850 and resolving front port communication issue of M1 Relay.	21-Jun-21	8:00	21-Jun-21	16:00	400 KV Padghe Boisar will be out of service.
157	855	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	Daily	1) Measurement of Tan delta & capacitance of 400KV R, Y & B-ph CTs which are due since 02 years. 2) Testing of LBB relay. 3) Maintenance and alignments of PG Isolators and CB Isolators.	21-Jun-21	09:00	21-Jun-21	17:00	During outage, HVDC Ckt. No.- 2 Will be in service in power restriction.

158	858	MSETCL	400KV/220KV AKOLA-ICT-2	Continu ous	1. Draining, filtration & refilling of oil for internal inspection of 3 Phase, ICT-02 due to the higher values of DGA. 2. Internal inspection work& repairing work if any abnormality observed during inspection. 3. All testing activities required before charging & maintenance work.	21-Jun-21	09:00	10-Jul-21	18:00	1.Work will be carried out by IMP powers limited. 2.Load will be shifted on ICT-01 during outage period 3.Previous outages were proposed from 23.11.2020 to 12.12.2020, 26.02.2021 to 17.03.2021 and 08.04.2021 to 27.04.2021 but all previous outages were not approved due to system constraint & GT-2 is in breakdown at Paras TPS on date 26.02.2021 4.NOC for the 150MW load relief will required from MSEDCL. 5.Necessary changes in the LTS will required. 6.The outage is uploaded in the system.
159	864	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-1	Daily	For Line AMP works Simultaneous ouatge of 400kV Pune-Parli#1 & 400kV Pune-Aurangabad -2 is required, due to multi circuit towers. 400kV Pune-Parli-2 & 400kV Pune-Aurangabad -1 A/R to be keep in non auto mode for safety measures.	21-Jun-21	7:00	21-Jun-21	18:00	Simultaneous outage of Parli#1 & Aurangabad#2
160	865	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	Daily	For Line AMP works Simultaneous ouatge of 400kV Pune-Parli#1 & 400kV Pune-Aurangabad -2 is required, due to multi circuit towers. 400kV Pune-Parli-2 & 400kV Pune-Aurangabad -1 A/R to be keep in non auto mode for safety measures.	21-Jun-21	7:00	21-Jun-21	18:00	Simultaneous outage of Parli#1 & Aurangabad#2
161	875	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Earthwire replacement work	21-Jun-21	08:00	21-Jun-21	17:00	Earthwire replacement work
162	877	POWERGRID_WR1	Main Bay - 400KV/220KV SOLAPUR-ICT-1 AND SOLAPUR - 400KV - BUS 1	Daily	Bay AMP Works.	21-Jun-21	8:30	21-Jun-21	18:00	
163	891	MSETCL	400KV-PARLI-M-NANDED-2 ON TBC @ PARLI	Continu ous	Overhauling of Circuit breaker	21-Jun-21	09:00	26-Jun-21	18:00	Line will be remain charged through TBC
164	892	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	For Carrying PID Work	21-Jun-21	08:00	30-Jun-21	18:00	-
165	893	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	For Carrying PID Work	21-Jun-21	08:00	30-Jun-21	18:00	-
166	894	MSETCL	CHANDRAPUR - 400KV - TRANSFER BUS 1	Continu ous	Overhauling & Servicing of Poles & Interrupter of all three phases.	21-Jun-21	09:00	30-Jun-21	17:00	TBC-2 bay will be available.
167	896	MSETCL	400KV-WARDHA-KORADI-II-1	Continu ous	For erection of Monopole between loc no 191& 192 & shifting of Koradi 2 - Wardha PG on ERS for height raising work at Chainage 23+650 km of Samruddhi Mahamarg.	22-Jun-21	6:00	23-Jun-21	22:00	
168	902	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1	D	FOR LINE CT AMP WORKS at Waluj end	22-Jun-21	7:00	22-Jun-21	18:00	
169	906	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Earthwire replacement work	22-Jun-21	08:00	22-Jun-21	17:00	NIL
170	911	MP_SLDC	220KV-PANDHURNA-MP-KALMESHVAR-MH	D	FOR LINE MAINTENANCE WORK	22-Jun-21	9:00	22-Jun-21	18:00	
171	917	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	22-Jun-21	09:00	22-Jun-21	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
172	918	MSETCL	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	Daily	Quarterly Maint. Work & Diagnostic Testing Work	22-Jun-21	09:00	22-Jun-21	18:00	Tesday is staggering day for Sangli Distriict
173	925	MSETCL	400KV-IEPL-KORADI-II-1	Continu ous	For erection of inline Monopole between loc no 191 & 193 & stringing between newly erected Monopoles for height raising work at chainage 23+650km of Samruddhi Mahamarg	22-Jun-21	6:00	27-Jun-21	22:00	
174	926	MSETCL	400KV-BHUSAWAL-AURANGABAD-M (WALUJ)-1	Continu ous	Routine Maintenance Relay retrofitting work	23-Jun-21	10:00	26-Jun-21	18:00	Routine Maintenance Relay retrofitting work
175	931	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	Daily	For Line AMP works Simultaneous ouatge of 400kV Pune-Parli#2 & 400kV Pune-Aurangabad -1 is required, due to multi circuit towers. 400kV Pune-Parli-1 & 400kV Pune-Aurangabad -2 A/R to be keep in non auto mode for safety measures.	23-Jun-21	7:00	23-Jun-21	18:00	Simultaneous outage of Parli#2 & Aurangabad#1
176	932	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-2	Daily	For Line AMP works Simultaneous ouatge of 400kV Pune-Parli#2 & 400kV Pune-Aurangabad -1 is required, due to multi circuit towers. 400kV Pune-Parli-1 & 400kV Pune-Aurangabad -2 A/R to be keep in non auto mode for safety measures.	23-Jun-21	7:00	23-Jun-21	18:00	Simultaneous outage of Parli#2 & Aurangabad#1
177	937	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	For AMP of Bay	23-Jun-21	8:00	23-Jun-21	18:00	
178	941	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance	23-Jun-21	08:00	23-Jun-21	17:00	-

179	949	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	23-Jun-21	09:00	23-Jun-21	17:00	
180	954	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Faulty string replacement	23-Jun-21	10:00	23-Jun-21	18:00	Faulty string replacement
181	959	MSETCL	400KV-KALWA-PADGHE-2	Daily	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.	23-Jun-21	09:00	30-Jun-21	17:00	PID Testing & Hot Line Washing Work of line Insulator strings at various locations. Auto-Reclose function to be out of service.
182	972	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routin line maintenance work	24-Jun-21	08:00	24-Jun-21	18:00	220 kV Pusad - Yewatmal Ckt is available during the outage.
183	981	MSETCL	400KV-EKTUNI-BABLESHWAR-1 ON TBC @ BABLESHWAR	Continu ous	Isolator repairing and servicing work & quartetly maintenance work	24-Jun-21	09:00	25-Jun-21	18:00	400kV Ektuni ckt I on TBC
184	991	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	Daily	For AMP and relay testing.	25-Jun-21	7:00	25-Jun-21	18:00	
185	999	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AND KOLHAPUR GIS - 400KV - BUS 1 at Kolhapur GIS - 400KV	D	Bay AMP	25-Jun-21	8:00	25-Jun-21	18:00	407 Bay
186	1003	MSETCL	WARORA - 400KV - BUS 1	Daily	Routine maintainance and diagonastic testing such as CVT tandelta & maintainance work	25-Jun-21	08:00	25-Jun-21	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV,125MVAR reactor kept off position during outage.
187	1010	MSETCL	AURANGABAD-M (WALUJ) - 400KV - BUS 1	Daily	Routine Maintenance	25-Jun-21	09:00	25-Jun-21	18:00	Routine Maintenance
188	1011	MSETCL	PADGHE - HVDC CKT- 1	Daily	1. Diagnostic Testing Work 2.Bay maintenance Work	25-Jun-21	09:00	25-Jun-21	19:00	Weather condition should be clear
189	1014	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	Diagnostic Testing	25-Jun-21	09:30	25-Jun-21	18:00	1500MVA ICT-II Will be in service
190	1020	POWERGRID_WR1	400KV-KALWA-PUNE-PG-1	D	AMP and Relay testing works	26-Jun-21	8:30	26-Jun-21	18:00	
191	1021	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Routine Line Maintenance work & Chemical Cleaning.	26-Jun-21	08:00	26-Jun-21	18:00	---
192	1025	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	For Khandwa-2 LR & Line CT AMP at Dhule end & 400KV-KHANDWA-DHULE-MS-1 A/R to be keep in non auto mode for line AMP works for safety precautions.	26-Jun-21	7:00	26-Jun-21	18:00	
193	1031	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	Premonsoon Maintenance	26-Jun-21	09:00	26-Jun-21	17:00	Premonsoon Maintenance
194	1032	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	29D & 29C Isolator repairing work.	26-Jun-21	09:00	26-Jun-21	17:00	400kV Ektuni ckt II,400kV Bhusawal, Dhule I&II and 400kV Aurangabad will be in in service
195	1033	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	Nut Bolt tightening, Corona ring replacement & fixing.	26-Jun-21	09:00	26-Jun-21	18:00	400kV Bhablesahwar ckt-II will be in service
196	1037	MSETCL	KORADI-II - 400KV - BUS 2	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor (bay no. 415).	27-Jun-21	08:00	27-Jun-21	20:00	The above work will be carried out by M/s KEI Industries Ltd. under supervision of AdIEE, 400KV S/stn. Projects S/Dn, Nagpur
197	1041	MSETCL	400KV-KALWA-PADGHE-1	Daily	1) Rutine Maintenance work, Faulty Insulator Replacement & chemical cleaning of insulators 2) Bay Maitenance & Testing work RTV coating work on open delta at 400KV RS Kalwa.	27-Jun-21	08:00	27-Jun-21	18:00	1) Rutine Maintenance work, Faulty Insulator Replacement & chemical cleaning of insulators 2) Bay Maintenance & Testing work RTV coating work on open delta at 400KV RS Kalwa.
198	1044	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Hardware Tightening and Fitting Work.	27-Jun-21	09:30	27-Jun-21	18:30	-
199	1045	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintainance work	27-Jun-21	10:00	27-Jun-21	18:00	NA
200	1047	MSETCL	400KV-EKTUNI-BABLESHWAR-2 ON TBC @ BABLESHWAR END	Continu ous	Isolator repairing and servicing work & quartetly maintenance work	27-Jun-21	09:00	28-Jun-21	17:00	400kV Ektuni ckt II on TBC
201	1049	POWERGRID_WR1	400KV-KOLHAPUR-SOLAPUR-1	Daily	Line Terminal Equipment AMP Works	28-Jun-21	7:00	28-Jun-21	18:00	Note-This line is having Nonswitchable Line reactor. Upon shutdown of the line, line reactor will also be under shutdown. Further, next day the maintenance work is planned on the line reactor. Therfore, the line needs to be charged on 28th June 2021 without LR.
202	1050	MSETCL	400KV-WARDHA-KORADI-II-1	Continu ous	For erection of Monopole between loc no 191& 192 & shifting of Koradi 2 - Wardha PG on ERS for height raising work at Chainage 23+650 km of Samruddhi Mahamarg.	28-Jun-21	6:00	29-Jun-21	18:00	

203	1067	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	28-Jun-21	09:00	28-Jun-21	17:00	Line will be charged through Tie CB 428.
204	1069	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Diagnostic Testing	28-Jun-21	09:30	28-Jun-21	18:00	1500MVA ICT-I Will be in service
205	1071	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine line maintainace	28-Jun-21	10:00	28-Jun-21	18:00	NA
206	1075	POWERGRID_WR1	400kv-SOLAPUR-KOLHAPUR LR@ SOLAPUR-400KV	Daily	Line Reactor AMP Works & Aircell Replacement in line Reactor	28-Jun-21	7:00	29-Jun-21	18:00	Note-This reactor is nonswitchable. For isolation of the reactor, 400kV kolhapur-Solapur line needs to isolated first.
207	1094	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	29-Jun-21	09:00	29-Jun-21	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
208	1095	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	29D & 29C Isolator repairing work.	29-Jun-21	09:00	29-Jun-21	17:00	-
209	1096	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	Nut Bolt tightening, Corona ring replacement & fixing,	29-Jun-21	09:00	29-Jun-21	18:00	400kV Bhabaleshwar ckt-I will be in service
210	1111	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance	30-Jun-21	08:00	30-Jun-21	17:00	-
211	1113	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	30-Jun-21	09:00	30-Jun-21	17:00	Line will be charged through mainCB 429.

Outages not considered in WRLDC OCCM for the Month of June' 2021

Sr.No.	OCCM Sr. No	Name of Requesting	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
1	367	MSETCL	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	Continu ous	Routine Maintenance	21-Jun-21	10:00	24-Jun-21	18:00	Routine Maintenance
2	548	MSETCL	400 KV RADSS Busbar@BBLR	Daily	Busbar Relay testing	11-Jun-21	08:00	11-Jun-21	21:00	Bus outage not required. Work is on 400 KV RADSS Busbar@BBLR

State Element List for the month of June'2021												
Sr.No.	Category	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	1	400 KV	125MVAR BUS REACTOR @ WARORA	01-Jun-21	09:00	01-Jun-21	18:00	Daily	Premonsoon activity , Routine maintainance of 400KV, 125MVAR Bus Reactor.	MSETCL	MSETCL	During outage reactor is in off condition
2	1	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	01-Jun-21	07:00	01-Jun-21	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
3	1	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	01-Jun-21	08:00	01-Jun-21	18:00	Daily	Premansoon Maint. Work	MSETCL	MSETCL	Planned outage
4	1	400 KV	NEW KOYNA - STAGE IV CKT 2	02-Jun-21	08:00	02-Jun-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
5	1	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	02-Jun-21	09:00	02-Jun-21	18:00	Daily	Replacement of isolator MOM box	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
6	1	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	02-Jun-21	08:00	02-Jun-21	15:00	Daily	Premonsoon Maintenance Work & DCRM of CB	MSETCL	MSETCL	_
7	1	400 KV	KHADKA-AURANGABAD	02-Jun-21	06:00	05-Jun-21	18:00	Daily	For replacement of physically damaged insulator strings	MSETCL	MSETCL	NIL
8	1	400 KV	KORADI-NANDGAONPETH (RPL)	02-Jun-21	09:00	04-Jun-21	18:00	Daily	PG & CB isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
9	1	400 KV	GTR - 9 @ CHANDRAPUR SWITCHING SS	03-Jun-21	08:00	03-Jun-21	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
10	1	400 KV	PADGHE - NAGOTHANE 1	03-Jun-21	08:00	09-Jun-21	17:00	Daily	chemical washing of insulator	MSETCL	MSETCL	nil
11	1	400 KV	NEW KOYNA-KARAD -CKT1	03-Jun-21	08:00	03-Jun-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
12	1	400 KV	JEJURI- KOYNA STAGE-IV	03-Jun-21	08:00	03-Jun-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
13	1	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	03-Jun-21	09:00	05-Jun-21	18:00	Daily	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
14	1	400 KV	KORADI-KHAPERKHEDA I	03-Jun-21	08:00	03-Jun-21	18:00	Daily	Routine Maintenance work.	MSETCL	MSETCL	_
15	1	400 KV	CHANDRAPUR-PARLU CKT-3	03-Jun-21	09:00	03-Jun-21	18:00	Daily	(1) C & Tan delta measurement of CTs. (2) Bay maintenance work. Line maint. Work	MSETCL	MSETCL	-
16	1	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	03-Jun-21	08:00	03-Jun-21	17:00	Daily	premonsoon maint & diagnostic testing work	MSETCL	MSETCL	NIL
17	1	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	03-Jun-21	09:00	03-Jun-21	17:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	--
18	1	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	04-Jun-21	10:00	04-Jun-21	19:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
19	1	400 KV	NEW KOYNA-KARAD-CKT 2	04-Jun-21	08:00	04-Jun-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
20	1	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	04-Jun-21	08:00	04-Jun-21	17:00	Daily	premonsoon maint & diagnostic testing work	MSETCL	MSETCL	NIL
21	1	400 KV	KARAD - TALANDGE CKT 1	04-Jun-21	09:00	04-Jun-21	18:00	Daily	QM work, Relay testing work	MSETCL	MSETCL	Load will be managed on 400kv karad Ckt -2
22	1	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	04-Jun-21	08:00	04-Jun-21	18:00	Daily	For Routine Maintenance Work & Diagnostic testing	MSETCL	MSETCL	400KV ICT-I, III will be in service.
23	1	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	05-Jun-21	08:00	05-Jun-21	17:00	Daily	premonsoon maint & diagnostic testing work	MSETCL	MSETCL	NIL
24	1	400 KV	JAIGAD-NEW KOYNA-I	05-Jun-21	08:00	05-Jun-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
25	1	400 KV	GT-9 @ KORADI-2	05-Jun-21	11:00	05-Jun-21	15:00	Daily	Tan delta measurement of Syn. CVT	MSETCL	MSETCL	outage will be availed subject to weather condition
26	1	400 KV	CHANDRAPUR-PARLU CKT-3	05-Jun-21	08:00	05-Jun-21	18:00	Daily	Pre mansoon Maintenaace	MSETCL	MSETCL	
27	1	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	05-Jun-21	08:00	05-Jun-21	18:00	Daily	CB Diagnostic testing	MSETCL	MSETCL	ICT 2, 3, 4 will be in service
28	1	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	06-Jun-21	09:00	06-Jun-21	18:00	Daily	Bay maintenance & testing work RTV coating work on open delta"	MSETCL	MSETCL	Bay maintenance & testing work RTV coating work on open delta"
29	1	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	07-Jun-21	07:00	07-Jun-21	17:00	Daily	HV LV Bushing winding tan delta testing work & ICT pre-monsoon Maint work	MSETCL	MSETCL	Need to be done as per yearly plan
30	1	400 KV	PARLU - KUMBHARGAON (NANDED) CKT - 1	07-Jun-21	09:00	07-Jun-21	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
31	1	400 KV	KARAD - LONIKAND 1	07-Jun-21	08:00	07-Jun-21	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work

32	1	400 KV	JAIGAD-NEW KOYNA-II	07-Jun-21	08:00	07-Jun-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
33	1	400 KV	DEEPNAGAR - THAPTI TANDA	07-Jun-21	08:00	08-Jun-21	18:00	Daily	On Line PID by PID Unit,Dhule	MSETCL	MSETCL	During Outage AR is required in Out Mode
34	1	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	07-Jun-21	08:00	12-Jun-21	18:00	Daily	Work of strings replacement detected faulty in PID testing	MSETCL	MSETCL	String replacement work will be done by agency.
35	1	400 KV	FUTURE CKT - 1 @ WARORA	07-Jun-21	09:00	07-Jun-21	17:00	Daily	Routine maintainance and Line/Bus/Tie CT TAN DELTA,IR and isolater maintainance work etc .	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 418.
36	1	400 KV	80 MVAR BUS REACTOR @ NAGOTHANE S/S	07-Jun-21	08:00	07-Jun-21	17:00	Daily	premonsoon maint & diagnostic testing work	MSETCL	MSETCL	NIL
37	1	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	07-Jun-21	09:00	07-Jun-21	17:00	Daily	CB DCRM TIMING CT RATIO change	MSETCL	MSETCL	400KV Line/Bus/Tie CT TAN DELTA,IR and isolater maintainance work etc . I&II lines will be in in service
38	1	400 KV	NEW KOYNA - STAGE IV CKT 1	08-Jun-21	08:00	08-Jun-21	18:00	Daily	Project work of ICT III	MSETCL	MSETCL	Planned outage
39	1	400 KV	Akola II (Yelwan) - Akola I CKT - 1	08-Jun-21	09:00	08-Jun-21	19:00	Daily	Annual Maintenance of Line Equipment's	MEGPTCL	MEGPTCL	Annual Maintenance of Line Equipment's
40	1	400 KV	400 KV FUTURE BAY II @ WARORA	08-Jun-21	09:00	08-Jun-21	17:00	Daily	Routine maintainance and Line/Bus/Tie CT TAN DELTA,IR and isolater maintainance work etc .	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.
41	1	400 KV	GT-8 @ KORADI-2	08-Jun-21	11:00	08-Jun-21	16:00	Daily	Tan delta meas. of Syn. CVT	MSETCL	MSETCL	outage will be availed subject to weather condition
42	1	400 KV	400/220 KV 500 MVA ICT @ ALKUD	08-Jun-21	09:00	08-Jun-21	18:00	Daily	Quarterly Maint. Work, Pre monsoon Maint. work & Diagnostic Testing Work	MSETCL	MSETCL	Tesday is staggering day for Sangli Distriict
43	1	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 1	08-Jun-21	09:00	08-Jun-21	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
44	1	400 KV	LONIKAND 1 - KOYNA STAGE-IV	08-Jun-21	08:00	08-Jun-21	17:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
45	1	400 KV	125 MVAR BUS REACTOR @ TALANDGE	09-Jun-21	09:00	09-Jun-21	18:00	Daily	QM Work, Annual diagnostic testing work. Relay testing work	MSETCL	MSETCL	80 MVAR Bus reactor is in service/available during outage
46	1	400 KV	NEW KOYNA-KARAD-CKT 2	09-Jun-21	08:00	09-Jun-21	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
47	1	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	09-Jun-21	07:00	09-Jun-21	17:00	Daily	Routine maintainance and Line/Bus/Tie CT TAN DELTA,IR and isolater maintainance work etc .	MSETCL	MSETCL	Bay No 404 charged upto line CT (400KV ICT No -1
48	1	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	09-Jun-21	08:00	09-Jun-21	18:00	Daily	Replacement of A Isolator	MSETCL	MSETCL	Planned outage
49	1	400 KV	LONIKAND 1 - KOYNA STAGE-IV	10-Jun-21	09:30	10-Jun-21	17:30	Daily	DT & Routine Maintenance Work.	MSETCL	MSETCL	--
50	1	400 KV	LONIKAND 1 -JEJURI	10-Jun-21	09:30	10-Jun-21	17:30	Daily	DT & Insulator String replacement Work.	MSETCL	MSETCL	--
51	1	400 KV	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	10-Jun-21	08:00	10-Jun-21	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
52	1	400 KV	TBC @ KORADI-1	10-Jun-21	09:00	12-Jun-21	18:00	Daily	PG & CB isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
53	1	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	10-Jun-21	08:00	10-Jun-21	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400/220kv 501 MVA ICT-II will remain in service.
54	1	400 KV	KORADI-KHAPERKHEDA II	10-Jun-21	08:00	10-Jun-21	18:00	Daily	Routine Maintenance work.	MSETCL	MSETCL	_
55	1	400 KV	PADGHE - NAGOTHANE 2	10-Jun-21	08:00	16-Jun-21	17:00	Daily	chemical washing of insulator	MSETCL	MSETCL	NIL
56	1	400 KV	JEJURI- KOYNA STAGE-IV	10-Jun-21	08:00	10-Jun-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
57	1	400 KV	KHADKA - BABLESHWAR	11-Jun-21	06:00	14-Jun-21	18:00	Daily	For replacement of Physically Damaged insulator strings	MSETCL	MSETCL	NIL
58	1	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	11-Jun-21	08:00	11-Jun-21	18:00	Daily	Pre mansoon Maintenaace	MSETCL	MSETCL	
59	1	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	11-Jun-21	09:00	11-Jun-21	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
60	1	400 KV	NEW KOYNA-KARAD -CKT1	11-Jun-21	08:00	11-Jun-21	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
61	1	400 KV	GT - 6 @ KORADI-1	14-Jun-21	09:00	16-Jun-21	18:00	Daily	PG isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
62	1	400 KV	AKOLA - KHADKA (BHUSAWAL)	14-Jun-21	08:00	19-Jun-21	18:00	Daily	Work of strings replacement detected faulty in PID testing	MSETCL	MSETCL	String replacement work will be done by agency.
63	1	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	14-Jun-21	09:00	14-Jun-21	18:00	Daily	Pre-monsoon, routine maintenance & testing work.	MSETCL	MSETCL	Load will be shifted on ICT-02
64	1	400 KV	WARORA - IEPL	14-Jun-21	09:00	14-Jun-21	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt

65	1	400 KV	400/11kV STN-4A @ DEEPNAGAR	14-Jun-21	08:00	14-Jun-21	16:00	Daily	Line & Main bus CT tan delta testing work & Quarterly Bay Maintenance work	MSETCL	MSETCL	As per diagnostic plan outage required
66	1	400 KV	DEEPNAGAR - THAPTI TANDA	14-Jun-21	08:00	15-Jun-21	18:00	Daily	On Line PID By PID Unit,Dhule	MSETCL	MSETCL	During outage AR is required in Out mode
67	1	400 KV	RPL(AMT) NANDGAON PETH - KORADI	15-Jun-21	08:00	15-Jun-21	17:00	Daily	For Insulator replacement and routine maintenance.	APTCL	APTCL	Outage require for Insulator replacement and routine maintenance.
68	1	400 KV	400/11kV STN-4B @ DEEPNAGAR	15-Jun-21	08:00	15-Jun-21	16:00	Daily	Line CT tan delta testing work & Quarterly Bay Maintenance work	MSETCL	MSETCL	bay maintenance is pending as per yearly plan
69	1	400 KV	RPL(AMT) NANDGAON PETH - AKOLA II LINE I	16-Jun-21	08:00	16-Jun-21	17:00	Daily	For Insulator replacement and routine maintenance.	APTCL	APTCL	Outage require for Insulator replacement and routine maintenance.
70	1	400 KV	CHANDRAPUR - KHAPERKHEDA	16-Jun-21	08:00	16-Jun-21	17:00	Daily	For Conductor & Earthwire H/W tightening work if found any during MP	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work if found any during MP
71	1	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	16-Jun-21	10:00	16-Jun-21	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI
72	1	400 KV	DEEPNAGAR - THAPTI TANDA	16-Jun-21	06:00	18-Jun-21	18:00	Daily	For replacement of Faulty insulator strings detected in PID	MSETCL	MSETCL	NIL
73	1	400 KV	CHANDRAPUR-PARLI CKT-3	16-Jun-21	08:00	16-Jun-21	17:00	Daily	For Conductor & Earthwire H/W tightening work if found any during MP	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work if found any during MP
74	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	17-Jun-21	09:00	17-Jun-21	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
75	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	17-Jun-21	09:00	17-Jun-21	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
76	1	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	17-Jun-21	09:30	17-Jun-21	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kv 501MVA, ICT-2 & ICT-3 will be in service.
77	1	400 KV	TIE BAY - 409 OF GT - 5 @KHAPARKHEDA S/s	17-Jun-21	08:00	17-Jun-21	20:00	Daily	T-Connection of Bus isolator of Reactor bay For 400kv, 125 MVAR Bus Shunt Reactor (bay no. 408).	MSETCL	MSETCL	The above work will be carried out by M/s KEI Industries Ltd. under supervision of AdIEE, 400KV S/stn. Projects
78	1	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	17-Jun-21	09:00	17-Jun-21	17:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	--
79	1	400 KV	GT - 7 @ KORADI-1	17-Jun-21	09:00	19-Jun-21	18:00	Daily	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
80	1	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	18-Jun-21	08:00	18-Jun-21	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kV Lonikand-II-Lonikand-I Interconector Ckt-I will remain in service
81	1	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	18-Jun-21	08:00	18-Jun-21	17:00	Daily	For Conductor & Earthwire H/W tightening work if found any during MP	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work if found any during MP
82	1	400 KV	RPL(AMT) NANDGAON PETH - AKOLA II LINE II	18-Jun-21	08:00	18-Jun-21	17:00	Daily	For Insulator replacement and routine maintenance.	APTCL	APTCL	Outage require for Insulator replacement and routine maintenance.
83	1	400 KV	MAIN BAY - 418 OF IEPL @ KORADI-2	18-Jun-21	10:00	18-Jun-21	15:00	Daily	Diagnostic testing of CB 418-Q52	MSETCL	MSETCL	outage will be availed subject to weather condition
84	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	19-Jun-21	08:00	19-Jun-21	17:00	Daily	For Conductor & Earthwire H/W tightening work if found any during MP	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work if found any during MP
85	1	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	19-Jun-21	08:00	19-Jun-21	18:00	Daily	LTS relay retrofitting work	MSETCL	MSETCL	ICT 1, 3, 4 will be in service
86	1	400 KV	400/220/20 KV 500MVA ICT - 1 @ KALWA	20-Jun-21	09:00	20-Jun-21	18:00	Daily	RTV coating work on open delta"	MSETCL	MSETCL	RTV coating work on open delta"
87	1	400 KV	WARORA - IEPL	20-Jun-21	09:00	20-Jun-21	18:00	Daily	Routine maintainance and diagonastic testing such as CVT/ CT tandelta,and ,isolater maintainance work	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt
88	1	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	21-Jun-21	09:00	21-Jun-21	18:00	Daily	QM work Annual Diagnostic testing work	MSETCL	MSETCL	1) Load will be managed on ICT 1 & ICT 2 2) Monday is load staggering day in Kolhapur
89	1	400 KV	KORADI-KHAPERKHEDA I	21-Jun-21	09:00	23-Jun-21	18:00	Daily	PG isolators alignment , testing and setting work & routine diagnostic testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
90	1	400 KV	DEEPNAGAR - THAPTI TANDA	21-Jun-21	08:00	22-Jun-21	18:00	Daily	On Line PID By PID Unit,Dhule	MSETCL	MSETCL	During outage AR is required in Out mode
91	1	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	21-Jun-21	10:00	30-Jun-21	15:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto	MSETCL	MSETCL	PID of 400 kv Akola-Nandgaonpeth (RPL) line shall
92	1	400 KV	167 MVA SPARE ICT @ TALANDGE	22-Jun-21	09:00	22-Jun-21	18:00	Daily	QM work	MSETCL	MSETCL	Spare ICT is on humming (no load)
93	1	400 KV	DHULE - - BABLESHWAR - II	23-Jun-21	09:00	23-Jun-21	17:00	Daily	CT & CVT C & tan D testing	MSETCL	MSETCL	400KV Ekamrathkar, 400KV Bableshwar lines will be in service
94	1	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	23-Jun-21	09:00	23-Jun-21	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.
95	1	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	23-Jun-21	10:00	23-Jun-21	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI
96	1	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	23-Jun-21	06:00	30-Jun-21	18:00	Daily	For replacement of Dead end ,Mid Span Joint and conductor at various LOCs	MSETCL	MSETCL	NIL
97	1	400 KV	TIE BAY-426 OF GT-8 @ KORADI-2	23-Jun-21	10:00	23-Jun-21	15:00	Daily	Diagnostic testing of CB 426-Q52	MSETCL	MSETCL	outage will be availed subject to weather condition

98	1	400 KV	JEJURI- KOYNA STAGE-IV	24-Jun-21	09:30	24-Jun-21	17:30	Daily	DT & Insulator String replacement Work.	MSETCL	MSETCL	–
99	1	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	24-Jun-21	09:00	26-Jun-21	18:00	Daily	PG isolators allignment , testing and setting work. Replacement of B ph 29 B Scissor assembly.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
100	1	400 KV	TIE BAY - 414 OF GT-9 @ KORADI-2	24-Jun-21	08:00	24-Jun-21	20:00	Daily	T-Connection of Bus isolator of Reactor bay For 400kV, 125 MVAR Bus Shunt Reactor (bay no. 415).	MSETCL	MSETCL	The above work will be carried out by M/s KEI Industries Ltd. under supervision of AdIEEE, 400KV S/stn. Projects
101	1	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	26-Jun-21	08:00	26-Jun-21	18:00	Daily	CB Diagnostic testing	MSETCL	MSETCL	ICT 1, 2, 4 will be in service