

Maharashtra State Load Despatch Centre												
Monthly Outage list approved in WRLDC OCCM for the Month of JUNE' 2022												
Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
1	841	PLANNED	OCC_555	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	1/Jun/22	08:00	1/Jun/22	18:00	Planned outage
2	843	PLANNED	OCC_555	MSETCL	400KV-TAPTHITHANDA-EKTUNI-1	D	Stringing of OPGW cable	1/Jun/22	08:00	10/Jun/22	19:00	Auto-Reclose to be kept in Non-Auto Mode
3	846	PLANNED	OCC_555	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	D	Permission for Auto-Reclose to be kept in Non-Auto Mode for PID testing work	1/Jun/22	13:00	15/Jun/22	19:00	NIL
4	847	PLANNED	OCC_555	MSETCL	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto-Reclose to be kept in Non-Auto Mode for PID testing work	1/Jun/22	09:00	15/Jun/22	17:00	NIL
5	853	PLANNED	OCC_555	MSETCL	400KV-KARIAT-LONIKHAND-II-1	D	Diagnostic testing and Maintenance.	2/Jun/22	06:00	2/Jun/22	16:00	---
6	854	PLANNED	OCC_555	MSETCL	400KV-WARORA-CHANDRAPU-II-1	D	Isolator maintenance work by Agency.	2/Jun/22	08:00	2/Jun/22	18:00	Load will managed by 400KV Warora-Chandrapur 2 Ckt. 2 .
7	855	PLANNED	OCC_555	MSETCL	400KV/220KV CHAKAN-ICT-3	C	For Overhauling of Bus C 89 C Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work.	2/Jun/22	10:00	4/Jun/22	18:00	The Existing 89 C Isolator has mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by
8	857	PLANNED	OCC_555	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	2/Jun/22	08:00	2/Jun/22	18:00	Planned outage
9	858	PLANNED	OCC_555	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	To the 48F OPGW installation on 400kv chandrapur-warora transmission line (from 400kv chandrapur s/s to 400kv warora s/s)by replacing existing earth wire in live line condition by keeping AR switch in Non-auto mode	2/Jun/22	08:00	13/Jun/22	19:00	To the 48F OPGW installation on 400kv chandrapur-warora transmission line (from 400kv chandrapur s/s to 400kv warora s/s)by replacing existing earth wire in live line condition by keeping AR switch in Non-auto mode
10	870	PLANNED	OCC_555	MSETCL	400KV-CHAKAN-PUNE-PG-1	Daily	For SSN-DSN conversion, DT and maintenance.	2/Jun/22	08:00	2/Jun/22	18:00	
11	1086	PLANNED	OCC_556	RGPPL	400Dabhol-Nagothane-2	D	Lightning Arrestor replacement	2/Jun/22	9:00	4/Jun/22	18:00	Lightning Arrestor replacement
12	250	PLANNED	OCC_555	POWERGRID_WRI	400KV-WARDHA-WARORA-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	3/Jun/22	7:00	9/Jun/22	18:00	SLDC MH comment:STU MSETCL NOC to be taken by PGCIL
13	250	PLANNED	OCC_555	POWERGRID_WRI	400KV-IEPL-WARORA-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	3/Jun/22	7:00	9/Jun/22	18:00	SLDC MH comment:STU MSETCL NOC to be taken by PGCIL
14	859	PLANNED	OCC_555	MSETCL	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1	D	Routine Maintenance work & Diagnostic Testing	3/Jun/22	10:00	3/Jun/22	18:00	NIL
15	861	PLANNED	OCC_555	MSETCL	400KV-RGPPL-NEW KOYNA-2	D	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	3/Jun/22	08:00	3/Jun/22	18:00	Planned outage
16	862	PLANNED	OCC_555	MSETCL	400KV-WARDHA-WARORA-1	D	CVT TanDelta testing work.Isolator maintenance work by Agency	3/Jun/22	08:00	3/Jun/22	18:00	400KV Warora -IEPL Ckt.is in service.
17	869	PLANNED	OCC_555	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work ,CB Timing, DCRM, CT & CVT	4/Jun/22	9:00	5/Jun/22	17:00	400kV Padghe II will be in in service
18	872	PLANNED	OCC_555	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	4/Jun/22	08:00	4/Jun/22	18:00	Planned outage
19	1005	PLANNED	OCC_555	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	4/Jun/22	09:00	4/Jun/22	18:00	Line will be charged through Tie CB 428.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
20	32	PLANNED	OCC_555	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	AMP and CVT repalcement of B phase at Bhilai SS	5/Jun/22	7:00	5/Jun/22	17:30	AMP and CVT repalcement of B phase at Bhilai SS
21	864	PLANNED	OCC_555	MSETCL	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2	Daily	For Replacement of R & B phase Bus CVT and Bus maintenance work. 400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.	5/Jun/22	7:00	5/Jun/22	19:00	400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.
22	865	PLANNED	OCC_555	MSETCL	KHARGHAR - 400KV - BUS 1	Daily	For Replacement of R & B phase Bus CVT and Bus maintenance work 400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.	5/Jun/22	7:00	5/Jun/22	19:00	400KV B Bus will be in service. All Lines & ICT's will be on B bus, load will be shifted via TBC.
23	868	PLANNED	OCC_555	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	Twin Conductor damaged pressure clamps replacement work for Loc no. 85-86, 104-106 and 116-117.	5/Jun/22	09:00	5/Jun/22	17:00	Twin Conductor damaged pressure clamps replacement work for Loc no. 85-86, 104-106 and 116-117.
24	875	PLANNED	OCC_555	MSETCL	400KV-KALWA-PADGHE-1	Daily	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity. 2) Bay maintenance & Complete diagnostic work at 400KV Kalwa ss.	5/Jun/22	09:00	5/Jun/22	18:00	1) Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity. 2) Bay maintenance & Complete diagnostic work at 400KV Kalwa ss.
25	876	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV-PADGHE HVDC-PADGHE-1 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	Daily	A&B bus PG Isolator maint work .	5/Jun/22	08:52	5/Jun/22	18:12	HVDC 1 in service through TBC
26	877	PLANNED	OCC_555	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	Bay Maintenance works.	5/Jun/22	09:00	5/Jun/22	17:00	Bay Maintenance works.
27	879	PLANNED	OCC_555	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance.	5/Jun/22	10:00	5/Jun/22	18:00	---
28	960	PLANNED	OCC_555	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	5/Jun/22	08:00	5/Jun/22	17:00	only Tie CB 421 is in OFF condition ,respective ckt charged through its own main CB.
29	59	PLANNED	OCC_555	POWERGRID_WR1	400KV-PARLI-M-PARLI-2	D	AMP of line terminal equipment at Parli SS. Dia to be kept open for relay testing at Parli SS. A/R of 400KV Parli-Parli M-1 to be in non Auto.	6/Jun/22	7:00	6/Jun/22	18:00	MSLDC Consent is required
30	394	PLANNED	OCC_555	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	D	AMP works of LTE at Boisar end. Also Line AMP works. A/R off of Ckt 2 and Dia to be kept open at Both ends	6/Jun/22	9:00	6/Jun/22	17:30	PG-WR2-BOISAR
31	881	PLANNED	OCC_555	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	6/Jun/22	08:00	6/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
32	882	PLANNED	OCC_555	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	Diagnostic testing of CB & routine maintenance "	6/Jun/22	10:00	6/Jun/22	18:00	765/400kv 1500MVA ICT-II will be in service through its TIE 712 Bay & Main Bus-I
33	883	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV/220KV KUDUS-ICT-1 AND KUDUS - 400KV - BUS 1 @KUDUS - 400KV at KUDUS - 400KV	Daily	Premonsoon Maintenance of bays equipment & Diagnostics Testing Work	6/Jun/22	09:00	6/Jun/22	17:00	Bay No 407(ICT-1 Main Bay) and 408(Tie Bay) outages required at the same time for Premonsoon maintenance work of ICT-1
34	884	PLANNED	OCC_555	MSETCL	TIE BAY OF 400KV/220KV KUDUS-ICT-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	Daily	Premonsoon Maintenance of bays equipment & Diagnostics Testing Work	6/Jun/22	09:00	6/Jun/22	17:00	Bay No 407(ICT-1 Main Bay) and 408(Tie Bay) outages required at the same time for Premonsoon maintenance work of ICT-1
35	885	PLANNED	OCC_555	MSETCL	400KV/220KV NAGOTHANE-ICT-2(ON TBC)	Continuous	For CB replacement work	6/Jun/22	08:00	10/Jun/22	17:00	ICT-II will be in service through TBC
36	887	PLANNED	OCC_555	MSETCL	220KV-BOISAR-BOISAR-M-1	Continuous	CB Maintenance work by shifting the line on TBC.	6/Jun/22	5:00	7/Jun/22	17:00	BOISAR II - BOISAR (PG) CKT - 1 Line will be in service through TBC.
37	888	PLANNED	OCC_555	MSETCL	132KV-DHARNI-NEPANAGAR-1	Daily	AR out for broken disc replacement by hotline method.	6/Jun/22	10:00	9/Jun/22	17:00	.
38	57	PLANNED	OCC_555	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Updating Siemens Distance Relay to Comply IEC61850 and Resolving Front Port Communication Issue of M1 Relay of Padghe Boisar Line at Padghe MSETCL SS.	7/Jun/22	7:00	7/Jun/22	17:00	400 KV Padghe Boisar LINE will be out of service.
39	61	PLANNED	OCC_555	POWERGRID_WR1	PARLI NEW - 400KV - BUS 1	D	AMP of 400 KV Bus 1	7/Jun/22	7:00	7/Jun/22	17:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
40	79	PLANNED	OCCM-555	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AURANGABAD-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	AMP of Bay	7/Jun/22	8:00	7/Jun/22	18:00	422
41	90	PLANNED	OCC_555	POWERGRID_WR1	Main Bay - 400KV-PADGHE-BOISAR-1 AND PADGHE - 400KV - Bus 1	D	AMP OF 400 KV Padghe Boisar Main Bay at Padghe MSETCL SS.	7/Jun/22	8:00	7/Jun/22	17:00	400 KV Padghe Boisar will be in service through TBC CB.
42	416	PLANNED	OCC_555	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	D	AMP works of LTE at Boisar end. Also Line AMP works. A/R off of Ckt 1 and Dia to be kept open at Both ends	7/Jun/22	9:00	7/Jun/22	17:30	PG-WR2-BOISAR
43	889	PLANNED	OCC_555	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	7/Jun/22	08:00	7/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
44	890	PLANNED	OCC_555	MSETCL	TIE BAY - 765KV-AKOLA (2)-EKTUNI-1 AND FUTURE at EKTUNI - 765KV	Daily	"Diagnostic Testing of CT & Routine Maintenance	7/Jun/22	10:00	7/Jun/22	14:00	765kV Akola ckt-I will be in service through its Main 706 Bay & Main Bus-II
45	891	PLANNED	OCC_555	MSETCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	Daily	"Diagnostic Testing of CT & Routine Maintenance	7/Jun/22	15:00	7/Jun/22	18:00	765kV Akola ckt-II will be in service through its TIE 702 Bay & Main Bus-I
46	894	PLANNED	OCC_555	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	7/Jun/22	10:00	7/Jun/22	18:00	NA
47	88	PLANNED	OCC-555	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND BHADRAWATI - 400KV - BUS 2 at BHADRAWATI - 400KV	D	AMP WORK	8/Jun/22	8:00	8/Jun/22	18:00	AMP WORK
48	95	PLANNED	OCCM-555	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-2	D	AMP of Line Bay. AR to be kept in non Auto mode for 400kV Wardha-Warora-1	8/Jun/22	7:00	8/Jun/22	18:00	409L
49	96	PLANNED	OCCM-555	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-2 L/R@ WARDHA - 400KV	D	AMP of Reactor Bay and relay testing works.	8/Jun/22	7:00	8/Jun/22	18:00	409R
50	895	PLANNED	OCC_555	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	8/Jun/22	08:00	8/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
51	896	PLANNED	OCC_555	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Tightening of hardware	8/Jun/22	09:00	8/Jun/22	18:00	Load managed on Lamboti-PGCIL line
52	897	PLANNED	OCC_555	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	8/Jun/22	10:00	8/Jun/22	18:00	NA
53	898	PLANNED	OCC_555	MSETCL	MAIN BAY OF 220KV-TARAPUR 1&2-BOISAR-M-1 AND BOISAR-M - 220KV - BUS 1 @BOISAR-M - 220KV at BOISAR-M - 220KV	Continuous	CB Maintenance work by shifting the line on TBC	8/Jun/22	08:00	9/Jun/22	17:00	BOISAR II - TARAPUR line will be in service through TBC
54	899	PLANNED	OCC_555	MSETCL	220KV-PANDURNA-KALMESHVAR-1	Daily	Routine Maintenance & Dignostic testing work	8/Jun/22	09:00	8/Jun/22	17:00	NA
55	900	PLANNED	OCC_555	MSETCL	132KV-PENCH-KANHAN-1	Daily	Routine Maintenance work.	8/Jun/22	09:00	8/Jun/22	17:00	NA
56	92	PLANNED	OCC_555	POWERGRID_WR1	PARLI - 220KV - BUS 2	D	For Bus AMP	9/Jun/22	7:00	9/Jun/22	18:00	
57	104	PLANNED	OCC_555	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	For Line AMP. AR to be kept in non auto mode for 400KV-KHANDWA-DHULE-MS-2	9/Jun/22	7:00	9/Jun/22	18:00	
58	318	PLANNED	OCC_555	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	D	Line H/T for AMP WORK of LTE at Khandwa end. Also Line AMP works. A/R off of Ckt 2 and Dia to be kept open at Both ends	9/Jun/22	9:00	9/Jun/22	18:00	PG-WR2-KHANDWA
59	902	PLANNED	OCC_555	MEGPTCL	765KV-TIRODA-KORADI-III-1	Daily	For spare reactor to be taken into service as per CEA Regulation.	9/Jun/22	08:00	9/Jun/22	12:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
60	904	PLANNED	OCC_555	MSETCL	400KV/220KV CHAKAN-ICT-2	Continuous	For Overhauling of Bus C 89 C Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work.	9/Jun/22	10:00	11/Jun/22	18:00	The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismanteling the Isolator So time required for Erection and
61	905	PLANNED	OCC_555	MSETCL	400KV-WARDHA-WARORA-1	D	Routine Maintenance & Diagnostic testing work .	9/Jun/22	09:00	9/Jun/22	18:00	400KV WARORA-IEPL Line is in ckt
62	906	PLANNED	OCC_555	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine maintenance	9/Jun/22	08:00	9/Jun/22	18:00	.
63	115	PLANNED	OCC_555	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1 L/R@ DHULE-MS - 400KV	D	For LR AMP	10/Jun/22	7:00	10/Jun/22	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
64	253	PLANNED	OCC_553	POWERGRID _WR1	400KV-WARDHA-WARORA-PG-1	C	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme(New Construction works)	10/Jun/22	7:00	16/Jun/22	18:00	
65	254	PLANNED	OCC_553	POWERGRID _WR1	400KV-WARDHA-WARORA-PG-2	C	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme(New Construction works)	10/Jun/22	7:00	16/Jun/22	18:00	
66	863	PLANNED	OCC_555	MEGPTCL	MAIN BAY - 400KV-KORADI-II-KORADI-III-3 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	Daily	Annual Maintenance of Bay Equipment	10/Jun/22	09:00	10/Jun/22	18:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
67	866	PLANNED	OCC_555	MSETCL	KORADI-II - 400KV - BUS 1	Daily	Tan delta measurement of Bus CVT	10/Jun/22	10:00	10/Jun/22	12:00	1) All the 400KV feeder will remain in service through 400kv Main Bus 2. 2) Same outage was proposed on dated
68	867	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	C	121) of 500KV Chandrapur-Padghe HVDC Line and restringing from Loc. no. 117-122 under HVDC TL O&M S/Dn. Chandrapur	10/Jun/22	06:00	12/Jun/22	18:00	With reduction in Mumbai & Maharashtra import TTC. No other outages from Pune, Kalwa, Khargahr, Boisar, Padghe.
69	873	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	D	To carry out following test on pole-1 Y phase converter transformer as per OEM recommendation.work 1.Ratio test 2.tan delta of A-b1b2 winding. 3.DFRA Test 4.Winding resistance measurement 5.IR & PI of A-B1-B2 winding 6.Core insulation Measurement. 7.Measurement of tan delta of 400KV CT Y-Ph of Tie bay which is under monitoring.	10/Jun/22	20:00	11/Jun/22	23:00	1.Pole-2 will be in service with 750MW in metallic return or 300MW in ground return due to Padghe end problem 2.The Pole-1 filter redundancy including base filter will not available till completion of tan delta of tie Bay 400KV CT of Y-Ph for about 5 to 6 hours. Clubbed with 10-12 June 22 outage
70	878	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	D	For Pre-monsoon preventive Maintenance work also To carry out covering of Buscholz relay.pole 2 will be in service with power 300MW	10/Jun/22	08:00	10/Jun/22	14:00	clubbed with 10-12 June outage
71	907	PLANNED	OCC_555	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Diagnostic and R&M Work.	10/Jun/22	8:00	10/Jun/22	18:00	400kV Kharghar-Talegaon line will be in service
72	908	PLANNED	OCC_555	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	10/Jun/22	08:00	10/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
73	909	PLANNED	OCC_555	MSETCL	EKTUNI - 765KV B/R 1	Daily	Diagnostic Testing of Bus Reactor & Routine Maintenance	10/Jun/22	10:00	10/Jun/22	18:00	765kV 240Mvar Bus Reactor will be out of service.
74	912	PLANNED	OCC_555	MSETCL	400KV-KORADI-II-KORADI-III-2	Daily	Tan delta measurement of Line CT	10/Jun/22	10:00	10/Jun/22	13:00	400kv Koradi-II -Koradi-III Ckt-II will remain in service as alternate source of supply
75	913	PLANNED	OCC_555	MSETCL	BOISAR-M - 220KV - BUS 2	Continuo s	Bus Maintenance works.	10/Jun/22	07:00	12/Jun/22	19:00	Bus Maintenance works
76	914	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-2	C	work of replacement of Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line and restringing from Loc. no. 117-122 under HVDC TL O&M S/Dn. Chandrapur	10/Jun/22	06:00	12/Jun/22	18:00	With reduction in Mumbai & Maharashtra import TTC. No other outages from Pune, Kalwa, Khargahr, Boisar, Padghe.
77	132	PLANNED	OCC_555	POWERGRID _WR1	400KV-AKOLA-AURANGABAD-2	D	For Line Bay AMP. AR ti be kept in non auto mode for 400KV-AKOLA-AURANGABAD-1	11/Jun/22	7:00	11/Jun/22	18:00	
78	251	PLANNED	OCC_555	POWERGRID _WR1	400KV-WARDHA-KORADI-II-1	C	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	11/Jun/22	7:00	12/Jun/22	18:00	
79	397	PLANNED	OCC_555	POWERGRID _WR2	400KV-KHANDWA-DHULE-MS-2	D	Line outage for disconnecting non switchable LR at Khandwa end for L/R R-Ph Bushing Replacement work. Line shall be taken in service without L/R at Khandwa end.	11/Jun/22	9:00	11/Jun/22	12:00	PG-WR2-KHANDWA
80	398	PLANNED	OCC_555	POWERGRID _WR2	400KV-KHANDWA-DHULE-MS-2 L/R@ KHANDWA - 400KV	C	Line Reactor outage at Khandwa end for R-ph Bushing Replacement work due to High Tan Delta.	11/Jun/22	9:00	11/Jun/22	18:00	PG-WR2-KHANDWA

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
81	473	PLANNED	OCC_555	POWERGRID _WR2	400KV-KHANDWA-DHULE-MS-2	D	Line outage for taking non Switchable L/R in service at Khandwa end	11/Jun/22	15:00	11/Jun/22	18:00	PG-WR2-KHANDWA
82	844	PLANNED	OCC_555	MSETCL	400KV-TAPTHITHANDA-EKTUNI-2	Daily	Stringing of OPGW cable	11/Jun/22	08:00	20/Jun/22	19:00	Auto-Reclose to be kept in Non-Auto Mode
83	910	PLANNED	OCC_555	MSETCL	400KV-WARDHA-KORADI-II-1	D	Line maintenance work	11/Jun/22	08:00	11/Jun/22	18:00	Clubbed with outage on 11-June-22
84	916	PLANNED	OCC_555	MEGPTCL	TIE BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-AKOLA (2)-EKTUNI-1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	11/Jun/22	08:00	11/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
85	921	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-2	D	To carry out pre monsoon Preventive work like covering of Buchholz relay etc	11/Jun/22	08:00	11/Jun/22	14:00	clubbed with 10-12 June outage
86	48	PLANNED	OCC_555	POWERGRID _WR1	TIE BAY - 400KV-CHAKAN-PUNE-PG-1 AND 400KV-KHARGHAR-PUNE-PG-1 at PUNE-PG - 400KV	D	For AMP Work	12/Jun/22	8:00	12/Jun/22	18:00	
87	70	PLANNED	OCC_555	POWERGRID _WR1	MAIN BAY - 400KV-KHANDWA-DHULE-MS-1 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	For Bay AMP	12/Jun/22	7:00	12/Jun/22	18:00	
88	874	PLANNED	OCC_555	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	Bay Maintenance works.	12/Jun/22	09:00	12/Jun/22	17:00	Bay Maintenance works.
89	915	PLANNED	OCC_555	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	For SSN-DSN conversion, Chemeical cleaning of insulator strings	12/Jun/22	20:00	13/Jun/22	5:00	Mumbai increased demand, to be availed on night hours, Mumbai & Maharashtra import would be reduced by 680 MW
90	917	PLANNED	OCC_555	MSETCL	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Diagnostic testing work .	12/Jun/22	09:00	12/Jun/22	18:00	Clubbed with outage on 12-June-22
91	919	PLANNED	OCC_555	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	12/Jun/22	08:00	12/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
92	922	PLANNED	OCC_555	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Earthwire restringing work	12/Jun/22	08:00	12/Jun/22	17:00	-
93	923	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV-PADGHE HVDC-PADGHE-2 AND PADGHE HVDC - 400KV - BUS 1 @PADGHE HVDC - 400KV at PADGHE HVDC - 400KV	Daily	HVDC -2 A&B bus PG Isolator maint work	12/Jun/22	09:12	12/Jun/22	18:30	HVDC 2 in service through TBC
94	924	PLANNED	OCC_555	MSETCL	400KV-KALWA-PADGHE-2	Daily	Cold line cleaning, Chemical cleaning of Insulators & Reorientation for HTLS work	12/Jun/22	09:00	12/Jun/22	18:00	Cold line cleaning, Chemical cleaning of Insulators & Reorientation for HTLS work
95	925	PLANNED	OCC_555	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance.	12/Jun/22	10:00	12/Jun/22	18:00	---
96	138	PLANNED	OCC_555	POWERGRID _WR1	400KV-TARAPUR 3&4-PADGHE-2	D	Relay Testing OF 400 KV Padghe Tarapur-2 at Padghe MSETCL SS.	13/Jun/22	7:00	13/Jun/22	17:00	400 KV Padghe Tarapur 2 will be out of service.
97	926	PLANNED	OCC_555	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	13/Jun/22	08:00	13/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
98	928	PLANNED	OCC_555	MSETCL	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	1. Own Bay 400kV B bus isolator replacement work. 2. 400kV TBC B bus PG isolator replacement work 3. outage is required along with Main bus 2	13/Jun/22	07:00	13/Jun/22	23:59	Monday is Load Staggering day in Kolhapur
99	929	PLANNED	OCC_555	MSETCL	KOLHAPUR-MS - 400KV - BUS 2	Daily	1. Annual Bus Maintenance 2. 400kV TBC B bus PG isolator replacement work 3. PID faulty string replacement work	13/Jun/22	07:00	13/Jun/22	23:59	Monday is load staggering day in Kolhapur
100	930	PLANNED	OCC_555	MSETCL	BUS COUPLER BAY OF NAGOTHANE - 400KV - BUS 1 AND NAGOTHANE - 400KV - BUS 2 @NAGOTHANE - 400KV at NAGOTHANE - 400KV	Continuo us	For CB replacement work	13/Jun/22	08:00	17/Jun/22	17:00	-
101	931	PLANNED	OCC_555	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine maintenance	13/Jun/22	09:00	13/Jun/22	18:00	.
102	932	PLANNED	OCC_555	MSETCL	765KV/400KV EKTUNI-ICT-3 (SPARE ICT UNIT)	Daily	"Diagnostic Testing of CT, CB & Routine Maintenance	14/Jun/22	10:00	14/Jun/22	18:00	765/400kV 500MVA Spare ICT-II, is Hot Standby on NO LOAD; will be out of service.
103	933	PLANNED	OCC_555	MEGPTCL	TIE BAY (708) of KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2 (NOT FOUND)	Daily	Circuit Breaker SF6 gas analysis	14/Jun/22	08:00	14/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
104	935	PLANNED	OCC_555	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	14/Jun/22	08:00	14/Jun/22	18:00	NA
105	936	PLANNED	OCC_555	MSETCL	400KV-KARAD-JAIGAD-1	Daily	Hotline insulator washing	14/Jun/22	09:00	15/Jun/22	18:00	Online work
106	937	PLANNED	OCC_555	MSETCL	400KV-KARAD-JAIGAD-2	Daily	Hotline insulator washing	14/Jun/22	09:00	15/Jun/22	18:00	Online work
107	971	PLANNED	OCC_555	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	For SSN-DSN conversion, Chemical cleaning of insulator strings	14/Jun/22	20:00	14/Jun/22	5:00	Mumbai increased demand, to be availed on night hours, Mumbai & Maharashtra import would be reduced by 680 MW
108	972	PLANNED	OCC_555	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Cold line cleaning, Chemical cleaning of Insulators & addition jumpuring work by fire wedge connector.	14/Jun/22	20:00	15/Jun/22	5:00	Mumbai increased demand, to be availed on night hours, Mumbai & Maharashtra import would be reduced by 680 MW
109	158	PLANNED	OCC_555	POWERGRID _WR1	400KV-KHANDWA-DHULE-MS-2	D	For Line Bay AMP. AR to be kept in non Auto for 400KV-400KV-KHANDWA-DHULE-MS-1	15/Jun/22	7:00	15/Jun/22	18:00	
110	848	PLANNED	OCC_555	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Permission for Auto-Reclose to be kept in Non-Auto Mode for PID testing work	15/Jun/22	13:00	30/Jun/22	19:00	Auto-Reclose feature of this line is already out of service since a generation connected line
111	938	PLANNED	OCC_555	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	Daily	For spare reactor to be taken into service as per CEA Regulation.	15/Jun/22	08:00	15/Jun/22	12:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
112	939	PLANNED	OCC_555	MSETCL	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	Daily	Diagnostic testing of CB 409-Q52	15/Jun/22	10:00	15/Jun/22	16:00	400kv Koradi-II -Koradi-III Ckt-1 will remain in service through Tie Bay 405
113	940	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV-IEPL-WARORA-1 AND WARORA - 400KV - BUS 1 @WARORA - 400KV at WARORA - 400KV	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	15/Jun/22	08:00	15/Jun/22	17:00	Line will charged through Tie bay no 418
114	941	PLANNED	OCC_555	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	15/Jun/22	08:00	15/Jun/22	18:00	NA
115	942	PLANNED	OCC_555	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	15/Jun/22	09:00	15/Jun/22	17:00	NA
116	999	PLANNED	OCC_555	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Cold line cleaning, Chemical cleaning of Insulators & addition jumpuring work by fire wedge connector.	15/Jun/22	20:00	16/Jun/22	5:00	Mumbai increased demand, to be availed on night hours, Mumbai & Maharashtra import would be reduced by 680 MW
117	60	PLANNED	OCC_555	POWERGRID _WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	16/Jun/22	8:00	16/Jun/22	18:00	
118	298	PLANNED	OCC_555	POWERGRID _WR1	WARDHA - 400KV - BUS 1	D	Bus Bar#01 protection changes (converting half dia to full dia) for Series Reactor under SS11 and isolator up gradation from 40kA to 50kA (essential part of series reactor commissioning) (new contruction work)	16/Jun/22	6:00	16/Jun/22	18:00	
119	301	PLANNED	OCC_555	POWERGRID _WR1	WARDHA - 400KV - BUS 1	D	Bus Splitting for series rector charging and protection changes in existing 400kV Bus Bar#01 and isolator up gradation from 40kA to 50kA(essential part of series reactor commissioning) under substation package SS11 (new contruction work)	16/Jun/22	6:00	17/Jun/22	18:00	
120	849	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID testing work. 400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode.	16/Jun/22	09:00	30/Jun/22	17:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
121	850	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing work. 400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode.	16/Jun/22	09:00	30/Jun/22	17:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
122	852	PLANNED	OCC_555	MSETCL	400KV-KARAD-NEW KOYNA-1	Daily	Permission for Auto-Reclose to be kept in Non-Auto Mode for PID testing work	16/Jun/22	09:00	30/Jun/22	17:00	NIL

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
123	943	PLANNED	OCC_555	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis	16/Jun/22	08:00	16/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
124	944	PLANNED	OCC_555	MSETCL	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	16/Jun/22	10:00	16/Jun/22	18:00	765kV 240Mvar Bus Reactor will be in service through its TIE 712 Bay & Main Bus-II
125	948	PLANNED	OCC_555	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Chemical washing of Disc Insulator strings	16/Jun/22	08:00	16/Jun/22	18:00	NIL
126	949	PLANNED	OCC_555	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	For Conductor & Earthwire H/W tightening work if found during MP	16/Jun/22	08:00	16/Jun/22	17:00	For Conductor & Earthwire H/W tightening work if found during MP
127	950	PLANNED	OCC_555	MSETCL	400KV/220KV CHAKAN-ICT-1	Continuo s	For Overhauling of Bus C 89 C Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work.	16/Jun/22	10:00	18/Jun/22	18:00	The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismanteling the Isolator So time required for Erection and Dismantaling Work along with Overhauling.
128	952	PLANNED	OCC_555	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine maintenance	16/Jun/22	08:00	16/Jun/22	18:00	.
129	954	PLANNED	OCC_555	MSETCL	400KV-JAIGAD-NEW KOYNA-1	Daily	Hotline insulator washing	16/Jun/22	09:00	16/Jun/22	18:00	Online work
130	955	PLANNED	OCC_555	MSETCL	400KV-JAIGAD-NEW KOYNA-2	Daily	Hotline insulator washing	16/Jun/22	09:00	16/Jun/22	18:00	Online work
131	860	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	D	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	17/Jun/22	08:00	17/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
132	962	PLANNED	OCC_555	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	17/Jun/22	08:00	17/Jun/22	18:00	NA
133	963	PLANNED	OCC_555	MSETCL	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV (NOT FOUND)	Continuo s	CB Maintenance work by shifting the line on TBC.	17/Jun/22	07:00	18/Jun/22	17:00	BOISAR II - BOISAR (PG) CKT - 3 will be in service through TBC.
134	181	PLANNED	OCC_555	POWERGRID _WR1	400KV-PARLI-SOLAPUR-1	D	AMP work line terminal equipment	18/Jun/22	7:00	18/Jun/22	18:00	
135	302	PLANNED	OCC_555	POWERGRID _WR1	WARDHA - 400KV - BUS 2	D	Bus Splitting for series reactor charging and protection changes in existing 400kV Bus Bar#02 and isolator up gradation from 40kA to 50kA (essential part of series reactor commissioning) under substation package SS11 (new contruction work)	18/Jun/22	6:00	19/Jun/22	18:00	
136	961	PLANNED	OCC_555	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	Twin Conductor damaged pressure clamps replacement work for Loc no. 121-124 and 142-143.	18/Jun/22	09:00	18/Jun/22	17:00	Twin Conductor damaged pressure clamps replacement work for Loc no. 121-124 and 142-143.
137	965	PLANNED	OCC_555	MEGPTCL	400KV-AKOLA-AKOLA (2)-1	Daily	Replacement of old MCVT with new design MCVT as per OEM recommendation	18/Jun/22	08:00	18/Jun/22	18:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
138	966	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	18/Jun/22	08:00	18/Jun/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
139	967	PLANNED	OCC_555	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	Bay Maintenance works.	18/Jun/22	09:00	18/Jun/22	17:00	Bay Maintenance works.
140	968	PLANNED	OCC_555	MSETCL	400KV-TAPTHITHANDA-EKTUNI-2	Daily	Stringing of OPGW cable	18/Jun/22	08:00	18/Jun/22	19:00	Nil
141	969	PLANNED	OCC_555	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	1) Bay maintenance work 2) Replacement of Y-Ph CT to Gantry main line jumper 3) MTAMC work 4) Replacement of PG isolator under LES scheme.	18/Jun/22	09:00	18/Jun/22	19:00	1) Agency will be present on site 2) Weather condition should be clear
142	970	PLANNED	OCC_555	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Diagnostic Testing & Routine Maintenance	18/Jun/22	10:00	18/Jun/22	18:00	765/400kV 1500MVA ICT-I will be in service
143	871	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	19/Jun/22	08:00	19/Jun/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
144	973	PLANNED	OCC_555	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Jumper tightening work	19/Jun/22	08:00	19/Jun/22	17:00	-
145	886	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	20/Jun/22	08:00	20/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
146	974	PLANNED	OCC_555	MEGPTCL	400KV-AKOLA-AKOLA (2)-2	Daily	Replacement of old MCVT with new design MCVT as per OEM recommendation	20/Jun/22	08:00	20/Jun/22	16:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
147	975	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV-RGPPL-NAGOTHANE-2 AND NAGOTHANE - 400KV - BUS 2 @NAGOTHANE - 400KV at NAGOTHANE - 400KV	Continuo s	For overhauling of ABB MAke CB	20/Jun/22	08:00	24/Jun/22	17:00	Dabhol-II will be in service through TBC
148	977	PLANNED	OCC_555	MSETCL	400KV/220KV KOLHAPUR-ICT-1(ON TBC)	Continuo s	400kV Side CB overhauling work	20/Jun/22	09:00	22/Jun/22	23:57	Online TBC Shifting only for CB OH work
149	208	PLANNED	OCC_555	POWERGRID _WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line side equipments AMP	21/Jun/22	7:00	21/Jun/22	18:00	
150	209	PLANNED	OCC_555	POWERGRID _WR1	400KV-KOLHAPUR-MS-SOLAPUR-2 L/R@ SOLAPUR - 400KV	D	Line Reactor AMP Works	21/Jun/22	7:00	21/Jun/22	18:00	
151	262	PLANNED	OCC_555	POWERGRID _WR1	400KV-WARDHA-AKOLA-2	D	For BHEL Insulator Replacement Work	21/Jun/22	7:00	21/Jun/22	18:00	
152	266	PLANNED	OCC_555	POWERGRID _WR1	400KV-WARDHA-AKOLA-1 (NON-AUTO)	D	For BHEL Insulator Replacement Work	21/Jun/22	7:00	21/Jun/22	18:00	
153	903	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	21/Jun/22	08:00	21/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
154	263	PLANNED	OCC_555	POWERGRID _WR1	400KV-WARDHA-AKOLA-1	D	For BHEL Insulator Replacement Work	22/Jun/22	7:00	22/Jun/22	18:00	
155	267	PLANNED	OCC_555	POWERGRID _WR1	400KV-WARDHA-AKOLA-2 (NON-AUTO)	D	For BHEL Insulator Replacement Work	22/Jun/22	7:00	22/Jun/22	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
156	790	Planned	OCC_555	GETCO	400KV-SSP-DHULE-MS-1	Daily	Maintenance work. Auto reclose of 400 kV SSP - Dhule - 2 will remain out	22/Jun/22	8:00	22/Jun/22	18:00	Non auto reclose code for 400kv SSP-Dhule no-2 is to be required.
157	980	PLANNED	OCC_555	MSETCL	KORADI - 400KV - BUS 1	Daily	ZIV BUSBAR SCHEME TESTING , all elements will be in service, only Bus protection will be out	22/Jun/22	09:00	22/Jun/22	18:00	Outages will be availed subject to weather conditions.
158	982	PLANNED	OCC_555	APTCL	400KV-AKOLA-AKOLA (2)-1	Daily	Routine maintenance & testing work	22/Jun/22	10:00	22/Jun/22	17:00	Load will be shifted on Yelwan Ckt-02
159	984	PLANNED	OCC_555	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	Daily	Maintenance work and relay testing.	22/Jun/22	10:00	22/Jun/22	18:00	Load will be managed on 400kV Lamboti-Parali Line
160	985	PLANNED	OCC_555	MSETCL	400KV-WARORA-CHANDRAPUR-II-1	Daily	Relay testing work, Routine Maintenance & Dignostic testing work etc.	22/Jun/22	08:00	22/Jun/22	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 2 Bay no 416
161	987	PLANNED	OCC_555	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	22/Jun/22	09:00	22/Jun/22	17:00	NA
162	223	PLANNED	OCC_555	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For Amp	23/Jun/22	7:00	23/Jun/22	18:00	
163	224	PLANNED	OCC_555	POWERGRID_WRI	400KV-ALKUD-SOLAPUR	D	Line side equipments AMP	23/Jun/22	7:00	23/Jun/22	18:00	
164	225	PLANNED	OCC_555	POWERGRID_WRI	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	Line Reactor AMP Works	23/Jun/22	7:00	23/Jun/22	18:00	
165	264	PLANNED	OCC_555	POWERGRID_WRI	400KV-WARDHA-AKOLA-2	D	For BHEL Insulator Replacement Work	23/Jun/22	7:00	23/Jun/22	18:00	
166	268	PLANNED	OCC_555	POWERGRID_WRI	400KV-WARDHA-AKOLA-1 (NON-AUTO)	D	For BHEL Insulator Replacement Work	23/Jun/22	7:00	23/Jun/22	18:00	
167	981	PLANNED	OCC_555	MSETCL	400KV-TAPTHITHANDA-EKTUNI-1	Daily	Relay Testing work & Quarterly maintenance work.	23/Jun/22	11:00	23/Jun/22	11:00	Nil
168	986	PLANNED	OCC_555	MEGPTCL	TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND 400KV-AKOLA-AKOLA (2)-1 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis	23/Jun/22	08:00	23/Jun/22	14:00	Outage can be upload in account of MEGPTCL in D-3 for readiness in portal
169	988	PLANNED	OCC_555	MSETCL	EKTUNI - 765KV B/R 1	Daily	Restoring Rph Phase Unit of Bus Reactor in service	23/Jun/22	10:00	23/Jun/22	18:00	765kV 240Mvar Bus Reactor will be out of service.
170	989	PLANNED	OCC_555	MSETCL	BUS COUPLER @ CHAKAN(NOT FOUND ON WRLDC PORTAL)	Continuo s	For Overhauling of Bus B 89B Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work.	23/Jun/22	10:00	25/Jun/22	18:00	The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismanteling the Isolator So time required for Erection and
171	990	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	23/Jun/22	08:00	23/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
172	991	PLANNED	OCC_555	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine maintenance	23/Jun/22	08:00	23/Jun/22	18:00	.
173	992	PLANNED	OCC_555	MSETCL	KARAD - TALANDGE CKT - 1(ON TBC @ KOLHAPUR-MS - 400KV)	Continuo s	400kV CB Overhauling work	23/Jun/22	09:00	25/Jun/22	23:59	Online TBC Shifting only for CB OH work
174	791	Planned	OCC_555	GETCO	400KV-SSP-DHULE-MS-2	Daily	Maintenance work. Auto reclose of 400 kV SSP - Dhule -1 will remain out	24/Jun/22	7:00	24/Jun/22	18:00	Non auto reclose code for 400kv SSP-Dhule no-1 is to be required.
175	994	PLANNED	OCC_555	MSETCL	AKOLA - 400KV - BUS 1	Daily	Routine maintenance & testing work	24/Jun/22	10:00	24/Jun/22	17:00	Load shifted on Main Bus -02

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
176	918	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	25/Jun/22	08:00	25/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
177	996	PLANNED	OCC_555	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	1) Bay maintenance work 2) MTAMC work 3) Distance relay retrofitting work 4) Replacement 29C Bus PG isolator under LES scheme.	25/Jun/22	09:00	25/Jun/22	19:30	1) Agency will be present on site 2) Weather condition should be clear
178	998	PLANNED	OCC_555	MSETCL	220KV-BOISAR-BOISAR-M-3	Daily	Bay Maintenance works	25/Jun/22	09:00	25/Jun/22	17:00	Bay Maintenance works
179	911	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	26/Jun/22	08:00	26/Jun/22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
180	1000	PLANNED	OCC_555	MSETCL	MAIN BAY - 400KV-PADGHE-NAGOTHANE-2 AND PADGHE - 400KV - BUS 1 at NAGOTHANE - 400KV(NOT FOUND)	Continuo us	For overhauling of BHEL make CB.Padgha-II will be in service through TBC at 400KV Nagothane end	26/Jun/22	08:00	30/Jun/22	17:00	Padgha-II will be in service through TBC at 400KV Nagothane end
181	1001	PLANNED	OCC_555	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	"Diagnostic Testing & Routine Maintenance "	26/Jun/22	10:00	26/Jun/22	18:00	765/400kV 1500MVA ICT-II will be in service
182	1002	PLANNED	OCC_555	MSETCL	400KV-KALWA-PADGHE-1	Daily	1) Bay maintenance work 2) Replacement of 29C Bus PG isolator under LES scheme. 3) Diagnostic Testing work 4) MTAMC work	26/Jun/22	09:00	26/Jun/22	19:00	1) Agency will be present on site 2) Weather condition should be clear
183	666	PLANNED	OCC_555	WTPL - ADANI	400KV-PARLI-SOLAPUR-1	Daily	Planned annual maintenance of line	27/Jun/22	9:00	27/Jun/22	17:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
184	667	PLANNED	OCC_555	WTPL - ADANI	400KV-PARLI-SOLAPUR-2	Daily	AR in non auto due to planned annual maintenance of 400 kV Solapur-Parli-1	27/Jun/22	9:00	27/Jun/22	17:00	Outage can be upload in WRLDC outage management portal in account of ATIL for D-3 readiness.
185	934	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	27/Jun/22	08:00	27/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
186	1003	PLANNED	OCC_555	MSETCL	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	Continuo us	400kV CB Overhauling work	27/Jun/22	09:00	29/Jun/22	23:59	Continue outage for CB OH work
187	959	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	28/Jun/22	08:00	28/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
188	825	Planned	OCC_555	GETCO	220KV-NASIK-NAVSARI-1	Daily	Bay and line maintance Work	29/Jun/22	9:00	29/Jun/22	18:00	
189	997	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	29/Jun/22	08:00	29/Jun/22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
190	1008	PLANNED	OCC_555	MSETCL	400KV-CHANDRAPUR-BHADRAWATI-1	Continuo us	Required for Main Bus -2 outage work.	29/Jun/22	08:00	30/Jun/22	18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuou s	Reason	From		To		Remarks
191	1009	PLANNED	OCC_555	MSETCL	400KV-CHANDRAPUR-BHADRAWATI-2	Continuou s	Required for Main Bus -2 outage work.	29/Jun/22	08:00	30/Jun/22	18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.
192	1010	PLANNED	OCC_555	MSETCL	400KV-TAPTHITHANDA-EKTUNI-2	Daily	Relay Testing work & Quarterly maintenance work.	29/Jun/22	11:00	29/Jun/22	17:00	Nil
193	1011	PLANNED	OCC_555	MSETCL	CHANDRAPUR - 400KV - BUS 2	Continuou s	1) Measurement of Tan delta and Capacitance of R, Y & B-ph Bus CVTs. 2) Nut bolt tightening of bus conductor and hardwares.	29/Jun/22	08:00	30/Jun/22	18:00	1. Bays/feeders connected to 400KV Main Bus-2 will be shifted to 400KV Main Bus-1 via TBC-1 and TBC-2 bay one by one. 2. All 400KV Bays/feeders will be in service on 400KV Main Bus-1. As 400KV Main Bus-1
194	1013	PLANNED	OCC_555	MSETCL	MAIN BUS @ BALE (SOLAPUR 2) (NOT FOUND WRLDC PORTAL)	Daily	Outage is required for Quarterly Maintenance	29/Jun/22	09:00	29/Jun/22	18:00	Quarterly Maintenance
195	307	PLANNED	OCC_555	POWERGRID _WR1	400KV-WARDHA-KORADI-II-1	D	isolator up gradation work for 41389B (new contruction work)	30/Jun/22	6:00	30/Jun/22	18:00	
196	308	PLANNED	OCC_555	POWERGRID _WR1	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	isolator up gradation work for 41389B (new contruction work)	30/Jun/22	6:00	30/Jun/22	18:00	
197	309	PLANNED	OCC_555	POWERGRID _WR1	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV	D	isolator up gradation work for 41389B (new contruction work)	30/Jun/22	6:00	30/Jun/22	18:00	
198	828	Planned	OCC_555	GETCO	220KV-NASIK-NAVSARI-2	Daily	Bay and line maintance Work	30/Jun/22	9:00	30/Jun/22	18:00	
199	1006	PLANNED	OCC_555	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	30/Jun/22	09:00	30/Jun/22	18:00	Clubbed with outage on 11-June-22
200	1014	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV-LONIKHAND-JEJURI-1 AND JEJURI - 400KV - BUS 2 @JEJURI - 400KV at JEJURI - 400KV	Daily	Annual Testing & Maintenance work.	30/Jun/22	09:30	30/Jun/22	17:30	400kV Lonikand line will be in service through 402 Tie Bay.
201	1015	PLANNED	OCC_555	MSETCL	KOLHAPUR-MS - 400KV - TRANSFER BUS 1	Continuou s	400kV CB Over hauling work	30/Jun/22	09:00	2/Jul/22	23:59	Generally 400kV TBC is free
202	1016	PLANNED	OCC_555	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Chemical washing of Disc Insulator strings	30/Jun/22	08:00	30/Jun/22	18:00	NIL
203	1020	PLANNED	OCC_555	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine maintenance	30/Jun/22	08:00	30/Jun/22	18:00	.

List of outages not considered by WRPC OCCM for the Month of JUNE' 2022													
Sr.No	OCCM Sr.No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		OCC-Remarks	Remarks
								Date	Time	Date	Time		
1	892	PLANNED	OCC_555	MSETCL	MAIN BAY OF 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 @WARORA - 400KV at WARORA - 400KV	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work	7-Jun-22	08:00	7-Jun-22	17:00	Only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.	Given on 4- June-22
2	1012	PLANNED	OCC_555	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work	5-Jun-22	09:00	5-Jun-22	18:00	Line will be charged through Main CB 429.	Given on 5- June-22
3	951	PLANNED	OCC_555	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	16-Jun-22	08:00	16-Jun-22	18:00	NA	Duplicate entry
4	175	PLANNED	OCC_555	POWERGRID_W R1	400KV-AURANGABAD-M (WALLU)-PUNE-PG-1	D	For Line Bay AMP AB to be kept in non Auto mode for 400KV Karbi-Rajpur-4	17-Jun-22	7:00	17-Jun-22	18:00		High Maharashtra and Mumbai demand. Please plan in the next OCC.
5	151	PLANNED	OCC_555	POWERGRID_W R1	400KV-KHARGHAR-PUNE-PG-1	D	For CVT Testing	14-Jun-22	7:00	14-Jun-22	18:00		High Maharashtra and Mumbai demand. Please plan in the next OCC.
6	880	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	Continuous	For Pre-monsoon Preventive Maintenance Work also To carry out covering of Buchholz relay pole 2 will be in service with power 300MW	5-Jun-22	08:00	5-Jun-22	14:00		duplicate entry
7	920	PLANNED	OCC_555	MSETCL	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-2	Continuous	For Pre-monsoon preventive Maintenance Work and measurement of C & tan delta of pole 2 Converter bay B phase CT	12-Jun-22	08:00	12-Jun-22	19:00	For Pre-monsoon preventive Maintenance Work like covering of Buchholz Relay, pole 2 B ph CT tan delta was 0.669 % on 26.11.2021 - outage required for its monitoring	duplicate entry
8	957	PLANNED	OCC_555	MSETCL	KHARGHAR - 400KV - BUS 1	Daily	Online Testing of 400V Bus Bar All Lines / T/Fs of 400KV & 220KV will be in service along with its own protection.	18-Jun-22	9:00	18-Jun-22	18:00	All Lines / T/Fs of 400KV & 220KV will be in service along with its own protection.	High Maharashtra and Mumbai demand. Please plan in the next OCC.
9	958	PLANNED	OCC_555	MSETCL	KHARGHAR - 400KV - BUS 2	Daily	Online Testing of 400V Bus Bar All Lines / T/Fs of 400KV & 220KV will be in service along with its own protection.	18-Jun-22	9:00	18-Jun-22	18:00	All Lines / T/Fs of 400KV & 220KV will be in service along with its own protection.	High Maharashtra and Mumbai demand. Please plan in the next OCC.
10	845	PLANNED	OCC_555	MSETCL	400KV-KARJAT-LONIKHAND-II-1	Daily	PID testing	1/ Jun/22	09:00	15-Jun-22	18:00	PID testing	Mumbai demand. Please plan in the next OCC.
11	842	PLANNED	OCC_555	MSETCL	400KV-PARLI-M-KARJAT-1	Daily	PID testing	1/ Jun/22	09:00	15-Jun-22	18:00	PID testing	Mumbai demand. Please plan in the next OCC.
12	851	PLANNED	OCC_555	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	For Carrying PID Work	1/ Jun/22	08:00	15-Jun-22	18:00		Mumbai demand. Please plan in the next OCC.
13	953	PLANNED	OCC_555	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	For Carrying PID Work	16/ Jun/22	08:00	30-Jun-22	18:00		Mumbai demand. Please plan in the next OCC.
14	856	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	replacement of PID suspicious disc insulator strings and other routine replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL To carry out PID	16/ Jun/22	08:00	16-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
15	893	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL To carry out PID	7/ Jun/22	08:00	7-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
16	901	PLANNED	OCC_555	MSETCL	400KV-KARJAT-LONIKHAND-II-2	Daily	replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL To carry out PID	15/ Jun/22	08:00	30-Jun-22	18:00	...	to 765 KV Aurangabad Padghe and 765 KV Pune
17	927	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL To carry out PID	13/ Jun/22	08:00	13-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
18	945	PLANNED	OCC_555	MSETCL	400KV-PARLI-M-KARJAT-1	Daily	Replacement of string	16/ Jun/22	09:00	16-Jun-22	18:00	Replacement of faulty string	
19	946	PLANNED	OCC_555	MSETCL	400KV-KARJAT-LONIKHAND-II-2	Daily	DT & Line Maintenance	16/ Jun/22	08:00	16-Jun-22	18:00	---	
20	947	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	30/ Jun/22	08:00	30-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
21	956	PLANNED	OCC_555	MSETCL	TIE BAY - 765KV / 400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	Daily		17/ Jun/22	10:00	17-Jun-22	18:00	765/400KV 1500MVA ICT-II will be in service through its Main 713 Bay & Main Bus-II & 765KV 240Mvar will be in	to 765 KV Aurangabad Padghe and 765 KV Pune
22	964	PLANNED	OCC_555	MSETCL	400KV-PARLI-M-KARJAT-2	Daily	PID testing	17/ Jun/22	09:00	29-Jun-22	18:00	PID testing	to 765 KV Aurangabad Padghe and 765 KV Pune
23	976	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	30/ Jun/22	08:00	30-Jun-22	18:00	400V SSNNL Ckt-1 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
24	978	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400KV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	30/ Jun/22	08:00	30-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
25	979	PLANNED	OCC_555	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	LBB relay testing work; bay maintenance work	21/ Jun/22	9:00	21-Jun-22	0.708333	400V Aurangabad, 400V Dhule I&II will be in service	to 765 KV Aurangabad Padghe and 765 KV Pune
26	983	PLANNED	OCC_555	MSETCL	KORADI - 400KV - BUS 1	Daily	elements will be in service, only Bus protection will be out	22/ Jun/22	09:00	22-Jun-22	18:00	Outages will be availed subject to weather conditions.	Duplicate entry
27	993	PLANNED	OCC_555	MSETCL	400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2	Daily	Routine maintenance work of Bus.	24/ Jun/22	8:00	24-Jun-22	0.75	NIL	to 765 KV Aurangabad Padghe and 765 KV Pune
28	995	PLANNED	OCC_555	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	Chemical Cleaning of Isolator string and Routine Line maintenance work	24/ Jun/22	9:00	25-Jun-22	0.708333	400V Padghe I will be in service	to 765 KV Aurangabad Padghe and 765 KV Pune
29	1004	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	replacement of PID suspicious disc insulator strings and other routine replacement of PID suspicious disc insulator strings and other routine maintenance work.	30/ Jun/22	08:00	30-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
30	1007	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-2	Daily	replacement of PID suspicious disc insulator strings and other routine replacement of PID suspicious disc insulator strings and other routine maintenance work.	30/ Jun/22	08:00	30-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
31	1017	PLANNED	OCC_555	MSETCL	400KV-SSP-DHULE-MS-1	Daily	replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine replacement of PID suspicious disc insulator strings and other routine maintenance work.	30/ Jun/22	08:00	30-Jun-22	18:00	400V SSNNL Ckt-2 A/R switch will be kept on non auto mode.	due to other planned outages from SSP
32	1018	PLANNED	OCC_555	MSETCL	400KV-LONIKHAND-CHAKAN-1	Continuous	Y ph, B ph Isolator and Routine Testing and Maintenance Work.	30/ Jun/22	10:00	2-Jul-22	18:00	mechanically jam due to which operation is difficult so Isolator	to 765 KV Aurangabad Padghe and 765 KV Pune
33	1019	PLANNED	OCC_555	MSETCL	400KV-PARLI-M-KARJAT-2	Daily	string replacement	30/ Jun/22	09:00	30-Jun-22	18:00	Load managed on Parli-Karjat 1.	to 765 KV Aurangabad Padghe and 765 KV Pune

State Element outage list for the month of JUNE'2022

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	JAIGAD - KARAD CKT - 1	01-Jun-22	09:00	01-Jun-22	18:00	Daily	Coldline washing work	MSETCL	MSETCL	Bay equipment washing at Jaigad switchyard
2	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	01-Jun-22	10:00	01-Jun-22	18:00	Daily	Maintenance & Diagnostic Testing work.	MSETCL	MSETCL	Load will be managed on ICT II.
3	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	01-Jun-22	08:00	02-Jun-22	18:00	Continuous	1) Premonsoon maintenance work. 2) Measurement of bushing tandelta 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	MSETCL	MSETCL	During outage, 400/220/33KV , (3*105) MVA ICT-2 & 220KV Chandrapur-2 will be in service
4	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	01-Jun-22	08:00	01-Jun-22	17:00	Daily	Annual Maint & testing work	MSETCL	MSETCL	Other 501MVA ICT-2 & 3 is in service
5	400 KV	125MVAr BUS REACTOR @ WARORA	01-Jun-22	08:00	01-Jun-22	17:00	Daily	Premonsoon Maintenance work. Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Reactor & Tie CB(bay No.403) is in OFF conditions.
6	400 KV	JAIGAD - KARAD CKT - 2	02-Jun-22	09:00	02-Jun-22	18:00	Daily	Coldline washing work	JSWEL	JPTL	Bay equipment washing at jaigad swithyard
7	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	02-Jun-22	09:30	02-Jun-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-1 & 2 will be in service.
8	400 KV	400/220/33 KV 500 MVA ICT - 2 @ DHULE	02-Jun-22	08:00	02-Jun-22	17:00	Daily	Annual Maint & testing work	MSETCL	MSETCL	Other 315MVA ICT-1 & 501MVA ICT-3 is in service.
9	400 KV	AKOLA - KHADKA (BHUSAWAL)	02-Jun-22	08:00	07-Jun-22	18:00	Daily	String replacement work will be carried out on 400 kV Akola- Khadka (Bhusawal) line. Also work of tightening of Sagging rods.	MSETCL	MSETCL	String replacement work will be carried out by agency.
10	400 KV	KARAD - LONIKAND I	02-Jun-22	08:00	02-Jun-22	18:00	Daily	Cold line washing of Disc Insulator strings	MSETCL	MSETCL	NIL
11	400 KV	KORADI - KHAPERKHEDA CKT - 1	03-Jun-22	08:00	03-Jun-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
12	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	03-Jun-22	06:00	03-Jun-22	18:00	Daily	For Pre-monsoon maintenance work along with Diagnostic testing.	MSETCL	MSETCL	Load will be managed on another 500 MVA ICT No. 1
13	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	03-Jun-22	08:00	04-Jun-22	18:00	Continuous	1) Premonsoon maintenance work. 2) Measurement of bushing tandelta 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	MSETCL	MSETCL	During outage, 400/220/33KV , 315 MVA ICT-1 & 220KV Chandrapur-2 will be in service
14	400 KV	400/220/33 KV 500 MVA ICT - 3 @ DHULE	03-Jun-22	08:00	03-Jun-22	17:00	Daily	Annual Maint & testing work	MSETCL	MSETCL	Other 315MVA ICT-1 & 501MVA ICT-2 is in service.
15	400 KV	400/220KV 105 MVA SPARE ICT @ DHULE	04-Jun-22	08:00	04-Jun-22	17:00	Daily	Annual Maint & Testing work	MSETCL	MSETCL	Spare ICT is in NO LOAD
16	400 KV	CHANDRAPUR - KHAPERKHEDA	04-Jun-22	08:00	04-Jun-22	17:00	Daily	Tan Delta & Capacitance of Line CTs,Main CTs,Tie CTs & routine maintenance work	MSETCL	MSETCL	NA
17	400 KV	KORADI - KHAPERKHEDA CKT - 2	04-Jun-22	08:00	04-Jun-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
18	400/220kV	315MVA, ICT 1@ BBLR	04-Jun-22	0.375	04-Jun-22	0.75	Daily	Premonsoon maintenance work;HV B/U Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 2, 3 and 4 will be in service
19	400 KV	THAPTI TANDA - WALUJ	06-Jun-22	11:00	06-Jun-22	17:00	Daily	Relay testing work & Quarterly maintenance work	MSETCL	MSETCL	Nil
20	400 KV	400/220KV 167 MVA SPARE ICT @ DHULE	06-Jun-22	08:00	06-Jun-22	17:00	Daily	Annual Maint & Testing work	MSETCL	MSETCL	Spare ICT is in NO LOAD

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
21	400 KV	TIE BAY - 402 OF 400/220/33 KV 500 MVA ICT - 1 AND PARLI @ LAMBOTI	06-Jun-22	10:00	11-Jun-22	18:00	Continuous	Overhauling/Servicing of 402-52 CB.	MSETCL	MSETCL	Without load interruption. ICT 1 will be in charged condition via 401-52 Main CB.
22	400 KV	KARAD - TALANDGE CKT - 1	06-Jun-22	09:00	06-Jun-22	18:00	Daily	1. QM of Bay 2. Relay Testing work	MSETCL	MSETCL	AR & LBB testing work. Monday is load staggering day.
23	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	06-Jun-22	07:00	06-Jun-22	17:00	Daily	Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
24	400 KV	WARORA - IEPL	06-Jun-22	08:00	06-Jun-22	17:00	Daily	Relay testing work, Routine maintenance etc and Isolator maintenance by Agency.	MSETCL	MSETCL	400KV Warora -PGCIL(Wardha) Ckt.is in service.
25	400 KV	GT-9 @ KORADI-2	06-Jun-22	10:00	06-Jun-22	14:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 414 & 413	MSETCL	MSETCL	NOC will be required from Mahagenco
26	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	06-Jun-22	08:00	06-Jun-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
27	400/220kV	167 MVA, Spare ICT 2@ BBLR	06-Jun-22	0.375	06-Jun-22	0.70833	Daily	CB testing work	MSETCL	MSETCL	Not in service
28	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	08-Jun-22	08:00	11-Jun-22	17:00	Daily	String replacement work will be carried out on 400 kV Akola-Nandgaonpeth line. Also work of	MSETCL	MSETCL	String replacement work will be carried out by agency.
29	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	08-Jun-22	07:00	08-Jun-22	17:00	Daily	Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	----
30	400 KV	KORADI - KHAPERKHEDA CKT - 2	08-Jun-22	09:00	08-Jun-22	18:00	Daily	CT TAN Delta	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
31	400 KV	GT-8 @ KORADI-2	08-Jun-22	10:00	08-Jun-22	14:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 425&426	MSETCL	MSETCL	NOC will be required from Mahagenco
32	400 KV	JEJURI- KOYNA STAGE-IV	09-Jun-22	08:00	09-Jun-22	18:00	Daily	Chemical washing of Disc Insulator strings	MSETCL	MSETCL	NIL
33	400 KV	LONIKAND I - KOYNA STAGE-IV	09-Jun-22	09:30	09-Jun-22	18:00	Daily	Half yearly DT and maintenance work.	MSETCL	MSETCL	---
34	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	09-Jun-22	06:00	09-Jun-22	16:00	Daily	Diagnostic testing and Maintenance.	MSETCL	MSETCL	---
35	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	09-Jun-22	09:30	09-Jun-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-2 & 3 will be in service
36	400KV	Babhaleshwar- Bhusawal @BBLR	09-Jun-22	0.375	10-Jun-22	0.70833	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work and CT Testing	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad , Dhule I&II will be in in service
37	400 KV	WARORA - IEPL	10-Jun-22	09:00	10-Jun-22	18:00	Daily	Routine Maintenance & Diagnostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
38	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	10-Jun-22	10:00	10-Jun-22	16:00	Continuous	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
39	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	10-Jun-22	10:00	10-Jun-22	18:00	Daily	Routine Maintenance work & Diagnostic Testing	MSETCL	MSETCL	NIL
40	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	10-Jun-22	09:00	10-Jun-22	18:00	Daily	CT TAN Delta, DFRA	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
41	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PADGHE	10-Jun-22	09:00	10-Jun-22	19:30	Daily	1) Bay maintenance work 2) Diagnostic testing work 3) MTAMC work 4) Replacement of 29C Bus PG isolator under LES scheme	MSETCL	MSETCL	1) Agency will be present on site 2) Weather condition should be clear

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
42	400 KV	MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	10-Jun-22	09:00	10-Jun-22	18:00	Daily	For carry out Line CT Tan delta testing with relay testing work.	MSETCL	MSETCL	During outage said Line will be completely "OFF" required for Line CT Tan delta & relay Testing work.
43	400 KV	KORADI II - IEPL	11-Jun-22	08:00	11-Jun-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
44	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	11-Jun-22	08:00	11-Jun-22	17:00	Daily	Bay maintenance work and diagnostic testing work	MSETCL	MSETCL	-
45	400/220kV	315MVA, ICT 2@ BBLR	11-Jun-22	0.375	11-Jun-22	0.75	Daily	Premonsoon maintenance work;HV LBB,HV CB testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 3 and 4 will be in service
46	400 KV	KARAD - TALANDGE CKT - 2	13-Jun-22	09:00	13-Jun-22	18:00	Daily	400kV TBC B Bus PG isolator replacement work,outage required along with mani bus 2	MSETCL	MSETCL	Monday is load staggering day in kolhapur
47	400 KV	PADGHE - NAGOTHANE CKT - 1	13-Jun-22	09:00	13-Jun-22	19:00	Continuous	1) 29D Isolator replacement work under LES scheme(project work). 2) Nagothane -I H/T require for Shrs for removing JBS tube	MSETCL	MSETCL	1) Agency will be present on site 2) Weather condition should be clear
48	400 KV	NEW KOYNA-KARAD CKT - 1	13-Jun-22	08:00	13-Jun-22	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	---
49	400 KV	TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	13-Jun-22	11:00	13-Jun-22	15:00	Continuous	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
50	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	13-Jun-22	08:00	13-Jun-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
51	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	13-Jun-22	08:00	13-Jun-22	18:00	Daily	For replacement of polymer insulator to antifog long rod porcelain insulator	MSETCL	MSETCL	.
52	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	14-Jun-22	08:00	14-Jun-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Line equipment will charged through Tie bay no 418
53	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END)	14-Jun-22	08:00	15-Jun-22	18:00	Continuous	1) Replacement of M1 distance relay by new numerical line differential relay. 2) Replacement of 86 Master trip relays under MTAMC project.	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 2, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadrawati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be available.
54	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	14-Jun-22	09:00	14-Jun-22	19:00	Continuous	R-ph metering CT Erection work	MSETCL	MSETCL	R-ph metering CT Erection work
55	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	14-Jun-22	08:00	14-Jun-22	18:00	Daily	For replacement of polymer insulator to antifog long rod porcelain insulator	MSETCL	MSETCL	.
56	400 KV	TBC @ KORADI-I	15-Jun-22	09:00	15-Jun-22	18:00	Daily	CT TAN Delta, Differential Protection	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
57	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	15-Jun-22	08:00	15-Jun-22	17:00	Daily	For replacement of faulty PID Disc Insulator	MSETCL	MSETCL	For replacement of faulty PID Disc Insulator
58	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	16-Jun-22	08:00	16-Jun-22	18:00	Daily	For replacement of polymer insulator to antifog long rod porcelain insulator	MSETCL	MSETCL	.
59	400 KV	DEEPNAGAR - THAPTI TANDA	15-Jun-22	11:00	15-Jun-22	17:00	Daily	Relay Testing Work & Quarterly Maintenance work.	MSETCL	MSETCL	Nil

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
60	400 KV	PADGHE - NAGOTHANE CKT - 1	16-Jun-22	09:00	16-Jun-22	19:00	Continuous	After replacement of 29D isolator for re-connection of IPS tube Nagothane-I required H/T . After the completion of work line will be taken in service	MSETCL	MSETCL	1) Agency will be present on site 2) Weather condition should be clear
61	400 KV	NEW KOYNA-KARAD CKT - 2	16-Jun-22	08:00	16-Jun-22	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	--
62	400 KV	CHANDRAPUR-PARLI CKT-3	16-Jun-22	08:00	18-Jun-22	18:00	Daily	For replacement of polymer insulator to long rod porcelain insulator	MSETCL	MSETCL	.
63	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	16-Jun-22	10:00	16-Jun-22	15:00	Continuous	Diagnostic testing & allied bay manintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay manintenance work
64	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	16-Jun-22	08:00	16-Jun-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Line equipment will charged through Tie bay no 421.
65	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	16-Jun-22	06:00	16-Jun-22	16:00	Daily	Diagnostic testing and Maintenance.	MSETCL	MSETCL	---
66	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	16-Jun-22	09:30	16-Jun-22	17:30	Daily	Annual Testing & Maintenance work	MSETCL	MSETCL	400/220/33kV ICT-1 & 3 will be in service.
67	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	16-Jun-22	09:30	16-Jun-22	18:00	Daily	Half yearly DT and maintenance work	MSETCL	MSETCL	---
68	400KV	Babhaleshwar-Aurangabad @BBLR	16-Jun-22	0.375	17-Jun-22	0.70833	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal, Dhule I&II will be in in service
69	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	17-Jun-22	08:00	30-Jun-22	19:00	Daily	To tie 481 Of GW installation on 400kv chandrapur2-switching transmission line (from 400kv chandrapur 2 - chandrapur switchyard)by replacing existing earth wire by new one and string broken AD switch in Newgate	MSETCL	MSETCL	To tie 481 Of GW installation on 400kv chandrapur2-switching transmission line (from 400kv chandrapur 2 - chandrapur switchyard)by replacing existing earth wire by new one and string broken AD switch in Newgate
70	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	17-Jun-22	10:00	17-Jun-22	18:00	Daily	Routine Maintenance work & Diagnostic Testing	MSETCL	MSETCL	NIL
71	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	18-Jun-22	08:00	18-Jun-22	17:00	Daily	Bay Maintenance and diagnsotic testing work	MSETCL	MSETCL	-
72	400/220kV	501 MVA, ICT III@BBLR	18-Jun-22	0.375	18-Jun-22	0.75	Daily	Premonsoon maintenance work; CB Timing,DCRM,Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 4 will be in service
73	400 KV	PADGHE - NAGOTHANE CKT - 1	20-Jun-22	08:00	20-Jun-22	17:00	Daily	Jumper tightening and earthwire restringing work	MSETCL	MSETCL	-
74	400 KV	KORADI - KHAPERKHEDA CKT - 1	20-Jun-22	08:00	20-Jun-22	17:00	Daily	DCRM,CB Timing & CRM of Breaker	MSETCL	MSETCL	Outage proposed on 400 kv Khaperkheda Koradi I Ckt Main Bay 411 & Tie Bay 412
75	400 KV	TBC @ NEW KOYNA	20-Jun-22	08:00	20-Jun-22	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	---
76	400 KV	FUTURE CKT - 1 @ WARORA	21-Jun-22	08:00	21-Jun-22	17:00	Daily	Routine maintenance and Relay testing work and isolater maintenance work .	MSETCL	MSETCL	IEPL Line charged through Main CB bay no 417.
77	400 KV	PADGHE - NAGOTHANE CKT - 2	21-Jun-22	08:00	21-Jun-22	17:00	Daily	Jumper tightening work	MSETCL	MSETCL	-
78	400 KV	KORADI - KHAPERKHEDA CKT - 2	22-Jun-22	08:00	22-Jun-22	17:00	Daily	Tan Delta & Capacitance of Line CTs,Main CTs,Tie CTs & routine maintenance work	MSETCL	MSETCL	Outage Proposed on 400 kv Khaperkheda Koradi II Ckt Main Bay 414 & Tie Bay 415
79	400 KV	TBC @ NEW KOYNA	22-Jun-22	08:00	22-Jun-22	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	---
80	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	22-Jun-22	10:00	22-Jun-22	15:00	Continuous	Diagnostic testing & allied bay manintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay manintenance work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
81	400 KV	400/220kV SPARE ICT @ JEJURI	23-Jun-22	09:30	23-Jun-22	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kV 167 MVA Spare ICT is on no load.
82	400 KV	LONIKAND I -JEJURI	23-Jun-22	08:00	23-Jun-22	18:00	Daily	DT & Line Maintenance	MSETCL	MSETCL	---
83	400 KV	JEJURI- KOYNA STAGE-IV	23-Jun-22	08:00	23-Jun-22	18:00	Daily	Chemical washing of Disc Insulator strings	MSETCL	MSETCL	NIL
84	400 KV	MAIN BAY (404) OF ICT -1 @ WARORA	23-Jun-22	08:00	23-Jun-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work etc	MSETCL	MSETCL	Reactor (Bay no 402) is charged through Tie Bay no 403.(ICT-1 hand over to 400KV Bhableshtar)
85	400 KV	TBC @ NEW KOYNA	24-Jun-22	08:00	24-Jun-22	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	---
86	400 KV	TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	24-Jun-22	08:00	24-Jun-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Reactor (Bay no 402) & ICT-1 (bay No.404) is Charged through own Main CB.
87	400 KV	STATION TF 8B @ CHANDRAPUR SWITCHING	24-Jun-22	09:00	24-Jun-22	18:00	Continuous	Diagnostic testing & allied bay manintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay manintenance work
88	400 KV	CHANDRAPUR-PARLI CKT-3	24-Jun-22	08:00	25-Jun-22	18:00	Continuous	1) For replacement of old M-2 distance relay under MTAMC project. 2) Circuit Breaker timing, CRM & DCRM. 3) Maintenance and alignments of PG-1, PG-	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1 & 2, 400KV KHAPARKHEDA ckt. 400KV
89	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	25-Jun-22	08:00	25-Jun-22	17:00	Daily	Bay maintenance and diagnostic testing work	MSETCL	MSETCL	-
90	400/220kV	501 MVA, ICT IV@BBLR	44737	0.375	44737	0.75	Daily	Premonsoon maintenance work; HV & MV B/U , Differen	MSETCL	MSETCL	ICT 1, 2, 3 will be in service
91	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	44739	08:00	44739	17:00	Daily	Tan Delta & Capacitance of Line CTs,Main CTs & IR ve	MSETCL	MSETCL	Outage proposed on 400/7.6 kV Station Transformer 5A Bay 416 & Tie Bay 415.
92	400 KV	TIE BAY (405) OF SWICHING SS CKT - 2 & NANDED - 1	44740	09:00	44740	17:00	Continuous	Diagnostic testing & allied bay manintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay manintenance work
93	400 KV	CHANDRAPUR-PARLI CKT-3	44740	08:00	44741	18:00	Continuous	1) For replacement of old M-2 distance relay under MTA	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1 & 2, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadrawati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be available.