

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of JUNE' 2023

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks	
1	4	PLANNED	OCC_567	MSETCL	PADGHE - 400KV - BUS 2	C	1) Replacement of Hanger Assembly of B bus PG isolator of all phase by Hot line method .	5/26/2023	11:00	6/3/2023 16:00	Hot line team will be present on site.
2	5	PLANNED	OCC_567	MSETCL	400KV/220KV PADGHE-ICT-2 ON TBC	C	1) Replacement of HV/ CB under LES scheme 2) ICT will be in service through TBC 3) Replacement of 29B bus PG Isolator under LES scheme	5/26/2023	08:00	6/4/2023 21:00	1) Agency will be present on site
3	31	PLANNED	OCC_567	DHARIWAL	DHARIWAL-CHANDRAPUR II CIRCUIT 1	D	For disconnection of CT/PT connection of MSEDCL /MSETCL energy meter post implementation of DIL CTU STU close bus operation and isolator 4-6896 rectification work & bay Pm work	6/1/2023	09:00	6/1/2023 18:00	
4	32	PLANNED	OCC_567	DHARIWAL	DHARIWAL-MS - 400KV - BUS 2	D	Line - 1 : Isolator 4-6896 rectification work which is to be connected to Bus-II, so bus-II needs off loaded	6/1/2023	09:00	6/1/2023 18:00	
5	33	PLANNED	OCC_567	DHARIWAL	DHARIWAL - 400KV - BUS 2	D	Line - 1 : Isolator 4-6896 rectification work which is to be connected to Bus-II, so bus-II needs off loaded	6/1/2023	09:00	6/1/2023 18:00	
6	43	PLANNED	OCC_567	MSETCL	400KV-WARDHA-KORADI-II-1	D	Routine Maint. Work	6/1/2023	08:00	6/1/2023 18:00	NA
7	44	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	Maintenance work	6/1/2023	08:00	6/1/2023 18:00	.
8	45	PLANNED	OCC_567	MSETCL	BABLESHWAR - 400KV - BUS 2	D	CVT C & Tan delta teting	6/1/2023	09:00	6/1/2023 17:00	Load to be managed on other bus
9	48	PLANNED	OCC_567	MSETCL	MAIN BAY - 400KV-TAPTHITHANDA-EKTUNI-2 AND EKTUNI - 400KV - BUS 1	D	Diagnostic Testing of CB, CT & Routine Maintenance	6/1/2023	10:31	6/1/2023 18:00	400KV Thapti-Tanda Ckt-II will be in service through itsTIE (402) Bay & Main Bus-II
10	66	PLANNED	OCC_567	MSETCL	400KV-CHANDRAPUR-II-NANDED-2	D	For PID Work, Shifting of auto reclose switch to non auto mode.	6/1/2023	08:00	6/4/2023 18:00	.
11	70	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 2. During Outage period 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.	6/1/2023	09:00	6/5/2023 15:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.
12	71	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-1	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 1. During Outage period 400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.	6/1/2023	09:00	6/5/2023 15:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.
13	74	PLANNED	OCC_567	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	D	For PID Work, Shifting of auto reclose switch to non auto mode.	6/1/2023	08:00	6/7/2023 18:00	.
14	76	PLANNED	OCC_567	POWERGRID_WR1	400KV-KOLHAPUR GIS-Mapusa-1	D	For Reconducting work of Kolhapur(PG)-Kolhapur(MSETCL)#2. AR to be kept in non Auto mode for 400KV-KOLHAPUR GIS-Mapusa-2	6/1/2023	07:00	6/10/2023 18:00	
15	85	PLANNED	OCC_567	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 ON TBC - 2	C	1. Servicing & Overhauling of interrupter and pole of 400KV BHEL make quad Circuit breaker. 2. HVDC CKT-2 will be in service via 400KV TBC-2	6/1/2023	08:00	6/13/2023 18:00	HVDC CKT-2 will be in service via 400KV TBC-2. There will be no power restriction as 400KV HVDC CKT-1 will be in service via 400KV TBC-2.
16	91	PLANNED	OCC_567	MSETCL	400KV-WARORA-CHANDRAPUR-II-2	D	For Live Line PID testing work by keeping AR switch is in Non-Auto Mode. 400 KV Warora 1 & 400 KV Warora 2 on same D/C tower Hence non auto reqired on both ckt	6/1/2023	08:00	6/15/2023 17:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower Hence non auto reqired on both ckt
17	92	PLANNED	OCC_567	MSETCL	400KV-WARORA-CHANDRAPUR-II-1	D	For Live Line PID testing work by keeping AR switch is in Non-Auto Mode. 400 KV Warora 1 & 400 KV Warora 2 on same D/C tower Hence non auto reqired on both ckt	6/1/2023	08:00	6/15/2023 17:00	400 KV Warora 1 & 400 KV Warora 2 on same D/C tower Hence Non auto reqired on both ckt
18	93	PLANNED	OCC_567	MSETCL	400KV-KALWA-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	6/1/2023	09:00	6/15/2023 17:00	PID Testing of Insulators Auto-Reclose function to be out of service.
19	98	PLANNED	OCC_567	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	C	For reconducting of Moose conductor with HTLS conductor for system improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1.(New Construction works)	6/1/2023	07:00	6/30/2023 17:00	
20	146	PLANNED	OCC_567	MSETCL	400KV-KARAD-NEW KOYNA-2	D	Permission for AR required in Non Auto mode	6/1/2023	08:00	6/30/2023 17:00	Permission for AR required in Non Auto mode
21	147	PLANNED	OCC_567	MSETCL	400KV-CHANDRAPUR-II-NANDED-1	D	For PID Work, Shifting of auto reclose switch to non auto mode.	6/1/2023	08:00	6/30/2023 18:00	.
22	149	PLANNED	OCC_567	MSETCL	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	6/1/2023	09:00	6/30/2023 15:00	/
23	150	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Online PID work	6/1/2023	09:00	6/30/2023 16:00	400 kv DHL-BBLR -1A/R switch should be kept on non auto mode
24	151	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Online PID work	6/1/2023	09:00	6/30/2023 16:00	400 kv DHL-BBLR -2 AR switch should be kept on non auto mode
25	152	PLANNED	OCC_567	MSETCL	400KV-KARAD-NEW KOYNA-1	D	Permission for AR required in Non Auto mode	6/1/2023	09:00	6/30/2023 17:00	Permission for AR required in Non Auto mode
26	153	PLANNED	OCC_567	MSETCL	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	6/1/2023	09:00	6/30/2023 17:30	-
27	154	PLANNED	OCC_567	MSETCL	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	6/1/2023	09:00	6/30/2023 17:30	-
28	155	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-1	D	PID testing work	6/1/2023	09:00	6/30/2023 18:00	-
29	194	PLANNED	OCC_567	DHARIWAL	DHARIWAL-CHANDRAPUR II CIRCUIT 2	D	For disconnection of CT/PT connection of MSEDCL /MSETCL energy meter post implementation of DIL CTU STU close bus operation	6/2/2023	09:00	6/2/2023 18:00	
30	197	PLANNED	OCC_567	MP_SLDC	220KV-PANDURNA-KALMESHVAR-1	D	FOR LINE MAINTENANCE WORK	6/2/2023	09:00	6/2/2023 18:00	
31	208	PLANNED	OCC_567	MSETCL	KARAD - 400KV - BUS 1	D	Shifting of Y ph Hanger assembly of 400 kv PG isolator of 400/220/33 kv ICT-II bay & fixing of PA rods to damaged conductors near Y ph hanger assembly with the help of Hot line unit (Oglewadi)	6/2/2023	08:00	6/2/2023 18:00	Hot line unit Oglewadi is available on 02.06.2023
32	209	PLANNED	OCC_567	MSETCL	400KV/220KV KARAD-ICT-3	D	Shifting of Y ph Hanger assembly of 400 kv PG isolator of 400/220/33 kv ICT-III bay & fixing of PA rods to damaged conductors near Y ph hanger assembly with the help of Hot line unit Oglewadi. Replacement of Y ph 220 kV side conductor jumps from ICT 220 kV gantry to 220 kV horizontal tower due to damaged conductor.	6/2/2023	08:00	6/2/2023 18:00	Hot line Unit Oglewadi is available on 02.06.2023
33	210	PLANNED	OCC_567	MSETCL	400KV-WARDHA-KORADI-II-1	D	Routine Maint. Work by Lines S/Dn Koradi and Diagnostic testing of Line Current transformer Routine nut bolt tightening by 400KV Koradi 2 substation.	6/2/2023	08:00	6/2/2023 18:00	400KV Koradi-II -EPL Ckt. Will remain in service.
34	216	PLANNED	OCC_567	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	D	Annual Maintenance of Line equipment at Akola(2) SS	6/2/2023	10:00	6/2/2023 18:00	Line Outage
35	217	PLANNED	OCC_567	MSETCL	TIE BAY - 400KV-TAPTHITHANDA-EKTUNI-2 AND FUTURE at EKTUNI - 400KV	D	Diagnostic Testing of CB, CT & Routine Maintenance	6/2/2023	10:30	6/2/2023 18:00	400kv Thapti-Tanda Ckt-II will be in service through its Main (401) Bay & Main Bus-I
36	224	PLANNED	OCC_567	NPCIL, TAPS 1&2	220 kv-Tarapur1&2 - Boisar	C	Annual maintenance of CT, CVT, LA and line side isolators of 220KV Boisar feeder at TAPS1&2 end	6/2/2023	08:00	6/3/2023 20:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
37	228	PLANNED	OCC_567	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	1. Replacement of conductor in span between loc. No. 33 - 34, 2. Replacement of discs type insulator with long rod insulators.	6/2/2023	08:00	6/5/2023	18:00	-
38	231	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	6/2/2023	08:00	6/30/2023	18:00	-
39	232	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-2	D	PID testing work	6/2/2023	09:00	6/30/2023	18:00	-
40	273	PLANNED	OCC_567	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	D	Work of replacement of bent tower members of cross arm of 500 KV Chandrapur-Padghe HVDC POLE 2 at Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur.	6/3/2023	08:00	6/3/2023	12:00	Pole 1 Will be in service in Ground return mode
41	274	PLANNED	OCC_567	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	D	for Pre monsoon maintenance activity	6/3/2023	08:00	6/3/2023	16:00	for Pre monsoon maintenance activity
42	280	PLANNED	OCC_567	POWERGRID_WR1	PADGHE-PG - 400KV - BUS 1	C	Interconnection of 400 KV Extension Bus with the existing Bus 1 and HV testing at Padghe GIS. (New Construction works)	6/3/2023	08:00	6/7/2023	18:00	
43	281	PLANNED	OCC_567	MSETCL	400KV-WARDHA-KORADI-II-1	D	Routine Maint. Work	6/3/2023	08:00	6/8/2023	18:00	NA
44	42	PLANNED	OCC_567	MSETCL	400KV-KARJAT-LONIKHAND-II-2	D	PID faulty insulator strings replacement	6/4/2023	08:00	6/4/2023	18:00	-
45	165	PLANNED	OCC_567	POWERGRID_WR1	400KV-KALWA-PUNE-PG-1	D	AMP WORK	6/4/2023	07:00	6/4/2023	18:00	Line Owned by MSETCL, Request for MSETCL Concern
46	225	PLANNED	OCC_567	MSETCL	220KV-TARAPUR 1-2-BORIVALI-1	D	For the replacement of old hardware at various critical locations. Simultaneously outage is required on 220 kV Borivali-Boisar (PGCIL) for the same work & also both lines are on same M/C Tower.	6/4/2023	09:00	6/6/2023	18:00	Simultaneously outage is required on 220 kV Borivali-Boisar (PGCIL) for the same work & also both lines are on same M/C Tower.
47	226	PLANNED	OCC_567	MSETCL	220KV-BOISAR-BORIVALI-1	D	For the replacement of old hardware at various critical locations. Simultaneously outage is required on 220 kV Borivali-Tarapur for the same work & also both lines are on same M/C Tower.	6/4/2023	09:00	6/6/2023	18:00	Simultaneously outage is required on 220 kV Borivali-Tarapur for the same work & also both lines are on same M/C Tower.
48	289	PLANNED	OCC_567	DHARIWAL	400KV-DHARIWAL-PARLI-2	D	for 400 kv line maintenance work and bay equipments testing & PM work	6/4/2023	09:00	6/4/2023	18:00	
49	294	PLANNED	OCC_567	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	D	Work of replacement of bent tower members of cross arm of 500 KV Chandrapur-Padghe HVDC POLE 1 at Suspension tower(loc. no. 121) of 500KV Chandrapur-Padghe HVDC Line under HVDC TL O&M S/Dn. Chandrapur	6/4/2023	08:00	6/4/2023	12:00	Pole 2 Will be in service in Ground return mode
50	295	PLANNED	OCC_567	MSETCL	220KV-BOISAR-BOISAR-M-1	D	Annual bay maintenance. Diag. testing for CT, LA & Isolator work.	6/4/2023	08:00	6/4/2023	13:00	Annual bay maintenance. Diag. testing for CT, LA & Isolator work.
51	296	PLANNED	OCC_567	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	D	for Pre monsoon maintenance activity	6/4/2023	08:00	6/4/2023	16:00	for Pre monsoon maintenance activity
52	297	PLANNED	OCC_567	MSETCL	400KV-KALWA-PADGHE-1	D	Tapping Arrangement of ERS-4 tapping (Tapping B/w 400Kv Kalwa-Kharghar(Loc.176) & Kalwa-Padghe Ckt.1(1113)) by availing outage on both lines for HTLS of 400KV Kalwa-Padghe-1 line.	6/4/2023	09:00	6/4/2023	18:00	Tapping Arrangement of ERS-4 tapping (Tapping B/w 400Kv Kalwa-Kharghar(Loc.176) & Kalwa-Padghe Ckt.1(1113)) for HTLS of 400KV Kalwa-Padghe-1 line.
53	298	PLANNED	OCC_567	MSETCL	400KV-KALWA-KHARGHAR-1	D	Tapping Arrangement of ERS-4 tapping (Tapping B/w 400Kv Kalwa-Kharghar(Loc.176) & Kalwa-Padghe Ckt.1(1113)) for HTLS of 400KV Kalwa-Padghe-1 line. Simultaneously, work of CB CRM and other maintenance/ Diagnostic work will be carried out at 400KV RS Kalwa.	6/4/2023	09:00	6/4/2023	18:00	Simultaneously, work of CB CRM and other maintenance/ Diagnostic work will be carried out at 400KV RS Kalwa.
54	299	PLANNED	OCC_567	MSETCL	220KV-BOISAR-BOISAR-M-2	D	Power Quality Analyzer device installation & commissioning work.	6/4/2023	15:00	6/4/2023	17:00	Power Quality Analyzer device installation & commissioning work.
55	305	PLANNED	OCC_567	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Amp of Line Bay	6/5/2023	07:00	6/5/2023	18:00	
56	306	PLANNED	OCC_567	POWERGRID_WR1	400KV-KORADI-BHILAI L/R@KORADI - 400KV	D	For Amp of Line Reactor	6/5/2023	07:00	6/5/2023	18:00	
57	312	PLANNED	OCC_567	POWERGRID_WR1	TIE BAY - 400KV-CHAKAN-PUNE-PG-1 AND 400KV-KHARGHAR-PUNE-PG-1 at PUNE-PG - 400KV	D	For CT Oil Level and Bellows Check Work & AMP Work	6/5/2023	08:00	6/5/2023	18:00	
58	322	PLANNED	OCC_567	POWERGRID_WR2	MAIN BAY - 400KV-AURANGABAD-BOISAR-2 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	D	AMP WORKS	6/5/2023	09:00	6/5/2023	17:30	PG-WR2-BOISAR
59	330	PLANNED	OCC_567	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR LINE MAINTENANCE WORK	6/5/2023	09:00	6/5/2023	18:00	
60	342	PLANNED	OCC_567	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	Changeover of Spare Line Reactor with Y-Pn Reactor at Ektuni SS as per CEA guideline	6/5/2023	10:00	6/5/2023	14:00	25.07.2022 Changeover from Y-Phase to Spare Reactor Non-switchable Reactor at Ektuni SS
61	351	PLANNED	OCC_567	MSETCL	400KV-KARJAT-LONIKHAND-II-2	D	PID testing of Insulator Strings	6/5/2023	08:00	6/8/2023	18:00	-
62	353	PLANNED	OCC_567	MSETCL	KARAD - 400KV B/R 1 ON TBC	C	Overhauling of 400 KV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad	6/5/2023	09:00	6/9/2023	18:00	80 MVA/B Bus Reactor will be charged through online TBC
63	361	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-1	D	PID work	6/5/2023	08:00	6/10/2023	18:00	-
64	376	PLANNED	OCC_567	POWERGRID_WR1	220KV-PARLI-HARANGUL-1	D	For AMP	6/6/2023	07:00	6/6/2023	18:00	
65	397	PLANNED	OCC_567	POWERGRID_WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	AMP WORK	6/6/2023	08:00	6/6/2023	18:00	
66	444	PLANNED	OCC_567	MSETCL	400KV-ALKUD-SOLAPUR-1	D	Diagnostic testing & Maintenance work	6/6/2023	10:00	6/6/2023	17:00	Load will be managed on 400KV Alkud-Kolhapur line
67	445	PLANNED	OCC_567	MSETCL	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	6/6/2023	10:00	6/6/2023	17:00	--
68	446	Planned	OCC_567	MSETCL	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	6/6/2023	10:00	6/6/2023	17:00	--
69	447	PLANNED	OCC_567	MSETCL	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	6/6/2023	10:00	6/6/2023	18:00	NA
70	453	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance and Insulator cleaning work	6/6/2023	08:00	6/7/2023	18:00	400KV Ektuni ckt I&II,400KV Bhussel,400kv Aurangabad and Dhule II will be in service
71	454	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Only AR required in Non Auto work to be carried out on Dhule-BBLR Ckt 1	6/6/2023	08:00	6/7/2023	18:00	Only AR required in Non Auto
72	455	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-1	C	Under MTAMC Project work, Main-II Dist Protin relay replacement work	6/6/2023	08:00	6/7/2023	20:00	Under MTAMC Project work, Main-II Dist Protin relay replacement work
73	527	PLANNED	OCC_567	MEGPTCL	765KV-AKOLA (2)-KORADI-II-I L/R@ KORADI- II - 765KV	D	As per CEA guideline within six month reactor changeover activity, spare reactor taken into service in place of B Ph reactor.	6/7/2023	08:00	6/7/2023	13:00	Changeover from spare reactor to B-Phase Reactor on dated 17.01.2023

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
74	528	PLANNED	OCC_567	MSETCL	HVDC 400KV TIE BAY CHANDRAPUR (Element not found)	D	To carry out CT tan delta which is under monitoring due increase in tan delta of Tie Bay Y Phase CT at HVDC Terminal Station, Chandrapur	6/7/2023	08:00	6/7/2023	13:00	Both Pole will be in service with 1500 MW Capacity without Tie Bay in service
75	529	PLANNED	OCC_567	MSETCL	220KV-TILLARI-MONA-1	D	Maintenance work	6/7/2023	09:00	6/7/2023	17:00	The said work is very important
76	530	PLANNED	OCC_567	MSETCL	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc	6/7/2023	09:00	6/7/2023	17:00	-
77	531	PLANNED	OCC_567	MSETCL	220KV-PANDURNA-KALMESHWAR-1	D	Routine Maint. Work	6/7/2023	09:00	6/7/2023	18:00	NA
78	532	PLANNED	OCC_567	MSETCL	220KV-PARLI-M-OSMANABAD-M-1	D	LINE/ s/s maintenance	6/7/2023	09:00	6/7/2023	18:00	-
79	533	PLANNED	OCC_567	MSETCL	132KV-PENCH-KANHAN-1	D	Routine Maint. Work	6/7/2023	09:00	6/7/2023	18:00	NA
80	534	PLANNED	OCC_567	MSETCL	220KV-SOLAPUR-JEUR-1	D	Outage is required for Quarterly Maintenance	6/7/2023	10:00	6/7/2023	17:00	Quarterly Maintenance
81	535	PLANNED	OCC_567	MSETCL	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	6/7/2023	10:00	6/7/2023	18:00	NA
82	537	PLANNED	OCC_567	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	D	PRESUMMER PREPAREDNESS WORK AND INSUALTOR REPLACEMENT WORK. A/R TO BE KEPT OFF IN CKT # 2 AND DIA TO BE KEPT OPEN AT BOTH ENDS.	6/7/2023	08:00	6/8/2023	19:00	PG-WR2-RHQ AM
83	538	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and cold line washing	6/7/2023	09:00	6/8/2023	19:00	Load will manage on 400KV lamboti - PGCIL line
84	540	PLANNED	OCC_567	MSETCL	400KV/220KV PADGHE-ICT-4 HV SIDE ON TBC	C	1) CB mechanism Overhauling work of HV CB 2)A & B bus PG isolator maint work 3) 600MVA ICT -4 in service through TBC on HV side	6/7/2023	07:00	6/10/2023	22:00	1) Weather Condition should be clear 2) Agency will be present on site
85	554	PLANNED	OCC_567	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	For Taking Oil sample after first month of charging of 414 R & B Phase CT at Kudus SS.	6/8/2023	08:00	6/8/2023	12:00	-
86	595	PLANNED	OCC_567	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	6/8/2023	08:00	6/8/2023	17:00	Line will be charged through Tie CB 428.
87	596	PLANNED	OCC_567	MSETCL	Pole-1 Non base AC filter Z4 (80 MVAR) @Chandrapur HVDC (Element not found in software)	D	To carry out DCRM & Timing of WA Z11 Q3 Breaker	6/8/2023	08:00	6/8/2023	18:00	Both Pole will be in service with 1500 MW Capacity & Pole II Z4 will be in Service as per System requirement
88	597	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	1) Maintenance work of Line. 2) Line bay equipment maintenance work at 220kv Pusad Substation.	6/8/2023	08:00	6/8/2023	18:00	-
89	599	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 2. During Outage period 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.	6/8/2023	09:00	6/8/2023	15:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.
90	600	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-1	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 1. During Outage period 400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.	6/8/2023	09:00	6/8/2023	15:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.
91	601	PLANNED	OCC_567	MSETCL	400KV-LONIKHAND-CHAKAN-1	D	Routine line and bay Maintenance and DT.	6/8/2023	10:00	6/8/2023	18:00	-
92	608	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance and Insulator cleaning work	6/8/2023	08:00	6/9/2023	18:00	400kv Ektuni ckt I&II,400KV Bhussawal,400kv Aurangabad and Dhule I will be in service
93	609	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Only AR will be in Non Auto work to be carry out on Dhule-BBLR ckt 2	6/8/2023	08:00	6/9/2023	18:00	Only AR will be in Non Auto
94	614	PLANNED	OCC_567	POWERGRID_WR1	PADGHE-PG - 400KV - BUS 2	C	Interconnection of 400 KV Extension Bus with the existing Bus 1 and HV testing at Padghe GIS.(New Construction works)	6/8/2023	08:00	6/12/2023	18:00	-
95	616	Planned	OCC_567	MSETCL	400KV-CHANDRAPUR-II-NANDED-2	D	For PID Work, Shifting of auto reclose switch to non auto mode.	6/8/2023	08:00	6/30/2023	18:00	-
96	622	PLANNED	OCC_567	NCA	400KV-SSP-DHULE-MS-1	D	Preventive & switchyard maintenance work	6/9/2023	07:00	6/9/2023	18:00	A/R swtch of 400KV-SSP-DHULE-MS-2 line to be put on Non Auto mode.
97	625	PLANNED	OCC_567	POWERGRID_WR1	220KV-PARLI-M-OSMANABAD-M-1	D	For AMP	6/9/2023	07:00	6/9/2023	18:00	-
98	644	PLANNED	OCC_567	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	CT Replacement Work	6/9/2023	08:00	6/9/2023	18:00	-
99	673	PLANNED	OCC_567	MSETCL	HVDC 400KV POLE I CONVERTER BAY @ CHANDRAPUR (Element not found)	D	To carry out CT tan delta which is under monitoring due increase in tan delta of Pole I Converter bay R Ph CT	6/9/2023	08:00	6/9/2023	13:00	Both Pole will be in service through Tie Bay with 950 MW capacity restriction due to constraint from 400 kV OCR. Chandrapur as only HVDC Ckt II will be available
100	675	PLANNED	OCC_567	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	6/9/2023	08:00	6/9/2023	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
101	677	PLANNED	OCC_567	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	D	PRESUMMER PREPAREDNESS WORK AND INSUALTOR REPLACEMENT WORK. A/R TO BE KEPT OFF IN CKT # 1 AND DIA TO BE KEPT OPEN AT BOTH ENDS.	6/9/2023	08:00	6/10/2023	19:00	PG-WR2-RHQ AM
102	679	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	C	Under MTAMC Project work, Main-II Dist Protn relay replacement work	6/9/2023	08:00	6/10/2023	20:00	Under MTAMC Project work, Main-II Dist Protn relay replacement work
103	681	PLANNED	OCC_567	MSETCL	220KV-TARAPUR 1-2-BORIVALI-1	D	For the replacement of old hardwares at various critical locations. Simultaneously outage is required on 220KV Borivali-PGCIL for the same work & also both lines are on same M/C Tower.	6/9/2023	09:00	6/11/2023	18:00	Simultaneously outage is required on 220KV Borivali-PGCIL for the same work & also both lines are on same M/C Tower.
104	682	PLANNED	OCC_567	MSETCL	220KV-BOISAR-BORIVALI-1	D	For the replacement of old hardwares at various critical locations. Simultaneously outage is required on 220KV Borivali-Tarapur for the same work & also both lines are on same M/C Tower.	6/9/2023	09:00	6/11/2023	18:00	Simultaneously outage is required on 220KV Borivali-Tarapur for the same work & also both lines are on same M/C Tower.
105	684	PLANNED	OCC_567	MSETCL	400KV-KALWA-PUNE-PG-1	D	1. Replacement of conductor in span between loc. No. 33 - 34, 2. Replacement of disc type insulator with long rod insulators.	6/9/2023	08:00	6/12/2023	18:00	-
106	688	PLANNED	OCC_567	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	C	Stringing Work for realignment in Bullet Train Diversion.Dia to be kept open at both ends.Simultaneous outage of 400KV Tarapur-Boisar # 1& 2 is required	6/9/2023	08:00	6/16/2023	19:00	PG-WR2-BOISAR
107	689	PLANNED	OCC_567	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	C	Stringing Work for realignment in Bullet Train Diversion.Dia to be kept open at both ends.Simultaneous outage of 400KV Tarapur-Boisar # 1& 2 is required	6/9/2023	08:00	6/16/2023	19:00	PG-WR2-BOISAR
108	693	PLANNED	OCC_567	NCA	400KV-SSP-DHULE-MS-2	D	Preventive & switchyard maintenance work	6/10/2023	07:00	6/10/2023	18:00	A/R swtch of 400KV-SSP-DHULE-MS-1 line to be put on Non Auto mode.
109	703	PLANNED	OCC_567	POWERGRID_WR1	MAIN BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For CT Oil Level and Bellows Check Work	6/10/2023	08:00	6/10/2023	18:00	-
110	712	PLANNED	OCC_567	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP WORKS. ICT WILL REMAIN IN SERVICE THROUGH TBC BAY	6/10/2023	09:00	6/10/2023	17:30	PG-WR2-BOISAR
111	730	PLANNED	OCC_567	MSETCL	400KV-KARAD-NEW KOYNA-2	D	PID Faulty disc insulator replacement work & Cold line washing work	6/10/2023	08:00	6/10/2023	17:00	PID Faulty disc insulator replacement work & Cold line washing work

Sr.No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
112	731	PLANNED	OCC_567	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	6/10/2023	08:00	6/10/2023	17:00	Line will be charged through Main CB 429.
113	733	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work:Quarterly bay maintenance work .	6/10/2023	08:00	6/11/2023	18:00	400kv Padghe 1 will be in in service
114	740	PLANNED	OCC_567	POWERGRID_WR1	765KV-PUNE-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samidhi Express Highway.(New Construction works)	6/10/2023	07:00	6/30/2023	18:00	
115	741	PLANNED	OCC_567	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samidhi Express Highway.(New Construction works)	6/10/2023	07:00	6/30/2023	18:00	
116	742	PLANNED	OCC_567	BDTCL - INDIGRID	TIE BAY - 400KV-DHULE-DHULE-MS-2 AND 765KV400KV DHULE-ICT-1 at DHULE - 400KV	D	Equipment annual maintenance & Testing	6/10/2023	09:00	6/10/2023	18:00	
117	46	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-2	D	(1) Reactor testing work. (2) Bay maintenance work.	6/11/2023	09:00	6/11/2023	18:00	-
118	753	PLANNED	OCC_567	MSETCL	220KV-BOISAR-BOISAR-M-3	D	1) Insulator String replacement Pilot -2nos. & Tension-2nos. 2) 220KV PGCIL Line no.03 bay A-Bus Iso Alignment work (not getting close).	6/11/2023	08:00	6/11/2023	15:00	220kv A-bus outage is required to replace insulator strings which identified in PID testing.
119	754	PLANNED	OCC_567	MSETCL	BOISAR-M - 220KV - BUS 1	D	1) Insulator String replacement Pilot -2nos. & Tension-2nos. 2) 220KV PGCIL Line no.03 bay A-Bus Iso Alignment work (not getting close).	6/11/2023	08:00	6/11/2023	15:00	220kv A-bus outage is required to replace insulator strings which identified in PID testing.
120	755	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-2	D	PID faulty insulator strings replacement	6/11/2023	08:00	6/11/2023	18:00	-
121	756	PLANNED	OCC_567	MSETCL	400KV-KALWA-PADGHE-1	D	1) Bay Maint work 2) diagnostic Testing work 3) Replacement of Over voltage relay 4)Replacement of CT with new Ratio of 3000/1A 5) Replacement of 29C Bus PG isolator under LES scheme	6/11/2023	09:00	6/11/2023	22:00	1) weather condition should be clear 2) agency will be present on site .
122	757	PLANNED	OCC_567	MSETCL	220KV-TALEGAON-PUNE-PG-1	D	Half yearly maintenance	6/11/2023	10:00	6/11/2023	18:00	-
123	760	PLANNED	OCC_567	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	C	To attend the sag correction in tower no. 534, to stop the deforming of tower members in the first section.	6/11/2023	08:00	6/12/2023	18:00	Line Outage
124	761	PLANNED	OCC_567	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	C	To attend the sag correction in tower no. 534 of 765KV-AKOLA (2)- KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	6/11/2023	08:00	6/12/2023	18:00	Auto reclosed mode off
125	762	PLANNED	OCC_567	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	C	To attend the sag correction in tower no. 534 of 765KV-AKOLA (2)- KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	6/11/2023	08:00	6/12/2023	18:00	Auto reclosed mode off
126	763	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 2. During Outage period 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.	6/11/2023	09:00	6/19/2023	15:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.
127	765	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-1	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 1. During Outage period 400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.	6/11/2023	09:00	6/30/2023	15:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.
128	810	PLANNED	OCC_567	MSETCL	400KV-RGPPL-NEW KOYNA-1	D	Diagnostic testing & Relay testing work , Routine maint. Work & Pre- Monsoon maintenance	6/12/2023	08:00	6/12/2023	17:00	----
129	811	PLANNED	OCC_567	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Changeover of Spare phase with B-Phase Reactor at Akola(2) SS as per CEA guideline	6/12/2023	09:00	6/12/2023	15:00	20.01.2023 Changeover from B-Phase to Spare Reactor.
130	812	PLANNED	OCC_567	MSETCL	KORADI - 400KV B/R 1	D	Bushings TAN Delta	6/12/2023	09:00	6/12/2023	18:00	Outage time may be varied as per site & weather condition
131	821	PLANNED	OCC_567	APML-ADANI	MAIN BAY - 400KV-TIRODA-WARORA-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	C	For line main bay breaker arcing contact inspection and testing work	6/12/2023	09:00	6/14/2023	18:00	Bay Outage
132	824	PLANNED	OCC_567	MSETCL	400KV-LONIKHAND-PUNE-PG-1 ON TBC	C	400KV CB O/H work by shifting on TBC and 29-A PG Isolator mechanism box replacement and trials. Line will be in service. Load will be shifted on TBC	6/12/2023	08:00	6/14/2023	23:30	Line will be in service. Load will be shifted on TBC
133	825	PLANNED	OCC_567	MSETCL	400KV-JEJURI-KARAD-1 ON TBC	C	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad	6/12/2023	09:00	6/15/2023	18:00	400 kv Jeguri-Karad line is charged through online TBC
134	826	PLANNED	OCC_567	MSETCL	TIE BAY OF 400KV-TAPTHITHANDA-EKTUNI-2 AND FUTURE @TAPTHITHANDA - 400KV	C	Circuit Breaker Overhauling by M/s CGL	6/12/2023	11:00	6/15/2023	18:00	C outage required for CB mechanism overhauling work. No load or line affected due to one and half breaker bus system.
135	827	PLANNED	OCC_567	MSETCL	400KV-KARJAT-LONIKHAND-II-2	D	PID testing of Insulator Strings	6/12/2023	08:00	6/16/2023	18:00	-
136	829	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-2	D	PID work	6/12/2023	08:00	6/17/2023	18:00	-
137	836	PLANNED	OCC_567	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	Khandwa-2 Line & LR AMP. AR to be kept in non auto mode for 400KV-KHANDWA-DHULE-MS-1	6/13/2023	07:00	6/13/2023	18:00	
138	837	PLANNED	OCC_567	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2 L/R@DHULE- MS-400KV	D	Khandwa-2 Line & LR AMP	6/13/2023	07:00	6/13/2023	18:00	
139	839	PLANNED	OCC_567	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element.	6/13/2023	07:00	6/13/2023	18:00	
140	840	PLANNED	OCC_567	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element.	6/13/2023	07:00	6/13/2023	18:00	
141	841	PLANNED	OCC_567	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	6/13/2023	07:00	6/13/2023	18:00	
142	842	PLANNED	OCC_567	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-2	D	For Replacement of Old BHEL Insulators on gantries of element.	6/13/2023	07:00	6/13/2023	18:00	
143	893	PLANNED	OCC_567	MSETCL	400KV-RGPPL-NAGOTHANE-1	D	cold washing & String Replacement work	6/13/2023	08:00	6/13/2023	18:00	---

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
144	894	PLANNED	OCC_567	MSETCL	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works. During 400KV Busbar Protection Relay testing works Outage . (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays ,respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays tripping etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e. 400KV Adani ckt. 1 & 2 ,PGCIL-Nagari,IEPL and 400KV Bus Reactor , remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e. 400KV Cpur-II dkt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bay CBs/Isolator will be isolated /opened during the testing works. (6) On completion of 400KV Bus bar Relay testing works ,normalcy of all 400KV Bays is ensured /restored and 400KV Busbar protection will be normalized.	6/13/2023	08:00	6/13/2023	18:00	During 400KV Busbar Protection Relay testing works Outage . (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays ,respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays tripping etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e. 400KV Adani ckt. 1 & 2 ,PGCIL-Nagari,IEPL and 400KV Bus Reactor , remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e. 400KV Cpur-II dkt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the said outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bay CBs/Isolator will be isolated /opened during the testing works. (6) On completion of 400KV Bus bar Relay testing works ,normalcy of all 400KV Bays is ensured /restored and 400KV Busbar protection will be normalized.
145	895	PLANNED	OCC_567	MSETCL	WARORA - 400KV - BUS 2	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works. During 400KV Busbar Protection Relay testing works Outage . (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays ,respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays tripping etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e. 400KV Adani ckt. 1 & 2 ,PGCIL-Nagari,IEPL and 400KV Bus Reactor , remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e. 400KV Cpur-II dkt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bay CBs/Isolator will be isolated /opened during the testing works. (6) On completion of 400KV Bus bar Relay testing works ,normalcy of all 400KV Bays is ensured /restored and 400KV Busbar protection will be normalized.	6/13/2023	08:00	6/13/2023	18:00	During 400KV Busbar Protection Relay testing works Outage . (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays ,respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays tripping etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e. 400KV Adani ckt. 1 & 2 ,PGCIL-Nagari,IEPL and 400KV Bus Reactor , remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e. 400KV Cpur-II dkt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened/ during the said outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bay CBs/Isolator will be isolated /opened during the testing works. (6) On completion of 400KV Bus bar Relay testing works ,normalcy of all 400KV Bays is ensured /restored and 400KV Busbar protection will be normalized.
146	897	PLANNED	OCC_567	MSETCL	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work .	6/13/2023	09:00	6/13/2023	17:00	400KV WARORA-IEPL Line is in dkt
147	902	PLANNED	OCC_567	MSETCL	400KV-KHANDWA-DHULE-MS-1	C	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A &B replacement work	6/13/2023	08:00	6/14/2023	20:00	Main-I Dist Protn, REF & Master trip relay Gr-A &B replacement work under MTAMC project work
148	916	PLANNED	OCC_567	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-1	D	765KV Aurangabad-Solapur1 line AR to be kept in Non-Auto Mode.	6/14/2023	07:00	6/14/2023	18:00	
149	927	PLANNED	OCC_567	POWERGRID_WR1	MAIN BAY - 220KV-PARLI-OSMANABAD-M-1 AND PARLI - 220KV - BUS 1 at PARLI - 220KV	D	For AMP	6/14/2023	08:00	6/14/2023	18:00	
150	928	PLANNED	OCC_567	POWERGRID_WR1	MAIN BAY - 220KV-PUNE-PG-JURSE-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	CB Operating Mechanism Box Lever replacement	6/14/2023	08:00	6/14/2023	18:00	
151	941	PLANNED	OCC_567	MEGPTCL	765KV-TIRODA-KORADI-III-2 L/R@ KORADI-III - 765KV	D	As per CEA guideline within six month reactor changeover activity, Y-Phase reactor taken into service in place of spare reactor.	6/14/2023	08:00	6/14/2023	13:00	Change over from Y-Phase Reactor to Spare Reactor on dated 24.01.2023
152	942	PLANNED	OCC_567	MSETCL	400KV-RGPPL-NAGOTHANE-2	D	cold washing & String Replacement work.	6/14/2023	08:00	6/14/2023	18:00	---
153	944	PLANNED	OCC_567	MSETCL	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work. For cold washing of 220 kV line bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments at 220KV Mahalaxmi ss.	6/14/2023	09:00	6/14/2023	17:00	The said work is very important. During same period outage is proposed on 220KV Hakami line & 220KV Bus at 220KV Mahalaxmi ss
154	945	PLANNED	OCC_567	MSETCL	220KV-PARLI-OSMANABAD-M-1	D	Line / s/s Maintenance	6/14/2023	09:00	6/14/2023	17:30	-
155	946	PLANNED	OCC_567	MSETCL	132KV-MANSAR-MS-KANHAN-1	D	Routine Maint. Work	6/14/2023	09:00	6/14/2023	18:00	NA
156	947	PLANNED	OCC_567	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening and cold line washing	6/14/2023	09:00	6/14/2023	19:00	Load will manage on 400KV lamboti - parli line
157	86	PLANNED	OCC_567	POWERGRID_WR1	400KV-PARLI-M-PARLI-NEW-1	C	HTLS conductor replacement and For ongoing project of Upgradation of 400KV Line Bays (02 Nos) of Part (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS'. AR to ne kept in non Auto mode for 400KV-PARLI-M-PARLI-2	6/15/2023	07:00	6/30/2023	17:30	
158	964	PLANNED	OCC_567	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-2	D	Mechanical interlock fitting & ISO Copper contact cleaning work	6/15/2023	07:00	6/15/2023	12:30	
159	971	PLANNED	OCC_567	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	AMP of Line Equipment	6/15/2023	07:00	6/15/2023	18:00	
160	972	PLANNED	OCC_567	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	6/15/2023	07:00	6/15/2023	18:00	
161	973	PLANNED	OCC_567	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	6/15/2023	07:00	6/15/2023	18:00	
162	974	PLANNED	OCC_567	POWERGRID_WR1	220KV-SOLAPUR-JEUR-1	D	Line terminal equipments AMP at 765KV Solapur Substation	6/15/2023	07:00	6/15/2023	18:00	
163	1005	PLANNED	OCC_567	MSETCL	400KV-RGPPL-NEW KOYNA-2	D	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	6/15/2023	08:00	6/15/2023	17:00	---
164	1006	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance and Insulator cleaning work	6/15/2023	08:00	6/15/2023	18:00	400KV Ektuni ckt I&II,400KV Bhussawal,400kv Aurangabad and Dhule II will be in service
165	1007	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Only AR will be in Non Auto work to be carry out on Dhule-BBLR 1	6/15/2023	08:00	6/15/2023	18:00	Only AR will be in Non Auto
166	1008	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	1) Maintenance work of Line. 2) Line bay equipment maintenance work at 220KV Pusad Substation.	6/15/2023	08:00	6/15/2023	18:00	.
167	1010	PLANNED	OCC_567	MSETCL	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	6/15/2023	09:00	6/15/2023	18:00	400 KV WARORA - DEOLI 2 Line is in dkt
168	1019	PLANNED	OCC_567	APML-ADANI	MAIN BAY - 400KV-TIRODA-WARORA-2 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	C	For line main bay breaker arcing contact inspection and testing work	6/15/2023	09:00	6/17/2023	18:00	Bay Outage
169	685	PLANNED	OCC_567	MSETCL	400KV-KALWA-PADGHE-2	C	To complete balance work of replacement of existing conductor by HTLS conductor.	6/16/2023	09:00	6/19/2023	06:00	To complete balance work of replacement of existing conductor by HTLS conductor.
170	1030	PLANNED	OCC_567	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-2	D	For AMP	6/16/2023	07:00	6/16/2023	18:00	
171	1032	PLANNED	OCC_567	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	D	AMP WORK	6/16/2023	07:00	6/16/2023	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
172	1034	PLANNED	OCC_567	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	6/16/2023	07:00	6/16/2023	18:00	
173	1035	PLANNED	OCC_567	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	6/16/2023	07:00	6/16/2023	18:00	
174	1046	PLANNED	OCC_567	POWERGRID_WR1	TIE BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR GIS - 400KV B/R 1 at Kolhapur GIS - 400KV	D	Bay AMP	6/16/2023	08:00	6/16/2023	18:00	
175	1053	PLANNED	OCC_567	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	For arresting oil leakage . Dia to be kept open at both sides	6/16/2023	09:00	6/16/2023	17:30	PG-WR2-BOISAR
176	1062	PLANNED	OCC_567	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	D	Changeover of Spare phase with B-ph ICT at Akola(2) SS as per CEA guideline	6/16/2023	08:00	6/16/2023	18:00	30.12.2022 Changeover from B-Phase ICT to Spare ICT.
177	1063	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance and Insulator cleaning work	6/16/2023	08:00	6/16/2023	18:00	400KV Ektuni ckt I&II,400kV Bhusawal,400kv Aurangabad and Dhule I will be in service
178	1064	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Only AR will be in Non Auto work to be carry out on Dhule--BBLR ckt 2.	6/16/2023	08:00	6/16/2023	18:00	Only AR will be in Non Auto
179	1066	PLANNED	OCC_567	MSETCL	AURANGABAD-M (WALUJ) - 400KV - BUS 1	D	Diagnostic testing & routine maintenance work	6/16/2023	10:00	6/16/2023	18:00	Outage on 400KV Main Bus I @Waluj
180	1073	PLANNED	OCC_567	MSETCL	400KV-KHANDWA-DHULE-MS-2	C	MTAMC Project work Main+ Dist Protn, REF & Master trip relay Gr-A &B relay replacement work	6/16/2023	08:00	6/17/2023	20:00	MTAMC Project work Main+ Dist Protn, REF & Master trip relay Gr-A &B relay replacement work
181	1074	PLANNED	OCC_567	MSETCL	400KV-KALWA-PADGHE-2	C	To complete balance HTLS conversion work.	6/16/2023	09:00	6/19/2023	06:00	To complete balance HTLS conversion work.
182	1077	PLANNED	OCC_567	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	PID Testing of Insulators Auto-Reclose function to be out of service.	6/16/2023	09:00	6/25/2023	17:00	PID Testing of Insulators Auto-Reclose function to be out of service.
183	1079	PLANNED	OCC_567	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-2 AND PARLI-M - 400KV - BUS 1 at PARLI-M - 400KV	C	For CB foundation work.Line will be in Service through TSC. For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS"	6/16/2023	08:00	6/30/2023	17:30	
184	943	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-1	D	LBB relay testing,Quarterly bay maintenance work	6/17/2023	08:00	6/17/2023	18:00	400KV Padghe I will be in in service
185	1009	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-1	D	Hardware Tightening & Fitting Work	6/17/2023	09:00	6/17/2023	18:00	-
186	1097	PLANNED	OCC_567	POWERGRID_WR2	220KV-BOISAR-PANCHALI-1	D	AMP works	6/17/2023	09:00	6/17/2023	17:30	PG-WR2-BOISAR
187	1111	PLANNED	OCC_567	MSETCL	400KV-KALWA-PUNE-PG-1	D	Routine Maintenance & Insulator cleaning work	6/17/2023	08:00	6/17/2023	18:00	Routine Maintenance & Insulator cleaning work.
188	1113	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	6/17/2023	08:00	6/18/2023	18:00	400KV Padghe I will be in in service
189	1114	PLANNED	OCC_567	MEGPTCL	765KV-TIRODA-KORADI-III-1	D	Installation of Bird Flight Divertor- In reference to the Hon�ble High Court, Nagpur Order dated 05th January 2022	6/17/2023	08:00	6/19/2023	18:00	Line Outage
190	1119	PLANNED	OCC_567	BDTCL - INDIGRID	DHULE - 400KV - BUS 1	D	Equipment annual maintenance & Testing	6/17/2023	09:00	6/18/2023	18:00	
191	47	PLANNED	OCC_567	MSETCL	400KV-LONIKHAND-PUNE-PG-1	D	1. PID detected weak strings replacement. 2. Routine maintenance activities	6/18/2023	10:00	6/18/2023	18:00	-
192	1127	PLANNED	OCC_567	MSETCL	BOISAR-M - 220KV - BUS 2	D	1) Insulator string replacement. Pilot -Ino & Tension-Ino.	6/18/2023	08:00	6/18/2023	14:00	1) Insulator string replacement. Pilot -Ino & Tension-Ino.
193	1129	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-1	D	Hardware tightening and cold line washing	6/18/2023	09:00	6/18/2023	19:00	Load will manage on 400KV Parli-karjat ckt 2
194	1130	PLANNED	OCC_567	MSETCL	400KV-KALWA-PADGHE-2	D	1) Bay Maint work 2) Diagnostic Testing work 3) Replacement of Over voltage relay 4)Replacement of CT with new Ratio of 3000/1A 5)Replacement of 29C Bus PG isolator under LES scheme	6/18/2023	09:00	6/18/2023	21:00	1) weather condition should be clear 2) agency will be present on site
195	1131	PLANNED	OCC_567	MSETCL	400KV-CHAKAN-PUNE-PG-1	D	1. Chemical cleaning of insulator strings. 2. PID detected weak strings replacement work. Routine Maintenance. And DT Fixing of SF6 gauge to a CB pole	6/18/2023	10:00	6/18/2023	18:00	-
196	1132	PLANNED	OCC_567	MSETCL	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance	6/18/2023	10:00	6/18/2023	18:00	-
197	1134	PLANNED	OCC_567	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	PID Scanning of insulator strings	6/18/2023	08:00	6/24/2023	18:00	-
198	1135	PLANNED	OCC_567	POWERGRID_WR2	400KV-PADGHE-BOISAR-1	C	Tower Erection and Stringing work For Realignment in Bullet Train Diverison. Simultaneous outage of 400KV Vapi-Boisar and 400KV Padghe-Boisar is required and Dia to be kept open at both ends.	6/18/2023	08:00	6/25/2023	19:00	PG-WR2-BOISAR
199	1136	PLANNED	OCC_567	POWERGRID_WR2	400KV-VAPI-BOISAR-1	C	Tower Erection and Stringing work For Realignment in Bullet Train Diverison. Simultaneous outage of 400KV Vapi-Boisar and 400KV Padghe-Boisar is required and Dia to be kept open at both ends.	6/18/2023	08:00	6/25/2023	19:00	PG-WR2-BOISAR
200	1166	PLANNED	OCC_567	MSETCL	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Badnera S/s	6/19/2023	09:00	6/19/2023	15:00	/
201	1167	PLANNED	OCC_567	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic testing & Maintenance work	6/19/2023	10:00	6/19/2023	17:00	Load will be managed on 400KV Alkud Solapur line
202	1168	PLANNED	OCC_567	MSETCL	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Diagnostic testing & Maintenance work	6/19/2023	10:00	6/19/2023	17:00	--
203	1169	PLANNED	OCC_567	MSETCL	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	6/19/2023	10:00	6/19/2023	17:00	--
204	1170	PLANNED	OCC_567	MSETCL	BABLESHWAR - 400KV B/R 1	D	LBB relay testing	6/19/2023	10:00	6/19/2023	18:00	-
205	1174	PLANNED	OCC_567	MSETCL	BUS COUPLER BAY - KARAD - 400KV - BUS 1 AND KARAD - 400KV - BUS 2	C	Outage for shifting of Relay panel of 400 KV bus coupler due to replacement of 400 KV Solapur & Lonikand ckt relay panel.For commissioning of 400 KV Solapur & Lonikand ckt shifting of relay panel of Buscoupler is necessary.	6/19/2023	09:00	6/20/2023	18:00	02 days are required for complete shifting of 400 KV buscoupler relay panel.
206	1180	PLANNED	OCC_567	MSETCL	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-2 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV	C	Circuit Breaker Overhauling by M/s CGL	6/19/2023	11:00	6/22/2023	18:00	C outage required for CB mechanism overhauling work. No load or line affected due to one and half breaker bus system. Load will be on Tie bay 411.
207	1182	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	PID work. 400 KV Dhule--BBLR 1 & 2 (Simultaneously)	6/19/2023	08:00	6/24/2023	18:00	400 KV Dhule--BBLR 1 & 2 (Simultaneously)
208	1183	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	PID work. 400 KV Dhule--BBLR 1 & 2 (Simultaneously)	6/19/2023	08:00	6/24/2023	18:00	400 KV Dhule--BBLR 1 & 2 (Simultaneously)
209	1220	PLANNED	OCC_567	GETCO	220KV-TARAPUR 1&2-BHILAD-1	C	PMM work	6/20/2023	09:00	6/20/2023	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
210	1226	PLANNED	OCC_567	MSETCL	400KV-WARORA-CHANDRAPU-II-1	D	For replacement of Faulty PID disc insulator if found in PID testing	6/20/2023	08:00	6/20/2023	17:00	replacement of insulator
211	1231	PLANNED	OCC_567	MSETCL	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND EKTUNI - 400KV - BUS 1 @EKTUNI - 400KV at EKTUNI - 400KV	D	Diagnostic Testing of CB, CT & Routine Maintenance	6/20/2023	10:30	6/20/2023	18:00	400KV Ektuni-ThaptiTanda Ckt-I will be in service through its TIE (405) Bay and Main Bus-II
212	1232	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-1	D	For Replacement of Missing Hardware & Cold line washing of PID Critical Strings. During Outage 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.	6/20/2023	08:00	6/21/2023	18:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.
213	1233	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance and Insulator cleaning work	6/20/2023	08:00	6/21/2023	18:00	400KV Ektuni ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule II will be in in service
214	1234	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Only AR will be in Non Auto work to be carry out on dhule-bblr 1	6/20/2023	08:00	6/21/2023	18:00	Only AR will be in Non Auto
215	1235	PLANNED	OCC_567	MSETCL	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	6/20/2023	08:00	6/21/2023	18:00	NA
216	1247	PLANNED	OCC_567	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2	D	409L AMP at Aurangabad & 404L AMP at Waluj and BHEL Insulator Replacement work. AR to be kept in non Auto mode for 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1	6/21/2023	07:00	6/21/2023	18:00	
217	1273	PLANNED	OCC_567	MSETCL	400KV-WARORA-CHANDRAPU-II-2	D	for replacement of Faulty PID disc insulator if found in PID testing	6/21/2023	08:00	6/21/2023	17:00	replacement of disc insulator
218	1274	PLANNED	OCC_567	MSETCL	400KV/220KV KARAD-ICT-2	D	Shifting of Y ph Hanger assembly of 400 kv PG Isolator of Bus-II 400/220/33 kv ICT-II bay & fixing of PA rods to damaged conductors near B ph hanger assembly with the help of Hot line unit Ogalewadi	6/21/2023	08:00	6/21/2023	18:00	Hot line Unit Ogalewadi is available on 21.06.2023
219	1275	PLANNED	OCC_567	MSETCL	KARAD - 400KV - BUS 2	D	Shifting of Y ph Hanger assembly of 400 kv PG Isolator of Bus-II 400/220/33 kv ICT-II bay & fixing of PA rods to damaged conductors near B ph hanger assembly with the help of Hot line unit Ogalewadi	6/21/2023	08:00	6/21/2023	18:00	Hot line unit,Ogalewadi is available on 21.06.2023
220	1277	PLANNED	OCC_567	MSETCL	220KV-SOLAPUR-JEUR-1	D	Hardware tightening and cold line washing	6/21/2023	09:00	6/21/2023	17:00	Load will manage on 220KV tembhurni - jeur line
221	1278	PLANNED	OCC_567	MSETCL	220KV-PARLI-PARLI-M-2	D	Line, s/s Maintenance	6/21/2023	09:00	6/21/2023	17:30	-
222	1279	PLANNED	OCC_567	MSETCL	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	6/21/2023	09:00	6/21/2023	18:00	NA
223	1304	PLANNED	OCC_567	POWERGRID_WR2	400KV-VAPI-BOISAR-1	C	For Tie LBB retrofitting bay 408. Simultaneous outage of 400KV Vapi Boisar # 1 and 400/220KV ICT # 1 is required and Dia to be kept open at both ends/sides	6/22/2023	08:00	6/22/2023	18:00	PG-WR2-VAPI
224	1326	PLANNED	OCC_567	MEGPTCL	KORADI-III - 765KV B/R 1	D	As per CEA guideline within six month reactor changeover activity spare reactor to be taken into service in place of B-Phase reactor.	6/22/2023	08:00	6/22/2023	13:00	Changeover from Spare Reactor to B-Phase Reactor on dated 06.01.2023
225	1327	PLANNED	OCC_567	MSETCL	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	6/22/2023	08:00	6/22/2023	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
226	1328	PLANNED	OCC_567	MSETCL	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV	D	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	6/22/2023	08:00	6/22/2023	17:00	---
227	1329	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	Maintenance work	6/22/2023	08:00	6/22/2023	18:00	.
228	1331	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 2. During Outage period 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.	6/22/2023	09:00	6/22/2023	15:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.
229	1332	PLANNED	OCC_567	MSETCL	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1	D	Diagnostic Testing of Circuit Breaker	6/22/2023	09:00	6/22/2023	18:00	240Mvar Bus Reactor will be in service through its TIE (712) Bay and Main Bus - II
230	1333	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	D	(1) Distance relay testing work (2) Bay maintenance work.	6/22/2023	09:00	6/22/2023	18:00	-
231	1334	PLANNED	OCC_567	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	D	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening	6/22/2023	10:00	6/22/2023	17:30	Koradi-II- Wardha(PG) Ckt. Will remain in service through Tie Bay 411
232	1337	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	Only AR will be in Non Auto Work to be carry out on Dhule-BBLR 2	6/22/2023	08:00	6/23/2023	18:00	Only AR will be in Non Auto
233	1338	PLANNED	OCC_567	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance and Insulator cleaning work,CVT Tan Delta	6/22/2023	08:00	6/23/2023	18:00	400KV Ektuni ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule I will be in in service
234	1339	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	6/22/2023	08:00	6/23/2023	18:00	NA
235	72	PLANNED	OCC_567	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	C	Stringing Work for realignment in Bullet Train Diversion.Dia to be kept open at both ends.Simultaneous outage of 400KV Tarapur-Padghe # 1& 2 is required	6/23/2023	08:00	6/30/2023	19:00	PG-WR2-BOISAR
236	73	PLANNED	OCC_567	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	C	Stringing Work for realignment in Bullet Train Diversion.Dia to be kept open at both ends.Simultaneous outage of 400KV Tarapur-Padghe # 1& 2 is required	6/23/2023	08:00	6/30/2023	19:00	PG-WR2-BOISAR
237	1031	Planned	OCC_567	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	D	AMP of Line Equipment and Oil Sampling of Line CT.	6/23/2023	07:00	6/23/2023	18:00	
238	1348	PLANNED	OCC_567	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	For Replacement of Old BHEL Insulators on gantries of element	6/23/2023	07:00	6/23/2023	13:00	
239	1350	PLANNED	OCC_567	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	AMP at Bhilai SS	6/23/2023	07:00	6/23/2023	17:30	
240	1353	PLANNED	OCC_567	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1	D	412L AMP at Aurangabad & 403L AMP at Waluj and BHEL Insulator Replacement work. AR to be kept in non Auto mode for 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2	6/23/2023	07:00	6/23/2023	18:00	
241	1384	PLANNED	OCC_567	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	For Replacement of Old BHEL Insulators on gantries of element	6/23/2023	13:15	6/23/2023	18:00	
242	1386	PLANNED	OCC_567	MSETCL	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1	D	Diagnostic Testing of Circuit Breaker	6/23/2023	09:00	6/23/2023	18:00	240Mvar Bus Reactor will be in service through its Main (711) Bay and Main Bus-II
243	1388	PLANNED	OCC_567	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	D	1) Bay Maint work 2) Diagnostic Testing work 3) MTAMC work	6/23/2023	09:00	6/23/2023	20:00	weather condition should be clear
244	1389	PLANNED	OCC_567	MSETCL	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	D	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening	6/23/2023	10:00	6/23/2023	17:30	Koradi-II- Wardha(PG) Ckt. Will remain in service through Main Bay 412
245	1390	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	D	For Replacement of Missing Hardware & Cold line washing of PID Critical Strings. During Outage 400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.	6/23/2023	08:00	6/24/2023	18:00	400 KV Dhule-SSNNL CKT 1 A/R switch will be kept on Non Auto mode.
246	1392	PLANNED	OCC_567	MSETCL	KHARGHAR - 400KV - BUS 1	C	1)Bus Extension Connection work along with charging of 2 nos of new 400KV Vikrol Line Bay/s at Kharghar(First time Charging). 2) For work of Damaged Quadraple conductor span replacement and Bus maintenance work.	6/23/2023	07:00	6/25/2023	18:00	Outage Required along with Bus coupler 1) All Lines & ICT's will be on B bus, load will be shifted via TBC. 2) First time Charging under 400 KV Vikrol receiving station and associated transmission lines for strengthening of

Sr.No.	OC/M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continu us	Reason	From	To	Remarks		
247	1393	PLANNED	OCC_567	MSETCL	400KV-KALWA-PADGHE-2	C	To complete balance HTLS conversion work.	6/23/2023	09:00	6/26/2023	06:00	To complete balance HTLS conversion work.
248	1419	PLANNED	OCC_567	MSETCL	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	D	400KV Bus Coupler 29-A & 29-B PG Isolator mechanism box replacement and trials. Also, DT Work & Bay Maintenance	6/24/2023	08:00	6/24/2023	23:30	-
249	1420	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	6/24/2023	08:00	6/25/2023	18:00	400KV Padghe 1 will be in in service
250	1421	PLANNED	OCC_567	POWERGRID_WR1	PADGHE-PG - 400KV - BUS 2	C	Link connection of 400 KV New Extension Bus with the existing Bus 2 and Charging of extension portion at Padghe GIS.	6/24/2023	08:00	6/26/2023	18:00	
251	1330	PLANNED	OCC_567	MSETCL	400KV-LONIKHAND-PUNE-PG-1	D	29-C PG Isolator mechanism box replacement and trials. Also, DT Work & Bay Maintenance	6/25/2023	08:00	6/25/2023	23:30	-
252	1424	PLANNED	OCC_567	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element	6/25/2023	07:00	6/25/2023	13:00	
253	1426	PLANNED	OCC_567	POWERGRID_WR1	WARDHA - 220KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element	6/25/2023	08:00	6/25/2023	18:00	
254	1429	PLANNED	OCC_567	WIPL	400KV-PARLI-SOLAPUR-2	D	Annual Maintenance of line.	6/25/2023	09:00	6/25/2023	18:00	Line outage
255	1430	PLANNED	OCC_567	WIPL	400KV-PARLI-SOLAPUR-1	D	AR disable for safety purpose. Doing annual maintenance of 400KV-PARLI-SOLAPUR-2	6/25/2023	09:00	6/25/2023	18:00	AR disable
256	1431	PLANNED	OCC_567	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element	6/25/2023	13:15	6/25/2023	18:00	
257	1432	PLANNED	OCC_567	MSETCL	400KV-KALWA-KHARGHAR-1	D	Routine Maintenance & Insulator cleaning work	6/25/2023	08:00	6/25/2023	18:00	Outage will be availed if other 400KV Line outages are deferred.
258	1433	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-2	D	Hardware lightning and cold line washing	6/25/2023	09:00	6/25/2023	17:00	Load will manage on 400KV Parli-karjat ckt1
259	1435	PLANNED	OCC_567	MEGPTCL	765KV-TIRODA-KORADI-III-2	D	Installation of Bird Flight Divertor- In reference to the Hon'ble High Court, Nagpur Order dated 05th January 2023	6/25/2023	08:00	6/26/2023	18:00	Line Outage
260	1438	PLANNED	OCC_567	MSETCL	400KV-SSP-DHULE-MS-2	D	For On line PID Work for 400 KV Dhule-SSNNL CKT 2. During Outage period 400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.	6/25/2023	09:00	6/30/2023	15:00	400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non Auto mode.
261	417	PLANNED	OCC_567	POWERGRID_WR2	220KV-TARAPUR 3&4-BOISAR-1	D	AMP WORKS	6/26/2023	09:00	6/26/2023	17:30	PG-WR2-BOISAR
262	1441	PLANNED	OCC_567	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element	6/26/2023	07:00	6/26/2023	13:00	
263	1442	PLANNED	OCC_567	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1	D	401AL AMP Work and For BHEL Insulator Replacement work	6/26/2023	07:00	6/26/2023	18:00	
264	1444	PLANNED	OCC_567	POWERGRID_WR1	400KV-DHARIWAL-PARLI-2	D	PRD Oil seepage arresting	6/26/2023	07:00	6/26/2023	18:00	
265	1445	PLANNED	OCC_567	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	6/26/2023	07:00	6/26/2023	18:00	
266	1446	PLANNED	OCC_567	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1 LIR@ SOLAPUR - 400KV	D	Line Reactor AMP works at 765kV Solapur Substation.	6/26/2023	07:00	6/26/2023	18:00	
267	1448	PLANNED	OCC_567	POWERGRID_WR2	400KV-KALA-VAPI-2	C	For Tie LBB retrofitting bay 417. Simultaneous outage of 400KV Vapi Kala # 2 and 400KV Vapi-Kakarapur # 2 is required and dia to be kept open at both ends.	6/26/2023	08:00	6/26/2023	18:00	PG-WR2-VAPI
268	1453	PLANNED	OCC_567	POWERGRID_WR1	AURANGABAD-M (WALUJ) - 400KV - BUS 1	D	For BHEL Insulator Replacement work	6/26/2023	08:00	6/26/2023	18:00	
269	1454	PLANNED	OCC_567	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element	6/26/2023	08:00	6/26/2023	18:00	
270	1456	PLANNED	OCC_567	POWERGRID_WR1	PARLI-M - 400KV - BUS 1	D	For dismantling of 89A Isolator of 400KV-PARLI-M-PARLI-2 For ongoing project of "Upgradation of 400KV Line Bays (02 Nos) of Parli (PG) & Ill at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS"	6/26/2023	08:00	6/26/2023	19:30	
271	1471	PLANNED	OCC_567	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element	6/26/2023	13:15	6/26/2023	18:00	
272	1473	PLANNED	OCC_567	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	6/26/2023	09:00	6/26/2023	17:00	The said work is very important
273	1477	PLANNED	OCC_567	MSETCL	KHARGHAR - 400KV - BUS 2	C	1) Bus Extension Connection work along with charging of 2 nos of new 400KV Vktroll Line Bay's at Kharghar(First time Charging) 2) For work of Damaged Quadraple conductor span replacement and Bus maintenance work.	6/26/2023	07:00	6/28/2023	18:00	Outage required along with Bus coupler 1) All Lines & ICT's will be on A bus, load will be shifted via TBC. 2) First time Charging under 400 KV
274	1480	PLANNED	OCC_567	POWERGRID_WR2	220KV-TARAPUR 3&4-BOISAR-1	C	Tower Erection and Stringing work For Realignment in Bullet Train Diversion. Dia to be kept open at both ends	6/26/2023	08:00	6/30/2023	19:00	PG-WR2-BOISAR
275	1387	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-2	D	Hardware Tightening & Fitting Work.	6/27/2023	09:00	6/27/2023	18:00	-
276	1517	PLANNED	OCC_567	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	6/27/2023	09:00	6/27/2023	17:00	The said work is very important
277	1519	PLANNED	OCC_567	MSETCL	TIE BAY - 400KV-TAPTHITHANDA-EKTUNI-1 AND 765KV/400KV EKTUNI-ICT-2	D	Diagnostic Testing of CB, CT & Routine Maintenance	6/27/2023	10:30	6/27/2023	18:00	400KV Ektuni-TapthiTanda Ckt-I will be in service through its Main (404) Bay and Main Bus -I
278	1536	PLANNED	OCC_567	POWERGRID_WR1	PARLI-M - 400KV - BUS 2	D	For dismantling of 89B Isolator of 400KV-PARLI-M-PARLI-2 For ongoing project of "Upgradation of 400KV Line Bays (02 Nos) of Parli (PG) & Ill at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS"	6/28/2023	08:00	6/28/2023	19:30	
279	1547	PLANNED	OCC_567	MEGPTCL	AKOLA (2) - 765KV B/R 1	D	Changeover of R-Ph Reactor with Spare Reactor at Akola(2) SS as per CEA guideline	6/28/2023	09:00	6/28/2023	15:00	07.01.2023 Changeover from Spare reactor to Y-ph reactor
280	1548	PLANNED	OCC_567	MSETCL	400KV-WARORA-CHANDRAPUR-II-2	D	Diagnostic testing and allied bay maintenance work	6/28/2023	09:00	6/28/2023	17:00	Diagnostic testing and allied bay maintenance work
281	1549	PLANNED	OCC_567	MSETCL	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	6/28/2023	09:00	6/28/2023	17:00	-
282	1550	PLANNED	OCC_567	MSETCL	220KV-PARLI-PARLI-M-2	D	Line, s/s Maintenance	6/28/2023	09:00	6/28/2023	17:30	-
283	1551	PLANNED	OCC_567	MSETCL	BALE - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	6/28/2023	09:00	6/28/2023	18:00	Quarterly Maintenance

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
284	1563	PLANNED	OCC_567	MSETCL	220KV-WARDHA-PUSAD-1	D	Maintenance work	6/29/2023	08:00	6/29/2023	18:00	.
285	1564	PLANNED	OCC_567	MSETCL	400KV-PARLI-M-KARJAT-1	D	(1) Distance relay testing work. (2) Bay maintenance work.	6/29/2023	09:00	6/29/2023	18:00	-
286	1565	PLANNED	OCC_567	MSETCL	JEJURI - 400KV - BUS 2	D	For Maintenance & Testing work	6/29/2023	09:30	6/29/2023	18:00	During outage all ICTs (ICT-1,ICT-2,ICT-3) will be in service.
287	1568	PLANNED	OCC_567	MSETCL	400KV/220KV CHAKAN-ICT-2	C	For Overhauling of SERGI NIFPS Fire system for ICT No.1 and routine Maintenance and DT.	6/29/2023	09:30	6/30/2023	21:00	-
288	1580	PLANNED	OCC_567	POWERGRID_WR2	400KV-KALA-VAPI-2	D	For Busbar and LBB Testing of Main Bay 418. Simultaneous outage of 400KV Bus # 2 is required and Dia to be kept open at both ends.	6/30/2023	12:00	6/30/2023	18:00	PG-WR2-VAPI
289	1581	PLANNED	OCC_567	MSETCL	400KV-KHARGHAR-PUNE-PG-1	D	Routine Maintenance & Insulator cleaning work.	6/30/2023	08:00	6/30/2023	18:00	Routine Maintenance & Insulator cleaning work.
290	1582	PLANNED	OCC_567	MEGPTCL	400KV-KORADI-II-KORADI-III-2	D	Annual Maintenance of Line equipment at Koradi III SS	6/30/2023	09:00	6/30/2023	18:00	Line Outage
291	1583	PLANNED	OCC_567	MSETCL	400KV-BABLESHWAR-PADGHE-2	C	1) LA replacement work under LES scheme 2) Bay maint work 3) Diagnostic Testing work 4) MTAMC work 5) Replacement of 29 D Isolator under LES scheme for which IPS tube will be removed between 29C bus PG Isolator and 29D Isolator. after that line will be charged on TBC and remain on TBC for 4 days . after completion of work line will be required H/T again on dated 04.07.23 for reconnection of IPS tube between 29D and 29C bus PG Isolator	6/30/2023	08:00	7/4/2023	23:59	1)weather condition should be clear 2) agency will be present on site

State Element outage list for the month of JUNE'2023

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	LONIKAND - JEJURI CKT - 2	01-Jun-23	09:30	01-Jun-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	During outage 400 kv Jejuri-Lonikand ckt-1 , 400 kv Jejuri-Karad , 400 kv Jejuri-Koyana Stg- 4 will be in service.
2	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	01-Jun-23	06:00	01-Jun-23	17:00	Daily	Premonsoon Maintenance	MSETCL	MSETCL	-
3	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	01-Jun-23	08:00	01-Jun-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
4	400 KV	BUS REACTOR (125MVA) @ WARORA	01-Jun-23	08:00	01-Jun-23	17:00	Daily	Routine and Premonsoon maintenance work.	MSETCL	MSETCL	Reactor kept in OFF position. Tie Bay No. 403 also kept in OFF position.
5	400 KV	400 KV WALLUJ (400 KV) - BABHALESHWAR CKT	02-Jun-23	10:00	02-Jun-23	18:00	Daily	Diagnostic Testing & Routine Maintenance	MSETCL	MSETCL	NIL
6	400 KV	JAIGAD - KARAD CKT - 1	02-Jun-23	09:00	02-Jun-23	18:00	Daily	BAY EQUIPMENT WASHING	JSWEL	JPTL	BAY EQUIPMENT WASHING
7	400 KV	TBC @ LONIKAND	02-Jun-23	08:00	03-Jun-23	23:30	Continuous	400kv TBC 29-A PG Isolator mechanim box replacement and trials	MSETCL	MSETCL	-
8	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	03-Jun-23	06:00	03-Jun-23	17:00	Daily	Premansoon Maintenance	MSETCL	MSETCL	-
9	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	03-Jun-23	09:00	03-Jun-23	17:00	Daily	Premonsoon maintenance work and Quarterly maintenance work,HV CB Timing /DCRM,SFRA,REF and NDR relay	MSETCL	MSETCL	315 MVA ICT 1,501 MVA ICT III and IV will be in service
10	400 KV	JAIGAD - KARAD CKT - 2	03-Jun-23	09:00	03-Jun-23	18:00	Daily	BAY EQUIPMENT WASHING	JSWEL	JPTL	BAY EQUIPMENT WASHING
11	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	03-Jun-23	08:00	03-Jun-23	18:00	Daily	For Premonsoon maintenance Work, HV and LV side routine bay maintenance works etc. of 400/132KV 200MVA - ICT No. 01	MSETCL	MSETCL	As per outage plan
12	400 KV	BABLESHWAR- AURANGABAD (WALLUJ)	05-Jun-23	09:00	05-Jun-23	17:00	Daily	CB DCRM/Timing,CT Tan delta	MSETCL	MSETCL	400KV Ekturi ckt I&II,400KV Bhusawal, and Dhule I&II will be in service
13	400 KV	KARAD - TALANDGE CKT - 1	05-Jun-23	08:00	05-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
14	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	05-Jun-23	08:00	07-Jun-23	18:00	Daily	For replacement of polymer Insulator string & Routine Maintenance work	MSETCL	MSETCL	.
15	400 KV	KORADI II - IEPL	05-Jun-23	10:00	05-Jun-23	17:30	Daily	Diagnostic testing of Line Current transformer Routine nut bolt tightening	MSETCL	MSETCL	400KV Koradi-II -Wardha (PG) Ckt. Will remain in service.
16	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	05-Jun-23	06:00	05-Jun-23	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
17	400 KV	AKOLA - KHADKA (BHUSAWAL)	05-Jun-23	07:00	09-Jun-23	17:00	Daily	String replacement work on 400 kv Akola-Bhusawal Line will be carried out by engaging agency which	MSETCL	MSETCL	String replacement work on 400 kv Akola- Bhusawal Line will
18	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	05-Jun-23	09:00	05-Jun-23	20:00	Daily	C bus isolator overhauling work Quarterly maintenance work	MSETCL	MSETCL	Load will be managed on 400 kv ICT -1 & 3
19	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	06-Jun-23	06:00	06-Jun-23	17:00	Daily	for replacement of faulty disc insulator found in PID testing	MSETCL	MSETCL	replacement of disc insulator
20	400 KV	KARAD - TALANDGE CKT - 2	06-Jun-23	08:00	06-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
21	400 KV	WARORA - IEPL	06-Jun-23	08:00	06-Jun-23	17:00	Daily	Line CT ,CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
22	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	07-Jun-23	08:00	07-Jun-23	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
23	400 KV	NEW KOYNA-KARAD CKT - 1	07-Jun-23	08:00	07-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
24	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	07-Jun-23	09:00	07-Jun-23	18:00	Daily	Pre-Monsoon maintenaance	MSETCL	MSETCL	NA
25	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	07-Jun-23	06:00	07-Jun-23	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
26	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	07-Jun-23	09:00	07-Jun-23	18:00	Daily	(1) Main-2 distance relay testing work. (2) Bay maintenance work. (3) Hardware lightning and fitting work.	MSETCL	MSETCL	-
27	400 KV	167 MVA SPARE ICT @ TALANDGE	07-Jun-23	09:00	07-Jun-23	18:00	Daily	Quarterly maintenance work Relay testing work	MSETCL	MSETCL	NA
28	400 KV	CHANDRAPUR-PARLI CKT-3	08-Jun-23	08:00	10-Jun-23	18:00	Daily	For replacement of polymer Insulator string & Routine Maintenance work	MSETCL	MSETCL	.
29	400 KV	LONIKAND I - KOYNA STAGE-IV	08-Jun-23	08:00	08-Jun-23	23:30	Daily	29-C PG Isolator mechanim box replacement and trials, PID faulty insulator string replacement and Cold Washing of insulator strings.	MSETCL	MSETCL	-
30	400 KV	JEJURI - KARAD	08-Jun-23	09:30	08-Jun-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	During outage 400 kv Jejuri-Lonikand ckt-1 , 400 kv Jejuri-Lonikand ckt-2 , 400 kv Jejuri-Koyana Stg-4 will be in service
31	400 KV	JEJURI-KOYNA STAGE-IV	08-Jun-23	07:00	09-Jun-23	17:00	Continuous	PID Faulty disc insulator replacement work & Cold line washing work & Conductor rstingning work between loc no 90-91	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work & Conductor rstingning work between loc no 90-91
32	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	08-Jun-23	06:00	08-Jun-23	17:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
33	400 KV	CHANDRAPUR - KHAPERKHEDA	08-Jun-23	08:00	08-Jun-23	17:00	Daily	for replacement of faulty disc insulator found in PID testing	MSETCL	MSETCL	replacement of faulty disc insulator
34	400 KV	LONIKAND I - KOYNA STAGE-IV	09-Jun-23	08:00	10-Jun-23	23:30	Continuous	29-B PG Isolator mechanim box replacement and trials	MSETCL	MSETCL	Line will be in service. Load will be shifted on TBC
35	400 KV	400/220kv 105 MVA SPARE ICT @ NEW KOYNA	09-Jun-23	08:00	09-Jun-23	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
36	400 KV	400KV GT 9 MAIN BAY 401 @ 400KV CHANDRAPUR SWITCHING S/S	09-Jun-23	09:00	09-Jun-23	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
37	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	09-Jun-23	08:00	09-Jun-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
38	400 KV	JEJURI- KOYNA STAGE-IV	09-Jun-23	07:00	09-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work & Conductor rstingning work between loc no 90-91	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work & Conductor rstingning work between loc no 90-91

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
39	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	09-Jun-23	10:00	09-Jun-23	18:00	Daily	Diagnostic testing & routine maintenance work	MSETCL	MSETCL	NIL
40	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	09-Jun-23	09:00	09-Jun-23	18:00	Daily	(1) IV breaker testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
41	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	10-Jun-23	09:00	10-Jun-23	17:00	Daily	Premonsoon maintenance work and Quarterly maintenance work.HV CB DCRM /Timing	MSETCL	MSETCL	315 MVA ICT II,501 MVA ICT III and IV will be in service
42	400 KV	KORADI - KHADKA	10-Jun-23	08:00	10-Jun-23	18:00	Daily	For replacement of R and B phase CVT old jump replacement work and routine bay maintenance works etc.	MSETCL	MSETCL	As per outage
43	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	10-Jun-23	06:00	10-Jun-23	17:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
44	400 KV	400KV GT 9 TIE BAY 402 @ 400KV CHANDRAPUR SWITCHING S/S	10-Jun-23	09:00	10-Jun-23	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
45	400 KV	KORADI-NANDGAONPETH (RPL)	10-Jun-23	08:00	10-Jun-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
46	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	11-Jun-23	07:00	11-Jun-23	10:00	Daily	Pre monsoon Maintenance work	MSETCL	MSETCL	Pre monsoon Maintenance work
47	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	11-Jun-23	11:00	11-Jun-23	13:00	Daily	Pre monsoon Maintenance work	MSETCL	MSETCL	Pre monsoon Maintenance work
48	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	11-Jun-23	14:00	11-Jun-23	16:00	Daily	Pre monsoon Maintenance work	MSETCL	MSETCL	Pre monsoon Maintenance work
108	400 KV	CHANDRAPUR-PARLI CKT-3	11-Jun-23	08:00	30-Jun-23	18:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	.
49	400 KV	KARAD - TALANDGE CKT - 1	12-Jun-23	09:00	12-Jun-23	20:00	Daily	C bus overhauling work Quarterly maintenance work	MSETCL	MSETCL	Monday is load staggering day Load will be managed from 400KV Karad -2
50	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	12-Jun-23	09:00	12-Jun-23	18:00	Daily	(1) HV breaker testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
51	400 KV	MAIN BAY - 413 OF GT-9 @ KORADI-2	12-Jun-23	10:00	12-Jun-23	17:30	Daily	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening	MSETCL	MSETCL	GT# 9 will remain in service through Tie bay 414
52	400 KV	TBC @ BABHALESHWAR	12-Jun-23	09:00	12-Jun-23	17:00	Daily	Chemical cleaning and bay maintenance work	MSETCL	MSETCL	400 KV TBC is free
53	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	12-Jun-23	07:00	14-Jun-23	18:00	Daily	String replacement work on 400 kV Akola- Nandgaonpeth Line will be carried out by engaging agency which are detected punctured in PID testing	MSETCL	MSETCL	String replacement work on 400 kV Akola- Nandgaonpeth Line will be carried out by engaging agency which are detected punctured in PID testing
54	400 KV	KARAD - TALANDGE CKT - 1	12-Jun-23	08:00	12-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
55	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	12-Jun-23	08:00	13-Jun-23	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	.
56	400 KV	400/220 KV SPARE 167 MVA ICT @ ALKUD	13-Jun-23	10:00	13-Jun-23	18:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
57	400 KV	400/220 KV 500 MVA ICT @ ALKUD	13-Jun-23	10:00	13-Jun-23	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	Load will be managed on 400KV Talandge & Karad
58	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	13-Jun-23	10:00	13-Jun-23	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
59	400 KV	CHANDRAPUR-PARLI CKT-3	13-Jun-23	09:00	13-Jun-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
60	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	13-Jun-23	10:00	13-Jun-23	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
61	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	13-Jun-23	08:00	13-Jun-23	17:00	Daily	for replacement of faulty disc insulator for in PID testing	MSETCL	MSETCL	Insulator replacement work
62	400 KV	KARAD - TALANDGE CKT - 2	13-Jun-23	08:00	13-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
63	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	14-Jun-23	09:00	14-Jun-23	18:00	Daily	Breaker CRM, DCRM, Timming	MSETCL	MSETCL	Outage time may be varied as per site & weather condition
64	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	14-Jun-23	08:00	14-Jun-23	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
65	400 KV	KORADI - KHAPERKHEDA CKT - 2	14-Jun-23	09:00	14-Jun-23	18:00	Daily	Diagnostic Testing of CBs	MSETCL	MSETCL	NA
66	400 KV	WARORA - IEPL	14-Jun-23	09:00	14-Jun-23	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
67	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	14-Jun-23	09:00	14-Jun-23	18:00	Daily	(1) Distance relay testing work. (2) Bay maintenance work. (3) Hardware lightning and fitting work.	MSETCL	MSETCL	-
68	400 KV	LONIKAND - JEJURI CKT - 1	15-Jun-23	08:00	15-Jun-23	18:00	Daily	Cold Washing of insulator strings	MSETCL	MSETCL	-
69	400 KV	LONIKAND I - KOYNA STAGE-IV	15-Jun-23	08:00	16-Jun-23	17:00	Continuous	PID Faulty disc insulator replacement work & Cold line washing work & Conductor rstringing work at loc no 90-91	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work & Conductor rstringing work at loc no 90-91
70	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	15-Jun-23	08:00	16-Jun-23	18:00	Daily	1. Measurement of tandelta of CT, bushing & winding. 2. Premonsoon maintenance work.	MSETCL	MSETCL	During outage, 400/220/33KV ICT-2, 220KV CHD-2 will be in service.
71	400 KV	CHANDRAPUR - KHAPERKHEDA	15-Jun-23	08:00	15-Jun-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
72	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	16-Jun-23	10:00	16-Jun-23	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
73	400 KV	TIE BAY - 414 OF GT-9 @ KORADI-2	16-Jun-23	10:00	16-Jun-23	17:30	Daily	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening	MSETCL	MSETCL	GT# 9 will remain in service through Main Bay 413
74	400 KV	TBC @ PADGHE	16-Jun-23	09:00	17-Jun-23	19:00	Continuous	1)Replacement of CT with New 3000/1A ratio to avoid power restriction on HVDC bay when in service through TBC 2) bay Maint work 3) Diagnostic Testing work 4) MTAMC work 5) TBC will be	MSETCL	MSETCL	1)weather condition should be clear 2) Agency will be present on site
75	400 KV	LONIKAND - JEJURI CKT - 2	17-Jun-23	10:00	17-Jun-23	18:00	Daily	1. PID detected weak strings replacement. 2. Routine maintenance activities	MSETCL	MSETCL	-
76	400 KV	JEJURI - KARAD	17-Jun-23	08:00	17-Jun-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
77	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	17-Jun-23	09:00	17-Jun-23	17:00	Daily	Premonsoon maintenance work and Quarterly maintenance work.Bushing Tand delta,LV CT tan Delta, HV LBB,MV LBB	MSETCL	MSETCL	315 MVA ICT I and II,501 MVA ICT IV will be in service
78	400 KV	TIE BAY-426 OF GT-8 @ KORADI-2	19-Jun-23	10:00	19-Jun-23	17:30	Daily	Diagnostic testing of Circuit Breaker & Routine nut bolt tightening	MSETCL	MSETCL	GT# 8 will remain in service through Main Bay 425

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
79	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	19-Jun-23	09:00	19-Jun-23	18:00	Daily	Bushings TAN Delta, Winding resistance, LBB relay testing	MSETCL	MSETCL	Outage time may be varied as per site & weather condition
80	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	19-Jun-23	08:00	20-Jun-23	18:00	Daily	1. Measurement of tandelta of bushing. 2. Measurement of CB timing, CRM & DCRM. 3. Premonsoon maintenance work. 4. Bay routine maintenance work.	MSETCL	MSETCL	During outage, 400/220/33KV ICT-1, 220KV CHD-2 will be in service.
81	400 KV	NEW KOYNA - STAGE IV CKT - 1	19-Jun-23	08:00	19-Jun-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
82	400 KV	KARAD - TALANDGE CKT - 2	19-Jun-23	09:00	19-Jun-23	20:00	Daily	C bus PG isolator overhauling work Quarterly maintenance work	MSETCL	MSETCL	Monday is load staggering day Load will be manged from 400KV KArad - 1
83	400 KV	FUTURE CKT - 1 @ WARORA	20-Jun-23	08:00	20-Jun-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
84	400 KV	CHANDRAPUR-PARLI CKT-3	20-Jun-23	08:00	21-Jun-23	18:00	Daily	1. Measurement of tandelta of CT and CVT. 2. Bay routine maintenance work.	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No - 1, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- load will be shifted on ICT-02
85	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	20-Jun-23	07:00	20-Jun-23	14:00	Daily	Routine maintenance & diagnostic testing DCRM, CRM& CB Timing	MSETCL	MSETCL	
86	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	20-Jun-23	09:00	20-Jun-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
87	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	21-Jun-23	07:00	21-Jun-23	14:00	Daily	Routine maintenance & diagnostic testing DCRM,CRM & CB Timing	MSETCL	MSETCL	bhusawal ckt will be in service
88	400 KV	400 KV FUTURE BAY II @ WARORA	21-Jun-23	08:00	21-Jun-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
89	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	21-Jun-23	08:00	21-Jun-23	17:00	Daily	1. Measurement of tan delta of line CVT. 2. Bay routine maintenance work	MSETCL	MSETCL	400KV CHD2 CKT-1, 400KV Parli Ckt-3, 400KV PGCIL CKT-1, CKT-2, CKT-3,CKT-4 will be in service.
90	400 KV	CHANDRAPUR-PARLI CKT-3	21-Jun-23	09:00	21-Jun-23	18:00	Daily	(1) Distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening and fitting work.	MSETCL	MSETCL	-
91	400 KV	MAIN BAY (403) OF CHANDRAPUR GCR CKT - 1 @ CHANDRAPUR - 2	21-Jun-23	09:00	21-Jun-23	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
92	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	22-Jun-23	09:00	22-Jun-23	18:00	Daily	Pre-Monsoon maintenaance	MSETCL	MSETCL	NA
93	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	22-Jun-23	09:30	23-Jun-23	21:00	Continuous	For Overhauling of SERGI NIFPS Fire system for ICT No.1 and routine Maintenance and DT.	MSETCL	MSETCL	-
94	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	22-Jun-23	09:30	22-Jun-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	During outage ICT 1 & ICT 2 will be in service.
95	400 KV	105 MVA SPARE ICT @ AKOLA	22-Jun-23	07:00	22-Jun-23	14:00	Daily	Routine maintenance work & testing work	MSETCL	MSETCL	N.A.
96	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	22-Jun-23	08:00	22-Jun-23	17:00	Daily	1. Measurement of tandelta of line CVT. 2. Bay routine maintenance work.	MSETCL	MSETCL	400KV CHD2 CKT-1, 400KV Parli Ckt-3, 400 KV PGCIL CKT-1, CKT-2, CKT-3, CKT-4, 400KV HVDC CKT-1 & CKT-2 will be in service.
97	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	23-Jun-23	07:00	23-Jun-23	14:00	Daily	Routine maintenance & diagnostic testing DCRM, CRM & CB Timing	MSETCL	MSETCL	load shifted on ICT-01
98	400 KV	125 MVAR BUS REACTOR @ 400KV KHAPARKHEDA S/S	23-Jun-23	09:00	23-Jun-23	18:00	Daily	Pre-Monsoon maintenaance	MSETCL	MSETCL	NA
99	400 KV	KHADKA-AURANGABAD (WALUJ)	23-Jun-23	10:00	23-Jun-23	18:00	Daily	Diagnostic Testing & Routine Maintenance work	MSETCL	MSETCL	NIL
100	400 KV	JEJURI - KARAD	24-Jun-23	08:00	24-Jun-23	18:00	Daily	Routine line maintenance activities	MSETCL	MSETCL	-
101	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	24-Jun-23	09:00	24-Jun-23	17:00	Daily	Premonsoon maintenance work and Quarterly maintenance work,DFRA, Tap continuity,MV LBB	MSETCL	MSETCL	315 MVA ICT I and II,501 MVA ICT III will be in service
109	400 KV	LONIKAND - JEJURI CKT - 2	25-Jun-23	08:00	30-Jun-23	18:00	Daily	PID Scanning of insulator strings	MSETCL	MSETCL	-
102	400 KV	NEW KOYNA - STAGE IV CKT - 2	26-Jun-23	08:00	26-Jun-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
103	400 KV	400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	26-Jun-23	10:00	26-Jun-23	18:00	Daily	DFRA	MSETCL	MSETCL	-
110	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	26-Jun-23	08:00	30-Jun-23	18:00	Daily	PID work	MSETCL	MSETCL	-
104	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	27-Jun-23	09:00	27-Jun-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
105	400 KV	400/220/33KV SPARE ICT @ KORADI 2	27-Jun-23	10:00	27-Jun-23	17:30	Daily	Diagnostic testing of Circuit Breaker & Routine nut bolt tightening	MSETCL	MSETCL	Spare ICT is on No Load.
106	400 KV	TBC @ NEW KOYNA	27-Jun-23	08:00	27-Jun-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & Pre-Monsoon maintenance	MSETCL	MSETCL	---
107	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	29-Jun-23	08:00	29-Jun-23	23:30	Daily	29-C PG Isolator mechanism box replacement and trials. Also DT Work & Bay Maintenance	MSETCL	MSETCL	-