

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of JUNE' 2024

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuous	Reason	From		To		Remarks
1	2	PLANNED	OCC_579	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-1	D	Simultaneous outage of both ckt's For repairing of Damaged jumper conductor, Dia to be kept open at both ends. A/R of Magarwada-Navasari-D/C out	1-Jun-2024	7:00	1-Jun-2024	18:00	PG-WR2-V/API
2	3	PLANNED	OCC_579	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-2	D	Simultaneous outage of both ckt's For repairing of Damaged jumper conductor, Dia to be kept open at both ends. A/R of Magarwada-Navasari-D/C out	1-Jun-2024	7:00	1-Jun-2024	18:00	PG-WR2-V/API
3	27	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	For taking on ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work by Project Circle.	1-Jun-2024	00:00	1-Jun-2024	12:00	For taking on ERS for shifting
4	28	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-4 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	D	For obtaining sufficient clearance so as to carry out connection of jumper of 501 MVA ICT V to 400 KV Main Bus II by Hot Line method. ICT IV will be in service through TBC	1-Jun-2024	08:00	1-Jun-2024	18:00	ICT IV will be in service through TBC
5	29	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of newly commissioned 501 MVA ICT V jumper to 400 KV Main Bus II by Hotline method	1-Jun-2024	08:00	1-Jun-2024	18:00	Work will be done online through Hotline method
6	30	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	Hot line washing of Bay Equipments for Talegaon line Bay	1-Jun-2024	10:00	1-Jun-2024	17:00	-
7	44	PLANNED	OCC_579	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	1-Jun-2024	8:00	10-Jun-2024	18:00	AR disable
8	45	PLANNED	OCC_579	WTPL	220KV-SOLAPUR-JEUR-1	D	AR disable for replacement of insulator in live line method.	1-Jun-2024	8:00	10-Jun-2024	18:00	AR disable
9	48	PLANNED	OCC_579	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	AR disable for replacement of insulator in live line method.	1-Jun-2024	8:00	15-Jun-2024	18:00	AR disable
10	61	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	1-Jun-2024	7:00	30-Jun-2024	18:00	
11	62	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	1-Jun-2024	7:00	30-Jun-2024	18:00	
12	71	PLANNED	OCC_579	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	1-Jun-2024	8:00	30-Jun-2024	18:00	AR disable
13	72	PLANNED	OCC_579	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	1-Jun-2024	8:00	30-Jun-2024	18:00	AR disable
14	95	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	D	PID Tsting work prmission to be required fo AR to be Kept Off	1-Jun-2024	08:00	30-Jun-2024	17:00	PID Tsting work prmission to be required fo AR to be Kept Off
15	96	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	For OPGW installation replacing existing earth wire	1-Jun-2024	08:00	30-Jun-2024	18:00	-
16	97	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	For OPGW installation replacing existing earth wire	1-Jun-2024	08:00	30-Jun-2024	18:00	Work is proposed by MTCIL
17	98	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	For OPGW installation replacing existing earth wire	1-Jun-2024	08:00	30-Jun-2024	18:00	Work is proposed by MTCIL
18	99	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	For OPGW installation replacing existing earth wire. AR in Non-auto mode	1-Jun-2024	08:00	30-Jun-2024	18:00	Work is proposed by MTCIL. AR in Non-auto mode
19	100	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	1-Jun-2024	08:00	30-Jun-2024	18:00	PID Work. A
20	101	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	D	PID Tsting work prmission to be required fo AR to be Kept Off.	1-Jun-2024	09:00	30-Jun-2024	17:00	PID Tsting work prmission to be required fo AR to be Kept Off
21	102	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID Testing work. Only AR will be out. Line will be in service.	1-Jun-2024	09:00	30-Jun-2024	18:00	PID Testing work. Only AR will be out. Line will be in service.
22	103	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID Testing work. Only AR will be out. Line will be in service.	1-Jun-2024	09:00	30-Jun-2024	18:00	PID Testing work. Only AR will be out. Line will be in service.
23	104	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	1-Jun-2024	11:00	30-Jun-2024	15:00	For PID work
24	105	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	1-Jun-2024	11:00	30-Jun-2024	15:00	For PID work
25	108	PLANNED	OCC_579	POWERGRID_WR1	PUNE-PG - 400KV - BUS 1	D	For AMP Work	2-Jun-2024	10:00	2-Jun-2024	18:00	Subject to same dia apposite main Bay of 400kV BUS-2 Load Limit to below 1550 AMP

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
26	109	PLANNED	OCC_579	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-1	D	Simultaneous outage of both ckts For repairing of Damaged jumper conductor, Dia to be kept open at both ends.	2-Jun-2024	7:00	2-Jun-2024	18:00	PG-WR2-VAPI
27	110	PLANNED	OCC_579	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-2	D	Simultaneous outage of both ckts For repairing of Damaged jumper conductor, Dia to be kept open at both ends.	2-Jun-2024	7:00	2-Jun-2024	18:00	PG-WR2-VAPI
28	116	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	For taking on ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.	2-Jun-2024	00:00	2-Jun-2024	12:00	For taking on ERS for shifting
29	117	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Outage is required for safety purpose during replacement of Disc Insulator broken at Loc No. 107 Y-Ph PGCIL side of 220kV PGCIL - Borivali Line.	2-Jun-2024	09:00	2-Jun-2024	17:00	Outage is required for safety purpose during replacement of Disc Insulator broken at Loc No. 107 Y-Ph PGCIL side of 220kV PGCIL - Borivali Line.
30	118	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-BORIVALL-1	D	Disc Insulator broken at Loc No. 107 Y-Ph PGCIL side.	2-Jun-2024	09:00	2-Jun-2024	17:00	Simultaneously outage is required on 220kV Tarapur - Borivali Line (for safety purpose)
31	119	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1) Bay maint work 2) Diagnostic Testing work 3) Replacement of Distance relay 4) Replacement of all phase LA under LES scheme	2-Jun-2024	09:00	2-Jun-2024	21:00	1) weather condition should be clear
32	120	PLANNED	OCC_579	MEGPTCL	AKOLA (2) - 765KV B/R 1	D	BUS REACTOR changeover activity as per CEA guideline, B- Ph Reactor taken into service in place of SPARE-Ph REACTOR at Akola-II SS	2-Jun-2024	10:00	2-Jun-2024	18:00	BUS REACTOR OUTAGE
33	122	PLANNED	OCC_579	ATIL	400KV-TIRODA-WARORA-1	D	Additional Earthing Work. AR IN NON AUTO	2-Jun-2024	08:00	15-Jun-2024	18:00	AR IN NON AUTO
34	123	PLANNED	OCC_579	POWERGRID_WR1	765KV-WARDHA-AURANGABAD-2	D	For Line AMP Works	3-Jun-2024	7:00	3-Jun-2024	18:00	712L
35	132	PLANNED	OCC_579	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For AMP Work	3-Jun-2024	7:00	3-Jun-2024	18:00	Line Owned By MSETCL
36	137	PLANNED	OCC_579	GETCO	220KV-NASIK-NAVSARI-1	D	Routine maintenance	3-Jun-2024	8:00	3-Jun-2024	15:00	
37	160	PLANNED	OCC_579	GETCO	220KV-TARAPUR 1&2-BHILAD-1	C	PMM work	3-Jun-2024	9:00	3-Jun-2024	18:00	
38	169	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	"1. For Replacement of Flashover Disc. 2. Fixing of Turbo Wind Bird Guard. 3. Diagnostic testing of Line Bay at Dharni S/s"	3-Jun-2024	09:00	3-Jun-2024	17:00	Outage
39	170	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	3-Jun-2024	10:00	3-Jun-2024	13:00	--
40	171	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Quarterly maintenance work	3-Jun-2024	10:00	3-Jun-2024	18:00	Monday is Staggering day of Kolhapur
41	172	PLANNED	OCC_579	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	3-Jun-2024	14:00	3-Jun-2024	17:00	--
42	184	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	3-Jun-2024	05:00	8-Jun-2024	09:00	Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
43	188	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	for PID testing work.Only AR will be kept off .Line will be in service.	3-Jun-2024	08:00	19-Jun-2024	18:00	line will in system only AR out.
44	189	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	3-Jun-2024	09:00	29-Jun-2024	18:00	PID testing of insulator A
45	195	PLANNED	OCC_579	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	D	AMP of Line Equipment at Padghe GIS & MSETCL Kudus substation. AR IN NON AUTO MODE OF CKT#2	4-Jun-2024	7:00	4-Jun-2024	17:00	
46	200	PLANNED	OCC_579	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	4-Jun-2024	7:00	4-Jun-2024	18:00	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire
47	201	PLANNED	OCC_579	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	4-Jun-2024	7:00	4-Jun-2024	18:00	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
48	227	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	4-Jun-2024	10:00	4-Jun-2024	18:00	Line Continuous through 411 TIE Bay andsame dia opposite Main Bay(412) current limitto 1550 AMP (Twin Moose thrmal Limit)
49	229	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage	4-Jun-2024	08:00	4-Jun-2024	18:00	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during
50	230	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Availing Outage on 400 KV Dhule-SSNNLCKT 1 & Safe working, 400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage period	4-Jun-2024	08:00	4-Jun-2024	18:00	For Availing Outage on 400 KV Dhule-SSNNLCKT 1 & Safe working, 400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage period
51	231	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Connection of Hanger rod assembly on 400 kV Main Bus-I in Reactor-II Bay by Hot Line Method	4-Jun-2024	09:00	4-Jun-2024	13:00	Work will be done online through Hotline method
52	232	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot Line Method. Shifting of auto reclose switch to non auto mode	4-Jun-2024	09:00	4-Jun-2024	17:00	Hot Line Work
53	233	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of Hanger rod assembly on 400 kV Main Bus-II in Reactor-II Bay by Hot Line Method	4-Jun-2024	13:00	4-Jun-2024	18:00	Work will be done online through Hotline method
54	237	PLANNED	OCC_579	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	C	400 kV GIS BUS MODULE CONNECTION WITH EXISTING 400 kV BUS-2, SIMULTANEOUS OUTAGE OF 400 KV PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED .	4-Jun-2024	7:00	6-Jun-2024	18:00	OUTAGE IS BEING TAKEN FOR 400
55	239	PLANNED	OCC_579	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	C	400 kV GIS BUS MODULE CONNECTION WITH EXISTING 400 kV BUS-2, SIMULTANEOUS OUTAGE OF 400 KV PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED .	4-Jun-2024	9:00	6-Jun-2024	18:00	OUTAGE IS BEING TAKEN FOR 400
56	247	PLANNED	OCC_579	MSLDC_OUTAGE	JAIGAD - 400KV B/R 1	C	CSD RELAY INTALLATION AND COMMISSIONING AT JAIGAD END	4-Jun-2024	09:00	8-Jun-2024	18:00	CSD RELAY INTALLATION AND COMMISSIONING AT JAIGAD END
57	253	PLANNED	OCC_579	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Winding Tan Delta, FDS, Moisture measurement of LR of 400KV- PADGHE-BOISAR-1. AR of CKT#2 in non auto mode.	5-Jun-2024	7:00	5-Jun-2024	17:00	
58	260	PLANNED	OCC_579	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme.400KV-WARORA-PG-WARORA (MSETCL)-1 AR OFF	5-Jun-2024	7:00	5-Jun-2024	18:00	Diamond Crossing of Earthwire
59	261	PLANNED	OCC_579	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	5-Jun-2024	7:00	5-Jun-2024	18:00	Earth wire Peak Strengthening work for Diamond Crossing of Earthwire
60	288	PLANNED	OCC_579	APML	400KV/11.5KV TIRODA-ST-4	C	MCT Testing work	5-Jun-2024	9:00	5-Jun-2024	18:00	GT-2 will be in service with main bay
61	295	PLANNED	OCC_579	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND 400KV/220KV PUNE-PG-ICT-2 at PUNE-PG - 400KV	D	For AMP Work	5-Jun-2024	10:00	5-Jun-2024	18:00	
62	298	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	To carry out maintenance work and attending the problems observed in the monkey patrolling	5-Jun-2024	07:00	5-Jun-2024	18:00	Work to be attended by AMC agency
63	299	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	5-Jun-2024	08:00	5-Jun-2024	18:00	Outage
64	300	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	5-Jun-2024	09:00	5-Jun-2024	18:00	na
65	301	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Quarterly Maintenance	5-Jun-2024	10:00	5-Jun-2024	17:00	Breaker of PGCIL line at Jeur End will be made off
66	302	PLANNED	OCC_579	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT	5-Jun-2024	10:00	5-Jun-2024	17:30	All feeders wil remain in service through 400kV Main Bus-II
67	303	PLANNED	OCC_579	POWERGRID_WR1	DHULE-MS - 400KV B/R 2	C	For old CT replacement work	5-Jun-2024	7:00	6-Jun-2024	18:00	PGG
68	312	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-I AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. Line will be in service through TBC at 400KV Bableshtar end	5-Jun-2024	09:00	8-Jun-2024	18:00	400 KV Aurangabad will be in service through TBC
69	315	PLANNED	OCC_579	POWERGRID_WR2	400KV-MAGARWADA-NAVSARI-1	C	for fixing tower member above waist level, Dia to be kept open at both ends.	5-Jun-2024	7:00	11-Jun-2024	18:00	PG-WR2-VAPI
70	318	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	A/R out of service for Balance PID Work.	5-Jun-2024	08:00	30-Jun-2024	18:00	NA

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
71	319	PLANNED	OCC_579	ATIL	400KV-TIRODA-WARORA-2	D	Line MCT calibration work	6-Jun-2024	09:00	6-Jun-2024	18:00	ST-2 will be in service with main bay
72	320	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	To carry out maintenance work and attending the problems observed in the monkey patrolling	6-Jun-2024	07:00	6-Jun-2024	18:00	Work to be attended by AMC agency
73	361	PLANNED	OCC_579	APML	400KV/11.5KV TIRODA-ST-1	C	MCT Testing work	6-Jun-2024	9:00	6-Jun-2024	18:00	400KV Line-1 will be in service with main bay
74	371	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	To carry out maintenance work and attending the problems observed in the monkey patrolling	6-Jun-2024	07:00	6-Jun-2024	18:00	Work to be attended by AMC agency
75	372	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work-400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage	6-Jun-2024	08:00	6-Jun-2024	18:00	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work-400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage.
76	373	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	6-Jun-2024	08:00	6-Jun-2024	18:00	Outage
77	374	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Availing Outage on 400 KV Dhule-SSNNLCKT 2 & Safe working, 400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage period	6-Jun-2024	08:00	6-Jun-2024	18:00	For Availing Outage on 400 KV Dhule-SSNNLCKT 2 & Safe working, 400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage period
78	375	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Diagnostic testing & Maintenance work	6-Jun-2024	10:00	6-Jun-2024	17:00	Load will be managed on 400KV Kolhapur Line
79	376	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Cold line washing. Line outage	6-Jun-2024	10:00	6-Jun-2024	17:00	-
80	377	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	Cold line washing of insulators.	6-Jun-2024	10:00	6-Jun-2024	17:00	-
81	384	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work .	7-Jun-2024	09:00	7-Jun-2024	17:00	400KV WARORA-IEPL Line is in ckt
82	385	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	7-Jun-2024	09:00	7-Jun-2024	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
83	399	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	For AMP	7-Jun-2024	7:00	7-Jun-2024	18:00	PGHL
84	400	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AR IN NON AUTO to faciliate Line Shutdown works.	7-Jun-2024	7:00	7-Jun-2024	18:00	PGHL
85	401	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2 L/R@ DHULE-MS - 400KV	D	For AMP	7-Jun-2024	7:00	7-Jun-2024	18:00	PGHR
86	405	PLANNED	OCC_579	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	AMP, Dia to be kept open at both sides	7-Jun-2024	7:00	7-Jun-2024	21:00	PG-WR2-BOISAR
87	415	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND BHADRAWATI - 400KV - BUS 2 at BHADRAWATI - 400KV	C	Bay AMP works	7-Jun-2024	9:00	7-Jun-2024	17:00	AMP works
88	416	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-1	D	Annual Maintenance	7-Jun-2024	9:00	7-Jun-2024	17:00	Outage
89	417	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Parli- Solapur -1	7-Jun-2024	9:00	7-Jun-2024	17:00	AR disable
90	425	PLANNED	OCC_579	APML	400KV/11.5KV TIRODA-ST-2	C	MCT Testing work	7-Jun-2024	9:00	7-Jun-2024	18:00	400KV Line-2 will be in service with main bay
91	432	PLANNED	OCC_579	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-1 at PUNE-PG - 400KV	D	For AMP Work	7-Jun-2024	10:00	7-Jun-2024	18:00	
92	436	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Line Disc replacement Works at various locations and nut bolt tightening	7-Jun-2024	09:00	7-Jun-2024	18:00	Line Disc replacement Works at various locations and nut bolt tightening
93	441	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	Hot line washing of Loc no. 36-51(54 strings) of 400 kV Chakan - Talegaon Line. Only A/R out	7-Jun-2024	10:00	8-Jun-2024	17:00	-
94	442	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	for shifting/ height rising work MMRDA Katni naka bridge work.	7-Jun-2024	00:00	14-Jun-2024	12:00	for shifting
95	449	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	For AMP	8-Jun-2024	7:00	8-Jun-2024	18:00	PGJL

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuous	Reason	From		To		Remarks
96	450	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AR IN NON AUTO to facilitate Line Shutdown works.	8-Jun-2024	7:00	8-Jun-2024	18:00	PGJL
97	451	PLANNED	OCC_579	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1 L/R@ DHULE-MS - 400KV	D	For AMP	8-Jun-2024	7:00	8-Jun-2024	18:00	PGJR
98	452	PLANNED	OCC_579	POWERGRID_WR1	765KV-PUNE-GIS-SOLAPUR-1	D	FOR ATTENDING LINE DEFECTS	8-Jun-2024	7:00	8-Jun-2024	18:00	FOR ATTENDING LINE DEFECTS
99	457	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-2	D	Annual Maintenance	8-Jun-2024	9:00	8-Jun-2024	17:00	Outage
100	458	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Parli- Solapur -2	8-Jun-2024	9:00	8-Jun-2024	17:00	AR disable
101	465	PLANNED	OCC_579	APML	400KV/11.5KV TIRODA-ST-3	C	MCT Testing work	8-Jun-2024	9:00	8-Jun-2024	18:00	ST-5 will be in service with main bay
102	469	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	8-Jun-2024	10:00	8-Jun-2024	18:00	Line Continuous through 402 TIE Bay and Kharghar Main Bay current Limit to below 1550 AMP (of Twin Moose thermal Limit)
103	471	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	To carry out maintenance work and attending the problems observed in the monkey patrolling	8-Jun-2024	07:00	8-Jun-2024	18:00	Work to be attended by AMC agency
104	472	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in routine patrolling; to replace faulty PID insulator strings and Insuator strings under R&M work at Jumer S-Dn.	8-Jun-2024	08:00	8-Jun-2024	18:00	400kV Babhaleshwar-Padghe Ckt 2 will be available.
105	478	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	For taking on ERS for shifting/ height rising work in between loc. 1097-1100 for NHSRCL work.	8-Jun-2024	00:00	9-Jun-2024	12:00	For taking on ERS for shifting
106	484	PLANNED	OCC_579	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	D	For AMP Work	9-Jun-2024	7:00	9-Jun-2024	18:00	Line Owned By ADANI TRANS
107	486	PLANNED	OCC_579	POWERGRID_WR1	765KV/400KV PUNE-GIS-JCT-1	D	SPARE CHANGE OVER OF 765/400 KV ICT 1(R -PH WILL BE TAKEN IN SERVICE BY REMOVING SPARE) Last spare R-Phase change over done on 23.03.2023	9-Jun-2024	7:00	9-Jun-2024	14:00	OUTAGE IS BEING TAKEN FOR 400
108	487	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	Maintenance Work at Panchali TSS.	9-Jun-2024	5:00	9-Jun-2024	9:00	Maintenance Work at Panchali TSS.
109	490	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-1	D	Annual Maintenance	9-Jun-2024	9:00	9-Jun-2024	17:00	Outage
110	491	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Parli- Solapur-1	9-Jun-2024	9:00	9-Jun-2024	17:00	AR disable
111	493	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	For the installation of saver assembly sets at TL no. 181, 184, 238 & 239 (Total 24 sets out of 24 sets are to be installed)	9-Jun-2024	08:00	9-Jun-2024	18:00	Simultaneously outage is required on 220 kV Borivali-PGCIL for same work & as both lines are on M
112	494	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For the installation of saver assembly sets at TL no. 181, 184, 238 & 239 (Total 24 sets out of 24 sets are to be installed)	9-Jun-2024	08:00	9-Jun-2024	18:00	Simultaneously outage is required on 220 kV Borivali-Tarapur for same work & as both lines are on M
113	495	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Connection of Hanger rod assembly on 400 kV Main Bus-I in Reactor-II Bay by Hot Line Method	9-Jun-2024	09:00	9-Jun-2024	13:00	Work will be done online through Hotline method
114	496	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Hot line washing of Bay Equipments for Lonikand line Bay	9-Jun-2024	10:00	9-Jun-2024	17:00	-
115	497	PLANNED	OCC_579	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Line Reactor changeover activity as per CEA guideline, B- Ph Reactor taken into service in place of spare-Ph Reactor at Akola-II SS	9-Jun-2024	10:00	9-Jun-2024	18:00	Line Outage
116	498	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of Hanger rod assembly on 400 kV Main Bus-II in Reactor-II Bay by Hot Line Method	9-Jun-2024	13:00	9-Jun-2024	18:00	Work will be done online through Hotline method
117	500	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work	9-Jun-2024	22:00	10-Jun-2024	6:00	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work
118	510	PLANNED	OCC_579	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For AMP	10-Jun-2024	7:00	10-Jun-2024	18:00	401AL
119	511	PLANNED	OCC_579	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	For AMP	10-Jun-2024	7:00	10-Jun-2024	18:00	401ALR
120	522	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY - 765KV-PUNE-PG-SOLAPUR-1 AND SOLAPUR - 765KV - BUS 2 at Solapur - 765KV	D	Bay AMP Works	10-Jun-2024	8:00	10-Jun-2024	18:00	
121	524	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-2	D	Annual Maintenance	10-Jun-2024	9:00	10-Jun-2024	17:00	Outage
122	525	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Parli- Solapur-2	10-Jun-2024	9:00	10-Jun-2024	17:00	AR disable

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks		
123	530	PLANNED	OCC_579	APML	400KV/11.5KV TIRODA-ST-5	C	MCT Testing work	10-Jun-2024	9:00	10-Jun-2024	18:00	ST-3 will be in service with main bay
124	538	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	10-Jun-2024	10:00	10-Jun-2024	18:00	Line Continuous through 405 TIE Bay and ICT_1 Main aby current Limit to below 1550 AMP
125	541	PLANNED	OCC_579	MEGPTCL	KORADI-III - 765KV B/R 1	D	Six monthly changeover of Spare-Ph Reactor to be taken in service in place of B-Ph Reactor as per CEA regulation at Koradi-III SS. Last changeover date 16.12.2023	10-Jun-2024	09:00	10-Jun-2024	14:00	Bus Reactor Outage. Last changeover date 16.12.2023
126	542	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	"1.For Replacement of Flashover Disc. testing of Line Bay at Badnera S/s" 2.Diagnostic	10-Jun-2024	09:00	10-Jun-2024	17:00	Outage
127	543	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	10-Jun-2024	09:00	10-Jun-2024	18:00	The said work is very important
128	544	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	10-Jun-2024	10:00	10-Jun-2024	13:00	--
129	545	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic testing & Maintenance work	10-Jun-2024	10:00	10-Jun-2024	17:00	Load will be managed on 400KV Solapur Line
130	546	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Diagnostic Testing and Maintenance Works	10-Jun-2024	10:00	10-Jun-2024	18:00	Bay no. 710 ICT I MAIN BAY
131	547	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine Line Maintenance Work	10-Jun-2024	10:00	10-Jun-2024	18:00	NA
132	548	PLANNED	OCC_579	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Diagnostic testing & Maintenance work	10-Jun-2024	14:00	10-Jun-2024	17:00	--
133	554	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Hot line washing of Loc. No 10-20(63 strings), loc. 30-60(192) of 400 kV Lonikand-1-Chakan line	10-Jun-2024	10:00	12-Jun-2024	18:00	-
137	585	PLANNED	OCC_579	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-1	D	For AMP	11-Jun-2024	7:00	11-Jun-2024	18:00	430L
138	586	PLANNED	OCC_579	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-2	D	AR IN NON AUTO to faciliate Line Shutdown works.	11-Jun-2024	7:00	11-Jun-2024	18:00	430L
139	608	PLANNED	OCC_579	APML	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	11-Jun-2024	9:00	11-Jun-2024	13:00	ICT will be in srvice with tie bay from 400KV side
140	611	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-1	D	Annual Maintenance	11-Jun-2024	9:00	11-Jun-2024	17:00	Outage
141	612	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Parli- Solapur -1	11-Jun-2024	9:00	11-Jun-2024	17:00	AR disable
142	621	PLANNED	OCC_579	APML	TIE BAY OF 400KV/21KV TIRODA-GT-3 AND FUTURE @TIRODA - 400KV at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	11-Jun-2024	9:00	11-Jun-2024	18:00	GT-3 will be in service with main bay
143	632	PLANNED	OCC_579	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Diagnostic test and routine maintenance work	11-Jun-2024	07:00	11-Jun-2024	14:00	Outage required for above work
144	633	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintainance work	11-Jun-2024	08:00	11-Jun-2024	18:00	NA
145	634	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Isolator alignment and servicing work in 400 KV Padghe bay	11-Jun-2024	09:00	11-Jun-2024	13:00	Work will be done online through Hotline method
146	635	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine Line Maintenance Work	11-Jun-2024	10:00	11-Jun-2024	18:00	NA
147	636	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Isolator alignment and servicing work in 400 KV Padghe bay	11-Jun-2024	13:00	11-Jun-2024	18:00	Work will be done online through Hotline method
148	642	PLANNED	OCC_579	POWERGRID_WR1	KOLHAPUR GIS-400KV B/R1	C	Turret CT oil leakage attending and Relay testing work	11-Jun-2024	8:00	14-Jun-2024	18:00	125Mvar Bus Reactor Turret CT Oil leakage attending and Relay testing work
149	645	PLANNED	OCC_579	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for replacement of insulator in live line method.	11-Jun-2024	8:00	20-Jun-2024	18:00	AR disable
150	646	PLANNED	OCC_579	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	11-Jun-2024	8:00	20-Jun-2024	18:00	AR disable
135	567	PLANNED	OCC_579	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP of 401L at MSETCL Kodus Substation. 400KV-KALA-KUDUS-1 A/R to be kept in Non-Auto mode.	12-Jun-2024	7:00	12-Jun-2024	17:00	
151	656	PLANNED	OCC_579	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment	12-Jun-2024	7:00	12-Jun-2024	17:00	
152	677	PLANNED	OCC_579	APML	TIE BAY - 400KV/11.5KV TIRODA-ST-3 AND 400KV/11.5KV TIRODA-ST-5 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	12-Jun-2024	9:00	12-Jun-2024	13:00	ST-3 and ST-5 will be in service with main bay

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
153	678	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-2	D	Annual Maintenance	12-Jun-2024	9:00	12-Jun-2024	17:00	Outage
154	679	PLANNED	OCC_579	WTPL	400KV-PARLI-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Parli- Solapur -2	12-Jun-2024	9:00	12-Jun-2024	17:00	AR disable
155	698	PLANNED	OCC_579	APML	TIE BAY OF 400KV/21KV TIRODA-GT-1 AND 765KV/400KV TIRODA-ICT-1 @TIRODA - 400KV at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	12-Jun-2024	14:00	12-Jun-2024	18:00	GT-1 and ICT will be in service with main bay
157	700	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	12-Jun-2024	08:00	12-Jun-2024	18:00	Outage
158	702	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	12-Jun-2024	09:00	12-Jun-2024	17:00	Line will be charged through Tie CB 428.
159	703	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	12-Jun-2024	09:00	12-Jun-2024	18:00	The said work is very mportant
160	704	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	For routine maintenance work	12-Jun-2024	09:00	12-Jun-2024	18:00	NA
161	705	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	12-Jun-2024	09:00	12-Jun-2024	18:00	NA
162	706	PLANNED	OCC_579	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT	12-Jun-2024	10:00	12-Jun-2024	17:30	All feeders wil remain in service through 400kV Main Bus-I
136	571	PLANNED	OCC_579	POWERGRID_WR1	400KV-KALA-KUDUS-1	D	AMP of 404L at MSETCL Kodus Substation. 400KV-KALA-KUDUS-2 A/R to be kept in Non-Auto mode.	13-Jun-2024	7:00	13-Jun-2024	17:00	
163	735	PLANNED	OCC_579	APML	MAIN BAY - TIRODA - 400KV B/R 2 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	D	CT OIL SAMPLE COLLECTION FOR DGA	13-Jun-2024	9:00	13-Jun-2024	13:00	BR-2 will be in service with main bay
164	752	PLANNED	OCC_579	APML	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	13-Jun-2024	14:00	13-Jun-2024	18:00	ICT will be in srvice with tie bay from 765KV side
165	753	PLANNED	OCC_579	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	13-Jun-2024	08:00	13-Jun-2024	18:00	During 400KV Busbar Protection Relay testing works Outage . (1). 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay
166	754	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintainance work	13-Jun-2024	08:00	13-Jun-2024	18:00	NA
167	755	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	13-Jun-2024	08:00	13-Jun-2024	18:00	Outage
168	758	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	13-Jun-2024	09:00	13-Jun-2024	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
169	759	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	Cold line washing	13-Jun-2024	10:00	13-Jun-2024	17:00	-
170	760	PLANNED	OCC_579	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Reactor SLR CB Drive Mechanism Inspection Work by OEM	13-Jun-2024	7:00	14-Jun-2024	18:00	707L
171	761	PLANNED	OCC_579	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2 L/R@ AURANGABAD - 765KV	C	Reactor CB Drive Mechanism Inspection Work by OEM	13-Jun-2024	7:00	14-Jun-2024	18:00	707LR
172	765	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	Cold line washing of insulators.	13-Jun-2024	20:00	14-Jun-2024	5:00	-
173	768	PLANNED	OCC_579	POWERGRID_WR1	765KV/400KV PUNE-GIS-ICT-2	D	FOR ERECTION OF LM TOWER DAILY SHUTDOWN REQUIRED.	13-Jun-2024	8:00	17-Jun-2024	18:00	OUTAGE IS BEING TAKEN FOR 400
174	770	PLANNED	OCC_579	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	14-Jun-2024	7:00	14-Jun-2024	13:00	
176	781	PLANNED	OCC_579	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	For AMP of Line Bay	14-Jun-2024	7:00	14-Jun-2024	20:00	
177	782	PLANNED	OCC_579	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element. Each Feeder will be shifted on TBC one at time	14-Jun-2024	7:00	14-Jun-2024	20:00	
178	799	PLANNED	OCC_579	APML	MAIN BAY OF 765KV/21KV TIRODA-GT-5 AND TIRODA - 765KV - BUS 1 @TIRODA - 765KV at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	14-Jun-2024	9:00	14-Jun-2024	13:00	GT-5 will be in service with Tie bay
179	818	PLANNED	OCC_579	APML	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	14-Jun-2024	14:00	14-Jun-2024	18:00	B
180	819	PLANNED	OCC_579	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element.	14-Jun-2024	14:00	14-Jun-2024	20:00	
181	820	PLANNED	OCC_579	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Diagnostic testing and routine maintenance work	14-Jun-2024	07:00	14-Jun-2024	14:00	Outage required for above work

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks		
182	821	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	14-Jun-2024	08:00	14-Jun-2024	18:00	NA
183	823	PLANNED	OCC_579	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	14-Jun-2024	09:00	14-Jun-2024	17:00	Line will be charged through Main CB 429.
184	824	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Routine diagnostic Testing and Maintenance Works	14-Jun-2024	10:00	14-Jun-2024	18:00	Main Bay 713 for diagnostic Testing
134	564	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	To complete the balance work of replacement of existing conductor by HTLS.	15-Jun-2024	08:00	30-Jun-2024	22:00	To complete the balance work of replacement of existing conductor by HTLS.
185	830	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14)	15-Jun-2024	5:00	15-Jun-2024	10:00	1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S
186	834	PLANNED	OCC_579	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-1	D	PT 100 Sensor check works	15-Jun-2024	7:00	15-Jun-2024	18:00	PT 100 Sendor check and relacement works
187	839	PLANNED	OCC_579	POWERGRID_WR1	WARDHA - 220KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element. Each Feeder will be shifted on TBC one at time	15-Jun-2024	7:00	15-Jun-2024	20:00	
189	849	PLANNED	OCC_579	APML	MAIN BAY OF 765KV/21KV TIRODA-GT-4 AND TIRODA - 765KV - BUS 1 @TIRODA - 765KV at TIRODA - 765KV	D	CT OIL SAMPLE COLLECTION FOR DGA	15-Jun-2024	9:00	15-Jun-2024	13:00	GT-4 will be in service with Tie bay
190	862	PLANNED	OCC_579	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Six monthly changeover of R-Ph ICT to be taken in service in place of Spare Ph ICT as per CEA regulation at Koradi-III SS. Last changeover date 30.12.2023	15-Jun-2024	09:00	15-Jun-2024	19:00	ICT Outage. Last changeover date 30.12.2024
191	879	PLANNED	OCC_579	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance and R &M work.	16-Jun-2024	06:00	16-Jun-2024	12:00	Bay maintenance and
192	880	PLANNED	OCC_579	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Line Reactor changeover activity as per CEA guideline, Spare- Ph Reactor taken into service in place of R-Ph Reactor at Akola-II SS	16-Jun-2024	10:00	16-Jun-2024	18:00	Line Outage
193	881	PLANNED	OCC_579	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1 L/R@ AKOLA (2) - 765KV	D	Line Reactor changeover activity as per CEA guideline, Spare- Ph Reactor taken into service in place of R-Ph Reactor at Akola-II SS	16-Jun-2024	10:00	16-Jun-2024	18:00	Line Reactor Outage
194	882	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12)	16-Jun-2024	5:00	17-Jun-2024	11:00	1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S
195	883	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. Line will be in service through TB at 400KV Babaleshwar end.	16-Jun-2024	22:00	19-Jun-2024	18:00	400 KV Padghe II will be in service through TBC
196	884	PLANNED	OCC_579	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	AR disable for replacement of insulator in live line method.	16-Jun-2024	8:00	30-Jun-2024	18:00	AR disable
197	885	PLANNED	OCC_579	ATIL	400KV-TIRODA-WARORA-2	D	Additional Earthing Work. AR IN NON AUTO	16-Jun-2024	08:00	30-Jun-2024	18:00	AR IN NON AUTO
156	699	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	17-Jun-2024	08:00	17-Jun-2024	18:00	NA
198	894	PLANNED	OCC_579	POWERGRID_WR1	WARDHA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element.Each Feeder will be shifted on TBC one at time	17-Jun-2024	7:00	17-Jun-2024	18:00	
200	912	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	29A Isolator alignment and servicing in 400 KV Padghe I bay	17-Jun-2024	09:00	17-Jun-2024	13:00	Work will be done online through Hotline method
201	913	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	29B Isolator alignment and servicing in 400 KV Padghe II bay	17-Jun-2024	13:00	17-Jun-2024	18:00	Work will be done online through Hotline method
202	921	PLANNED	OCC_579	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-1	C	Overhauling of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS & AMP works at both end. AR in non auto mode CKT#2	17-Jun-2024	8:00	19-Jun-2024	20:00	
203	923	PLANNED	OCC_579	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV - BUS 1	C	Insulator cleaing work. 400kV PG Isolator alignment and maintenance work.	17-Jun-2024	10:00	22-Jun-2024	18:00	Load will be managed form Main bus -2.
204	924	PLANNED	OCC_579	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV- RAIPUR-WARDHA-1 at Wardha - 400KV	C	For Overhuling of CGL Pneumatic Breakers	17-Jun-2024	7:00	23-Jun-2024	20:00	
188	840	PLANNED	OCC_579	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	18-Jun-2024	7:00	18-Jun-2024	20:00	
205	965	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot line method.	18-Jun-2024	09:00	18-Jun-2024	17:00	Hot Line Work
206	966	PLANNED	OCC_579	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Bay maintenance	18-Jun-2024	10:00	18-Jun-2024	13:00	BAY OUTAGE
207	967	PLANNED	OCC_579	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	D	maintenance of Bay equipment at Akola SS	18-Jun-2024	15:00	18-Jun-2024	18:00	BAY OUTAGE
208	968	PLANNED	OCC_579	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1	C	Reactor SLR CB Drive Mechanism Inspection Work by OEM	18-Jun-2024	7:00	19-Jun-2024	18:00	710L

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuos	Reason	From		To		Remarks
209	969	PLANNED	OCC_579	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1 L/R@ AURANGABAD - 765KV	C	Reactor CB Drive Mechanism Inspection Work by OEM	18-Jun-2024	7:00	19-Jun-2024	18:00	710LR
210	973	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY OF KOLHAPUR-MS - 400KV B/R 1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	C	Proposed Circuit Breaker Overhauling work. Reactor	18-Jun-2024	8:00	22-Jun-2024	18:00	Outage required on CB only. Bus reactor can be kept in service through TBC.
199	895	PLANNED	OCC_579	POWERGRID_WR1	WARDHA - 400KV - BUS 3	D	For Replacement of Old BHEL Insulators on gantries of element.	19-Jun-2024	7:00	19-Jun-2024	18:00	
211	979	PLANNED	OCC_579	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	19-Jun-2024	7:00	19-Jun-2024	13:00	
212	985	PLANNED	OCC_579	POWERGRID_WR1	AKOLA - 400KV - BUS-1 at Akola	D	For Replacement of Old BHEL Insulators on gantries of element.Each Feeder will be shifted on TBC one at time	19-Jun-2024	7:00	19-Jun-2024	20:00	
213	1006	PLANNED	OCC_579	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	D	For Replacement of Old BHEL Insulators on gantries of element.	19-Jun-2024	14:00	19-Jun-2024	20:00	
214	1007	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	19-Jun-2024	08:00	19-Jun-2024	18:00	Outage
215	1008	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	19-Jun-2024	09:00	19-Jun-2024	18:00	The said work is very mportant
216	1009	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	For routine maintenance work	19-Jun-2024	09:00	19-Jun-2024	18:00	NA
217	1010	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Diagnostic Testing of Line CVT	19-Jun-2024	10:00	19-Jun-2024	17:30	400kV Koradi-II-HEPL Ckt. Will be service as alternate soucre
218	1011	PLANNED	OCC_579	MSLDC_OUTAGE	TIE BAY - 765KV-AKOLA (2)-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	D	Diagnostic Testing and Maintenance Works	19-Jun-2024	10:00	19-Jun-2024	18:00	765kV Akola 2 Tie bay , buy no. 702
175	777	PLANNED	OCC_579	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2	D	For AMP Work	20-Jun-2024	7:00	20-Jun-2024	18:00	Line Owned By ADANI TRANS
219	1023	PLANNED	OCC_579	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element.	20-Jun-2024	7:00	20-Jun-2024	13:00	
220	1030	PLANNED	OCC_579	POWERGRID_WR1	MAIN BAY - 220KV-AURANGABAD-CHITEGAON-2 AND AURANGABAD - 220KV - BUS 1 at AURANGABAD - 220KV	D	For AMP	20-Jun-2024	7:00	20-Jun-2024	18:00	206
221	1031	PLANNED	OCC_579	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	D	For Conductor strands snap rectification	20-Jun-2024	7:00	20-Jun-2024	18:00	For Conductor strands snap rectification
222	1036	PLANNED	OCC_579	POWERGRID_WR1	AKOLA - 400KV - BUS-2 at Akola	D	For Replacement of Old BHEL Insulators on gantries of element.Each Feeder will be shifted on TBC one at time	20-Jun-2024	7:00	20-Jun-2024	20:00	
223	1051	PLANNED	OCC_579	POWERGRID_WR2	MAIN BAY - 400KV-TARAPUR 3&4-BOISAR-2 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	D	AMP	20-Jun-2024	9:00	20-Jun-2024	17:30	PG-WR2-BOISAR
224	1063	PLANNED	OCC_579	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element.	20-Jun-2024	14:00	20-Jun-2024	20:00	
225	1064	PLANNED	OCC_579	MSLDC_OUTAGE	LONIKHAND-II - 400KV - BUS 1	D	Testing of 400kV Busbar protection.	20-Jun-2024	06:00	20-Jun-2024	18:00	Bus outage is not required. Only protection out required.
226	1065	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance work	20-Jun-2024	08:00	20-Jun-2024	18:00	400kV Ektuni ckt I&II,400kV Bhusawal,400kv Aurangabad and Dhule II will be in service
227	1066	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	20-Jun-2024	08:00	20-Jun-2024	18:00	Outage
228	1067	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	In view of outage on 400 KV Dhule Ckt I for Line maintenance work.Only AR will be in Non Auto	20-Jun-2024	08:00	20-Jun-2024	18:00	Only AR will be in Non Auto Line will be in service.
229	1068	PLANNED	OCC_579	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Maintenance of bay equipment At Akola SS	20-Jun-2024	10:00	20-Jun-2024	13:00	BAY OUTAGE
230	1069	PLANNED	OCC_579	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Maintenance of Bay equipment at Akola SS	20-Jun-2024	15:00	20-Jun-2024	18:00	BAY OUTAGE
231	1071	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	Cold line washing of insulators.	20-Jun-2024	20:00	21-Jun-2024	6:00	-
232	1073	PLANNED	OCC_579	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-2	C	Overhauling of pantograph isolator of bus-2 and auxliary bus at Chandrapur MSETCL SS, AMP works & CVT replacement at Bhadrawati end. AR in non auto mode CKT#1	20-Jun-2024	8:00	22-Jun-2024	20:00	
233	1077	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	For PID testing work. Only AR to be kept off.Line will be in service	20-Jun-2024	08:00	30-Jun-2024	18:00	line will in system only AR Out

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks		
234	1078	PLANNED	OCC_579	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-4	C	FOR ATTENDING SF6 GAS LEAKAGE WORK IN 406GD 6R SPACER	21-Jun-2024	7:00	23-Jun-2024	18:00	GAS LEAKAGE IDENTIFIED IN LINE GIB COMPARTMENT , LINE OUTAGE IS REQUIRED.
239	1083	PLANNED	OCC_579	POWERGRID_WRI	PUNE-PG - 400KV - BUS 2	C	For Conductor Replacment works	21-Jun-2024	10:00	23-Jun-2024	18:00	Subject to same dia apposite Main Bay of 400kV BUS-1 Load carrying Limit to below 1550 AMP
241	1093	PLANNED	OCC_579	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1	D	For AMP	21-Jun-2024	7:00	21-Jun-2024	18:00	412L
242	1094	PLANNED	OCC_579	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2	D	AR IN NON AUTO to faciliate Line Shutdown works.	21-Jun-2024	7:00	21-Jun-2024	18:00	
243	1108	PLANNED	OCC_579	POWERGRID_WRI	220KV-SOLAPUR-JEUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	21-Jun-2024	8:00	21-Jun-2024	18:00	
244	1129	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance work	21-Jun-2024	08:00	21-Jun-2024	18:00	400kV Ektuni ckt I&II,400kV Bhusawal,400kV Aurangabad and Dhule I will be in service
245	1130	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	In view of outage on 400 KV Dhule Ckt I for Line maintenance work.Only AR will be in Non Auto	21-Jun-2024	08:00	21-Jun-2024	18:00	Only AR will be in Non Auto.Line will be in service.
246	1131	PLANNED	OCC_579	MSLDC_OUTAGE	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND EKTUNI - 765KV - BUS 2	D	Diagnostic Testing and Maintenance Works	21-Jun-2024	10:00	21-Jun-2024	18:00	765kV Akola II Main Bay outage
247	1135	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	C	Hot line washing of Loc No. 80-98(93 strings) of 400 kV Lonikand-1-Talegaon(PGCIL) line	21-Jun-2024	10:00	22-Jun-2024	17:00	-
236	1080	PLANNED	OCC_579	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-3	D	For AMP Work	22-Jun-2024	10:00	22-Jun-2024	18:00	Line Owned By ADANI TRANS
240	1088	PLANNED	OCC_579	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-3	C	FOR ATTENDING SF6 GAS LEAKAGE WORK IN 407GD 7R ,7B SPACER	22-Jun-2024	7:00	22-Jun-2024	18:00	GAS LEAKAGE IDENTIFIED IN LINE GIB COMPARTMENT , LINE OUTAGE IS REQUIRED.
248	1143	PLANNED	OCC_579	POWERGRID_WRI	AURANGABAD - 400KV - BUS 1	D	For AMP	22-Jun-2024	7:00	22-Jun-2024	18:00	400kV BUS_1
249	1160	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work	22-Jun-2024	08:00	22-Jun-2024	18:00	400kV Padghe I will be in service
250	1163	PLANNED	OCC_579	POWERGRID_WRI	765KV/400KV PADGHE-PG-ICT-2	C	Interconnection of newly constructed Auxiliary Bus with existing Auxiliary Bus . (New Construction works)	22-Jun-2024	7:00	24-Jun-2024	17:00	
251	1167	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	for shifting/ height rising work MMRDA Katai naka bridge work.	22-Jun-2024	00:00	29-Jun-2024	12:00	for shifting/ height rising work MMRDA Katai naka bridge work.
252	1173	PLANNED	OCC_579	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	D	220kV A-Bus Isolator R/M Works. 220kV A-Bus connected line/equipment: Viraj Line: 181A/ 37MW	23-Jun-2024	07:00	23-Jun-2024	20:00	1) During the outage, all Elements / Lines will be in service through 220kV B-Bus. 2) Due to A-Bus Isolator alignment issue of 220kV PGCIL -
253	1174	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in routine patrolling and to replace faulty PID insulator strings and Insuator strings under R&M work at Junner S-Dn.	23-Jun-2024	08:00	23-Jun-2024	18:00	400kV Babhaleshwar-Padghe Ckt 2 will be available.
254	1175	PLANNED	OCC_579	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	D	Six monthly changeover of Spare-Ph Reactor to be taken in service in place of B-Ph Reactor as per CEA regulation at Koradi-III SS. Last changeover date 07.01.2024	23-Jun-2024	09:00	23-Jun-2024	14:00	765KV-AKOLA (2)-KORADI-III-1 will remain in service without L.R. Changeover from Spare-Ph reactor to B-Phase Reactor on dated 07.01.2024
255	1176	PLANNED	OCC_579	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1 L/ R@ KORADI-III - 765KV	D	Six monthly changeover of Spare-Ph Reactor to be taken in service in place of B-Ph Reactor as per CEA regulation at Koradi-III SS. Last changeover date 07.01.2024	23-Jun-2024	09:00	23-Jun-2024	14:00	Line Reactor Outage. Last changeover date 07.01.2024
256	1177	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Attending Damaged Conductor at Loc. No. 76-77.	23-Jun-2024	09:00	23-Jun-2024	17:00	Simultaneously outage is required on 220kV PGCIL - Borivali Line (for safety purpose)
257	1178	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Outage is required for safety purpose during Attending Damaged Conductor at Loc. No. 76-77 of 220kV Tarapur - Borivali Line.	23-Jun-2024	09:00	23-Jun-2024	17:00	Outage is required for safety purpose during Attending Damaged Conductor at Loc. No. 76-77 of 220kV Tarapur - Borivali Line.
237	1081	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Quarterly Maintenance Work	24-Jun-2024	09:00	24-Jun-2024	18:00	Monday is load Staggering day
258	1188	PLANNED	OCC_579	POWERGRID_WRI	765KV-PUNE-GIS-SOLAPUR-1	D	Line terminal equipments AMP in Substation & Rectification of Shutdown defects in Transmission line at 765kV Solapur end.	24-Jun-2024	7:00	24-Jun-2024	18:00	
259	1195	PLANNED	OCC_579	POWERGRID_WRI	220KV-PARLI-OSMANABAD-M-1	D	AMP of Line bay & Bay	24-Jun-2024	8:00	24-Jun-2024	18:00	AMP of Line bay & Bay
260	1212	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1. For Replacement of Flashover Disc 2. Fixing of Turbo Wind Bird Guard.	24-Jun-2024	09:00	24-Jun-2024	17:00	Outage
261	1213	PLANNED	OCC_579	MEGPTCL	TIE BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-AKOLA (2)-EKTUNI-1 at AKOLA (2) - 765KV	D	Maintenance of bay equipment at Akola SS	24-Jun-2024	10:00	24-Jun-2024	13:00	BAY OUTAGE
262	1214	PLANNED	OCC_579	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Maintenance of Bay Equipment's At Akola SS	24-Jun-2024	15:00	24-Jun-2024	18:00	BAY OUTAGE

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks		
263	1223	PLANNED	OCC_579	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV - BUS 2	C	Insulator cleaning work. 400kV PG Isolator alignment and maintenance work.	24-Jun-2024	10:00	29-Jun-2024	18:00	Load will be managed form Main bus -2. For maintenance of PG isolator 400kv feeders needs to be shifted on TBC one by one
264	1258	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.	25-Jun-2024	00:00	25-Jun-2024	12:00	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.
265	1259	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	BUS PT Capacitance and tan D testing	25-Jun-2024	08:00	25-Jun-2024	18:00	All feeders and ICT's on Main Bus II will be shifted on Main Bus I through TBC
266	1260	PLANNED	OCC_579	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of CB & CT at Koradi-III SS.	25-Jun-2024	09:00	25-Jun-2024	18:00	Bay Outage
267	1261	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	CT and CB diagnostic testing work along with relay testing work.	25-Jun-2024	11:00	25-Jun-2024	18:00	Outage required for routine diagnostic testing work
268	1263	PLANNED	OCC_579	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	FOR ERECTION OF LINE GIB COMPARTMENT FOR ICT IN VICINITY OF 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	25-Jun-2024	7:00	26-Jun-2024	20:00	OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI 5S93
269	1299	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.	26-Jun-2024	00:00	26-Jun-2024	12:00	For removing from ERS for shifting/ height rising work in between loc. 178-180 for NHSRCL work.
270	1300	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	26-Jun-2024	08:00	26-Jun-2024	18:00	Outage
271	1301	PLANNED	OCC_579	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Diagnostic Testing and Maintenance Works	26-Jun-2024	09:00	26-Jun-2024	19:00	ICT I UNIT OUTAGE.
272	1302	PLANNED	OCC_579	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Maintenance of Bay equipments at Akola SS	26-Jun-2024	10:00	26-Jun-2024	13:00	BAY OUTAGE
273	1303	PLANNED	OCC_579	MSLDC_OUTAGE	BALE - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	26-Jun-2024	10:00	26-Jun-2024	18:00	NIL Breaker of PGCIL line at Bale End will be made off
274	1304	PLANNED	OCC_579	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	D	Maintenance of Bay equipments ay Akola SS	26-Jun-2024	15:00	26-Jun-2024	18:00	BAY OUTAGE
238	1082	PLANNED	OCC_579	POWERGRID_WRI	RAIGARH-PS - 765KV - BUS 2	C	Const. of ICT- 5&6	27-Jun-2024	9:00	30-Jun-2024	18:00	Commissioning of new Champa Main bay-710
275	1314	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	DT Work & Bay Maintenance	27-Jun-2024	5:00	27-Jun-2024	10:00	-
276	1318	PLANNED	OCC_579	POWERGRID_WRI	AURANGABAD - 400KV - BUS 2	D	For AMP	27-Jun-2024	7:00	27-Jun-2024	18:00	400kV BUS_2
277	1342	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	27-Jun-2024	08:00	27-Jun-2024	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
278	1343	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	27-Jun-2024	08:00	27-Jun-2024	18:00	Outage
279	1344	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	27-Jun-2024	09:00	27-Jun-2024	18:00	The said work is very mportant
280	1345	PLANNED	OCC_579	MSLDC_OUTAGE	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	D	Back up relay testing	27-Jun-2024	10:00	27-Jun-2024	16:00	400 KV Main Bus I and II will be separated
235	1079	PLANNED	OCC_579	POWERGRID_WRI	PUNE-GIS - 400KV - BUS 1	C	400 kV GIS BUS MODULE CONNECTION WITH EXISTING 400 kV BUS-1, SIMULTENEOUS OUTAGE OF 400 KV PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED ,(400/220 kV GIS EXTENSION WORK)	28-Jun-2024	9:00	30-Jun-2024	18:00	OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI 5S93
281	1366	PLANNED	OCC_579	POWERGRID_WRI	PARLI - 220KV - BUS 2	D	For AMP. Each Feeder will be shifted on TBC one at time	28-Jun-2024	8:00	28-Jun-2024	18:00	For AMP of Bus
282	1367	PLANNED	OCC_579	POWERGRID_WRI	765KV-AURANGABAD-SOLAPUR-2 L/R@ SOLAPUR - 765KV	D	PRV NC contact modification	28-Jun-2024	8:00	28-Jun-2024	18:00	
283	1373	PLANNED	OCC_579	POWERGRID_WRI	TIE BAY OF 765KV/400KV PADGHE-PG-ICT-3 AND 400KV-PADGHE-PG-KHARGHAR-1 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	D	For termination of Kharghar line at the gantry	28-Jun-2024	9:00	28-Jun-2024	17:00	
284	1374	PLANNED	OCC_579	POWERGRID_WRI	MAIN BAY OF 400KV-PADGHE-PG-KHARGHAR-1 AND PADGHE-PG - 400KV - BUS 1 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	D	For termination of Kharghar line at the gantry	28-Jun-2024	9:00	28-Jun-2024	17:00	
285	1388	PLANNED	OCC_579	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	132kV Kanhan- Pench ckt ON and OFF operation required for black start activity	28-Jun-2024	08:00	28-Jun-2024	18:00	NA
286	1389	PLANNED	OCC_579	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at Badnera S/s"	28-Jun-2024	09:00	28-Jun-2024	17:00	Outage
287	1390	PLANNED	OCC_579	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Maintenance of Bay equipment's At Akola SS	28-Jun-2024	10:00	28-Jun-2024	13:00	BAY OUTAGE

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
288	1392	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	Cold line washing	28-Jun-2024	22:00	29-Jun-2024	06:00	
289	1401	PLANNED	OCC_579	POWERGRID_WRI	400KV-ALKUD-SOLAPUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	29-Jun-2024	8:00	29-Jun-2024	18:00	
290	1402	PLANNED	OCC_579	POWERGRID_WRI	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	PRV NC contact modification and Line Reactor AMP works at 765kV Solapur Substation. Note: Dia to be kept open	29-Jun-2024	8:00	29-Jun-2024	18:00	
291	1405	PLANNED	OCC_579	POWERGRID_WRI	TIE BAY OF PADGHE-PG - 400KV B/R 1 AND 400KV-PADGHE-PG-KHARGHAR-2 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	D	For termination of Khargarh line at the gantry	29-Jun-2024	9:00	29-Jun-2024	17:00	
292	1406	PLANNED	OCC_579	POWERGRID_WRI	MAIN BAY OF 400KV-PADGHE-PG-KHARGHAR-2 AND PADGHE-PG - 400KV - BUS 1 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	D	For termination of Khargarh line at the gantry	29-Jun-2024	9:00	29-Jun-2024	17:00	
293	1414	PLANNED	OCC_579	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Bus CVT tan D testing	29-Jun-2024	08:00	29-Jun-2024	18:00	All feeders and ICT on Main Bus II will be shifted on Main Bus I through TBC
294	1415	PLANNED	OCC_579	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of CB & CT at Koradi-III SS.	29-Jun-2024	09:00	29-Jun-2024	18:00	Bay Outage
295	1422	PLANNED	OCC_579	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	D	220kV B-Bus Isolator R/M Works. 220kV B-Bus connected line/equipment: Ghodbandar Line: 459A/ 161MW Borivali Line: 435/ 161MW. Versova Line: 315A/ 116MW PGCIL 1 Line :696A/ 272MW PGCIL 3 Line :855A/ 318MW 100MVA, PTR2: 151A/ 55MW 200MVA, ICT1 : 300A/ 110MW	30-Jun-2024	07:00	30-Jun-2024	20:00	During the outage, all Elements / Lines will be in service through 220kV A-Bus.
296	1423	PLANNED	OCC_579	MEGPTCL	765KV-TIRODA-KORADI-III-2 L/R@ KORADI-III - 765KV	D	Six monthly changeover of Y-Ph Reactor to be taken in service in place of Spare-ph Reactor as per CEA regulation at Koradi-III SS. Last changeover date 10.01.2024	30-Jun-2024	09:00	30-Jun-2024	14:00	Line Reactor Outage. Last changeover date 10.01.2024
297	1424	PLANNED	OCC_579	MEGPTCL	765KV-TIRODA-KORADI-III-2	D	Six monthly changeover of Y-Ph Reactor to be taken in service in place of Spare-ph Reactor as per CEA regulation at Koradi-III SS. Last changeover date 10.01.2024	30-Jun-2024	09:00	30-Jun-2024	14:00	765KV-TIRODA-KORADI-III-2 will remain in service without L.R.Changeover from Y-Ph reactor to Spare-Phase Reactor on dated 10.01.2024
298	1425	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Line Disc Replacement works along with nut bolt tightening at various locations	30-Jun-2024	09:00	30-Jun-2024	18:00	Line Disc Replacement works along with nut bolt tightening at various locations
299	1426	PLANNED	OCC_579	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Diagnostic Testing and Maintenance Works	30-Jun-2024	09:00	30-Jun-2024	19:00	ICT II OUTAGE
300	1427	PLANNED	OCC_579	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	To attend defects identified in routine patrolling and to replace faulty PID insulator strings and Insuator strings under R&M work at Junner S-Dn.	30-Jun-2024	22:00	1-Jul-2024	6:00	400kV Babhaleshwar-Padghe Ckt 1 will be available.

State Element outage list for the month of JUNE'2024

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	BUS REACTOR (125MVAr) @ WARORA	01-Jun-24	08:00	01-Jun-24	17:00	Daily	Routine and Premonsoon maintenance work.	MSETCL	MSETCL	Reactor kept in OFF position., Tie Bay No. 403 also kept in OFF position.
2	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	03-Jun-24	08:00	03-Jun-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
3	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	04-Jun-24	08:00	05-Jun-24	18:00	Continuous	1.Measurement of tandelta of Bushing & winding. 2.Measurement of tandelta & capacitance of CT. 3.Premonsoon maintenance work of ICT. 4. Bay routine maintenance work.	MSETCL	MSETCL	During outage 400/220/33KV 315MVA ICT-1 will be in service.
4	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	04-Jun-24	10:00	04-Jun-24	17:00	Daily	Hot line washing of Bay Equipments for ICT-1 Bay	MSETCL	MSETCL	-
5	400 KV	BUS REACTOR (125 MVAr) @ ALKUD	05-Jun-24	10:00	05-Jun-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
6	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	05-Jun-24	10:00	05-Jun-24	13:30	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
7	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	05-Jun-24	14:00	05-Jun-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
8	400 KV	TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	05-Jun-24	10:00	05-Jun-24	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
9	400 KV	KORADI - KHAPERKHEDA CKT - 1	05-Jun-24	08:00	05-Jun-24	15:00	Daily	DCRM,CB Timing & CRM of Main & Tie CB	MSETCL	MSETCL	NA
10	400 KV	NEW KOYNA - STAGE IV CKT - 2	05-Jun-24	08:00	05-Jun-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
11	400 KV	TBC @ KORADI-1	05-Jun-24	07:00	05-Jun-24	17:00	Daily	DFRA, CT / BUSHING / WINDING TANDELTA, RELAY TESTING	MSETCL	MSETCL	Outage time may be varied as per site & weather condition.
12	400 KV	WARORA - IEPL	05-Jun-24	09:00	05-Jun-24	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
13	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	05-Jun-24	10:00	05-Jun-24	17:00	Daily	Hot line washing of Bay Equipments for ICT-2 Bay	MSETCL	MSETCL	-
14	400 KV	WARORA - IEPL	06-Jun-24	08:00	06-Jun-24	17:00	Daily	Line CT, CVT Tan delta, IR values & Routine maintenance and and isolater maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
15	400 KV	167 MVA SPARE ICT @ TALANDGE	06-Jun-24	09:00	06-Jun-24	16:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Monday is load staggering day Load affected nil
16	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	06-Jun-24	10:00	06-Jun-24	18:00	Daily	DCRM of 410 CB and Routine maintenance & Relay Testing work.	MSETCL	MSETCL	-
17	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	06-Jun-24	06:00	06-Jun-24	18:00	Daily	Diagnostic testing and Pre Mansoon Maintenance	MSETCL	MSETCL	-
18	400 KV	MAIN Bay - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	06-Jun-24	06:00	06-Jun-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
19	400 KV	LONIKAND - JEJURI CKT - 1	06-Jun-24	08:00	06-Jun-24	18:00	Daily	DT Work & Bay Maintenance Also DT and Line Maintenance activities	MSETCL	MSETCL	-

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	LONIKAND - JEJURI CKT - 1	06-Jun-24	09:30	06-Jun-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-2, 400 kV Jejuri-Karad & 400 kV Jejuri-Koyna ST-IV will continue to remain in service
21	400 KV	LONIKAND I - KOYNA STAGE-IV	06-Jun-24	09:00	06-Jun-24	17:00	Daily	PID Faulty string replacement work	MSETCL	MSETCL	PID Faulty disc Replacement work.
22	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	06-Jun-24	10:00	06-Jun-24	17:00	Daily	Hot line washing of Bay Equipments for ICT-3 Bay	MSETCL	MSETCL	-
23	400 KV	105 MVA SPARE ICT @ CHAKAN	06-Jun-24	10:00	06-Jun-24	17:00	Daily	Hot line washing of Bay Equipments for Spare ICT Bay	MSETCL	MSETCL	-
24	400 KV	NEW KOYNA-KARAD CKT - 1	07-Jun-24	09:00	07-Jun-24	17:00	Daily	PID Faulty disc replacement work	MSETCL	MSETCL	PID Faulty disc replacement work
25	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	07-Jun-24	08:00	08-Jun-24	18:00	Continuous	1.Measurement of tandelta of Bushing & winding.. 2.Premonsoon maintenance work of ICT. 3. Bay routine maintenance work.	MSETCL	MSETCL	During outage 400/220/33KV (3*105)MVA ICT-2 will be in service.
26	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	07-Jun-24	10:00	07-Jun-24	18:00	Daily	Routine Maintenance and Diagnostic Testing work.	MSETCL	MSETCL	NIL
27	400 KV	KORADI - KHAPERKHEDA CKT - 2	07-Jun-24	07:00	07-Jun-24	14:00	Daily	CT TAN DELTA TEST	MSETCL	MSETCL	Outage time may be varied as per site & weather condition.
28	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	07-Jun-24	07:00	07-Jun-24	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
29	400 KV	CHANDRAPUR - KHAPERKHEDA	07-Jun-24	06:00	07-Jun-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	na
30	400 KV	GT-8 @ KORADI-2	07-Jun-24	10:00	07-Jun-24	19:30	Daily	Diagnostic Testing of Line CT & Syn CVT	MSETCL	MSETCL	NOC required from Mahagenco
31	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	08-Jun-24	10:00	08-Jun-24	18:00	Daily	Routine Maintenance and DT.	MSETCL	MSETCL	-
32	400 KV	NEW KOYNA-KARAD CKT - 2	08-Jun-24	09:00	08-Jun-24	17:00	Daily	PID Faulty disc replacement work	MSETCL	MSETCL	PID Faulty disc replacement work
33	400 KV	KORADI - KHADKA	08-Jun-24	09:00	08-Jun-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per annual outage plan
34	400 KV	400/220/33 KV 501MVA ICT - 5 @ BABHALESHWAR	08-Jun-24	09:00	08-Jun-24	18:00	Daily	Bushing tan D testing work and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III and IV will be in service
35	400 KV	KARAD - TALANDGE CKT - 1	10-Jun-24	08:00	10-Jun-24	17:00	Daily	PID Faulty disc replacement work	MSETCL	MSETCL	PID Faulty disc replacement work
36	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	10-Jun-24	08:00	10-Jun-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
37	400 KV	MAIN BAY (403) of WALUJ @ TAPTITANDA	11-Jun-24	11:00	11-Jun-24	18:00	Daily	Outage required on all the three bays 401 , 402 , 403 simultaneously for routine maintenance and testing work.	MSETCL	MSETCL	Outage required on all the three bays 401 , 402 , 403 simultaneously for routine maintenance and testing work.
38	400 KV	SPARE LINE-1 BAY (401) @ TAPTITANDA	11-Jun-24	11:00	11-Jun-24	18:00	Daily	Outage required on all the three bays 401 , 402 , 403 for routine maintenance, testing work.	MSETCL	MSETCL	Outage required on all the three bays 401 , 402 , 403 simultaneously.
39	400 KV	TIE BAY (402) of WALUJ @ TAPTITANDA	11-Jun-24	11:00	11-Jun-24	18:00	Daily	Outage required on all the three bays 401 , 402 , 403 for routine maintenance and testing work.	MSETCL	MSETCL	Outage required on all the three bays 401 , 402 , 403 simultaneously for routine maintenance and testing work.
40	400 KV	KARAD - TALANDGE CKT - 2	11-Jun-24	08:00	11-Jun-24	17:00	Daily	PID Faulty disc replacement work	MSETCL	MSETCL	PID Faulty disc replacement work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	STATION TF No 5 @ CHANDRAPUR GCR	11-Jun-24	08:00	12-Jun-24	18:00	Continuous	1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators.	MSETCL	MSETCL	During outage 400KV STN TF-4 will be in service.
42	400 KV	NEW KOYNA - STAGE IV CKT - 1	12-Jun-24	08:00	12-Jun-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
43	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	13-Jun-24	6:00	13-Jun-24	12:00	Daily	Line maintenance work	MSETCL	MSETCL	to avoid tripping
44	400 KV	JEJURI- KOYNA STAGE-IV	13-Jun-24	6:00	13-Jun-24	12:00	Daily	PID Faulty disc replacement work	MSETCL	MSETCL	PID Faulty disc replacement work
45	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	13-Jun-24	13:00	13-Jun-24	22:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
46	400 KV	BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR	13-Jun-24	10:00	13-Jun-24	16:00	Daily	Excitation current testing work	MSETCL	MSETCL	Reactor is off during day hours
47	400 KV	LONIKAND I - KOYNA STAGE-IV	13-Jun-24	13:00	13-Jun-24	22:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
48	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	13-Jun-24	06:00	13-Jun-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
49	400 KV	400/220kV SPARE ICT @ JEJURI	13-Jun-24	09:30	13-Jun-24	18:00	Daily	For RRS Trials work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
50	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	13-Jun-24	09:30	13-Jun-24	18:00	Daily	For RRS Trials work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
51	400 KV	MAIN BAY (419) OF 400/220/33kV 500MVA ICT-I @ LONIKAND 2	13-Jun-24	06:00	13-Jun-24	18:00	Daily	Diagnostic testing and Pre Monsoon Maintenance	MSETCL	MSETCL	-
52	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	13-Jun-24	6:00	13-Jun-24	12:00	Daily	line maintenance activity	MSETCL	MSETCL	to avoid tripping
53	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	14-Jun-24	10:00	14-Jun-24	18:00	Daily	DCRM of 411 CB and Routine maintenance & Relay Testing work.	MSETCL	MSETCL	-
54	400 KV	NEW KOYNA-KARAD CKT - 1	14-Jun-24	08:00	14-Jun-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
55	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	14-Jun-24	10:00	14-Jun-24	18:00	Daily	Routine Maintenance and Diagnostic Testing Work.	MSETCL	MSETCL	NIL
56	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	14-Jun-24	07:00	14-Jun-24	15:00	Daily	DFRA	MSETCL	MSETCL	Outage time may be varied as per site & weather condition.
57	400 KV	KORADI II - IEPL	14-Jun-24	10:00	14-Jun-24	17:30	Daily	Diagnostic Testing of Line CVT	MSETCL	MSETCL	400kV Koradi-II-Wardha Ckt. Will be service as alternate source
58	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	14-Jun-24	08:00	14-Jun-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
59	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	14-Jun-24	06:00	14-Jun-24	13:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA
60	400 KV	KHADKA - BABLESHWAR	14-Jun-24	13:00	14-Jun-24	22:00	Daily	Routine Line maintenance work;LBB relay testing	MSETCL	MSETCL	400kV Aurangabad ,400kV Dhule ckt I&II, Ektuni I&II will be in service
61	400 KV	CHANDRAPUR-PARLI CKT-3	14-Jun-24	08:00	15-Jun-24	18:00	Daily	1.Measurement of tandelta of Bushing of 50MVar Line shunt Reactor. 2.Premonsoon maintenance work of Reactor.3.	MSETCL	MSETCL	During outage 400KV CHD-2 CKT-1 & 2 400KV Khaperkheda, 400KV HVDC CKT-1 &2, 400KV PGCIL CKT-1,2,3&4 will be in
62	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	15-Jun-24	09:00	15-Jun-24	18:00	Daily	HV CT tand Testing and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV and V will be in service
63	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	15-Jun-24	07:00	15-Jun-24	13:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
64	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	15-Jun-24	09:00	15-Jun-24	18:00	Daily	line mainteance work	MSETCL	MSETCL	to avoid tripping
65	400 KV	400/220 KV 500 MVA ICT @ ALKUD	17-Jun-24	10:00	17-Jun-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	Load will be managed on 400KV Talandge & Karad substations
66	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	17-Jun-24	10:00	17-Jun-24	14:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
67	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	18-Jun-24	09:00	18-Jun-24	18:00	Daily	line maintenance work	MSETCL	MSETCL	to avoid tripping
68	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	18-Jun-24	07:00	18-Jun-24	14:00	Daily	Diagnostic testing and routine maintenance work	MSETCL	MSETCL	Outage required for above work
69	400 KV	NEW KOYNA-KARAD CKT - 2	18-Jun-24	08:00	18-Jun-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
70	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	18-Jun-24	07:00	18-Jun-24	14:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
71	400 KV	Main bay (406) of Deepnagar line @ Taptitanda	18-Jun-24	11:00	18-Jun-24	18:00	Daily	CB diagnostic testing work.	MSETCL	MSETCL	CB diagnostic testing work.
72	400 KV	FUTURE CKT - 1 @ WARORA	20-Jun-24	08:00	20-Jun-24	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
73	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	20-Jun-24	10:00	20-Jun-24	18:00	Daily	Routine Maintenance and DT.	MSETCL	MSETCL	-
74	400 KV	JEJURI - KARAD	20-Jun-24	6:00	20-Jun-24	12:00	Daily	PID Faulty disc replacement work	MSETCL	MSETCL	PID Faulty disc replacement work
75	400 KV	JEJURI - KARAD	20-Jun-24	6:00	20-Jun-24	12:00	Daily	For AR trials and Maintenance & Testing work	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-2, 400 kV Jejuri-Lonikand Ckt-1 & 400 kV Jejuri-Koyna ST-IV will continue to remain in service
76	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	20-Jun-24	09:00	20-Jun-24	18:00	Daily	line maintenance activity	MSETCL	MSETCL	to avoid tripping
77	400 KV	JEJURI- KOYNA STAGE-IV	20-Jun-24	12:00	20-Jun-24	22:00	Daily	DT and Line Maintenance activities	MSETCL	MSETCL	-
78	400 KV	JEJURI- KOYNA STAGE-IV	20-Jun-24	12:00	20-Jun-24	22:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
79	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	20-Jun-24	10:00	20-Jun-24	18:00	Daily	DCRM of 403 CB.	MSETCL	MSETCL	-
80	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	20-Jun-24	08:00	20-Jun-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
81	400 KV	400 KV FUTURE BAY II @ WARORA	21-Jun-24	08:00	21-Jun-24	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
82	400 KV	105 MVA SPARE ICT @ AKOLA	21-Jun-24	07:00	21-Jun-24	14:00	Daily	Diagnostic testing and routine maintenance work	MSETCL	MSETCL	Outage required for above work
83	400 KV	400/220 KV 3X105 MVA ICT - 1 @ PADGHE	21-Jun-24	09:00	21-Jun-24	21:00	Daily	1) Bay maint work 2) Replacment of 33kV PT of all phase 3) RTV coating to IPS tube	MSETCL	MSETCL	weather conditions should be clear
84	400 KV	KHADKA-AURANGABAD (WALUJ)	22-Jun-24	09:00	22-Jun-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per outage plan
85	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	23-Jun-24	08:00	26-Jun-24	18:00	Continuous	CB pole overhauling work	MSETCL	MSETCL	400/220 KV ICT II HV will be in service through TBC
86	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	24-Jun-24	09:00	24-Jun-24	18:00	Daily	line maintenance activity	MSETCL	MSETCL	to avoid tripping
87	400 KV	LONIKAND - JEJURI CKT - 2	24-Jun-24	10:00	26-Jun-24	17:00	Continuous	Hot line washing of Loc. No. 417-400(72 strings), of 400 kV Lonikand-1-Jejuri Ckt-II	MSETCL	MSETCL	-
88	400 KV	AKOLA - KHADKA (BHUSAWAL)	25-Jun-24	09:00	25-Jun-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per annual outage plan.

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
89	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	25-Jun-24	09:00	25-Jun-24	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
90	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	26-Jun-24	08:00	26-Jun-24	18:00	Daily	Routine Line maintenance work;LBB relay testing	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
91	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	26-Jun-24	09:00	26-Jun-24	18:00	Daily	Line maintenance activity	MSETCL	MSETCL	to avoid tripping
92	400 KV	JEJURI- KOYNA STAGE-IV	27-Jun-24	11:00	27-Jun-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-2, 400 kV Jejuri-Lonikand Ckt-1 & 400 kV Jejuri-Karad will continue to remain in service
93	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	27-Jun-24	10:00	27-Jun-24	18:00	Daily	Routine Maintenance and DT.	MSETCL	MSETCL	-
94	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	27-Jun-24	10:00	27-Jun-24	18:00	Daily	DCRM of 407 CB.	MSETCL	MSETCL	-
95	400 KV	JEJURI - KARAD	27-Jun-24	10:00	29-Jun-24	17:00	Continuous	Hot line washing of Loc. No 300-315(134 strings). of 400 kV Jejuri-Karad	MSETCL	MSETCL	-
96	400 KV	GT-9 @ KORADI-2	28-Jun-24	10:00	28-Jun-24	17:30	Daily	Diagnostic Testing of Line CT & Syn CVT	MSETCL	MSETCL	NOC required from Mahagenco
97	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	28-Jun-24	09:00	28-Jun-24	18:00	Daily	Line maintenace activity	MSETCL	MSETCL	to avoid tripping
98	400 KV	KHADKA- DEEPNAGAR CKT 1	29-Jun-24	09:00	29-Jun-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per outage plan.