

WRPC OCCM approved Monthly Outage list for the Month of Jul'2018

Sr.no.	OCCM Sr. No	Voltage Rating	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
1	9	400KV	Aurangabad-Boisar # 2 Outage & Aurangabad-Boisar # Ckt # 1 into N/A mode	01/Jul/18	9:00	01/Jul/18	18:00	Daily	Installation of pilot string at one location.	POWERGRID	WR-II	R
2	10	400KV	PADGHE - KALWA 1	01/Jul/18	09:00	01/Jul/18	18:00	Daily	Maintenance & testing work.	MSETCL	MSETCL	--
3	16	400KV	PARLI-SOLAPUR (LAMBOTI)	01/Jul/18	10:00	31/Jul/18	18:00	Daily	For PID Work	MSETCL	MSETCL	Line will be in service only A/R in Non Auto mode
4	32	400KV	400kV Akola-1 LR atAurangabad	02/Jul/18	9:00	02/Jul/18	18:00	Daily	For AMP works, line will charge with out LR during this period , Line outage required for LR take out & take in to service.	WRTS-I	WRTS-I	R
5	41	400KV	KHADKA - BABLESHWAR	02/Jul/18	09:00	02/Jul/18	21:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400 kv Aurangabad Dhule-Ckt-1&2, Ektuni-ckt-1&2, will be in service
6	48	220KV	DEOLI(PGCIL)-BADNERA	02/Jul/18	08:00	07/Jul/18	17:00	Daily	For PID work, Shifting of auto reclose	MSETCL	MSETCL	-
7	51	400KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	02/Jul/18	08:00	13/Jul/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	--
8	52	220KV	PUSAD - WARDHA (PG)	02/Jul/18	10:00	31/Jul/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	--
9	57	400KV	SSNL - Dhule - 1	03/Jul/18	8:00	03/Jul/18	18:00	Daily	PMM work	NCA	GETCO	Auto reclose of Dhule - 2 will remain out
10	63	400KV	400kv Akola-2 LR atAurangabad	03/Jul/18	9:00	03/Jul/18	18:00	Daily	for AMP works,line will charge with out LR during this period , Line outage required for LR take out & take in to service.	WRTS-I	WRTS-I	R
11	70	400KV	400KV KOLHAPUR(MSETCL)-I & FUTURETIE BAY (408) at Kolhapur	03/Jul/18	10:00	03/Jul/18	18:00	DAILY	BAY AMP WORKS & Control circuitry check	WRTS-I	WRTS-I	R
12	74	400KV	CHANDRAPUR-PARLI CKT-3	03/Jul/18	07:00	03/Jul/18	19:00	Daily	For Replacement Missing of Earth wire .	MSETCL	MSETCL	--
13	82	400KV	SSNL - Dhule - 2	04/Jul/18	8:00	04/Jul/18	18:00	Daily	PMM work	NCA	GETCO	Auto reclose of Dhule - 1 will remain out
14	87	220KV	220KV Pandhurna Kalmeahwar	04/Jul/18	9:00	04/Jul/18	16:00	Daily	DPR relay testing and Maintenance of Equipment	MPPTCL	MPPTCL	R
15	91	765KV	765KV Wardha - Aurangabad (PG) III	04/Jul/18	9:00	04/Jul/18	18:00	Daily	for AMP works	WRTS-I	WRTS-I	R
16	102	400KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	04/Jul/18	09:00	04/Jul/18	17:00	Daily	Testing and maintenance work of line	MSETCL	MSETCL	--
17	103	220KV	KALMESHVAR-PANDHURNA	04/Jul/18	09:00	04/Jul/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
18	104	400KV	BUS COUPLER @ KARAD	04/Jul/18	10:00	04/Jul/18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on BUS I& II
19	105	220KV	DEOLI(PGCIL)-BADNERA	04/Jul/18	10:00	04/Jul/18	18:00	Daily	Suspension clamp and nut bolt tightening	MSETCL	MSETCL	--
20	144	400KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	05/Jul/18	08:00	05/Jul/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	--
21	145	400KV	LONIKAND 1 -JEJURI	05/Jul/18	09:00	05/Jul/18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Load will be fed from 400KV Koyna Stage IV line.
22	163	400KV	TIE BAY (428) OF WARORA @ WARDHA (PG)	06/Jul/18	09:00	10/Jul/18	17:00	Continuous	Routine Maintenance & Dignostic testing work and replacement of R-ph pole complete wiring.	MSETCL	MSETCL	--
23	168	400KV	MAIN BUS - 2 @ KUMBHARGAON (NANDED)	06/Jul/18	08:00	06/Jul/18	17:00	Daily	Annual Maintenance and Testing work	MSETCL	MSETCL	--
24	187	400KV	KALWA - KHARGHAR	06/Jul/18	08:00	06/Jul/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
25	188	400KV	MAIN BUS - 1 @ AKOLA	06/Jul/18	08:00	06/Jul/18	18:00	Daily	Isolator Maintenance work of 418 bay (89) Isolator and routine bus maintenance & testing work will be carried out in oppurtunity.	MSETCL	MSETCL	--
26	198	400KV	EKTUNI - BABLESHWAR CKT 1	07/Jul/18	09:00	07/Jul/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400 kv Bhusawal, Aurangabad Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
27	204	400KV	BUS COUPLER @ PARLI	07/Jul/18	09:00	07/Jul/18	17:00	Daily	CT and Breaker testing work.	MSETCL	MSETCL	--
28	221	400KV	400 KV Bus-1 and Bus-2 Bus bar prot.scheme@ 400 KV Khadka ss	07/Jul/18	08:00	07/Jul/18	17:00	Daily	400 KV Bus Bar testing work & integration of 400 KV 50 MVAr new reactor bay cabling work	MSETCL	MSETCL	Outage on 400 KV Bus-1 and Bus-2 Bus bar prot.scheme@ 400 KV Khadka ss
29	239	220KV	TALANDGE - CHIKODI	08/Jul/18	09:00	08/Jul/18	18:00	Daily	Maintenance & testing work.	MSETCL	MSETCL	--
30	271	400KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	09/Jul/18	09:00	09/Jul/18	17:00	Daily	hardware/Earth wire clamp n/b tightening Work Loc. No. 878,881	MSETCL	MSETCL	--
31	272	400KV	Akola II (Yelwan) - Akola I CKT - 1	09/Jul/18	09:00	09/Jul/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
32	278	220KV	DEOLI(PGCIL)-BADNERA	09/Jul/18	08:00	14/Jul/18	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	-
33	287	400KV	BABHALESHWAR - PADGHE 1	10/Jul/18	09:00	10/Jul/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400KV Babhaleshwar-Padghe-Ckt-2 will be in service
34	314	400KV	CHANDRAPUR 2 - WARORA CKT-1	10/Jul/18	08:00	10/Jul/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	--
35	316	400KV	KORADI-KHADKA	10/Jul/18	08:00	11/Jul/18	18:00	Daily	Restrtring between location 111-112	MSETCL	MSETCL	--
36	327	400KV	CHANDRAPUR 2 - WARORA CKT-2	11/Jul/18	08:00	11/Jul/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	--
37	334	400KV	400kv PADGHE (PG)-KUDUS (MSETCL)-I	11/Jul/18	8:00	11/Jul/18	18:00	Daily	For Taking Breaker CRM (for Main and TIE Bay) is to be taken by Removing IPS and cleaning the Breker PAD.	WRTS-I	WRTS-I	R
38	340	400KV	WARORA - Wardha(PG)	11/Jul/18	09:00	11/Jul/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
39	363	400KV	80 MVAr Bus reactor @ Talandge	11/Jul/18	09:00	11/Jul/18	18:00	Daily	Quarterly Maint.Work	MSETCL	MSETCL	--
40	364	220KV	DEOLI(PGCIL)-BADNERA	11/Jul/18	10:00	11/Jul/18	18:00	Daily	Suspension clamp and nut bolt tightening	MSETCL	MSETCL	--
41	368	400KV	LONIKAND 1 - TALEGAON (PGCIL)	12/Jul/18	08:00	12/Jul/18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	--
42	383	400KV	BABHALESHWAR - PADGHE 2	12/Jul/18	09:00	12/Jul/18	21:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400kv Babhaleshwar-Padghe-Ckt-1 will be in service
43	384	400KV	400kv PADGHE (PG)-KUDUS (MSETCL)-II	12/Jul/18	8:00	13/Jul/18	18:00	Daily	For Taking Breaker CRM (for Main and TIE Bay) is to be taken by Removing IPS and cleaning the Breker PAD.	WRTS-I	WRTS-I	R
44	409	400KV	MAIN BUS - 1 @ KUMBHARGAON (NANDED)	12/Jul/18	08:00	12/Jul/18	17:00	Daily	Annual Maintenance and Testing work	MSETCL	MSETCL	--
45	410	400KV	JEJURI- KOYNA STAGE-IV BY Pune zone	12/Jul/18	08:00	12/Jul/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	--

Sr.no.	OCCM Sr. No	Voltage Rating	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
46	412	400KV	AKOLA - KHADKA (BHUSAWAL)	12/Jul/18	12:00	14/Jul/18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
47	414	400KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR -1)	13/Jul/18	09:00	13/Jul/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Load will be manage on 400KV Interconnector II at 400KV Lonikand II substation
48	459	400KV	BABLESHWAR- AURANGABAD (WALUJ)	14/Jul/18	09:00	14/Jul/18	21:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
49	470	220KV	NASHIK - NAVSARI CKT - 1	14/Jul/18	08:00	14/Jul/18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
50	477	500 KV	CHANDRAPUR - PADGHE HVDC POLE 1	15/Jul/18	06:00	15/Jul/18	17:00	Daily	Broken Disc insulator replacement & hardware tightening work	MSETCL	MSETCL	--
51	488	400KV	CHANDRAPUR GCR - CHANDRAPUR HVDC - I	15/Jul/18	08:00	15/Jul/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work)	MSETCL	MSETCL	400 KV GCR- HVDC ckt No. - II will be in service.
52	489	400KV	PARLI(MS) - PARLI (PG) CKT -1	15/Jul/18	09:00	15/Jul/18	17:00	Daily	Testing and maintenance work of line	MSETCL	MSETCL	--
53	499	220KV	MUDSHINGI - CHIKODI	15/Jul/18	09:00	15/Jul/18	18:00	Daily	Maintenance & testing work.	MSETCL	MSETCL	
54	505	400KV	PARLI - LONIKAND 2 CKT 1	16/Jul/18	10:00	16/Jul/18	18:00	Daily	Hardware Tightening & Fitting Work At Loc No-107,112,95,154,170,	MSETCL	MSETCL	--
55	517	400KV	765KV SOLAPUR-PARLI 2	16/Jul/18	11:00	16/Jul/18	13:00	DAILY	FOR COMMISSIONING OF PLCC DTPC	WRTS-I	WRTS-I	C
56	522	400KV	NEW KOYNA - DABHOL - II	16/Jul/18	08:00	16/Jul/18	17:00	Daily	Routine Maintenance & Relay testing work	MSETCL	MSETCL	-
57	523	400KV	BUS COUPLER @ KOLHAPUR-III (TALANDGE)	16/Jul/18	09:00	16/Jul/18	18:00	Daily	Quarterly Maint.Work	MSETCL	MSETCL	--
58	524	400KV	Akola II (Yelwan) - Akola I CKT - 2	16/Jul/18	09:00	16/Jul/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
59	527	220KV	DEOLI(PGCIL)-BADNERA	16/Jul/18	08:00	21/Jul/18	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	--
60	528	400KV	CHANDRAPUR-PARLI CKT-3	16/Jul/18	08:00	31/Jul/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III lines are on DC tower so both lines require on same day A/R out.
61	529	400KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16/Jul/18	08:00	31/Jul/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III lines are on DC tower so both lines require on same day A/R out.
62	556	400KV	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	17/Jul/18	08:00	17/Jul/18	17:00	Daily	Bay 420 CB DCRM ,CRM,Timing and IR Values Testing works Isolater maintainance work .	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.
63	557	400KV	EKTUNI - BABLESHWAR CKT 2	17/Jul/18	09:00	17/Jul/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal, Aurangabad Dhule-Ckt-1&2, Ektuni-ckt-1, will be in service
64	584	400KV	i) 404 -Main Bay of 400 KV Switching ckt-2 and ii) 406 -Main Bay of 400KV Nanded ckt-1 @ 400KV Chandrapur-II s/s	18/Jul/18	07:00	18/Jul/18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
65	588	400KV	MAIN BUS - A @ CHAKAN WITH BUS COUPLER	19/Jul/18	08:00	19/Jul/18	17:00	Daily	Yearly maintenance and testing activities.	MSETCL	MSETCL	
66	589	220KV	BOISAR (M) - BOISAR (PG) CKT - 1	19/Jul/18	09:00	19/Jul/18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
67	608	400KV	JEJURI- KOYNA STAGE-IV	19/Jul/18	09:00	19/Jul/18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Load will be red from 400KV Lonikand Line.
68	612	400KV	RPL(AMT) NANDGAON PETH - AKOLA I	19/Jul/18	12:00	21/Jul/18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
69	618	400KV	KORADI 2-WARDHA PGCIL	20/Jul/18	09:00	20/Jul/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
70	622	400KV	PARLI(MS) - PARLI (PG) CKT -2	20/Jul/18	09:00	20/Jul/18	17:00	Daily	Testing and maintenance work of line	MSETCL	MSETCL	--
71	623	400KV	SOLAPUR PG - ALKUD	20/Jul/18	09:30	20/Jul/18	17:30	Daily	Routine Maintenance Work	MSETCL	MSETCL	-
72	637	400KV	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	20/Jul/18	09:00	20/Jul/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
73	647	400KV	PARLI - LONIKAND 2 CKT 2	21/Jul/18	09:00	21/Jul/18	17:00	Daily	Distance relay testing work.	MSETCL	MSETCL	--
74	648	400KV	BUS COUPLER @ BABHALESHWAR	21/Jul/18	09:00	21/Jul/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Bus will be seperated
75	651	400KV	AKOLA - WARDHA(PG) CKT - 2	21/Jul/18	09:00	21/Jul/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
76	655	400KV	400kv Boisar-Padghe at Boisar	21/Jul/18	14:00	21/Jul/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	POWERGRID	WR-II	R
77	656	220KV	NASHIK - NAVSARI CKT - 2	21/Jul/18	08:00	21/Jul/18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
78	659	400KV	KALWA - TALEGAON (PGCIL) BY Pune zone	22/Jul/18	08:00	22/Jul/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	Outage proposed by 400kv Lonikand (Line maint.)
79	665	400KV	Bus-I and Bus-II Bus bar protection scheme @ KORADI 2	22/Jul/18	10:00	22/Jul/18	17:00	Daily	On line testing of 400KV BusBar Protection Scheme.	MSETCL	MSETCL	400KV Bus-1 & Bus-II will remain in service, bus bar protection will be out.
80	673	400KV	Aurangabad-Aurangabad-1 along with Main Bus-1 at Msetcl, Waluj SS	23/Jul/18	8:00	23/Jul/18	18:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers replacement	WRTS-I	WRTS-I	R
81	683	400KV	CHANDRAPUR-PARLI CKT-3	23/Jul/18	09:00	23/Jul/18	17:00	Daily	Outage For hardware/Earth wire clamp n/b tightening Work . Loc. No. 890,891 and Distance relay testing work.	MSETCL	MSETCL	--
82	685	220KV	DEOLI(PGCIL)-BADNERA	23/Jul/18	08:00	28/Jul/18	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	-
83	700	400KV	400kv Aurangabad (PG)-Aurangabad (MSETCL) II	24/Jul/18	8:00	24/Jul/18	18:00	Daily	Line AMP works & CT drop jumper replacement at Msetcl, waluj S/s	WRTS-I	WRTS-I	R

Sr.no.	OCCM Sr. No	Voltage Rating	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
84	707	400KV	CHANDRAPUR GCR - CHANDRAPUR HVDC - II	24/Jul/18	08:00	24/Jul/18	18:00	Daily	PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work) .	MSETCL	MSETCL	400 KV GCR- HVDC ckt No. - I will be in service
85	734	400KV	TIE BAY (405) OF SWITCHING SS CKT - 2 & NANDED - 1 @ CHANDRAPUR 2	25/Jul/18	07:00	25/Jul/18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
86	735	400KV	MAIN BUS - 1 @ LAMBOTI (401-52 C.B & 404-52 C.B Will be made off)	25/Jul/18	08:00	25/Jul/18	13:00	Daily	Bus Bar Testing	MSETCL	MSETCL	401-52 C.B & 404-52 C.B Will be made off
87	736	400KV	AKOLA - KHADKA (BHUSAWAL)	25/Jul/18	09:00	25/Jul/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
88	737	400KV	MAIN BUS - 2 @ LAMBOTI (403-52 C.B & 406-52 C.B Will be made off)	25/Jul/18	13:00	25/Jul/18	18:00	Daily	Bus Bar Testing	MSETCL	MSETCL	403-52 C.B & 406-52 C.B Will be made off
89	746	220KV	TALEGAON (AMBI) - TALEGAON (PG) CKT - 1	26/Jul/18	08:00	26/Jul/18	17:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
90	747	220KV	BOISAR (M) - BOISAR (PG) CKT - 2	26/Jul/18	09:00	26/Jul/18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
91	752	400KV	PARLI-SOLAPUR (LAMBOTI)	26/Jul/18	09:00	26/Jul/18	17:00	Daily	Testing and maintenance work of line	MSETCL	MSETCL	--
92	759	400KV	400 KV Akola -aurangabad-2 Line reactor at Akola	26/Jul/18	9:00	26/Jul/18	18:00	Daily	FOR AMP WORK AT AKOLA END. Line outage required for 1 hr LR take out & take into	WRTS-I	WRTS-I	R
93	766	400KV	KORADI-KHADKA	26/Jul/18	12:00	28/Jul/18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	Outage proposed by Akola lines division. 400 kv Akola- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
94	770	400KV	Aurangabad-Aurangabad-1 along with Main Bus-2 at Msetcl, Waluj SS	27/Jul/18	8:00	27/Jul/18	18:00	Daily	line AMP works and for repairing of damaged strands of Bus conductors & CT drop jumpers replacement	WRTS-I	WRTS-I	R
95	775	220KV	TALEGAON (AMBI) - TALEGAON (PG) CKT - 2	27/Jul/18	08:00	27/Jul/18	17:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
96	776	400KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	27/Jul/18	09:00	27/Jul/18	17:00	Daily	Distance relay testing work.	MSETCL	MSETCL	--
97	789	400KV	MAIN BUS - 2 @ WARORA	27/Jul/18	08:00	27/Jul/18	17:00	Daily	Routine maintainance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM.	MSETCL	MSETCL	400KV MAIN BUS-1 WILL BE IN SERVICE
98	790	220KV	BOISAR (M) - BOISAR (PG) CKT - 3	27/Jul/18	09:00	27/Jul/18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	
99	797	400KV	PARLI - LONIKAND 2 CKT 2	28/Jul/18	10:00	28/Jul/18	18:00	Daily	Hardware Tightening & Fitting Work At Loc No- 94,95,137,149,157,	MSETCL	MSETCL	--
100	816	400KV	PADGHE - KALWA 2	29/Jul/18	09:00	29/Jul/18	18:00	Daily	Maintenance & testing work.	MSETCL	MSETCL	--
101	828	400KV	MAIN BUS - 2 @ KHADKA	30/Jul/18	08:00	30/Jul/18	17:00	Daily	BUS 2 CVT R Ph tan delta monitoring and replacement if required.	MSETCL	MSETCL	--
102	829	220KV	DEOLI(PGCIL)-BADNERA	30/Jul/18	08:00	31/Jul/18	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	-
103	842	400KV	KORADI 2-WARDHA PGCIL	31/Jul/18	08:00	31/Jul/18	18:00	Daily	Refixing of missing and tightening of loose jumper N/B on conductor hardware at various locations	MSETCL	MSETCL	--

State Element outages for the Month of Jul 2018

Sr.No.	Voltage Rating	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
1	400 KV	DEEPNAGAR - THAPTI TANDA	02-Jul-18	06:00	07-Jul-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	--
2	400 KV	NEW KOYNA - STAGE IV CKT 1	02-Jul-18	08:00	02-Jul-18	17:00	Daily	Routine Maintenance & Relay testing work	MSETCL	MSETCL	--
3	400 KV	NEW KOYNA-KARAD - CKT 1	02-Jul-18	10:00	02-Jul-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kv NEW KOYANA 2
4	400 KV	KHADKA-AURANGABAD	02-Jul-18	09:00	02-Jul-18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	--
5	400 KV	400/220/33 KV 315 MVA ICT - 1 @ KOLHAPUR	02-Jul-18	09:00	02-Jul-18	20:00	Daily	Quarterly Maint.Work	MSETCL	MSETCL	Replacement of 220kV CT
6	400 KV	THAPTI TANDA - WALUJ	02-Jul-18	08:00	07-Jul-18	16:00	Daily	PID Test	MSETCL	MSETCL	-
7	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	03-Jul-18	08:00	04-Jul-18	18:00	Daily	1) For Measurement of Tan delta & capacitance of bushing & winding of R-ph ICT-II 2) SFRA of R-ph ICT-II. 3) Measurement of transformer resistance of R, Y & B-ph ICT-II. 4) Relay testing work. 5) Measurement of Contact resistance of breaker. 6) Isolator maintenance works.	MSETCL	MSETCL	for 02 day on Daily Basis
8	400 KV	105 MVA SPARE ICT @ CHAKAN	05-Jul-18	08:00	05-Jul-18	17:00	Daily	Half yearly maintenance and testing activities.	MSETCL	MSETCL	-
9	400 KV	TBC @ KOLHAPUR(TALANDGE)	05-Jul-18	09:00	05-Jul-18	18:00	Daily	Quarterly Maint.Work	MSETCL	MSETCL	--
10	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	06-Jul-18	08:00	30-Jul-18	17:00	Daily	routine maintenance and tertiary coating work	MSETCL	MSETCL	--
11	400 KV	TIE BAY-402 OF GT-10 @ KORADI-2	06-Jul-18	10:00	06-Jul-18	17:00	Daily	DCRM,CRM & Timing IR of 402-Q52	MSETCL	MSETCL	ST#10 will remain in operation through Main bay 401
12	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	06-Jul-18	08:00	06-Jul-18	18:00	Daily	1) For checking healthiness of Y-ph CVT as the secondary volatges is higher as compare to other phases CVT's (i.e. R & B-ph CVT). Presently, measured secondary voltage is Vyn - 68.2V. (Phase to earth). If during confirming the healthiness of CVT, it is found abnormal, then CVT will be replaced immediately. The sapre CVT is available in stock. 2) Isolator maintenance.	MSETCL	MSETCL	400KV CHD-I CHD-II CKT No.II & 400 KV CHD-PARLI ckt No.-III will be in service.
13	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	07-Jul-18	08:00	07-Jul-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 501MVA ICT-III , ICT-IV and 315 MVA ICT-II will be in service
14	400 KV	MAIN BAY (417) OF 500 MVA ICT - 1 @ DEEPNAGAR	07-Jul-18	08:00	07-Jul-18	12:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	ICT-1 will be in service through TIE only Main CB will be off.
15	400 KV	TIE BAY (418) OF ICT - 1 & ST 4B @ DEEPNAGAR	07-Jul-18	13:00	07-Jul-18	17:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	ICT-1 & station 4B will be in service through respective main CB only TIE CB will be off.
16	400 KV	THAPTI TANDA - WALUJ	09-Jul-18	08:00	14-Jul-18	16:00	Daily	PID Test	MSETCL	MSETCL	--
17	400 KV	NEW KOYNA - STAGE IV CKT 2	09-Jul-18	08:00	09-Jul-18	17:00	Daily	Routine Maintenance & Relay testing work	MSETCL	MSETCL	--
18	400 KV	DEEPNAGAR - THAPTI TANDA	09-Jul-18	06:00	11-Jul-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	--
19	400 KV	DHULE - BABLESHWAR - I	09-Jul-18	09:00	09-Jul-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-2, Ektuni-ckt-1, Ektuni-ckt-2 will be in service
20	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	09-Jul-18	10:00	09-Jul-18	17:00	Daily	Maintenance work	MSETCL	MSETCL	--
21	400 KV	TBC @ PARLI	09-Jul-18	09:00	09-Jul-18	17:00	Daily	CT and Breaker testing work.	MSETCL	MSETCL	--
22	400 KV	NEW KOYNA -KARAD - CKT 2	09-Jul-18	10:00	09-Jul-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kv NEW KOYANA 1
23	400 KV	TBC 2 @ CHANDRAPUR	10-Jul-18	08:00	10-Jul-18	18:00	Daily	For attending the hot spot on isolators and isolator maintenance works.	MSETCL	MSETCL	TBC-I bay will available.
24	400 KV	KARAD - TALANDGE CKT 2	10-Jul-18	09:00	10-Jul-18	18:00	Daily	Quarterly Maint.Work	MSETCL	MSETCL	--
25	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	11-Jul-18	08:00	11-Jul-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
26	400 KV	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	11-Jul-18	10:00	11-Jul-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
27	400 KV	DEEPNAGAR AURANGABAD	12-Jul-18	06:00	14-Jul-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	--
28	400 KV	WARORA - IEPL	12-Jul-18	09:00	12-Jul-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
29	400 KV	MAIN BAY-401 OF GT-10 @ KORADI-2	12-Jul-18	10:00	12-Jul-18	18:00	Daily	Tan delta measurement of Bus CT of Bay 401, DCRM,CRM & Timing IR of 401-Q52	MSETCL	MSETCL	NOC will be required from Mahagenco.
30	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	13-Jul-18	09:00	13-Jul-18	16:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	--
31	400 KV	MAIN BAY (419) OF STATION TF 4B@ DEEPNAGAR	13-Jul-18	08:00	13-Jul-18	12:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	Station -4B will be in service through TIE only Main CB will be off.
32	400 KV	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	13-Jul-18	10:00	13-Jul-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
33	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	14-Jul-18	16:00	14-Jul-18	22:00	Daily	Bushing & winding C& tan delta Test	MSETCL	MSETCL	--
34	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	14-Jul-18	08:00	14-Jul-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I , 501 MVA ICT -III and ICT-IV will be in service
35	400 KV	400/220/20 KV 500MVA ICT - 1 @ KALWA	15-Jul-18	09:00	15-Jul-18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	--
36	400 KV	DEEPNAGAR AURANGABAD	16-Jul-18	06:00	21-Jul-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	--
37	400 KV	DHULE - BABLESHWAR - II	16-Jul-18	09:00	16-Jul-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-1, Ektuni-ckt-1, Ektuni-ckt-2 will be in service

Sr.No.	Voltage Rating	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
38	400 KV	400/220/33 KV 500 MVA ICT - 3 @ DHULE	17-Jul-18	08:00	17-Jul-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
39	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	18-Jul-18	08:00	19-Jul-18	18:00	Daily	1) For Measurement of Tan delta & capacitance of bushing & winding of R-ph ICT-I 2) DFRA & SFRA of ICT-I. 3) Relay testing work. 4) Isolator maintenance works.	MSETCL	MSETCL	During outage, ICT-I will be in service.
40	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	18-Jul-18	08:00	18-Jul-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--
41	400 KV	TBC @ BABHALESHWAR	18-Jul-18	09:00	18-Jul-18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	TBC is free
42	400 KV	Future Line-I (Bay no 419 and Tie bay no 418) @400kv s/s warora end	19-Jul-18	08:00	19-Jul-18	17:00	Daily	DCRM ,CRM,Timing and IR Values Testing works isolater maintainance work .	MSETCL	MSETCL	--
43	400 KV	JAIGAD-KARAD-II	19-Jul-18	10:00	19-Jul-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 KV JAIGAD -1
44	400 KV	KARAD - LONIKAND 1	19-Jul-18	08:00	19-Jul-18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	--
45	400 KV	MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	21-Jul-18	08:00	21-Jul-18	12:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	ICT-2 will be in service through TIE only Main CB will be off.
46	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	21-Jul-18	16:00	21-Jul-18	22:00	Daily	Bushing & winding C& tan delta Test	MSETCL	MSETCL	--
47	400 KV	TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	21-Jul-18	13:00	21-Jul-18	17:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	ICT-2 & station 4 A will be in service through RESPECTIVE main CB only TIE CB will be off.
48	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	22-Jul-18	09:00	22-Jul-18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	--
49	400 KV	400/220 KV 315MVA ICT - 1 @ KARAD	23-Jul-18	10:00	23-Jul-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S
50	400 KV	NEW KOYNA -KARAD -CKT 2	23-Jul-18	08:00	23-Jul-18	17:00	Daily	Routine Maintenance & Relay testing work	MSETCL	MSETCL	--
51	400 KV	RPL(AMT) NANDGAON PETH - KORADI	24-Jul-18	08:00	24-Jul-18	18:00	Daily	Refixing of missing and tightening of loose jumper N/B on conductor hardware at various locations	MSETCL	MSETCL	--
52	400 KV	WARORA - IEPL	25-Jul-18	08:00	25-Jul-18	17:00	Daily	DCRM ,CRM, Timing and IR Values Testing works isolater maintainance work .	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt
53	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	26-Jul-18	09:00	26-Jul-18	18:00	Daily	Routine Dignostic testing work	MSETCL	MSETCL	--
54	400 KV	MAIN BAY (401) OF ICT -1 @ JEJURI	26-Jul-18	09:00	26-Jul-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	--
55	400 KV	MAIN BAY (416) OF STATION TF 4A @ DEEPNAGAR	27-Jul-18	08:00	27-Jul-18	12:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	Station -4A will be in service through TIE only Main CB will be off.
56	400 KV	KHADKA- DEEPNAGAR CKT 1	28-Jul-18	08:00	28-Jul-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	--