

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of JULY' 2024

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuous | Reason | From | | To | | Remarks |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|--|
| 1 | 5 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-SOLAPUR-FUTURE-1 | D | Line terminal equipments AMP at 765kV Solapur Substation | 01/Jul/2024 | 8:00 | 01/Jul/2024 | 18:00 | |
| 2 | 7 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV | D | For AMP Work | 01/Jul/2024 | 9:00 | 01/Jul/2024 | 17:30 | Pune GIS Line_4 Line in service through the 411 TIE Bay |
| 3 | 13 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PARLI NEW-PARLI-M-1 | D | AMP OF LINE TERMINAL EQUIPMENTS | 01/Jul/2024 | 9:00 | 01/Jul/2024 | 18:00 | AMP OF LINE TERMINAL EQUIPMENTS WITH DIA OPEN |
| 4 | 22 | PLANNED | OCC_580 | MSLDC_OUTAGE | KORADI-II - 400KV - BUS 1 | D | Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT | 01/Jul/2024 | 10:00 | 01/Jul/2024 | 17:30 | All feeders wil remain in service through 400kV Main Bus-II |
| 5 | 26 | PLANNED | OCC_580 | APML | MAIN BAY - 400KV-TIRODA-WARORA-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV | C | Bay equipment maintenance work | 01/Jul/2024 | 9:00 | 02/Jul/2024 | 18:00 | ST-1 will be in service with main bay |
| 6 | 38 | PLANNED | OCC_580 | POWERGRID_WR1 | TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV | D | For Bay Amp Works and Overhauling of CB. | 01/Jul/2024 | 7:00 | 08/Jul/2024 | 20:00 | |
| 7 | 40 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | D | Only AR kept off line will be in service for overhead Power Line crossing proposal and installation of Padghe (PGCIL)-Kharghar 400kV D/C (Quad) line associated with Mumbai Urja Marg Limited | 01/Jul/2024 | 8:00 | 04/Jul/2024 | 18:00 | A/R in N/A, Line will be in service. |
| 8 | 41 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-KHARGHAR-1 | D | Only AR kept off line will be in service for overhead Power Line crossing proposal and installation of Padghe (PGCIL)-Kharghar 400kV D/C (Quad) line associated with Mumbai Urja Marg Limited | 01/Jul/2024 | 8:00 | 04/Jul/2024 | 18:00 | A/R in N/A, Line will be in service. |
| 9 | 42 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | D | Only AR kept off line will be in service for overhead Power Line crossing proposal and installation of Padghe (PGCIL)-Kharghar 400kV D/C (Quad) line associated with Mumbai Urja Marg Limited | 01/Jul/2024 | 8:00 | 04/Jul/2024 | 18:00 | A/R in N/A, Line will be in service. |
| 10 | 43 | PLANNED | OCC_580 | WTPL | 400KV-ALKUD-SOLAPUR-1 | D | AR disable for replacement of insulator in live line method. | 01/Jul/2024 | 8:00 | 10/Jul/2024 | 18:00 | AR disable |
| 11 | 44 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KARAD-SOLAPUR-1 | C | Replacement of Complete Relay panel including replacement cables from Yard to Panel. | 01/Jul/2024 | 09:00 | 10/Jul/2024 | 18:00 | Line is kept off from 2017 and Bay is utilized for 80 MVAR Reactor as Bus Reactor for voltage control. |
| 12 | 56 | PLANNED | OCC_580 | POWERGRID_WR2 | 400KV-KHANDWA-DHULE-MS-2 | D | For OPGW stringing under live line condition, A/R to kept in Non Auto mode from both ends. | 01/Jul/2024 | 7:00 | 31/Jul/2024 | 18:00 | PG-WR2- RHQIT |
| 13 | 64 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TILLARI-AMONA-1 | D | A/R off PTW for Live line OPGW installation | 01/Jul/2024 | 7:00 | 31/Jul/2024 | 19:00 | Work is proposed by MTCIL |
| 14 | 65 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-MAHALAXMI(KONALKATTA)-AMONA-1 | D | A/R off PTW for Live line OPGW installation | 01/Jul/2024 | 7:00 | 31/Jul/2024 | 19:00 | Work is proposed by MTCIL |
| 15 | 71 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-1 | D | For OPGW installation replacing existing earth wire (AR Out) | 01/Jul/2024 | 08:00 | 31/Jul/2024 | 18:00 | Work is proposed by MTCIL |
| 16 | 72 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-2 | D | For OPGW installation replacing existing earth wire (AR Out) | 01/Jul/2024 | 08:00 | 31/Jul/2024 | 18:00 | Work is proposed by MTCIL |
| 17 | 75 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-OSMANABAD-M-1 | D | PID Testing Hotline: Work | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 17:30 | - |
| 18 | 76 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-2 | D | PID Testing Hotline: Work | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 17:30 | - |
| 19 | 77 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-1 | D | PID testing work | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 18:00 | PID testing work |
| 20 | 78 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-HARANGUL-1 | D | PID Testing work | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 18:00 | Line maintenance work |
| 21 | 79 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-SOLAPUR-BALE-1 | C | for project work balance foundation, erection & stringing stringing 42 no.s of M/C towers for 220kV Bale-Solapur(PG) (Second source i.e. ckt-2) | 01/Jul/2024 | 0:00 | 21/Aug/2024 | 18:00 | for project work balance foundation, erection & stringing stringing 42 no.s of M/C towers for 220kV Bale-Solapur(PG) (Second source i.e. ckt-2) |
| 22 | 99 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-WARORA-PG-1 | D | Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme | 02/Jul/2024 | 7:00 | 02/Jul/2024 | 18:00 | Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme |
| 23 | 100 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARORA (M)-WARORA-PG-2 | D | Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme | 02/Jul/2024 | 7:00 | 02/Jul/2024 | 18:00 | Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme |
| 24 | 113 | PLANNED | OCC_580 | POWERGRID_WR2 | MAIN BAY - 400KV-AURANGABAD-BOISAR-2 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV | D | AMP | 02/Jul/2024 | 9:00 | 02/Jul/2024 | 17:30 | PG-WR2-BOISAR |
| 25 | 114 | PLANNED | OCC_580 | POWERGRID_WR1 | TIE BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND 400KV/220KV PUNE-PG-ICT-2 at PUNE-PG - 400KV | D | For AMP Work | 02/Jul/2024 | 9:00 | 02/Jul/2024 | 17:30 | |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuous | Reason | From | | To | | Remarks |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|--|-------------|-------|-------------|-------|---|
| 26 | 133 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-HARANGUL-1(Taken on TBC at 220KV Harangul end) | C | CB overhauling work by agency by transferring 220 kV own CB to 220 kV TBC CB | 02/Jul/2024 | 09:00 | 04/Jul/2024 | 19:00 | Overhauling of CB is necessary as CB is OLD. NO load will be affected CB transferred o TBC |
| 27 | 137 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV | C | Overhauling of Circuit breaker | 02/Jul/2024 | 08:00 | 09/Jul/2024 | 17:30 | Koradi-II Wardha(PG) ckt. will remain inservice through tie Bay 411 |
| 28 | 152 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-SOLAPUR-NARANGWADI-2 | D | Line terminal equipments AMP at 765kV Solapur Substation | 03/Jul/2024 | 7:00 | 03/Jul/2024 | 18:00 | |
| 29 | 157 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PARLI NEW-PARLI-M-1 | D | CT OIL SAMPLING AFTER 6 MONTHS OF CHAGING | 03/Jul/2024 | 8:00 | 03/Jul/2024 | 18:00 | CT OIL SAMPLING AFTER 6 MONTHS OF CHAGING |
| 30 | 158 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PARLI NEW-PARLI-M-2 | D | AR IN NON-AUTO | 03/Jul/2024 | 8:00 | 03/Jul/2024 | 18:00 | AR IN NON-AUTO |
| 31 | 174 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-2 | D | Extension of CT, PT connections with new LTS Panel under LTS / SPS scheme work of Mumbai Source Lines. | 03/Jul/2024 | 05:00 | 03/Jul/2024 | 09:00 | Extension of CT, PT connections with new LTS Panel under LTS / SPS scheme work of Mumbai Source Lines. |
| 32 | 178 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-OSMANABAD-M-1 | D | LINE/ s/ s maintenance | 03/Jul/2024 | 09:00 | 03/Jul/2024 | 17:30 | - |
| 33 | 179 | PLANNED | OCC_580 | MSLDC_OUTAGE | 132KV-PENCH-KANHAN-1 | D | For routine maintenance work | 03/Jul/2024 | 09:00 | 03/Jul/2024 | 18:00 | NA |
| 34 | 180 | PLANNED | OCC_580 | MEGPTCL | TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV | D | Annual Maintenance of Bay Equipments at Koradi-III SS. | 03/Jul/2024 | 09:00 | 03/Jul/2024 | 18:00 | Bay Outage |
| 35 | 181 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TILLARI-AMONA-1 | D | Maintenance work | 03/Jul/2024 | 09:00 | 03/Jul/2024 | 18:00 | The said work is very important |
| 36 | 182 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-SOLAPUR-KUMBARI-1 | D | Outage is required for Quarterly Maintenance | 03/Jul/2024 | 10:00 | 03/Jul/2024 | 17:00 | Breaker of PGCIL line at South Solapur End will be made off |
| 37 | 183 | PLANNED | OCC_580 | MSLDC_OUTAGE | KUMBARI - 220KV - BUS 1 | D | Outage is required for Quarterly Maintenance | 03/Jul/2024 | 11:00 | 03/Jul/2024 | 17:00 | Breaker of PGCIL line at South Solapur End will be made off |
| 38 | 185 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-WARORA-PG-1 | D | Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme | 03/Jul/2024 | 7:00 | 04/Jul/2024 | 18:00 | Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme |
| 39 | 186 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARORA (M)-WARORA-PG-2 | D | Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme | 03/Jul/2024 | 7:00 | 04/Jul/2024 | 18:00 | Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme |
| 40 | 187 | PLANNED | OCC_580 | APML | MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV | C | Bay equipment maintenance work | 03/Jul/2024 | 9:00 | 04/Jul/2024 | 18:00 | IC-1-1 will be in service on TIE bay |
| 41 | 192 | PLANNED | OCC_580 | MSLDC_OUTAGE | BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV | C | Required for Main Bus -1 outage work. | 03/Jul/2024 | 04:00 | 05/Jul/2024 | 18:00 | Required for Main Bus -1 outage work. |
| 42 | 193 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV/21KV CHANDRAPUR-GT-6 | C | 1. For dismantling of IP's tube of Bph PG-1 Isolator required for replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 2. GTR-6 will be in service via TBC-2 | 03/Jul/2024 | 04:00 | 05/Jul/2024 | 18:00 | GTR-6 will be in service via TBC-2 |
| 43 | 194 | PLANNED | OCC_580 | MSLDC_OUTAGE | CHANDRAPUR-GCR - 400KV - BUS 1 | C | 1. Replacement of cable of BUS-1 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadraple Bus conductor in span Required for Main Bus -1 outage work. | 03/Jul/2024 | 04:00 | 05/Jul/2024 | 18:00 | *This circuits/bays which are connected to 400KV MainBUS-1 will be shifted on 400KV Main Bus-2 one by one via TBC-1 & TBC-2 |
| 44 | 195 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-3 | C | Required for Main Bus -1 outage work. | 03/Jul/2024 | 04:00 | 05/Jul/2024 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service. |
| 45 | 196 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-4 | C | Required for Main Bus -1 outage work. | 03/Jul/2024 | 04:00 | 05/Jul/2024 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service. |
| 46 | 197 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1 | C | 1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work. | 03/Jul/2024 | 04:00 | 05/Jul/2024 | 18:00 | 1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work. |
| 47 | 198 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 | D | 1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work. | 03/Jul/2024 | 16:00 | 05/Jul/2024 | 19:00 | Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. |
| 48 | 217 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV-AURANGABAD-M (WALLJ)-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV | D | For AMP | 04/Jul/2024 | 7:00 | 04/Jul/2024 | 18:00 | 412 |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuous | Reason | From | | To | | Remarks |
|--------|-------------|--------------|------------|---------------------------|--|--------------------|---|-------------|-------|-------------|-------|---|
| 49 | 229 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-SOLAPUR-KUMBARI-1 | D | Line terminal equipments AMP at 765kV Solapur Substation | 04/Jul/2024 | 8:00 | 04/Jul/2024 | 18:00 | |
| 50 | 233 | PLANNED | OCC_580 | POWERGRID_WR2 | MAIN BAY OF 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV | D | AMP | 04/Jul/2024 | 9:00 | 04/Jul/2024 | 17:30 | PG-WR2-BOISAR |
| 51 | 235 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV | D | For AMP Work | 04/Jul/2024 | 9:00 | 04/Jul/2024 | 17:30 | Pune Chakan Line in service through the 402 TIE Bay |
| 52 | 249 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-3 | D | Extension of CT, PT connections with new LTS Panel under LTS / SPS scheme work of Mumbai Source Lines. | 04/Jul/2024 | 05:00 | 04/Jul/2024 | 09:00 | Extension of CT, PT connections with new LTS Panel under LTS / SPS scheme work of Mumbai Source Lines. |
| 53 | 251 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LO | D | Diagnostic testing and Pre Monsoon Maintenance | 04/Jul/2024 | 09:00 | 04/Jul/2024 | 18:00 | - |
| 54 | 252 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV | D | Diagnostic testing and Pre Monsoon Maintenance | 04/Jul/2024 | 09:00 | 04/Jul/2024 | 18:00 | - |
| 55 | 254 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-EKTUNI-BABLESHWAR-2 AND 765KV/400KV EKTUNI-ICT-1 at EKTUNI - 400KV | D | Routine testing and Maintenance Works | 04/Jul/2024 | 10:00 | 04/Jul/2024 | 18:00 | 765/400kV ICT in service via 400kV Main bus 2 |
| 56 | 263 | PLANNED | OCC_580 | POWERGRID_WR1 | 407 bay at Padghe Ss | C | Breaker Close/open & spring Charge/Discharge Indication replacement | 04/Jul/2024 | 9:00 | 06/Jul/2024 | 17:00 | Element Unique Equipment ID not Created |
| 57 | 311 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-EKTUNI-BABLESHWAR-1 | D | Routine Line maintenance and diagnostic work. | 04/Jul/2024 | 09:00 | 04/Jul/2024 | 18:00 | Second Circuit will be in service. |
| 58 | 278 | PLANNED | OCC_580 | POWERGRID_WR1 | AURANGABAD - 220KV - BUS 1 | D | For AMP | 05/Jul/2024 | 7:00 | 05/Jul/2024 | 18:00 | All bay shifted on TBC bay & their main bay out one by one during 89A isolator maintenance of each bay |
| 59 | 282 | PLANNED | OCC_580 | POWERGRID_WR2 | 400KV/220KV BOISAR-ICT-3 | D | AMP, Dia to be kept open at both sides | 05/Jul/2024 | 7:00 | 05/Jul/2024 | 21:00 | PG-WR2-BOISAR |
| 60 | 290 | PLANNED | OCC_580 | POWERGRID_WR1 | PARLI - 400KV - BUS 1 | D | AMP WORK OF 400KV BUS 1 & RELAY TESTING | 05/Jul/2024 | 8:00 | 05/Jul/2024 | 18:00 | AMP WORK OF 400KV BUS 1 & RELAY TESTING |
| 61 | 291 | PLANNED | OCC_580 | POWERGRID_WR1 | 765KV-SOLAPUR-PARLI NEW-2 | D | AMP OF TERMINAL EQUIPMENTS at Solapur end | 05/Jul/2024 | 8:00 | 05/Jul/2024 | 18:00 | AMP OF TERMINAL EQUIPMENTS & LR WITH DIA OPEN |
| 62 | 296 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PADGHE-PG-KUDUS-1 | D | AMP of Line Equipment at Padghe GIS & MSETCL Kodus substation and Autoreclosure scheme checking at Padghe SS. AR IN NON AUTO MODE OF CKT#2 | 05/Jul/2024 | 9:00 | 05/Jul/2024 | 17:00 | |
| 63 | 299 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV | D | For AMP Work | 05/Jul/2024 | 9:00 | 05/Jul/2024 | 17:30 | Pune GIS Line_1 in service through the 405 TIE Bay |
| 64 | 312 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-EKTUNI-BABLESHWAR-2 | D | Routine Maintenance work and diagnostic testing work. | 05/Jul/2024 | 09:00 | 05/Jul/2024 | 18:00 | Babhleshwar Ckt-4 will be in service. |
| 65 | 313 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-EKTUNI-BABLESHWAR-1 AND FUTURE at EKTUNI - 400KV | D | Routine testing and Maintenance Works | 05/Jul/2024 | 10:00 | 05/Jul/2024 | 18:00 | 400kV Bableshwar 2 in service. |
| 66 | 317 | PLANNED | OCC_580 | APML | TIE BAY OF 765KV/21KV TIRODA-GT-4 AND 765KV/400KV TIRODA-ICT-1 @TIRODA - 765KV at TIRODA - 765KV | C | Bay equipment maintenance work | 05/Jul/2024 | 9:00 | 06/Jul/2024 | 18:00 | 765KV/400KV-ICT-1 and 765KV/21KV GT-4 will be in service on main bay |
| 67 | 427 | PLANNED | OCC_580 | POWERGRID_WR1 | 765KV-AURANGABAD-PADGHE-PG-2 | C | Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works) | 05/Jul/2024 | 9:00 | 25/Jul/2024 | 17:00 | 765 KV AURANGABAD PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE |
| 68 | 428 | PLANNED | OCC_580 | POWERGRID_WR1 | 765KV-PUNE-GIS-PADGHE-PG-1 | C | Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works) | 05/Jul/2024 | 9:00 | 25/Jul/2024 | 18:00 | 765 KV PUNE PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE |
| 69 | 369 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BORIVALI-1 | D | outage is required on 220kV PGCIL - Borivali Line (for safety purpose) during work of Providing Repair Sleeve for damaged Conductor at Loc No. 82-83 Top Ph of 220kV Tarapur - Borivali Line. | 07/Jul/2024 | 07:00 | 07/Jul/2024 | 17:00 | outage is required on 220kV PGCIL - Borivali Line (for safety purpose) during work of Providing Repair Sleeve for damaged Conductor at Loc No. 82-83 Top Ph of 220kV Tarapur - Borivali Line. |
| 70 | 370 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TARAPUR 1-2-BORIVALI-1 | D | Providing Repair Sleeve for damaged Conductor at Loc No. 82-83 Top Ph. | 07/Jul/2024 | 09:00 | 07/Jul/2024 | 17:00 | Simultaneously outage is required on 220kV PGCIL - Borivali Line (for safety purpose) |
| 71 | 372 | PLANNED | OCC_580 | APML | 400KV/21KV TIRODA-GT-2 | C | GT-2 Maintenance, testing and painting work. Main bay and Tie bay equipment maintenance work | 07/Jul/2024 | 7:00 | 31/Jul/2024 | 18:00 | ST-4 will be in service on MAIN bay |
| 72 | 387 | PLANNED | OCC_580 | POWERGRID_WR1 | PARLI - 400KV - BUS 2 | D | AMP WORK OF 400KV BUS 2 & RELAY TESTING | 08/Jul/2024 | 8:00 | 08/Jul/2024 | 18:00 | AMP WORK OF 400KV BUS 2 & RELAY TESTING |
| 73 | 388 | PLANNED | OCC_580 | POWERGRID_WR1 | PARLI NEW - 400KV - BUS 1 | D | AMP OF BUS & ISOLATOR ALIGNMENT WORK | 08/Jul/2024 | 8:00 | 08/Jul/2024 | 18:00 | AMP OF BUS & ISOLATOR ALIGNMENT WORK |
| 74 | 389 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-SOLAPUR-NARANGWADI-1 | D | Line terminal equipments AMP at 765kV Solapur Substation | 08/Jul/2024 | 8:00 | 08/Jul/2024 | 18:00 | |
| 75 | 412 | PLANNED | OCC_580 | MSLDC_OUTAGE | WARORA - 400KV - BUS 1 | D | For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works | 08/Jul/2024 | 09:00 | 08/Jul/2024 | 17:00 | During 400KV Busbar Protection Relay testing works Outage , (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work. (2) The 400KV Busbar |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuo us | Reason | From | | To | | Remarks |
|--------|----------------|--------------|------------|------------------------------|---|---------------------------|--|-------------|-------|-------------|-------|---|
| 76 | 413 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV | D | Annual Maintenance of CB at Koradi-III SS. | 08/Jul/2024 | 09:00 | 08/Jul/2024 | 18:00 | Bay Outage |
| 77 | 414 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV | D | Diagnostic testing & Maintenance work | 08/Jul/2024 | 10:00 | 08/Jul/2024 | 14:00 | -- |
| 78 | 415 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-WARDHA-WARDHA-M-1 | D | Routine line maintenance work | 08/Jul/2024 | 10:00 | 08/Jul/2024 | 18:00 | NA |
| 79 | 416 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV | D | Diagnostic testing & Maintenance work | 08/Jul/2024 | 14:00 | 08/Jul/2024 | 18:00 | -- |
| 80 | 417 | PLANNED | OCC_580 | POWERGRID_WR1 | DHULE-MS - 400KV B/R 2 | C | For old CT replacement work | 08/Jul/2024 | 7:00 | 09/Jul/2024 | 18:00 | PGG |
| 81 | 418 | PLANNED | OCC_580 | POWERGRID_WR1 | TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV/220KV WARDHA-ICT-1 at Wardha - 400KV | D | For Replacement of Density monitor cu pipe by M/s CGL. | 08/Jul/2024 | 7:00 | 09/Jul/2024 | 20:00 | |
| 82 | 437 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 765KV-AURANGABAD-PADGHE-PG-2 AND AURANGABAD - 765KV - BUS 1 at AURANGABAD - 765KV | D | For AMP | 09/Jul/2024 | 7:00 | 09/Jul/2024 | 18:00 | 707 |
| 83 | 440 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-AURANGABAD-1 | D | For Amp of Line Bay AND For Replacement of Old BHEL Insulators on gantries of element. AR of Ckt#2 in Non Auto mode | 09/Jul/2024 | 7:00 | 09/Jul/2024 | 20:00 | |
| 84 | 441 | PLANNED | OCC_580 | POWERGRID_WR2 | 400KV-MAGARWADA-BOISAR-2 | D | AR Relay Retrofitting, A/R off of ckt 1 is required. Dia to be kept open at both ends. | 09/Jul/2024 | 7:00 | 09/Jul/2024 | 21:00 | PG-WR2-BOISAR |
| 85 | 450 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV | D | For AMP Work | 09/Jul/2024 | 9:00 | 09/Jul/2024 | 17:30 | Pune GIS Line_2 Line in service through the 408 TIE Bay |
| 86 | 464 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-WARORA-PG-WARORA-1 | D | Routine Maintenance & Dignostic testing work . | 09/Jul/2024 | 09:00 | 09/Jul/2024 | 17:00 | 400KV WARORA-IEPL. Line is in ckt |
| 87 | 465 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 765KV-AKOLA (2)-EKTUNI-1 AND FUTURE at EKTUNI - 765KV | D | Routine Diagnostic testing works | 09/Jul/2024 | 10:00 | 09/Jul/2024 | 13:00 | 765kV Ektuni-Akola 1 will be in service via 765kV Main bus 2 |
| 88 | 466 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV | D | SF6 Gas Analysis Of CB. | 09/Jul/2024 | 10:00 | 09/Jul/2024 | 13:00 | BAY OUTAGE |
| 89 | 467 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-WARDHA-BADNERA-1 | D | Routine line maintainance work | 09/Jul/2024 | 10:00 | 09/Jul/2024 | 18:00 | NA |
| 90 | 468 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND FUTURE at EKTUNI - 765KV | D | Routine Diagnostic testing works | 09/Jul/2024 | 14:00 | 09/Jul/2024 | 18:00 | 765/400kV ICT-1 will be in service via 765kV Main bus 2 |
| 91 | 469 | PLANNED | OCC_580 | MEGPTCL | TIE BAY - 765KV/400KV AKOLA (2)-ICT-1 AND 400KV-AKOLA (2)-FUTURE-5 at AKOLA (2) - 400KV | D | SF6 Gas Analysis Of CB. | 09/Jul/2024 | 15:00 | 09/Jul/2024 | 18:00 | BAY OUTAGE |
| 92 | 499 | PLANNED | OCC_580 | POWERGRID_WR1 | TIE BAY - 400KV-AURANGABAD-M (WALUJ)- AURANGABAD-1 AND 400KV-WARDHA- AURANGABAD-2 at AURANGABAD - 400KV | D | For AMP | 10/Jul/2024 | 7:00 | 10/Jul/2024 | 18:00 | 411 |
| 93 | 508 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-KALA-KUDUS-1 | D | AMP of 404L at MSEITCL. Kudus Substation. 400KV-KALA- KUDUS-2 A/R to be kept in Non-Auto mode. | 10/Jul/2024 | 9:00 | 10/Jul/2024 | 17:00 | |
| 94 | 519 | PLANNED | OCC_580 | GETCO | 220KV-TARAPUR 1&2-VAPI-1 | D | PMM work | 10/Jul/2024 | 9:00 | 10/Jul/2024 | 18:00 | |
| 95 | 527 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV | D | Annual Maintenance of bays equipment & 405 Tie Bay B-phase isolator damaged blade replacement work | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 17:00 | Load of Kala PG ckt-1 Line shifted on 400KV Kala PG ckt 2- (No interruption), Kala-1 Line (404 bay)Outage is essential as line dropper is connected to 405 bay isolator. |
| 96 | 528 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY OF 400KV-KALA-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV | D | Annual Maintenance of bays equipment & 405 Tie Bay B-phase isolator damaged blade replacement work | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 17:00 | Load of Kala PG ckt-1 Line shifted on 400KV Kala PG ckt 2- (No interruption), Kala-1 Line (404 bay)Outage is essential as line dropper is connected to 405 bay isolator |
| 97 | 529 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-OSMANABAD-M-1 | D | LINE/ s/ s maintenance | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 17:30 | - |
| 98 | 530 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PANDURNA-KALMESHWAR-1 | D | For routine maintenance work | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 18:00 | NA |
| 99 | 531 | PLANNED | OCC_580 | MSLDC_OUTAGE | 132KV-MANSAR-MS-KANHAN-1 | D | For routine maintenance work | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 18:00 | NA |
| 100 | 532 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-MAHALAXMI(KONALKATTA)-AMONA-1 | D | Maintenance work | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 18:00 | The said work is very important |
| 101 | 533 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-SOLAPUR-M-1 | D | Hardware tightening and cold washing | 10/Jul/2024 | 09:00 | 10/Jul/2024 | 18:00 | Load managed on 400kV Lamboti-PGCIL line |
| 102 | 84 | PLANNED | OCC_580 | WITPL | 400KV-SOLAPUR-M-SOLAPUR-1 | D | AR disable for replacement of insulator in live line method. | 11/Jul/2024 | 8:00 | 20/Jul/2024 | 18:00 | AR disable |
| 103 | 558 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-KHANDWA-DHULE-MS-2 | D | For AMP | 11/Jul/2024 | 7:00 | 11/Jul/2024 | 18:00 | PGHL |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuo us | Reason | From | | To | | Remarks |
|--------|----------------|--------------|------------|------------------------------|---|---------------------------|--|-------------|-------|-------------|-------|--|
| 104 | 559 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-KHANDWA-DHULE-MS-2 L/R@ DHULE- MS - 400KV | D | For AMP | 11/jul/2024 | 7:00 | 11/jul/2024 | 18:00 | PGHR |
| 105 | 564 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-WARDHA-AURANGABAD-2 | D | For Amp of Line Bay AND For Replacement of Old BHEL Insulators on gantries of element. AR of Ckt#2 in Non Auto mode | 11/jul/2024 | 7:00 | 11/jul/2024 | 20:00 | |
| 106 | 578 | PLANNED | OCC_580 | POWERGRID_WRI | 220KV-TALEGAON-PUNE-PG-2 | D | For AMP Work | 11/jul/2024 | 9:00 | 11/jul/2024 | 17:30 | Line Owned By MSETCL |
| 107 | 593 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY OF 400KV-KARJAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV | D | Diagnostic testing and Pre Monsoon Maintenance | 11/jul/2024 | 09:00 | 11/jul/2024 | 18:00 | - |
| 108 | 594 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY OF 400KV-KARJAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV | D | Diagnostic testing and Pre Monsoon Maintenance | 11/jul/2024 | 09:00 | 11/jul/2024 | 18:00 | - |
| 109 | 596 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV | D | Routine Diagnostic testing works | 11/jul/2024 | 10:00 | 11/jul/2024 | 13:00 | 765KV ICT 1 will be in service via TIE bay and 765kV Main bus 1 |
| 110 | 597 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 400KV-AKOLA (2)-FUTURE-S AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV | D | Sf6 Gas Analysis Of CB. | 11/jul/2024 | 10:00 | 11/jul/2024 | 13:00 | BAY OUTAGE |
| 111 | 598 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TALEGAON-PUNE-PG-1 | D | Cold line washing of insulators & Other Maintenance Work. | 11/jul/2024 | 10:00 | 11/jul/2024 | 17:00 | - |
| 112 | 599 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV/11.5KV CHANDRAPUR-GCR-ST-4 | D | "1. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and | 11/jul/2024 | 13:00 | 11/jul/2024 | 16:00 | Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. |
| 113 | 600 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV | D | Routine Diagnostic testing works | 11/jul/2024 | 14:00 | 11/jul/2024 | 18:00 | 765KV EKTUNI-AKOLA 1 will be in service via Tie bay and 765kV Main bus 1 |
| 114 | 601 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH- 1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV | D | Sf6 Gas Analysis Of CB. | 11/jul/2024 | 15:00 | 11/jul/2024 | 18:00 | BAY OUTAGE |
| 115 | 602 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 | D | "1. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and | 11/jul/2024 | 16:00 | 11/jul/2024 | 19:00 | Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. |
| 116 | 604 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV | C | Bay equipment maintenance work | 11/jul/2024 | 09:00 | 12/jul/2024 | 18:00 | 765KV-TIRODA-KORADI-III-2 LINE WILL BE IN SERVICE ON TIE BAY |
| 117 | 606 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-1 | C | Required for Main Bus -2 outage work. | 11/jul/2024 | 04:00 | 13/jul/2024 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service. |
| 118 | 607 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1 | C | "1. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware | 11/jul/2024 | 04:00 | 13/jul/2024 | 18:00 | "1. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware |
| 119 | 608 | PLANNED | OCC_580 | MSLDC_OUTAGE | BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV | C | Required for Main Bus -2 outage work. | 11/jul/2024 | 04:00 | 13/jul/2024 | 18:00 | Required for Main Bus -1 outage work. |
| 120 | 609 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV/21KV CHANDRAPUR-GT-6 | C | 1. For replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6'. 2. GTR-6 will be in service via TBC-2. | 11/jul/2024 | 04:00 | 13/jul/2024 | 18:00 | GTR-6 will be in service via TBC-2 |
| 121 | 610 | PLANNED | OCC_580 | MSLDC_OUTAGE | CHANDRAPUR-GCR - 400KV - BUS 2 | C | 1. Replacement of cable of BUS-1 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadraple Bus conductor in span | 11/jul/2024 | 04:00 | 13/jul/2024 | 18:00 | "This circuits/bays which are connected to 400KV Main Bus-2 will be shifted on 400KV Main Bus-1 one by one via TBC-1 & TBC-2 |
| 122 | 611 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-2 | C | Required for Main Bus -2 outage work. | 11/jul/2024 | 04:00 | 13/jul/2024 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service. |
| 123 | 612 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV | C | CB pole overhauling work 400 KV Padghe 1 will be in service through TBC | 11/jul/2024 | 08:00 | 16/jul/2024 | 18:00 | 400 KV Padghe 1 will be in service through TBC |
| 124 | 620 | PLANNED | OCC_580 | GETCO | 220KV-NASIK-NAVSARI-1 | D | Bay maintenance | 12/jul/2024 | 8:00 | 12/jul/2024 | 15:00 | |
| 125 | 652 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-SOLAPUR-M-1 | D | 1) Reactor Differential relay testing work. (2) Bay maintenance work. 3) String replacement at location No 2,223 & 250 | 12/jul/2024 | 09:00 | 12/jul/2024 | 18:00 | - |
| 126 | 653 | PLANNED | OCC_580 | MSLDC_OUTAGE | BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV | D | 1) Bay Maint work 2) Diagnostic testing work 3)MTAMC work | 12/jul/2024 | 09:00 | 12/jul/2024 | 19:00 | 1) Weather Condition should be clear |
| 127 | 654 | PLANNED | OCC_580 | MEGPTCL | TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND 400KV-AKOLA-AKOLA (2)-1 at AKOLA (2) - 400KV | D | Sf6 Gas Analysis Of CB. | 12/jul/2024 | 10:00 | 12/jul/2024 | 13:00 | BAY OUTAGE |
| 128 | 656 | PLANNED | OCC_580 | POWERGRID_WRI | 765KV-AURANGABAD-PADGHE-PG-2 | C | Drive Mechanism Inspection Work of Rector CB by OEM | 12/jul/2024 | 7:00 | 13/jul/2024 | 18:00 | 707L |
| 129 | 657 | PLANNED | OCC_580 | POWERGRID_WRI | 765KV-AURANGABAD-PADGHE-PG-2 L/R@ AURANGABAD - 765KV | C | Drive Mechanism Inspection Work by OEM | 12/jul/2024 | 7:00 | 13/jul/2024 | 18:00 | 707LR |
| 130 | 661 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-1 | D | hardware tightening and cold washing | 13/jul/2024 | 5:00 | 13/jul/2024 | 13:00 | load managed on 400kv parli-karjat ckt-2 line |
| 131 | 670 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-ALKUD-SOLAPUR-1 | D | Line terminal equipments AMP at 765kV Solapur Substation | 13/jul/2024 | 7:00 | 13/jul/2024 | 18:00 | |
| 132 | 671 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV | D | PRV NC contact modification and Line Reactor AMP works at 765kV Solapur Substation. Note: Dia to be kept open | 13/jul/2024 | 7:00 | 13/jul/2024 | 18:00 | |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuo us | Reason | From | | To | | Remarks |
|--------|----------------|--------------|------------|------------------------------|--|---------------------------|--|-------------|-------|-------------|-------|--|
| 133 | 674 | PLANNED | OCC_580 | GETCO | 220KV-NASIK-NAVSARI-2 | D | Bay maintenance | 13/Jul/2024 | 8:00 | 13/Jul/2024 | 15:00 | |
| 134 | 690 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-ALKUD-SOLAPUR-1 | D | Diagnostic testing & Maintenance work | 13/Jul/2024 | 15:00 | 13/Jul/2024 | 23:00 | Load will be managed on 400KV Alkud Kolhapur Line |
| 135 | 692 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-AKOLA-2 | D | For Aerial Patrolling S/D defect and Annual defect Rectification Work | 14/Jul/2024 | 7:00 | 14/Jul/2024 | 18:00 | For Aerial Patrolling S/D defect and Annual defect Rectification Work |
| 136 | 693 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-AKOLA-1 | D | AR IN NON AUTO | 14/Jul/2024 | 7:00 | 14/Jul/2024 | 18:00 | For Aerial Patrolling S/D defect and Annual defect Rectification Work |
| 137 | 695 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-CHANDRAPUR-BHADRAWATI-1 | C | Replacement of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS & AMP works at both end. | 14/Jul/2024 | 8:00 | 14/Jul/2024 | 20:00 | retrofitting of pantograph Isolator |
| 138 | 700 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-WARDHA-PUSAD-1 | D | For Replacement of Old BHEL Insulators on gantries of element. | 15/Jul/2024 | 7:00 | 15/Jul/2024 | 13:00 | |
| 139 | 708 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 | D | For AMP | 15/Jul/2024 | 7:00 | 15/Jul/2024 | 18:00 | 404L |
| 140 | 709 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-SOLAPUR-JEUR-1 | D | Line terminal equipments AMP at 765kV Solapur Substation | 15/Jul/2024 | 7:00 | 15/Jul/2024 | 18:00 | |
| 141 | 710 | PLANNED | OCC_580 | POWERGRID_WR1 | WARDHA - 220KV - BUS 2 | D | For Replacement of Old BHEL Insulators on gantries of element. Each Feeder will be shifted on TBC one at time | 15/Jul/2024 | 7:00 | 15/Jul/2024 | 20:00 | All bay shifted on TBC bay & their main bay out one by one during maintenance of each bay |
| 142 | 712 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY OF 400KV-PARLI-KALLAM PS-1 AND PARLI - 400KV - BUS 2 @PARLI - 400KV AT PARLI - 400KV at PARLI - 400KV | D | Repairing of 403 Bay CSD | 15/Jul/2024 | 8:00 | 15/Jul/2024 | 18:00 | Repairing of 403 Bay CSD |
| 143 | 726 | PLANNED | OCC_580 | POWERGRID_WR1 | TIE BAY - 400KV-WARORA(M)-WARORA-PG-1 AND FUTURE at WARORA-PG - 400KV | D | For Tie Bay AMP-411 | 15/Jul/2024 | 9:00 | 15/Jul/2024 | 18:00 | For Tie Bay AMP-411 @ Warora SS |
| 144 | 733 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-WARDHA-BHUGAON-1 | D | For Replacement of Old BHEL Insulators on gantries of element. | 15/Jul/2024 | 14:00 | 15/Jul/2024 | 20:00 | |
| 145 | 734 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KOLHAPUR-MS-ALKUD-1 | D | Diagnostic testing & Maintenance work | 15/Jul/2024 | 15:00 | 15/Jul/2024 | 23:00 | Load will be managed on 400KV Solapur Alkud line |
| 146 | 737 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV | D | Annual Maintenance of CB at Koradi-III SS. | 15/Jul/2024 | 09:00 | 15/Jul/2024 | 18:00 | Bay Outage |
| 147 | 738 | PLANNED | OCC_580 | MSLDC_OUTAGE | BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV | D | Retrofitting of O/C & E/F Back up relay. | 15/Jul/2024 | 09:00 | 15/Jul/2024 | 18:00 | Monday is load staggering day for kolhapur |
| 148 | 739 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV | D | Diagnostic testing & Maintenance work | 15/Jul/2024 | 10:00 | 15/Jul/2024 | 14:00 | -- |
| 149 | 740 | PLANNED | OCC_580 | MSLDC_OUTAGE | KORADI-II - 400KV - BUS 2 | D | Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT | 15/Jul/2024 | 10:00 | 15/Jul/2024 | 17:30 | All feeders wil remain in service through 400kV Main Bus-1 |
| 150 | 741 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE | D | Diagnostic testing & Maintenance work | 15/Jul/2024 | 14:00 | 15/Jul/2024 | 18:00 | -- |
| 151 | 747 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-WARDHA-BHUGAON-1 | D | Routine line maintainance work | 15/Jul/2024 | 08:00 | 16/Jul/2024 | 18:00 | NA |
| 152 | 748 | PLANNED | OCC_580 | POWERGRID_WR2 | MAGARWADA - 400KV - BUS 2 | C | Interconnection of busbar for bay extension works | 15/Jul/2024 | 7:00 | 17/Jul/2024 | 18:00 | PG-WR2-MAGARWADA |
| 153 | 759 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-JEJURI-KARAD-1 | C | Replacement of Complete relay Panel and including replacement of cables from yard to relay panel. | 15/Jul/2024 | 09:00 | 25/Jul/2024 | 18:00 | NIL, all other grid lines will be in service. |
| 154 | 780 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-KALA-KUDUS-2 | D | AMP of 401L at MSETCL Kudus Substation. 400KV-KALA-KUDUS-1 A/R to be kept in Non-Auto mode. | 16/Jul/2024 | 9:00 | 16/Jul/2024 | 17:00 | |
| 155 | 801 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-WARDHA-KORADI-II-1 | D | Routine Maintenance & Dignostic testing work . | 16/Jul/2024 | 09:00 | 16/Jul/2024 | 17:00 | 400 KV WARORA - DEOLI 2 Line is in ckt |
| 156 | 802 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV | D | Routine Maintenance & Dignostic testing work . | 16/Jul/2024 | 09:00 | 16/Jul/2024 | 17:00 | Line will be charged through Tie CB 428. |
| 157 | 803 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-WARDHA-KORADI-II-1 | D | Diagnostic Testing of Line CVT BY 400kV Koradi-2 substation and LINE MAINT. WORKS by LMU Koradi | 16/Jul/2024 | 10:00 | 16/Jul/2024 | 17:30 | 400kV Koradi-II-HEPL Ckt. Will be service as alternate source |
| 158 | 807 | PLANNED | OCC_580 | WTPL | 400 KV PARLI- SOLAPUR-2 | D | AR disable for replacement of insulator in live line method. | 16/Jul/2024 | 8:00 | 31/Jul/2024 | 18:00 | AR disable |
| 159 | 809 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-KHARGHAR-1 | D | SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint. | 17/Jul/2024 | 5:00 | 17/Jul/2024 | 13:00 | SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint. |
| 160 | 826 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-TARAPUR 3&4-PADGHE-2 | D | AMP of Line Equipment | 17/Jul/2024 | 9:00 | 17/Jul/2024 | 17:00 | |
| 161 | 840 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV | D | Routine Maintenance & Dignostic testing work . | 17/Jul/2024 | 09:00 | 17/Jul/2024 | 17:00 | 400KV KORADI-WARDHA Line will be charged through Tie CB 414. |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuous | Reason | From | | To | | Remarks |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|---|
| 162 | 841 | PLANNED | OCC_580 | MSLDC_OUTAGE | KORADI - 400KV - BUS 1 | D | To change CT ratio of buscoupler bay in ZIV make busbar scheme (CU and PU) from 500/1 to 1000/1 | 17/Jul/2024 | 09:00 | 17/Jul/2024 | 18:00 | NA |
| 163 | 842 | PLANNED | OCC_580 | MSLDC_OUTAGE | BUS COUPLER BAY - KORADI - 400KV - BUS 1 AND KORADI - 400KV - BUS 2 at Koradi - 400KV | D | To change CT ratio of Busbar and LBB Protection core from 500/1 to 1000/1 | 17/Jul/2024 | 09:00 | 17/Jul/2024 | 18:00 | NA |
| 164 | 843 | PLANNED | OCC_580 | MSLDC_OUTAGE | 132KV-MANSAR-MS-PENCH-1 | D | For routine maintenance work | 17/Jul/2024 | 09:00 | 17/Jul/2024 | 18:00 | NA |
| 165 | 844 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-CHANDRAPU-II-1 | D | Diagnostic testing and allied bay maintenance work | 17/Jul/2024 | 10:00 | 17/Jul/2024 | 16:00 | Diagnostic testing and allied bay maintenance work |
| 166 | 845 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-SOLAPUR-BALE-1 | D | Outage is required for Quarterly Maintenance | 17/Jul/2024 | 10:00 | 17/Jul/2024 | 18:00 | Breaker of PGCIL line at Bale End will be made off |
| 167 | 848 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | Routine line maintenance work | 17/Jul/2024 | 08:00 | 18/Jul/2024 | 18:00 | NA |
| 168 | 849 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-PUNE-GIS-PUNE-PG-3 | C | FOR ATTENDING SF6 GAS LEAKAGE WORK IN 407GD 7R 7B SPACER | 17/Jul/2024 | 6:00 | 19/Jul/2024 | 18:00 | GAS LEAKAGE IDENTIFIED IN LINE GIB COMPARTMENT ,LINE OUTAGE IS REQUIRED. |
| 169 | 853 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-WARDHA-BHUGAON-1 | D | A/R out of service for Balance PID Work. | 17/Jul/2024 | 08:00 | 30/Jul/2024 | 18:00 | NA |
| 170 | 893 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV | D | Routine Maintenance & Dignostic testing work . | 18/Jul/2024 | 09:00 | 18/Jul/2024 | 17:00 | Line will be charged through Main CB 429. |
| 171 | 894 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-2 | D | LINE/ s/s maintenance | 18/Jul/2024 | 09:00 | 18/Jul/2024 | 17:30 | - |
| 172 | 895 | PLANNED | OCC_580 | MEGPTCL | MAIN BAY - 400KV-AKOLA-AKOLA (2)-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV | D | SF6 Gas Analysis Of CB. | 18/Jul/2024 | 10:00 | 18/Jul/2024 | 13:00 | BAY OUTAGE |
| 173 | 896 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TALEGAON-PUNE-PG-2 | D | Cold line washing of insulators & Other Maintenance Work. | 18/Jul/2024 | 10:00 | 18/Jul/2024 | 17:00 | - |
| 174 | 897 | PLANNED | OCC_580 | MSLDC_OUTAGE | 765KV/400KV EKTUNI-ICT-1 | D | Routine testing and Diagnostic testing works | 18/Jul/2024 | 10:00 | 18/Jul/2024 | 18:00 | 765kv ICT II will be in service. |
| 175 | 913 | PLANNED | OCC_580 | POWERGRID_WRI | WARDHA - 220KV - BUS 1 | D | For Replacement of Old BHEL Insulators on gantries of element. Each Feeder will be shifted on TBC one at time | 19/Jul/2024 | 7:00 | 19/Jul/2024 | 20:00 | All bay shifted on TBC bay & their main bay out one by one during maintenance of each bay |
| 176 | 914 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 | D | Routine Testing and Diagnostic testing works | 19/Jul/2024 | 10:00 | 19/Jul/2024 | 18:00 | 765/400kv ICT-2 AND BUS RECTOR will be in service via 765kv Main bus 2 and 765kv Main bus 1 resp. |
| 177 | 915 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-WARDHA-AKOLA-1 | D | For Replacement of Old BHEL Insulators on gantries of element. | 19/Jul/2024 | 7:00 | 19/Jul/2024 | 13:00 | |
| 178 | 920 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 | D | For AMP | 19/Jul/2024 | 7:00 | 19/Jul/2024 | 18:00 | 412L. |
| 179 | 925 | PLANNED | OCC_580 | POWERGRID_WRI | AKOLA - 400KV - BUS 2 | D | For Replacement of Old BHEL Insulators on gantries of element. | 19/Jul/2024 | 7:00 | 19/Jul/2024 | 20:00 | |
| 180 | 930 | PLANNED | OCC_580 | POWERGRID_WRI | MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV | D | AMP of Bay Equipment | 19/Jul/2024 | 9:00 | 19/Jul/2024 | 17:00 | |
| 181 | 946 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-WARDHA-AKOLA-2 | D | For Replacement of Old BHEL Insulators on gantries of element. | 19/Jul/2024 | 14:00 | 19/Jul/2024 | 20:00 | |
| 182 | 948 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-1 | D | (1) CT testing, (2) Bay maintenance work. (3)B Ph String replacement at location No 18 | 19/Jul/2024 | 09:00 | 19/Jul/2024 | 18:00 | - |
| 183 | 949 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 | D | Routine testing and Diagnostic testing works | 19/Jul/2024 | 10:00 | 19/Jul/2024 | 18:00 | 765kv BUS REACTOR will be in service via TIE bay and 765kv Main bus 2 |
| 184 | 952 | PLANNED | OCC_580 | POWERGRID_WRI | MAIN BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV - BUS 1B at Wardha - 400KV | D | For Replacement of DAC by M/s CGL. | 19/Jul/2024 | 7:00 | 22/Jul/2024 | 18:00 | |
| 185 | 956 | PLANNED | OCC_580 | POWERGRID_WRI | WARDHA - 220KV - BUS 2 | D | For Replacement of Old BHEL Insulators on gantries of element. | 20/Jul/2024 | 7:00 | 20/Jul/2024 | 20:00 | All bay shifted on TBC bay & their main bay out one by one during maintenance of each bay |
| 186 | 960 | PLANNED | OCC_580 | POWERGRID_WRI | AKOLA - 400KV - BUS 1 | D | For Replacement of Old BHEL Insulators on gantries of element. | 20/Jul/2024 | 7:00 | 20/Jul/2024 | 20:00 | |
| 187 | 963 | PLANNED | OCC_580 | POWERGRID_WRI | MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV | D | AMP of 404 bay at MSETCL. Kudus | 20/Jul/2024 | 9:00 | 20/Jul/2024 | 17:00 | |
| 188 | 973 | PLANNED | OCC_580 | MSLDC_OUTAGE | 765KV/400KV EKTUNI-ICT-2 | D | Routine testing and Diagnostic testing works | 20/Jul/2024 | 09:00 | 20/Jul/2024 | 18:00 | 765kv ICT I will be in service. |
| 189 | 978 | PLANNED | OCC_580 | POWERGRID_WRI | 400KV-CHANDRAPUR-BHADRAWATI-2 | C | Replacement of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL.SS, AMP works & CVT replacement at Bhadrawati end. | 20/Jul/2024 | 8:00 | 23/Jul/2024 | 20:00 | retrofitting of pantograph Isolator, CVT replacement at BVT end |
| 190 | 979 | PLANNED | OCC_580 | APMIL | 400KV/11.5KV TIRODA-ST-2 | C | ST-2 Maintenance, testing and painting work. Main bay and Tie bay equipment maintenance work | 20/Jul/2024 | 9:00 | 24/Jul/2024 | 18:00 | 400KV Tirda-Warora-2 will be in service on main bay |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuo us | Reason | From | | To | | Remarks |
|--------|----------------|--------------|------------|------------------------------|--|---------------------------|---|-------------|-------|-------------|-------|--|
| 191 | 85 | PLANNED | OCC_580 | WITPL | 400 KV PARLI-SOLAPUR-1 | D | AR disable for replacement of insulator in live line method. | 21/Jul/2024 | 8:00 | 31/Jul/2024 | 18:00 | AR disable |
| 192 | 985 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-2 | D | hardware tightening and cold washing | 21/Jul/2024 | 09:00 | 21/Jul/2024 | 23:00 | Load managed on 400kv parli-karjat ckt 1 line |
| 193 | 999 | PLANNED | OCC_580 | POWERGRID_WR1 | 220KV-PARLI-OSMANABAD-M-1 | D | AMP WORK OF MAIN BAY AND LINE BAY | 22/Jul/2024 | 8:00 | 22/Jul/2024 | 18:00 | AMP WORK OF MAIN BAY AND LINE BAY |
| 194 | 1005 | PLANNED | OCC_580 | POWERGRID_WR2 | MAIN BAY - 400KV/220KV BOISAR-ICT-1 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV | D | AMP | 22/Jul/2024 | 9:00 | 22/Jul/2024 | 17:30 | PG-WR2-BOISAR |
| 195 | 1018 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-MUDSHINGI-CHIKKODI-II-1 | D | Maintenance work | 22/Jul/2024 | 09:00 | 22/Jul/2024 | 18:00 | The said work is very mportant |
| 196 | 1019 | PLANNED | OCC_580 | MSETCL | 220KV-MUDSHINGI-CHIKKODI-II-1 | D | Maintenance work | 22/Jul/2024 | 09:00 | 22/Jul/2024 | 18:00 | The said work is very important |
| 197 | 1059 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 | D | For AMP work @ Pune765 | 23/Jul/2024 | 9:00 | 23/Jul/2024 | 18:00 | For AMP work @ Pune765 |
| 198 | 1064 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV | D | Routine testing and Diagnostic testing works | 23/Jul/2024 | 10:00 | 23/Jul/2024 | 18:00 | 765kv EKTUNI-AKOLA 1 will be in service via Tie bay and 765kv Main bus 1 |
| 199 | 1086 | PLANNED | OCC_580 | POWERGRID_WR2 | TBC BAY - BOISAR - 220KV - BUS 1 AND FUTURE at BOISAR - 220KV | D | AMP | 24/Jul/2024 | 9:00 | 24/Jul/2024 | 17:30 | PG-WR2-BOISAR |
| 200 | 1101 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-2 | D | LINE/ s/s maintenance | 24/Jul/2024 | 09:00 | 24/Jul/2024 | 17:30 | - |
| 201 | 1102 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-SOLAPUR-M-SOLAPUR-1 | D | Hardware tightening and cold washing | 24/Jul/2024 | 09:00 | 24/Jul/2024 | 18:00 | Line will be in service |
| 202 | 1103 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-SOLAPUR-KUMBARI-2 | D | Outage is required for Quarterly Maintenance | 24/Jul/2024 | 10:00 | 24/Jul/2024 | 17:00 | Breaker of PGCIL line at South Solapur End will be made off |
| 203 | 1104 | PLANNED | OCC_580 | MSLDC_OUTAGE | KUMBARI - 220KV - BUS 2 | D | Outage is required for Quarterly Maintenance | 24/Jul/2024 | 11:00 | 24/Jul/2024 | 17:00 | Breaker of PGCIL line at South Solapur End will be made off |
| 204 | 82 | PLANNED | OCC_580 | POWERGRID_WR1 | PUNE-GIS - 400KV - BUS 1 | C | 400 kv GIS BUS MODULE CONNECTION WITH EXISTING 400 kv BUS-1, SIMULTENEOUS OUTAGE OF 400 kv PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED .(400/220 kv | 25/Jul/2024 | 9:00 | 27/Jul/2024 | 18:00 | OUTAGE IS BEING TAKEN FOR 400/220 kv EXTENSION WORK (CONSTRUCTION) UNDER WRES XXV1 S993 |
| 205 | 83 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 | C | 400 kv GIS BUS MODULE CONNECTION WITH EXISTING 400 kv BUS-1, SIMULTENEOUS OUTAGE OF 400 kv PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED . | 25/Jul/2024 | 9:00 | 27/Jul/2024 | 18:00 | OUTAGE IS BEING TAKEN FOR 400/220 kv EXTENSION WORK (CONSTRUCTION) UNDER WRES XXV1 S993 |
| 206 | 1112 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-LONIKHAND-PUNE-PG-1 | D | To maintain the ground clearance by using JCB in span between loc no. 50-51, 51-52 and Cold line washing | 25/Jul/2024 | 6:00 | 25/Jul/2024 | 13:00 | - |
| 207 | 1125 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY OF 220KV-SOLAPUR-NARANGWADI-2 AND SOLAPUR - 220KV - BUS 1 @SOLAPUR - 220KV at Solapur - 220KV | D | Bay AMP Works Note : 220KV Narangwadi-2 line shall be in service via TBC. | 25/Jul/2024 | 8:00 | 25/Jul/2024 | 18:00 | |
| 208 | 1129 | PLANNED | OCC_580 | POWERGRID_WR1 | PUNE-PG - 220KV - BUS#1 | D | For Hotspot rectification | 25/Jul/2024 | 9:00 | 25/Jul/2024 | 17:30 | Each bay will be taken on TBC bay |
| 209 | 1134 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-2 | D | (1) CT & CVT testing, (2) Bay maintenance work. (3) Hardware tightening & fitting work | 25/Jul/2024 | 10:00 | 25/Jul/2024 | 18:00 | - |
| 210 | 1137 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND FUTURE at EKTUNI - 765KV | D | Routine testing and Diagnostic testing works | 25/Jul/2024 | 10:00 | 25/Jul/2024 | 18:00 | 765kv ICT-1 1 will be in service via 765kv Main bus 2 |
| 211 | 1146 | PLANNED | OCC_580 | MEGPTCL | 765KV/400KV TIRODA-ICT-1 | C | Maintenance and testing work. Main bay and Tie bay equipment maintenance work | 25/Jul/2024 | 09:00 | 26/Jul/2024 | 18:00 | GT-1 and GT-4 will be in service on Main bay |
| 212 | 343 | PLANNED | OCC_580 | POWERGRID_WR2 | MAIN BAY - 400KV/220KV BOISAR-ICT-3 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV | D | AMP | 26/Jul/2024 | 9:00 | 26/Jul/2024 | 17:30 | PG-WR2-BOISAR |
| 213 | 344 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV/220KV PUNE-PG-ICT-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV | D | For AMP Work | 26/Jul/2024 | 9:00 | 26/Jul/2024 | 17:30 | Pune ICT_1 in service through the 405 TIE Bay |
| 214 | 352 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Routine Line maintenance work | 26/Jul/2024 | 08:00 | 26/Jul/2024 | 18:00 | 400kv Padghe II will be in in service |
| 215 | 353 | PLANNED | OCC_580 | MSLDC_OUTAGE | LONIKHAND - 400KV - BUS 2 | D | Conductor Strengthening work in Jejuri 2 Bay by Hot Line Unit | 26/Jul/2024 | 09:00 | 26/Jul/2024 | 18:00 | 400kv Jejuri ckt 2 to be shifted on TBC |
| 216 | 344 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV/220KV PUNE-PG-ICT-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV | D | For AMP Work | 26/Jul/2024 | 9:00 | 26/Jul/2024 | 17:30 | Pune ICT_1 in service through the 405 TIE Bay |
| 217 | 352 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Routine Line maintenance work | 26/Jul/2024 | 08:00 | 26/Jul/2024 | 18:00 | 400kv Padghe II will be in in service |
| 218 | 353 | PLANNED | OCC_580 | MSLDC_OUTAGE | LONIKHAND - 400KV - BUS 2 | D | Conductor Strengthening work in Jejuri 2 Bay by Hot Line Unit | 26/Jul/2024 | 09:00 | 26/Jul/2024 | 18:00 | 400kv Jejuri ckt 2 to be shifted on TBC |
| 219 | 1155 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PARLI-SOLAPUR-1 | D | AMP WORK OF LINE BAY | 26/Jul/2024 | 8:00 | 26/Jul/2024 | 18:00 | AMP WORK OF LINE BAY |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuo us | Reason | From | | To | | Remarks |
|--------|----------------|--------------|------------|------------------------------|---|---------------------------|---|-------------|-------|-------------|-------|---|
| 220 | 1156 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PARLI-SOLAPUR-2 | D | AR IN NON-AUTO | 26/Jul/2024 | 8:00 | 26/Jul/2024 | 18:00 | AR IN NON-AUTO |
| 221 | 1157 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 220KV-SOLAPUR-KUMBARI-1 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV | D | Bay AMP Works Note : 220kV Kumbhari-1 line shall be in service via TBC. | 26/Jul/2024 | 8:00 | 26/Jul/2024 | 18:00 | |
| 222 | 1173 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV-BHUSAVAL-AKOLA-1 at AKOLA - 400K | D | FOR DIAGNOSTIC AND MAINTENANCE WORK | 26/Jul/2024 | 09:00 | 26/Jul/2024 | 17:00 | LD AMBAZARI PERMISSION REQUIRED |
| 223 | 365 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-PUNE-GIS-PUNE-PG-3 | D | For AMP Work | 27/Jul/2024 | 9:00 | 27/Jul/2024 | 17:30 | Line Owned By ADANI Trans |
| 224 | 1189 | PLANNED | OCC_580 | POWERGRID_WR1 | PARLI - 220KV - BUS 1 | D | AMP WORK OF 220KV BUS-1 & RELAY TESTING | 28/Jul/2024 | 8:00 | 28/Jul/2024 | 18:00 | All bay shifted on TBC bay & their main bay out one by one during maintenance of each bay |
| 225 | 1190 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TARAPUR 1-2-BORIVALI-1 | D | outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during work of Providing Repair Sleeve for damaged Conductor at Loc No. 158-159 Bottom Ph of 220kV PGCIL - | 28/Jul/2024 | 09:00 | 28/Jul/2024 | 17:00 | outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during work of Providing Repair Sleeve for damaged Conductor at Loc No. 158-159 Bottom Ph of 220kV PGCIL - |
| 226 | 1195 | PLANNED | OCC_580 | POWERGRID_WR1 | MAIN BAY - 400KV-AURANGABAD-BOISAR-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV | D | For AMP | 29/Jul/2024 | 7:00 | 29/Jul/2024 | 18:00 | 430 |
| 227 | 1196 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-AKOLA-1 | D | For Amp of Line Bay | 29/Jul/2024 | 7:00 | 29/Jul/2024 | 20:00 | |
| 228 | 1205 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KORADI-II-KORADI-III-1 | D | LINE MAINT. WORKS | 29/Jul/2024 | 06:00 | 29/Jul/2024 | 18:00 | NA |
| 229 | 1206 | PLANNED | OCC_580 | MSLDC_OUTAGE | MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV | D | CB pole overhauling work.400 KV Padghe I will be in service through TBC | 29/Jul/2024 | 08:00 | 29/Jul/2024 | 18:00 | 400 KV Padghe I will be in service through TBC |
| 230 | 1207 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TALANGADE(MS)-CHIKKODI-II-1 | D | Maintenance work | 29/Jul/2024 | 09:00 | 29/Jul/2024 | 18:00 | The said work is very important |
| 231 | 1208 | PLANNED | OCC_580 | MSETCL | 220KV-TALANGADE(MS)-CHIKKODI-II-1 | D | Maintenance work | 29/Jul/2024 | 09:00 | 29/Jul/2024 | 18:00 | The said work is very important |
| 232 | 1218 | PLANNED | OCC_580 | POWERGRID_WR1 | 400KV-WARDHA-AKOLA-2 | D | For Amp of Line Bay | 30/Jul/2024 | 7:00 | 30/Jul/2024 | 20:00 | |
| 233 | 1219 | PLANNED | OCC_580 | POWERGRID_WR1 | PARLI - 220KV - BUS 2 | D | AMP WORK OF 220KV BUS-2 & RELAY TESTING | 30/Jul/2024 | 8:00 | 30/Jul/2024 | 18:00 | All bay shifted on TBC bay & their main bay out one by one during maintenance of each bay |
| 234 | 1228 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KORADI-II-KORADI-III-2 | D | LINE MAINT. WORKS | 30/Jul/2024 | 06:00 | 30/Jul/2024 | 18:00 | NA |
| 235 | 1229 | PLANNED | OCC_580 | MSLDC_OUTAGE | TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV | D | FOR DIAGNOSTIC AND MAINTENANCE WORK | 30/Jul/2024 | 09:00 | 30/Jul/2024 | 17:00 | LD AMBAZARI PERMISSION REQUIRED |
| 236 | 1230 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KORADI-II-KORADI-III-2 | D | Diagnostic Testing of Line CT | 30/Jul/2024 | 10:00 | 30/Jul/2024 | 18:30 | 400kV Koradi-II -Koradi-III Ckt-I will be service as alternate source |
| 237 | 1237 | PLANNED | OCC_580 | POWERGRID_WR1 | 765KV-AURANGABAD-SOLAPUR-2 | D | PRV NC contact modification of Line Reactor. | 31/Jul/2024 | 8:00 | 31/Jul/2024 | 18:00 | |
| 238 | 1238 | PLANNED | OCC_580 | POWERGRID_WR1 | 765KV-AURANGABAD-SOLAPUR-2 I./R@ SOLAPUR - 765KV | D | PRV NC contact modification | 31/Jul/2024 | 8:00 | 31/Jul/2024 | 18:00 | |

Maharashtra State Load Despatch Centre

Monthly Outage list Not Considered in WRLDC OCCM for the Month of JULY' 2024

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuous | Reason | From | | To | | Remarks | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|--|-------------|-------|-------------|-------|---|--|
| 1 | 38 | PLANNED | OCC_580 | MSLDC_OUTAGE | HVDC 500KV CHANDRAPUR HVDC POLE 1 | D | Pre Monsoon Maintenance work | 06/Jul/2024 | 10:00 | 06/Jul/2024 | 17:00 | Pole-II will be in service | Site not availing. |
| 2 | 40 | PLANNED | OCC_580 | MSLDC_OUTAGE | HVDC 500KV CHANDRAPUR HVDC POLE 2 | D | Pre Mansoon maintenance work | 07/Jul/2024 | 10:00 | 07/Jul/2024 | 17:00 | Pole I will be in service | Site not availing. |
| 3 | 84 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | PID testing work | 01/Jul/2024 | 08:00 | 16/Jul/2024 | 18:00 | - | In view of Pune Padghe and Aurangabad Padghe long outage and |
| 4 | 85 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-1 | C | To complete balance work of replacement of existing conductor by HTLS conductor. | 01/Jul/2024 | 08:00 | 22/Jul/2024 | 22:00 | To complete balance work of replacement of existing conductor by HTLS conductor. | In view of Pune Padghe and Aurangabad Padghe |
| 5 | 88 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-1 | D | For OPGW installation replacing existing earth wire (AR Out) | 01/Jul/2024 | 08:00 | 31/Jul/2024 | 18:00 | Work is proposed by MTCIL. | In view of Karjat Lonikhand D/C AR in NA. |
| 6 | 89 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-2 | D | For OPGW installation replacing existing earth wire (AR Out) | 01/Jul/2024 | 08:00 | 31/Jul/2024 | 18:00 | Work is proposed by MTCIL. | In view of Karjat Lonikhand D/C AR in NA. |
| 7 | 90 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-1 | D | PID testing | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 18:00 | Line will be in service | In view of Karjat Lonikhand D/C AR in NA. |
| 8 | 91 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-1 | D | PID testing work | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 18:00 | - | In view of Karjat Lonikhand D/C AR in NA. |
| 9 | 92 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-PARLI-M-KARJAT-2 | D | PID testing work | 01/Jul/2024 | 09:00 | 31/Jul/2024 | 18:00 | - | In view of Karjat Lonikhand D/C AR in NA. |
| 10 | 96 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-2(Taken on TBC at Padghe end) | C | 1) Diagnostic Testing Work 2.Replacement of all phase LA. 3. Replacement of Distance & | 05/Jul/2024 | 08:00 | 13/Jul/2024 | 23:00 | 1) weather condition should be clear | In view of Aurangabad Pune Padghe line outage |
| 11 | 99 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | D | To maintain the ground clearance by using JCB in span between loc no. 55-56, 56-57 and Cold line washing | 07/Jul/2024 | 10:00 | 07/Jul/2024 | 18:00 | - | In view of Aurangabad Pune Padghe line outage |
| 12 | 100 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-LONIKHAND-PUNE-PG-1 | D | DT Work & Bay Maintenance | 11/Jul/2024 | 6:00 | 11/Jul/2024 | 13:00 | - | In view of Aurangabad Pune Padghe lines outage. |
| 13 | 101 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-LONIKHAND-CHAKAN-1 | D | Routine maintenance and DT. | 11/Jul/2024 | 10:00 | 11/Jul/2024 | 18:00 | - | In view of Aurangabad Pune Padghe lines outage. |
| 14 | 104 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-1 | D | Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14) | 13/Jul/2024 | 07:00 | 13/Jul/2024 | 18:00 | 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. 2) Both outages on 220kV Boisaar-PGCIL-1 & 3 are inter related for the said work. | In view of Aurangabad Pune Padghe lines outage. |
| 15 | 105 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-3 | D | Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12) | 13/Jul/2024 | 22:00 | 13/Jul/2024 | 18:00 | 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. 2) Both outages on 220kV Boisaar-PGCIL-1 & 3 are inter related for the said work. | In view of Aurangabad Pune Padghe lines outage. |
| 16 | 108 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | D | SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint | 14/Jul/2024 | 08:00 | 14/Jul/2024 | 18:00 | SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint | In view of Aurangabad Pune Padghe lines outage. |
| 17 | 109 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BORIVALI-1 | D | Replacement of Disc Insulator broken at Loc No. 107 Y-Ph PGCIL side & 150 B-Ph. | 14/Jul/2024 | 09:00 | 14/Jul/2024 | 17:00 | Simultaneously outage is required on 220kV Tarapur - Borivali Line (for safety purpose) | In view of Aurangabad Pune Padghe lines outage. |
| 18 | 110 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-TARAPUR 1-2-BORIVALI-1 | D | outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during work of Replacement of Disc Insulator broken at Loc No. 107 Y-Ph PGCIL side & 150 B-Ph of 220kV PGCIL - Borivali line. | 14/Jul/2024 | 09:00 | 14/Jul/2024 | 17:00 | outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during work of Replacement of Disc Insulator broken at Loc No. 107 Y-Ph PGCIL side & 150 B-Ph of 220kV PGCIL - Borivali line. | In view of Aurangabad Pune Padghe lines outage. |
| 19 | 111 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-3 | D | Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12) | 14/Jul/2024 | 22:00 | 14/Jul/2024 | 18:00 | 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. 2) Both outages on 220kV Boisaar-PGCIL-1 & 3 are inter related for the said work. | In view of Aurangabad Pune Padghe lines outage. |
| 20 | 124 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-2 | D | Bay maintenance and R &M work . | 21/Jul/2024 | 05:00 | 21/Jul/2024 | 10:00 | Bay maintenance and R &M work . | In view of Aurangabad Pune Padghe lines outage. |
| 21 | 125 | PLANNED | OCC_580 | MSLDC_OUTAGE | BOISAR-M - 220KV - BUS 1 | D | 220kV A-Bus Isolator R/M Works. 220kV A-Bus connected line/equipment: Viraj Line: Tarapur Line: | 21/Jul/2024 | 07:00 | 21/Jul/2024 | 20:00 | 1) During the outage, all Elements / Lines will be in service through 220kV B-Bus. 2) Due to A-Bus Isolator alignment issue of 220kV PGCIL - Boisar Line No. 3, 220kV A-Bus outage is required prior to 220kV B-Bus. | In view of Aurangabad Pune Padghe lines outage. |
| 22 | 126 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-PANCHALI-1 | D | For Line Maintenance Work. | 21/Jul/2024 | 09:00 | 21/Jul/2024 | 17:00 | For Line Maintenance Work. | In view of Aurangabad Pune Padghe lines outage. |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element OCC_571 | Daily / Continuo us | Reason | From | | To | | Remarks | |
|--------|----------------|--------------|------------|------------------------------|---------------------------|---------------------------|--|-------------|-------|-------------|-------|--|---|
| 23 | 127 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | D | Cold line washing | 21/Jul/2024 | 10:00 | 21/Jul/2024 | 18:00 | - | In view of Aurangabad Pune Padghe lines outage. |
| 24 | 135 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-2 | C | 1) Replacement of CB with rating of 3150A for HTLS work 2) A& B bus PG isolator maint work 3 400kV Kalwa -2 in service through TBC | 26/Jul/2024 | 08:00 | 04/Aug/2024 | 23:00 | 1) Weather condition should be clear during CB erection and commissioning work | In view of Aurangabad Pune Padghe lines outage. |
| 25 | 138 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Routine Line maintenance work;CT tanD testing | 27/Jul/2024 | 08:00 | 27/Jul/2024 | 18:00 | 400kV Padghe II will be in in service | In view of Aurangabad Pune Padghe lines outage. |
| 26 | 142 | PLANNED | OCC_580 | MSLDC_OUTAGE | BOISAR-M - 220KV - BUS 2 | D | 220kV B-Bus Isolator r/m works. 220kV B-Bus connected line/ equipment: Ghodbandar Line: | 28/Jul/2024 | 07:00 | 28/Jul/2024 | 20:00 | During the outage, all Elements / Lines will be in service through 220kV A-Bus. | In view of Aurangabad Pune Padghe lines outage. |
| 27 | 143 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | D | SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint | 28/Jul/2024 | 08:00 | 28/Jul/2024 | 18:00 | SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint | In view of Aurangabad Pune Padghe lines outage. |
| 28 | 144 | PLANNED | OCC_580 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | D | SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work. | 28/Jul/2024 | 08:00 | 28/Jul/2024 | 18:00 | SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work. | In view of Aurangabad Pune Padghe lines outage. |
| 29 | 145 | PLANNED | OCC_580 | MSLDC_OUTAGE | 220KV-BOISAR-BORIVALI-1 | D | Providing Repair Sleeve for damaged Conductor at Loc No. 158- 159 Bottom Ph. | 28/Jul/2024 | 09:00 | 28/Jul/2024 | 17:00 | Simultaneously, outage is required on 220kV Tarapur - Borivali Line (for safety purpose) | In view of Aurangabad Pune Padghe lines outage. |

State Element outage list for the month of JULY'2024

| Sr.no. | Voltage | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark ,If any. |
|--------|---------|--|-----------|-----------|-----------|---------|-------|--|--------|--------|---|
| 1 | 400 KV | PARLI - KUMBHARGAON (NANDED) CKT - 1 | 01-Jul-24 | 09:00 | 31-Jul-24 | 18:00 | Daily | PID testing work | MSETCL | MSETCL | - |
| 2 | 400 KV | WARORA - IEPL | 02-Jul-24 | 09:00 | 02-Jul-24 | 17:00 | Daily | Line CT,CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work. Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work . | MSETCL | MSETCL | Both Main & Tie Bay is in OFF condition. |
| 3 | 400 KV | WARORA - IEPL | 02-Jul-24 | 09:00 | 02-Jul-24 | 17:00 | Daily | Routine Maintenance & Dignostic testing work . | MSETCL | MSETCL | 400 KV KORADI 2-WARDHA PGCIL Line is in ckt |
| 4 | 400 KV | TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA | 02-Jul-24 | 09:00 | 02-Jul-24 | 17:00 | Daily | Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work . | MSETCL | MSETCL | only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB. |
| 5 | 400 KV | MAIN BAY (403) of 500 MVA ICT @ ALKUD | 02-Jul-24 | 10:00 | 02-Jul-24 | 14:00 | Daily | Diagnostic testing & Maintenance work | MSETCL | MSETCL | -- |
| 6 | 400 KV | 400/220 KV 500 MVA ICT @ ALKUD | 02-Jul-24 | 10:00 | 02-Jul-24 | 17:00 | Daily | Diagnostic testing & Maintenance work | MSETCL | MSETCL | Load will be managed on 400KV Karad & Talandge Substation |
| 7 | 400 KV | STATION TF No 4 @ CHANDRAPUR GCR | 03-Jul-24 | 13:00 | 03-Jul-24 | 16:00 | Daily | 1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work. | MSETCL | MSETCL | Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. |
| 8 | 400 KV | 400/220/33 KV 315 MVA ICT - 2 @ KORADI | 03-Jul-24 | 08:00 | 03-Jul-24 | 18:00 | Daily | Retrofitting of old Sifang CSC 211 HV & LV Backup protection relay by New Siemens make 7SJ6621 | MSETCL | MSETCL | NA |
| 9 | 400 KV | NEW KOYNA - STAGE IV CKT - 1 | 03-Jul-24 | 08:00 | 03-Jul-24 | 17:00 | Daily | Relay testing work , Routine maint. Work | MSETCL | MSETCL | ---- |
| 10 | 400 KV | MAIN BAY (401) OF BUS REACTOR @ ALKUD | 03-Jul-24 | 10:00 | 03-Jul-24 | 14:00 | Daily | Diagnostic testing & Maintenance work | MSETCL | MSETCL | -- |
| 11 | 400 KV | TIE BAY - 402 OF BUS REACTOR @ ALKUD | 03-Jul-24 | 14:00 | 03-Jul-24 | 18:00 | Daily | Diagnostic testing & Maintenance work | MSETCL | MSETCL | -- |
| 12 | 400 KV | BUS REACTOR (125 MVA) @ ALKUD | 03-Jul-24 | 10:00 | 03-Jul-24 | 18:00 | Daily | Diagnostic testing & Maintenance work | MSETCL | MSETCL | -- |
| 13 | 400 KV | BUS REACTOR (125MVA) @ WARORA | 04-Jul-24 | 09:00 | 04-Jul-24 | 17:00 | Daily | Routine and Premonsoon maintenance work. | MSETCL | MSETCL | Reactor kept in OFF position.,Tie Bay No. 403 also kept in OFF position. |
| 14 | 400 KV | TIE BAY - 402 CHD SWITCHING CKT1 AND CHANDRAPUR GCR CKT-1 @ CHANDRAPUR 2 | 04-Jul-24 | 10:00 | 04-Jul-24 | 17:00 | Daily | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 15 | 400 KV | 400/220/33 KV 315MVA ICT - 1 @ CHAKAN | 04-Jul-24 | 10:00 | 04-Jul-24 | 18:00 | Daily | Routine Maintenance and DT. | MSETCL | MSETCL | - |
| 16 | 400 KV | 400/220/33 KV 500 MVA ICT - 1 @ JEJURI | 04-Jul-24 | 10:00 | 04-Jul-24 | 18:00 | Daily | For Routine Maintenance & Testing work | MSETCL | MSETCL | ICT-2 & ICT-3 will continue to remain in service |
| 17 | 400 KV | 400/220/33KV 315MVA ICT - 2 @ LONIKAND | 04-Jul-24 | 09:00 | 04-Jul-24 | 18:00 | Daily | DT Work & Bay Maintenance | MSETCL | MSETCL | - |

| Sr.no. | Voltage | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark ,If any. |
|--------|---------|--|-----------|-----------|-----------|---------|------------|---|---------|---------|---|
| 18 | 400 KV | CHANDRAPUR 2 - CHD SWITCHING CKT - 1 | 05-Jul-24 | 10:00 | 05-Jul-24 | 20:00 | Daily | Retrofitting of M-1 line differential relay | MSETCL | MSETCL | Relay retrofitting work to be carried at both ends |
| 19 | 400 KV | 400/220/20 KV 300 MVA ICT - 1 @ KORADI | 05-Jul-24 | 08:00 | 05-Jul-24 | 18:00 | Daily | Retrofitting of old Sifang CSC 211 HV & LV Backup protection relay by New Siemens make 7SJ6621 | MSETCL | MSETCL | NA |
| 20 | 400 KV | KHADKA-AURANGABAD (WALUJ) | 08-Jul-24 | 09:00 | 08-Jul-24 | 18:00 | Daily | Diagnostic Testing and routine maintenance work | MSETCL | MSETCL | NIL |
| 21 | 400 KV | 400/220/33 KV 315MVA ICT - 1 @ AKOLA | 08-Jul-24 | 09:00 | 08-Jul-24 | 17:00 | Daily | FOR DIAGNOSTIC AND MAINTENANCE WORK | MSETCL | MSETCL | LD AMBAZARI PERMISSION REQUIRED |
| 22 | 400 KV | KHADKA-AURANGABAD (WALUJ) | 08-Jul-24 | 06:00 | 09-Jul-24 | 22:00 | Continuous | FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK. | MSETCL | MSETCL | URGENT WORK. |
| 23 | 400 KV | 400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI | 08-Jul-24 | 08:00 | 08-Jul-24 | 18:00 | Daily | Retrofitting of old Static (EM) CDD type HV Backup protection relay by New Siemens make 7SJ6621 | MSETCL | MSETCL | NA |
| 24 | 400 KV | 400/220KV 315 MVA ICT - 1 @ NEW KOYNA | 08-Jul-24 | 08:00 | 08-Jul-24 | 17:00 | Daily | Relay testing work , Routine maint. Work | MSETCL | MSETCL | --- |
| 25 | 400 KV | PARLI - KUMBHARGAON (NANDED) CKT - 1 | 09-Jul-24 | 09:00 | 09-Jul-24 | 18:00 | Daily | 1) CT testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work | MSETCL | MSETCL | - |
| 26 | 400 KV | CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1 | 10-Jul-24 | 10:00 | 10-Jul-24 | 18:00 | Daily | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 27 | 400 KV | CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1 | 10-Jul-24 | 10:00 | 10-Jul-24 | 18:00 | Daily | regular line maintenance work | MSETCL | MSETCL | outage need for conductor strand repair |
| 28 | 400 KV | 400 /7.6KV Station T/F-5 A @ KHAPERKHEDA | 10-Jul-24 | 11:00 | 10-Jul-24 | 17:00 | Daily | Diagnostic Testing of Line CTs & Main Bay CTs | MSETCL | MSETCL | NA |
| 29 | 400 KV | KARAD - TALANDGE CKT - 2 | 11-Jul-24 | 15:00 | 11-Jul-24 | 23:00 | Daily | 1. Retrofitting of TCS Relay 2. Annual relay testing work | MSETCL | MSETCL | Monday is load staggering day for kolhapur |
| 30 | 400 KV | 400/220KV 315 MVA ICT - 2 @ NEW KOYNA | 11-Jul-24 | 08:00 | 11-Jul-24 | 17:00 | Daily | Relay testing work , Routine maint. Work | MSETCL | MSETCL | --- |
| 31 | 400 KV | 400/220/33 KV 500 MVA ICT - 2 @ JEJURI | 11-Jul-24 | 10:00 | 11-Jul-24 | 18:00 | Daily | For Routine Maintenance & Testing work | MSETCL | MSETCL | ICT-1 & ICT-3 will continue to remain in service |
| 32 | 400 KV | 400/220/33 KV 315 MVA ICT - 1 @ WALUJ | 12-Jul-24 | 09:00 | 12-Jul-24 | 18:00 | Daily | Diagnostic Testing and routine maintenance work. | MSETCL | MSETCL | NIL |
| 33 | 400 KV | MAIN BAY (409) OF AKOLA-1 CKT-1 @ AKOLA 2 | 12-Jul-24 | 15:00 | 12-Jul-24 | 18:00 | Daily | SF6 Gas Analysis Of CB. | MEGPTCL | MEGPTCL | BAY OUTAGE |
| 34 | 400 KV | KHADKA - BABLESHWAR | 12-Jul-24 | 6:00 | 13-Jul-24 | 22:00 | Continuous | FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK. | MSETCL | MSETCL | URGENT WORK. |
| 35 | 400 KV | JAIGAD - NEW KOYNA CKT - 2 | 15-Jul-24 | 08:00 | 15-Jul-24 | 17:00 | Daily | Relay testing work , Routine maint. Work | MSETCL | MSETCL | --- |
| 36 | 400 KV | MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2 | 16-Jul-24 | 10:00 | 16-Jul-24 | 13:00 | Daily | SF6 Gas Analysis Of CB. | MEGPTCL | MEGPTCL | BAY OUTAGE |
| 37 | 400 KV | TIE BAY (411) OF RPL CKT - 2 & AKOLA-1 CKT-2 @ AKOLA 2 | 16-Jul-24 | 15:00 | 16-Jul-24 | 18:00 | Daily | SF6 Gas Analysis Of CB. | MEGPTCL | MEGPTCL | BAY OUTAGE |
| 38 | 400 KV | 167 MVA SPARE ICT @ TALANDGE | 16-Jul-24 | 09:00 | 16-Jul-24 | 20:00 | Daily | Retrofitting of O/C & E/F Back up Relay | MSETCL | MSETCL | Spare ICT charged from HV side and kept on humming. |

| Sr.no. | Voltage | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark ,If any. |
|--------|---------|--|-----------|-----------|-----------|---------|------------|---|--------|--------|--|
| 39 | 400 KV | CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1 | 17-Jul-24 | 09:00 | 17-Jul-24 | 18:00 | Daily | Disc Repalcement work loc.no.432,455 | MSETCL | MSETCL | - |
| 40 | 400 KV | CHANDRAPUR 2 - CHD SWITCHING CKT - 2 | 18-Jul-24 | 10:00 | 18-Jul-24 | 20:00 | Daily | Retrofitting of M-1 Line Differential relay | MSETCL | MSETCL | Relay retrofitting work to be carried at both ends |
| 41 | 400 KV | LONIKAND - JEJURI CKT - 1 | 18-Jul-24 | 08:00 | 18-Jul-24 | 18:00 | Daily | For Distace Protection Relay Retrofitting work. Work to be carried out by GE. | MSETCL | MSETCL | 400 kV Jejuri-Lonikand Ckt-2, 400 kV Jejuri-Karad & 400 kV Jejuri-Koyna ST-IV will continue to remain in service. |
| 42 | 400 KV | MAIN BAY (407) OF BUS REACTOR @ LONIKAND 2 | 18-Jul-24 | 09:00 | 18-Jul-24 | 18:00 | Daily | Diagnostic testing | MSETCL | MSETCL | - |
| 43 | 400 KV | LONIKAND - JEJURI CKT - 1 | 18-Jul-24 | 08:00 | 18-Jul-24 | 18:00 | Daily | DT and Line Maintenance activities | MSETCL | MSETCL | - |
| 44 | 400 KV | STATION TF 8B @ CHANDRAPUR SWITCHING | 19-Jul-24 | 10:00 | 19-Jul-24 | 18:00 | Daily | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 45 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 19-Jul-24 | 08:00 | 20-Jul-24 | 18:00 | Daily | 1.Measurement of tandelta of Bushing of 50MVar Line shunt Reactor. 2.Premonsoon maintenance work of Reactor. 3. Maintenance and alignment of Isolators. 3. Bay routine maintenance work. | MSETCL | MSETCL | During outage 400KV CHD-2 CKT-1 & 2 400KV Khaperkheda, 400KV HVDC CKT-1 & 2, 400KV PGCIL CKT-1,2,3&4 will be in service. |
| 46 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 19-Jul-24 | 09:00 | 19-Jul-24 | 18:00 | Daily | 1)Reactor testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work | MSETCL | MSETCL | - |
| 47 | 400 KV | LONIKAND - JEJURI CKT - 2 | 19-Jul-24 | 5:00 | 19-Jul-24 | 13:00 | Daily | Cold line washing | MSETCL | MSETCL | - |
| 48 | 400 KV | 400KV NANDED(KUMBHARGAON)-PARLY CKT 2 | 20-Jul-24 | 10:00 | 20-Jul-24 | 18:00 | Daily | regular line maintenance work | MSETCL | MSETCL | need for repairing conductor strand |
| 49 | 400 KV | CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2 | 20-Jul-24 | 09:00 | 20-Jul-24 | 18:00 | Daily | Earthwire Stringing Work loc.no.497-500 & Nut bolt hardware tightning work | MSETCL | MSETCL | - |
| 50 | 400 KV | PARLI - KUMBHARGAON(NANDED) CKT - 2 | 20-Jul-24 | 09:00 | 20-Jul-24 | 18:00 | Daily | (1) CVT testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work | MSETCL | MSETCL | - |
| 51 | 400 KV | FUTURE CKT - 1 @ WARORA | 22-Jul-24 | 09:00 | 22-Jul-24 | 17:00 | Daily | Relay testing work & routine maintenance work. Relay testing work & routine maintenance work. | MSETCL | MSETCL | In Dia the 400KV IEPL ckt charged on its Main Bay CB |
| 52 | 400 KV | 400/220/33 KV 500 MVA ICT - 3 @ PARLI | 22-Jul-24 | 09:00 | 22-Jul-24 | 18:00 | Daily | 1) NDR & IV B/U relays testing work.2) Bay Maintenance work. | MSETCL | MSETCL | - |
| 53 | 400 KV | KORADI II - IEPL | 22-Jul-24 | 10:00 | 22-Jul-24 | 17:30 | Daily | Diagnostic Testing of Line CVT | MSETCL | MSETCL | 400kV Koradi-II-Wardha Ckt. Will be service as alternate soucre |
| 54 | 400 KV | KORADI II - IEPL | 22-Jul-24 | 06:00 | 22-Jul-24 | 18:00 | Daily | LINE MAINT. WORKS | MSETCL | MSETCL | NA |
| 55 | 400 KV | 400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR | 22-Jul-24 | 09:00 | 22-Jul-24 | 20:00 | Daily | Annual Relay Testing work | MSETCL | MSETCL | Monday is load staggering for kolhapur |
| 56 | 400 KV | 400 KV FUTURE BAY II @ WARORA | 23-Jul-24 | 09:00 | 23-Jul-24 | 17:00 | Daily | Relay testing work & routine maintenance work. | MSETCL | MSETCL | In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB. |
| 57 | 400 KV | STATION TF No 5 @ CHANDRAPUR GCR | 23-Jul-24 | 08:00 | 24-Jul-24 | 18:00 | Continuous | 1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine mainteance work. | MSETCL | MSETCL | During outage 400KV STN TF-4 will be in service. |
| 58 | 400 KV | KORADI - KHAPERKHEDA CKT - 2 | 23-Jul-24 | 08:00 | 23-Jul-24 | 21:00 | Daily | Retrofitting of old CSC-101 Main 1 Distance relay by New GE make P443 type Distance Relay | MSETCL | MSETCL | NA |
| 59 | 400 KV | KORADI - KHADKA | 25-Jul-24 | 06:00 | 26-Jul-24 | 22:00 | Continuous | FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK. | MSETCL | MSETCL | URGENT WORK. |

| Sr.no. | Voltage | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark ,If any. |
|--------|---------|--|-----------|-----------|-----------|---------|------------|---|--------|--------|--|
| 60 | 400 KV | PARLI - KUMBHARGAON (NANDED) CKT - 1 | 25-Jul-24 | 5:00 | 25-Jul-24 | 10:00 | Daily | regular line maintenance work | MSETCL | MSETCL | need for repairing conductor strand |
| 61 | 400 KV | KORADI - KHAPERKHEDA CKT - 2 | 25-Jul-24 | 09:00 | 25-Jul-24 | 18:00 | Daily | Retrofitting of old SEL 421 Main 2 Distance relay by New GE make P443 type Distance Relay | MSETCL | MSETCL | NA |
| 62 | 400 KV | LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2 | 25-Jul-24 | 14:00 | 25-Jul-24 | 23:00 | Daily | Diagnostic testing | MSETCL | MSETCL | - |
| 63 | 400 KV | JEJURI- KOYNA STAGE-IV | 25-Jul-24 | 16:00 | 25-Jul-24 | 23:00 | Daily | For Distace Protection Relay Retrofitting work. Work to be carried out by GE. | MSETCL | MSETCL | 400 kV Jejuri-Lonikand Ckt-2, 400 kV Jejuri-Lonikand Ckt-1 & 400 kV Jejuri-Karad will continue to remain in service. |
| 64 | 400 KV | 400/220/33 KV 315MVA ICT - 2 @ CHAKAN | 25-Jul-24 | 10:00 | 25-Jul-24 | 18:00 | Daily | Routine Maintenance and DT. | MSETCL | MSETCL | - |
| 65 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 26-Jul-24 | 09:00 | 26-Jul-24 | 18:00 | Daily | Nut bolt hardware tightning work/ Spacer Repalcement &loc. No.474,631,657 Disc Repalcement work | MSETCL | MSETCL | - |
| 66 | 400 KV | CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2 | 27-Jul-24 | 10:00 | 27-Jul-24 | 18:00 | Daily | regular line maintenance work | MSETCL | MSETCL | outage need for repairing of conductor strand |
| 67 | 400 KV | AKOLA - KHADKA (BHUSAWAL) | 27-Jul-24 | 06:00 | 28-Jul-24 | 22:00 | Continuous | FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK. | MSETCL | MSETCL | URGENT WORK. |