

509th WRPC OCCM approved Monthly Outage list for the Month of August'2018

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
1	11	400	KORADI-KHADKA	01/Aug/18	9:00	01/Aug/18	18:00	Daily	Tan Delta of Bushing, winding resistance and preventive maintenance work. of 400 Bhusawal Reactor at 400/220 Koradi s/s	MSETCL	MSETCL	
2	26	400	NAGOTHANE - DABHOL 2	01/Aug/18	8:00	01/Aug/18	18:00	Daily	Pending Hill cutting work at Loc.92-93 & 132-133 & Line Sign.Test	MSETCL	MSETCL	
3	37	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01/Aug/18	8:00	15/Aug/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
4	38	400	400/220/33 KV 315 MVA ICT - 1 @ PARLI	01/Aug/18	9:00	15/Aug/18	18:00	Continuous	Replacement of B Phase Unit by Overhauled Unit. Outage will be required on contineous basis.	MSETCL	MSETCL	
5	39	400	400 Warora - Parli Ckt-1	01/Aug/18	9:00	20/Aug/18	18:00	Daily	AR non auto mode for OPGW work.	WRTS-I	WRTS-I	
6	40	220	PUSAD - WARDHA (PG)	01/Aug/18	7:00	22/Aug/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
7	42	400	KORADI-KHADKA	01/Aug/18	8:00	31/Aug/18	19:00	Daily	PID Testing work . A/R in Non Auto Mode	MSETCL	MSETCL	
8	44	400	PARLI-SOLAPUR (LAMBOTI)	01/Aug/18	10:00	31/Aug/18	18:00	Daily	For PID Testing Work (AR off required)	MSETCL	MSETCL	
9	52	400	KHADKA - BABLESHWAR	02/Aug/18	9:00	05/Aug/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400 P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	Shall be facilitated after restoration of 400kV Dhule-Bableswhar-D/C
10	54	400	CHANDRAPUR-PARLI CKT-3	02/Aug/18	7:00	02/Aug/18	18:00	Daily	for replacement of Damaged Earthwire Cross Arm to avoid breakdown	MSETCL	MSETCL	
11	58	400	JEJURI- KOYNA STAGE-IV	02/Aug/18	8:00	02/Aug/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	
12	84	400	Dhariwal- Parli 400 Tr. Line	03/Aug/18	8:00	03/Aug/18	18:00	Daily	Outage for fixing of line Spacer cum Damper, Suspension Pilot clamp and Jumper Pad n&bs tightening works.	WRTS-I	Dhariwal Infrastructure Ltd.	
13	104	400	NAGOTHANE - DABHOL 1	03/Aug/18	8:00	04/Aug/18	18:00	Daily	Earthwire replacement at loc.42-43 & Line Sign.Test.	MSETCL	MSETCL	
14	115	400	DHULE - SSNNL I	04/Aug/18	8:00	05/Aug/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	
15	146	400	CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT - 2	06/Aug/18	7:00	06/Aug/18	18:00	Daily	for replacement of Damedged Earthwire Cross Arm to avoid breakdown	MSETCL	MSETCL	
16	148	400	400 SSP - Dhule - 2	06/Aug/18	8:00	06/Aug/18	18:00	Daily	PMM work	GETCO - Mah	GETCO	
17	157	400	AKOLA - WARDHA(PG) CKT - 1	06/Aug/18	9:00	06/Aug/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
18	170	220	BHUGAON - WARDHA (PG)	06/Aug/18	10:00	06/Aug/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
19	174	400	KORADI-KHADKA	06/Aug/18	13:00	06/Aug/18	16:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	
20	181	400	NEW KOYNA - DABHOL - I	06/Aug/18	8:00	07/Aug/18	18:00	Daily	String replacement at loc.91 & Line Sign.Test.	MSETCL	MSETCL	
21	185	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	06/Aug/18	8:00	09/Aug/18	18:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400 P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	
22	186	400	MAIN BUS - 2 @ TALANDGE	06/Aug/18	7:00	10/Aug/18	20:00	Continuous	Replacement of Strings, Alignment of Bus Hangers	MSETCL	MSETCL	
23	236	220	KALMESHVAR-PANDHURNA	08/Aug/18	9:00	08/Aug/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
24	246	400	EKTUNI - TAPTITANDA CKT - 1	08/Aug/18	10:00	08/Aug/18	18:00	Daily	Relay testing work	MSETCL	MSETCL	
25	247	400	PARLI-SOLAPUR (LAMBOTI)	08/Aug/18	10:00	08/Aug/18	18:00	Daily	Hardware Tightening & Fitting Work At Loc No-57,72,110, 137,131,140	MSETCL	MSETCL	
26	248	220	BHUGAON - WARDHA (PG)	08/Aug/18	10:00	08/Aug/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
27	258	400	NEW KOYNA - DABHOL - II	08/Aug/18	8:00	09/Aug/18	18:00	Daily	Fixing repair sleeves at 45-46 & Line Sign.Test.	MSETCL	MSETCL	
28	268	400	CHANDRAPUR 2 - WARORA CKT-2	09/Aug/18	8:00	09/Aug/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	
29	271	400	AKOLA - KHADKA (BHUSAWAL)	09/Aug/18	8:00	09/Aug/18	11:30	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	
30	288	220	220KV Talegaon-Talegaon(MSETCL)-1 at Talegaon Substation	09/Aug/18	9:00	09/Aug/18	17:00	Daily	AMP of Line Equipments	WRTS-I	WRTS-I	

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
31	294	400	MAIN BAY (413) OF NANDGAON PETH CKT@ AKOLA -M	09/Aug/18	10:00	09/Aug/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
32	303	400	AKOLA - KHADKA (BHUSAWAL)	09/Aug/18	12:00	11/Aug/18	18:00	Daily	PID testing of insulator strings by PID Uint of Akola.	MSETCL	MSETCL	
33	308	400	KHADKA - BABLESHWAR	10/Aug/18	8:00	10/Aug/18	11:30	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	
34	309	400	CHANDRAPUR 2 - WARORA CKT-1	10/Aug/18	8:00	10/Aug/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	
35	325	220	PUSAD - WARDHA (PG)	10/Aug/18	10:00	10/Aug/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
36	335	500 KV	CHANDRAPUR - PADGHE HVDC POLE 2	11/Aug/18	6:00	11/Aug/18	17:00	Daily	Broken disc insulator replacement & H/w Tightning work.	MSETCL	MSETCL	
37	359	400	EKTUNI - TAPTITANDA CKT - 2	11/Aug/18	10:00	11/Aug/18	18:00	Daily	Relay testing work	MSETCL	MSETCL	
38	387	765 KV	765/400 1500 MVA ICT-1 @ EKTUNI	13/Aug/18	10:00	13/Aug/18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	
39	390	400	400 Talegaon-Lonikand Line at Talegaon	13/Aug/18	9:00	13/Aug/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Talegaon end.	WRTS-I	WRTS-I	
40	392	400	CHANDRAPUR-PARLI CKT-3	13/Aug/18	9:00	13/Aug/18	17:00	Daily	Relay Testing work	MSETCL	MSETCL	
41	395	400	BABHALESHWAR - PADGHE 1	13/Aug/18	9:00	17/Aug/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400 P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	After restoration of Dhule-Bableshtar-D/C
42	401	220	DEOLI(PGCIL)-BADNERA	13/Aug/18	9:00	13/Aug/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
43	431	765 KV	765/400 1500MVA ICT-2 @ EKTUNI	14/Aug/18	10:00	14/Aug/18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	
44	434	400	KOLHAPUR (TALANDGE) - ALKUD	14/Aug/18	9:30	14/Aug/18	17:30	Daily	Quarterly Maint. Work	MSETCL	MSETCL	
45	442	220	PUSAD - WARDHA (PG)	14/Aug/18	10:00	14/Aug/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
46	450	400	BABHALESHWAR - PADGHE 1	14/Aug/18	9:00	14/Aug/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
47	478	400	RPL(AMT) NANDGAON PETH - AKOLA I	16/Aug/18	12:00	18/Aug/18	18:00	Daily	PID testing of insulator strings by PID Uint of Akola.	MSETCL	MSETCL	
48	479	400	CHANDRAPUR-PARLI CKT-3	16/Aug/18	8:00	31/Aug/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	double ckt tower?
49	480	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16/Aug/18	8:00	31/Aug/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	double ckt tower?
50	502	220	SHENDRA-CHITTEPIMPALGAON(PGCIL) 1	17/Aug/18	10:00	17/Aug/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	
51	508	400	DHULE - SSNNL II	17/Aug/18	8:00	18/Aug/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	
52	514	400	BABHALESHWAR - PADGHE 2	18/Aug/18	9:00	22/Aug/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400 P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	
53	515	400	BABHALESHWAR - PADGHE 2	18/Aug/18	8:30	18/Aug/18	17:30	Daily	Annual Maintenance work	MSETCL	MSETCL	
54	520	400	KORADI 2-WARDHA PGCIL	18/Aug/18	8:00	18/Aug/18	17:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	
55	536	400	BUS COUPLER @ LONIKAND-1	19/Aug/18	10:00	19/Aug/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
56	543	400	BABHALESHWAR - PADGHE 2	19/Aug/18	9:00	19/Aug/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
57	547	400	CHANDRAPUR-PARLI CKT-3	20/Aug/18	9:00	20/Aug/18	17:00	Daily	Outage For n/b tightening of hardware at Loc. No. 881, 950,	MSETCL	MSETCL	
58	554	400	TIE BAY (412) OF WARDHA (PG) CKT - 2 & NANDGAON PETH CKT @ AKOLA	20/Aug/18	10:00	20/Aug/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
59	587	400	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	22/Aug/18	8:00	22/Aug/18	17:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	
60	594	400	KHARGHAR - TALEGAON (PG)	23/Aug/18	8:00	23/Aug/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
61	596	400	BUS COUPLER @ KHADKA	23/Aug/18	8:00	23/Aug/18	18:00	Daily	CT C& tan delta test.	MSETCL	MSETCL	

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
62	597	400	KHARGHAR - TALEGAON (PG)	23/Aug/18	8:00	23/Aug/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	
63	606	220	PUSAD - WARDHA (PG)	23/Aug/18	8:00	23/Aug/18	15:00	Daily	For routine maintainance and Diagnostic Work and line signature work at 220kV Pusad S/Stn.	MSETCL	MSETCL	
64	609	400	KOLHAPUR - KOLHAPUR (PG) CKT - 1	23/Aug/18	9:00	23/Aug/18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	
65	619	400	PARLI - LONIKAND 2 CKT 2	23/Aug/18	10:00	23/Aug/18	18:00	Daily	Hardware Tightening & Fitting Work At Loc No-8,42,56,74, 107,106,	MSETCL	MSETCL	
66	623	400	40kv Tarapur-Boisar-I at Boisar	23/Aug/18	9:00	24/Aug/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	
67	624	400	BUS COUPLER @ BABHALESHWAR	23/Aug/18	9:00	24/Aug/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400 P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	
68	625	400	KORADI-KHADKA	23/Aug/18	12:00	25/Aug/18	18:00	Daily	PID testing of insulator strings by PID Unlt of Akola.	MSETCL	MSETCL	
69	626	400	PARLI - LONIKAND 2 CKT 2	24/Aug/18	9:00	24/Aug/18	17:00	Daily	CVT C & Tan Delta measurement work & allied works	MSETCL	MSETCL	
70	628	400	400 Boisar-Padghe at Boisar	24/Aug/18	9:00	25/Aug/18	17:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	
71	636	400	KOLHAPUR - KOLHAPUR (PG) CKT - 2	24/Aug/18	9:00	24/Aug/18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	
72	647	220	PUSAD - WARDHA (PG)	24/Aug/18	7:00	31/Aug/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
73	654	400	A BUS @ NAGOTHANE with bus coupler	25/Aug/18	8:00	25/Aug/18	18:00	Daily	Routine Maintenance work and PG iso overhauling of 400 A Bus with Bus coupler at nagothane.	MSETCL	MSETCL	
74	656	400	400 Boisar-Padghe at Boisar	25/Aug/18	14:00	25/Aug/18	17:00	Daily	For tripping and A/R Trials of Main-I relay. Line outage required	PGCIL	WR-II	
75	657	400	BABLESHWAR- AURANGABAD (WALUJ)	25/Aug/18	9:00	28/Aug/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400 P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	
76	663	400	BUS REACTOR_400_50MVAR_WARDHA	25/Aug/18	7:00	25/Aug/18	16:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	
77	671	400	B BUS @ NAGOTHANE and Bus coupler	26/Aug/18	8:00	26/Aug/18	18:00	Daily	Routine Maintenance work and PG iso overhauling of 400 B Bus with Bus coupler at nagothane.	MSETCL	MSETCL	
78	673	400	400 Kalwa Main bay (416) at Pune (Talegaon)	26/Aug/18	9:00	26/Aug/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	
79	675	400	PADGHE - KALWA 2	26/Aug/18	8:30	26/Aug/18	17:30	Daily	Annual Maintenance work	MSETCL	MSETCL	
80	686	400	PARLI - KUMBHARGAON(NANDED) CKT - 2	27/Aug/18	9:00	27/Aug/18	17:00	Daily	Outage For n/b tightening of hardware at Loc. No. 890, 900.	MSETCL	MSETCL	
81	690	400	BUS REACTOR_400_80MVAR_DHULE	27/Aug/18	7:00	27/Aug/18	16:00	Daily	for AMP works of Reactor and Bay eqpt	WRTS-I	WRTS-I	
82	702	400	PARLI - LONIKAND 2 CKT 1	28/Aug/18	10:00	28/Aug/18	16:00	Daily	Hardware Tightening & Fitting Work At Loc No-17,10,106, 107,112,114	MSETCL	MSETCL	
83	703	400	400 Kalwa Line & ICT # 3 Tie bay (417) at Tpune (Talegaon)	28/Aug/18	9:00	28/Aug/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	
84	711	400	400 Koradi Bhilai Line	28/Aug/18	9:00	28/Aug/18	18:00	Daily	For attending Aununciator issue at Koradi end.	WRTS-I	WRTS-I	
85	718	400	CHANDRAPUR GCR - CHANDRAPUR HVDC - I	28/Aug/18	8:00	29/Aug/18	18:00	Continuous	1) PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work). 2) For Measurement of Tan delta &	MSETCL	MSETCL	
86	722	400	MAIN BUS - 1 @ WARORA	29/Aug/18	8:00	29/Aug/18	17:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	
87	731	400	400 Chakan & 400 Kharghar Tie bay (402) at Pune (Talegaon)	30/Aug/18	9:00	30/Aug/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	
88	748	400	CHANDRAPUR GCR - CHANDRAPUR HVDC - II	30/Aug/18	8:00	31/Aug/18	18:00	Continuous	1) PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work). 2) For Measurement of Tan delta &	MSETCL	MSETCL	
89	755	400	400 Kharghar Main bay (403) at Pune (Talegaon)	31/Aug/18	9:00	31/Aug/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	
90	758	400	BABLESHWAR- AURANGABAD (WALUJ)	31/Aug/18	9:00	31/Aug/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
91	765	220	SHENDRA-CHITTEPIMPALGAON(PGCIL) 2	31/Aug/18	10:00	31/Aug/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	

State Element outage list for the Month of Aug 2018

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	02-Aug-18	08:00	03-Aug-18	18:00	Continuous	1) For Measurement of Tan delta & capacitance of bushing & winding of R-ph ICT-II 2) SFRA of R-ph ICT-II. 3) Measurement of transformer resistance of R, Y & B-ph ICT-II. 4) Relay testing work. 5) Measurement of Contact resistance of breaker. 6) Isolator maintenance works.	MSETCL	MSETCL	During outage, ICT-I will be in service.
2	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	02-Aug-18	09:00	02-Aug-18	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Load will be fed from 400/220KV ICT-NO. II CGL & 400/220KV ICT-III ALSTOM @ Jejuri ss
3	400 KV	TIE BAY - 402 CHD SWITCHING CKT1 AND CHANDRAPUR GCR CKT-1 @ CHANDRAPUR 2	02-Aug-18	07:00	02-Aug-18	15:00	Daily	Routine Maintenance & Dignostic testing work.	MSETCL	MSETCL	-
4	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	03-Aug-18	08:00	03-Aug-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	-
5	400 KV	TIE BAY (412) of THAPTITANDA @Deepnagar	03-Aug-18	13:00	03-Aug-18	17:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	Thapti tanda line will be in service through respective main CB only TIE CB will be off.
6	400 KV	MAIN BAY (411) of THAPTITANDA @Deepnagar	03-Aug-18	08:00	03-Aug-18	12:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	Thapti Tanda line will be in service through TIE only Main CB will be off.
7	400 KV	TBC @ KORADI-1	03-Aug-18	09:00	03-Aug-18	18:00	Daily	Tan Delta of Bushing and Preventive Bay maintenance work will be carried out of 400KV TBC (Spare Reactor) at 400/220	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
8	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	04-Aug-18	08:00	04-Aug-18	18:00	Daily	Bushing & winding & CT C& tan delta Test	MSETCL	MSETCL	-
9	400 KV	PADGHE - NAGOTHANE 1	06-Aug-18	08:00	07-Aug-18	17:00	Daily	Insulator string replacement work ,jumper tightening	MSETCL	MSETCL	-
10	400 KV	THAPTI TANDA - WALUJ	06-Aug-18	10:00	11-Aug-18	17:00	Daily	PID Works. (AR off required)	MSETCL	MSETCL	-
11	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	07-Aug-18	08:00	08-Aug-18	18:00	Continuous	1) For Measurement of Tan delta & capacitance of CT's. 2) Measurement of DCRM, Timing & CRM of breaker. 3) Isolator maintenance works.	MSETCL	MSETCL	400KV CHD-I CHD-II CKT No.II & 400 KV CHD-PARLI ckt No.-III and 400KV CHD-KHAPARKHEDA line will be in service. In addition to these lines, the 400KV MSETCL Chandrapur-I - PGCIL Bhadravati Ckt. No.- I, II, III & IV lines will be in service.
12	400 KV	DEEPNAGAR AURANGABAD	07-Aug-18	13:00	07-Aug-18	16:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
13	400 KV	DEEPNAGAR - THAPTI TANDA	07-Aug-18	08:00	07-Aug-18	11:30	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
14	400 KV	PADGHE - NAGOTHANE 2	08-Aug-18	08:00	09-Aug-18	17:00	Daily	Insulator string replacement work ,jumper tightening	MSETCL	MSETCL	-
15	400 KV	KHADKA- DEEPNAGAR CKT 2	08-Aug-18	13:00	08-Aug-18	16:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
16	400 KV	KHADKA- DEEPNAGAR CKT 1	08-Aug-18	08:00	08-Aug-18	11:30	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
17	400 KV	KORADI-NANDGAONPETH (RPL)	08-Aug-18	09:00	08-Aug-18	18:00	Daily	DCRM, CB timings and Preventive Bay maintenance work will be carried out.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
18	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	09-Aug-18	10:00	09-Aug-18	18:00	Daily	1) TAN DELTA MEASUREMENT OF ICT1 BUSHING IR & PI, 2) TAN DELTA MEASUREMENT OF 205CT	MSETCL	MSETCL	-
19	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	09-Aug-18	09:00	09-Aug-18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
20	400 KV	KHADKA-AURANGABAD	09-Aug-18	17:00	09-Aug-18	22:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
21	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	09-Aug-18	07:00	09-Aug-18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
22	400 KV	400/220/33 KV 315 MVA ICT - 3 @ PADGHE	10-Aug-18	08:30	10-Aug-18	17:30	Daily	Annual Maintenance work	MSETCL	MSETCL	-
23	400 KV	DEEPNAGAR AURANGABAD	10-Aug-18	08:00	10-Aug-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	-
24	400 KV	MAIN BAY (407) OF ICT - 2 @ WARORA	11-Aug-18	08:00	11-Aug-18	17:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	ICT No.II handed over to Padaghe
25	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	11-Aug-18	08:00	11-Aug-18	18:00	Daily	Bushing & winding & CT C& tan delta Test	MSETCL	MSETCL	-
26	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	13-Aug-18	09:00	13-Aug-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
27	400 KV	THAPTI TANDA - WALUJ	13-Aug-18	10:00	14-Aug-18	17:00	Daily	PID Works. (AR off required)	MSETCL	MSETCL	-
28	400 KV	SPARE LINE @ LONIKAND 2	16-Aug-18	09:00	16-Aug-18	18:00	Daily	Routine Maintenance & Diagnostic testing work of Spare Line bay and Tie bay (bay no 417 & 418)	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
29	400 KV	TIE BAY (402) OF ICT -1 @ JEJURI	16-Aug-18	09:00	16-Aug-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	400 KV JEJURI-LONIKAND LINE WILL BE CONNECTED TO BUS II AND ICT I WILL BE CONNECTED TO BUS I
30	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	16-Aug-18	09:00	16-Aug-18	18:00	Daily	Relay Testing work	MSETCL	MSETCL	-
31	400 KV	DEEPNAGAR AURANGABAD	16-Aug-18	06:00	18-Aug-18	18:00	Daily	For replacement of Dead end & mid span joint	MSETCL	MSETCL	-
32	400 KV	THAPTI TANDA - WALUJ	16-Aug-18	10:00	18-Aug-18	17:00	Daily	PID Works. (AR off required)	MSETCL	MSETCL	-
33	400 KV	KORADI 2-IEPL	17-Aug-18	08:00	17-Aug-18	17:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
34	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	20-Aug-18	09:00	20-Aug-18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	Load manage on 315MVA ICT-1 And 315MVA ICT -2
35	400 KV	THAPTI TANDA - WALUJ	20-Aug-18	10:00	25-Aug-18	17:00	Daily	PID Works. (AR off required)	MSETCL	MSETCL	-
36	400 KV	TBC 1 @ CHANDRAPUR GCR	21-Aug-18	08:00	22-Aug-18	18:00	Continuous	1) For Measurement of Tan delta & capacitance of CT's. 2) Measurement of DCRM, Timing & CRM of breaker. 3) Isolator maintenance works.	MSETCL	MSETCL	TBC-II bay will available.
37	400 KV	CHANDRAPUR - KHAPERKHEDA	21-Aug-18	08:00	21-Aug-18	17:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	-
38	400 KV	DEEPNAGAR - THAPTI TANDA	21-Aug-18	10:00	21-Aug-18	18:00	Daily	Relay testing work	MSETCL	MSETCL	-
39	400 KV	TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	21-Aug-18	07:00	21-Aug-18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
40	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	21-Aug-18	08:00	21-Aug-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
41	400 KV	THAPTI TANDA - WALUJ	22-Aug-18	08:00	22-Aug-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	-
42	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	22-Aug-18	08:00	22-Aug-18	18:00	Daily	Insulation coating of ICT tertiary	MSETCL	MSETCL	-
43	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	23-Aug-18	10:00	23-Aug-18	18:00	Daily	1)Tan delta Measurement of ICT-II Bushing IR & PI, 2)Tan delta Measurement of 201- CT	MSETCL	MSETCL	Load will be shifted to 400/220/33KV ICT-I
44	400 KV	THAPTI TANDA - WALUJ	23-Aug-18	10:00	23-Aug-18	18:00	Daily	Relay testing work	MSETCL	MSETCL	-
45	400 KV	MAIN BAY (403) OF LONIKAND CKT @ JEJURI	23-Aug-18	09:00	23-Aug-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	400 KV JEJURI-LONIKAND LINE WILL REMAIN CONNECTED TO BUS I THROUGH TIE CB 402 AND 401 CB
46	400 KV	KARAD - TALANDGE CKT 1	23-Aug-18	09:00	23-Aug-18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	Load manage on 400 kv Kolhapur PG 2
47	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	23-Aug-18	09:00	23-Aug-18	18:00	Daily	Relay Testing work	MSETCL	MSETCL	-
48	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	23-Aug-18	08:00	23-Aug-18	18:00	Daily	Insulation coating of ICT tertiary	MSETCL	MSETCL	-
49	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	24-Aug-18	08:00	25-Aug-18	18:00	Continuous	1) For Measurement of Tan delta & capacitance of bushing & winding of R-ph ICT-I 2) DFRA & SFRA of ICT-I. 3) Relay testing work. 4) Isolator maintenance works.	MSETCL	MSETCL	During outage, ICT-I will be in service.
50	400 KV	400220KV 167MVA SPARE ICT @ DEEPNAGAR	24-Aug-18	08:00	24-Aug-18	17:00	Daily	Annual Maintenance of bays & equipment And DCRM OF CB	MSETCL	MSETCL	Main CB BAY ALONG WITH SP. ICT Outage is required.
51	400 KV	TBC @ BABHALESHWAR	25-Aug-18	09:00	27-Aug-18	17:00	Daily	Quarterly Maintenance work & Reapir scissors of 400KV P.G Isolator and Servicing and allignment of isolators work	MSETCL	MSETCL	TBC is free
52	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	27-Aug-18	08:00	27-Aug-18	17:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	-
53	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	27-Aug-18	09:00	27-Aug-18	18:00	Daily	Quarterly Maint work	MSETCL	MSETCL	Load manage on 315MVA ICT-1 And 501MVA ICT- 3
54	400 KV	KHADKA-AURANGABAD	28-Aug-18	08:00	28-Aug-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	outage will be availed when Line will be off due to system constraint.
55	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	28-Aug-18	08:00	28-Aug-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220KV 315MVA ICT-I , 501 MVA ICT-III and ICT-IV will be in service
56	400 KV	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	29-Aug-18	07:00	29-Aug-18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
57	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	29-Aug-18	10:00	29-Aug-18	15:00	Daily	Diagnostic Testing of CT-5A Main Breaker bay 416	MSETCL	MSETCL	-
58	220 KV	MUDSHINGI- BELEWADI LINE	29-Aug-18	09:00	29-Aug-18	17:00	Daily	Quarterly Maintenance work of Belewadi bay equipment's.	MSETCL	MSETCL	-
59	400 KV	400/220 KV 167 MVA ICT @ PARLI	30-Aug-18	09:00	30-Aug-18	18:00	Daily	Bay & ICT Unit Maintenance ;CB DCRM & Timing Test work	MSETCL	MSETCL	-