

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of August 2020

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
1	11	400KV-TARAPUR 3&4-PADGHE-1	01-Aug-20	10:00	01-Aug-20	17:00	D	POWERGRID_WR1	AMP of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.	
2	12	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at Akola - 400KV	01-Aug-20	9:00	06-Aug-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola.	
3	13	400 kV TBC bay at Bableshwar	01-Aug-20	09:00	08-Aug-20	17:00	Continuous	MSETCL	Circuit breaker overhauling work with Testing and commissioning will be done	Overhauling work of 400kV TBC bay will be carried out by agency .
4	16	400KV/220KV DHULE-MS-ICT-2	01-Aug-20	9:00	26-Jan-21	17:00	Continuous	MSETCL	Augmentation work of 400/220KV, 315MVA ICT-II to 501MVA at 400kV S/S Dhule.	
5	17	BABHALESHWAR - PADGHE 1	01-Aug-20	08:00	10-Aug-20	18:00	Daily	MSETCL	For Carrying PID Work	AR required out of service
6	43	400KV-KALWA-PUNE-PG-1	02-Aug-20	08:00	02-Aug-20	18:00	Daily	MSETCL	Routine Maintenance work	Routine Maintenance work
7	45	400KV-KALWA-PUNE-PG-1	02-Aug-20	9:00	02-Aug-20	18:00	D	POWERGRID_WR1	For AMP Works	
8	49	BHUGAON - WARDHA (PG)	03-Aug-20	08:00	03-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	na
9	53	400KV-KOLHAPUR-SOLAPUR-1	03-Aug-20	9:00	03-Aug-20	18:00	D	POWERGRID_WR1	Line Terminal equipments AMP works	
10	67	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-1 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	03-Aug-20	09:00	06-Aug-20	18:00	C	POWERGRID_WR1	for replacement of BHEL make CB	
11	68	KHADKA - BABLESHWAR	03-Aug-20	08:00	08-Aug-20	18:00	Continuous	MSETCL	Shifting of 400 KV BBLR On TBC For overhauling of 400 KV BBLR Circuit Breaker,	As 400 KV BBLR CB having sf-6 gas leakage problem it is very very Important to carry out overhauling of above CB
12	96	MAIN BAY - 765KV-AKOLA-EKTUNI-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	04-Aug-20	10:00	04-Aug-20	18:00	Daily	MSETCL	" Diagnostic Testing & Routine Maintenance "	765KV AKOLA Ckt-II will be in service through its TIE (702) Bay and Main Bus-I
13	109	DHULE - SSNNL II	04-Aug-20	08:00	22-Aug-20	17:00	Daily	MSETCL	Online PID testing work	A/R switch kept on non auto mode
14	110	DHULE - SSNNL I	04-Aug-20	08:00	22-Aug-20	17:00	Daily	MSETCL	Online PID testing work	A/R switch kept on non auto mode
15	121	OSMANABAD - PARLY (PG)	05-Aug-20	08:00	05-Aug-20	17:00	Daily	MSETCL	Line Maintenance	-
16	127	BHUGAON - WARDHA (PG)	05-Aug-20	08:00	05-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
17	131	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	05-Aug-20	09:00	05-Aug-20	17:00	Daily	MSETCL	Routine maintainace and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	400KV PGCIL Ckt. will be charged through main CB 420.
18	132	MAHALAXMI - AMONA	05-Aug-20	09:00	05-Aug-20	17:00	Daily	MSETCL	quarterly maintenance	-
19	133	MANSAR-PENCH	05-Aug-20	09:00	05-Aug-20	17:00	Daily	MSETCL	Routine Maintenance work.	-
20	136	CHANDRAPUR GCR - CHANDRAPUR HVDC - II	05-Aug-20	09:00	05-Aug-20	18:00	Daily	MSETCL	1)For measurement of Tan delta & Capacitance of CT's 2)Measurement of Timing, Contact Resistance and DCRM of CB.	Outage will be availed subjected to weather conditions.
21	140	220KV-WARDHA-WARDHA-M-1	05-Aug-20	9:00	05-Aug-20	18:00	D	POWERGRID_WR1	For AMP Works	
22	144	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	05-Aug-20	10:00	05-Aug-20	18:00	Daily	MSETCL	" Diagnostic Testing & Routine Maintenance "	765KV AKOLA Ckt-I will be in service through its TIE (705) Bay and Main Bus-I
23	145	JEUR - SOLAPUR (PG)	05-Aug-20	10:00	05-Aug-20	18:00	Daily	MSETCL	Quarterly Maintenance of Main Bus at Jeur s/s	Outage is required for QM work. Line CB of 220 kV PGCIL line at 220 kV Jeur S/Sn end needs to be made off during outage.
24	155	220KV-SOLAPUR-JEUR-1	05-Aug-20	9:00	05-Aug-20	18:00	D	POWERGRID_WR1	Line Terminal equipments AMP works	
25	173	CHANDRAPUR 2 - WARORA CKT-1	06-Aug-20	09:00	06-Aug-20	17:00	Daily	MSETCL	Routine maintainance and diagonastic testing ,relay testing work etc and for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	Load will be managed on 400KV chandrapur 2 Ckt-2 .
26	179	PARLI(MS) - PARLI (PG) CKT -1	06-Aug-20	09:00	06-Aug-20	18:00	Daily	MSETCL	(1) For changing CT ratio from 1000A to 2000A and distance relay testing. (2) Breaker testing work.	-
27	184	220KV-WARDHA-BHUGAON-1	06-Aug-20	9:00	06-Aug-20	18:00	D	POWERGRID_WR1	For AMP Works	

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
28	188	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND 400KV/220KV AKOLA-ICT-2 at AKOLA - 400KV	06-Aug-20	10:00	06-Aug-20	15:00	Daily	MSETCL	ROUTINE MAINTENANCE AND TESTING WORK	AURANGABAD CKT-2 & ICT-2 WILL BE IN SERVICE THROUGH MAIN BAYS 404 & 405 RESPECTIVELY
29	189	STATION TF-3 @ KORADI 2	06-Aug-20	10:00	06-Aug-20	15:00	Daily	MSETCL	Tan delta measurement of Line CT at Bay 404	Outages will be availed subject to weather conditions.
30	191	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	06-Aug-20	10:00	06-Aug-20	18:00	Daily	MSETCL	"Diagnostic Testing & Routine Maintenance	765/400KV ICT-1 will be in service through its TIE (709) & Main Bus-I
31	200	EKLHARA-(OCR)-NAVASARI I	06-Aug-20	08:00	08-Aug-20	18:00	Daily	MSETCL	replacement of old disc insulator, diagnostic testing, broken/flashover string replacement	-
32	215	PUSAD - WARDHA (PG)	07-Aug-20	08:00	07-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
33	238	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	07-Aug-20	10:00	07-Aug-20	18:00	Daily	MSETCL	"Diagnostic Testing & Routine Maintenance	(712) & Main Bus-I.
34	244	400KV-PADGHE-BOISAR-1	07-Aug-20	10:00	14-Aug-20	17:00	C	POWERGRID_WRI	Retrofitting of old BHEL make CB with New GE make CB for 400 KV Boisar Line Bay at Padghe MSETCL.	
35	269	KHARGHAR - TALEGAON (PG)	09-Aug-20	08:00	09-Aug-20	18:00	Daily	MSETCL	Line Maintenance & Routine Diagnostic testing work	Insulator string replacement found in PID.
36	276	OSMANABAD - PARLY (PG)	10-Aug-20	08:00	10-Aug-20	17:00	Daily	MSETCL	Line maintenance work	-
37	285	NEW KOYNA - DABHOL - I	10-Aug-20	09:00	10-Aug-20	18:00	Daily	MSETCL	Routine Maint. Work	Planned Outage
38	295	765KV/400KV EKTUNI-ICT-1	10-Aug-20	10:00	10-Aug-20	18:00	Daily	MSETCL	"Diagnostic Testing & Routine Maintenance	765/400KV ICT-1 will be in service
39	296	WARDHA- PGCIL(DEOLI)	10-Aug-20	10:00	10-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
40	307	BUS COUPLER @ KHADKA	10-Aug-20	08:00	14-Aug-20	18:00	Continuous	MSETCL	For overhauling of 400 KV Bus-coupler Circuit Breaker,	As 400 KV Bus-Coupler CB having Mechanism problem it is very very Important to carry out overhauling of above CB
41	309	BABLESHWAR - 400KV B/R 1	10-Aug-20	09:00	17-Aug-20	17:00	Continuous	MSETCL	Circuit breaker overhauling work with Testing and commissioning will be done .	Overhauling work of 400kV Reactor-1 will be carried out by agency .Reactor-1 bay will be shifted on 400kV TBC
42	323	BHUGAON - WARDHA (PG)	11-Aug-20	08:00	11-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
43	329	BABHALESHWAR - PADGHE I	11-Aug-20	09:00	11-Aug-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing Chemicle Cleaning of strings .	400kV Padghe ckt II will be in service
44	331	220KV-Pandhurna-MP-Kamleshwar	11-Aug-20	9:00	11-Aug-20	17:00	D	MP_SLDC	For bay equipment maintenance and testing work	
45	334	NEW KOYNA - DABHOL - II	11-Aug-20	09:00	11-Aug-20	18:00	Daily	MSETCL	Routine Maint. Work	Planned outage
46	357	KALMESHWAR-PANDHURNA	12-Aug-20	08:00	12-Aug-20	18:00	Daily	MSETCL	Routine Maintenance work	-
47	359	KORADI 2-WARDHA PGCIL	12-Aug-20	09:00	12-Aug-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
48	360	KANHAN-MANSAR	12-Aug-20	09:00	12-Aug-20	17:00	Daily	MSETCL	Routine Maintenance work.	-
49	362	NAGOTHANE - DABHOL I	12-Aug-20	09:00	12-Aug-20	18:00	Daily	MSETCL	Routine Maint. Work	Planned outage
50	363	OSMANABAD - PARLY (PG)	12-Aug-20	09:00	12-Aug-20	18:00	Daily	MSETCL	Vibration damper fixing	-
51	367	DEOLI(PGCIL)-BADNERA	12-Aug-20	10:00	12-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
52	371	EKALAHARA(OCR)-NAVASARI II	12-Aug-20	08:00	14-Aug-20	18:00	Daily	MSETCL	replacement of old disc insulator, diagnostic testing, broken/flashover string replacement	-
53	375	PUSAD - WARDHA (PG)	13-Aug-20	08:00	13-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
54	381	WARORA - Wardha(PG)	13-Aug-20	09:00	13-Aug-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL Line is in ckt
55	382	AIN BAY - 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 at WARORA - 400KV	13-Aug-20	09:00	13-Aug-20	17:00	Daily	MSETCL	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	400KV PGCIL Line will be charged through Tie CB 421.
56	385	NAGOTHANE - DABHOL 2	13-Aug-20	09:00	13-Aug-20	18:00	Daily	MSETCL	Routine Maint. Work	Planned outage
57	392	765KV/400KV EKTUNI-ICT-2	13-Aug-20	10:00	13-Aug-20	18:00	Daily	MSETCL	"Diagnostic Testing & Routine Maintenance	765/400KV ICT-1 will be in service

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
58	395	400KV-CHAKAN-PUNE-PG-1	13-Aug-20	9:00	13-Aug-20	18:00	D	POWERGRID_WR1	For Replacment of CVT	
59	402	400KV-WARDHA-WARORA-PG-1	14-Aug-20	9:00	14-Aug-20	18:00	D	POWERGRID_WR1	For restoration of earth wire & 400KV-WARDHA-WARORA-PG-2 AR to be keep in non auro mode for safety precautions. Diameter to be kept open at both the ends for SS AMP works	
60	438	NALASOPARA - BOISAR PG	16-Aug-20	09:00	16-Aug-20	17:00	Daily	MSETCL	Routine maintenance work	Routine maintenance work
61	452	AURANGABAD-M (WALUJ) - 400KV - BUS 1	17-Aug-20	09:00	17-Aug-20	17:00	Daily	MSETCL	Quarterly maintenance of waluj deepnagar bay at waluj end	Quarterly maintenance of waluj deepnagar bay at waluj end
62	454	PUSAD - WARDHA (PG)	17-Aug-20	08:00	17-Aug-20	18:00	Daily	MSETCL	Routine maintainace work	NA
63	462	TALANDAGE - CHIKODI	17-Aug-20	09:00	17-Aug-20	18:00	Daily	MSETCL	Annual Relay CB & CT Testing Work	Annual Maintenance Work.
64	467	400KV-ALKUD-SOLAPUR-1	17-Aug-20	9:00	17-Aug-20	18:00	D	POWERGRID_WR1	Line Terminal equipments AMP works	
65	483	400KV/220KV BHUSAWAL-ICT-3	17-Aug-20	08:00	20-Aug-20	18:00	Continuous	MSETCL	Shifting of 400 KV ICT-III HV On TBC For overhauling of 400 KV ICT-III HV Circuit Breaker,	As 400 KV ICT-III CB having Mechanism problem it is very very Important to carry out overhauling of above CB
66	500	CHANDRAPUR - 400KV - BUS 1	18-Aug-20	09:00	20-Aug-20	18:00	C	POWERGRID_WR1	Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2	
67	509	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	18-Aug-20	09:00	18-Aug-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through Tie CB 428.
68	511	400KV-PADGHE-BOISAR-1	18-Aug-20	9:00	18-Aug-20	17:00	D	POWERGRID_WR2	Line Equipment AMP at Boisar. Line AMP on opportunity, dia to be kept open at both ends.	PG-Boisar
69	526	KHADKA - BABLESHWAR	18-Aug-20	09:00	25-Aug-20	18:00	Continuous	MSETCL	Circuit breaker overhauling work with Testing and commissioning will be done .	Overhauling work of 400kV Bhusawal will be carried out by agency .Bhusawal bay will be shifted on 400kV TBC
70	541	220 KV OLD GCR PARLI - PARLY (PG)	19-Aug-20	08:00	19-Aug-20	17:00	Daily	MSETCL	Line maintenance work	-
71	547	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	19-Aug-20	09:00	19-Aug-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
72	548	TILARI - AMONA LINE	19-Aug-20	09:00	19-Aug-20	17:00	Daily	MSETCL	quarterly maintenance	-
73	586	LONIKAND 1 - TALEGAON (PGCIL)	20-Aug-20	08:00	20-Aug-20	18:00	Daily	MSETCL	Line Maintenance & Routine Diagnostic testing work	---
74	588	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	20-Aug-20	09:00	20-Aug-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
75	612	EKTUNI - BABLESHWAR CKT 2	21-Aug-20	10:00	22-Aug-20	18:00	Daily	MSETCL	Line Jumper Nut Bolt tightening & Faulty Disc Insulator Replacement work	400kV Bhabaleshwar Ckt-I will be in service
76	613	CHANDRAPUR 2 - WARORA CKT-2	21-Aug-20	07:00	21-Aug-20	17:00	Daily	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling. Routine maintainance and diagonastic testing ,relay testing work etc	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
77	638	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	21-Aug-20	10:00	21-Aug-20	15:00	Daily	MSETCL	ROUTINE MAINTENANCE AND TESTING WORK	AURANGABAD CKT-2 WILL BE IN SERVICE THROUGH TIE BAY 406
78	642	SHENDRA-CHITTEPIMPALGAON(PGCIL) 1	21-Aug-20	11:00	21-Aug-20	18:00	Daily	MSETCL	Diagnostic Testing work & Routine Maint. Work	Diagnostic Testing work & Routine Maint. Work
79	647	DHULE- - BABLESHWAR - I	21-Aug-20	08:00	30-Aug-20	18:00	Daily	MSETCL	For Carrying PID Work	AR required out of service
80	648	DHULE- - BABLESHWAR - II	21-Aug-20	08:00	30-Aug-20	18:00	Daily	MSETCL	For Carrying PID Work	AR required out of service
81	655	400KV-PARLI-PUNE-PG-2	22-Aug-20	9:00	22-Aug-20	17:00	D	POWERGRID_WR1	For AMP of Line Reactor and line terminal equipments at Parli end & 400KV-PUNE-PARLI-1 AR to be keep in non auro mode for safety precautions to carry out line AMP works. Diameter to be kept open at both the ends for SS AMP works	
82	661	WARDHA - 765KV - BUS 2	23-Aug-20	9:00	23-Aug-20	18:00	D	POWERGRID_WR1	For AMP & replacement of Dropper spacer	
83	663	EKTUNI - BABLESHWAR CKT 1	23-Aug-20	10:00	24-Aug-20	18:00	Daily	MSETCL	Line Jumper Nut Bolt tightening & Faulty Disc Insulator Replacement work	400kV Bhabaleshwar Ckt-II will be in service
84	680	AURANGABAD-M (WALUJ) - 400KV - BUS 2	24-Aug-20	09:00	24-Aug-20	17:00	Daily	MSETCL	Quarterly maintenance of waluj Thaptitanda bay at waluj end	Quarterly maintenance of waluj Thaptitanda bay at waluj end
85	692	BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	24-Aug-20	09:00	24-Aug-20	18:00	Daily	MSETCL	CB Testing Work, LBB Relay Testing Work	Monday is Load Staggering Day in Kolhapur, & Bus Load is Balanced.

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason	Remarks
86	704	TIE BAY - AKOLA - 765KV B/R 1 AND 765KV/400KV AKOLA-ICT-1 at AKOLA - 765KV	24-Aug-20	10:00	24-Aug-20	14:00	Daily	MEGPTCL	For testing of Circuit Breaker.	For testing of Circuit Breaker.
87	713	AKOLA - KHADKA (BHUSAWAL)	24-Aug-20	08:00	27-Aug-20	18:00	Continuous	MSETCL	For overhauling of 400 KV Akola Circuit Breaker,	s 400 KV Akola CB having is due for it is very very Important to carry out overhauling of above CB
88	716	PARLI - LONIKAND 2 CKT 2	25-Aug-20	10:00	25-Aug-20	18:00	Daily	MSETCL	Hardware Tightening and Fitting Work.	-
89	743	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	25-Aug-20	9:00	30-Aug-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola.	
90	757	220 KV OLD GCR PARLI - PARLY (PG)	26-Aug-20	08:00	26-Aug-20	17:00	Daily	MSETCL	Line maintenance work	-
91	766	220 kV Navsari-Nashik Line No.1	26-Aug-20	9:00	26-Aug-20	18:00	Daily	GETCO	General bay maint.	
92	781	DHULE - SSNNL I	26-Aug-20	08:00	27-Aug-20	16:00	Daily	MSETCL	Replacement PID suspicious disc insulator and routine maint. work	400kV SSNNL-2 A/R switch kept on non auto mode
93	795	LONIKAND 1 - CHAKAN	27-Aug-20	08:00	27-Aug-20	18:00	Daily	MSETCL	Line Maintenance & Routine Diagnostic testing work	----
94	804	220 kV Navsari-Nashik Line No.2	27-Aug-20	9:00	27-Aug-20	18:00	Daily	GETCO	General bay maint.	
95	815	765KV/400KV AKOLA (2)-ICT-1	27-Aug-20	10:00	27-Aug-20	14:00	Daily	MEGPTCL	Testing of ICT	Testing of ICT
96	827	CHANDRAPUR - 400KV - BUS 2	28-Aug-20	09:00	29-Aug-20	18:00	C	POWERGRID_WR1	Replacement of Bus isolators (Pantograph) of PGCIL#1 & 2	
97	843	SHENDRA-CHITTEPIMPALGAON(PGCIL) 2	28-Aug-20	11:00	28-Aug-20	18:00	Daily	MSETCL	Diagnostic Testing work & Routine Maint. Work	Diagnostic Testing work & Routine Maint. Work
98	848	DHULE - SSNNL II	28-Aug-20	08:00	29-Aug-20	18:00	Daily	MSETCL	Replacement PID suspicious disc insulator and routine maint. work	400kV SSNNL-1 A/R switch kept on non auto mode
99	851	PADGHE - KALWA 2	29-Aug-20	08:00	29-Aug-20	18:00	Daily	MSETCL	Routine Maintenance work	Routine Maintenance work
100	860	220KV-WARDHA-BADNERA-1	29-Aug-20	9:00	29-Aug-20	18:00	D	POWERGRID_WR1	For AMP Works	
101	863	PADGHE - KALWA 1	30-Aug-20	09:00	30-Aug-20	18:00	Daily	MSETCL	Bay Maintenance work.	Bay Maintenance work.
102	867	BABHALESHWAR - PADGHE 2	30-Aug-20	09:00	30-Aug-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing Chemicle Cleaning of strings ,	400kV Padghe ckt I will be inservice
103	869	KALWA - KHARGHAR	30-Aug-20	09:00	30-Aug-20	18:00	Daily	MSETCL	Bay Maintenance work.	Bay Maintenance work.
104	875	EKTUNI - BABLESHWAR CKT 1	31-Aug-20	09:00	31-Aug-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing	400kV Ektuni ckt II,400kV Bhusawal and 400kV Aurangabad lines will be in in service

State Element Outage list for the month of August 2020

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
1	400 KV	400/220/33KV SPARE ICT @ KORADI 2	04-Aug-20	10:00	04-Aug-20	18:00	Daily	IR, Tan delta measurement of Bushing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
2	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	05-Aug-20	09:00	05-Aug-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
3	400 KV	Main bay (406) of Deepnagar line @ Tapitanda	05-Aug-20	11:00	05-Aug-20	17:00	Daily	Relay testing work & CT diagnostic testing work	MSETCL	MSETCL	Nil
4	400 KV	SPARE LINE-2 BAY (404) @ TAPITANDA	05-Aug-20	11:00	05-Aug-20	17:00	Daily	Relay Testing work & CT diagnostic testing work	MSETCL	MSETCL	Nil
5	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	05-Aug-20	09:00	05-Aug-20	18:00	Daily	Routine diagnostic work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
6	400 KV	TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	06-Aug-20	09:00	06-Aug-20	17:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
7	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	06-Aug-20	08:00	06-Aug-20	18:00	Daily	Quarterly Maintenance work Diagnostic testing & Relay Testing	MSETCL	MSETCL	400/220kV 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT- IV will be in service
8	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-I @ WARORA	06-Aug-20	09:00	06-Aug-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	400KV IEPL Ckt. will be charged through main CB 417.
9	400 KV	400/220kV SPARE ICT @ JEJURI	06-Aug-20	09:30	06-Aug-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	----
10	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	06-Aug-20	09:00	06-Aug-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kV Interconnector I will be in service for no supply interruption.
11	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	07-Aug-20	09:00	07-Aug-20	18:00	Daily	Half yearly maintenance and diagnostic testing.Routine Diagnostic testing work.	MSETCL	MSETCL	400kV Interconnector I will be in service for no supply interruption.
12	400 KV	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	07-Aug-20	10:00	07-Aug-20	15:00	Daily	ROUTINE MAINTENANCE AND TESTING WORK	MSETCL	MSETCL	ICT-2 WILL BE IN SERVICE THROUGH TIE BAY 406
13	400 KV	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	07-Aug-20	09:00	07-Aug-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work	MSETCL	MSETCL	400KV IEPL Line will be IN charged CONDITION.
14	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	07-Aug-20	09:00	07-Aug-20	17:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
15	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	08-Aug-20	07:00	08-Aug-20	17:00	Daily	for conductor & Earthing Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthing Hardware tightening if found During Monkey Patrolling
16	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	09-Aug-20	10:00	09-Aug-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Dhule I&II lines will be in service
17	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	10-Aug-20	09:00	10-Aug-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	400KV PGCIL Line will be IN CHARGED CONDITION.
18	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	10-Aug-20	09:00	10-Aug-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kV Spare future line is spare bay, no supply interruption.
19	400 KV	SPARE LINE @ LONIKAND 2	10-Aug-20	09:00	10-Aug-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kV Spare future line is spare bay, no supply interruption
20	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	10-Aug-20	07:00	10-Aug-20	17:00	Daily	for conductor & Earthing Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthing Hardware tightening if found During Monkey Patrolling
21	400 KV	WARORA - IEPL	11-Aug-20	11:00	11-Aug-20	17:00	Daily	Routine Maintenance & Diagnostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	1) Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work . 2)400 KV KORADI 2-WARDHA PGCIL. Line is in ckt
22	400 KV	KARAD - TALANDGE CKT 1	11-Aug-20	09:00	11-Aug-20	18:00	Daily	C& Tan dehta Testing Work	MSETCL	MSETCL	QM & Testing Work
23	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	11-Aug-20	08:00	20-Aug-20	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	AR required out of service
24	400 KV	125 MVAr BUS REACTOR @ TALANDGE	12-Aug-20	09:00	12-Aug-20	18:00	Daily	Winding & Bushing Tan delta Testing Work	MSETCL	MSETCL	Reactor will be in Off condition for Voltage Control
25	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	13-Aug-20	09:00	13-Aug-20	18:00	Daily	Half yearly maintenance and diagnostic testing.Routine Diagnostic testing work.	MSETCL	MSETCL	400kV Interconnector II will be in service for no supply interruption.
26	400 KV	MAIN BAY (404) OF ICT - 2 @ JEJURI	13-Aug-20	09:30	13-Aug-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	ICT-2 will be in service through 405 Tie bay.
27	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	13-Aug-20	09:00	13-Aug-20	16:00	Daily	DCRM Testing, Relay Testing & Bay Maintenance work. and Hardware tightening & fitting work	MSETCL	MSETCL	-
28	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	13-Aug-20	08:00	13-Aug-20	18:00	Daily	Quarterly Maintenance work Diagnostic testing & Relay Testing	MSETCL	MSETCL	400/220kV 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT- IV will be in service
29	400 KV	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	13-Aug-20	10:00	13-Aug-20	15:00	Daily	ROUTINE MAINTENANCE AND TESTING WORK	MSETCL	MSETCL	ICT-1 WILL BE IN SERVICE THROUGH TIE BAY 403
30	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	13-Aug-20	09:00	13-Aug-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
31	400 KV	CHANDRAPUR - KHAPERKHEDA	13-Aug-20	09:00	13-Aug-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
32	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	13-Aug-20	09:00	13-Aug-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kV Interconnector II will be in service for no supply interruption.
33	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	13-Aug-20	09:00	13-Aug-20	14:00	Daily	ICT-1 Main & Tie CB DCRM testing & LV CT tan delta testing work.	MSETCL	MSETCL	-
34	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	14-Aug-20	07:00	14-Aug-20	17:00	Daily	for conductor & Earthing Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthing Hardware tightening if found During Monkey Patrolling
35	400 KV	NEW KOYNA - STAGE IV CKT 1	14-Aug-20	09:00	14-Aug-20	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	Planned outage
36	400 KV	MAIN BAY (413) OF NANDGAON PETH CKT @ AKOLA (M)	14-Aug-20	10:00	14-Aug-20	15:00	Daily	ROUTINE MAINTENANCE AND TESTING WORK	MSETCL	MSETCL	NANDGAON PETH CKT WILL BE IN SERVICE THROUGH TIE BAY 412

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
37	400 KV	CHANDRAPUR-PARLI CKT-3	15-Aug-20	07:00	15-Aug-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling	MSETCL	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
38	400 KV	NEW KOYNA - STAGE IV CKT 2	15-Aug-20	09:00	15-Aug-20	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	Planned outage
39	400 KV	TBC 1 @ CHANDRAPUR GCR	19-Aug-20	09:00	19-Aug-20	18:00	Daily	1) for measurement of Tan delta & Capacitance or C.T's 2) measurement of Timing, Contact Resistance and DCRM of CB.	MSETCL	MSETCL	Outage will be availed subjected to weather conditions.
40	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	19-Aug-20	10:00	19-Aug-20	16:00	Daily	DCRM Testing, Relay Testing & Bay Maintenance work.	MSETCL	MSETCL	-
41	400 KV	MAIN BAY (410) OF FUTURE BAY @ JEJURI	20-Aug-20	09:30	20-Aug-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	ICT-III will be in service through 408 Bus I CB.
42	400 KV	KORADI-NANDGAONPETH (RPL)	20-Aug-20	09:00	20-Aug-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
43	400 KV	THAPTI TANDA - WALUJ	20-Aug-20	09:00	20-Aug-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
44	400 KV	MAIN BAY (410) OF BHUSAWAL (KHADKA) @ AKOLA	20-Aug-20	10:00	20-Aug-20	15:00	Daily	ROUTINE MAINTENANCE AND TESTING WORK	MSETCL	MSETCL	BHUSAWAL CKT WILL BE IN SERVICE THROUGH TIE BAY 409
45	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	20-Aug-20	09:00	20-Aug-20	16:00	Daily	ICT-I HV Main & Tie CB DCRM testing & LV CT Tan delta testing work.	MSETCL	MSETCL	-
46	400 KV	CHANDRAPUR-PARLI CKT-3	22-Aug-20	09:00	22-Aug-20	18:00	Daily	Hardware tightening & fitting work	MSETCL	MSETCL	-
47	400 KV	400kv Stn. TF No 5 @ C'pur GCR	25-Aug-20	09:00	25-Aug-20	18:00	Daily	1) for measurement of Tan delta & Capacitance or C.T's 2) measurement of Timing, Contact Resistance and DCRM of CB.	MSETCL	MSETCL	Outage will be availed subjected to weather conditions.
48	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	27-Aug-20	08:00	27-Aug-20	18:00	Daily	Quarterly Maintenance work Diagnostic testing & Relay Testing	MSETCL	MSETCL	400/220KV 315MVA ICT- II & 501 MVA ICT -III& 501 MVA ICT- IV will be in service
49	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	27-Aug-20	09:00	27-Aug-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
50	400 KV	MAIN BAY OF 167MVA (401) 400/220 Spare ICT @ NANDED	27-Aug-20	10:00	27-Aug-20	16:00	Daily	DCRM Testing, Relay Testing & Bay Maintenance work.	MSETCL	MSETCL	-
51	400 KV	TIE BAY (405) OF ICT -2 AND STG-4 @ JEJURI	27-Aug-20	09:30	27-Aug-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	----