

Maharashtra State Load Despatch Centre										
Monthly Outage list approved in WRLDC OCCM for the Month of August' 2021										
Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
1	1	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Hardware Tightening, Disc Replacement and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole I.	1-Aug-21	06:00	1-Aug-21	19:00	Annual maintenance work of Hardware Tightening, Disc Replacement and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole I. 1)The above work cannot/can be carried out by Hot Line Method. 2)Duration is justified. 3)All necessary arrangements will be ensured before charging by engineer incharge. 4)Required NOCs shall be obtained before charging.
2	5	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	Retrofitting work of Earth Isolator & R&M Work at Borivali end	1-Aug-21	10:00	1-Aug-21	20:00	Retrofitting work of Earth Isolator & R&M Work at Borivali end
3	6	MSETCL	JEJURI - 400KV - BUS 1	Daily	Online PID Testing work By Hot Line Method.	1-Aug-21	09:30	7-Aug-21	17:30	---
4	12	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	PID Testing work	1-Aug-21	08:00	15-Aug-21	18:00	-
5	14	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard	1-Aug-21	08:00	30-Aug-21	17:00	Nil
6	29	MSETCL	400KV-CHANDRAPUR-II-NANDED-2	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Aug-21	08:00	31-Aug-21	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III lines are on DC tower so both lines require on same day A/R out.
7	30	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	1-Aug-21	08:00	31-Aug-21	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III lines are on DC tower so both lines require on same day A/R out.
8	33	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing work	1-Aug-21	09:00	31-Aug-21	17:00	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
9	34	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	emission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Aug-21	09:00	31-Aug-21	17:00	emission for Auto Reclose to be kept in Non auto mode for PID testing work
10	35	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID testing work	1-Aug-21	09:00	31-Aug-21	17:00	400kv SSNNL-2 A/R switch kept on non auto mode
11	36	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	emission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Aug-21	09:00	31-Aug-21	17:00	emission for Auto Reclose to be kept in Non auto mode for PID testing work
12	38	POWERGRID_WR2	220KV-BOISAR-BORIVALI	D	For AMP works. Line outage is required	1-Aug-21	9:00	1-Aug-21	17:30	PG-WR2-Boisar
13	40	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Hardware Tightening, Disc Replacement and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole I.	2-Aug-21	06:00	2-Aug-21	19:00	Annual maintenance work of Hardware Tightening, Disc Replacement and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole I. 1)The above work cannot/can be carried out by Hot Line Method. 2)Duration is justified. 3)All necessary arrangements will be ensured before charging by engineer incharge. 4)Required NOCs shall be obtained before charging.
14	51	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Pre monsoon Work	2-Aug-21	08:00	2-Aug-21	16:00	Covering of Buchholz relay, PRV etc.
15	58	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire	2-Aug-21	08:00	2-Aug-21	18:00	400kv SSNNL-2 A/R switch will be kept on non auto mode
16	64	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For AMP works	2-Aug-21	9:00	2-Aug-21	17:30	PG-WR2-Boisar
17	77	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Hill cutting work at loc. No.94-95	2-Aug-21	08:00	4-Aug-21	18:00	--
18	84	MSETCL	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	Continuos	CB O/H WORK . Since 2010 C.B not overhauled.	2-Aug-21	09:00	8-Aug-21	18:00	Many times same outage was postponed due to various reasons such as Cyclone; rainy days; agencies persons were having corona positive results etc etc.
19	86	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Online PID testing work	2-Aug-21	08:00	31-Aug-21	17:00	400KV Dhule-BBLR- I & II is to be kept on NONAUTO mode
20	87	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Online PID testing work	2-Aug-21	08:00	31-Aug-21	17:00	400KV Dhule-BBLR- I & II is to be kept on NONAUTO mode
21	102	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	FOR 418 BAY AMP WORKS	3-Aug-21	7:00	3-Aug-21	18:00	
22	103	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2	D	FOR ACPG-2 LINE CT AMP WORKS @MSETCL WALUJ	3-Aug-21	7:00	3-Aug-21	18:00	
23	109	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Pre Monsoon Work	3-Aug-21	08:00	3-Aug-21	16:00	Covering of PRV, Buchholz Relay etc.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
24	116	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	3-Aug-21	08:00	3-Aug-21	18:00	400kv SSNNL-1 A/R switch will be kept on non auto mode
25	122	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	Daily	1) Measurement of Tan delta & capacitance of 400KV R, Y & B-ph CTs which are due since 02 years. 2) Maintenance and alignments of PG Isolators and CB Isolators.	3-Aug-21	09:00	3-Aug-21	18:00	During outage, HVDC Ckt. No.- 2 Will be in service and there will be power restriction.
26	134	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Continuos	Dismantling/de-stringing, tower erection and stringing work between span 258-259 for LULO arrangement to proposed 400kv Karjat substation	3-Aug-21	08:00	17-Aug-21	18:00	For making LULO arangement work for 400kv Karjat S/s, dismantling/destringing, tower erection and stringing work is required to be carried out between location on 258--
27	136	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Hardware Tightening and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole II.	4-Aug-21	06:00	4-Aug-21	19:00	Annual maintenance work of Hardware Tightening and Line Signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole II. 1)The above work cannot/can be carried out by Hot Line Method. 2)Duration is justified. 3)All necessary arrangements will be ensured before charging by engineer incharge. 4)Required NOCs shall be obtained before charging.
28	141	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	For Line Bay AMP Work at Wardha.	4-Aug-21	7:00	4-Aug-21	18:00	
29	147	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance work	4-Aug-21	08:00	4-Aug-21	17:00	-
30	157	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire	4-Aug-21	08:00	4-Aug-21	18:00	400kv SSNNL-2 A/R switch will be kept on non auto mode
31	160	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	CT, CB relay testing work	4-Aug-21	09:00	4-Aug-21	17:00	400kv Ektuni ckt I&II,400kv Aurangabad and 400kv Dhule-II , Bhusawal lines will be in in service
32	161	MSETCL	132KV-PENCH-MP-KANHAN-1	Daily	Routine Maintenance work.	4-Aug-21	09:00	4-Aug-21	17:00	NA
33	167	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	For STN to DTN insulator string conversion at tower location no M/C-13,14,15	4-Aug-21	09:00	4-Aug-21	18:00	Other lines at 220 KV Mudshingi s/s will be in service. Also 220 kv Talandge-Chikodi line will be in service
34	168	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	For STN to DTN insulator string conversion at tower location no M/C-13,14,15	4-Aug-21	09:00	4-Aug-21	18:00	Other lines at 220 KV Mudshingi s/s will be in service. Also 220 kv Talandge-Chikodi line will be in service
35	172	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	Diagnostic Testing Work	4-Aug-21	10:00	4-Aug-21	17:00	Diagnostic Testing Work
36	174	MSETCL	JEUR - 220KV - BUS 1	Daily	Outage is required for Quarterly Maintenance	4-Aug-21	10:00	4-Aug-21	18:00	Quarterly Maintenance
37	184	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTTING AT KUDUS END.	5-Aug-21	7:00	5-Aug-21	17:00	
38	190	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	5-Aug-21	07:00	5-Aug-21	18:00	Nil
39	199	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	5-Aug-21	08:00	5-Aug-21	18:00	400kv SSNNL-1 A/R switch will be kept on non auto mode
40	200	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Routine Maint. Work	5-Aug-21	08:00	5-Aug-21	18:00	--
41	205	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	Daily	1) Measurement of Tan delta & capacitance of 400KV R, Y & B-ph CTs which are due since 02 years. 2) Testing of LBB relay. 3) Maintenance and alignments of PG Isolators and CB Isolators.	5-Aug-21	09:00	5-Aug-21	18:00	During outage, HVDC Ckt. No.- 1 Will be in service and there will be power restriction.
42	206	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	(1) Reactor backup relay retrofitting work.(2)Bay maintenance work.	5-Aug-21	09:00	5-Aug-21	18:00	-
43	207	MSETCL	220KV-NASIK-NAVSARI-1	Daily	For replacement of old disk insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issu	5-Aug-21	09:29	5-Aug-21	18:34	-
44	224	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	For AMP works. Line outage is required	6-Aug-21	9:00	6-Aug-21	17:30	PG-WR2-Boisar
45	226	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1 L/R@Aurangabad	D	For LR AMP Works at Aurangabad end	6-Aug-21	7:00	6-Aug-21	18:00	
46	227	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	D	For unswitchable L/R AMP works at Aurangabad end. Line outage required to take LR out of service & in service each operation 20 min.	6-Aug-21	7:00	6-Aug-21	18:00	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
47	228	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2 MAIN BAY at KOLHAPUR-MS-400KV	D	For Bay AMP, Outage required on CB only. Line ill be in service through TBC CB.	6-Aug-21	7:00	6-Aug-21	18:00	
48	239	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Routine Maint. Work	6-Aug-21	08:00	6-Aug-21	18:00	--
49	244	POWERGRID_WR2	BUS COUPLER BAY - BOISAR - 220KV - BUS 1 AND BOISAR - 220KV - BUS 2 at BOISAR - 220KV	D	For AMP works	6-Aug-21	9:00	6-Aug-21	17:30	PG-WR2-Boisar
50	253	MSETCL	220KV-NASIK-NAVSARI-2	Daily	For replacement of old disk insulator by porcelain long rod. Dignostic testing, broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issu	6-Aug-21	09:29	6-Aug-21	18:29	-
51	256	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	Isolator Modification & Alignment work by OEM.	6-Aug-21	09:30	6-Aug-21	18:00	ICT-II Will be in service
52	257	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	6-Aug-21	10:00	6-Aug-21	18:00	NA
53	270	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	D	For AMP works. Line outage is required	7-Aug-21	9:00	7-Aug-21	17:30	PG-WR2-Boisar
54	273	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Updating Siemens Distance Relay M1 75A522(EN100 Module) to comply for IEC61850 and resolving front port communication issue of M1 Relay.	7-Aug-21	7:00	7-Aug-21	16:00	
55	279	POWERGRID_WR1	MAIN BAY - 220KV-WARDHA-PUSAD-1 AND WARDHA - 220KV - BUS 1 at Wardha - 220KV	D	For Bay AMP Work	7-Aug-21	8:00	7-Aug-21	18:00	
56	283	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earth wire	7-Aug-21	08:00	7-Aug-21	18:00	400kv SSNNL-2 A/R switch will be kept on non auto mode
57	284	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Routine Maint. Work	7-Aug-21	08:00	7-Aug-21	18:00	--
58	296	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Isolator Modification & Alignment work by OEM.	7-Aug-21	09:30	7-Aug-21	18:00	ICT-I Will be in service
59	302	MSETCL	400KV-KALWA-PADGHE-1	Daily	1) SSN to DSN Insulator string conversion work by Line maintenance S/Dn Kalwa. 2) Bay maintenance work at 400KV RS Kalwa.	7-Aug-21	08:00	7-Aug-21	18:00	1) SSN to DSN Insulator string conversion work by Line maintenance S/Dn Kalwa. 2) Bay maintenance work at 400KV RS Kalwa.
60	310	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	REPLACEMENT OF INSULATOR STRING & JUMPER NUT-BOLT TIGHTNING and Bay Maintenance at 220 kV Nalasopara S/S.	8-Aug-21	09:00	8-Aug-21	17:00	REPLACEMENT OF INSULATOR STRING & JUMPER NUT-BOLT TIGHTNING and Bay Maintenance at 220 kV Nalasopara S/S.
61	311	MSETCL	400KV-KALWA-PADGHE-2	Daily	1) Bay Maint work 2) Diagnostic Testing work 3) Replacement of Isolator 4) Attending Hot Spot if any 5) Replacement of CT to MK Box Al cable with Copper cable	8-Aug-21	09:00	8-Aug-21	18:45	1) Weather condition should be clear 2) Outage proposal on dated 06 June not approved
62	312	MSETCL	JEJURI - 400KV - BUS 2	Daily	Online PID Testing work By Hot Line Method.	8-Aug-21	09:30	15-Aug-21	17:30	Online PID Testing work will be carried on all days Except outage on 12.08.2021 .
63	313	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	CT, CB relay testing work & 29D & 29C Isolator repairing work.	8-Aug-21	09:00	8-Aug-21	17:00	400kv Ektuni ckt II, 400kv Bhusawal, Dhule I&II and 400kv Aurangabad will be in service
64	317	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2 L/R@Aurangabad	D	For LR AMP Works at Aurangabad end	9-Aug-21	7:00	9-Aug-21	18:00	
65	318	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	D	For unswitchable L/R AMP works at Aurangabad end. Line outage required to take LR out of service & in service each operation 20 min.	9-Aug-21	7:00	9-Aug-21	18:00	
66	323	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND BHADRAWATI - 400KV - BUS 2 at BHADRAWATI - 400KV	D	For AMP works	9-Aug-21	8:00	9-Aug-21	18:00	
67	327	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	9-Aug-21	08:00	9-Aug-21	18:00	400kv SSNNL-1 A/R switch will be kept on non auto mode
68	350	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	C	Simultaneous outages of 400KV Khandwa-Dhule-1&2 for-Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam. Dia to be kept open. [Similar Line Outages proposed/approved for work to be done in May/21 can not be taken up due to Covid19 and delay in supply of towers]	9-Aug-21	8:00	13-Aug-21	18:00	PG-WR2-Khandwa
69	351	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	C	Simultaneous outages of 400KV Khandwa-Dhule-1&2 for-Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam. Dia to be kept open.	9-Aug-21	8:00	13-Aug-21	18:00	PG-WR2-Khandwa
70	365	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	Daily	Replacement of insulator strings if found faulty in PID testing	10-Aug-21	08:00	10-Aug-21	17:00	400KV Dhule-BBLR-II is to be kept on NONAUTO mode

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
71	366	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	For Conductor & Earthwire H/W tightening work if found any during MP	10-Aug-21	08:00	10-Aug-21	17:00	For Conductor & Earthwire H/W tightening work if found any during MP
72	367	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-1 AND BHADRAWATI - 400KV - BUS 1 at BHADRAWATI - 400KV	D	For AMP works	10-Aug-21	8:00	10-Aug-21	18:00	
73	374	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire	10-Aug-21	08:00	10-Aug-21	18:00	400kV SSNNL-2 A/R switch will be kept on non auto mode
74	375	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	10-Aug-21	08:00	10-Aug-21	18:00	NA
75	385	MSETCL	400KV-WARDHA-WARORA-1	Daily	Routine Maintenance & Diagnostic testing work .	10-Aug-21	09:00	10-Aug-21	17:00	400KV WARORA-IEPL Line is in ckt
76	387	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BORIVALI AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For AMP works	10-Aug-21	9:00	10-Aug-21	17:30	PG-WR2-Boisar
77	394	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Maintenance of Circuit Breaker	10-Aug-21	10:00	10-Aug-21	18:00	Maintenance of Circuit Breaker
78	402	APML	400KV/21KV TIRODA-GT-1	Continuo us	For Generation Unit-1 AOH	10-Aug-21	00:00	31-Aug-21	23:59	For Generation Unit-1 AOH
79	403	POWERGRID_WR1	WARDHA - 400KV - BUS 1	D	For 400KV Bus AMP Work.	10-Aug-21	8:00	10-Aug-21	18:00	
80	404	POWERGRID_WR1	400KV WARDHA-AURANGABAD-1	C	For line diversion work due to samrudhi express way near Aurangabad.(New Construction).	11-Aug-21	7:00	31-Aug-21	18:00	
81	405	POWERGRID_WR1	400KV WARDHA-AURANGABAD-2	C	For line diversion work due to samrudhi express way near Aurangabad.(New Construction).	11-Aug-21	7:00	31-Aug-21	18:00	
82	406	POWERGRID_WR1	400kV-WARDHA-AURANGABD-1	D	For Diamond Crossing works of 400kV D/C Wardha - Aurangabad line over 765kV D/C Wardha-Nizamabad line	11-Aug-21	8:00	12-Aug-21	18:00	
83	407	POWERGRID_WR1	400kV-WARDHA-AURANGABD-2	D	For Diamond Crossing works of 400kV D/C Wardha - Aurangabad line over 765kV D/C Wardha-Nizamabad line	11-Aug-21	8:00	12-Aug-21	18:00	
84	409	MSETCL	BHUSAWAL - 400KV - BUS 1	Daily	For testing of 400 KV BUS-I CVT and isolator maintainance work	11-Aug-21	06:00	11-Aug-21	18:00	If any abnormal results found then CVT will be replaced
85	419	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	For Conductor & Earthwire H/W tightening work if found any during MP	11-Aug-21	08:00	11-Aug-21	17:00	For Conductor & Earthwire H/W tightening work if found any during MP
86	420	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance work	11-Aug-21	08:00	11-Aug-21	17:00	-
87	431	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	CT, CB relay testing work & 29D & 29C Isolator repairing work.	11-Aug-21	9:00	11-Aug-21	17:00	400kV Ektuni ckt I,400kV Bhusawal, Dhule I&II and 400kV Aurangabad will be in in service
88	432	MSETCL	220KV-PANDURNA-KALMESHVAR-1	Daily	Routine Maintenance & Diagnostic testing work	11-Aug-21	09:00	11-Aug-21	17:00	NA
89	433	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	11-Aug-21	09:00	11-Aug-21	17:00	NA
90	447	MSETCL	220KV-AURANGABAD-CHITEGAON-2	Daily	Replacement of TNC switch	11-Aug-21	11:00	11-Aug-21	14:00	The line will be in service through TBC
91	451	MSETCL	BABLESHWAR - 400KV B/R 1	Continuo us	400KV CGL make CB pole overhauling work	11-Aug-21	09:00	19-Aug-21	18:00	400kV Reactor I on TBC
92	452	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Hardware Tightening and Fitting Work.	12-Aug-21	09:30	12-Aug-21	18:30	-
93	458	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	12-Aug-21	07:00	12-Aug-21	18:00	NIL
94	459	POWERGRID_WR1	MAIN BAY-400KV-PADGHE-PG-KUDUS-1 AND PADGHE-PG - 400KV - Bus 1 at PADGHE-PG	D	AMP of 401 Bay CB.	12-Aug-21	7:30	12-Aug-21	16:00	
95	466	POWERGRID_WR1	TIE BAY - 400KV-BHADRAWATI-PARLI-1 AND 400KV-CHANDRAPUR-BHADRAWATI-3 at BHADRAWATI - 400KV	D	For AMP works	12-Aug-21	8:00	12-Aug-21	18:00	
96	471	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	12-Aug-21	08:00	12-Aug-21	18:00	400kV SSNNL-1 A/R switch will be kept on non auto mode
97	472	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	DT & SCADA trials under MTAMC work, Routine Line Maintenance work.	12-Aug-21	08:00	12-Aug-21	18:00	---
98	473	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	12-Aug-21	08:00	12-Aug-21	18:00	NA
99	477	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work .	12-Aug-21	09:00	12-Aug-21	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
100	482	MSETCL	CHANDRAPUR - 400KV - TRANSFER BUS 2	Daily	1) Measurement of BKR Timing, CRM & DCRM. 2) Routine maintenance of PG isolators and CB isolators.	12-Aug-21	09:00	12-Aug-21	18:00	TBC-2 bay will not be available. TBC-1 will be available.
101	483	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	Isolator Modification & Alignment work by OEM.	12-Aug-21	10:00	12-Aug-21	18:00	400kV Bhabaleshwar Ckt-II will be in service

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
102	492	MSETCL	kOLHAPUR-MS - 400KV - BUS 2	Continuo us	1.Replacement of a. 400kV TBC B bus B ph isolator b. 400kV Solapur Bay B bus R ph isolator 2. Annual Maintenance of Main Bus 2. 3. Alignment of all 400kV B bus isolators by online shifting one by one bay on TBC. 4. C & tan delta testing of B bus CVT. 5. Chemical cleaning of Bus Strings	12-Aug-21	9:00	17-Aug-21	18:00	For making LILO arrangement work for 400kV Karjat S/s, dismantling/destringing, tower erection and stringing work is required to be carried out between location on 258-259 & location on 261-263 of existing 400kV Lonikand-II Girawali line ckt-I & ck
103	495	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	For AMP works. Line outage is required	13-Aug-21	9:00	13-Aug-21	17:30	PG-WR2-Boisar
104	496	POWERGRID_WR1	220KV-PARLI-HARANGUL-M-1	D	For line terminal AMP works at Parli-PG end	13-Aug-21	7:00	13-Aug-21	17:30	
105	499	POWERGRID_WR1	Tie Bay - 400KV-PADGHE-PG-KUDUS-1 AND 765KV/400KV PADGHE-PG-ICT-1 at PADGHE-PG	D	AMP of 402 Bay CB.	13-Aug-21	7:30	13-Aug-21	16:00	
106	521	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	Isolator Modification & Alignment work by OEM.	13-Aug-21	10:00	13-Aug-21	18:00	400kV Bhabaleshwar Ckt-I will be in service
107	531	POWERGRID_WR2	220KV-BOISAR-TARAPUR	D	For AMP works. Line outage is required	14-Aug-21	9:00	14-Aug-21	17:30	PG-WR2-Boisar
108	532	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of Insulator strings if found faulty in PID testing.	14-Aug-21	08:00	14-Aug-21	17:00	400KV Dhule-BBLR-I is to be kept on NONAUTO mode
109	533	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire	14-Aug-21	08:00	14-Aug-21	18:00	400kV SSNNL-2 A/R switch will be kept on non auto mode
110	539	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	REPLACEMENT OF INSULATOR STRING	14-Aug-21	09:00	14-Aug-21	17:00	REPLACEMENT OF INSULATOR STRING
111	541	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance, Diagnostic Testing.	14-Aug-21	10:00	14-Aug-21	17:00	---
112	548	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	15-Aug-21	08:00	15-Aug-21	18:00	400kV SSNNL-1 A/R switch will be kept on non auto mode
113	549	MSETCL	400KV-KALWA-PADGHE-2	Daily	1) SSN to DSN Insulator string conversion work by Line maintenance S/Dn Kalwa. 2) Bay maintenance work at 400KV RS Kalwa.	15-Aug-21	08:00	15-Aug-21	18:00	1) SSN to DSN Insulator string conversion work by Line maintenance S/Dn Kalwa. 2) Bay maintenance work at 400KV RS Kalwa.
114	550	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	PID Testing work	15-Aug-21	09:00	31-Aug-21	18:00	-
115	558	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire	16-Aug-21	08:00	16-Aug-21	18:00	400kV SSNNL-2 A/R switch will be kept on non auto mode
116	562	POWERGRID_WR2	400KV-PADGHE-BOISAR-1	D	For AMP works at Boisar. Line AMP works on opportunity. Dia to be kept open at both ends.	16-Aug-21	9:00	16-Aug-21	17:30	PG-WR2-Boisar
117	586	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	17-Aug-21	08:00	17-Aug-21	18:00	400kV SSNNL-1 A/R switch will be kept on non auto mode
118	587	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	17-Aug-21	08:00	17-Aug-21	18:00	NA
119	600	MSETCL	MAIN BAY - 400KV-TAPTHITHANDA-EKTUNI-2 AND EKTUNI - 400KV - BUS 1 at EKTUNI - 400KV	Daily	Diagnostic Testing	17-Aug-21	10:30	17-Aug-21	18:00	400kV Thapti-Tanda ckt-II will be in service through its TIE (402) Bay & Main Bus-II.
120	614	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance	18-Aug-21	08:00	18-Aug-21	17:00	-
121	618	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire	18-Aug-21	08:00	18-Aug-21	18:00	400kV SSNNL-2 A/R switch will be kept on non auto mode
122	621	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	18-Aug-21	09:00	18-Aug-21	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
123	622	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	18-Aug-21	09:00	18-Aug-21	17:00	NA
124	623	POWERGRID_WR2	MAIN BAY - 400KV-AURANGABAD-BOISAR-2 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	D	For AMP works	18-Aug-21	9:00	18-Aug-21	17:30	PG-WR2-Boisar
125	634	MSETCL	SOLAPUR-M - 400KV - BUS 2	Daily	Diagnostic testing work.	18-Aug-21	10:00	18-Aug-21	18:00	Load will be managed on 400 kV Main BUS-I
126	635	MSETCL	TIE BAY - 400KV-TAPTHITHANDA-EKTUNI-2 AND FUTURE at EKTUNI - 400KV	Daily	Diagnostic Testing	18-Aug-21	10:30	18-Aug-21	18:00	400kV Thapti-Tanda ckt-II will be in service through its Main (401) Bay & Main Bus-I.
127	640	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1	D	Line Terminal equipments AMP works. Dia to be kept open	19-Aug-21	7:00	19-Aug-21	18:00	
128	641	POWERGRID_WR1	400kV-SOLAPUR-ALKUD LR@ SOLAPUR-400KV	D	Line Reactor AMP Works	19-Aug-21	7:00	19-Aug-21	18:00	
129	646	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	19-Aug-21	07:00	19-Aug-21	18:00	Nil

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
130	659	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	Daily	(1) Breaker DCRM & Timing measurement. (2) Bay maintenance work, (3) Hardware Tightening and Fitting Work.	19-Aug-21	09:00	19-Aug-21	18:30	-
131	663	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Continuo us	Dismantling/de-stringing, tower erection and stringing work between span 261-263 for LULO arrangement to proposed 400kV Karjat substatio	19-Aug-21	08:00	30-Aug-21	18:00	For making LULO arrangement work for 400kV Karjat S/s dismantling/destringing, tower erection and stringing work is required to be caried out between location on 258-
132	665	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line side equipments AMP and Relay testing works at Solapur end.	20-Aug-21	7:00	20-Aug-21	18:00	
133	666	POWERGRID_WR1	400KV-KOLHAPUR-MS-ALKUD MAIN BAY at KOLHAPUR_MS-400KV	D	For Bay AMP Outage required on CB only. Line will be in service through TBC CB.	20-Aug-21	7:00	20-Aug-21	18:00	
134	667	POWERGRID_WR1	400kV-SOLAPUR-KOLHAPUR LR@ SOLAPUR-400KV	D	Line Reactor AMP Works & Aircell Replacement in line Reactor	20-Aug-21	7:00	20-Aug-21	18:00	
135	673	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	20-Aug-21	08:00	20-Aug-21	18:00	400kV SSNNL-1 A/R switch will be kept on non auto mode
136	674	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	20-Aug-21	08:00	20-Aug-21	18:00	NA
137	678	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	20-Aug-21	09:00	20-Aug-21	17:00	Line will be charged through Main CB 429.
138	685	MSETCL	400KV-PADGHE HVDC-PADGHE-1	Daily	1) Bay Maint work 2) Diagnostic Testing Work 3) Replacement of Isolator 4) Attending Hot spot 5) Replacement of AI cable to copper cable from CT to CT MK box	20-Aug-21	09:00	20-Aug-21	18:45	Weather condition should be clear
139	690	MSETCL	BUS COUPLER BAY - AURANGABAD-M (WALUJ) - 400KV - BUS 1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 2 at Aurangabad-M (Waluj) - 400KV	Continuo us	PG isolator overhauling work	20-Aug-21	10:00	21-Aug-21	18:00	Agency available
140	696	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For cleaning of contacts at Pune-PG end	21-Aug-21	7:00	21-Aug-21	18:00	
141	697	POWERGRID_WR1	400KV-KOLHAPUR-MS-ALKUD	D	For Line Bay AMP Outage required on line for Line bay equipment AMP works	21-Aug-21	7:00	21-Aug-21	18:00	
142	704	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earth wire	21-Aug-21	08:00	21-Aug-21	18:00	400kV SSNNL-2 A/R switch will be kept on non auto mode
143	705	POWERGRID_WR1	MAIN BAY OF 220KV-SOLAPUR-NARANGWADI-1 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV	D	Bay AMP Works.	21-Aug-21	8:30	21-Aug-21	18:00	
144	706	POWERGRID_WR2	400KV/220KV JABALPUR-ICT-1	D	For opening of Jumper of 420-898 Isolator for retrofitting work. Dia to be kept open on both sides.	21-Aug-21	9:00	21-Aug-21	11:00	PG-WR2-400Jabalpur
145	707	WTPJ	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	Daily	Outage required for annual maintenance work.	21-Aug-21	9:00	21-Aug-21	17:00	Line outage
146	708	WTPJ	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	Daily	AR to be kept OFF for safety point of view during 400KV Aurangabad - M (Walunj) - Pune - GIS - 1 outage.	21-Aug-21	9:00	21-Aug-21	17:00	AR disable
147	711	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance, Diagnostic Testing	21-Aug-21	10:00	21-Aug-21	17:00	---
148	713	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	D	For CVT testing and and relay testing works	22-Aug-21	7:00	22-Aug-21	18:00	
149	716	POWERGRID_WR1	220KV-PARLI-PARLI-M-1	D	For line terminal AMP works at Parli-PG end	23-Aug-21	7:00	23-Aug-21	17:30	
150	717	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-BOISAR-1 AND 765KV/400KV AURANGABAD-ICT-1 at AURANGABAD - 400KV	D	For 429 Bay AMP Works	23-Aug-21	7:00	23-Aug-21	18:00	
151	726	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	23-Aug-21	08:00	23-Aug-21	18:00	400kV SSNNL-1 A/R switch will be kept on non auto mode
152	728	POWERGRID_WR1	MAIN BAY OF 220KV-SOLAPUR-NARANGWADI-2 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV	D	Bay AMP Works.	23-Aug-21	8:30	23-Aug-21	18:00	
153	729	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Daily	Attending of SF6 gas leakage at top of the Y-Phase pole of 429 Main CB at 400 KV PGCIL Deoli S/Stn. By complete O/H of Y-Pole.	23-Aug-21	09:00	23-Aug-21	17:00	Line will be charged through Tie CB 428.
154	737	MSETCL	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	Daily	Routine maintenance & Testing Work	23-Aug-21	10:00	23-Aug-21	16:00	Aurangabad Ckt-01 will be in service through Tie bay 403
155	747	MSETCL	400KV/220KV CHANDRAPUR-ICT-1	Continuo us	Replacement of old BHEL make 400KV Breaker by new Siemens make 400KV Breaker.	23-Aug-21	09:00	29-Aug-21	18:00	Outage will be availed by shifting 400KV ICT-1 bay on 400KV TBC-1 bay.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
156	750	POWERGRID_WR1	220KV-PARLI-PARLI-M-2	D	For line terminal AMP works at Parli-PG end	24-Aug-21	7:00	24-Aug-21	17:30	
157	754	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-1	D	Line Terminal equipments AMP works at Solapur end	24-Aug-21	7:00	24-Aug-21	18:00	
158	759	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	D	replacement of Insulator strings if found faulty in PID testing	24-Aug-21	08:00	24-Aug-21	17:00	400KV Dhule-BBLR-II is to be kept on NONAUTO mode
159	765	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earth wire	24-Aug-21	08:00	24-Aug-21	18:00	400kv SSNNL-2 A/R switch will be kept on non auto mode
160	779	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-2	D	Line Terminal equipments AMP works at Solapur end	25-Aug-21	7:00	25-Aug-21	18:00	
161	782	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	Daily	Replacement of insulator strings if found faulty in PID Testing.	25-Aug-21	08:00	25-Aug-21	17:00	400KV Dhule-BBLR-I is to be kept on NONAUTO mode
162	783	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance work	25-Aug-21	08:00	25-Aug-21	17:00	-
163	795	MSETCL	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND 400KV/220KV AKOLA-ICT-2 at AKOLA - 400KV	Daily	Routine maintenance & testing work	25-Aug-21	10:00	25-Aug-21	16:00	ICT-02 & Aurangabad Ckt-02 will be in service through main bay's 405 & 407 respectively
164	804	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire	26-Aug-21	08:00	26-Aug-21	18:00	400kv SSNNL-1 A/R switch will be kept on non auto mode
165	808	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Line Bay AMP Work	26-Aug-21	7:00	26-Aug-21	18:00	
166	809	POWERGRID_WR1	400KV-KORADI-BHILAI L/R@KORADI - 400KV	D	For Line Reactor AMP Work	26-Aug-21	7:00	26-Aug-21	18:00	
167	810	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	26-Aug-21	07:00	26-Aug-21	18:00	Nil
168	811	POWERGRID_WR1	TIE BAY - 400KV-PARLI-M-PARLI-1 AND PARLI - 400KV B/R 1 at PARLI-400KV	D	For bay AMP works	26-Aug-21	7:30	26-Aug-21	17:30	
169	816	MSETCL	400KV-CHAKAN-PUNE-PG-1	Daily	Routine Line Maintenance work.	26-Aug-21	08:00	26-Aug-21	18:00	---
170	824	MSETCL	MAIN BAY - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	26-Aug-21	09:00	26-Aug-21	17:00	Load of Kala-2 Line shifted on 400KV Kala-Kudus Ckt-1, (No interruption)
171	825	MSETCL	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work.	26-Aug-21	09:00	26-Aug-21	17:00	Load of Kala-2 Line shifted on 400KV Kala-Kudus Ckt-1, (No interruption)
172	826	MSETCL	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work.	26-Aug-21	09:00	26-Aug-21	17:00	Outage required on Spare bay no. 403 but the option not indicated in OMS.
173	827	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	Diagnostic testing and maintenance activities.	26-Aug-21	09:00	26-Aug-21	17:00	---
174	828	GETCO	220kV Navsari-Nashik line no.1	Daily	maintenance work	26-Aug-21	9:00	26-Aug-21	18:00	
175	831	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Hardware Tightening and Fitting Work.	26-Aug-21	09:30	26-Aug-21	18:30	-
176	833	MSETCL	132KV-DHARNI-NEPANAGAR-1	Daily	"1)Replacement of R-ph metering PT 2) Line Signature Analysis & Other Maintenance Works of Line "	26-Aug-21	11:00	26-Aug-21	16:00	nil
177	844	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For Line Bay AMP Work	27-Aug-21	7:00	27-Aug-21	18:00	
178	848	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earth wire	27-Aug-21	08:00	27-Aug-21	18:00	400kv SSNNL-2 A/R switch will be kept on non auto mode
179	851	GETCO	220kV Navsari-Nashik line no.2	Daily	maintenance work	27-Aug-21	9:00	27-Aug-21	18:00	
180	855	MSETCL	400KV-PADGHE HVDC-PADGHE-2	Daily	1) Bay Maint work 2) diagnostic testing work 3) Replacement of isolator 4) Attending Hot spot	27-Aug-21	09:00	27-Aug-21	18:30	1) Weather condition should be clear .
181	856	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	27-Aug-21	10:00	27-Aug-21	18:00	NA
182	857	MSETCL	400KV-PADGHE HVDC-PADGHE-2	Continuo us	1) Quad CB Overhauling work	27-Aug-21	18:45	5-Sep-21	19:00	weather condition should be clear HVDC 2 in service through TBC
183	863	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	D	For Line Bay AMP Work at Wardha. For line AMP works 400KV-AKOLA-AURANGABAD-2 A/R to be kept in non auto mode for safety precautions. Dia to be kept open at both the ends.	28-Aug-21	7:00	28-Aug-21	18:00	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
184	864	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1 L/R@ AKOLA - 400KV	D	For Line Reactor AMP Work	28-Aug-21	7:00	28-Aug-21	18:00	
185	867	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earth wire	28-Aug-21	08:00	28-Aug-21	18:00	400kV SSNNL-1 A/R switch will be kept on non auto mode
186	873	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	1) Routine maintenance work by Line maintenance S/Dn Kalwa. 2) Bay maintenance work at 400KV RS Kalwa.	29-Aug-21	08:00	29-Aug-21	18:00	1) Routine maintenance work by Line maintenance S/Dn Kalwa. 2) Bay maintenance work at 400KV RS Kalwa.
187	874	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	FIXING OF MISSING SPACERS	29-Aug-21	09:00	29-Aug-21	17:00	Simultaneously, outage is also required on 220KV PGCIL- BORIVALI LINE for execution of the work AS Tarapur-Borivali Line is below the PGCIL-Borivali Line.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
--------	----------------	------------------------------	----------------	-----	--------	------	------	----	------	---------

Outages not considered in WRLDC OCCM for the Month of August' 2021

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	D/C	Reason	From	Time	To	Time	Remarks
NIL										

NIL

State Element List for the month of August'2021											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	CHANDRAPUR - KHAPERKHEDA	01-Aug-21	08:00	14-Aug-21	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode
2	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	03-Aug-21	09:00	03-Aug-21	17:00	Daily	Routine maintainance and diagonastic testing such as CT tandelta and isolater maintainance work	MSETCL	MSETCL	Bay No 404 charged upto line CT (400KV ICT No -1 handed over to 400kv Bableshtar)
3	400 KV	GTR - 8 @ CHANDRAPUR SWITCHING SS	03-Aug-21	09:00	03-Aug-21	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
4	400 KV	MIAN BAY-422 OF STATION TF - 1 @ KORADI -2	04-Aug-21	10:00	04-Aug-21	16:00	Daily	TAN DELTA MEASUREMENT OF LINE CT & ROUTINE BAY MAINTENANCE	MSETCL	MSETCL	Station Transformer II & III will remain in service as alternate source
5	400 KV	LONIKAND 1 -JEJURI	05-Aug-21	09:00	05-Aug-21	17:00	Daily	DT/Line Maintenance and Insulator String replacement (LILO part).	MSETCL	MSETCL	---
6	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	05-Aug-21	09:00	05-Aug-21	17:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---
7	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	05-Aug-21	08:00	05-Aug-21	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400/220kv 501 MVA ICT-II will remain inservice.
8	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	06-Aug-21	11:00	06-Aug-21	17:00	Daily	Relay testing work and quarterly maintenance work and isolator alignment if weather permits	MSETCL	MSETCL	Nil
9	400 KV	KORADI-KHADKA	07-Aug-21	08:00	07-Aug-21	18:00	Daily	for diagnostic testing and routine bay maintaianance work	MSETCL	MSETCL	NIL
10	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	07-Aug-21	09:00	07-Aug-21	18:00	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 4 will be in service
11	400 KV	NEW KOYNA - STAGE IV CKT 1	09-Aug-21	08:00	09-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	---
12	400 KV	KHADKA- DEEPNAGAR CKT 1	09-Aug-21	09:00	09-Aug-21	16:00	Daily	For CT tandelta testing and Quarterly bay maintenance work	MSETCL	MSETCL	As per diagnostic plan
13	400 KV	Akola II (Yelwan) - Akola I CKT - 1	09-Aug-21	09:00	09-Aug-21	17:00	Daily	Routine Maintenance & testing Work	APTCL	APTCL	Yelwan Ckt-02 will be in service
14	400 KV	TIE BAY-420 OF ICT - 2 @ KORADI -2	09-Aug-21	10:00	09-Aug-21	16:00	Daily	Bay 420 Breaker Diagnosis	MSETCL	MSETCL	400/220/33KV ICT-1 WILL REMAIN IN SERVICE & ICT-2 will remain in service through Bay 421
15	400 KV	NEW KOYNA - STAGE IV CKT 2	10-Aug-21	08:00	10-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--
16	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	10-Aug-21	09:00	10-Aug-21	18:00	Daily	1) Measurement of Tan delta & capacitance of 400KV R, Y & B-ph CVTs . 2) Maintenance and alignments of PG Isolators and CB Isolators.	MSETCL	MSETCL	During outage, 400KV CHD_2 Ckt. No-2, 400KV Parli ckt-3, 400KV PGCIL Ckt. - 1, 2, 3 and 4 will be in service.

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
17	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	10-Aug-21	09:00	10-Aug-21	17:00	Daily	Routine maintainance and diagonastic testing such as CT tandelta and isolater maintainance work	MSETCL	MSETCL	only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.
18	400 KV	MIAN BAY-421 OF ICT - 2 @ KORADI -2	10-Aug-21	10:00	10-Aug-21	16:00	Daily	Bay 421 Breaker Diagnosis	MSETCL	MSETCL	400/220/33KV ICT-1 WILL REMAIN IN SERVICE & ICT-2 will remain in service through Bay 420
19	400 KV	MAIN BAY (403) OF CHANDRAPUR GCR CKT - 1 @ CHANDRAPUR - 2	10-Aug-21	10:00	10-Aug-21	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
20	400 KV	WARORA - IEPL	11-Aug-21	09:00	11-Aug-21	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
21	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	11-Aug-21	09:00	11-Aug-21	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
22	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	11-Aug-21	09:00	11-Aug-21	18:00	Daily	Bushing & widing tan delta testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
23	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 1	11-Aug-21	10:00	11-Aug-21	17:00	Continuous	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
24	400 KV	Akola II (Yelwan) - Akola I CKT - 2	11-Aug-21	09:00	11-Aug-21	17:00	Daily	Routine Maintenance & testing Work	APTCL	APTCL	Yelwan ckt-01 will be in service
25	400 KV	NEW KOYNA-KARAD -CKT1	12-Aug-21	08:00	12-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--
26	400 KV	JEJURI- KOYNA STAGE-IV	12-Aug-21	08:00	12-Aug-21	18:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
27	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	12-Aug-21	08:00	12-Aug-21	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	400kv Lonikand-II-Lonikand-I Interconnector Ckt-II will remain in service
28	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	12-Aug-21	09:30	12-Aug-21	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kv ICT-2 & ICT-3 will be in service.
29	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	12-Aug-21	09:00	12-Aug-21	18:00	Daily	(1) Differential & HV backup relay testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
30	400 KV	KHADKA- DEEPNAGAR CKT 2	13-Aug-21	09:00	13-Aug-21	16:00	Daily	For CT tan delta testing and quarterly bay maintenance work	MSETCL	MSETCL	As per diagnostic plan
31	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	13-Aug-21	11:00	13-Aug-21	17:00	Daily	Relay Testing, Quarterly Maintenance Work and Isolation Alignment if weather permits	MSETCL	MSETCL	Nil
32	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	14-Aug-21	08:00	14-Aug-21	18:00	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 3 will be in service
33	400 KV	NEW KOYNA-KARAD-CKT 2	14-Aug-21	08:00	14-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
34	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	16-Aug-21	08:00	16-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--
35	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	16-Aug-21	08:00	31-Aug-21	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode
36	400 KV	THAPTI TANDA - WALUJ	17-Aug-21	10:00	18-Aug-21	17:00	Continuous	PG isolator overhauling work	MSETCL	MSETCL	agency available
37	400 KV	JAIGAD-NEW KOYNA-I	18-Aug-21	08:00	18-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--
38	400 KV	CHANDRAPUR - KHAPERKHEDA	18-Aug-21	09:00	19-Aug-21	18:00	Continuous	1) Measurement of Tan delta & capacitance of 400KV R, Y & B-ph CTs which are due since 02 years. 2)For Drilling holes,cable Inwarding,glinding and dressing at CP/RP panel, fixing of MFM meter & CMR relay on CP panel for MTAMC project. 3)Retrofitting of Distance relay Main-1 & 3phase Master trip relay 86.1, under	MSETCL	MSETCL	During outage, 400KV CHD_2 Ckt. No- 1 & 2, 400KV Parli ckt-3, 400KV PGCL Ckt. - 1, 2, 3 and 4 will be in service.
39	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	18-Aug-21	09:00	18-Aug-21	18:00	Daily	Bushing & widening tan delta testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
40	400 KV	JEJURI- KOYNA STAGE-IV	19-Aug-21	09:00	19-Aug-21	17:00	Daily	DT/Line Maintenance and Insulator String replacement (LULO part).	MSETCL	MSETCL	---
41	400 KV	JEJURI- KOYNA STAGE-IV	19-Aug-21	08:00	19-Aug-21	18:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
42	400 KV	SPARE BAY 401@ TAPTITANDA	20-Aug-21	11:00	20-Aug-21	17:00	Daily	Full dia relay testing work	MSETCL	MSETCL	Nil
43	400 KV	JAIGAD-NEW KOYNA-II	20-Aug-21	08:00	20-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--
44	400 KV	LONIKAND 1 - KOYNA STAGE-IV	20-Aug-21	08:00	20-Aug-21	18:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
45	400 KV	TIE BAY (402) of WALUJ @ TAPTITANDA	20-Aug-21	11:00	20-Aug-21	17:00	Daily	Full dia relay testing work	MSETCL	MSETCL	Nil
46	400 KV	KORADI-NANDGAONPETH (RPL)	20-Aug-21	08:00	20-Aug-21	18:00	Daily	Line maintenance work.	MSETCL	MSETCL	NA
47	400 KV	MAIN BAY (403) of WALUJ @ TAPTITANDA	20-Aug-21	11:00	20-Aug-21	17:00	Daily	Full dia relay testing work	MSETCL	MSETCL	Nil
48	400 KV	KHADKA- DEEPNAGAR CKT 2	21-Aug-21	08:00	21-Aug-21	18:00	Daily	For diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	Nil
49	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	21-Aug-21	08:00	21-Aug-21	18:00	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	MSETCL	MSETCL	ICT 2, 3,4 will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
50	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	23-Aug-21	08:00	23-Aug-21	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	--
51	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	25-Aug-21	09:00	25-Aug-21	18:00	Daily	Bushing & widening tan delta testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
52	400 KV	JEJURI- KOYNA STAGE-IV	26-Aug-21	08:00	26-Aug-21	18:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
53	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	26-Aug-21	09:00	26-Aug-21	18:00	Daily	(1) Breaker DCRM & Timing measurement. (2) Bay maintenance work. 2) Line Maint. Work	MSETCL	MSETCL	-
54	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	26-Aug-21	09:30	26-Aug-21	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kV ICT-1 & ICT-3 will be in service..
55	400 KV	KARAD - LONIKAND 1	26-Aug-21	08:00	26-Aug-21	18:00	Daily	DT & Relay replacement under MTAMC work.	MSETCL	MSETCL	---
56	400 KV	NEW KOYNA-KARAD-CKT 2	27-Aug-21	08:00	27-Aug-21	18:00	Daily	Cold line washing work & PID Faulty insulator replacement work	MSETCL	MSETCL	Cold line washing work & PID Faulty insulator replacement work
57	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	27-Aug-21	08:00	27-Aug-21	18:00	Daily	Line maintenance work.	MSETCL	MSETCL	NA
58	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	28-Aug-21	08:00	28-Aug-21	18:00	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	MSETCL	MSETCL	ICT 1, 3, 4 will be in service
59	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	31-Aug-21	08:00	31-Aug-21	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work