

Maharashtra State Load Despatch Centre										
Monthly Outage list approved in WRLDC OCCM for the Month of AUGUST' 2022										
Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
						Date	Time	Date	Time	
1	5	POWERGRID_WR1	400KV-PARLI-M-PARLI-2	Daily	For line terminal equipment, Line AMP works. Dia to be kept open for relay testing at Parli SS & A/R to be kept in non auto mode for 400KV-PARLI-M-PARLI-1 for safety precautions.	1-Aug-22	7:00	1-Aug-22	18:00:00	
2	6	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR	Daily	Line side equipments AMP	1-Aug-22	7:00	1-Aug-22	18:00	
3	7	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2 L/R@ SOLAPUR - 400KV	Daily	Line Reactor AMP Works	1-Aug-22	7:00	1-Aug-22	18:00	
4	11	POWERGRID_WR1	WARDHA - 220KV - BUS 1	Daily	AMP of Bus-Bar	1-Aug-22	8:00	1-Aug-22	18:00	
5	19	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	Daily	For Bushing Testing.	1-Aug-22	9:00	1-Aug-22	18:00	
6	32	POWERGRID_WR1	400KV-IEPL-WARDHA-1	Continuous	MSETCL Line Diversion/By-passing works associated with Bus-splitting Scheme	1-Aug-22	7:00	3-Aug-22	18:00	
7	34	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV KOLHAPUR-MS-ICT-3 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	Continuous	400 kV CB Overhauling work by online TBC shifting of HV Bay	1-Aug-22	09:00	3-Aug-22	20:00	Online TBC shifting only.
8	39	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 1	Daily	PID Work	1-Aug-22	8:00	8-Aug-22	18:00	Online Work (PID)
9	40	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	Continuous	Pilot Wire Protection Scheme work	1-Aug-22	09:00	8-Aug-22	17:00	Total 8 days required for both the lines. Lines will be in service, only A/R will be out.
10	41	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	Continuous	Pilot Wire Protection Scheme work	1-Aug-22	09:00	8-Aug-22	17:00	Total 8 days required for both the lines. Lines will be in service, only A/R will be out.
11	44	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	Daily	For Carrying PID Work	1-Aug-22	08:00	13-Aug-22	18:00	-
12	46	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	Continuous	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway.(New Construction works)	1-Aug-22	7:00	15-Aug-22	18:00	
13	47	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	Continuous	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway.(New Construction works)	1-Aug-22	7:00	15-Aug-22	18:00	
14	49	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	Daily	Stringing of OPGW cable (Hot line Work).	1-Aug-22	08:00	15-Aug-22	18:00	Work will be carried out by M/s MTCIL
15	50	POWERGRID_WR1	765KV-WARDHA-AURANGABAD-1	Continuous	For Samridhi Diversion Work	1-Aug-22	7:00	20-Aug-22	18:00	
16	51	POWERGRID_WR1	765KV-WARDHA-AURANGABAD-2	Continuous	For Samridhi Diversion Work	1-Aug-22	7:00	20-Aug-22	18:00	
17	52	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	Daily	PID Testing Hotline Work	1-Aug-22	09:30	30-Aug-22	17:30	-
18	53	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	Daily	PID Testing Hotline Work	1-Aug-22	09:30	30-Aug-22	17:30	-
19	78	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Aug-22	09:00	31-Aug-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
20	79	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	Daily	PID WORK.BBLR-II AR SWITCH WILL BE KEPT ON NON AUTO MODE	1-Aug-22	09:00	31-Aug-22	17:00	BBLR-II AR SWITCH WILL BE KEPT ON NON AUTO MODE
21	80	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Aug-22	09:00	31-Aug-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
22	81	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	Daily	PID WORK. BBLR-I AR SWITCH WILL BE KEPT ON NON AUTO MODE	1-Aug-22	09:00	31-Aug-22	17:00	BBLR-I AR SWITCH WILL BE KEPT ON NON AUTO MODE
23	82	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Aug-22	09:00	31-Aug-22	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
24	85	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	Daily	For Line Bays, L/R & Line AMP works at both ends, Dia to be kept in open condition at both ends. A/R to be kept in non auto mode for 400KV-AKOLA-AURANGABAD-2 for safety precautions	2-Aug-22	7:00	2-Aug-22	18:00	
25	86	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1 L/R@ AURANGABAD - 400KV	Daily	For LR AMP works	2-Aug-22	7:00	2-Aug-22	18:00	
26	87	POWERGRID_WR1	400KV Kala-Kudus 2	Daily	Attending Hotspot in Line Isolator.	2-Aug-22	7:00	2-Aug-22	18:00	
27	88	POWERGRID_WR1	400KV-ALKUD-SOLAPUR	Daily	Line side equipments AMP	2-Aug-22	7:00	2-Aug-22	18:00	
28	89	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	Daily	Line Reactor AMP Works	2-Aug-22	7:00	2-Aug-22	18:00	
29	103	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-1 AND BHADRAWATI - 400KV - BUS 1 at BHADRAWATI - 400KV	Daily	For AMP WORK	2-Aug-22	8:00	2-Aug-22	18:00	

30	106	MSLDC_OUTAGE	BUS COUPLER BAY - KARAD - 400KV - BUS 1 AND KARAD - 400KV - BUS 2 at KARAD - 400KV	Daily	Alignment of Horizontal Cu bar of Bus-II B ph PG Isolator Quadriple bus for proper closing of PG Isolator with the help of Hot Line Unit,Ogalewadi.Also CB DCRM,CRM & CB timing measurement of CGL make CB.Quarterly Maint Work	2-Aug-22	08:00	2-Aug-22	19:00	Hot Line Unit Ogalewadi Unit is available on 02.08.2022
31	127	POWERGRID_WR1	WARDHA - 400KV - BUS 2	Daily	Bus Splitting converting bus#2 into bus2A and bus2B for charging of Series Reactor and 40689B, 40989B and 41589B Isolator Upgradation work under substation package SS11 (new construction element)	2-Aug-22	6:00	3-Aug-22	18:00	
32	130	APML-ADANI	400KV/11.5KV TIRODA-ST-1	Continuous	For bay equipment maintenance and testing work	2-Aug-22	9:00	3-Aug-22	18:00	TRANSFORMER OUTAGE
33	135	MSLDC_OUTAGE	DEEPNAGAR - 400KV - BUS 1	Continuous	400 kV Bus Bar Panel Replacement work by M/S BNC. Power Project Ltd, Pune. 400 kV Bus bar relay will be out of service during work (for 400 kV both BUS-1 and BUS-2)	2-Aug-22	08:00	5-Aug-22	18:00	400 kV Bus bar relay will be out of service during work (for 400 kV both BUS-1 and BUS-2)
34	149	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Annual maintenance work	3-Aug-22	09:00	3-Aug-22	17:00	The said work is very important
35	150	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Annual maintenance work	3-Aug-22	09:00	3-Aug-22	17:00	The said work is very important
36	162	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2 L/R@ BOISAR - 400KV	Daily	For AMP works of Switchable L/R	3-Aug-22	9:00	3-Aug-22	17:30	PG-WR2-BOISAR
37	153	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	Daily	(1) CVTs testing work. (2) Bay maintenance work.	3-Aug-22	09:00	3-Aug-22	18:00	-
38	160	POWERGRID_WR1	400KV-BHILAI-KORADI-1	Daily	For Line bays, L/R and line AMP works at both ends.	3-Aug-22	9:15	3-Aug-22	17:30	
39	168	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	Continuous	Diversion of 400 kV Koradi-Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kV Koradi Bays at Wardha shall	3-Aug-22	7:00	7-Aug-22	18:00	
40	172	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	Daily	401 Bay AMP	4-Aug-22	7:00	4-Aug-22	18:00	
41	173	POWERGRID_WR1	MAIN BAY OF 220KV-SOLAPUR-NARANGWADI-1 AND SOLAPUR - 220KV - BUS 1 @SOLAPUR - 220KV at Solapur - 220KV	Daily	Bay AMP Works	4-Aug-22	7:00	4-Aug-22	18:00	
42	178	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	Daily	For Conductor & Earthwire H/W tightening work if found during MP	4-Aug-22	08:00	4-Aug-22	17:00	400KV CHANDRAPUR 2 - WARORA CKT-II will be in service
43	181	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	Daily	Fixing of Earthwire	4-Aug-22	08:00	4-Aug-22	18:00	--
44	182	MSLDC_OUTAGE	400KV-KARIJAT-LONIKHAND-II-1	Daily	Diagnostic testing and Maintenance	4-Aug-22	08:00	4-Aug-22	18:00	-
45	199	POWERGRID_WR2	MAIN BAY OF 220KV-BOISAR-BORIVALI-1 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	Daily	For Bay AMP works	4-Aug-22	9:00	4-Aug-22	17:30	PG-WR2-BOISAR
46	200	MSLDC_OUTAGE	400KV-KARIJAT-LONIKHAND-II-1	Daily	Hardware tightening & Bird diverter fixing	4-Aug-22	09:00	4-Aug-22	18:00	400kV Lonikand2-Karjat ckt 2 will be in service & load will be managed
47	215	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	4-Aug-22	10:00	4-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
48	224	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARAD-KOLHAPUR-MS-1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	Continuous	400 kV CB Overhauling work by online TBC shifting.	4-Aug-22	09:00	6-Aug-22	20:00	Online TBC shifting only
49	225	MSLDC_OUTAGE	400KV/220KV CHAKAN-ICT-3	Continuous	For Overhauling of Bus C. 89 C. Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work	4-Aug-22	10:00	6-Aug-22	18:00	The Existing 89 C Isolator has mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismantling the Isolator So time required for Erection and Dismantling Work along with Overhauling
50	228	MSLDC_OUTAGE	400KV-KARAD-LONIKHAND-1	Continuous	For making UILO arrangement of 400kV Lonikand - Karad line at 400kV Jejuri s/s	4-Aug-22	08:00	18-Aug-22	18:00	Project work
51	15	POWERGRID_WR2	BUS COUPLER BAY - BOISAR - 220KV - BUS 1 AND BOISAR - 220KV - BUS 2 at BOISAR - 220KV	Daily	For Bay AMP works	5-Aug-22	9:00	5-Aug-22	17:30	PG-WR2-BOISAR
52	230	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-BOISAR-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	Daily	427 Bay AMP	5-Aug-22	7:00	5-Aug-22	18:00	
53	231	POWERGRID_WR1	MAIN BAY - 765KV/400KV PADGHE-PG-ICT-1 AND PADGHE-PG - 765KV - BUS 1 at PADGHE-PG - 765KV	Daily	For 701 Bay AMP works	5-Aug-22	7:00	5-Aug-22	18:00	
54	232	POWERGRID_WR1	220KV-PARLI-PARLI-M-1	Daily	AMP work line terminal equipment	5-Aug-22	7:00	5-Aug-22	18:00	
55	233	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-1	Daily	Line side equipments AMP Note: 220kV Narangwadi-1 line shall be in service via TBC	5-Aug-22	7:00	5-Aug-22	18:00	
56	237	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	Daily	For Conductor & Earthwire H/W tightening work if found during MP	5-Aug-22	08:00	5-Aug-22	17:00	400KV CHANDRAPUR 2 - WARORA CKT-I will be in service
57	253	POWERGRID_WR2	MAIN BAY - 400KV-PADGHE-BOISAR-1 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	Daily	Isolator servicing work	5-Aug-22	9:00	5-Aug-22	17:30	PG-WR2-BOISAR

58	265	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	Daily	1) Bay maint work 2) Diagnostic Testing work 3) MTAMC work 4) Replacement of PG Isolator under LES scheme 5) Replacement of Yph CT to Gantry jumper	5-Aug-22	09:15	5-Aug-22	19:20	Weather conditions should be clear
59	267	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	5-Aug-22	10:00	5-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
60	273	APML-ADANI	400KV/11.5KV TIRODA-ST-3	Continuous	For bay equipment maintenance and testing work	5-Aug-22	9:00	6-Aug-22	18:00	TRANSFORMER OUTAGE
61	241	MP_SLDC	220KV-KHANDWA-NEPANAGAR-1	Daily	FOR LINE MAINTENANCE WORK	6-Aug-22	8:00	6-Aug-22	18:00	
62	276	POWERGRID_WR1	400kv BHADRAWATI-RAMAGUNDAM-1	Daily	Line outage required for OPGW erection between Tower no 477 to 478	6-Aug-22	6:00	6-Aug-22	19:00	
63	277	POWERGRID_WR1	400kv BHADRAWATI-RAMAGUNDAM-2	Daily	Line A/R in non auto mode to facilitate outage on 400kv BHADRAWATI-RAMAGUNDAM-1	6-Aug-22	6:00	6-Aug-22	19:00	
64	278	POWERGRID_WR1	400kv BHADRAWATI-CHANDRAPUR-3	Daily	Line A/R in non auto mode to facilitate outage on 400kv BHADRAWATI-RAMAGUNDAM-1	6-Aug-22	6:00	6-Aug-22	19:00	
65	279	POWERGRID_WR1	400kv BHADRAWATI-CHANDRAPUR-4	Daily	Line A/R in non auto mode to facilitate outage on 400kv BHADRAWATI-RAMAGUNDAM-1	6-Aug-22	6:00	6-Aug-22	19:00	
66	280	POWERGRID_WR1	400kv CHADRAPUR-WARORA-MS-1	Daily	Line outage required for OPGW erection between Tower no 477 to 478 of 400kv BHADRAWATI-RAMAGUNDAM-1 at crossing point.	6-Aug-22	6:00	6-Aug-22	19:00	
67	281	POWERGRID_WR1	400kv CHADRAPUR-WARORA-MS-2	Daily	Line outage required for OPGW erection between Tower no 477 to 478 of 400kv BHADRAWATI-RAMAGUNDAM-1 at crossing point.	6-Aug-22	6:00	6-Aug-22	19:00	
68	282	POWERGRID_WR1	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND FUTURE at AURANGABAD - 400KV	Daily	417 Bay AMP	6-Aug-22	7:00	6-Aug-22	18:00	
69	283	POWERGRID_WR1	MAIN BAY - 400KV-KARAD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	Daily	412-R.Ph CB Terminal Pad cleaning due to imbalance current in 412-Bay.	6-Aug-22	7:00	6-Aug-22	18:00	
70	295	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-1 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	Daily	Isolator servicing work	6-Aug-22	9:00	6-Aug-22	17:30	PG-WR2-BOISAR
71	296	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Daily	Replacement of Existing Conductor by HTLS conductor.	6-Aug-22	09:00	6-Aug-22	18:00	Replacement of Existing Conductor by HTLS conductor.
72	307	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	6-Aug-22	10:00	6-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
73	309	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work. CB Timing DCRM, CVT Testing	6-Aug-22	08:00	7-Aug-22	18:00	400kv Ektuni ckt I&II, 400kv Aurangabad, Dhule I&II will be in service
74	297	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	Daily	Bay Maintenance works.	7-Aug-22	09:00	7-Aug-22	18:00	Bay Maintenance works.
75	301	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	Daily	1) Bay Maint work 2) Diagnostic Testing work 3) MTAMC work for M 1 Relay retrofitting work 4) Replacement of PG Isolator under LES scheme	7-Aug-22	09:00	7-Aug-22	19:00	Weather conditions should be clear Agency will be present on site
76	313	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Daily	Replacement of Existing Conductor by HTLS conductor.	7-Aug-22	09:00	7-Aug-22	18:00	Replacement of Existing Conductor by HTLS conductor.
77	314	MSLDC_OUTAGE	220KV-BOISAR-NALASOPARA-1	Daily	For Bay Maintenance Work at Nalasopara End and Line Maintenance Work by Line Maintenance Sub-Division Boisar.	7-Aug-22	09:00	7-Aug-22	18:00	For Bay Maintenance Work at Nalasopara End and Line Maintenance Work by Line Maintenance Sub-Division Boisar.
78	315	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	Daily	1) Bay maint work 2) Diagnostic Testing work 3) Replacement of Gantry to Wave trap jumper of Rph	7-Aug-22	09:29	7-Aug-22	19:00	Weather conditions should be clear
79	316	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	Daily	Tan delta measurement of Bus CVT.1) All the 400KV feeder will remain in service through 400kv Main Bus 2.	7-Aug-22	10:00	7-Aug-22	12:00	1) All the 400KV feeder will remain in service through 400kv Main Bus 2.
80	390	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	Daily	FOR LINE BAY AMP WORK at PUNE	7-Aug-22	9:00	7-Aug-22	18:00	
81	674	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	Daily	Routine Testing and Maintenance Work	7-Aug-22	10:00	7-Aug-22	18:00	-
82	306	MSLDC_OUTAGE	400KV-KORADI-II-KORADI-III-2	Daily	Tan delta measurement of Line CT	8-Aug-22	10:00	8-Aug-22	15:00	400kv Koradi-II -Koradi-III Ckt-I will remain in service as alternate source of supply
83	322	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-2	Daily	Line side equipments AMP Note: 220kv Narangwadi-2 line shall be in service via TBC	8-Aug-22	7:00	8-Aug-22	18:00	
84	323	POWERGRID_WR1	MAIN BAY - 400KV-RAIPUR-RAIPUR-PS (DURG)-1 AND RAIPUR-PS (DURG) - 400KV - BUS 1 at RAIPUR-PS (DURG) - 400KV	Daily	BAY AMP WORK	8-Aug-22	7:30	8-Aug-22	17:30	
85	326	APML-ADANI	TIRODA - 400KV - BUS 2	Daily	Tan delta measurement of Bus CVT & Bus isolator maintenance work	8-Aug-22	8:00	8-Aug-22	18:00	All the 400KV feeder will remain in service through 400kv Bus-1
86	335	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	Daily	CT Tan D, LBB, Quarterly Bay Maintenance	8-Aug-22	09:00	8-Aug-22	17:00	400kv Ektuni- II, Bhusawal, 400kv Aurangabad and Dhule-I & II will be in service
87	337	MSLDC_OUTAGE	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2 at PARLI-M - 400KV	Daily	1) LBB & Back Up Relay testing (2) Bay maintenance work.	8-Aug-22	09:00	8-Aug-22	18:00	-
88	352	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	8-Aug-22	10:00	8-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities

89	353	MSLDC_OUTAGE	MAIN BAY - 400KV/11.5KV KORADI-II-ST-3 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	8-Aug-22	10:00	8-Aug-22	16:00	Station Transformer-III will remain service in service through Tie Bay 405
90	354	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	8-Aug-22	10:00	8-Aug-22	18:00	NA
91	360	MSLDC_OUTAGE	KHAPARKHEDA - 400KV - BUS 1	Daily	PID Testing of Bus Insulators	8-Aug-22	09:00	9-Aug-22	18:00	NA
92	361	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-WARORA-PG-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Continuous	PIR removal due to conversion of Warora line reactor to Bus Reactor under substation package SS11 (construction outage)	8-Aug-22	8:00	10-Aug-22	18:00	
93	362	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV KOLHAPUR-MS-ICT-1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	Continuous	400 kV CB Overhauling work by online TBC shifting.	8-Aug-22	09:00	10-Aug-22	20:00	Online TBC shifting only
94	363	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	Continuous	POWERGRID Line Diversion/Re-routing works associated with Bus-splitting Scheme	8-Aug-22	7:00	15-Aug-22	18:00	
95	105	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	Daily	AMP of Line Bay	9-Aug-22	8:00	9-Aug-22	18:00	
96	385	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	Daily	CB Timing, DCRM, Quarterly Bay Maintenance	9-Aug-22	09:00	9-Aug-22	17:00	400kv Ektuni- I, Bhusawal,400kv Aurangabad and Dhule-I & II will be in service
97	387	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	Daily	Hardware tightening	9-Aug-22	09:00	9-Aug-22	18:00	Load managed on 400kv Lamboti-PGCIL Line
98	392	MEGPTCL	TIE BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-AKOLA (2)-EKTUNI-1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	9-Aug-22	10:00	9-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
99	393	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	9-Aug-22	10:00	9-Aug-22	18:00	NA
100	395	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR-II-1 (ON TBC @ CHANDRAPUR GCR)(Element not available in software)	Continuous	1. PID testing work on disc insulators of Auxiliary bus. Feeder needs to be shifted to TBC-1. 2.Circuit Breaker timing, CRM & DCRM. 3. Maintenance and alignment of PG-1, PG-2 Isolators.	9-Aug-22	08:00	11-Aug-22	18:00	During outage, 400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1 will be in service via TBC-1
101	396	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - AUXILIARY BUS 1	Daily	PID of Disc insulator Strings of 400KV Aux. Bus (Section-1)	9-Aug-22	08:00	11-Aug-22	18:00	Work will be executed in live condition.
102	398	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 2	Daily	PID Work	9-Aug-22	8:00	16-Aug-22	18:00	Online Work (PID)
103	401	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2	Daily	For Line Bays & Line AMP works at both ends, Dia to be kept in open condition at both ends. A/R to be kept in non auto mode for 400KV-AURANGABAD-M (WALUJ)-	10-Aug-22	7:00	10-Aug-22	18:00	
104	406	POWERGRID_WR1	MAIN BAY OF 220KV-SOLAPUR-NARANGWADI-2 AND SOLAPUR - 220KV - BUS 1 @SOLAPUR - 220KV at Solapur - 220KV	Daily	Bay AMP Works	10-Aug-22	7:00	10-Aug-22	18:00	
105	407	APML-ADANI	TIRODA - 400KV - BUS 1	Daily	Tan delta measurement of Bus CVT & Bus isolator maintenance work	10-Aug-22	8:00	10-Aug-22	18:00	All the 400KV feeder will remain in service through 400kv Bus-2
106	419	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	Daily	Routine Maintenance & Dignostic testing work	10-Aug-22	09:00	10-Aug-22	17:00	NA
107	420	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	Daily	Annual maintenance work	10-Aug-22	09:00	10-Aug-22	17:00	The said work is very important
108	421	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	Daily	Routine Maintenance work.	10-Aug-22	09:00	10-Aug-22	17:00	NA
109	423	POWERGRID_WR2	MAIN BAY - 400KV-TARAPUR 3&4-BOISAR-2 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV	Daily	Isolator servicing work	10-Aug-22	9:00	10-Aug-22	17:30	PG-WR2-BOISAR
110	431	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR-MS - 400KV - BUS 1 at KOLHAPUR-MS - 400KV	Daily	For Bay AMP works	10-Aug-22	9:00	10-Aug-22	18:00	
111	436	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	Daily	LINE/ s/s maintenance	10-Aug-22	09:30	10-Aug-22	17:30	-
112	439	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	10-Aug-22	10:00	10-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
113	444	MSLDC_OUTAGE	KHAPARKHEDA - 400KV - BUS 2	Daily	PID Testing of Bus Insulators	10-Aug-22	09:00	11-Aug-22	18:00	NA
114	450	MSLDC_OUTAGE	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	Daily	DT & Bay Maintenance	11-Aug-22	08:00	11-Aug-22	18:00	-
115	455	POWERGRID_WR2	TIE BAY - 400KV-VAPI-BOISAR-1 AND 400KV-TARAPUR 3&4-BOISAR-2 at BOISAR - 400KV	Daily	Isolator servicing work	11-Aug-22	9:00	11-Aug-22	17:30	PG-WR2-BOISAR
116	465	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	11-Aug-22	10:00	11-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
117	466	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-WARORA-PG-2 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Continuous	PIR removal due to conversion of Warora line reactor to Bus Reactor under substation package SS11 (construction outage)	11-Aug-22	8:00	13-Aug-22	18:00	
118	468	MSLDC_OUTAGE	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	Continuous	400 kV CB Overhauling work	11-Aug-22	09:00	13-Aug-22	20:00	
119	469	MSLDC_OUTAGE	400KV/220KV CHAKAN-ICT-2	Continuous	For Overhauling of Bus C. 89 C. Rph. Y ph. B ph Isolator and Routine Testing and Maintenance Work	11-Aug-22	10:00	13-Aug-22	18:00	The Existing 89 C Isolator has mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismantling the Isolator So time required for Erection and Dismantling Work along with Overhauling
120	470	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-BOISAR-1 AND 765KV/400KV AURANGABAD-ICT-1 at AURANGABAD - 400KV	Daily	429 Bay AMP	12-Aug-22	7:00	12-Aug-22	18:00	

121	479	POWERGRID_WR1	TIE BAY - 400KV-PARLI-M-PARLI-1 AND PARLI - 400KV B/R 1 at Parli - 400KV	Daily	AMP Work	12-Aug-22	8:30	12-Aug-22	18:00:00	
122	487	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	Daily	Hardware Tightening & Fitting Work	12-Aug-22	09:00	12-Aug-22	18:00	-
123	498	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	Daily	TCircuit Breaker SF6 gas analysis & CB Preventive maintenance activities	12-Aug-22	10:00	12-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
124	159	POWERGRID_WR1	PUNE-PG - 400KV - BUS 1	Daily	AMP WORK	13-Aug-22	9:00	13-Aug-22	18:00	
125	506	MSLDC_OUTAGE	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	Daily	CB Maintenance work after shifting the Line on TBC.	13-Aug-22	07:00	13-Aug-22	18:00	220kv BOISAR -PGCIL LINE NO.03 will be in service through TBC.
126	508	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 1 at Solapur - 400KV	Daily	Bay AMP Works	13-Aug-22	7:00	13-Aug-22	18:00	
127	515	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Daily	Replacement of existing Conductor by HTLS conductor.	13-Aug-22	09:00	13-Aug-22	18:00	Replacement of existing Conductor by HTLS conductor.
128	519	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	13-Aug-22	10:00	13-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
129	522	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work, LBB Testing	13-Aug-22	08:00	14-Aug-22	18:00	400kv Padghe I will be in service
130	525	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Daily	Replacement of existing Conductor by HTLS conductor.	14-Aug-22	09:00	14-Aug-22	18:00	Replacement of existing Conductor by HTLS conductor.
131	529	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Daily	1) Bay maint work 2) Diagnostic Testing work 3)MTAMC work	14-Aug-22	09:28	14-Aug-22	19:32	Weather conditions should be clear
132	523	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-2	Daily	For SLR CB AMP works AT Aurangabad end.	15-Aug-22	7:00	15-Aug-22	18:00	
133	524	POWERGRID_WR1	400KV-AURANGABAD-BOISAR-2 L/R@ AURANGABAD - 400KV	Daily	For SLR &SLR CB AMP works	15-Aug-22	7:00	15-Aug-22	18:00	
134	531	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	Daily	Relay testing work and Bay no 413 DCRM/CRM/CB Timings Testing works and isolater maintainance work .	15-Aug-22	09:00	15-Aug-22	18:00	Load will managed by 400KV Warora-Chandrapur 2 Ckt. 2 .
135	533	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	15-Aug-22	10:00	15-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
136	537	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV - TRANSFER BUS 1	Continuous	400 kv CB Overhauling work	15-Aug-22	09:00	18-Aug-22	20:00	
137	553	POWERGRID_WR2	MAIN BAY - 400KV-TARAPUR 3&4-BOISAR-1 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	Daily	Isolator servicing work	16-Aug-22	9:00	16-Aug-22	17:30	PG-WR2-BOISAR
138	561	POWERGRID_WR2	400KV-MAGARWADA-NAVSARI-1	Daily	For AMP work of terminal equipments at both ends and Line AMP works by Navsari TLM. A/R off of Ckt 2 and Dia to be kept open at both ends.	16-Aug-22	9:30	16-Aug-22	18:00	PG-WR2-NAVSARI
139	562	MEGPTCL	TIE BAY - 765KV/400KV AKOLA (2)-ICT-1 AND 400KV-AKOLA (2)-FUTURE-5 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	16-Aug-22	10:00	16-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
140	565	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-3 (Element not available in software)	Continuous	1. PID Testing work of disc Insulators of Auxilliary bus. Feeder needs to be shifted to TBC-1. 2.Circuit Breaker timing, CRM & DCRM. 3. Maintenance and alignments of PG-1, PG-2 Isolators and CBI Isolators.	16-Aug-22	08:00	18-Aug-22	18:00	During outage, 400kv Stn. TF No 3 will be in service via TBC-2
141	566	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - AUXILIARY BUS 2	Daily	PID of Disc insulator Strings of 400KV Aux. Bus (Section-2)	16-Aug-22	08:00	18-Aug-22	18:00	Work will be executed in live condition.
142	567	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	Daily	PID test for Insulator string. Work will be carried out Online by PID Unit Nagpur	16-Aug-22	08:00	19-Aug-22	18:00	PID Test for: 400KV Switchyard (10no. DIAs & 2 no. of Bus) 1) 400KV Main Bus-I 2) 400KV Main Bus -II 3) 400KV DIA-1(GT#10) 4) 400KV DIA-2 (Station Tr.-3 & Koradi-3 Ckt.-2) 5) 400KV DIA-3(Station Tr.-2 & Koradi-3 Ckt.-1) 6) 400KV DIA-4 (Wardha PG Line) 7) 400KV DIA-5 (GT#09) 8) 400KV DIA 6(IEPL Line) 9) 400KV DIA-7(400/220/33KV ICT-II) 10)400KV DIA-8(Station Tr. -01) 11)400KV DIA-9 (GT#08) 12) 400KV DIA -10 (400/220/33KV ICT-I) 13)Spare ICT unit Bay 431
143	569	MSLDC_OUTAGE	POLE-1 BASE AC FILTER Z1- Z2(200MVAR) @ CHANDRAPUR HVDC (Element not available in software)	Continuous	To replace interconnecting jumpers of AC filter capacitor bank & its accessories like clamps,round bar,washres etc. It is necessary to carry out above work to avoid frequent hotspots in AC filter.	16-Aug-22	08:00	21-Aug-22	22:00	1.work will be carried out through agency M/S BHEL. 2. both pole will be in service &there is bi-power restriction of 850MW. 3. pole-II base filter will be available. 4.Due to any reason pole-II base filter get tripped both pole will get tripped.

144	570	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	Daily	For Carrying PID Work	16-Aug-22	08:00	30-Aug-22	18:00	-
145	571	WTPL	400KV-KHARGHAR-PUNE-PG-1	Continuous	Line diversion work due to expansion of MIDC road at Talegaon. This is for other utility and hence proposed as deemed available	16-Aug-22	9:00	30-Aug-22	18:00	Shutdown required for dismantling, erection and stringing work.
146	580	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	Daily	Annual maintenance work	17-Aug-22	09:00	17-Aug-22	17:00	The said work is very important
147	581	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	17-Aug-22	09:00	17-Aug-22	17:00	NA
148	595	MSLDC_OUTAGE	220KV-PARU-PARU-M-2	Daily	Line, s/s Maintenance	17-Aug-22	09:30	17-Aug-22	17:30	-
149	596	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	17-Aug-22	10:00	17-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
150	597	MSLDC_OUTAGE	MAIN BAY - 400KV-WARORA-CHANDRAPU-II-1 AND CHANDRAPU-II - 400KV - BUS 1 at CHANDRAPUR-II - 400KV	Daily	Diagnostic testing and allied bay maintenance work	17-Aug-22	10:00	17-Aug-22	17:00	Diagnostic testing and allied bay maintenance work
151	598	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	Daily	Diagnostic Testing work	17-Aug-22	10:00	17-Aug-22	18:00	Load will be managed on 400kv Lamboti Parali Line
152	629	MSLDC_OUTAGE	TIE BAY (429) OF WARORA CKT-1 @ CHANDRAPUR 2 (Element not available in software)	Daily	Diagnostic testing and allied bay maintenance work	18-Aug-22	10:00	18-Aug-22	15:00	Diagnostic testing and allied bay maintenance work
153	630	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	Daily	cold line washing of insulator string and routine Line maintenance work, CB Timing DCRM, LBB Testing	18-Aug-22	08:00	19-Aug-22	18:00	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule II will be in service
154	626	MSLDC_OUTAGE	JEIURI - 400KV - BUS 2	Daily	Annual bay Maintenance and Testing Work	19-Aug-22	09:30	19-Aug-22	17:30	All elements will be in service through Tie CB
155	632	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	Daily	Shifting from B bus to A bus for Partial Bus Outage . 2) H/T for 2hrs for jumper removing work by cold line method between nago-2 & 1 in afternoon for 3hrs @	19-Aug-22	04:43	19-Aug-22	09:48	Weather conditions should be clear
156	633	MSLDC_OUTAGE	400KV-TARAPUR 3&4-PADGHE-2	Daily	Shifting from B bus to A bus for partial Bus Outage	19-Aug-22	04:45	19-Aug-22	10:00	Waether should be clear
157	641	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	Daily	H/T required for safety purpose for removing jumper by Hot line method	19-Aug-22	09:33	19-Aug-22	12:43	Weather conditions should be clear
158	642	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	Continuous	Replacement of B bus conductor of sec 3 between 400KV HVDC 2 & Nagothane 1 2) Erection of B bus CVT	19-Aug-22	04:46	21-Aug-22	23:59	Weather conditions should be clear for Hot line work
159	643	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-2	Continuous	Shifting on TBC for partial Bus Outage on day 1 & shifting from TBC to own bay on day 3 after B bus outage	19-Aug-22	05:00	21-Aug-22	21:00	Weather conditions should be clear
160	644	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	Continuous	For partial Bus Outage for replacement of Bus Conductor of sec 3 between Nagothane 1& HVDC 2	19-Aug-22	08:00	21-Aug-22	23:00	Weather conditions should be clear
161	646	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-BOISAR-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	Daily	430 Bay AMP	20-Aug-22	7:00	20-Aug-22	18:00	
162	647	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work & 400KV-WARDHA-AKOLA-2 A/R to be keep in non auto mode for safety measures.	20-Aug-22	7:00	20-Aug-22	18:00	
163	648	POWERGRID_WR1	220KV-SOLAPUR-JEUR	Daily	Line side equipments AMP Note: 220kV Jeur line shall be in service via TBC	20-Aug-22	7:00	20-Aug-22	18:00	
164	658	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	Daily	Bay Maintenance works.	20-Aug-22	09:00	20-Aug-22	18:00	Bay Maintenance works.
165	663	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-1 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	20-Aug-22	10:00	20-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
166	665	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	Daily	cold line washing of insulator string and routine Line maintenance work	20-Aug-22	08:00	21-Aug-22	18:00	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in service
167	666	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	Daily	Addition jumpering work by fire wedge connector.	20-Aug-22	09:00	21-Aug-22	18:00	Addition jumpeuring work by fire wedge connector.
168	667	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	Daily	PID test for Insulator string. Work will be carried out Online by PID Unit Nagpur.	20-Aug-22	08:00	22-Aug-22	18:00	PID Test for: 400KV Switchyard (10no. DIAs & 2 no. of Bus) 1) 400KV Main Bus-I 2) 400KV Main Bus-II 3) 400KV DIA-1(GT#10) 4) 400KV DIA-2 (Station Tr.-3 & Koradi-3 Ckt.-2) 5) 400KV DIA-3(Station Tr.-2 & Koradi-3 Ckt.-1) 6) 400KV DIA-4 (Wardha PG Line) 7) 400KV DIA-5 (GT#09) 8) 400KV DIA-6(IEPL Line) 9) 400KV DIA-7(400/220/33KV ICT-II) 10)400KV DIA-8(Station Tr. -01) 11)400KV DIA-9 (GT#08) 12) 400KV DIA -10 (400/220/33KV ICT-I) 13)Spare ICT unit Bay 431

169	671	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work & 400KV-WARDHA-AKOLA-1 A/R to be keep in non auto mode for safety measures.	21-Aug-22	7:00	21-Aug-22	18:00	
170	672	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	Daily	Annual Maintenance of line	21-Aug-22	08:00	21-Aug-22	18:00	Annual Maintenance of line
171	675	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	Daily	For safety purposed for re connection of jumper by cold line method between nago I & II	21-Aug-22	12:30	21-Aug-22	14:00	Agency will be present on site
172	676	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	Daily	for safety purposed for re-connection of jumper between 400KV HVDC 1 & 2	21-Aug-22	14:30	21-Aug-22	17:00	weather condition should be clear
173	677	MSLDC_OUTAGE	400KV-TARAPUR 3&4-PADGHE-2	Daily	shifting from A bus to Bbus through TBC	21-Aug-22	20:00	21-Aug-22	21:00	weather condition should be clear
174	680	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-BOISAR-2 AND 765KV/400KV AURANGABAD-ICT-2 at AURANGABAD - 400KV	Daily	426 Bay AMP	22-Aug-22	7:00	22-Aug-22	18:00	
175	681	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	Daily	For BHEL Insulator Replacement Work & 400KV-WARDHA-AKOLA-2 A/R to be keep in non auto mode for safety measures. Near Wardha end work to be done on Multi circuit tower hence outage of 400 KV Wardha - Aurangaabd 1 along with Ckt 2 AR N/A is required on same day.	22-Aug-22	7:00	22-Aug-22	18:00	
176	682	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	Daily	For BHEL Insulator Replacement Work & 400KV-WARDHA-AURANGABAD-2 A/R to be keep in non auto mode for safety measures. Near Wardha end work to be done on Multi circuit tower hence outage of 400 KV Wardha - Akola 1 along with Ckt 2 AR N/A is required on same day	22-Aug-22	7:00	22-Aug-22	18:00	
177	685	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-SOLAPUR-2	Daily	400KV TBC B bus isolator repair work. Outage required alongwith Bus-2 and 400KV Karad - Kolhapur(M) ckt - 2	22-Aug-22	07:00	22-Aug-22	23:59	Monday is load staggering day in kolhapur.
178	688	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	22-Aug-22	08:00	22-Aug-22	18:00	NA
179	719	MSLDC_OUTAGE	Pole-2 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC (Element not available in software)	Continuous	To carry out the work of replacing interconnecting jumpers of AC filter capacitor bank & its accessories like clamps,round bar,washres etc. It is necessary to carry out above work to nullify the frequent hotspots in filter	22-Aug-22	08:00	24-Aug-22	22:00	1.work will be carried out through agency M/S BHEL. 2. both pole will be in service & there is no power restriction. 3. pole-1-Z3 filter will be available.
180	721	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV - BUS 2	Continuous	outage is required along with Kolhapur - Solapur PG ckt 2 and Karad-kolhapur ckt 1 alos 1)PID faulty insulator string replacement work 2. Chemical cleaning of Bus insulator 3. Annual Testing of Bus CVT	22-Aug-22	07:00	25-Aug-22	20:00	Bays will be shifted to Main bus 1 online through TBC
181	259	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1	Daily	For line terminal equipment, Line AMP works. Dia to be kept open for relay testing at both ends & A/R to be keep in non auto mode for 400KV-PUNE-GIS-PUNE-PG-2, 3 & 4 for safety precautions on multi circuit portion..	23-Aug-22	9:00	23-Aug-22	18:00	
182	456	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	Daily	Hardware tightening & Bird diverter fixing	23-Aug-22	09:00	23-Aug-22	18:00	400kv LONIKAND 2 - KARIAT CKT - 1will be in service & load will be managed
183	457	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	Daily	(1) C & Tan delta measurement of reactor. (2)Bay maintenance work.	23-Aug-22	09:00	23-Aug-22	18:00	-
184	686	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	Daily	400KV TBC B bus isolator repair work. Outage required alongwith Bus-2 and 400KV Kolhapur - Solapur (PG) ckt	23-Aug-22	07:00	23-Aug-22	23:59	Monday is load staggering day in kolhapur.
185	732	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	23-Aug-22	08:00	23-Aug-22	18:00	NA
186	728	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For BHEL Insulator Replacement Work & 400KV-WARDHA-AKOLA-1 A/R to be keep in non auto mode for safety measures. Near Wardha end work to be done on Multi circuit tower hence outage of 400 KV Wardha - Aurangaabd 2 along with Ckt 1 AR N/A is required on same day.	24-Aug-22	7:00	24-Aug-22	18:00	
187	729	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-2	Daily	For BHEL Insulator Replacement Work & 400KV-WARDHA-AURANGABAD-1 A/R to be keep in non auto mode for safety measures. Near Wardha end work to be done on Multi circuit tower hence outage of 400 KV Wardha - Akola 2 along with Ckt 1 AR N/A is required on same day.	24-Aug-22	7:00	24-Aug-22	18:00	
188	773	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Routine line maintainance work	24-Aug-22	08:00	24-Aug-22	18:00	NA
189	775	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	Daily	AMP of Bay	24-Aug-22	8:00	24-Aug-22	18:00	
190	776	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	Annual maintenance work	24-Aug-22	09:00	24-Aug-22	17:00	The said work is very important
191	777	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	24-Aug-22	09:00	24-Aug-22	17:00	only Tie CB 421 is in OFF condition, respective ckt charged through its own main CB.
192	778	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	Annual maintenance work	24-Aug-22	09:00	24-Aug-22	17:00	The said work is very important
193	779	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	24-Aug-22	09:00	24-Aug-22	17:00	NA

194	794	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	Daily	Line Maintenance	24-Aug-22	09:30	24-Aug-22	17:30	-
195	796	MSLDC_OUTAGE	MAIN BAY - 400KV/20KV KORADI-II-GT-9 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	Daily	Diagnostic Testing of CT and routine bay maintenance work	24-Aug-22	10:00	24-Aug-22	13:00	GT#09 will remain service through Tie Bay 414
196	797	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	24-Aug-22	10:00	24-Aug-22	15:00	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
197	754	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-1	Continuous	outage required along with Main Bus -2 This circuit/bay can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.	25-Aug-22	08:00	26-Aug-22	18:00	This circuit/bay can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.
198	755	MSLDC_OUTAGE	CHANDRAPUR - 400KV - BUS 2	Continuous	1) Measurement of Tan delta and Capacitance of R, Y & Bph Bus CVTs. 2) Nut bolt tightening of bus conductor and hardware. 1. Bays/feeders connected to 400KV Main Bus-2 will be shifted to 400KV Main Bus-1 via TBC-1 and TBC -2 bay one by one. 2. All 400KV Bays/feeders will be in service on 400KV Main Bus-1. As 400KV Main Bus-1 will be in service. 3. After shifting of connected bays/feeders of 400KV Main Bus-2, 400KV Bus Coupler will be handtripped and Isolators of Bus coupler bay will be opened.	25-Aug-22	08:00	26-Aug-22	18:00	1. Bays/feeders connected to 400KV Main Bus-2 will be shifted to 400KV Main Bus-1 via TBC-1 and TBC -2 bay one by one. 2. All 400KV Bays/feeders will be in service on 400KV Main Bus-1. As 400KV Main Bus-1 will be in service. 3. After shifting of connected bays/feeders of 400KV Main Bus-2, 400KV Bus Coupler will be handtripped and Isolators of Bus coupler bay will be opened.
199	756	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-2	Continuous	outage required along with Main Bus -2 This circuit/bay can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.	25-Aug-22	08:00	26-Aug-22	18:00	This circuit/bay can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.
200	807	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	25-Aug-22	08:00	25-Aug-22	18:00	NA
201	811	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	Daily	For Line Bays, L/R & Line AMP works at both ends, Dia to be kept in open condition at both ends. A/R to be kept in non auto mode for 400KV-AKOLA-AURANGABAD-1 for safety precautions	25-Aug-22	8:00	25-Aug-22	18:00	
202	812	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2 L/R@ AKOLA - 400KV	Daily	For AMP of Reactor Bay at Akola SS	25-Aug-22	8:00	25-Aug-22	18:00	
203	828	MSLDC_OUTAGE	Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC (Element not available in software)	Continuous	To replace interconnecting jumpers of AC filter capacitor bank & its accessories like clamps, round bar, washres etc. It is necessary to carry out above work to avoid frequent hotspots in AC filter	25-Aug-22	08:00	27-Aug-22	22:00	1. work will be carried out through agency M/S BHEL. 2. both pole will be in service & there is no power restriction. 3. pole-1-Z4 filter will be available.
204	829	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400KV	Continuous	For Overhauling of BusB 89B Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work	25-Aug-22	10:00	27-Aug-22	18:00	The Existing 89 C Isolator has mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismantling the Isolator So time required for Erection and Dismantling Work along with Overhauling
205	631	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	C	For Overhauling of Bus C 89 C Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work	26-Aug-22	10:00	28-Aug-22	18:00	The Existing 89 C Isolator has mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by Dismantling the Isolator So time required
206	832	POWERGRID_WR1	400KV-PARLI-M-PARLI-1	D	For line terminal equipment, Line AMP works. Dia to be kept open for relay testing at Parli SS & A/R to be kept in non auto mode for 400KV-PARLI-M-PARLI-2 for safety precautions.	26-Aug-22	7:00	26-Aug-22	18:00:00	
207	833	POWERGRID_WR1	TIE BAY - 400KV-PARLI-SOLAPUR-1 AND 400KV-ALKUD-SOLAPUR-1 at Solapur - 400KV	D	Bay AMP Works	26-Aug-22	7:00	26-Aug-22	18:00	
208	834	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-1	D	LINE BAY AMP WORKS AT KOLHAPUR MS END. LINE OUTAGE REQUIRED	26-Aug-22	7:00	26-Aug-22	18:00	
209	837	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Diagnostic testing & Relay testing work	26-Aug-22	08:00	26-Aug-22	17:00	--
210	845	WTPL	400KV-PARLI-SOLAPUR-1	D	Planned annual maintenance of line	26-Aug-22	9:00	26-Aug-22	17:00	Line outage
211	846	WTPL	400KV-PARLI-SOLAPUR-2	D	AR in non auto due to planned annual maintenance of 400 kV Solapur-Parli-I	26-Aug-22	9:00	26-Aug-22	17:00	AR disable
212	865	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-4	C	1)Replacement of Bph ICT unit with new ICT unit due to increased in key gases & PD problem of existing Bph unit 2) Filtration of Yph Unit 3) Attending oil leakage of R&Yph Unit from various points. 4) CB overhauling work 5) MTAMC Work	26-Aug-22	00:06	11-Sep-22	23:59	Weather conditions should be clear
213	684	POWERGRID_WR1	400KV-KOLHAPUR-MS-ALKUD-1	D	LINE BAY AMP WORKS AT KOLHAPUR MS END. LINE OUTAGE REQUIRED	27-Aug-22	7:00	27-Aug-22	18:00	
214	867	POWERGRID_WR1	TIE BAY - 400KV/220KV SOLAPUR-ICT-1 AND 400KV-KARAD-SOLAPUR-1 at Solapur - 400KV	D	Bay AMP Works	27-Aug-22	7:00	27-Aug-22	18:00	
215	874	WTPL	400KV-PARLI-SOLAPUR-2	D	Planned annual maintenance of line	27-Aug-22	9:00	27-Aug-22	17:00	Line outage
216	875	WTPL	400KV-PARLI-SOLAPUR-1	D	AR in non auto due to planned annual maintenance of 400 kV Solapur-Parli-II	27-Aug-22	9:00	27-Aug-22	17:00	AR disable
217	881	GETCO	220KV Navsari-Nashik line no.2	D	Bay Maintenance	27-Aug-22	9:00	27-Aug-22	18:00	

218	890	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	To carry out following test on pole-1 Y phase converter transformer as per OEM recommendation work 1.Ratio test 2.tan delta of A-B1B2 winding. 3.DFRA Test 4.Winding resistance measurement 5.IR & PI of A-B1-B2 winding 6.Core insulation Measurement	27-Aug-22	1:00	28-Aug-22	22:00	pole-2 will be in service with 300MW in earth return mode or 750 MW in mettalic return mode
219	891	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Addition jumpering work by fire wedge connector.	27-Aug-22	09:00	28-Aug-22	18:00	Addition jumpering work by fire wedge connector
220	892	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Annual Maintenance of line	28-Aug-22	08:00	28-Aug-22	18:00	Annual Maintenace of line
221	893	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Bay Maintenance works.	28-Aug-22	09:00	28-Aug-22	18:00	Bay Maintenance works.
222	608	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	D	Diagnostic testing and Maintenance	29-Aug-22	08:00	29-Aug-22	18:00	-
223	618	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	D	Hardware tightening and Bird diverter fixing	29-Aug-22	09:00	29-Aug-22	18:00	load will be managed on 400kv LONIKAND 2 - KARIAT CKT - 1
224	899	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	D	For Line Bays, L/R & Line AMP works at both ends, Dia to be kept in open condition at both ends. A/R to be keep in non auto mode for 400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1 & 400KV-PARLI-PUNE-1, 2 for safety precautions.	29-Aug-22	7:00	29-Aug-22	18:00	
225	901	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Diagnostic testing & Relay testing work	29-Aug-22	08:00	29-Aug-22	17:00	--
226	905	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	29-Aug-22	09:00	29-Aug-22	17:00	Chandrapur 2 ckt 2 charged through the Tie CB 415.
227	919	MSLDC_OUTAGE	400KV/220KV CHAKAN-ICT-1	C	For Overhauling of Bus C. 89 C. Rph, Y ph, B ph Isolator and Routine Testing and Maintenance Work	29-Aug-22	10:00	31-Aug-22	18:00	The Existing 89 C Isolator has mechanically Jam due to which operation is difficult so Isolator overhauling is carried out by
228	920	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV - BUS 1	C	1. PID faulty insulator string replacement work 2. Chemical cleaning of Bus insulator 3. Annual Testing of Bus CVT All bays will be shifted to MAin Bus 2 online through TBC	29-Aug-22	07:00	1-Sep-22	20:00	All bays will be shifted to MAIN Bus 2 online through TBC
229	930	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA 400KV at WARORA - 400KV	D	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work.	30-Aug-22	09:00	30-Aug-22	17:00	only Tie CB 415 is in OFF condition, respective ckt charged through its own main CB.
230	936	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line & s/s Maintenance	30-Aug-22	09:30	30-Aug-22	17:30	-
231	940	MSLDC_OUTAGE	400KV-PARLI-M-PARLI-2	D	(1) Replacement of R phase WT clamp & jumper (2)Bay maintenance work.	31-Aug-22	09:00	31-Aug-22	18:00	-

Maharashtra State Load Despatch Centre

State Element outage list for the month of AUGUST'2022

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	01-Aug-22	09:00	01-Aug-22	18:00	Daily	Quartely Maint. of bays & CT Tan Delta & capacitance , CB timing & CRM, ICT winding & bushing Tan Delta & capacitance	MSETCL	MSETCL	Nil
2	400 KV	NEW KOYNA-KARAD CKT - 2	01-Aug-22	09:00	31-Aug-22	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
3	400 KV	GT-9 @ KORADI-2	03-Aug-22	10:00	03-Aug-22	14:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 414 & 413	MSETCL	MSETCL	NOC will be required from Mahagenco
4	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	03-Aug-22	09:00	03-Aug-22	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
5	400 KV	GT-8 @ KORADI-2	04-Aug-22	10:00	04-Aug-22	14:00	Daily	Tan delta measurement of Line CT & Bus CT at bay 425&426	MSETCL	MSETCL	NOC will be required from Mahagenco
6	400 KV	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	04-Aug-22	09:30	04-Aug-22	17:30	Daily	Annual bay Maintenance and Testing Work	MSETCL	MSETCL	-
7	400 KV	TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	04-Aug-22	09:00	04-Aug-22	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	Reactor (Bay no 402) & ICT-1 (bay No.404) is Charged through own Main CB.
8	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	04-Aug-22	08:00	04-Aug-22	18:00	Daily	DT & Bay Maintenance	MSETCL	MSETCL	-
9	400 KV	LONIKAND I - KOYNA STAGE-IV	04-Aug-22	08:00	04-Aug-22	18:00	Daily	DT & Line Maintenance	MSETCL	MSETCL	-
10	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	04-Aug-22	10:30	04-Aug-22	17:00	DAILY	Line CVT Testing & Bay maintenance. Relay Routine Testing.	MSETCL	MSETCL	-
11	400 KV	KARAD - LONIKAND I	04-Aug-22	09:00	05-Aug-22	18:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
12	400 KV	JAIGAD - NEW KOYNA CKT - 1	05-Aug-22	08:00	05-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	---
13	400 KV	MAIN BAY (407) OF STATION TF 8B @ CHANDRAPUR SWG S/S	05-Aug-22	09:00	05-Aug-22	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
14	400 KV	MAIN BAY (404) OF ICT -1 @ WARORA	05-Aug-22	09:00	05-Aug-22	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work etc	MSETCL	MSETCL	Reactor (Bay no 402) is charged through Tie Bay no 403.(ICT-1 hand over to 400KV Bhableshwar)
15	400 KV	GTR - 5 @ CHANDRAPUR SS	05-Aug-22	08:00	05-Aug-22	18:00	Daily	PID of Disc insulator Strings of 400KV GT-5 circuits from CSTPS Chandrapur to 400KV SS Chandrapur (21 nos. Strings)	MSETCL	MSETCL	Work will be executed in live condition.
16	400 KV	CHANDRAPUR-PARLI CKT-3	06-Aug-22	08:00	07-Aug-22	18:00	Continuous	1) For replacement of old M-2 distance relays. 2) Circuit Breaker timing, CRM & DCRM. 3) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	MSETCL	MSETCL	During outage, 400 KV Chandrapur-Chandrapur-2 ckt-1, 400 KV Chandrapur-Chandrapur-2 ckt-2 will be in service.
17	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	06-Aug-22	09:00	06-Aug-22	17:00	Daily	HV B/U Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 2, 3 and 4 will be in service
18	400 KV	TIE BAY - 402 CHD SWITCHING CKT1 AND CHANDRAPUR GCR CKT-1 @ CHANDRAPUR 2	06-Aug-22	10:00	06-Aug-22	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
19	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 2	08-Aug-22	10:00	08-Aug-22	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
20	400 KV	JAIGAD - NEW KOYNA CKT - 2	08-Aug-22	08:00	08-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	--

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
21	400 KV	GTR - 6 @ CHANDRAPUR	08-Aug-22	08:00	08-Aug-22	18:00	Daily	PID of Disc insulator Strings of 400KV GT-6 circuits from CSTPS Chandrapur to 400KV SS Chandrapur (21 nos. Strings)	MSETCL	MSETCL	Work will be executed in live condition.
22	400 KV	TIE BAY (406) OF ICT -2 @ WARORA	10-Aug-22	09:00	10-Aug-22	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	Presently this bay is not charged codition.
23	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	10-Aug-22	10:00	10-Aug-22	13:00	Daily	Stub bus Disc Cleaning.	MSETCL	MSETCL	Load will be managed on 400/220kV ICT II.
24	400 KV	KHADKA- DEEPNAGAR CKT 1	10-Aug-22	08:00	10-Aug-22	16:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	400 kV Deepnagar-Khadka Ckt 2 will be in service.
25	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	10-Aug-22	10:00	10-Aug-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
26	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	10-Aug-22	14:00	10-Aug-22	18:00	Daily	Stub Bus Disc Cleaning.	MSETCL	MSETCL	Load will be Managed on 400/220kV ICT I
27	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	10-Aug-22	09:00	10-Aug-22	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
28	400 KV	80 MVar BUS REACTOR - 1 @ BABHALESHWAR	10-Aug-22	10:00	10-Aug-22	17:00	Daily	DFRA and bay maintenance work	MSETCL	MSETCL	Reactor will be taken in service after 18:00 hrs i.e at peak voltage hours
29	400 KV	JEJURI- KOYNA STAGE-IV	11-Aug-22	08:00	11-Aug-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
30	400 KV	THAPTI TANDA - WALUJ	11-Aug-22	10:00	12-Aug-22	18:00	Continuous	1) Routine Maintenance work 2) PG Isolator Overhauling work	MSETCL	MSETCL	PG Isolator Overhauling work will be carried out by M/s. BIMCO representative.
31	400 KV	TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	11-Aug-22	09:00	11-Aug-22	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
32	400 KV	NEW KOYNA-KARAD CKT - 1	11-Aug-22	08:00	11-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	--
33	400 KV	KHADKA - BABLESHWAR	11-Aug-22	08:00	12-Aug-22	18:00	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work. CT Tan D	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad , Dhule I&II will be in in service
34	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	12-Aug-22	09:00	12-Aug-22	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
35	400 KV	MAIN BAY-425 OF GT-8 @ KORADI-2	12-Aug-22	10:00	12-Aug-22	13:00	Daily	Diagnostic Testing of CT and routine bay maintenance work	MSETCL	MSETCL	GT#08 will remain service through Tie Bay 426
36	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	13-Aug-22	08:00	13-Aug-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
37	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	13-Aug-22	09:00	13-Aug-22	17:00	Daily	LBB,HV CB Timing DCRM SFRA work and bay maintenance work	MSETCL	MSETCL	ICT 1, 3 and 4 will be in service
38	400 KV	NEW KOYNA-KARAD CKT - 2	13-Aug-22	08:00	13-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	--
39	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	14-Aug-22	09:00	14-Aug-22	18:00	Daily	(1) Hardware Tightening & Fitting Work (2) Cold washing work	MSETCL	MSETCL	-
40	400 KV	LONIKAND I - KOYNA STAGE-IV	14-Aug-22	08:00	14-Aug-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
41	400 KV	JEJURI- KOYNA STAGE-IV	15-Aug-22	08:00	15-Aug-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
42	400 KV	TBC @ BABHALESHWAR	16-Aug-22	09:00	16-Aug-22	14:00	Daily	CT Tan D	MSETCL	MSETCL	400 KV TBC is free
43	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	16-Aug-22	08:00	16-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	---
44	400 KV	MAIN BAY (407) OF ICT - 2 @ WARORA	17-Aug-22	09:00	17-Aug-22	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work etc	MSETCL	MSETCL	Presently this bay is not charged codition.
45	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	17-Aug-22	09:00	17-Aug-22	13:00	Daily	CB Timing,DCRM	MSETCL	MSETCL	Not in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
46	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	17-Aug-22	10:00	17-Aug-22	17:00	Daily	Tan Delta & Capacitance of Line CTs,Main CTs & IR values of LA	MSETCL	MSETCL	NA
47	400 KV	KORADI-NANDGAONPETH (RPL)	17-Aug-22	09:00	17-Aug-22	17:00	Daily	400KV RPL line Reactor DFRA testing work	MSETCL	MSETCL	Outage required only on 400KV RPL line Reactor. Line will be in service without reactor after taking reactor out.
48	400 KV	KHADKA- DEEPNAGAR CKT 2	17-Aug-22	08:00	17-Aug-22	16:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	400 kV Deepnagar-Khadka Ckt-1 will be in service.
49	400 KV	CHANDRAPUR-PARLI CKT-3	18-Aug-22	09:00	18-Aug-22	18:00	Daily	(1) Main-1 distance relay testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
50	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	18-Aug-22	08:00	18-Aug-22	18:00	Daily	DT & Bay Maintenance	MSETCL	MSETCL	-
51	400 KV	MAIN BAY (407) OF RPL CKT-1 @ AKOLA 2	18-Aug-22	10:00	18-Aug-22	15:00	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	MEGPTCL	MEGPTCL	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
52	400 KV	TIE BAY - 411 OF PARLI (GIRWALI) CKT-1 @ NANDED	18-Aug-22	10:30	18-Aug-22	17:00	Daily	CB DCRM and Bay maintenance works.	MSETCL	MSETCL	-
53	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	18-Aug-22	08:00	18-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	--
54	400 KV	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	19-Aug-22	10:00	19-Aug-22	15:00	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	MEGPTCL	MEGPTCL	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
55	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	19-Aug-22	10:00	19-Aug-22	18:00	Daily	1) Routine Maintenance work 2) Diagnostic Testing Work	MSETCL	MSETCL	NIL
56	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	20-Aug-22	09:00	20-Aug-22	17:00	Daily	CB Timing DCRM and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 4 will be in service
57	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	22-Aug-22	09:00	22-Aug-22	18:00	DAILY	(1) Main-2 Distance relay testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
58	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	22-Aug-22	10:00	22-Aug-22	17:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	bhusawal ckt will be in service
59	400 KV	NEW KOYNA - STAGE IV CKT - 1	22-Aug-22	08:00	22-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	--
60	400 KV	MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2	22-Aug-22	10:00	22-Aug-22	15:00	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	MEGPTCL	MEGPTCL	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
61	400 KV	TIE BAY-426 OF GT-8 @ KORADI-2	23-Aug-22	10:00	23-Aug-22	13:00	Daily	Diagnostic Testing of CT and routine bay maintenance work	MSETCL	MSETCL	GT#08 will remain service through Main Bay 425
62	400 KV	TIE BAY (411) OF RPL CKT - 2 & AKOLA-1 CKT-2 @ AKOLA 2	23-Aug-22	10:00	23-Aug-22	15:00	Daily	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities	MEGPTCL	MEGPTCL	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
63	400 KV	NEW KOYNA - STAGE IV CKT - 2	23-Aug-22	08:00	23-Aug-22	17:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	--
64	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	24-Aug-22	09:00	24-Aug-22	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
65	400 KV	KARAD - LONIKAND I	24-Aug-22	08:00	25-Aug-22	18:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
66	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	24-Aug-22	10:00	24-Aug-22	17:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Load shifted on ICT-02
67	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	24-Aug-22	10:00	24-Aug-22	17:00	Daily	CTR Servicing & Maintenance Work	MSETCL	MSETCL	NA
68	400 KV	MAIN BAY (407) OF ICT - 2 @ NANDED	25-Aug-22	10:30	25-Aug-22	17:00	Daily	CB DCRM and Bay maintenance works.	MSETCL	MSETCL	-
69	400 KV	KORADI-NANDGAONPETH (RPL)	25-Aug-22	08:00	25-Aug-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
70	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	25-Aug-22	09:00	25-Aug-22	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	Line equipment will charged through Tie bay no 418
71	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	25-Aug-22	08:00	25-Aug-22	18:00	Daily	DT & Bay Maintenance	MSETCL	MSETCL	-
72	400 KV	400KV 125MVAR BUS REACTOR @ KARAD	25-Aug-22	09:00	25-Aug-22	18:00	Daily	Quartely Maint. of bays & CT Tan Delta & capacitance , CB timing & CRM,Reactor winding & bushing Tan Delta & capacitance	MSETCL	MSETCL	Nil
73	400 KV	TIE BAY - 414 OF GT-9 @ KORADI-2	25-Aug-22	10:00	25-Aug-22	13:00	Daily	Diagnostic Testing of CT and routine bay maintenance work	MSETCL	MSETCL	GT#09 will remain service through Main Bay 413
74	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	25-Aug-22	09:00	25-Aug-22	18:00	Daily	(1) HV CTs Testing work & HV Backup relay testing. (2) Bay maintenance work.	MSETCL	MSETCL	-
75	400 KV	400/220kV SPARE ICT @ JEJURI	25-Aug-22	09:30	25-Aug-22	17:30	Daily	Annual bay Maintenance and Testing Work	MSETCL	MSETCL	-
76	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT 2	25-Aug-22	09:00	25-Aug-22	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
77	400 KV	NEW KOYNA-KARAD CKT - 1	25-Aug-22	08:00	25-Aug-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
78	400 KV	TBC @ WALUJ	26-Aug-22	10:00	26-Aug-22	18:00	Daily	1) Routine Maintenance work 2) Diagnostic Testing Work	MSETCL	MSETCL	NIL
79	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	26-Aug-22	09:00	26-Aug-22	17:00	Daily	Main-II Distance relay Testing,Quarterly Bay Maintenance	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal, Dhule I&II will be in service
80	400 KV	GTR - 7 @ CHANDRAPUR	26-Aug-22	08:00	26-Aug-22	18:00	Daily	PID of Disc insulator Strings of 400KV GT-7 circuits from CSTPS Chandrapur to 400KV SS Chandrapur (21 nos. Strings)	MSETCL	MSETCL	Work will be executed in live condition.
81	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	27-Aug-22	09:00	27-Aug-22	17:00	Daily	Tap Condition, HV LV Backup, HV LV Differential, CB Timing,DCRM,HV LV CT Tan D,Winding Tan D, REF Relay Testing and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 3 will be in service
82	400 KV	NEW KOYNA-KARAD CKT - 2	27-Aug-22	08:00	27-Aug-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
83	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	29-Aug-22	10:00	29-Aug-22	17:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Load will be shifed on ICT-01
84	400 KV	JEJURI- KOYNA STAGE-IV	29-Aug-22	08:00	29-Aug-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
85	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	29-Aug-22	09:00	29-Aug-22	18:00	Daily	(1) C & Tan D measurement ICT Units. (2) Bay maintenance work.	MSETCL	MSETCL	-
86	400 KV	400kv Stn. TF No 4 @ C'pur GCR	29-Aug-22	08:00	29-Aug-22	18:00	Daily	PID of Disc insulator Strings of 400KV STN TF-4 circuits from CSTPS Chandrapur to 400KV SS Chandrapur (21 nos. Strings)	MSETCL	MSETCL	Work will be executed in live condition.