

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of AUGUST'2024

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
1	14	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	01/Aug/2024	08:00	01/Aug/2024	18:00	/Outage/
2	20	PLANNED	OCC_581	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	D	AMP of Line Equipment at Padghe GIS & MSETCL Kudus substation and Autoreclosure scheme checking at Padghe SS. AR IN NON AUTO MODE OF CKT#2	01/Aug/2024	9:00	01/Aug/2024	17:00	
3	30	PLANNED	OCC_581	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	D	SF6 analysis of BAY 702	01/Aug/2024	10:00	01/Aug/2024	15:00	/BAY Outage/
4	32	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Maintaining clearance with the help of JCB work in the span between loc no 51-52. Half yearly maintainance.	01/Aug/2024	10:00	01/Aug/2024	18:00	
5	46	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-1	C	For making LILO point connection at loc 1 and chargind of new CPRI substation	01/Aug/2024	09:00	03/Aug/2024	18:00	OCC Remark-loadings to be reviewed. MH-CTU permission is pending./the said outage is processed by line Project subdivision/
6	47	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. ICT-1 will be in service through TBC	01/Aug/2024	08:00	04/Aug/2024	18:00	/400/220 KV ICT 1 HV will be in service through TBC /
7	48	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-KALWA-PADGHE-2 AND KALWA - 400KV - BUS 1 at KALWA - 400KV	C	1) Replacement of CB with rating of 3150A for HTLS work 2) A& B bus PG isolator maint work 3 400kV Kalwa -2 in service through TBC	01/Aug/2024	08:00	04/Aug/2024	23:00	WRLDC-At KALWA, Main bay of Padghe 2 and Padghe line 1 outage planned simultaneously for 4 days./1) Weather condition should be clear during CB erection and commissioning work /
8	50	PLANNED	OCC_581	APML	400KV/21KV TIRODA-GT-2	C	GT-2 Maintenance, testing and painting work. Main bay and Tie bay equipment maintenance work	01/Aug/2024	9:00	10/Aug/2024	18:00	/ST-4 will be in service on MAIN bay /
9	51	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To carry out PID work. Only A/R Out, Line will in service	01/Aug/2024	08:00	14/Aug/2024	18:00	/Only A/R Out, Line will in service/
10	77	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	OPGW Stringing work. Only AR to be kept off. Line will be in service	01/Aug/2024	07:00	31/Aug/2024	19:00	/OPGW Stringing work/
11	78	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	OPGW Stringing work. Only AR to be kept off. Line will be in service	01/Aug/2024	07:00	31/Aug/2024	19:00	/OPGW Stringing work/
12	81	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	For OPGW installation replacing existing earth wire (AR Out)	01/Aug/2024	08:00	31/Aug/2024	18:00	OCC Remark-Study /contingency plan to be submitted.WRLDC-Availed in July. Work progress status to be informed./MTCL work/
13	82	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	For OPGW installation replacing existing earth wire (AR Out)	01/Aug/2024	08:00	31/Aug/2024	18:00	OCC Remark-Study /contingency plan to be submitted.WRLDC-Availed in July. Work progress status to be informed./MTCL work/
14	83	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/Aug/2024	08:00	31/Aug/2024	18:00	/PID Work. A/R Out /
15	84	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/Aug/2024	08:00	31/Aug/2024	18:00	/PID Work. A/R Out /
16	88	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-1	D	A/R off PTW for Live line OPGW installation	01/Aug/2024	08:00	31/Aug/2024	19:00	/Only AR kept off. Line will be in service/
17	89	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-2	D	A/R off PTW for Live line OPGW installation	01/Aug/2024	08:00	31/Aug/2024	19:00	/Only AR kept off. Line will be in service/
18	91	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	01/Aug/2024	09:00	31/Aug/2024	17:30	
19	92	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID	01/Aug/2024	09:00	31/Aug/2024	17:30	OCC Remark-AR outMH-Only AR will be kept of f. Line will be in service./-/
20	100	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	C	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)	01/Aug/2024	09:00	31/Aug/2024	18:00	OCC Remark-90 days/MH-Work in progress from 14 June 2024./For 220 kV Bale S/Sn Source will be available from 220 kV Lamboti Ckt- I & II & 220 kV South Solapur.Also for 220 kV Tuljapur S/Sn Source will be available from 220 kV Murud & PGCIL. 2) Line will be off only for 24 Hrs for necessary arrangements. 3) Outage is proposed as per the directives from Hon. Director
21	101	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing & For Safety purpose on M/C Towers (loc 1 to 16) for OPGW installation replacing existing earth wire on Lonikand2- Karjat D/s Lines (AR Out)	01/Aug/2024	09:00	31/Aug/2024	18:00	OCC Remark-Study /contingency plan to be submitted.WRLDC-AT Karjat, Parli D/C and Lonikhand II D/C AR in NA planned simultaneously for 31 days./-/
22	102	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing & For Safety purpose on M/C Towers (loc 1 to 16) for OPGW installation replacing existing earth wire on Lonikand2- Karjat D/s Lines (AR Out)	01/Aug/2024	09:00	31/Aug/2024	18:00	OCC Remark-Study /contingency plan to be submitted.WRLDC-AT Karjat, Parli D/C and Lonikhand II D/C AR in NA planned simultaneously for 31 days./-/
23	103	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	PID testing, Only AR will be kept off. Line will be in service.	01/Aug/2024	09:00	31/Aug/2024	18:00	/PID testing work/
24	104	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID Testing work. Only AR to be kept off. Line will be in service	01/Aug/2024	09:00	31/Aug/2024	18:00	/Line maintenance work/
25	105	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	A/R out of service for OPGW stringing work by MTCL	01/Aug/2024	10:00	31/Aug/2024	18:00	/NA/

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuous	Reason	From		To		Remarks
26	106	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	A/R out of service for OPGW stringing work by MTCIL	01/Aug/2024	10:00	31/Aug/2024	18:00	/NA/
27	107	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	01/Aug/2024	11:00	31/Aug/2024	15:00	/For PID work . A/R Out /
28	108	PLANNED	OCC_581	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	01/Aug/2024	11:00	31/Aug/2024	15:00	/For PID work. A/R Out. /
29	112	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	For AMP	02/Aug/2024	7:00	02/Aug/2024	18:00	/412/
30	113	PLANNED	OCC_581	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	For AMP	02/Aug/2024	7:00	02/Aug/2024	18:00	/PGHL/
31	114	PLANNED	OCC_581	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2 L/R@ DHULE-MS - 400KV	D	For AMP	02/Aug/2024	7:00	02/Aug/2024	18:00	/PGHR/
32	115	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-KHANDWA-DHULE-MS-2 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	For AMP	02/Aug/2024	7:00	02/Aug/2024	18:00	/PGH/
33	116	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - DHARAMJAYGARH - 765KV B/R 3 AND DHARAMJAYGARH - 765KV - BUS 3 at DHARAMJAYGARH - 765KV	D	For bay AMP works	02/Aug/2024	7:00	02/Aug/2024	18:00	
34	134	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Line Maintenance and Routine Diagnostic works	02/Aug/2024	09:00	02/Aug/2024	17:00	/Line maintenance and routine Diagnostic works/
35	137	PLANNED	OCC_581	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	D	For AMP Work	02/Aug/2024	9:00	02/Aug/2024	17:30	/Line Owned By MSETCL/
36	146	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR-II-1	D	1. Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine maintenance work.	02/Aug/2024	08:00	03/Aug/2024	18:00	/During outage 400KV CHD-2 CKT-2, 400KV Parli CKT-3, 400KV Khaperkheda, 400KV HVDC CKT-1 &2, 400KV PGCIL CKT-1,2,3&4 will be in service./
37	149	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	02/Aug/2024	08:00	07/Aug/2024	18:00	/PID Work. A/R Out/
38	152	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-2	D	1) Bay Maint work 2) Diagnostic Testing work	02/Aug/2024	09:00	04/Aug/2024	19:00	OCC Remark-reschedule/1)Weather conditions should be clear /
39	153	PLANNED	OCC_581	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	C	FOR ATTENDING SF6 GAS LEAKAGE WORK IN 406GD 6R SPACER	03/Aug/2024	6:00	05/Aug/2024	6:00	OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayWRLDC-Subject to MSLDC cosentMH-
40	161	PLANNED	OCC_581	MSLDC_OUTAGE	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	D	DT and Bay Maintenance activities	03/Aug/2024	08:00	03/Aug/2024	18:00	Outage to be availed from Night hours from 22:00 hrs(friday). /Load to be balanced on Bus-1 and Bus-2/
41	170	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	03/Aug/2024	9:00	03/Aug/2024	17:30	OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayMH-Continuous outage on 400KV-PUNE-GIS-PUNE-PG-4 from 02.08.2024 to 04.08.2024 Please reschedule on another Thurs / Friday / Sat/Sunday IN
42	171	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-JPL EXTN-TAMNAR-4 AND TAMNAR - 400KV - BUS 2 at TAMNAR - 400KV	D	AMP works	03/Aug/2024	9:00	03/Aug/2024	17:30	
43	176	PLANNED	OCC_581	POWERGRID_WR1	RAIGARH-PS - 400KV - BUS 3	D	AMP as per Maintenance schedule	03/Aug/2024	9:00	03/Aug/2024	18:00	/HOTSPT RECTIFICATION IN 432 ISO BUS SIDE/
44	181	PLANNED	OCC_581	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	D	SF6 analysis of BAY 704	03/Aug/2024	10:00	03/Aug/2024	15:00	/BAY Outage/
45	182	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	Routine Maintenance & Diagnostic Testing Works	03/Aug/2024	10:00	03/Aug/2024	18:00	/Outage on 400KV ThaptiTanda-1 (Line Bay & Tie Bay) along with 400KV Main Bus-1/
46	183	PLANNED	OCC_581	MSLDC_OUTAGE	EKTUNI - 400KV - BUS 1	D	Routine Maintenance & Diagnostic Testing Works	03/Aug/2024	10:00	03/Aug/2024	18:00	/Outage on 400KV Main Bus-1 along with 400KV ThaptiTanda-1 (Line Bay & Tie Bay)/
47	186	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	connection of CT to new LTS panel	04/Aug/2024	5:00	04/Aug/2024	7:00	/connection of CT to new LTS panel. All 400kV elements at Kalwa ss to be in service./
48	192	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Repair Sleeves for Conductor damaged at Loc No. 136-137 Top Ph.	04/Aug/2024	09:00	04/Aug/2024	17:00	/Simultaneously outage is required on 220kV PGCIL - Borivali Line (for safety purpose)/
49	193	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	outage is required on 220kV PGCIL - Borivali Line (for safety purpose) during the work of Repair Sleeves for Conductor damaged at Loc No. 136-137 Top Ph on 220kV Tarapur - Borivali Line.	04/Aug/2024	09:00	04/Aug/2024	17:00	/outage is required on 220kV PGCIL - Borivali Line (for safety purpose) during the work of Repair Sleeves for Conductor damaged at Loc No. 136-137 Top Ph on 220kV Tarapur - Borivali Line./

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks	
50	194	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Line maintenance and routine Diagnostic works	04/Aug/2024	09:00	04/Aug/2024 17:00	/Line maintenance and routine Diagnostic works/
51	202	PLANNED	OCC_581	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)- AURANGABAD-1	D	For AMP	05/Aug/2024	7:00	05/Aug/2024 18:00	/412L/
52	220	PLANNED	OCC_581	POWERGRID_WR2	MAIN BAY OF 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	D	AMP of Bay	05/Aug/2024	9:00	05/Aug/2024 17:30	/PG-WR2- BOISAR/
53	222	PLANNED	OCC_581	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND 400KV/220KV PUNE-PG-ICT-2 at PUNE-PG - 400KV	D	For AMP Work	05/Aug/2024	9:00	05/Aug/2024 17:30	OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayMH-Please reschedule on Thurs / Friday/ Sat/Sunday IN NIGHT HOURS & No other outage at 765KV & 400KV level in PUNE region /
54	241	PLANNED	OCC_581	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Sf6 analysis of BAY 706	05/Aug/2024	10:00	05/Aug/2024 15:00	/BAY Outage/
55	244	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintainance work	05/Aug/2024	10:00	05/Aug/2024 18:00	/NA/
56	268	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	A/R out of service for Balance PID Work.	05/Aug/2024	08:00	31/Aug/2024 18:00	/NA/
57	272	PLANNED	OCC_581	POWERGRID_WR1	220KV-PARLI-PARLI-M-1	D	For AMP	06/Aug/2024	7:00	06/Aug/2024 18:00	
58	274	PLANNED	OCC_581	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	06/Aug/2024	7:00	06/Aug/2024 18:00	/Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme/
59	288	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-KUDUS-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	D	To check alignment and to take remote trial	06/Aug/2024	08:00	06/Aug/2024 18:00	/400kV Kudus 1 bay is only in charged condition/
60	289	PLANNED	OCC_581	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	to check alignment and to take remote trial	06/Aug/2024	08:00	06/Aug/2024 18:00	OCC Remark-one at a timeWRLDC-Simultaneously planned with Bus 1/Project outage proposed by ADDE Line project subdivision/
61	301	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	06/Aug/2024	9:00	06/Aug/2024 17:30	OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayMH-Outage Most feasible in night Hours.
62	327	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintainance work	06/Aug/2024	10:00	06/Aug/2024 18:00	/NA/
63	329	PLANNED	OCC_581	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1	C	Reactor CB Drive Mechanism Inspection Work by OEM. Line outage is proposed as per the requirement of RLDC.	06/Aug/2024	7:00	07/Aug/2024 18:00	OCC Remark-RLDC requirement not to be mentioned.MH- Kindly Schedule from Saturday to Sunday. In Night Hours TOTAL LOADING ON ALL PUNE GIS to PUNE PG ckt's to be
64	330	PLANNED	OCC_581	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1 L/R@ AURANGABAD - 765KV	C	Reactor CB Drive Mechanism Inspection Work by OEM	06/Aug/2024	7:00	07/Aug/2024 18:00	MH-Kindly Schedule from Saturday to Sunday. In Night Hours TOTAL LOADING ON ALL PUNE GIS to PUNE PG ckt's to be
65	333	PLANNED	OCC_581	DHARIWAL	DHARIWAL - 400KV B/R 1	D	for 400 Kv BUS Reactor 80 Mvar maintenance work and its equipments testing work	06/Aug/2024	9:00	07/Aug/2024 18:00	/on daily basis/For Annual testing & maintenance
66	345	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Replacement polymer insulator	06/Aug/2024	08:00	10/Aug/2024 18:00	/Replacement polymer insulator/
67	348	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-2	C	1) PLCC ,CVT and WT foundation, Erection,Testitng and Commissioning work at 220KV Navsari ss. 2) PLCC ,CC and WT foundation, Erection,Testitng and Commissioning work at 220 KV Nasik ss.	06/Aug/2024	09:00	22/Aug/2024 17:00	
68	351	PLANNED	OCC_581	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	To check the alignment and to take remote trail of 400kV Kudus I Bay Bus CVT tan D testing	07/Aug/2024	08:00	07/Aug/2024 18:00	OCC Remark-one at a timeWRLDC-Simultaneously planned with Bus 2/All feeders and ICT on Main Bus I will be shifted on Main Bus II
69	360	PLANNED	OCC_581	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-2	D	Line terminal equipments AMP at 765kV Solapur Substation	07/Aug/2024	7:00	07/Aug/2024 18:00	
70	366	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	PLCC Panel Replacement work	07/Aug/2024	08:00	07/Aug/2024 17:00	
71	372	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	07/Aug/2024	08:00	07/Aug/2024 18:00	/Outage /
72	382	PLANNED	OCC_581	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	07/Aug/2024	09:00	07/Aug/2024 17:00	/ONLINE WORK During 400KV Busbar Protection Relay testing works Outage,
73	384	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	07/Aug/2024	9:00	07/Aug/2024 17:30	OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayMH-Outage Most feasible in night Hours.
74	385	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	07/Aug/2024	09:00	07/Aug/2024 17:30	
75	403	PLANNED	OCC_581	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	07/Aug/2024	09:00	07/Aug/2024 18:00	/NA/
76	408	PLANNED	OCC_581	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Sf6 analysis of BAY 707	07/Aug/2024	10:00	07/Aug/2024 15:00	/BAY Outage/

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From	To	Remarks
77	410	PLANNED	OCC_581	MSLDC_OUTAGE	JEUR - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	07/Aug/2024	10:00	07/Aug/2024 17:00 /220 kV SOLAPUR PG - JEUR Line will be OUT. Breaker of PCCLL line at Jeur End will be made off/
78	412	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Routine Diagnostic Testing and Maintenance Works.	07/Aug/2024	10:00	07/Aug/2024 18:00 /1500MVA 765/400kV ICT II will be in service by 765kV Tie by 4 and Main bus 1/
79	415	PLANNED	OCC_581	POWERGRID_WRI	400KV-WARORA (M)-WARORA-PG-2	C	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	07/Aug/2024	7:00	08/Aug/2024 18:00 /Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme/
80	419	PLANNED	OCC_581	MEGPTCL	765KV/400KV TIRODA-ICT-1	C	Maitenance and testing work. Main bay and Tie bay equipment maintenance work	07/Aug/2024	9:00	08/Aug/2024 18:00 /GT-1 and GT-4 will be in service on Main bay/
81	425	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	C	Overhauling of Circuit breaker , Koradi-II Wardha(PG) ckt. will remain inservice through tie Bay 411	07/Aug/2024	08:00	14/Aug/2024 17:30 /Koradi-II Wardha(PG) ckt. will remain inservice through tie Bay 411 /
82	430	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	LINE MAINT. WORKS	08/Aug/2024	06:00	08/Aug/2024 18:00 /NA/
83	437	PLANNED	OCC_581	POWERGRID_WRI	220KV-PARLI-OSMANABAD-M-1	D	For AMP	08/Aug/2024	7:00	08/Aug/2024 18:00
84	445	PLANNED	OCC_581	POWERGRID_WRI	MAIN BAY OF 400KV-KOLHAPUR-MS-SOLAPUR-2 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	08/Aug/2024	8:00	08/Aug/2024 18:00 /Outage required on CB only. Line can be kept in service through TBC./
85	451	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance work	08/Aug/2024	08:00	08/Aug/2024 18:00 /400kv Ektuni ckt 16H,400kV Bhusawal,400kv C-Sambhaji nagar and Dhule II will be in service /
86	452	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	In view of outage on 400 KV Dhule Ckt I for Line maintenance work.Only AR will be in Non Auto work.Only AR will be in Non Auto	08/Aug/2024	08:00	08/Aug/2024 18:00 /Only AR will be in Non Auto.Line will be in service. /
87	453	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	08/Aug/2024	08:00	08/Aug/2024 18:00 /Outage/
88	454	PLANNED	OCC_581	POWERGRID_WRI	TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV/220KV WARDHA-ICT-1 at Wardha - 400KV	D	For Replacement of Density monitor cu pipe by M/s CGL.	08/Aug/2024	8:00	08/Aug/2024 20:00 /Work @ Wardha SS/
89	461	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	08/Aug/2024	09:00	08/Aug/2024 17:00 /400 KV WARORA - DEOLI 2 Line is in ckt /
90	462	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	"1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at Badnera S/s"	08/Aug/2024	09:00	08/Aug/2024 17:00 /Outage /
91	484	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1	D	Routine Diagnostic Testing and Maintenance Works	08/Aug/2024	10:00	08/Aug/2024 18:00 /1500MVA 765/400kV ICT will be in service by 765kV Main Bus 2 and 765kV Bus Reactor will be in service via 765kV Main Bus 1/
92	488	PLANNED	OCC_581	POWERGRID_WRI	765KV-AURANGABAD-PADGHE-PG-2	C	Reactor CB Drive Mechanism Inspection Work by OEM. Line outage is proposed as per the requirement of RLDC.	08/Aug/2024	7:00	09/Aug/2024 18:00 OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayNLDC-L/R work shall be clubbed with loine outage/AMP work/707L/
93	489	PLANNED	OCC_581	POWERGRID_WRI	765KV-AURANGABAD-PADGHE-PG-2 L/R@ AURANGABAD - 765KV	C	Reactor CB Drive Mechanism Inspection Work by OEM	08/Aug/2024	7:00	09/Aug/2024 18:00 NLDC-L/R work shall be clubbed with loine outage/AMP work/707LR/
94	495	PLANNED	OCC_581	POWERGRID_WRI	400KV-CHANDRAPUR-BHADRAWATI-2	C	Overhauling of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS. AMP works & CVT replacement at Bhadrawati end. AR IN NON AUTO MODE OF CKT#1	08/Aug/2024	8:00	10/Aug/2024 20:00 /Overhauling of pantograph Isolator, CVT replacement at BVT end/
95	499	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work.400 KV Padghe II will be in service through TBC	08/Aug/2024	08:00	12/Aug/2024 18:00 WRLDC-At KALWA, Main bay of Padghe 2 and Padghe line 1 outage planned simultaneously for 4 days./400 KV Padghe II will be in service through TBC at Babbleshwar end/
96	500	PLANNED	OCC_581	POWERGRID_WRI	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	08/Aug/2024	9:00	27/Aug/2024 17:00 OCC Remark-compilation done without considering outage Under reviewMH-Already discussed and approved in 580th OCCMNLDC-All statutory clearances, FTC Approval to be submitted before charging of line.765KV-AURANGABAD-PADGHE
97	501	PLANNED	OCC_581	POWERGRID_WRI	765KV-PUNE-GIS-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	08/Aug/2024	9:00	27/Aug/2024 18:00 OCC Remark-compilation done without considering outage Under reviewMH-Already discussed and approved in 580th OCCMNLDC-All statutory clearances, FTC Approval to be submitted before charging of line.765KV-PUNE-PADGHE
98	502	PLANNED	OCC_581	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-3	C	FOR ATTENDING SF6 GAS LEAKAGE WORK IN 407GD 7R,7B SPACER	09/Aug/2024	6:00	11/Aug/2024 18:00 OCC Remark-on Sunday/ subject to no other important outage nearby/ to be planned from FridayMH-Kindly Schedule from Friday to Sunday.Outage to be availed from Night hours from 22:00 hrs(friday)
99	508	PLANNED	OCC_581	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	AMP, Dia to be kept open at both sides	09/Aug/2024	7:00	09/Aug/2024 21:00 OCC Remark-Friday to Sunday. RescheduleWRLDC-MSLDC consent required/PG-WR2- BOISAR/
100	515	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	In view of outage on 400 KV Dhule Ckt II for Line maintenance work.Only AR will be in Non Auto	09/Aug/2024	08:00	09/Aug/2024 18:00 /Only AR will be in Non Auto.Line will be in service. /
101	516	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance work	09/Aug/2024	08:00	09/Aug/2024 18:00 /400kv Ektuni ckt 16H,400kV Bhusawal,400kv C-Sambhaji nagar and Dhule I will be in service /
102	535	PLANNED	OCC_581	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR LINE MAINTENANCE WORK	09/Aug/2024	9:00	09/Aug/2024 18:00 MP-reschedule it to 10.08.24//
103	544	PLANNED	OCC_581	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	D	SF6 analysis of BAY 708	09/Aug/2024	10:00	09/Aug/2024 15:00 /BAY Outage/

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuous	Reason	From		To		Remarks
104	551	PLANNED	OCC_581	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	1. Replacement of cable of BUS-1 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 3. Tan delta measurement of Bus CVT. 4. Nut Bolts and hardware tightening work.	09/Aug/2024	04:00	11/Aug/2024	18:00	/This circuits/bays which are connected to 400KV MainBUS-1 will be shifted on 400KV Main Bus-2 one by one via TBC-1 & TBC-2 /
105	552	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	Required for Main Bus -1 outage work.	09/Aug/2024	04:00	11/Aug/2024	18:00	/This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service./
106	553	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	Required for Main Bus -1 outage work.	09/Aug/2024	04:00	11/Aug/2024	18:00	/This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service./
107	554	PLANNED	OCC_581	MSLDC_OUTAGE	400KV/21KV CHANDRAPUR-GT-6	C	1. For dismantling of IPS tube of Bph PG-1 Isolator required for replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 2. Nut Bolts and hardware tightening work.	09/Aug/2024	04:00	11/Aug/2024	18:00	/GTR-6 will be in service via TBC-2/
108	555	PLANNED	OCC_581	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -1 outage work.	09/Aug/2024	04:00	11/Aug/2024	18:00	/Required for Main Bus -1 outage work./
109	556	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work	09/Aug/2024	04:00	11/Aug/2024	18:00	/HVDC CKT-2 will be in service./
110	559	PLANNED	OCC_581	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 2. Nut Bolts and hardware tightening work.	09/Aug/2024	13:00	11/Aug/2024	16:00	/ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work./
111	560	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 2. Nut Bolts and hardware tightening work.	09/Aug/2024	16:00	11/Aug/2024	19:00	OCC Remark-No power order restriction/ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work./
112	561	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	09/Aug/2024	08:00	14/Aug/2024	18:00	/PID Work. A/R Out/
113	569	PLANNED	OCC_581	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	10/Aug/2024	7:00	10/Aug/2024	18:00	
114	570	PLANNED	OCC_581	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	PRV NC contact modification and Line Reactor AMP works at 765kV Solapur Substation. Note: Dia to be kept open	10/Aug/2024	7:00	10/Aug/2024	18:00	
115	582	PLANNED	OCC_581	POWERGRID_WR1	400KV-KALA-KUDUS-1	D	AMP of 404L at MSETCL Kudos Substation. 400KV-KALA-KUDUS-2 A/R to be kept in Non-Auto mode.	10/Aug/2024	9:00	10/Aug/2024	17:00	
116	602	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	C	SSN to D5N insulator string Conversion work, and installation of fire wedge connector at mid-span joint	10/Aug/2024	22:00	11/Aug/2024	6:00	/SSN to D5N insulator string Conversion work, and installation of fire wedge connector at mid-span joint /
117	607	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	1) For the installation of saver assembly sets at TL no. 201 (Total 06 sets out of 24 sets are to be installed)	11/Aug/2024	08:00	11/Aug/2024	17:00	/Simultaneous outage is required on 220 KV Borivali-Boisar (PGCIL) & 220 kV Borivali-Tarapur due to multi circuit configuration./
118	608	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	1) For the installation of saver assembly sets at TL no. 201 (Total 06 sets out of 24 sets are to be installed) 2) 2) Also Disc Insulator broken replacement at Loc No. 107 Y-Ph PGCIL side & Loc No. 150 B-Ph.	11/Aug/2024	08:00	11/Aug/2024	17:00	/Simultaneous outage is required on 220 KV Borivali-Boisar (PGCIL) & 220 kV Borivali-Tarapur due to multi circuit configuration./
119	609	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	1) To attend defects identified in line patrolling. 2) Replacement of PID faulty Insulator strings. 3) Replacement of Insulator String under R&M Scheme.	11/Aug/2024	08:00	11/Aug/2024	18:00	OCC Remark-rescheduleWRLDC-At Padghe, Babheshwar line 1, Tarapur 3&4 line 2 and Kalwa line 1 planned simultaneously on 11 th August./400kV Babhaleshwar-Padghe Ckt-2 will be available./
120	610	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work, CT Tan Delta and quaterly bay maintenance	11/Aug/2024	08:00	11/Aug/2024	18:00	WRLDC-At Padghe, Babheshwar line 1, Tarapur 3&4 line 2 and Kalwa line 1 planned simultaneously on 11 th August./400kV Padghe II will be in service
121	622	PLANNED	OCC_581	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-2	D	AR Relay Retrofitting, A/R of ckt#1 to be kept on non auto mode. Dia to be kept open at both ends.	12/Aug/2024	7:00	12/Aug/2024	21:00	/PG-WR2- BOISAR/
122	624	PLANNED	OCC_581	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 at KOLHAPUR-MS - 400KV	D	Line Bay AMP and CT Oil sample collecting works at MSETCL.	12/Aug/2024	8:00	12/Aug/2024	18:00	/CT Oil sample collecting works at MSETCL/
123	647	PLANNED	OCC_581	MSLDC_OUTAGE	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2 at PARLI-M - 400KV	D	1) CT testing work. (2) Bay maintenance work.	12/Aug/2024	09:00	12/Aug/2024	18:00	/Both Bus Loads should be balanced/
124	650	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine maintenance work	12/Aug/2024	10:00	12/Aug/2024	14:00	WRLDC-To be clubbed with line outage./--/
125	651	PLANNED	OCC_581	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Sf6 analysis of BAY 709	12/Aug/2024	10:00	12/Aug/2024	15:00	/BAY Outage/
126	653	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Routine maintenance work	12/Aug/2024	10:00	12/Aug/2024	17:00	/Load will be managed on 400KV Kolhapur Line/
127	656	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Routine maintenance work	12/Aug/2024	14:00	12/Aug/2024	17:00	WRLDC-To be clubbed with line outage./--/

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
128	663	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintainance work	12/Aug/2024	08:00	13/Aug/2024	18:00	/NA/
129	671	PLANNED	OCC_581	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - AUXILIARY BUS 1	D	1. Tightning of spacers of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 2. Hardware tightning work of Aux Bus conductor in section of PGCIL-3 & 4 Ckt.	12/Aug/2024	08:00	14/Aug/2024	18:00	/400KV PGCIL CKT-1 & 2 will be in service. /
130	672	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work-400/220 KV ICT II HV will be in service through TBC	12/Aug/2024	08:00	14/Aug/2024	18:00	/400/220 KV ICT II HV will be in service through TBC /
131	692	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY (410) OF LONIKAND 2 CKT -1 @ KARJAT (Element not found on WRLDC Portal)	D	All Isolator Alignment work to be done by agency (410-89B, 411-89A, 410-89L). Diagnostic testing, Relay Testing and Maintenance work.	13/Aug/2024	8:00	13/Aug/2024	18:00	
132	693	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY (411) OF LONIKAND CKT 1 AND FUTURE BAY @ KARJAT (Element not found on WRLDC Portal)	D	All Isolator Alignment work to be done by agency (410-89B, 411-89A, 410-89L). Diagnostic testing, Relay Testing and Maintenance work.	13/Aug/2024	8:00	13/Aug/2024	18:00	
133	728	PLANNED	OCC_581	POWERGRID_WR1	220KV-SOLAPUR-KUMBARI-1	D	Line terminal equipments AMP at 765kV Solapur Substation	14/Aug/2024	8:00	14/Aug/2024	18:00	
134	729	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	14/Aug/2024	08:00	14/Aug/2024	18:00	/Outage /
135	730	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintainance work	14/Aug/2024	08:00	14/Aug/2024	18:00	/NA/
136	731	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY (413) OF LONIKAND II CKT -2 @ KARJAT (Element not found on WRLDC Portal)	D	All insulator alignment work to be done by AGENCY (413-89B, 414-89A, 413-89L) Diagnostic Testing, Relay testing and Maintenance work.	14/Aug/2024	8:00	14/Aug/2024	18:00	
137	732	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY (414) OF LONIKAND II CKT -2 AND FUTURE BAY @KARJAT (Element not found on WRLDC Portal)	D	All Isolator alignment work to be done by Agency (413-89B, 414-89A, 413-89L) Diagnostic Testing Relay testing and Maintenance work.	14/Aug/2024	8:00	14/Aug/2024	18:00	
138	736	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	14/Aug/2024	09:00	14/Aug/2024	17:00	/Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt /
139	737	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	14/Aug/2024	09:00	14/Aug/2024	17:30	
140	745	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHVAR-1	D	For routine maintenance work	14/Aug/2024	09:00	14/Aug/2024	18:00	/NA/
141	746	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	14/Aug/2024	09:00	14/Aug/2024	18:00	/The said work is very important /
142	747	PLANNED	OCC_581	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	14/Aug/2024	09:00	14/Aug/2024	18:00	/NA/
143	757	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint	15/Aug/2024	5:00	15/Aug/2024	13:00	/SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint. If required, 400/220 kV ICTs at Vikroli ss will be H/T from LV
144	758	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	15/Aug/2024	08:00	15/Aug/2024	18:00	/Outage/ /
145	759	PLANNED	OCC_581	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1. For Replacement of Flashover Disc. 2. Fixing of Turbo Wind Bird Guard. 3. Diagnostic testing of Line Bay at 132kv Dharni S/s'	15/Aug/2024	09:00	15/Aug/2024	17:00	/Outage /
146	760	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot line method, Shifting of auto reclose switch to non auto mode	15/Aug/2024	09:00	15/Aug/2024	17:00	/Hot Line Work. A/ R Out /
147	764	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	D	1. Tightning of spacers of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 2. Hardware tightning work of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 3. To excute the said work, outage is required on PGCIL- CKT-3.	15/Aug/2024	08:00	17/Aug/2024	18:00	/During outage 400KV CHD-2 CKT-1 & 2 400KV Khaperkheda, 400KV HVDC CKT-1 &2, 400KV PGCIL CKT-1,2, will be in service./
148	765	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	D	1. Tightning of spacers of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 2. Hardware tightning work of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 3. To excute the said work, outage is required on PGCIL- CKT-4.	15/Aug/2024	08:00	17/Aug/2024	18:00	/1. Tightning of spacers of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 2. Hardware tightning work of Aux Bus conductor in section of PGCIL-3 & 4 Ckt. 3. To excute the said work, outage is required on PGCIL- CKT-4/ /
149	766	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	C	For retrofitting work of 400 KV Main-1 Distance Relay	15/Aug/2024	08:00	17/Aug/2024	18:00	/No load affected as other grid lines will be in service./
150	767	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work-400 KV Aurangabad will be in service through TBC	15/Aug/2024	09:00	18/Aug/2024	18:00	/400 KV Aurangabad will be in service through TBC /
151	773	PLANNED	OCC_581	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	D	For OPGW stringing under live line condition	16/Aug/2024	7:00	31/Aug/2024	18:00	/PG-WR2-RHQ-II/ /
152	774	PLANNED	OCC_581	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	D	For OPGW stringing under live line condition	16/Aug/2024	7:00	31/Aug/2024	18:00	/PG-WR2-RHQ-II/ /

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
153	775	PLANNED	OCC_581	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	16/Aug/2024	7:00	31/Aug/2024	18:00	
154	776	PLANNED	OCC_581	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	16/Aug/2024	7:00	31/Aug/2024	18:00	
155	795	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	16/Aug/2024	08:00	16/Aug/2024	18:00	/NA/
156	799	PLANNED	OCC_581	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP of 401L at MSETCL Kudus Substation. 400KV-KALA- KUDUS-1 A/R to be kept in Non-Auto mode.	16/Aug/2024	9:00	16/Aug/2024	17:00	
157	801	PLANNED	OCC_581	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	AMP of Bay	16/Aug/2024	9:00	16/Aug/2024	17:30	/PG-WR2- BOISAR/
158	815	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV at TA	D	CB diagnostic work and routine maintenance work	16/Aug/2024	11:00	16/Aug/2024	18:00	/Outage required for routine work/
159	822	PLANNED	OCC_581	POWERGRID_WR2	MAGARWADA - 400KV - BUS 2	C	Interconnection of busbar for bay extension works	16/Aug/2024	7:00	18/Aug/2024	18:00	/PG-WR2-MAGARWADA/
160	823	PLANNED	OCC_581	POWERGRID_WR2	400KV/220KV MAGARWADA-ICT-2	C	Interconnection of busbar for bay extension works	16/Aug/2024	7:00	18/Aug/2024	18:00	OCC Remark-DD DNH consent is required./PG-WR2- MAGARWADA/
161	825	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	16/Aug/2024	08:00	21/Aug/2024	18:00	/PID Work. A/R Out/
162	853	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY (404) OF PARLI CKT -1 @ KARJAT(Element not found WRLDC Portal)	D	All Isolator Alignment work to be done by agency (404-89B, 405- 89A, 404-89L). Diagnostic testing, Relay Testing and Maintenance work.	17/Aug/2024	9:00	17/Aug/2024	18:00	
163	854	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY (405) OF PARLI CKT -1 AND ICT -2 @ KARJAT (Element not found on WRLDC Portal)	D	All Isolator Alignment work to be done by agency (404-89B, 405- 89A, 404-89L). Diagnostic testing, Relay Testing and Maintenance work.	17/Aug/2024	9:00	17/Aug/2024	18:00	
164	857	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12)	17/Aug/2024	22:00	18/Aug/2024	16:00	/1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.
165	863	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	1) For Line Maintenance Work. 2) Maintenance Work.	18/Aug/2024	5:00	18/Aug/2024	14:00	/1) For Line Maintenance Work. 2) Maintenance Work./
166	864	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	18/Aug/2024	09:00	18/Aug/2024	17:00	/Line will be charged through Tie CB 428./
167	865	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY (407) OF PARLI (M) CKT-2 @ KARJAT (Element not found on WRLDC Portal)	D	All Isolator Alignment work to be done by agency (407-89B, 408- 89A, 407-89L). Diagnostic testing, Relay Testing and Maintenance work.	18/Aug/2024	9:00	18/Aug/2024	18:00	
168	866	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY (408) OF PARLI (M) CKT -2 AND FUTURE BAY @KARJAT (Element not found on WRLDC Portal)	D	All isolator Alignment work to be done by Agency (407-89B, 408- 89A, 407-89L) Diagnostic Testing Relay Testing and Maintenance work	18/Aug/2024	9:00	18/Aug/2024	18:00	
169	881	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Routine maintenance work	19/Aug/2024	8:00	19/Aug/2024	17:00	/Load will be managed on 400KV Solapur line/
170	889	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Diagnostic testing work .	19/Aug/2024	9:00	19/Aug/2024	17:00	/400KV WARORA-IEPL Line is in ckt /
171	890	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	19/Aug/2024	09:00	19/Aug/2024	17:00	/400KV KORADI-WARDHA Line will be charged through Tie CB 414./
172	891	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Line CT,CVT Tan delta ,IR values & Routine maintenance and isolator maintenance work .	19/Aug/2024	09:00	19/Aug/2024	17:00	/Both Main & Tie Bay is in OFF condition./
173	892	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	19/Aug/2024	09:00	19/Aug/2024	17:00	/Line will be charged through Main CB 429./
174	901	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	19/Aug/2024	09:00	19/Aug/2024	18:00	NLDC-Subjected to SRPC Approval/The said work is very important /
175	902	PLANNED	OCC_581	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	19/Aug/2024	09:00	19/Aug/2024	18:00	NLDC-Duplicate entry/The said work is very important/
176	906	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine maintenance work	19/Aug/2024	10:00	19/Aug/2024	14:00	WRLDC-To be clubbed with line outage./-/-/
177	908	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Routine maintenance work	19/Aug/2024	14:00	19/Aug/2024	17:00	WRLDC-To be clubbed with line outage./-/-/
178	921	PLANNED	OCC_581	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)- AURANGABAD-2	D	For AMP	20/Aug/2024	7:00	20/Aug/2024	18:00	/409L/
179	926	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	CB CRM/DCRM Timing	20/Aug/2024	08:00	20/Aug/2024	18:00	/400 KV Ektuni II will be in service through TBC /
180	928	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	D	AMP of Bay Equipment	20/Aug/2024	9:00	20/Aug/2024	17:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuou us	Reason	From		To		Remarks
181	946	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Routine Diagnostic Testing and Maintenance Works	20/Aug/2024	10:00	20/Aug/2024	18:00	/1500MVA 765kv/400KV ICT will be in service via 765kV Tie bay and 765kV Main Bus 1/
182	968	PLANNED	OCC_581	POWERGRID_WRI	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	21/Aug/2024	8:00	21/Aug/2024	13:00	/Work @ Wardha SS/
183	972	PLANNED	OCC_581	POWERGRID_WRI	220KV-SOLAPUR-NARANGWADI-1	D	Line terminal equipments AMP at 765kV Solapur Substation	21/Aug/2024	8:00	21/Aug/2024	18:00	
184	976	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	21/Aug/2024	08:00	21/Aug/2024	18:00	/Outage/
185	977	PLANNED	OCC_581	POWERGRID_WRI	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element. Each Feeder will be shifted on TBC one at time	21/Aug/2024	8:00	21/Aug/2024	20:00	/Work @ Wardha SS/
186	978	PLANNED	OCC_581	POWERGRID_WRI	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element.	21/Aug/2024	8:00	21/Aug/2024	20:00	/Work @ Wardha SS/
187	986	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	21/Aug/2024	09:00	21/Aug/2024	17:30	
188	994	PLANNED	OCC_581	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	For routine maintenance work	21/Aug/2024	09:00	21/Aug/2024	18:00	/NA/
189	995	PLANNED	OCC_581	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of CB at Koradi-III SS.	21/Aug/2024	9:00	21/Aug/2024	18:00	/Bay Outage/
190	998	PLANNED	OCC_581	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 2. Nut Bolts and hardware tightening work.	21/Aug/2024	13:00	21/Aug/2024	16:00	/ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work./
191	999	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	D	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 2. Nut Bolts and hardware tightening work.	21/Aug/2024	16:00	21/Aug/2024	19:00	OCC Remark-No power order restriction/ to be rescheduled / BUS 2WRLDC-Contingency plan. Will be rescheduled to Weekends/ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work./
192	1001	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	C	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	21/Aug/2024	09:00	22/Aug/2024	18:00	
193	1002	PLANNED	OCC_581	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	C	1. Replacement of cable of BUS-1 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadraple Bus conductor in span Required for Main Bus -2 outage work.	21/Aug/2024	04:00	23/Aug/2024	18:00	/ "This circuits/bays which are connected to 400KV Main Bus-2 will be shifted on 400KV Main Bus-1 one by one via TBC-1 & TBC-2/
194	1003	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-1	C	Required for Main Bus -2 outage work.	21/Aug/2024	04:00	23/Aug/2024	18:00	/This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service./
195	1004	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-2	C	Required for Main Bus -2 outage work.	21/Aug/2024	04:00	23/Aug/2024	18:00	/This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service./
196	1005	PLANNED	OCC_581	MSLDC_OUTAGE	400KV/21KV CHANDRAPUR-GT-6	C	1. For replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 2. GTR-6 will be in service via TBC-2	21/Aug/2024	04:00	23/Aug/2024	18:00	/GTR-6 will be in service via TBC-2/
197	1006	PLANNED	OCC_581	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -2 outage work.	21/Aug/2024	04:00	23/Aug/2024	18:00	/Required for Main Bus -2 outage work. /
198	1007	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work.	21/Aug/2024	04:00	23/Aug/2024	18:00	OCC Remark-Timings to revise. No power order restrictionWRLDC-Contingency plan. Will be rescheduled to Weekends/HVDC CKT-2 will be in service./
199	1019	PLANNED	OCC_581	POWERGRID_WRI	MAIN BAY OF 765KV-PUNE-GIS-AURANGABAD-1 AND AURANGABAD - 765KV - BUS 1 @AURANGABAD - 765KV at AURANGABAD - 765KV	D	For AMP	22/Aug/2024	7:00	22/Aug/2024	18:00	/710/
200	1021	PLANNED	OCC_581	POWERGRID_WRI	400KV-PARLI NEW-PARLI-M-1	D	For CT Oil Sample AND AMP	22/Aug/2024	7:00	22/Aug/2024	18:00	
201	1022	PLANNED	OCC_581	POWERGRID_WRI	220KV-SOLAPUR-JEUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	22/Aug/2024	7:00	22/Aug/2024	18:00	
202	1027	PLANNED	OCC_581	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-1 by Hot Line Method	22/Aug/2024	08:00	22/Aug/2024	13:00	/ONLINE Work will be done online through Hotline method/
203	1031	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	22/Aug/2024	08:00	22/Aug/2024	18:00	/Outage/
204	1036	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at 220kv Badnera S/s"	22/Aug/2024	09:00	22/Aug/2024	17:00	/Outage/
205	1038	PLANNED	OCC_581	POWERGRID_WRI	PUNE-PG - 220KV - BUS#1	D	For Hotspot rectification	22/Aug/2024	9:00	22/Aug/2024	17:30	/Each bay will be taken on TBC bay/
206	1049	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) CT testing, (2) Bay maintenance work. (3)B Ph String replacement at location No 18	22/Aug/2024	09:00	22/Aug/2024	18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
207	1051	PLANNED	OCC_581	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of Hanger rod assembly on 400 kV Main Bus-II in Reactor-II Bay by Hot Line Method	22/Aug/2024	13:00	22/Aug/2024	18:00	/ONLINE Work will be done online through Hotline method/
208	1064	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	D	For AMP	23/Aug/2024	7:00	23/Aug/2024	18:00	/401/
209	1065	PLANNED	OCC_581	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-BOISAR-1 AND 765KV/400KV AURANGABAD-ICT-1 at AURANGABAD - 400KV	D	For AMP	23/Aug/2024	7:00	23/Aug/2024	18:00	/429/
210	1067	PLANNED	OCC_581	POWERGRID_WR1	PARLI - 220KV - BUS 2	D	For AMP	23/Aug/2024	7:00	23/Aug/2024	18:00	
211	1086	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 220KV-PUNE-PG-URSE-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	AMP Work	23/Aug/2024	9:00	23/Aug/2024	17:30	/Future Bay/
212	1096	PLANNED	OCC_581	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of CB at Koradi-III SS.	23/Aug/2024	9:00	23/Aug/2024	18:00	/Bay Outage/
213	1098	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	Routine Maintenance & Diagnostic Testing Works	23/Aug/2024	10:00	23/Aug/2024	18:00	OCC Remark-Ict loading reducesWRLDC-Required with line outage ?/Outage on 400KV ThaptiTanda-2 (Line Bay & Tie Bay) along with 400KV Main Bus-2/
214	1099	PLANNED	OCC_581	MSLDC_OUTAGE	EKTUNI - 400KV - BUS 2	D	Routine Maintenance & Diagnostic Testing Works	23/Aug/2024	10:00	23/Aug/2024	18:00	OCC Remark-N-1 compliance to be checkedWRLDC-Required with line outage ?/Outage on 400KV Main Bus-2 along with 400KV ThaptiTanda-2 (Line Bay & Tie Bay)/
215	1103	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-JEJURI-KARAD-1	C	For replacement of Main-1 & Main-2 relay Panels.	23/Aug/2024	0:01	25/Aug/2024	22:00	/Other Grid lines will be in service. LONG DURATION OUTAGE. SUBJECT TO REAL TIME LOADING CONDITIONS/
216	1106	PLANNED	OCC_581	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Routine Maintenance & Diagnostic Testing Works	24/Aug/2024	09:00	24/Aug/2024	18:00	OCC Remark-on Sunday / subject to loadingsWRLDC-High loading on ICTs. N-1 non compliantNLD-Subjected to consent of maharashtra./ICT-1 Units - Routine Maintenance &
217	1123	PLANNED	OCC_581	POWERGRID_WR1	400KV-WARORA-PG-WARORA (MSETCL)-1	D	For 400KV Warora (MSETCL) #1 Line Equipments AMP Work. 400KV-WARDHA-WARORA -PG-1 AR OFF	24/Aug/2024	9:00	24/Aug/2024	18:00	/400KV-WARDHA-WARORA -PG-1 AR OFF/
218	1125	PLANNED	OCC_581	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 1	D	1)REPLACEMENT OF DAMAGED ARM OF BUS CONNETED ISOLATOR 411-89A	24/Aug/2024	10:00	24/Aug/2024	17:30	/All feeders wil remain in service through 400kV Main Bus-II/
219	1128	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV - BUS 1B at Wardha - 400KV	C	For Replacement of DAC by M/s CGL.	24/Aug/2024	8:00	27/Aug/2024	18:00	/Work @ Wardha SS/
220	1130	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during 220kV PGCIL - Borivali Line Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph.	25/Aug/2024	09:00	25/Aug/2024	17:00	/Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during 220kV PGCIL - Borivali Line Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph./
221	1131	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph.	25/Aug/2024	09:00	25/Aug/2024	17:00	/Simultaneously outage is required on 220kV Tarapur - Borivali Line (for safety purpose)/
222	1142	PLANNED	OCC_581	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element. AR TO BE KETP IN NON AUTO MODE OF CKT#2	26/Aug/2024	8:00	26/Aug/2024	13:00	WRLDC-Simultaneously planned with Akola 2 line/Work @ Wardha SS/
223	1145	PLANNED	OCC_581	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element. AR TO BE KETP IN NON AUTO MODE OF CKT#1	26/Aug/2024	13:30	26/Aug/2024	20:00	WRLDC-Simultaneously planned with Akola 1 line/Work @ Wardha SS/
224	1146	PLANNED	OCC_581	POWERGRID_WR1	AKOLA - 400KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	26/Aug/2024	8:00	26/Aug/2024	20:00	/Work @ Wardha SS/
225	1148	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	26/Aug/2024	09:00	26/Aug/2024	18:00	NLDC-Subjected to SRPC Approval/The said work is very important /
226	1149	PLANNED	OCC_581	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	26/Aug/2024	09:00	26/Aug/2024	18:00	NLDC-Duplicate entry/The said work is very important/
227	1150	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	D	Diagnostic Testing of Circuit Breaker	26/Aug/2024	10:00	26/Aug/2024	17:30	/400kV Koradi-II -Koradi-III Ckt-I will remain in service through Tie Bay 408/
228	1179	PLANNED	OCC_581	APTCL	400KV-AKOLA-AKOLA (2)-1	D	Diagnostic testing and routine bay maintenance work	27/Aug/2024	09:00	27/Aug/2024	17:00	/Outage required foe above work/
229	1204	PLANNED	OCC_581	POWERGRID_WR1	AURANGABAD - 220KV - BUS 1	D	For AMP	28/Aug/2024	7:00	28/Aug/2024	18:00	/220kV BUS_1 (All bay shifted on TBCB before outage of equipment/line bay one by one for 89A isolator maintenance of each bay./
230	1211	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	28/Aug/2024	08:00	28/Aug/2024	18:00	/Outage/
231	1213	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND WARDHA - 400KV - BUS 1B at Wardha - 400KV	D	For AMP of Bay	28/Aug/2024	8:00	28/Aug/2024	20:00	/Work @ Wardha SS/
232	1214	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	D	For AMP of Bay	28/Aug/2024	8:00	28/Aug/2024	20:00	/Work @ Wardha SS/
233	1221	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	28/Aug/2024	09:00	28/Aug/2024	17:30	
234	1233	PLANNED	OCC_581	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Routine Maintenance & Diagnostic Testing Works	28/Aug/2024	09:00	28/Aug/2024	18:00	OCC Remark-N-1 compliance to be checkedWRLDC-High loading on ICTs. N-1 non compliantNLD-Subjected to consent of maharashtra./ICT-2 Units - Routine Maintenance &
235	1234	PLANNED	OCC_581	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND FUTURE at KORADI-III - 400KV	D	Annual Maintenance of CB at Koradi-III SS.	28/Aug/2024	9:00	28/Aug/2024	18:00	/Bay Outage/

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuous	Reason	From		To		Remarks
236	1237	PLANNED	OCC_581	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT	28/Aug/2024	10:00	28/Aug/2024	17:30	/All feeders will remain in service through 400KV Main Bus-1/
237	1255	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY OF 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR-MS - 400KV - BUS 2 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS -	D	Main Bay AMP work	29/Aug/2024	8:00	29/Aug/2024	18:00	/Outage required on CB only. Line can be kept in service through TBC./
238	1258	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	29/Aug/2024	08:00	29/Aug/2024	18:00	/Outage/
239	1263	PLANNED	OCC_581	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	*1. For Replacement of Flashover Disc. 2. Fixing of Turbo Wind Bird Guard. 3. Diagnostic testing of Line Bay at 132kv Dharni S/s*	29/Aug/2024	09:00	29/Aug/2024	17:00	/Outage /
240	1271	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) CT & CVT testing. (2) Bay maintenance work. (3) Hardware tightening & fitting work	29/Aug/2024	09:00	29/Aug/2024	18:00	
241	1274	PLANNED	OCC_581	MSLDC_OUTAGE	TIE BAY - 765KV-AKOLA (2)-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	D	ROUTINE DIAGNOSTIC TESTING AND MAINTENENCE WORKS	29/Aug/2024	10:00	29/Aug/2024	18:00	/765kv Akola Circuit 2 will be in service via 765kv Main bus 2/
242	1277	PLANNED	OCC_581	POWERGRID_WR1	DHULE-MS - 400KV B/R 2	D	For old CT replacement work	29/Aug/2024	7:00	30/Aug/2024	18:00	
243	1278	PLANNED	OCC_581	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-2	C	LR CB Drive Mechanism Inspection by OEM (M/s ABB) at 765kv Solapur Substation. PRV NC contact modification	29/Aug/2024	7:00	30/Aug/2024	18:00	NLDC-LR CB shutdown shall be clubbed with Line AMP/Outage work/ /
244	1279	PLANNED	OCC_581	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-2 L/R@ SOLAPUR - 765KV	C	LR CB Drive Mechanism Inspection by OEM (M/s ABB) at 765kv Solapur Substation. PRV NC contact modification	29/Aug/2024	7:00	30/Aug/2024	18:00	NLDC-LR CB shutdown shall be clubbed with Line AMP/Outage work/ /
245	1283	PLANNED	OCC_581	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	D	Main Bus -2 HV TEST	29/Aug/2024	7:00	29/Aug/2024	18:00	MH-Kindly Schedule on Sunday TOTAL LOADING ON PUNE GIS to PUNE PG ckt to be below 2800 MW
246	1284	PLANNED	OCC_581	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	CB pole overhauling work,400 KV Padghe I will be in service through TBC	29/Aug/2024	08:00	01/Sep/2024	18:00	/400 KV Padghe I will be in service through TBC/
247	1285	PLANNED	OCC_581	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 2	C	For Replacement of 400kv Y phase BUS Span of 400kv TBC & BC and Routine Maintenance, Bus coupler Relay replacement Work	30/Aug/2024	07:00	31/Aug/2024	19:00	OCC Remark-contingency plan to be submitted / / All the B Bus elements i.e 400kv Kalwa, 400kv Vikhroli-2 and ICT-1 will be shifted on A bus via TBC /
248	1286	PLANNED	OCC_581	MSLDC_OUTAGE	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	C	For Replacement of 400kv Y phase BUS Span of 400kv TBC & BC and Routine Maintenance, Bus coupler Relay replacement Work	30/Aug/2024	07:00	31/Aug/2024	19:00	/All the B Bus elements i.e 400kv Kalwa, 400kv Vikhroli-2 and ICT-1 will be shifted on A bus via TBC /
249	1287	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work,Distance Relay ,CT Tan D,and quarterly bay maintenance	30/Aug/2024	14:00	30/Aug/2024	23:00	OCC Remark-Reschedule as per commentMH-kindly schedule on 30.08.2024 from 14:00 to 23:00 hrs/400kv Padghe I will be in service
250	1288	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1) To attend defects identified in line patrolling. 2) Replacement of PID faulty Insulator strings. 3) Replacement of Insulator String under R&M Scheme.	30/Aug/2024	14:00	30/Aug/2024	23:00	MH-kindly schedule on 30.08.2024 from 14:00 to 23:00 hrs/400kv Babhaleshwar-Padghe Ckt-1 will be available. /
251	1289	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	Maintaining clearance with the help of JCB work in the span between loc no 52-53. Half yearly maintainance.	30/Aug/2024	5:00	30/Aug/2024	13:00	
252	1292	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-2 AND PARLI-M - 400KV - BUS 1 at PARLI-M - 400KV	D	For AMP	30/Aug/2024	7:00	30/Aug/2024	18:00	
253	1295	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1) To attend defects identified in line patrolling. 2) Replacement of PID faulty Insulator strings. 3) Replacement of Insulator String under R&M Scheme.	30/Aug/2024	08:00	30/Aug/2024	18:00	/400kv Babhaleshwar-Padghe Ckt-1 will be available. /
254	1297	PLANNED	OCC_581	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	For Amp of Line Bay	30/Aug/2024	8:00	30/Aug/2024	20:00	/Work @ Wardha SS/
255	1298	PLANNED	OCC_581	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-1 by Hot Line Method	30/Aug/2024	09:00	30/Aug/2024	12:00	OCC Remark-online work/Work will be done online through Hotline method /
256	1301	PLANNED	OCC_581	APTCL	400KV-AKOLA-AKOLA (2)-2	D	For diagnostic work and routine bay maintenance work	30/Aug/2024	09:00	30/Aug/2024	17:00	/Outage required for above work/
257	1308	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	1) Bay Maint work 2) Diagnostic Testing work 3) replacement of old CT & CVT MK box	30/Aug/2024	09:00	30/Aug/2024	20:00	/1) weather condition should be clear /
258	1311	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KORADI-II-KORADI-III-2	D	Diagnostic Testing of Line CT	30/Aug/2024	10:00	30/Aug/2024	17:30	/400kv Koradi-II -Koradi-III Ckt-I will be service as alternate source/
259	1313	PLANNED	OCC_581	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-II by Hot Line Method	30/Aug/2024	13:00	30/Aug/2024	16:00	/Work will be done online through Hotline method /
260	1315	PLANNED	OCC_581	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	30/Aug/2024	08:00	31/Aug/2024	18:00	/PID Work. A/R Out/
261	1316	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	C	For retrofitting of Mian-1 Distance relay at karad end.	30/Aug/2024	08:00	01/Sep/2024	17:00	/No Load affected as other grid lines will be in service.LONG DURATION OUTAGE/
262	1321	PLANNED	OCC_581	POWERGRID_WR1	MAIN BAY OF 220KV-SOLAPUR-BALE-1 AND SOLAPUR - 220KV - BUS 1 @SOLAPUR - 220KV at Solapur - 220KV	D	Bay AMP Works Note : 220kv Bale line shall be in service via TBC.	31/Aug/2024	8:00	31/Aug/2024	18:00	
263	1329	PLANNED	OCC_581	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For AMP work @ Pune765_GIS ON NON SWITCHABLE LINE REACTOR AND LINE BAY	31/Aug/2024	9:00	31/Aug/2024	18:00	/For AMP work @ Pune765/
264	1333	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1) Bay Maint work 2) Diagnostic Testing work 3) Rph Wave Trap replacement work	31/Aug/2024	22:00	01/Sep/2024	7:00	/weather condition should be clear. /

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element OCC_571	Daily / Continuo us	Reason	From		To		Remarks
265	1334	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Maintaining clearance with the help of JCB work in the span between loc no 55-56. Half yearly maintainance.	31/Aug/2024	5:00	31/Aug/2024	13:00	OCC Remark-on Sunday/ subject to loadings/-/
266	1335	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work	31/Aug/2024	5:00	31/Aug/2024	13:00	/SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work/

Maharashtra State Load Despatch Centre

Monthly Outage list Not Considered in WRLDC OCCM for the Month of AUGUST'2024

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
1	33	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Overhead crossing/stringing of Padghe (PG)-Kharghar 400kV D/C(Quad) line, stretch no. 27/0-28/0. By Hot Line Method. (Crossing loc no-142-143 of 400KV Kharghar-Talegaon D/C line) by MUMUL.	02/Aug/2024	09:00	10/Aug/2024	18:00	WRLDC-Availied in July, Work progress to be informed.MH- Work will be completed in July month itself/Overhead crossing/stringing of Padghe (PG)-Kharghar 400kV D/C(Quad) line, stretch no. 27/0-28/0. By Hot Line Method. (Crossing loc no-142-143 of 400KV Kharghar-Talegaon D/C line) by MUMUL.
2	34	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Overhead crossing/stringing of Padghe (PG)-Kharghar 400kV D/C(Quad) line, stretch no. 27/0-28/0. By Hot Line Method. (Crossing loc no-143-1 of 400KV Kalwa-Kharghar D/C line) by MUMUL.	02/Aug/2024	09:00	10/Aug/2024	18:00	WRLDC-Availied in July, Work progress to be informed.MH- Work will be completed in July month itself/Overhead crossing/stringing of Padghe (PG)-Kharghar 400kV D/C(Quad) line, stretch no. 27/0-28/0. By Hot Line Method. (Crossing loc no-143-1 of 400KV Kalwa-Kharghar D/C line) by MUMUL.
3	35	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	Overhead crossing/stringing of Padghe (PG)-Kharghar 400kV D/C(Quad) line Stretch 27/0-28/0. By Hot Line Method. (Crossing loc no-142-143 of 400KV Kalwa-Talegaon D/C line) by MUMUL.	02/Aug/2024	09:00	10/Aug/2024	18:00	WRLDC-Availied in July, Work progress to be informed.MH- Work will be completed in July month itself/Overhead crossing/stringing of Padghe (PG)-Kharghar 400kV D/C(Quad) line Stretch 27/0-28/0. By Hot Line Method. (Crossing loc no-142-143 of 400KV Kalwa-Talegaon D/C line) by MUMUL.
4	39	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	C	For replacement of Main- 1 & Main-2 relay Panels.	05/Aug/2024	08:00	15/Aug/2024	18:00	OCC Remark-at karad end WRLDC-Which session of line/Other 400Kv Grid lines will be in service./
5	46	PLANNED	OCC_581	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	For replacement of balance existing conductor by HTLS conductor.	01/Aug/2024	08:00	31/Aug/2024	22:00	OCC Remark-20 days.WRLDC-Contingency plan to be provided by MSLDC. No other outages at Kalwa, Padghe, Pune etc. /For replacement of balance existing conductor by HTLS

State Element outage list for the month of AUGUST '2024

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	01-Aug-24	10:00	01-Aug-24	18:00	Daily	Routine Testing & Maintenance Work	MSETCL	MSETCL	-
2	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	01-Aug-24	09:00	31-Aug-24	18:00	Daily	PID AR in Non-auto mode	MSETCL	MSETCL	
3	400 KV	BUS REACTOR (125MVAr) @ WARORA	02-Aug-24	09:00	02-Aug-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Reactor kept in OFF position., Tie Bay No. 403 also kept in OFF position.
4	400 KV	MAIN BAY (403) of WALUJ @ TAPTITANDA	02-Aug-24	11:00	02-Aug-24	18:00	Daily	CB diagnostic work	MSETCL	MSETCL	Outage required for CB diagnostic work
5	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	02-Aug-24	10:00	03-Aug-24	18:00	Daily	Line maintenance activity	MSETCL	MSETCL	to avoid tripping
6	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	03-Aug-24	08:00	03-Aug-24	18:00	Daily	For Relay replacement and Routine Maintenance Work	MSETCL	MSETCL	For Relay replacement and Routine Maintenance Work
7	400 KV	AKOLA - KHADKA (BHUSAWAL)	03-Aug-24	09:00	03-Aug-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per outage plan.
8	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	03-Aug-24	10:00	03-Aug-24	18:00	Daily	Line maintenace activity	MSETCL	MSETCL	to avoid tripping
9	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	03-Aug-24	10:00	03-Aug-24	18:00	Daily	1) Main-1 distance relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	to avoid tripping
10	400 KV	Main bay (406) of Deepnagar line @ Taptitanda	05-Aug-24	11:00	05-Aug-24	18:00	Daily	CB Diagnostic work and routine maintenance work.	MSETCL	MSETCL	Outage required for routine activities.
11	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	05-Aug-24	08:00	05-Aug-24	17:00	Daily	Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
12	400 KV	WARORA - IEPL	05-Aug-24	09:00	05-Aug-24	17:00	Daily	Line CT,CVT Tan delta ,IR values & Routine maintenance and and isolater maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
13	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	05-Aug-24	08:00	05-Aug-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT. HV CB DCRM ,Timing and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
14	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	05-Aug-24	08:00	05-Aug-24	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -III.	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-III.
15	400 KV	CHANDRAPUR-PARLI CKT-3	5-Aug-24	9:00	5-Aug-24	18:00	Daily	Loc.no.610 Earth bond broken loc.no.511,512 earth wire stringing work	MSETCL	MSETCL	-
16	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	06-Aug-24	09:00	06-Aug-24	18:00	Daily	1) C & tan delta measurement of ICT Units..2) Bay Maintenance work.	MSETCL	MSETCL	.
17	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	06-Aug-24	08:00	06-Aug-24	18:00	Daily	For Relay replacement work and R&M work.	MSETCL	MSETCL	ICT2,3 are in service & also VIKHROLI ICT will be in service
18	400 KV	400/220 KV SPARE 167 MVA ICT @ ALKUD	06-Aug-24	10:00	06-Aug-24	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	--
19	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	06-Aug-24	10:00	06-Aug-24	18:00	Daily	line maintenance activity	MSETCL	MSETCL	to avoid tripping

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	400/220KV 500MVA ICT 3 @ AKOLA	06-Aug-24	09:00	06-Aug-24	17:00	Daily	For diagnostic work by testing team and routine bay maintenance work	MSETCL	MSETCL	Outage required for above work
21	400 KV	400/220 KV 500 MVA ICT @ ALKUD	06-Aug-24	10:00	06-Aug-24	17:00	Daily	Load will be managed on 400KV Karad & Talandge S/S	MSETCL	MSETCL	Routine Maintenance work
22	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	06-Aug-24	10:00	06-Aug-24	14:00	Daily	Diagnostic Testing & Routine Maintenance work	MSETCL	MSETCL	--
23	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	07-Aug-24	08:00	07-Aug-24	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-III
24	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	07-Aug-24	08:00	07-Aug-24	18:00	Daily	For restoration ICT -III from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
25	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	08-Aug-24	09:00	08-Aug-24	18:00	Daily	Disc Repalcement work loc.no.432,455	MSETCL	MSETCL	-
26	400 KV	LONIKAND - JEJURI CKT - 1	08-Aug-24	08:00	08-Aug-24	18:00	Daily	DT, Bay and Line Maintenance activities @ Lonikand I & Relay Retrofitting work by G.E @ Jejuri	MSETCL	MSETCL	-
27	400 KV	TBC @ CHAKAN	08-Aug-24	10:00	08-Aug-24	18:00	Daily	Routine maintenance and DT.	MSETCL	MSETCL	-
28	400 KV	BUS REACTOR (125 MVar) @ ALKUD	08-Aug-24	10:00	08-Aug-24	18:00	Daily	Routine maintenance work	MSETCL	MSETCL	--
29	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	08-Aug-24	10:00	08-Aug-24	14:00	Daily	Routine maintenance work	MSETCL	MSETCL	--
30	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	08-Aug-24	14:00	08-Aug-24	18:00	Daily	Routine maintenance work	MSETCL	MSETCL	--
31	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	08-Aug-24	10:00	08-Aug-24	18:00	Daily	Routine maintenance and DT.	MSETCL	MSETCL	-
32	400 KV	WARORA - IEPL	09-Aug-24	09:00	09-Aug-24	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL. Line is in ckt
33	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	09-Aug-24	09:00	09-Aug-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
34	400 KV	NEW KOYNA-KARAD CKT - 1	09-Aug-24	08:00	09-Aug-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
35	400 KV	400KV 125 MVAR BUS REACTOR @ AKOLA	09-Aug-24	09:00	09-Aug-24	17:00	Daily	For diagnostic testing by testing team and routine maintenance work	MSETCL	MSETCL	Outage required for above work
36	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	10-Aug-24	09:00	10-Aug-24	18:00	Daily	Nut bolt hardware tightning work	MSETCL	MSETCL	-
37	400 KV	KORADI - KHADKA	10-Aug-24	09:00	10-Aug-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per outage plan
38	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	10-Aug-24	09:00	10-Aug-24	18:00	Daily	1) Main-1 distance relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
39	400 KV	NEW KOYNA - STAGE IV CKT - 1	11-Aug-24	08:00	11-Aug-24	17:00	Daily	Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
40	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	12-Aug-24	10:00	12-Aug-24	17:00	Daily	line maintenance activity	MSETCL	MSETCL	to avoid tripping

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	FUTURE CKT - 1 @ WARORA	12-Aug-24	09:00	12-Aug-24	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
42	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	12-Aug-24	08:00	12-Aug-24	17:00	Daily	Relay testing work ,maint. Work Routine	MSETCL	MSETCL	----
43	400 KV	400 KV FUTURE BAY II @ WARORA	13-Aug-24	09:00	13-Aug-24	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
44	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	13-Aug-24	08:00	13-Aug-24	18:00	Daily	SFRA,Bay maintenance Work	MSETCL	MSETCL	315 MVA ICT-II and 501 MVA ICT III, IV & V will be in service
45	400 KV	KORADI-NANDGAONPETH (RPL)	13-Aug-24	09:30	13-Aug-24	16:00	Daily	DFRA TESTING OF REACTOR	MSETCL	MSETCL	NA
46	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	15-Aug-24	10:00	15-Aug-24	18:00	Daily	Routine Testing & Maintenance Work	MSETCL	MSETCL	-
47	400 KV	LONIKAND I - KOYNA STAGE-IV	15-Aug-24	08:00	15-Aug-24	17:00	Daily	R&M Scheme work Replacement of disc insulator by PLRI at differnt locations & Cold line washing work.	MSETCL	MSETCL	R&M Scheme work Replacement of disc insulator by PLRI at differnt locations & Cold line washing work.
48	400 KV	CHANDRAPUR-PARLI CKT-3	15-Aug-24	08:00	31-Aug-24	18:00	Daily	1.Measurement of tandelta of Bushing of 50MVAR Line shunt Reactor.	MSETCL	MSETCL	During outage 400KV CHD-2 CKT-1 & 2 400KV Khaperkheda, 400KV HVDC CKT-1 & 2 400KV PGCIL CKT-1 2 3&4 will be in
49	400 KV	JAIGAD - NEW KOYNA CKT - 2	16-Aug-24	08:00	16-Aug-24	17:00	Daily	2.Premonsoon maintenance work of Reactor Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
50	400 KV	KHADKA - BABLESHWAR	16-Aug-24	08:00	16-Aug-24	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kv C'Sambhaji nagar ,400kv Dhule ckt I&II, Ektuni I&II will be in service
51	400 KV	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	16-Aug-24	08:00	16-Aug-24	23:00	Daily	1) Oil Top in Yph unit due to Radiator leakage	MSETCL	MSETCL	weather condition should be clear . Will be allowed in Low Demand time slot, Subject to Padaha ICT loading conditions below 1300
52	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	17-Aug-24	09:00	18-Aug-24	18:00	Continuous	2) Hot Spot attending work if 1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
53	400 KV	KHADKA- DEEPNAGAR CKT 2	17-Aug-24	09:00	17-Aug-24	15:00	Daily	Routine bay maintenance works.	MSETCL	MSETCL	As per outage plan.
54	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	17-Aug-24	10:00	17-Aug-24	18:00	Daily	Line maintenance activity	MSETCL	MSETCL	to avoid tripping
55	400 KV	LONIKAND I - KOYNA STAGE-IV	18-Aug-24	08:00	18-Aug-24	17:00	Daily	R&M Scheme work Replacement of disc insulator by PLRI at differnt locations & Cold line washing work.	MSETCL	MSETCL	R&M Scheme work Replacement of disc insulator by PLRI at differnt locations & Cold line washing work.
56	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	18-Aug-24	10:00	18-Aug-24	18:00	Daily	Line maintenance activity	MSETCL	MSETCL	to avoid tripping
57	400 KV	400/220KV 315 MVA ICT - 3 @ NEW KOYNA	19-Aug-24	08:00	19-Aug-24	17:00	Daily	Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
58	400 KV	400/220kv SPARE ICT @ JEJURI	20-Aug-24	09:30	20-Aug-24	18:00	Daily	For RRS Trials work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
59	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	20-Aug-24	09:30	20-Aug-24	18:00	Daily	For RRS Trials work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
60	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	21-Aug-24	9:00	21-Aug-24	18:00	Daily	Earth wire Stringing Work loc.no.497-500 & Nut bolt hardware tightning work	MSETCL	MSETCL	.
61	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	21-Aug-24	09:30	21-Aug-24	17:00	Daily	220KV CT TANDELTA	MSETCL	MSETCL	NA

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
62	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	21-Aug-24	08:00	21-Aug-24	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
63	400 KV	KORADI II - IEPL	22-Aug-24	06:00	22-Aug-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA
64	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	22-Aug-24	10:00	22-Aug-24	18:00	Daily	Routine maintenance and DT.	MSETCL	MSETCL	-
65	400 KV	KORADI II - IEPL	23-Aug-24	10:00	23-Aug-24	17:30	Daily	Diagnostic Testing of Line CVT	MSETCL	MSETCL	400kV Koradi-II-Wardha Ckt. Will be service as alternate source
66	400 KV	CHANDRAPUR-PARLI CKT-3	24-Aug-24	09:00	24-Aug-24	18:00	Daily	Nut bolt hardware tightning work/ Spacer Repalcement &loc. No.474,631,657 Broken Disc Repalcement work	MSETCL	MSETCL	-
67	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	27-Aug-24	08:00	27-Aug-24	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -IV.	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-IV.
68	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	27-Aug-24	08:00	27-Aug-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT.Differential HV ,LV Back up relay ,HV CB DCRM ,Timing HV CT Tan D and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
69	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	28-Aug-24	09:00	28-Aug-24	18:00	Daily	1) CT testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
70	400 KV	STATION TF No 5 @ CHANDRAPUR GCR	28-Aug-24	08:00	28-Aug-24	18:00	Daily	1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine mainteance work.	MSETCL	MSETCL	During outage 400KV STN TF-4 will be in service.
71	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	28-Aug-24	08:00	28-Aug-24	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-IV
72	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	28-Aug-24	08:00	28-Aug-24	18:00	Daily	For restoration ICT -IV from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
73	400 KV	KARAD - TALANDGE CKT - 1	29-Aug-24	08:00	29-Aug-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
74	400 KV	STATION TF No 5 @ CHANDRAPUR GCR	29-Aug-24	08:00	29-Aug-24	18:00	Daily	1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine mainteance work.	MSETCL	MSETCL	During outage 400KV STN TF-4 will be in service.
75	400 KV	JEJURI- KOYNA STAGE-IV	30-Aug-24	7:00	30-Aug-24	17:00	Daily	R&M Scheme work Replacement of disc insulator by PLRI at diffiernt locations & Cold line washing work.	MSETCL	MSETCL	R&M Scheme work Replacement of disc insulator by PLRI at diffiernt locations & Cold line washing work.
76	400 KV	JEJURI- KOYNA STAGE-IV	30-Aug-24	7:00	30-Aug-24	18:00	Daily	Relay Retrofitting work by G.E..	MSETCL	MSETCL	-
77	400 KV	KARAD - TALANDGE CKT - 2	30-Aug-24	08:00	30-Aug-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
78	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	30-Aug-24	14:00	30-Aug-24	23:00	Daily	DT and Bay Maintenance activities	MSETCL	MSETCL	-
79	400 KV	CHANDRAPUR-PARLI CKT-3	30-Aug-24	08:00	30-Aug-24	18:00	Daily	1.Measurement of tandelta of Bushing of 50MVar Line shunt Reactor. 2.Premonsoon maintenance work of Reactor. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work	MSETCL	MSETCL	During outage 400KV CHD-2 CKT-1 & 2 400KV Khaperkheda, 400KV HVDC CKT-1 &2, 400KV PGCIL CKT-1,2,3&4 will be in service
80	400 KV	CHANDRAPUR-PARLI CKT-3	31-Aug-24	09:00	31-Aug-24	18:00	Daily	1) Main-1 distance relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
81	400 KV	JEJURI- KOYNA STAGE-IV	31-Aug-24	08:00	31-Aug-24	17:00	Daily	R&M Scheme work Replacement of disc insulator by PLRI at diffiernt locations & Cold line washing work.	MSETCL	MSETCL	R&M Scheme work Replacement of disc insulator by PLRI at diffiernt locations & Cold line washing work.