

Outage Planning of Transmission elements during September 2015

SN	KV	Line	From		To		Basis	Reason	System	Agency
1	400	400 kv GIRWALI CHANDRAPUR III	1-Sep-15	09:00	3-Sep-15	17:00	Daily	Routine testing and Maintenance work	MSETCL	MSETCL
2	400	Tie Bay of ICT & 400 KV Aurangabad -I Bay no. 403 at Akola SS	1-Sep-15	09:00	1-Sep-15	17:00	Daily	Routine testing and Maintenance work	MSETCL	MSETCL
3	400	Thapitlinda-Babhaleshwar ckt-1	2-Sep-15	11:00	2-Sep-15	18:00	Daily	Quaretrly maintenance work	MSETCL	MSETCL
4	400	400 KV LAMBOTI-SOLAPUR (PGCIL)	2-Sep-15	10:00	2-Sep-15	18:00	Daily	Replacement of normal insulator string to antifrog insulator in D/C line, Crpss arm rusted replacement work	MSETCL	MSETCL
5	400	Chakan Talegaon(PG)	3-Sep-15	10:00	3-Sep-15	18:00	Daily	Bay Maint. Work	MSETCL	MSETCL
6	400	Tie Bay of 400 Yelwan Bay No.415 at 400 KV Akola Ss	3-Sep-15	09:00	3-Sep-15	17:00	Daily	Routine testing and Maintenance work	MSETCL	MSETCL
7	400	CHANDRAPUR-PARALI 3	3-Sep-15	10:00	3-Sep-15	18:00	Daily	Bay Maint. Work	MSETCL	MSETCL
8	400	Waluj Aurangabad(PG) II	4-Sep-15	10:00	4-Sep-15	18:00	Daily	Line and bay mainenance with tree cutting etc.	MSETCL	MSETCL
9	400	400 KV Khadka-BBLR Line Bay	4-Sep-15	9:00	4-Sep-15	17:00	Daily	Routine bay Maintenance & attending high tempature point /Testing work	MSETCL	MSETCL
10	400	400 KV Deepnagar-Waluj Ckt	4-Sep-15	7:00	5-Sep-15	17:00	Daily	Tightening of nut bolts of all cut point Locations of Tension plate, Arcing Horn, Yoke Plate, corona ring, jumpers, jumper spacers & 'D' cycles etc of newly erected line.	MSETCL	MSETCL
11	400	AKOLA - AURANGABAD MAIN BAY NO.404	5-Sep-15	09:00	5-Sep-15	17:00	Daily	Routine Maintenance and testing work along with Dignostic testing activities	MSETCL	MSETCL
12	400	AKOLA - BHUSAWAL	5-Sep-15	10:00	5-Sep-15	18:00	Daily	Half Yearly maintenance work	MSETCL	MSETCL
13	400	400 KV KARAD - TALANDGE CKT 1	7-Sep-15	10:00	7-Sep-15	18:00	Daily	Bay maintenance & Testing work	MSETCL	MSETCL
14	400	NEW KOYNA - DABHOL-I	7-Sep-15	10:00	7-Sep-15	18:00	Daily	Bay maintenance & Testing work	MSETCL	MSETCL
15	400	400 KV Deepnagar-Waluj Ckt	7-Sep-15	7:00	9-Sep-15	17:00	Daily	Tightening of nut bolts of all cut point Locations of Tension plate, Arcing Horn, Yoke Plate, corona ring, jumpers, jumper spacers & 'D' cycles etc of newly erected line.	MSETCL	MSETCL
16	400	Main Bay 400 kv Wardha-I Bay No. 408 at 400 kv Akola SS	8-Sep-15	10:00	8-Sep-15	18:00	Daily	Routine testing and Maintenance work	MSETCL	MSETCL
17	400	400 KV CHANDRAPUR - KHAPERKHEDA	9-Sep-15	10:00	9-Sep-15	18:00	Daily	Line and bay mainenance with tree cutting etc.	MSETCL	MSETCL
18	400	400KV CHANDRAPUR II -WARORA CKT II	9-Sep-15	8:00	10-Sep-15	18:00	DAILY	LINE MAINTENANCE WORK	MSETCL	MSETCL
19	400	400KV 125Mvar BUS REACTOR AT 400KV WARORA	9-Sep-15		9-Sep-15	17:00	DAILY	To Carry out CRM of main & Tie CB, IR Values, supervisary trials of bucholz, PRV, & C & tan Delta of line CVT	MSETCL	MSETCL
20	400	400kv WARORA- Wardha(PG) CKT-2	9-Sep-15	8:00	9-Sep-15	17:00	DAILY	To carry out Signature test & Tree cutting work	MSETCL	MSETCL
21	400	Tie Bay of 400 kv Bhusawal & 400 kv Wardha - I Bay no.409 at Akola SS	10-Sep-15	09:00	10-Sep-15	17:00	Daily	Routine testing and Maintenance work	MSETCL	MSETCL
22	400	400 kv Babhleshwar - Aurangabad	10-Sep-15	09:00	10-Sep-15	17:00	Daily	Quarterly Maintenance.	MSETCL	MSETCL
23	400	Parli(MS) Parli (PG) I	10-Sep-15	09:00	10-Sep-15	18:00	Daily	Routine Maintenance and testing work along with Dignostic testing activities	MSETCL	MSETCL
24	400	400kv GIRAWALI-CHANDRAPUR II CKT I	10-Sep-15	7:00	10-Sep-15	17:00	daily	Quarterly Maintenance.	MSETCL	MSETCL
25	400	Thapitlinda-Akola ckt-1	11-Sep-15	8:00	11-Sep-15	18:00	Daily	bay maintenance work & line work	MSETCL	MSETCL
26	400	400/220/33KV 315MVA ICT-II AT 400KV AURANGABAD	11-Sep-15	9:00	11-Sep-15	17:00	Daily	Quarterly Maintenance.	MSETCL	MSETCL
27	400	BABLESHWAR- AURANGABAD (WALUJ)	12-Sep-15	09:00	12-Sep-15	18:00	Daily	Bay Maint. Work	MSETCL	MSETCL
28	400	DHULE- BABLESHWAR - II	13-Sep-15	10:00	13-Sep-15	18:00	Daily	Routine Maintenance and testing work along with Dignostic testing activities	MSETCL	MSETCL
29	400	KORADI-BHUSAWAL	14-Sep-15	10:00	14-Sep-15	18:00	Daily	Routine Maintenance and testing work along with Dignostic testing activities	MSETCL	MSETCL
30	400	Main Bay of 400 kv Bhusawal Bay No.410 at Akola Ss	15-Sep-15	09:00	15-Sep-15	17:00	Daily	Routine testing and Maintenance work	MSETCL	MSETCL
31	400	400 KV WARORA-ADANI(TIRODA)I	15-Sep-15	09:00	15-Sep-15	17:00	Daily	Bay Maint. Work	MSETCL	MSETCL
32	400	400 KV KORADI-KHAPERKHEDA -I	16-Sep-15	09:00	16-Sep-15	17:00	Daily	Routine Maintenance and testing work along with Dignostic testing activities	MSETCL	MSETCL
33	400	400/220KV 500MVA ICT III AT 400KV PARLY	17-Sep-15	7:00	17-Sep-15	17:00	Daily	Quarterly Maintenance.	MSETCL	MSETCL
34	400	400KV DHULE-SSP CKT I	19-Sep-15	10:00	19-Sep-15	18:00	Daily	Replacement of broken earth wire,Q.M. work, routing testing	MSETCL	MSETCL
35	500	Chandrapur-Padghe HVDC Line Pole I	21-Sep-15	8:00	24-Sep-15	18:00	Daily	Broken disc insulator replacement work. Hardware tightning, missing hardware replacement work.	MSETCL	MSETCL
37	400	Main Bus I at 400 kv Akola	22-Sep-15	9:00	22-Sep-15	18:00	Daily	Servicing of 02 Nos Bus Earth switches by Agency M/s BIMCO Isolators, Hyderabad and other routine maintenance and testing works.	MSETCL	MSETCL
38	400	Chandrapur-Dhariwal Ckt-I	23-Sep-15	10:00	23-Sep-15	18:00	Daily	408 Tie bay B-phase Isolator Cross Arm replacement work	MSETCL	MSETCL
39	400	TBC-II bay at 400kv GCR Chandrapur	23-Sep-15	8:00	23-Sep-15	18:00	Cont	For servicing & O/H of B-ph PG-III Isolator.	MSETCL	MSETCL
40	400	Chandrapur-Khaperkheda line	23-Sep-15	9:00	23-Sep-15	12:00	Daily	Line Signature Test	MSETCL	MSETCL
41	400	Main Bus II at 400 kv Akola	23-Sep-15	9:00	23-Sep-15	18:00	Daily	Servicing of 02 Nos Bus Earth switches by Agency M/s BIMCO Isolators, Hyderabad. C and Tan Delta of Bus CVT and other routine maintenance and testing works.	MSETCL	MSETCL
42	400	400KV Dhariwal-Chandrapur(II) Ckt-I	23-Sep-15	10:00	23-Sep-15	18:00	Daily	408 Tie bay B-phase Isolator Cross Arm replacement work	MSETCL	MSETCL
43	400	400KV Chandrapur-Khaperkheda line	23-Sep-15	9:00	23-Sep-15	12:00	Daily	Line Signature Test	MSETCL	MSETCL
44	400	400KV Chandrapur-Parli Ckt-III line	23-Sep-15	14:00	23-Sep-15	17:00	Daily	Line Signature Test	MSETCL	MSETCL
45	400	400KV TBC-II bay at Chandrapur	23-Sep-15	8:00	23-Sep-15	18:00	Cont	For servicing & O/H of B-ph PG-III Isolator.	MSETCL	MSETCL
46	400	Chandrapur II - Parli Ckt-II line	24-Sep-15	9:00	24-Sep-15	12:00	Daily	Line Signature Test	MSETCL	MSETCL
47	400	400kv Akola - Aurangabad Ckt - I (PGCIL) with bay numbers 403, 404 & reactor bay at 400 kv Akola	25-Sep-15	10:00	25-Sep-15	18:00	Daily	Replacement of B Phase contact assembly with arm of isolator 40389A by Agency M/s BIMCO Isolators, Hyderabad and other routine maintenance and testing works.	MSETCL	MSETCL
48	400	Chandrapur-PARLI CKT. NO. - III bay	25-Sep-15	7:00	25-Sep-15	19:00	Cont	For replacement of R & B-ph CVT's	MSETCL	MSETCL
49	500	HVDC Pole-2 of Chandrapur-Padghe line	26-Sep-15	8:00	27-Sep-15	19:00	Daily	Broken insulator replacement and OPGW wire stringing.	MSETCL	MSETCL
50	400	NEW KOYNA - DABHOL - II	28-Sep-15	10:00	28-Sep-15	17:00	Daily	Quarterly Maintenance.	MSETCL	MSETCL
51	400	400 kv Akola-Yelwan ckt.2	29-Sep-15	9:00	30-Sep-15	18:00	Continuou s	1.All Numerical Relay testing. 2. SCADA configuration with CRP/ Eqpt. & SCADA trials. This work is proposed by APTCL in coordination with Siemens.	MSETCL	MSETCL
52	400	GCR CPUR- CHD-II Ckt. No. - II bay	30-Sep-15	8:00	30-Sep-15	18:00	Cont	For measurement of C & Tan delta of R, Y & B-ph CT's and CVT's	MSETCL	MSETCL
53	400	400KV Dhariwal-Chandrapur(II) Ckt-II	30-Sep-15	10:00	30-Sep-15	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL