

WRPC OCCM approved Monthly Outage list for the Month of September'2018

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
1	17	400	NAGOTHANE - DABHOL 2	01/Sep/18	08:00	02/Sep/18	18:00	Daily	String replacement work & Line Sign.Test	MSETCL	MSETCL	
2	26	220	PUSAD - WARDHA (PG)	01/Sep/18	10:00	30/Sep/18	17:00	Daily	OPGW WORK / PID TESTING WORK	MSETCL	MSETCL	
3	27	220	BHUGAON - WARDHA (PG)	01/Sep/18	10:00	30/Sep/18	17:00	Daily	OPGW WORK / PID TESTING WORK	MSETCL	MSETCL	
4	42	400	KALWA - TALEGAON (PGCIL)	03/Sep/18	09:00	03/Sep/18	18:00	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	
5	55	400	400 KV Wardha-Warora-2 Tie Bay 408 at Wardha SS	03/Sep/18	9:00	03/Sep/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	
6	59	400	400KV Padghe GIS-1 MAIN BAY (415) at MSETCL KUDUS	03/Sep/18	10:00	03/Sep/18	12:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I	
7	60	400	400KV Padghe-1 TIE BAY (414) at MSETCL KUDUS	03/Sep/18	13:00	03/Sep/18	15:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I	
8	65	400	PARLI(MS) - PARLI (PG) CKT -1	03/Sep/18	09:00	03/Sep/18	17:00	Daily	Bay maintenance	MSETCL	MSETCL	
9	70	400	DHULE - SSNNL I &2 AR in Non-auto mode	03/Sep/18	08:00	04/Sep/18	18:00	Daily	Online PID testing Work	MSETCL	MSETCL	
10	71	400	NAGOTHANE - DABHOL 1	03/Sep/18	08:00	04/Sep/18	18:00	Daily	String replacement work & Line Sign.Test	MSETCL	MSETCL	
11	72	400	KHADKA - BABLESHWAR	03/Sep/18	09:00	06/Sep/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	after Restoration of Dhule-Bableshwar-D/C
12	75	400	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	03/Sep/18	09:00	12/Sep/18	20:00	Continuous	replacement of seek B ph unit by repaired job	MSETCL	MSETCL	
13	77	400	TIE BAY (428) OF WARORA - WARDHA(PG) @ WARDHA (PG)	04/Sep/18	09:00	09/Sep/18	17:00	Continuous	Routine Maintenance & Diagnostic testing work and replacement of R-ph pole complete wiring.	MSETCL	MSETCL	
14	79	400	SSNL-Dhule-1	04/Sep/18	8:00	04/Sep/18	18:00	Daily	Maintenance work. Auto reclose of 400 KV SSP - Dhule No. 2 will remain out	GETCO	GETCO	
15	91	400	400KV PADGHE-2 MAIN BAY (418) at MSETCL KUDUS	04/Sep/18	10:00	04/Sep/18	12:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I	
16	93	400	400KV PADGHE-2 TIE BAY (417) at MSETCL KUDUS	04/Sep/18	13:00	04/Sep/18	15:00	Daily	for taking Oil Sample of Bay CT.	WRTS-I	WRTS-I	
17	98	400	400/11.5KV STATION TRANSFORMER - 3 @ TIRORA	04/Sep/18	09:00	05/Sep/18	21:00	Continuous	Testing & Maintenance of Transformers, Bay Equipment and Its Relay	ATIL	ATIL	
18	105	400	SSNL-Dhule-2 and ckt-1 AR off	05/Sep/18	8:00	05/Sep/18	18:00	Daily	Maintenance work. Auto reclose of 400 KV SSP - Dhule No. 1 will remain out	NCA	GETCO	Auto reclose of 400 KV SSP - Dhule No. 1 will remain out
19	119	400	400KV Padghe GIS-1 MAIN BAY (415) at MSETCL KUDUS	05/Sep/18	10:00	05/Sep/18	18:00	Daily	for CRM of 415 CB	WRTS-I	WRTS-I	
20	124	400	CHANDRAPUR 2 - WARORA CKT-2	05/Sep/18	08:00	05/Sep/18	17:00	Daily	Tightening of conductor ,Earth wire Hardware.	MSETCL	MSETCL	
21	125	400	LAMBOTI-SOLAPUR (PGCIL)	05/Sep/18	09:00	05/Sep/18	17:00	Daily	Maintenance, servicing overhauling and alignment of 400 KV Isolators.	MSETCL	MSETCL	
22	126	220	KALMESHWAR-PANDHURNA	05/Sep/18	09:00	05/Sep/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
23	127	220	MAHALAXMI - AMONA	05/Sep/18	09:00	05/Sep/18	18:00	Daily	Routine maintenance and diagnostic testing	MSETCL	MSETCL	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
24	128	400	MAIN BAY (404) OF AURANGABAD (PG) - 1 @ AKOLA	05/Sep/18	10:00	05/Sep/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
25	129	765 KV	TIE BAY - 709 OF 765/400KV ICT-1 @ EKTUNI	05/Sep/18	10:00	05/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic/Relay Testing work	MSETCL	MSETCL	
26	159	400	400KV Padghe-1 TIE BAY (414) at MSETCL KUDUS	06/Sep/18	10:00	06/Sep/18	18:00	Daily	for CRM of 414 CB	WRTS-I	WRTS-I	
27	163	400	MAIN BUS - 1 @ LAMBOTI	06/Sep/18	09:00	06/Sep/18	17:00	Daily	Maintenance, servicing overhauling and alignment of 400 KV isolators.	MSETCL	MSETCL	
28	164	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR - 1)	06/Sep/18	09:00	06/Sep/18	17:00	Daily	Half yearly maint. And diag.testing	MSETCL	MSETCL	
29	165	400	TIE BAY (411) LINE - 1 OF KORADI-2 @ KORADI 3	06/Sep/18	09:00	06/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
30	166	765 KV	TIE BAY - 712 OF 765/400KV ICT-2 AND BUS RECTOR @ EKTUNI	06/Sep/18	10:00	06/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic/Relay Testing work	MSETCL	MSETCL	
31	168	400	NEW KOYNA - DABHOL - I	06/Sep/18	08:00	07/Sep/18	18:00	Daily	String replacement work & Line Sign.Test	MSETCL	MSETCL	
32	169	220	BHUGAON - WARDHA (PG)	06/Sep/18	10:00	07/Sep/18	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
33	193	400	400KV PADGHE-2 MAIN BAY (418) at MSETCL KUDUS	07/Sep/18	10:00	07/Sep/18	18:00	Daily	for CRM of 418 CB	WRTS-I	WRTS-I	
34	195	400	KALWA - KHARGHAR	07/Sep/18	08:00	07/Sep/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
35	196	400	CHANDRAPUR 2 - WARORA CKT-1	07/Sep/18	08:00	07/Sep/18	17:00	Daily	Tightening of conductor ,Earth wire Hardware.	MSETCL	MSETCL	
36	197	400	MAIN BUS - 2 @ LAMBOTI	07/Sep/18	09:00	07/Sep/18	17:00	Daily	Maintenance, servicing overhauling and alignment of 400 KV isolators.	MSETCL	MSETCL	
37	198	400	MAIN BAY (418) OF 400/11.5KV Station Transformer - 5 @ Tirora	07/Sep/18	09:00	07/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and Isolator	ATIL	ATIL	
38	199	400	TIE BAY (405) OF STN T/F-3 & KORADI 3 CKT-2 @ Koradi 2 SS	07/Sep/18	10:00	07/Sep/18	18:00	Daily	1) DCRM, CRM & Timing IR of 405-Q52 2)Tan delta Maesurement of Bus CT of Bay 405	MSETCL	MSETCL	
39	200	400	MAIN BAY - 406 OF 765/400kv ICT-2 @ EKTUNI	07/Sep/18	10:00	07/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic/Relay Testing work	MSETCL	MSETCL	
40	214	400	400KV Kudus-1 & ICT-1 Tie bay (402) at Padghe-GIS	08/Sep/18	9:00	08/Sep/18	13:00	Daily	For NTAMC integration works	WRTS-I	WRTS-I	
41	215	220	Bay No. 206 Main Bay of 220kv Boisar-Boisar-I Line at Boisar	08/Sep/18	9:00	08/Sep/18	17:30	Daily	For Bay AMP	POWERGRID	WR-II	
42	218	400	400KV KORADI-SATPURA	08/Sep/18	9:00	08/Sep/18	18:00	Daily	Replacement of Wave trap at Koradi end.	WRTS-I	WRTS-I	
43	223	400	DHULE - SSNNL I with AR in non-auto mode for DHULE - SSNNL II	08/Sep/18	08:00	08/Sep/18	18:00	Daily	Routine maintence work	MSETCL	MSETCL	
44	224		MAIN BAY (409) LINE - 2 OF KORADI-2 @ KORADI 3	08/Sep/18	09:00	08/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
45	225	220	PUSAD - WARDHA (PG)	08/Sep/18	10:00	08/Sep/18	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
46	226	400	NEW KOYNA - DABHOL - II	08/Sep/18	08:00	09/Sep/18	18:00	Daily	String replacement work & Line Sign.Test	MSETCL	MSETCL	
47	233	400	400KV PADGHE-2 TIE BAY (417) at MSETCL KUDUS	09/Sep/18	10:00	09/Sep/18	18:00	Daily	for AMP work	WRTS-I	WRTS-I	
48	241	500	Pole-2 Non base AC filter Z3 (120 MVAR) of CHANDRAPUR - PADGHE HVDC POLE 2	10/Sep/18	08:00	10/Sep/18	18:00	Daily	For Diagnostic Testing of 400KV Breaker, 245kV CTs, 24kV CTs and general maintenance of Filter.	MSETCL	MSETCL	

Sr.No.	OCCM Sr. No	KV	Line / Element	From	Time	To		Basis	Reason	System	Agency	REMARKS
				Date		Date	Time					
49	248	400	400KV Kudus-2 Main bay (404) at Padghe-GIS	10/Sep/18	9:00	10/Sep/18	13:00	Daily	For NTAMC integration works	WRTS-I	WRTS-I	
50	250	400	400KV Talegaon-Lonikand Line at Pune (Talegaon)	10/Sep/18	9:00	10/Sep/18	17:00	Daily	For line Isolator Alignment & For Line side Equipment AMP works.	MSETCL	WRTS-I	
51	263	400	400KV Kudus-2 & ICT-2 Tie bay (405) at Padghe-GIS	10/Sep/18	14:00	10/Sep/18	18:00	Daily	For NTAMC integration works	WRTS-I	WRTS-I	
52	264	400	PARLI - KUMBHARGAON (NANDED) CKT - 1	10/Sep/18	09:00	10/Sep/18	17:00	Daily	CT C & Tan delta measurement.	MSETCL	MSETCL	
53	265	400	TIE BAY (408) LINE - 2 OF KORADI-2 @ KORADI 3	10/Sep/18	09:00	10/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
54	266	400	BABLESHWAR- AURANGABAD (WALUJ)	10/Sep/18	09:00	10/Sep/18	18:00	Daily	Routine maint work and Line Signature	MSETCL	MSETCL	After Restoration of Dhule-Bableshwar-D/C
55	267	220	PUSAD - WARDHA (PG)	10/Sep/18	10:00	10/Sep/18	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
56	268	220	TALANDAGE - CHIKODI	10/Sep/18	10:00	10/Sep/18	17:00	Daily	Routine maintenance and diagnostic testing	MSETCL	MSETCL	
57	271	400	DHULE - SSNNL I & II AR in Non auto mode	10/Sep/18	08:00	11/Sep/18	18:00	Daily	Online PID testing Work	MSETCL	MSETCL	
58	276	500 KV	Pole-1 Non base AC filter Z3 (120 MVAR) of CHANDRAPUR - PADGHE HVDC POLE 1	11/Sep/18	08:00	11/Sep/18	18:00	Daily	For Diagnostic Testing of 400kV Breaker, 245kV CTs, 24kV CTs and general maintenance of Filter.	MSETCL	MSETCL	Any Power regulation?
59	280	400	400KV Padghe GIS-1 MAIN BAY (415) at MSETCL KUDUS	11/Sep/18	10:00	11/Sep/18	18:00	Daily	for DCRM, Timing of Bay CB and CT Testing of Bay CT	WRTS-I	WRTS-I	
60	287	220	220KV Talegaon (MSETCL) Line-1 at Pune (Talegaon)	11/Sep/18	9:00	11/Sep/18	17:00	Daily	For Line side Equipment AMP works.	MSETCL	WRTS-I	
61	304	220	TILARI - AMONA LINE	11/Sep/18	09:00	11/Sep/18	18:00	Daily	Routine maintenance and diagnostic testing	MSETCL	MSETCL	
62	305	400	KORADI 2 - KORADI 3 CKT-1	11/Sep/18	10:00	11/Sep/18	13:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	
63	306	400	KORADI 2 - KORADI 3 CKT-2	11/Sep/18	13:00	11/Sep/18	17:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	
64	311	500 KV	Pole-1 Non base AC filter Z4 (80 MVAR) of CHANDRAPUR - PADGHE HVDC POLE 1	12/Sep/18	08:00	07/Sep/18	18:00	Daily	For Diagnostic Testing of 400kV Breaker, 245kV CTs, 24kV CTs and general maintenance of Filter.	MSETCL	MSETCL	Any Power regulation?
65	315	400	400KV Padghe-1 TIE BAY (414) at MSETCL KUDUS	12/Sep/18	10:00	12/Sep/18	18:00	Daily	for DCRM, Timing of Bay CB and CT Testing of Bay CT	WRTS-I	WRTS-I	
66	326	220	Bay No. 211 Main Bay of 220kv Boisar-Boisar-II Line at Boisar	12/Sep/18	9:00	12/Sep/18	17:30	Daily	For Bay AMP	POWERGRID	WR-II	
67	335	400	MAIN BAY (404) OF ICT - 2 @ KORADI 3	12/Sep/18	09:00	12/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
68	336	220	DEOLI(PGCIL)-BADNERA	12/Sep/18	10:00	12/Sep/18	17:00	Daily	loc no 53,56,58 Suspension clamp and arcing horn nut bolt tightening	MSETCL	MSETCL	
69	340	500	Pole-2 Non base AC filter Z4 (80 MVAR) of CHANDRAPUR - PADGHE HVDC POLE 2	13/Sep/18	08:00	13/Sep/18	18:00	Daily	For Diagnostic Testing of 400kV Breaker, 245kV CTs, 24kV CTs and general maintenance of Filter.	MSETCL	MSETCL	
70	343	400	400KV PADGHE GIS- KUDUS I	13/Sep/18	9:00	13/Sep/18	18:00	Daily	For CVT, LA testing and Isolator CRM & Oil sampling taking	WRTS-I	WRTS-I	
71	355	765 KV	BUS - 2 @ TIRODA	14/Sep/18	08:00	14/Sep/18	21:00	Daily	Testing & Maintenance of Bus Connected Isolator & CVT	MEGPTCL	MEGPTCL	
72	370	400	400KV PADGHE-2 MAIN BAY (418) at MSETCL KUDUS	14/Sep/18	10:00	14/Sep/18	18:00	Daily	for DCRM, Timing of Bay CB and CT Testing of Bay CT	WRTS-I	WRTS-I	
73	374	400	MAIN BAY (412) LINE - 1 OF KORADI-2 @ KORADI 3	14/Sep/18	09:00	14/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	

Sr.No.	OCCM Sr. No	KV	Line / Element	From	Time	To		Basis	Reason	System	Agency	REMARKS
				Date		Date	Time					
74	375	400	MAIN BAY (407) OF AURANGABAD (PG) - 2 @ AKOLA	14/Sep/18	10:00	14/Sep/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
75	379	400	PARLI - LONIKAND 2 CKT 1	14/Sep/18	10:00	14/Sep/18	18:00	Daily	Line Signature Analysis	MSETCL	MSETCL	
76	381	400	BABHALESHWAR - PADGHE 1	15/Sep/18	09:00	18/Sep/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	All switching actions shall be facilitated after restoration of Dhule-Bableshwar-D/C
77	385	400	400KV Kalwa Line & ICT # 3 Tie bay (417) at Pune (Talegaon)	15/Sep/18	9:00	15/Sep/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	
78	390	400	400KV PADGHE-2 TIE BAY (417) at MSETCL KUDUS	15/Sep/18	10:00	15/Sep/18	18:00	Daily	for DCRM, Timing of Bay CB and CT Testing of Bay CT	WRTS-I	WRTS-I	
79	392	400	DHULE - SSNNL ckt II with AR in non-auto mode for DHULE - SSNNL ckt I	15/Sep/18	08:00	15/Sep/18	18:00	Daily	Routine maintenance work	MSETCL	MSETCL	
80	393	400	Tie Bay (405) of ICT-2 & Line-3 @ Koradi 3	15/Sep/18	09:00	15/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
81	394	400	KALWA - KHARGHAR	15/Sep/18	09:00	15/Sep/18	18:00	Daily	Line Signature analysis test & Bay Maintenance & Testing work.	MSETCL	MSETCL	
82	396	400	LONIKAND 1 - TALEGAON (PGCIL)	16/Sep/18	08:00	16/Sep/18	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	Facilitated on Sunday
83	423	400	WARORA - Wardha(PG)	17/Sep/18	09:00	17/Sep/18	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	MSETCL	MSETCL	
84	424	400	MAIN BAY (406) OF LINE- 3 @ KORADI 3	17/Sep/18	09:00	17/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
85	455	400	TIE BAY (402) OF ICT - 1 & LINE - 4 @ KORADI 3	18/Sep/18	08:00	18/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
86	460	400	BABHALESHWAR - PADGHE 1	18/Sep/18	09:00	18/Sep/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
87	461	400	BABHALESHWAR - PADGHE 2	19/Sep/18	09:00	23/Sep/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	All Switching actions shall be allowed at Bableshwar after restoration of Dhule-Bableshwar-D/C
88	490	400	B BUS @ NAGOTHANE	19/Sep/18	08:00	19/Sep/18	18:00	Daily	Padgha 1 PG Isolator overhauling	MSETCL	MSETCL	
89	492	400	CHANDRAPUR-PARLI CKT-3	19/Sep/18	09:00	19/Sep/18	17:00	Daily	1)Fixing of earth wire at loc no -613 2) strengthening of earth wire at loc no. 550-551and at loc no. 502-503 4)tightening /fixing of N/B at loc no. 502 and 519	MSETCL	MSETCL	
90	493	400	KORADI 2-WARDHA PGCIL	19/Sep/18	09:00	19/Sep/18	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	MSETCL	MSETCL	
91	497	220	TAPS1&2 -Boisar	20/Sep/18	7:00	20/Sep/18	10:00	daily	For backcharging Zone -III	MSETCL	NPCL	
92	525	400	MAIN BUS - 1 @ KORADI-3	20/Sep/18	08:00	20/Sep/18	18:00	Daily	Testing & Maintenance of Bus Connected Isolator & CVT	MEGPTCL	MEGPTCL	
93	527	400	400Kv Boisar-Padghe at Boisar	20/Sep/18	9:00	21/Sep/18	17:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WR-II	
94	535	220	220KV Bus-I at Boisar	21/Sep/18	9:00	21/Sep/18	17:30	Daily	For AMP	POWERGRID	WR-II	
95	543	400	MAIN BUS - 2 @ TIRORA	21/Sep/18	08:00	21/Sep/18	21:00	Daily	Testing & Maintenance of Bus Connected Isolator & CVT	MEGPTCL	MEGPTCL	

Sr.No.	OCCM Sr. No	KV	Line / Element	From	Time	To		Basis	Reason	System	Agency	REMARKS
				Date		Date	Time					
96	559	400	400kv Boisar-Padghe at Boisar	21/Sep/18	14:00	21/Sep/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line outage required)	POWERGRID	WR-II	
97	561	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	21/Sep/18	09:00	21/Sep/18	17:00	Daily	1)fixing of earth wire at loc no. 553 and 4) fixing of N/b at loc .no.475,502	MSETCL	MSETCL	
98	562	400	EKTUNI - TAPTITANDA CKT - 1	21/Sep/18	10:00	21/Sep/18	17:00	Daily	Relay testing work & Routine Maintenance work	MSETCL	MSETCL	
99	569	220	220KV Bus-II at Boisar	22/Sep/18	9:00	22/Sep/18	17:30	Daily	For AMP	POWERGRID	WR-II	
100	570	400	400KV PADGHE GIS- KUDUS II	22/Sep/18	9:00	22/Sep/18	18:00	Daily	For CVT,LA testing and Isolator CRM & Oil sampling taking	WRTS-I	WRTS-I	
101	585	400	MAIN BAY (401) OF ICT - 1 @ KORADI 3	22/Sep/18	09:00	22/Sep/18	18:00	Daily	Testing & Maintenance of Breaker and CT	MEGPTCL	MEGPTCL	
102	594	400	400KV Talegaon - Chakan Line	23/Sep/18	9:00	23/Sep/18	17:00	Daily	For Line side Equipment AMP works at Pune (Talegaon).	MSETCL	WRTS-I	
103	598	400	BABHALESHWAR - PADGHE 2	23/Sep/18	09:00	23/Sep/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
104	603	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_4	24/Sep/18	9:00	24/Sep/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments	WRTS-I	WRTS-I	
105	606	400	BABLESHWAR- AURANGABAD (WALUJ)	24/Sep/18	09:00	28/Sep/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	After restoration of Dhule-Bableshwar-D/C
106	627	220	MUDSHINGI - CHIKODI	24/Sep/18	10:00	24/Sep/18	17:00	Daily	Routine Maintenance and diagnostic testing	MSETCL	MSETCL	
107	634	400	MAIN BUS - 2 @ WALUJ	25/Sep/18	08:00	25/Sep/18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	
108	651	220	220KV Pandhurna - Kalmeahwar	25/Sep/18	10:00	25/Sep/18	17:00	Daily	For Circuit Breaker Maintenance work	MPPTCL	MPPTCL	
109	653	400	PARLI(MS) - PARLI (PG) CKT -2	25/Sep/18	09:00	25/Sep/18	17:00	Daily	Bay maintenance	MSETCL	MSETCL	
110	654	400	BABLESHWAR- AURANGABAD (WALUJ)	25/Sep/18	09:00	25/Sep/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
111	664	220	TAPS1&2 -Boisar	26/Sep/18	15:00	26/Sep/18	19:00	daily	For normalising the Boisar feeder after completion of Zone-I outage	MSETCL	NPCIL	
112	672	220	Navsari Nashik-1	26/Sep/18	8:00	26/Sep/18	18:00	Daily	Bay equipment maintenance and testing work	GETCO	GETCO	
113	686	400	400kv Tarapur-Boisar-II at Boisar	26/Sep/18	14:00	26/Sep/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line outage required)	POWERGRID	WR-II	
114	688	400	CHANDRAPUR-PARLI CKT-3	26/Sep/18	07:00	26/Sep/18	18:00	Daily	For replacement of Damaged Earth wire Cross Arm .	MSETCL	MSETCL	
115	690	400	Main Bay (428) of 400 KV Warora Ckt-I @ Chandrapur - 2	26/Sep/18	09:00	26/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
116	691	765	Main Bay (703) OF EKTUNI-AKOLA II ckt-2 & LR @ EKTUNI	26/Sep/18	10:00	26/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic/Relay Testing	MSETCL	MSETCL	
117	700	400	0-51300-Line-1 (Tarapur-Padghe ckt-2).	27/Sep/18	9:00	28/Sep/18	18:00	Continuous	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	PGCIL	NPCIL	
118	702	220	Navsari Nashik - 2	27/Sep/18	8:00	27/Sep/18	18:00	Daily	Bay equipment maintenance and testing work	GETCO	GETCO	
119	707	400	BUS REACTOR_400KV_80MVAR_DHULE	27/Sep/18	7:00	27/Sep/18	16:00	Daily	For AMP works of Reactor and Bay equipment at Dhule	WRTS-I	WRTS-I	
120	712	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	27/Sep/18	07:00	27/Sep/18	18:00	Daily	For replacement of Damaged Earth wire Cross Arm .	MSETCL	MSETCL	

Sr.No.	OCCM Sr. No	KV	Line / Element	From	Time	To		Basis	Reason	System	Agency	REMARKS
				Date		Date	Time					
121	713	400	MAIN BUS - 2 @ KORADI-3	27/Sep/18	08:00	27/Sep/18	18:00	Daily	Testing & Maintenance of CVT and Isolator and relays	MEGPTCL	MEGPTCL	
122	714	400	KOLHAPUR (TALANDGE) - ALKUD	27/Sep/18	09:00	27/Sep/18	18:00	Daily	Quarterly maintenance	PGCIL	MSETCL	
123	715	400	Main Bay 412 of Chadrapur II ckt 2 @ C'pur Swiching Substation	27/Sep/18	09:00	27/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
124	716	765	Main Bay (706) OF EKTUNI-AKOLA II ckt-1 & LR @ EKTUNI	27/Sep/18	10:00	27/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic/Relay Testing	MSETCL	MSETCL	
125	738	400	400KV Dhule-Khandwa-1	28/Sep/18	9:00	28/Sep/18	18:00	Daily	For AMP testing works of CT, CVT at Dhule end by Aurangabad.	WRTS-I	WRTS-I	
126	739	400	400KV BHILAI-KORADI	28/Sep/18	9:00	28/Sep/18	18:00	Daily	AMP works	WRTS-I	WRTS-I	
127	741	400	EKTUNI - TAPTITANDA CKT - 2	28/Sep/18	10:00	28/Sep/18	17:00	Daily	Relay testing work & Routine Maintenance work	MSETCL	MSETCL	
128	743	765	765KV AURANGABAD(PG)-SOLAPUR I	29/Sep/18	9:00	29/Sep/18	18:00	Daily	For attending line defects and line terminal equipment AMP works	WRTS-I	WRTS-I	
129	744	400	PADGHE - KALWA 2	29/Sep/18	08:00	29/Sep/18	18:00	Daily	Replacement of faulty insulator, nutbolt tightening & line signature analysis	MSETCL	MSETCL	Facilitated on Sunday
130	752	400	KOLHAPUR - SOLAPUR (PG) CKT - 2	29/Sep/18	09:00	29/Sep/18	18:00	Daily	Quarterly maintenance	PGCIL	MSETCL	
131	753	400	Main bay (410) of 765/400KV 1500 MVA ICT-1@ Ektuni	29/Sep/18	10:00	29/Sep/18	18:00	Daily	Routine Maintenance & Diagnostic/Relay Testing	MSETCL	MSETCL	
132	757	220	Zone III Main bus at TAPS-1&2	29/Sep/18	8:00	29/Sep/18	19:00	Daily basis	Annual maintenance (AM)Works	MSETCL	NPCIL	
133	758	220	TAPS3&4 tie line-TAPS -Stg-1&2	29/Sep/18	8:00	29/Sep/18	19:00	Daily basis	For Zone-III outage	MSETCL	NPCIL	
134	764	400	400KV Dhule-Khandwa-2	29/Sep/18	9:00	29/Sep/18	18:00	Daily	For AMP testing works of CT, CVT at Dhule end by Aurangabad.	WRTS-I	WRTS-I	
135	770	400	PADGHE - KALWA 1	30/Sep/18	09:00	30/Sep/18	18:00	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	
136	771	400	BUS COUPLER @ BABHALESHWAR	30/Sep/18	09:00	30/Sep/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400KV P.G Isolator and Servicing and allignment of isolators work	MSETCL	MSETCL	
137	772	400	PADGHE - KALWA 1	30/Sep/18	08:30	30/Sep/18	17:30	Daily	Annual Maintenance work	MSETCL	MSETCL	
138	779	400	Parli-Pune(GIS)-I	30/Sep/18	8:00	30/Sep/18	18:00	Daily	Annual maintenance work in transmission line	WTPL	WTPL	

State Element outages for the Month of September' 2018

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	KORADI-KHADKA	01-Sep-18	08:00	01-Sep-18	18:00	Daily	CT C & tan delta test & LSA	MSETCL	MSETCL	-
2	400 KV	PADGHE - NAGOTHANE 1	04-Sep-18	08:00	04-Sep-18	17:00	Daily	Jumper Tightening and bay maintenance at substation	MSETCL	MSETCL	Nil
3	400 KV	NEW KOYNA-KARAD -CKT 1	03-Sep-18	09:00	06-Sep-18	18:00	Daily	Faulty Insulator replacement work	MSETCL	MSETCL	New Koyna-Karad ckt 2 will be in service
4	400 KV	DEEPNAGAR - THAPTI TANDA	04-Sep-18	10:00	08-Sep-18	16:00	Daily	AR out for PID work	MSETCL	MSETCL	Line will be in service
5	400 KV	DEEPNAGAR- AURANGABAD	04-Sep-18	06:00	08-Sep-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	--
6	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	04-Sep-18	08:00	04-Sep-18	18:00	Daily	Annual Maintenance of bays & equipment And Dignostic Testing of ICT.	MSETCL	MSETCL	ICT-2 will be in service.
7	400 KV	KARAD - TALANDGE CKT 1	04-Sep-18	10:00	04-Sep-18	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	Load will be manage on 400 kv Talandge Ckt-2
8	400 KV	400kv Stn. TF No 3 @ C'pur GCR	04-Sep-18	08:00	05-Sep-18	18:00	Daily	1) For Measurement of Tan delta & capacitance of CTs. 2)Measurment of DCRM, Timing & CRM of breaker. 3) Isolator maintenance works.	MSETCL	MSETCL	During outage on STN T/F- 3, the 400KV STN T/F -4 & 5 bays will be in service.
9	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	04-Sep-18	10:00	05-Sep-18	18:00	Daily	"1) TAN DELTA MEASUREMENT OF ICT1 BUSHING IR & PI, 2) TAN DELTA MEASUREMENT OF 205CT 3) TAN DELTA MEASUREMENT OF 430 LCT 4)DCRM,CRM & Timing IR of 429-Q52 5)Tan delta Maeasurement of Bus CT of Bay 429. 6) DCRM,CRM & Timing IR of 430-Q52 7)Tan delta Maeasurement of Bus CT of Bay 430"	MSETCL	MSETCL	Load will be shifted to 400/220/33KV ICT-II
10	400 KV	PADGHE - NAGOTHANE 1	05-Sep-18	08:00	05-Sep-18	17:00	Daily	Jumper Tightening and bay maintenance at substation.	MSETCL	MSETCL	Nil
11	400 KV	PADGHE - NAGOTHANE 1	06-Sep-18	08:00	06-Sep-18	17:00	Daily	Jumper tightening and bay maintenance work	MSETCL	MSETCL	Nil
12	400 KV	MAIN BAY (416) OF STATION TF 4A @ DEEPNAGAR	06-Sep-18	08:00	06-Sep-18	18:00	Daily	ANNUAL BAY MAINTENANCE AND DIAGNOSTIC TESTING OF CB.	MSETCL	MSETCL	ONLY MAIN BAY-416 CB will be off and STAION TRANSFORMER WILL BE IN SERVICE THROUGH TIE CB.
13	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	06-Sep-18	09:00	06-Sep-18	17:00	Daily	Bay maintenance & HV CB DCRM & Timing test.	MSETCL	MSETCL	--
14	400 KV	MAIN BAY (401) OF ICT -1 @ JEJURI	06-Sep-18	09:00	06-Sep-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	ICT-I will remain charged through 402 TIE CB
15	400 KV	KARAD - LONIKAND	06-Sep-18	10:00	06-Sep-18	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	Load will be manage on other circuit
16	400 KV	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	07-Sep-18	08:30	07-Sep-18	17:30	Daily	Annual Maintenance work	MSETCL	MSETCL	--
17	400 KV	400kv Stn. TF No 4 @ C'pur GCR	07-Sep-18	08:00	08-Sep-18	18:00	Daily	1) For Measurement of Tan delta & capacitance of CTs. 2)Measurment of DCRM, Timing & CRM of breaker. 3) Isolator maintenance works.	MSETCL	MSETCL	During outage on STN T/F- 4, the 400KV STN T/F - 3 & 5 bays will be in service.
18	400 KV	105 MVA SPARE ICT @ AKOLA	07-Sep-18	09:00	07-Sep-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Spare ICT - with Bay 401 @ AKOLA
19	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	07-Sep-18	09:00	07-Sep-18	18:00	Daily	Routine Maintenance Work	MSETCL	MSETCL	--
20	400 KV	125MVAr BUS REACTOR @ WARORA	07-Sep-18	08:00	07-Sep-18	17:00	Daily	Routine maintainance and diagnoastic testing such as CT tandelta,CRM,IR values,isolater maintenance work and DCRM	MSETCL	MSETCL	Main bay no 402 & Tie bay no 403 will be out
21	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	08-Sep-18	08:00	09-Sep-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I and II , 501 MVA ICT -III will be in service
22	400 KV	AKOLA - KHADKA (BHUSAWAL)	08-Sep-18	08:00	08-Sep-18	18:00	Daily	CT C & tan delta test & LSA	MSETCL	MSETCL	--
23	400 KV	PADGHE - NAGOTHANE 2	10-Sep-18	08:00	10-Sep-18	17:00	Daily	Jumper tightening and bay maintenance work	MSETCL	MSETCL	Nil
24	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	10-Sep-18	08:00	10-Sep-18	18:00	Daily	RTV Coating, Routine Maintenance & Relay Testing work	MSETCL	MSETCL	Load can be managed on 315 MVA ICT -II

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
25	400 KV	AKOLA - KHADKA (BHUSAWAL)	10-Sep-18	12:00	12-Sep-18	18:00	Daily	PID testing of insulator strings by PID Unit of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Nandgaonpeth & 400 kv Koradi- Nandgaonpeth will be in service.
26	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	10-Sep-18	09:00	10-Sep-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--
27	400 KV	PADGHE - NAGOTHANE 2	11-Sep-18	08:00	11-Sep-18	17:00	Daily	Jumper Tightening and bay maintenance work	MSETCL	MSETCL	Nil
28	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	11-Sep-18	08:00	11-Sep-18	17:00	Daily	Routine maintainance and diagnoastic testing such as CT tanelta,CRM,IR values,isolater maintenance work and DCRM	MSETCL	MSETCL	Bay No 404 charged upto line CT (400KV ICT No -1 handed over to 400kv Babbleshwar)
29	400 KV	400/220 KV 500 MVA ICT @ ALKUD	11-Sep-18	09:30	11-Sep-18	17:30	Daily	Quarterly Maintenance Work & Diagnostic Testing Work	MSETCL	MSETCL	For QM Work
30	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	11-Sep-18	08:00	11-Sep-18	18:00	Daily	Annual Maintenance of bays & equipment And Diagnostic Testing of ICT.	MSETCL	MSETCL	ICT-1 will be in service.
31	400 KV	PADGHE - NAGOTHANE 2	12-Sep-18	08:00	12-Sep-18	17:00	Daily	Jumper tightening and bay maintenance work	MSETCL	MSETCL	Nil
32	400 KV	THAPTI TANDA - WALUJ	12-Sep-18	11:00	12-Sep-18	13:00	Daily	Line Signature	MSETCL	MSETCL	--
33	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	12-Sep-18	08:00	12-Sep-18	17:00	Daily	Maintenance, servicing overhauling and allignment of 400 KV isolators.	MSETCL	MSETCL	Load will be managed on 400 kv ICT-I
34	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	12-Sep-18	08:00	12-Sep-18	18:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
35	400 KV	DEEPNAGAR - THAPTITANDA	13-Sep-18	10:00	28-Sep-18	16:00	Daily	AR out for PID work by Hot Line Technique	MSETCL	MSETCL	Line will be in service
36	400 KV	PADGHE - NAGOTHANE 2	13-Sep-18	08:00	13-Sep-18	17:00	Daily	Jumper tightening and bay maintenance work	MSETCL	MSETCL	Nil
37	400 KV	KHADKA - BABLESHWAR	15-Sep-18	08:00	15-Sep-18	18:00	Daily	CVT & CB DCRM & Timing Test & LSA	MSETCL	MSETCL	--
38	400 KV	PADGHE - NAGOTHANE 1	17-Sep-18	08:00	17-Sep-18	17:00	Daily	CT replacement	MSETCL	MSETCL	Nil
39	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	17-Sep-18	08:00	17-Sep-18	18:00	Daily	RTV coating,routine maintenance & relay testing	MSETCL	MSETCL	Load can be managed on 315 MVA ICT -I
40	400 KV	400/220/33 KV 315MVA ICT - 3 @ KARAD	17-Sep-18	10:00	17-Sep-18	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	Load manage on other Two ICT'S
41	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	17-Sep-18	12:00	19-Sep-18	18:00	Daily	PID testing of insulator strings by PID Unit of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Bhusawal & 400 kv Koradi-Nandgaonpeth will be in service.
42	400 KV	PADGHE - NAGOTHANE 2	18-Sep-18	08:00	18-Sep-18	17:00	Daily	CT replacement	MSETCL	MSETCL	Nil
43	400 KV	KORADI 2- IEPL	18-Sep-18	10:00	18-Sep-18	18:00	Daily	Tan delta Measurement of LINE CVT	MSETCL	MSETCL	--
44	400 KV	WARORA - IEPL	19-Sep-18	09:00	19-Sep-18	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work	MSETCL	MSETCL	--
45	400 KV	400kv Stn. TF No 5 @ C'pur GCR	18-Sep-18	08:00	19-Sep-18	18:00	Daily	1) For Measurement of Tan delta & capacitance of CT's. 2) Measurment of DCRM, Timing & CRM of breaker. 3) Isolator maintenance works.	MSETCL	MSETCL	During outage on STN T/F- 5, the 400KV STN T/F - 3 & 4 bays will be in service.
46	400 KV	400/220 KV 167 MVA ICT @ PARLI	18-Sep-18	09:00	18-Sep-18	17:00	Daily	Bay maintenance & HV CB DCRM & Timing test.	MSETCL	MSETCL	--
47	400 KV	MAIN BAY (407) OF DHARIWAL CKT - 1 @ CHANDRAPUR - 2	19-Sep-18	09:00	19-Sep-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	--
48	400 KV	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	19-Sep-18	08:00	19-Sep-18	18:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
49	400 KV	FUTURE CKT - 1 @ WARORA	19-Sep-18	08:00	19-Sep-18	17:00	Daily	CB DCRM ,CRM,Timing and IR Values Testing works isolater maintenance work .	MSETCL	MSETCL	Bay no 419 and Tie bay no 418 will be out (400KV Bay No 419 charged on No Load)
50	400 KV	TBC @ KARAD	19-Sep-18	10:00	19-Sep-18	17:00	Daily	Quarterly Maint. Work	MSETCL	MSETCL	NIL
51	400 KV	MAIN BAY - 410 OF BHUSAWAL (KHADKA)	19-Sep-18	10:00	19-Sep-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	--

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
52	400 KV	TBC @ Lonikand-1	20-Sep-18	08:00	20-Sep-18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	Line Maintenance
53	400 KV	125 MVAr BUS REACTOR @ ALKUD	20-Sep-18	09:30	20-Sep-18	17:30	Daily	Quarterly Maint. Work & Diagnostic Testing Work	MSETCL	MSETCL	For QM Work
54	400 KV	KORADI-NANDGAONPETH (RPL)	21-Sep-18	10:00	21-Sep-18	17:00	Daily	Line signature test & other Routine Maintenance work	MSETCL	MSETCL	--
55	400 KV	KHADKA- DEEPNAGAR CKT 1	22-Sep-18	08:00	22-Sep-18	18:00	Daily	CT& CVT C & Tan delta test, CB DCRM	MSETCL	MSETCL	--
56	400 KV	DEEPNAGAR - THAPTITANDA	24-Sep-18	06:00	29-Sep-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	--
57	400 KV	KORADI-KHADKA	24-Sep-18	12:00	26-Sep-18	18:00	Daily	PID testing of insulator strings by PID Unit of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Akola- Bhusawal, 400 kV Akola-Nandgaonpeth & 400 kV Koradi-Nandgaonpeth will be in service.
58	400 KV	400/220/33 KV 315 MVA ICT - 1 @ KOLHAPUR	24-Sep-18	09:00	24-Sep-18	20:00	Daily	Quarterly maintenance	MSETCL	MSETCL	-
59	400 KV	NEW KOYNA -KARAD -CKT 2	24-Sep-18	08:00	24-Sep-18	18:00	Daily	Routine maintenance and relay testing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna-Karad CKT-I line
60	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	25-Sep-18	10:00	25-Sep-18	18:00	Daily	"1)Tan delta Maeasurement of ICT-II Bushing IR & PI, 2)Tan delta Maeasurement of 201- CT 3)Tan delta Maeasurement of Syn. CVT at Bay 421"	MSETCL	MSETCL	Load will be shifted to 400/220/33KV ICT-I
61	400 KV	WARORA - IEPL	25-Sep-18	08:00	25-Sep-18	17:00	Daily	CB DCRM ,CRM, Timing and IR Values Testing works isolater maintenance work .	MSETCL	MSETCL	Load will be managed on 400KV Wardha PGCIL Ckt
62	400 KV	400220KV 167MVA SPARE ICT @ DEEPNAGAR	25-Sep-18	08:00	25-Sep-18	17:00	Daily	Annual Maintenance of bays & equipment And Diagnostic Testing of SPARE ICT.	MSETCL	MSETCL	--
63	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	27-Sep-18	09:00	27-Sep-18	18:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	Routine Dignostic testing & maintenance work
64	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	28-Sep-18	09:00	28-Sep-18	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Annual maintenance work & testing work
65	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	27-Sep-18	09:00	27-Sep-18	17:00	Daily	IV CB CRM & Timing test.	MSETCL	MSETCL	--
66	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	29-Sep-18	14:00	29-Sep-18	17:00	Daily	Half yearly maint. And diag.testing	MSETCL	MSETCL	No load will be affected and ICT-II will be kept charged through Tie bay
67	400 KV	MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	27-Sep-18	08:00	27-Sep-18	17:00	Daily	ANNUAL BAY MAINTENANCE AND DIAGNOSTIC TESTING OF CB.	MSETCL	MSETCL	ICT-2 will be in service through its TIE CB.
68	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	27-Sep-18	09:00	27-Sep-18	13:00	Daily	Half yearly maint. And diag.testing	MSETCL	MSETCL	No load will be affected and ICT-II will be kept charged through own bay
69	400 KV	BUS REACTOR - 2 @ TIRORA	28-Sep-18	09:00	28-Sep-18	19:00	Daily	Shutdown Mainetnance of BR, Bay equipments and Its Relay testing	MEGPTCL	MEGPTCL	--
70	400 KV	CHANDRAPUR - KHAPERKHEDA	28-Sep-18	08:00	28-Sep-18	18:00	Daily	"works such as Line Signature by Tuarus Kit ,Faulty disc strings replacement found during PID test."	MSETCL	MSETCL	--
71	400 KV	BUS COUPLER @ KHADKA	29-Sep-18	08:00	29-Sep-18	18:00	Daily	CT C & Tan delta test	MSETCL	MSETCL	--
72	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	29-Sep-18	08:00	29-Sep-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I , 501 MVA ICT -III and ICT-IV will be in service