

Maharashtra State Load Despatch Centre										
WRPC OCCM approved Monthly Outage list for the Month of Sep'2019										
Sr.No.	OCCM Sr. No.	Line / Element	From Date	From Time	To Date	To Time	Basis	reason	Name of Requesting Agency	Remarks
1	2	LONIKHAND-II - 400KV - BUS 2	01/Sep/2019	09:00	01/Sep/2019	19:00	Daily	400kV online Busbar Relay Testing / (Bus bar protection out)	MSETCL	Bus will be in service. Only Bus bar protection required out of service.
2	3	LONIKHAND-II - 400KV - BUS 1	01/Sep/2019	09:00	01/Sep/2019	19:00	Daily	400kV online Busbar Relay Testing / (Bus bar protection out)	MSETCL	Bus will be in service. Only Bus bar protection required out of service.
3	4	765KV-AKOLA (2)-EKTUNI-2	01/Sep/2019	08:00	02/Sep/2019	18:00	Daily	Annual Maintenance of Line, Line equipments	MEGPTCL	Annual Maintenance of Line, Line equipments
4	10	400KV-DHULE-MS-BABLESHWAR-1	01/Sep/2019	08:00	10/Sep/2019	18:00	Daily	PID testing work	MSETCL	AR required in non auto
5	11	400KV-DHULE-MS-BABLESHWAR-2	01/Sep/2019	08:00	10/Sep/2019	18:00	Daily	PID testing work	MSETCL	AR required in non auto
6	12	220KV-WARDHA-PUSAD-1	01/Sep/2019	07:00	30/Sep/2019	17:00	Daily	PID works	MSETCL	Except sundays.
7	41	220KV-WARDHA-BADNERA-1	02/Sep/2019	08:00	14/Sep/2019	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	For PID work
8	47	400KV-DHULE-DHULE-MS-1	03/Sep/2019	09:00	03/Sep/2019	17:00	Daily	Routine maintenance and testing work	MSETCL	CB DCRM testing work
9	48	400KV-WARDHA-WARORA-1	03/Sep/2019	09:00	03/Sep/2019	17:00	Daily	Attending the issues of 400 KV related to SCADA and Protection in co-ordination with M/s Sifang and testing work	MSETCL	400 KV Warora- IEPL Ckt is in service.
10	49	400KV-WARDHA-WARORA-1	03/Sep/2019	09:00	03/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	400KV WARORA-IEPL Line is in ckt
11	67	400KV-CHANDRAPUR-BHADRAWATI-3	03/Sep/2019	11:00	03/Sep/2019	13:00	Daily	1) Making cut out on control panel for installation the contact multiplier relay. 2) Fixing of contact multiplier relay and wiring work.	MSETCL	During this outage period, the 400KV CHD-PGCIL Bhadrawati Ckt. No.- I, II and IV bays/lines will be in service.
12	96	400KV-DHULE-DHULE-MS-2	04/Sep/2019	09:00	04/Sep/2019	17:00	Daily	Routine maintenance and testing work	MSETCL	CB DCRM testing work
13	97	132KV-MANSAR-MS-PENCH-1	04/Sep/2019	09:00	04/Sep/2019	17:00	Daily	Routine maint work	MSETCL	NIL
14	102	220KV-PARLI-OSMANABAD-M-1	04/Sep/2019	09:00	04/Sep/2019	18:00	Daily	Tower shifting work at Loc.No.10-11 for National Highway 211 crossing	MSETCL	-
15	118	400KV-SOLAPUR-M-SOLAPUR-1	04/Sep/2019	10:00	04/Sep/2019	18:00	Daily	Diagnostic Testing work	MSETCL	Load will be manged on 400 kv Lamboti Parli Line
16	129	400KV-PADGHE-BOISAR-1	04/Sep/2019	10:00	05/Sep/2019	12:00	C	Replacement of Line CT at Padghe (MSETCL) end due to oil leakage.	POWERGRID_WR1	
17	150	400KV-WARDHA-KORADI-II-1	05/Sep/2019	09:00	05/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	400KV WARORA-IEPL Line is in ckt
18	151	400KV-EKTUNI-BABLESHWAR-2	05/Sep/2019	09:00	05/Sep/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	-
19	163	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	05/Sep/2019	10:00	05/Sep/2019	14:00	Daily	Bushing urrection work for 709 LR R-ph	MEGPTCL	Bushing urrection work for 709 LR R-ph
20	190	220KV Pandhurna-Kamleshwar	06/Sep/2019	9:00	06/Sep/2019	18:00	D	For bay equipment maintenance and testing work	MP_SLDC	
21	200	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	06/Sep/2019	10:00	06/Sep/2019	10:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)Station Transformer II will remain in service through Main Bay 407 & Koradi-II Ckt-I will remain service through Main Bay 409 2) Outage subject to weather Condition & availability of Kit.
22	203	MAIN BAY - AKOLA - 765KV B/R 1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	06/Sep/2019	10:00	06/Sep/2019	18:00	Daily	Commissioning activity of CBS Lite	MEGPTCL	Commissioning activity of CBS Lite
23	204	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	06/Sep/2019	10:30	06/Sep/2019	11:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)400KV Koradi-II Koradi-III Ckt.-I will remain service through Tie Bay 408. 2) Outage subject to weather Condition & availability of Kit.
24	205	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	06/Sep/2019	11:00	06/Sep/2019	11:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)400KV Wardha(PG) line will remain service through Tie Bay 411. 2) Outage subject to weather Condition & availability of Kit.
25	225	MAIN BAY - 400KV/11.5KV KORADI-II-ST-3 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	07/Sep/2019	09:30	07/Sep/2019	10:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)station transformer III will remain in service through tie bay 405. 2) Outage subject to weather Condition & availability of Kit.
26	226	TIE BAY (405) OF STN T/F-3 & KORADI 3 CKT-2	07/Sep/2019	10:00	07/Sep/2019	10:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	Station Transformer III will remain in service through Main Bay 404 & Koradi-II Ckt-II will remain service through Main Bay 406
27	228	400KV-KALA-KUDUS-2	07/Sep/2019	10:00	07/Sep/2019	17:00	Daily	1. Annual maint. work. 2. Diagnostics testing work of CB, CT etc.	MSETCL	400KV Kala-Kudus Ckt-1 will be in service
28	229	MAIN BAY - AKOLA - 765KV B/R 1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	07/Sep/2019	10:00	07/Sep/2019	18:00	Daily	Commissioning activity of CBS Lite	MEGPTCL	Commissioning activity of CBS Lite
29	232	MAIN BAY - 400KV/11.5KV KORADI-II-ST-2 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	07/Sep/2019	10:30	07/Sep/2019	11:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)station transformer II will remain in service through tie bay 408. 2) 400kv Wardha PG line will remain service through Main Bay 412.
30	233	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	07/Sep/2019	11:00	07/Sep/2019	11:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	2) Outage subject to weather Condition & availability of Kit.

Sr.No.	OCCM Sr. No.	Line / Element	From Date	From Time	To Date	To Time	Basis	reason	Name of Requesting Agency	Remarks
31	261	BUS COUPLER BAY - PARLI M - 400KV - BUS 1 AND PARLI M - 400KV - BUS 2 at PARLI M - 400KV	09/Sep/2019	09:00	09/Sep/2019	18:00	Daily	Back up protection relay testing work & Bay Maintenance work.	MSETCL	
32	272	400KV-KALA-KUDUS-1	09/Sep/2019	10:00	09/Sep/2019	17:00	Daily	1. Annual maint. work. 2. Diagnostics testing work of CB, CT etc.	MSETCL	400KV Kala-Kudus Ckt-2 will be in service
33	274	TIE BAY - 702 OF BUS REACTOR AND 765/400KV 1500MVA ICT @ AKOLA 2	09/Sep/2019	10:00	09/Sep/2019	18:00	Daily	Commissioning activity of CBS Lite	MEGPTCL	Commissioning activity of CBS Lite
34	281	400KV-KORADI-BHUSAWAL-1	09/Sep/2019	08:00	13/Sep/2019	18:00	Continuous	Restraining of conductor of all three phases of 400 kv Koradi-Bhusawal line due to conversion of Metergauge to Broadgauge of Akola-Bhusawal line and also for maintenance work of line.	MSETCL	400 kv Akola- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
35	283	400KV-SSP-DHULE-MS-1	09/Sep/2019	08:00	21/Sep/2019	16:00	Daily	On Line PID Testing	MSETCL	on linet testing
36	284	400KV-SSP-DHULE-MS-2	09/Sep/2019	08:00	21/Sep/2019	16:00	Daily	PID on line testing	MSETCL	On line PID testing
37	297	400KV-WARORA-CHANDRAPUR-II-1	10/Sep/2019	09:00	10/Sep/2019	17:00	Daily	Attending the issues of 400 KV related to SCADA and Protection in co-ordination with M/s Sifang and testing work	MSETCL	Load will be managed on 400KV Chandrapur Ckt-2
38	320	220KV-WARDHA-BHUGAON-1	10/Sep/2019	10:00	14/Sep/2019	18:00	Daily	Tightening of jumper nut bolt at loc. No.02, 04 and other work.	MSETCL	NA
39	321	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	10/Sep/2019	09:00	10/Sep/2019	18:00	Daily	Bay Maintenance Work	MSETCL	Bay Maintenance Work
40	329	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	11/Sep/2019	08:00	11/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	NA
41	330	220KV-PANDURNA-KALMESHWAR-1	11/Sep/2019	08:00	11/Sep/2019	17:00	Daily	Routine Maintenance work	MSETCL	OUTAGE PROPOSED BY LMU S/Dn Mankapur .
42	339	CHANDRAPUR SWITCHING STATION - 400KV - BUS 1	11/Sep/2019	09:00	11/Sep/2019	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	400KV BUS-1 CVT TAN DELTA & BAY MAINTENANCE WORK
43	340	400KV-PARLI-M-SOLAPUR-M-1	11/Sep/2019	09:00	11/Sep/2019	18:00	Daily	Line and bay maintenance work	MSETCL	-
44	341	220KV-PARLI-OSMANABAD-M-1	11/Sep/2019	09:00	11/Sep/2019	18:00	Daily	Tower shifting work at Loc.No.10-11 for National Highway 211 crossing	MSETCL	-
45	346	220KV-WARDHA-WARDHA-M-1	11/Sep/2019	9:00	11/Sep/2019	18:00	D	For AMP work	POWERGRID_WR1	
46	372	TIE BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV B/R 1 at TIRODA - 765KV	12/Sep/2019	08:00	12/Sep/2019	18:00	Daily	Testing & Maintenance of bay Equipments	MEGPTCL	Testing & Maintenance of bay Equipments
47	378	400KV-TARAPUR 3&4-BOISAR-2	12/Sep/2019	9:00	12/Sep/2019	14:00	D	main relay replacement & for tripping and A/R trials on main relay (Line will be out of service). A/R OFF of ckt-1 and dia to be kept open at both ends.	POWERGRID_WR2	
48	381	CHANDRAPUR SWITCHING STATION - 400KV - BUS 2	12/Sep/2019	09:00	12/Sep/2019	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	for Diagnostic testing & allied bay maintenance work
49	382	220KV-WARDHA-PUSAD-1	12/Sep/2019	09:00	12/Sep/2019	18:00	Daily	For Routine Maintainance Work	MSETCL	nil
50	384	TIE BAY - 400KV-PARLI-PUNE-PG-2 AND 400KV-WARORA-PG-PARLI-2 at PARLI - 400KV	12/Sep/2019	9:00	12/Sep/2019	18:00	D	For bay AMP works	POWERGRID_WR1	
51	393	400KV-KORADI-II-KORADI-III-1	12/Sep/2019	10:00	12/Sep/2019	17:00	Daily	Testing of High teed relay	MSETCL	400KV Koradi-II - Koradi-III Ckt. 2 will remain in service as alternate source
52	395	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	12/Sep/2019	10:00	12/Sep/2019	18:00	D	FOR AMP WORKS.	POWERGRID_WR1	A/R to be kept in non Auto mode for ckt-1 , dia to be kept open for relay testing works
53	423	400KV-KORADI-II-KORADI-III-2	13/Sep/2019	10:00	13/Sep/2019	17:00	Daily	Testing of Distance Protection Scheme	MSETCL	400KV Koradi-II - Koradi-III Ckt. 1 will remain in service as alternate source
54	429	400KV-CHANDRAPUR-BHADRAWATI-1	13/Sep/2019	09:00	15/Sep/2019	18:00	Continuous	For replacement of old S & S power line 400KV K. I & B-PH PG-1 Isolator (400KV Main Bus-1 Isolator) during bus outage.	MSETCL	During this outage period, the 400KV CHD-PGCL Bhadrawati Ckt. No.- II, III and IV bays/lines will be in service.
55	430	400KV/11.5KV CHANDRAPUR-GCR-ST-5	13/Sep/2019	09:00	15/Sep/2019	18:00	Continuous	Permission for shifting of 400KV STN T/F No.- V bay on TBC-II bay.	MSETCL	During, this outage 400KV HVDC Ckt. No.- 1 will be in service. The 400KV STN T/F No.-V bay will be shift on TBC-2 bay required as the work of replacement of bus conductor of Main Bus-1 is to be carried out in STN-5 bay.
56	431	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	13/Sep/2019	09:00	15/Sep/2019	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in HVDC- II and 400KV STN T/F No.- 5 bay section span. 2) Tightening of nut bolts & hardware of Main Bus-I.	MSETCL	During, this outage 400KV HVDC Ckt. No.- 1 will be in service. The outage on 400KV HVDC Ckt. No.-2 bay is required as the work of replacement of bus conductor of Main Bus-1 is to be carried out in HVDC Ckt. N-2 bay.
57	432	CHANDRAPUR - 400KV - BUS 1	13/Sep/2019	09:00	15/Sep/2019	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in HVDC- II and 400KV STN T/F No.- 5 bay section span. 2) Tightening of nut bolts & hardware of Main Bus-I.	MSETCL	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
58	450	BUS COUPLER BAY - BHUSAWAL - 400KV - BUS 1 AND BHUSAWAL - 400KV - BUS 2 at BHUSAWAL - 400KV	14/Sep/2019	06:00	14/Sep/2019	18:00	Daily	CT tan-Delta and routine bay maintenance.	MSETCL	nil
59	453	220KV-BOISAR-BOISAR-M-1	14/Sep/2019	09:00	14/Sep/2019	17:00	Daily	REPLACEMENT OF MISSING EARTH-WIRE	MSETCL	-
60	462	TIE BAY - 400KV-KALWA-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-3 at PUNE-PG - 400KV	14/Sep/2019	9:00	14/Sep/2019	18:00	D	For AMP Works	POWERGRID_WR1	
61	465	220KV-BOISAR-NALASOPARA-1	15/Sep/2019	9:00	15/Sep/2019	18:00	D	For AMP & 220kv Bus-II CVT replacement and also Outage With 220kv Boisar-Nalasopara Line & 220kv Boisar-Boisar-1 Line	POWERGRID_WR2	

Sr.No.	OCCM Sr. No.	Line / Element	From Date	From Time	To Date	To Time	Basis	reason	Name of Requesting Agency	Remarks
62	466	220KV-BOISAR-BOISAR-M-1	15/Sep/2019	9:00	15/Sep/2019	18:00	D	For AMP & 220kv Bus-II CVT replacement and also Outage With 220kv Boisar-Nalasopara Line & 220kv Boisar-Boisar-1 Line	POWERGRID_WR2	
63	467	BOISAR - 220KV - BUS 2	15/Sep/2019	9:00	15/Sep/2019	18:00	D	For AMP & 220kv Bus-II CVT replacement and also Outage With 220kv Boisar-Nalasopara Line & 220kv Boisar-Boisar-1 Line	POWERGRID_WR2	
64	477	400KV-PADGHE-BOISAR-1	15/Sep/2019	9:00	15/Sep/2019	14:00	D	Main-I relay replacement & For tripping and A/R Trials of Main-I relay (Line will be out of service), dia to be kept open at both ends.	POWERGRID_WR2	
65	490	400KV-BABLESHWAR-PADGHE-PG-1	16/Sep/2019	09:00	17/Sep/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing and for string replacement	MSETCL	-
66	498	400KV-WARORA-CHANDRAPU-II-2	16/Sep/2019	09:00	16/Sep/2019	17:00	Daily	Attending the issues of 400 KV related to SCADA and Protection in co-ordination with M/s Sifang and testing work	MSETCL	Load will be managed on 400KV Chandrapur Ckt-1
67	499	220KV-WARDHA-BADNERA-1	16/Sep/2019	09:00	16/Sep/2019	17:00	Daily	For measurement of C& Tan delta of R, Y & B phase CT and Circuit Breaker CRM	MSETCL	nil
68	508	400KV-PARLI-M-PARLI-1	16/Sep/2019	9:00	16/Sep/2019	18:00	D	For protection testing and Line terminal AMP works & Ckt-2 AR to be kept in non auto mode during outage period.	POWERGRID_WR1	Ckt-2 AR to be kept in non auto mode during outage period.Dia to be kept open for relay testing works
69	520	400KV-ALKUD-SOLAPUR-1	16/Sep/2019	10:00	16/Sep/2019	17:30	Daily	Quarterly maintenance work	MSETCL	Load will be managed on 400KV ALKUD-KOLHAPUR LINE
70	521	ALKUD - 400KV - BUS 1	16/Sep/2019	10:00	16/Sep/2019	17:30	Daily	Quarterly maintenance work	MSETCL	Load will be managed on Bus II
71	526	400KV-RGPPL-NEW KOYNA-2	16/Sep/2019	08:00	18/Sep/2019	18:00	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work	MSETCL	Load can be managed on Dabhol-New Koyna -I line
72	528	400KV-BHUSAWAL-AKOLA-1	16/Sep/2019	08:00	20/Sep/2019	18:00	Continuous	Restraining of conductor or all three phases of 400 kv Akola-Bhusawal line due to conversion of Metergauge to Broadgauge of Akola Railway line and also for maintenance work of line.	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
73	530	400KV-CHANDRAPU-II-NANDED-2	16/Sep/2019	08:00	30/Sep/2019	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	nil
74	531	400KV-CHANDRAPUR-GCR-PARLI-M-3	16/Sep/2019	08:00	30/Sep/2019	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	nil
75	545	CHANDRAPU-II - 400KV - BUS 2	17/Sep/2019	09:00	17/Sep/2019	18:00	Daily	for diagnostic testing and allied bay maintenance work	MSETCL	400KV BUS-2 CVT TAN DELTA & BAY MAINTENANCE WORK
76	561	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	17/Sep/2019	10:00	17/Sep/2019	14:00	Daily	To carry out changeover activities.	MEGPTCL	To carry out changeover activities.
77	567	220KV-WARDHA-PUSAD-1	17/Sep/2019	10:00	21/Sep/2019	18:00	Daily	Tightening of jumper nut bolt at loc. No.76 ,17,01,08,12 and, 78 carona ring nut bolt .	MSETCL	NA
78	568	220KV-WARDHA-BADNERA-1	17/Sep/2019	08:00	28/Sep/2019	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	For PID work
79	572	400KV-BABLESHWAR-PADGHE-PG-2	18/Sep/2019	09:00	19/Sep/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing and for string replacement	MSETCL	-
80	576	220KV-TARAPUR 3&4-BOISAR-1	18/Sep/2019	9:00	18/Sep/2019	14:00	D	Main-I relay replacement & For tripping and A/R Trials of Main-I relay (Line will be out of service)	POWERGRID_WR2	
81	578	220KV-WARDHA-WARDHA-M-1	18/Sep/2019	08:00	18/Sep/2019	05:00	Daily	Maintenance work on line to attende the defect observed in monkey patrolling	MSETCL	NA
82	579	220KV-PARLI-OSMANABAD-M-1	18/Sep/2019	08:00	18/Sep/2019	16:00	Daily	Line maintenance	MSETCL	-
83	581	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-1	18/Sep/2019	08:00	18/Sep/2019	17:00	Continuous	For Conductor & Earthwire Hardware tightening work	MSETCL	For Conductor & Earthwire Hardware tightening work
84	582	220KV-TILLARI-AMONA-1	18/Sep/2019	08:00	18/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	NA
85	584	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	18/Sep/2019	08:00	18/Sep/2019	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	APML	Testing & Maintenance of Bay Breaker & CT
86	587	132KV-PENCH-KANHAN-1	18/Sep/2019	09:00	18/Sep/2019	17:00	Daily	Routine maint work	MSETCL	NIL
87	589	400KV-PARLI-M-SOLAPUR-M-1	18/Sep/2019	09:00	18/Sep/2019	18:00	Daily	Diagnostic testing work	MSETCL	Load will be managed on 400 kv Lamboti-PGCL IINE.
88	619	220KV-WARDHA-BADNERA-1	19/Sep/2019	8:00	19/Sep/2019	15:00	Daily	Maintenance work on line to attende the defect observed in monkey patrolling	MSETCL	NA
89	621	400KV-EKTUNI-BABLESHWAR-1	19/Sep/2019	09:00	19/Sep/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	-
90	626	400KV-PARLI-M-PARLI-1	19/Sep/2019	09:00	19/Sep/2019	18:00	Daily	Distance relay testing work	MSETCL	-
91	637	765KV-TIRODA-KORADI-III-2	19/Sep/2019	15:00	19/Sep/2019	22:00	Daily	Bushing dismantling work	APML	Bushing dismantling work
92	638	TALEGAON - 220KV - BUS 1	19/Sep/2019	9:00	19/Sep/2019	18:00	D	Replacement of Clamp & connectors	POWERGRID_WR1	
93	645	400KV-RGPPL-NAGOTHANE-1	19/Sep/2019	08:00	21/Sep/2019	18:00	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work	MSETCL	Load can be managed on Dabhol-Nagothane -II line
94	648	765KV-TIRODA-KORADI-III-2 L/R@ TIRODA - 765KV	19/Sep/2019	06:00	04/Oct/2019	18:00	Continuous	Replacement of Reactor	APML	Replacement of Reactor
95	664	MAIN BAY - 400KV/11.5KV TIRODA-ST-5 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	20/Sep/2019	08:00	20/Sep/2019	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	APML	Testing & Maintenance of Bay Breaker & CT
96	668	220KV-BOISAR-NALASOPARA-1	20/Sep/2019	09:00	20/Sep/2019	17:00	Daily	REPLACEMENT OF PID FAULTY INSULATOR STRING	MSETCL	-

Sr.No.	OCCM Sr. No.	Line / Element	From Date	From Time	To Date	To Time	Basis	reason	Name of Requesting Agency	Remarks
97	682	MAIN BAY - 400KV-KORADI-II-KORADI-III-3 AND KORADI-III - 400KV - BUS 2	20/Sep/2019	10:00	20/Sep/2019	18:00	Daily	To carry out maintenance of line related equipments	MEGPTCL	-
98	707	400KV-PARLI-M-LONIKHAND-II-1	21/Sep/2019	09:00	21/Sep/2019	18:00	Daily	Half yearly maintenance and diagnostic testing work	MSETCL	-
99	716	PUNE-PG - 400KV - BUS 1	22/Sep/2019	9:00	22/Sep/2019	18:00	D	Replacement of Clamp & connectors	POWERGRID_WR1	
100	719	400KV-TARAPUR 3&4-PADGHE-2	22/Sep/2019	9:00	23/Sep/2019	18:00	C	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	TAPS34	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
101	720	CHANDRAPUR - 400KV - BUS 1	22/Sep/2019	09:00	24/Sep/2019	18:00	Continuous	Replacement of damaged bus conductor in 400KV HVDC Ckt. No.-I & GTR-VI bay and Bus coupler bay section.	MSETCL	During this outage period, the all feeders/circuit connected to 400KV Main Bus-I will be shifted on 400KV Main Bus-II. After shifting of all feeders/circuits, the 400KV Bus Coupler bay will be kept OFF.
102	721	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	22/Sep/2019	09:00	24/Sep/2019	18:00	Continuous	Replacement of damaged bus conductor in 400KV HVDC Ckt. No.-I & GTR-VI bay and Bus coupler bay section.	MSETCL	During, this outage 400KV HVDC Ckt. No.- 2 will be in service. The outage on 400KV HVDC Ckt. No.-1 bay is required as the work of replacement of bus conductor of Main Bus-1 is to be carried out in HVDC ckt. No.-1 bay
103	722	GTR - 6 @ CHANDRAPUR	22/Sep/2019	09:00	24/Sep/2019	18:00	Continuous	Permission for shifting of 400KV GT - 6 bay on TBC-II bay.	MSETCL	During, this outage 400KV HVDC Ckt. No.- 2 will be in service. The 400KV GT-6 bay will be shift on TBC-2 bay required as the work of replacement of bus conductor of Main Bus-1 is to be carried out in GT-6 bay.
104	727	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	22/Sep/2019	10:00	22/Sep/2019	18:00	Daily	For additional safety for working conditions, it is requested to approve shutdown on 765/400KV, 500MVA, Spare ICT Unit along with ICT-I.	MSETCL	Being Spare ICT Unit, it is on NO LOAD
105	728	765KV/400KV EKTUNI-ICT-2	22/Sep/2019	10:00	22/Sep/2019	18:00	Daily	High Insulation coating work on ICT Delta formation	MSETCL	765/400KV ICT-I will be in service.
106	729	400KV-RGPP-L-NAGOTHANE-2	22/Sep/2019	08:00	22/Sep/2019	18:00	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work	MSETCL	Load can be managed on Dabhol-Nagotnae CKT-I line
107	731	400KV-BABLESHWAR-PADGHE-PG-2	22/Sep/2019	08:00	30/Sep/2019	18:00	Daily	PID testing work	MSETCL	AR required in non auto
108	742	400KV-RGPP-L-NEW KOYNA-1	23/Sep/2019	08:00	23/Sep/2019	18:00	Daily	Routine maint. Work & Faulty string replacement Work	MSETCL	Load can be managed on Dabhol-New Koyna CKT-II line
109	743	400KV-SSP-DHULE-MS-2	23/Sep/2019	08:00	23/Sep/2019	18:00	Daily	Replacement of suspicious faulty strings if found in PID testing.	MSETCL	Replacement of suspicious faulty strings if found in PID testing. AR out of Ckt 1 required
110	760	MAIN BAY - 400KV/11.5KV KORADI-II-ST-3 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	23/Sep/2019	13:00	23/Sep/2019	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
111	761	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	23/Sep/2019	15:00	23/Sep/2019	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
112	762	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	23/Sep/2019	9:00	23/Sep/2019	18:00	D	Replacement of Clamp & connectors	POWERGRID_WR1	
113	773	400KV-DHULE-MS-BABLESHWAR-2	23/Sep/2019	08:00	27/Sep/2019	18:00	Daily	on line PID testing	MSETCL	On line PID testing
114	774	400KV-DHULE-MS-BABLESHWAR-1	23/Sep/2019	08:00	27/Sep/2019	18:00	Daily	On PID testing	MSETCL	on line PID testing
115	777	AURANGABAD-M (WALUJ) - 400KV - BUS 2	24/Sep/2019	09:00	24/Sep/2019	17:00	Daily	Routine maintenance of 400KV Bableshwar bay @ waluj end	MSETCL	Routine Maintenance
116	778	CHANDRAPUR - PADGHA POLE 1 & 2	24/Sep/2019	06:00	30/Sep/2019	18:00	Continuous	Work of 2 nos of tower Erection(Loc. no. 285 & 286) and stringing of. 16 span of towers(Loc. no. 278-294) for the Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambezary Dam.	MSETCL	ORC work of Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambezary Dam.
117	782	MAIN BAY - 400KV/KV TIRODA-ST-3 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	24/Sep/2019	08:00	24/Sep/2019	18:00	Daily	Testing & Maintenance of ICT & Its Relay	APML	Testing & Maintenance of ICT & Its Relay
118	783	400KV-SSP-DHULE-MS-2	24/Sep/2019	08:00	24/Sep/2019	18:00	Daily	Replacement of PID suspicious string if found faulty in PID testing	MSETCL	Replacement of PID suspicious string if found faulty in PID testing. AR out of Ckt 1 required
119	784	MAIN BAY - 400KV/11.5KV KORADI-II-ST-2 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	24/Sep/2019	09:00	24/Sep/2019	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
120	799	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	24/Sep/2019	11:00	24/Sep/2019	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
121	800	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	24/Sep/2019	13:00	24/Sep/2019	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
122	801	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	24/Sep/2019	15:00	24/Sep/2019	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
123	808	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	25/Sep/2019	9:00	25/Sep/2019	18:00	D	For AMP work	POWERGRID_WR1	
124	810	PUNE-PG - 400KV - BUS 2	25/Sep/2019	9:00	25/Sep/2019	18:00	D	Replacement of Clamp & connectors	POWERGRID_WR1	
125	811	CHANDRAPU-II - 400KV - BUS 1	25/Sep/2019	09:00	25/Sep/2019	18:00	Daily	for diagnostic testing and allied bay maintenance work	MSETCL	400KV BUS-1 CVT TAN DELTA & BAY MAINTENANCE WORK
126	813	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	25/Sep/2019	10:00	25/Sep/2019	18:00	Daily	For additional safety for working conditions, it is requested to approve shutdown on 765/400KV, 500MVA, Spare ICT Unit along with ICT-I.	MSETCL	Being Spare Unit, it is on NO LOAD

Sr.No.	OCCM Sr. No.	Line / Element	From Date	From Time	To Date	To Time	Basis	reason	Name of Requesting Agency	Remarks
127	814	765KV/400KV EKTUNI-ICT-1	25/Sep/2019	10:00	25/Sep/2019	18:00	Daily	High Insulation coating work on ICT Delta formation	MSETCL	765/400KV ICT-II will be in service.
128	820	220KV-PARLI-OSMANABAD-M-1	25/Sep/2019	08:00	25/Sep/2019	16:00	Daily	line maintenance	MSETCL	-
129	825	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	25/Sep/2019	09:00	25/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	Line will be charged through Tie CB 428.
130	845	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	26/Sep/2019	9:00	26/Sep/2019	18:00	D	For AMP works.	POWERGRID_WVR1	
131	846	AURANGABAD-M (WALUJ) - 400KV - BUS 2	26/Sep/2019	09:00	26/Sep/2019	17:00	Daily	ROUTINE MAINTENANCE	MSETCL	ROUTINE MAINTENANCE
132	849	MAIN BAY - 404 OF 765/400kv 1500MVA ICT @ AKOLA 2	26/Sep/2019	09:00	26/Sep/2019	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	Annual Maintenance of Bay Equipments
133	859	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	26/Sep/2019	09:00	26/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
134	860	220KV-WARDHA-PUSAD-1	26/Sep/2019	09:00	26/Sep/2019	17:00	Daily	For Routine Maintanance Work	MSETCL	nil
135	864	400KV-KOLHAPUR-MS-ALKUD-1	26/Sep/2019	09:00	26/Sep/2019	18:00	Daily	Quarterly. Maint. work	MSETCL	-
136	871	MAIN BAY (414) OF TIRODA CKT - 2 @ WARORA	26/Sep/2019	10:00	27/Sep/2019	18:00	Daily	Replacement of Breaker	ATIL	Replacement of Breaker
137	877	NEW KOYNA - 400KV - BUS 1	26/Sep/2019	08:00	28/Sep/2019	18:00	Continuous	Cold washing, condutor replacement, Isolator replacement & Routine maint. Work	MSETCL	Main Bus-II will be in service
138	889	400KV-PARLI-M-LONIKHAND-II-2	27/Sep/2019	09:00	27/Sep/2019	18:00	Daily	Half yearly maintenance and diagnostic testing work	MSETCL	-
139	892	Tie Bay- 417 of Station Transformer 3@ Tirora	27/Sep/2019	08:00	27/Sep/2019	18:00	Daily	-	APML	Testing & Maintenance of Bay Breaker & CT
140	895	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400K	27/Sep/2019	09:00	27/Sep/2019	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	Line will be charged through mainCB 429.
141	896	220KV-TARAPUR 1&2-BOISAR-M-1	27/Sep/2019	09:00	27/Sep/2019	17:00	Daily	ERTH-WIRE REPLACEMENT & INSULATOR REPLACEMENT	MSETCL	-
142	900	400KV-KOLHAPUR-MS-SOLAPUR-2	27/Sep/2019	09:00	27/Sep/2019	18:00	Daily	Quarterly. Maint. work	MSETCL	-
143	906	400KV/220KV BOISAR-ICT-1	27/Sep/2019	9:00	27/Sep/2019	18:00	D	For AMP Works, dia to be kept open on both sides	POWERGRID_WVR2	
144	909	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-1 at PUNE-PG - 400KV	27/Sep/2019	9:00	27/Sep/2019	18:00	D	For AMP Works	POWERGRID_WVR1	
145	922	TIE BAY - 405 OF 765/400kv 1500MVA ICT & FUTURE BAY @ AKOLA 2	28/Sep/2019	09:00	28/Sep/2019	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	Annual Maintenance of Bay Equipments
146	929	AKOLA - 400KV - BUS 2	28/Sep/2019	10:00	28/Sep/2019	18:00	Daily	Routine maintenance & testing work	MSETCL	NA
147	934	400KV-KHARGHAR-PUNE-PG-1	28/Sep/2019	08:30	28/Sep/2019	18:00	Daily	R&M and Diagnostic testing work	MSETCL	--
148	935	220KV-BOISAR-BOISAR-M-2	28/Sep/2019	09:00	28/Sep/2019	17:00	Daily	Line Isoaltor repairing work.	MSETCL	-
149	937	BOISAR - 220KV - BUS 2	29/Sep/2019	9:00	29/Sep/2019	18:00	D	For AMP Works	POWERGRID_WVR2	
150	938	220KV-TALEGAON-PUNE-PG-1	29/Sep/2019	09:00	29/Sep/2019	17:00	Daily	Half yearly maintenance , Diagonastic Testing	MSETCL	-
151	942	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	29/Sep/2019	08:30	30/Sep/2019	18:00	Continuous	R&M and Diagnostic testing work	MSETCL	Outage required along with A Bus at Kharghar
152	943	KHARGHAR - 400KV - BUS 1	29/Sep/2019	08:30	30/Sep/2019	18:00	Continuous	R&M and diagnostic testing work	MSETCL	OUTAGE REQUIRED ALONG WITH BUS COUPLER @ KHARGHAR
153	945	220KV-BOISAR-BOISAR-M-3	29/Sep/2019	09:00	29/Sep/2019	17:00	Daily	Line Isoaltor repairing work.	MSETCL	-
154	947	NEW KOYNA - 400KV - BUS 2	29/Sep/2019	08:00	30/Sep/2019	18:00	Continuous	Cold washing, condutor replacement, Isolator replacement & Routine maint. Work	MSETCL	Main Bus-I will be in service
155	961	400KV/220KV WARDHA-ICT-1	30/Sep/2019	9:00	30/Sep/2019	18:00	D	For AMP work	POWERGRID_WVR1	
156	967	MAIN BAY - 400KV/220KV PUNE-PG-ICT-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	30/Sep/2019	9:00	30/Sep/2019	18:00	D	Replacement of Clamp & connectors	POWERGRID_WVR1	

Maharashtra State Load Despatch Centre												
State Element Outages list for the month of Sep'19												
Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	
1	400	AKOLA-NANDGAONPETH (RPL-AMT)	01-Sep-19	10:00	05-Sep-19	15:00	Daily	PID testing of insulator strings by PID Uint Akola of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.	
2	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01-Sep-19	08:00	15-Sep-19	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.	
3	400	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	03-Sep-19	11:00	07-Sep-19	17:00	Daily	PID Work	MSETCL	MSETCL	By reclose from auto mode	
4	400	KORADI-KHADKA	03-Sep-19	13:00	03-Sep-19	16:00	Daily	For Line Signature Analysis	MSETCL	MSETCL	NIL	
5	400	KARAD - TALANDGE CKT 1	03-Sep-19	09:00	03-Sep-19	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	-	
6	400	AKOLA - KHADKA (BHUSAWAL)	03-Sep-19	08:00	03-Sep-19	12:00	Daily	For Line Signature Analysis	MSETCL	MSETCL	NIL	
7	400	KARAD - TALANDGE CKT 1	03-Sep-19	10:00	03-Sep-19	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load will be managed on 400 kV Karad-Talandge 2	
8	400	PARLI - KUMBHARGAON(NANDED) CKT - 2	04-Sep-19	09:00	04-Sep-19	18:00	Daily	C & Tan Delta measurement of CT Line maintenance work & Bay maintenance.	MSETCL	MSETCL	-	
9	400	KORADI-KHAPERKHEDA II	04-Sep-19	10:00	04-Sep-19	17:00	Daily	Diagnostic Testing & Routine maintenance work	MSETCL	MSETCL	nil	
10	400	KHADKA- DEEPNAGAR CKT 1	04-Sep-19	08:00	04-Sep-19	18:00	Daily	CT, CVT Tan-Delta and CB DCRM and routine bay maintenance	MSETCL	MSETCL	Load will be shifted on 400 KV Deepnagar-II Ckt	
11	400	TIE BAY (402) of WALUJ @ TAPTITANDA	04-Sep-19	11:00	04-Sep-19	17:00	Daily	Teed protection relay testing	MSETCL	MSETCL	Nil	
12	400	MAIN BAY KHADKA- DEEPNAGAR CKT 1	04-Sep-19	09:00	04-Sep-19	13:00	Daily	Main CB DCRM	MSETCL	MSETCL	The Ckt will be in service through tie CB	
13	400	WARORA - IEPL	04-Sep-19	09:00	04-Sep-19	17:00	Daily	Attending the issues of 400 KV related to SCADA and Protection in co-ordination with M/s Sifang and testing work	MSETCL	MSETCL	400 KV Warora- PGCIL Ckt is in service.	
14	400	WARORA - IEPL	04-Sep-19	09:00	04-Sep-19	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400KV KORADI-WARDHA Line is in ckt	
15	400	MAIN BAY (403) of WALUJ @ TAPTITANDA	04-Sep-19	11:00	04-Sep-19	17:00	Daily	Teed protection relay testing work	MSETCL	MSETCL	Nil	
16	400	SPARE LINE-1 BAY (401) @ TAPTITANDA	04-Sep-19	11:00	04-Sep-19	17:00	Daily	Teed protection relay testing	MSETCL	MSETCL	Nil	
17	400	TIE BAY KHADKA- DEEPNAGAR CKT 1	04-Sep-19	14:00	04-Sep-19	18:00	Daily	DCRM of Tie CB	MSETCL	MSETCL	The Line will be in service through main CB	
18	400	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	05-Sep-19	09:00	05-Sep-19	18:00	Daily	Half yearly maintenance and diagnostic testing work	MSETCL	MSETCL	-	
19	400	KARAD - LONIKAND 1	05-Sep-19	10:00	05-Sep-19	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load will be managed on other Ckt	
20	400	JEJURI- KOYNA STAGE-IV	05-Sep-19	09:00	05-Sep-19	18:00	Daily	Annual testing & maint.	MSETCL	MSETCL	During the outage 400kV Jejuri-Lonikand line will be in service	
21	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	05-Sep-19	09:00	05-Sep-19	18:00	Daily	Half yearly maintenance and diagnostic testing work	MSETCL	MSETCL	-	
22	400	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	05-Sep-19	10:00	05-Sep-19	17:00	Daily	Routine Maintenance & testing works.	MSETCL	MSETCL	NA	
23	400	KHADKA- DEEPNAGAR CKT 2	05-Sep-19	08:00	05-Sep-19	12:00	Daily	For Line Signature Analysis	MSETCL	MSETCL	NIL	
24	400	MIAN BAY-421 OF ICT - 2 @ KORADI - 2	06-Sep-19	12:30	06-Sep-19	13:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)ICT-II will remain service through Tie Bay 420. 2) Outage subject to weather Condition & availability of Kit.	
25	400	KORADI-NANDGAONPETH (RPL)	06-Sep-19	09:00	06-Sep-19	18:00	Daily	Diagnostic testing work.	MSETCL	MSETCL	Outages will be availed subject to weather conditions	
26	400	AKOLA-NANDGAONPETH (RPL-AMT)	06-Sep-19	07:00	07-Sep-19	18:00	Daily	Work of replacing broken Spacers cum vibration dampers with new on Lilo line by agency.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.	
27	400	DEEPNAGAR - THAPTI TANDA	06-Sep-19	08:00	06-Sep-19	12:00	Daily	For Line Signature Analysis	MSETCL	MSETCL	NIL	
28	400	DEEPNAGAR - AURANGABAD (WALUJ)	06-Sep-19	13:00	06-Sep-19	16:00	Daily	FOR Line Signature Analysis	MSETCL	MSETCL	NIL	
29	400	MAIN BAY - 418 OF IEPL @ KORADI-2	06-Sep-19	12:00	06-Sep-19	12:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)400KV IEPL Line will remain servie through Tie Bay 417. 2) Outage subject to weather Condition & availability of Kit	
30	400	TIE BAY-426 OF GT-8 @ KORADI-2	06-Sep-19	14:00	06-Sep-19	14:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)GT#08 will remain in service through Main Bay 425. 2) Outage subject to weather Condition & availability of Kit.	
31	400	TIE BAY (423) OF STATION TF - 1 @ KORADI 2	06-Sep-19	13:00	06-Sep-19	13:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Main Bay 422. 2) Outage subject to weather Condition & availability of Kit.	
32	400	TIE BAY-402 OF GT-10 @ KORADI-2	06-Sep-19	09:00	06-Sep-19	09:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1) GT10 will remain in service through Main Bay 401. 2) Outage subject to weather Condition & availability of Kit.	
33	400	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	06-Sep-19	14:30	06-Sep-19	15:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)ICT-I will remain service through Tie Bay 429. 2) Outage subject to weather Condition & availability of Kit.	

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
34	400	400/220/33KV SPARE ICT @ KORADI 2	06-Sep-19	15:00	06-Sep-19	15:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)Spare ICT is On No Load 2) Outage subject to weather Condition & availability of Kit.
35	400	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	06-Sep-19	09:00	06-Sep-19	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
36	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	07-Sep-19	08:00	07-Sep-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220KV 315MVA ICT - II , 501 MVA ICT -III& IV will be in service
37	400	TIE BAY (429) OF ICT - 1 @ KORADI - 2	07-Sep-19	14:30	07-Sep-19	15:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)ICT-I will remain service through Main Bay 430 2) Outage subject to weather Condition & availability of Kit.
38	400	KHADKA - BABLESHWAR	07-Sep-19	13:00	07-Sep-19	16:00	Daily	FOR LSA	MSETCL	MSETCL	NIL
39	400	KHADKA - BABLESHWAR	07-Sep-19	09:00	07-Sep-19	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	-
40	400	TIE BAY-420 OF ICT - 2 @ KORADI -2	07-Sep-19	12:30	07-Sep-19	13:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)ICT-II will remain service through Main Bay 421. 2) Outage subject to weather Condition & availability of Kit.
41	400	TIE BAY - 417 OF IEPL @ KORADI-2	07-Sep-19	12:00	07-Sep-19	12:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)400KV IEPL Line will remain servie through Main Bay 418 2) Outage subject to weather Condition & availability of Kit.
42	400	MIAN BAY-422 OF STATION TF - 1 @ KORADI -2	07-Sep-19	13:00	07-Sep-19	13:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Tie Bay 423 2) Outage subject to weather Condition & availability of Kit.
43	400	MAIN BAY-401 OF GT-10 @ KORADI-2	07-Sep-19	09:00	07-Sep-19	09:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)GT10 will remain in service through Tie Bay 402. 2) Outage subject to weather Condition & availability of Kit.
44	400	MAIN BAY-425 OF GT-8 @ KORADI-2	07-Sep-19	14:00	07-Sep-19	14:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)GT#08 will remain in service through Tie Bay 426. 2) Outage subject to weather Condition & availability of Kit.
45	400	MAIN BAY - 413 OF GT-9 @ KORADI-2	07-Sep-19	11:30	07-Sep-19	12:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1) GT09 will remain in service through Tie Bay 414 2) Outage subject to weather Condition & availability of Kit.
46	400	KHADKA-AURANGABAD	09-Sep-19	08:00	09-Sep-19	12:00	Daily	For LSA	MSETCL	MSETCL	NIL
47	400	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	09-Sep-19	09:00	09-Sep-19	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	-
48	400	TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	09-Sep-19	10:00	09-Sep-19	17:00	Daily	Routine maintenance & testing work.	MSETCL	MSETCL	NA
49	400	400/220/33 KV 500MVA ICT - 1 @ WARORA	09-Sep-19	09:00	09-Sep-19	17:00	Daily	Attending the issues of 400 KV releted to SCADA and Protection in co-ordination with M/s Sifang and testing work	MSETCL	MSETCL	500MVA ,ICT No-1 handed over 400kv Bableshwar
50	400	Tie bay (405) of Deepnagar line @ Taptitanda	11-Sep-19	11:00	11-Sep-19	17:00	Daily	Teed protection relay testing work	MSETCL	MSETCL	Nil
51	400	Main bay (406) of Deepnagar line @ Taptitanda	11-Sep-19	11:00	11-Sep-19	17:00	Daily	Teed protection relay testing work	MSETCL	MSETCL	Nil
52	400	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	11-Sep-19	09:00	11-Sep-19	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Load will be managed on 400 kv ICT-II
53	400	SPARE LINE-2 BAY (404) @ TAPTITANDA	11-Sep-19	11:00	11-Sep-19	17:00	Daily	Teed protection relay testing work	MSETCL	MSETCL	Nil
54	400	MAIN BAY KHADKA- DEEPNAGAR CKT 2	11-Sep-19	09:00	11-Sep-19	13:00	Daily	DCRM Main CB	MSETCL	MSETCL	The Line will be in service through tie CB
55	400	400KV 125MVAR BUS REACTOR @ KARAD	11-Sep-19	10:00	11-Sep-19	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	Nil
56	400	MAIN BAY - 406 OF FUTURE BAY @ AKOLA 2	11-Sep-19	09:00	11-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments
57	400	TIE BAY KHADKA- DEEPNAGAR CKT 2	11-Sep-19	14:00	11-Sep-19	18:00	Daily	Tie CB DCRM	MSETCL	MSETCL	The Line will be in service through Main CB
58	400	BABLESHWAR- AURANGABAD (WALUJ)	11-Sep-19	08:00	21-Sep-19	18:00	Daily	PID testing work	MSETCL	MSETCL	AR required in non auto
59	400	400/220/33 KV 500 MVA ICT - 1 @ NANDED	12-Sep-19	10:00	12-Sep-19	18:00	Daily	Maintenance work	MSETCL	MSETCL	-
60	400	TIE BAY - 417 OF IEPL @ KORADI-2	12-Sep-19	10:00	12-Sep-19	17:00	Daily	Tan delta Measurement of Bus CT and DCRM, IR Measurement of CB of Bay 417	MSETCL	MSETCL	Outage subject to weather Condition & availability of Kit
61	400	MAIN BAY (407) OF RPL CKT-1 @ AKOLA 2	13-Sep-19	09:00	13-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments
62	400	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	14-Sep-19	08:00	14-Sep-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220KV 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT-IV will be in service
63	400	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	14-Sep-19	09:00	14-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments
64	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16-Sep-19	08:00	17-Sep-19	18:00	Daily	For Replacement of Broken Spacer Cum Vibration Damper	MSETCL	MSETCL	nil
65	400	400/220KV 167 MVA SPARE ICT @ DHULE	16-Sep-19	11:00	16-Sep-19	17:00	Daily	Routine maintenance and testing work	MSETCL	MSETCL	Routine maintenance and CB DCRM testing work
66	400	400/220/33 KV 315MVA ICT - 3 @ KARAD	16-Sep-19	10:00	16-Sep-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICTs

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
67	400	CHANDRAPUR 2 - CHD SWITCHING CKT1	16-Sep-19	09:00	16-Sep-19	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
68	400	MAIN BAY (409) OF AKOLA-1 CKT-1 @ AKOLA 2	16-Sep-19	09:00	16-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments
69	400	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	16-Sep-19	10:00	16-Sep-19	17:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	NA
70	400	400/220/33 KV 500 MVA ICT - 3 @ DHULE	16-Sep-19	08:00	16-Sep-19	17:00	Daily	Routine maintenance and testing work	MSETCL	MSETCL	CB DCRM testing work
71	400	DEEPNAGAR - THAPTI TANDA	16-Sep-19	06:00	18-Sep-19	18:00	Daily	For Replacement of Faulty Insulator string found in PID	MSETCL	MSETCL	NIL
72	400	CHANDRAPUR - KHAPERKHEDA	16-Sep-19	08:00	30-Sep-19	17:00	Daily	For the Replacing of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
73	400	CHANDRAPUR 2 - CHD SWITCHING CKT2	17-Sep-19	09:00	17-Sep-19	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
74	400	400 KV FUTURE BAY II @ WARORA	17-Sep-19	08:00	17-Sep-19	17:00	Daily	Routine Maintenance & Dignostic testing work ,Relay testing etc	MSETCL	MSETCL	400KV Bay No 422 charged on No Load
75	400	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	17-Sep-19	11:00	19-Sep-19	17:00	Daily	PID WORKS	MSETCL	MSETCL	A/R out from both end
76	400	KORADI 2-IEPL	17-Sep-19	09:00	17-Sep-19	18:00	Daily	Fixing of Missing and tightening of loose jumper Nut bolts at various cut point towers.	MSETCL	MSETCL	OUTAGE PROPOSED BY 400KV LMU, Koradi
77	400	FUTURE CKT - 1 @ WARORA	18-Sep-19	08:00	18-Sep-19	17:00	Daily	Routine Maintenance & Dignostic testing work ,Relay testing etc	MSETCL	MSETCL	400KV Bay No 421 charged on No Load
78	400	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	18-Sep-19	09:00	18-Sep-19	18:00	Daily	for diagnostic testing & bay maint .work	MSETCL	MSETCL	Bus CT,Line CT,CB tan delta work
79	400	DEEPNAGAR - THAPTI TANDA	18-Sep-19	09:00	18-Sep-19	13:00	Daily	Main CB DCRM	MSETCL	MSETCL	The Line will be in service through tie CB
80	400	MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2	18-Sep-19	09:00	18-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments
81	400	TIE BAY (412) OF KORADI-1 @ KHAPARKHEDA	18-Sep-19	14:00	18-Sep-19	17:00	Daily	Diagnostic Testing & Routine Maintenance Work	MSETCL	MSETCL	NIL
82	400	MAIN BAY (411) OF KORADI-1 @ KHAPARKHEDA	18-Sep-19	10:00	18-Sep-19	13:00	Daily	Diagnostic Testing & Routine Maintenance Work	MSETCL	MSETCL	NIL
83	400	400/220/33 KV 315 MVA ICT - 2 @ KORADI	18-Sep-19	09:00	18-Sep-19	18:00	Daily	Diagnostic testing work.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
84	400	LONIKAND 1 -JEJURI	19-Sep-19	09:00	19-Sep-19	18:00	Daily	Annual testing & maint.	MSETCL	MSETCL	During the outage 400kv Jejuri-Koyna ST-IV line will be in service
85	400	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	19-Sep-19	09:00	19-Sep-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
86	400	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	19-Sep-19	09:00	19-Sep-19	18:00	Daily	Annual testing & maint.	MSETCL	MSETCL	During the outage 400/220kv 501MVA ICT-II and 400/220kv 501 MVA ICT-III will be in service
87	400	DEEPNAGAR - AURANGABAD (WALUJ)	19-Sep-19	06:00	21-Sep-19	18:00	Daily	For Replacement of Faulty Insulator String found in PID	MSETCL	MSETCL	NIL
88	400	TIE BAY (411) OF RPL CKT - 2 & AKOLA-1 CKT-2 @ AKOLA 2	19-Sep-19	09:00	19-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments
89	400	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	19-Sep-19	10:00	19-Sep-19	17:00	Daily	Routine maintenance & testing work.	MSETCL	MSETCL	NA
90	400	LONIKAND 1 -JEJURI	19-Sep-19	08:00	19-Sep-19	18:00	Daily	Line Maintenance & Routine Diagnostic testing work, CT Ratio changing work	MSETCL	MSETCL	-
91	400	400/220/33 KV 500 MVA ICT - 2 @ NANDED	19-Sep-19	10:00	19-Sep-19	18:00	Daily	Maintenance work	MSETCL	MSETCL	-
92	400	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	20-Sep-19	08:00	20-Sep-19	18:00	Daily	Oil Filtration. VFD installation	MSETCL	MSETCL	220 Temghar-1 & 2 will remain handtripped
93	400	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	20-Sep-19	10:00	20-Sep-19	18:00	Daily	iR, Tan delta measurement of Bushing Tan delta Measurement of Line CT of 421	MSETCL	MSETCL	Tan delta Measurement of Line CT of 421 & 220KV side CT at Bay 201
94	400	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	21-Sep-19	08:00	21-Sep-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220KV 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT-III will be in service
95	400	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	21-Sep-19	11:00	21-Sep-19	17:00	Daily	PID WORKS	MSETCL	MSETCL	A/R out from both end
96	400	400/132 KV 200 MVA ICT - 1 @ KHADKA	21-Sep-19	08:00	21-Sep-19	18:00	Daily	Bushing Tan-Delta,SFRA , Winding resistance of ICT and routine bay maintenance	MSETCL	MSETCL	load will be shifted on 400/132 KV ,200 MVA ICT-II
97	400	400/220/20 KV 500MVA ICT - 3 @ KALWA	22-Sep-19	09:00	22-Sep-19	18:00	Daily	Bay maint. And testing work	MSETCL	MSETCL	-
98	400	MAIN BAY-401 OF GT-10 @ KORADI-2	23-Sep-19	09:00	23-Sep-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
99	400	TIE BAY-402 OF GT-10 @ KORADI-2	23-Sep-19	11:00	23-Sep-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
100	400	400/220/33 KV 315 MVA ICT - 1 @ KOLHAPUR	23-Sep-19	09:00	23-Sep-19	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	-
101	400	LONIKAND 1 - KOYNA STAGE-IV	23-Sep-19	09:00	23-Sep-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold washing work	MSETCL	MSETCL	Stage4-Jejuri ckt will be in service
102	400	AKOLA - KHADKA (BHUSAWAL)	23-Sep-19	10:00	30-Sep-19	15:00	Daily	PID testing of insulator strings by PID Uint Akola of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
103	400	KORADI-NANDGAONPETH (RPL)	24-Sep-19	09:00	24-Sep-19	18:00	Daily	Fixing of Missing and tightening of loose jumper Nut bolts at various cut point towers.	MSETCL	MSETCL	OUTAGE PROPOSED BY 400KV LMU, KORADI
104	400	MAIN BAY (412) OFAKOLA -1 CKT-2 @ AKOLA 2	24-Sep-19	09:00	24-Sep-19	18:00	Daily	Annual Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	Annual Maintenance of Bay Equipments

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
105	400	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	24-Sep-19	11:00	26-Sep-19	17:00	Daily	PID WORKS	MSETCL	MSETCL	A/R out from both end
106	400	NEW KOYNA - STAGE IV CKT 1	24-Sep-19	08:00	24-Sep-19	18:00	Daily	Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
107	400	NEW KOYNA-KARAD -CKT 1	25-Sep-19	09:00	25-Sep-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold washing work	MSETCL	MSETCL	New Koyna-Karad ckt 2 will be in service
108	400	MAIN BAY - 413 OF GT-9 @ KORADI-2	25-Sep-19	09:00	25-Sep-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
109	400	NEW KOYNA - STAGE IV CKT 2	25-Sep-19	08:00	25-Sep-19	18:00	Daily	Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
110	400	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	25-Sep-19	10:00	25-Sep-19	17:00	Daily	Diagnostic Testing & Routine Maintenance Work	MSETCL	MSETCL	NIL
111	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	25-Sep-19	09:00	25-Sep-19	18:00	Daily	Diagnostic testing work.	MSETCL	MSETCL	Load will be manged on 400 kv ICT-I
112	400	MAIN BAY - 418 OF IEPL @ KORADI-2	25-Sep-19	15:00	25-Sep-19	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
113	400	KARAD - TALANDGE CKT 2	25-Sep-19	09:00	25-Sep-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold washing	MSETCL	MSETCL	400KV Karad-Talandge ckt I will be in service
114	400	TIE BAY - 414 OF GT-9 @ KORADI-2	25-Sep-19	11:00	25-Sep-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
115	400	TIE BAY - 417 OF IEPL @ KORADI-2	25-Sep-19	13:00	25-Sep-19	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
116	400	TIE BAY-420 OF ICT - 2 @ KORADI -2	26-Sep-19	09:00	26-Sep-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
117	400	JEJURI- KOYNA STAGE-IV	26-Sep-19	09:00	26-Sep-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold, chemical washing work	MSETCL	MSETCL	400KV Jejuri-Lonikand Ckt will be in service
118	400	400/220/33 KV 315 MVA ICT - 1 @ PARLI	26-Sep-19	09:00	26-Sep-19	19:00	Daily	REF & IV Back up relay testing work & Bay maintenance work.	MSETCL	MSETCL	-
119	400	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	26-Sep-19	09:00	26-Sep-19	18:00	Daily	Annual testing & maint.	MSETCL	MSETCL	167 MVA Spare ICT is in RRS mode with ICT-II, Outage on 400kv Main Bus-I is also needed to make Spare ICT free from the
120	400	MIAN BAY-421 OF ICT - 2 @ KORADI -2	26-Sep-19	11:00	26-Sep-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
121	400	MIAN BAY-422 OF STATION TF - 1 @ KORADI -2	26-Sep-19	13:00	26-Sep-19	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
122	400	TIE BAY (423) OF STATION TF - 1 @ KORADI 2	26-Sep-19	15:00	26-Sep-19	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
123	400	TBC @ CHAKAN	26-Sep-19	09:00	26-Sep-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
124	400	105 MVA SPARE ICT @ AKOLA	26-Sep-19	10:00	26-Sep-19	18:00	Daily	Routine Maintenance & testing work.	MSETCL	MSETCL	NA
125	400	TIE BAY-426 OF GT-8 @ KORADI-2	27-Sep-19	11:00	27-Sep-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
126	400	400/220 KV 500 MVA ICT - 5 @ PADGHA	27-Sep-19	08:00	27-Sep-19	18:00	Daily	Isolator alignment work. jaw replacement work	MSETCL	MSETCL	Bay maintenance work
127	400	431 BAY OF 167 MVA SPARE ICT @ KORADI II	27-Sep-19	17:00	27-Sep-19	18:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
128	400	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	27-Sep-19	15:00	27-Sep-19	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
129	400	TIE BAY (429) OF ICT - 1 @ KORADI - 2	27-Sep-19	13:00	27-Sep-19	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
130	400	NEW KOYNA -KARAD -CKT 2	27-Sep-19	09:00	27-Sep-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold washing	MSETCL	MSETCL	New Koyna-Karad ckt I will be in service
131	400	MAIN BAY-425 OF GT-8 @ KORADI-2	27-Sep-19	09:00	27-Sep-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
132	400	KARAD - TALANDGE CKT 1	28-Sep-19	09:00	28-Sep-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold washing	MSETCL	MSETCL	400KV Karad-Talandage Ckt-2 will be in service
133	400	400/132 KV 200 MVA ICT - 2 @ KHADKA	28-Sep-19	08:00	28-Sep-19	18:00	Daily	Bushing & winding Tan-Delta,DFR of ICT and routine bay maintenance carried out	MSETCL	MSETCL	Load will be shifted on 400/132 KV 200 MVA ICT-I
134	400	DHULE- - BABLESHWAR - I	28-Sep-19	07:00	28-Sep-19	12:00	Daily	Replacement of PID suspicious string if found faulty in PID testing	MSETCL	MSETCL	Replacement of PID suspicious string if found in PID testingfaulty
135	400	NEW KOYNA-KARAD -CKT 1	30-Sep-19	08:00	30-Sep-19	18:00	Daily	Relay Testing & Routine maint. Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Karad-II line
136	400	DHULE - BABLESHWAR - II	30-Sep-19	13:00	30-Sep-19	19:00	Daily	Replacement of PID suspicious string if found faulty in PID testing	MSETCL	MSETCL	Replacement of PID suspicious string if found faulty in PID testing