

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of September 2020

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D	reason	Name of Requesting Agency	Remarks
1	49	400KV-BABLESHWAR-PADGHE-1	1-Sep-20	08:00	10-Sep-20	18:00	Daily	Carrying PID Work//	MSETCL	-
2	53	400KV-PARLI-M-SOLAPUR-M-1	1-Sep-20	10:00	15-Sep-20	18:00	Daily	PID Testing work//	MSETCL	Without Interruption
3	78	LONIKHAND-II - 400KV - BUS 2	1-Sep-20	09:00	30-Sep-20	18:00	Daily	PID of insulator.//One by One	MSETCL	Both the Bus 1 and Bus 2 will remain in service while taking PID test and no operations are required.
4	79	LONIKHAND-II - 400KV - BUS 1	1-Sep-20	09:00	30-Sep-20	18:00	Daily	PID of insulator.//One by One	MSETCL	Both the Bus 1 and Bus 2 will remain in service while taking PID test and no operations are required.
5	91	220KV-PARLI-OSMANABAD-M-1	2-Sep-20	08:00	2-Sep-20	17:00	Daily	LINE maintenance//	MSETCL	-
6	106	220KV-MUDSHINGI-CHIKKODI-II-1	2-Sep-20	09:00	2-Sep-20	17:00	Daily	quarterly maintenance//	MSETCL	-
7	108	400KV-PARLI-M-SOLAPUR-M-1	2-Sep-20	09:30	2-Sep-20	18:30	Daily	Work of replacement of suspension string insulators(SSN/DSN)//	MSETCL	-
8	111	TIE BAY - 765KV-AKOLA-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	2-Sep-20	10:00	2-Sep-20	13:00	Daily	"Diagnostic Testing & Routine Maintenance" //	MSETCL	765KV Akola Ckt-II will be in service through its Main (703) Bay and Main Bus-II
9	114	TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND FUTURE at EKTUNI - 765KV	2-Sep-20	14:00	2-Sep-20	17:00	Daily	"Diagnostic Testing & Routine Maintenance" //	MSETCL	765/400KV ICT-I will be in service through its Main (710) & Main Bus-II
10	120	TBC 1 @ CHANDRAPUR GCR	2-Sep-20	09:00	11-Sep-20	18:00	Continuous	1) For capital overhauling of drive mechanism, poles and Interrupter of all 3 phases of 400KV CGL make Breaker. 2) Measurement of Timing, Contact Resistance and DCRM of breaker after overhauling work. //	MSETCL	During outage, 400KV TBC-2 bay will be available.
11	121	220KV-SOLAPUR-KUMBARI-1	2-Sep-20	9:00	2-Sep-20	18:00	D	CT & Line Terminal equipments AMP works/Please reschedule outage on 02.09.2020//	POWERGRID_W	Others
12	152	400KV-CHAKAN-PUNE-PG-1	3-Sep-20	09:00	3-Sep-20	18:00	Daily	DT & Line Maintenance work.//	MSETCL	---
13	155	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	3-Sep-20	11:00	3-Sep-20	14:00	Daily	"Diagnostic Testing & Routine Maintenance" //	MSETCL	Bus Reactor will be in service through its TIE (712) & Main Bus-II
14	158	220KV-WARDHA-PUSAD-1	3-Sep-20	08:00	4-Sep-20	18:00	Daily	Routine line maintainace work//	MSETCL	NA
15	173	400KV-WARORA-CHANDRAPU-II-1	4-Sep-20	08:00	4-Sep-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling//	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
16	188	220KV-AURANGABAD-CHITEGAON-2	4-Sep-20	09:00	4-Sep-20	18:00	Daily	Routine Maintenance & Diagnostic testing work //	MSETCL	Routine Maintenance & Diagnostic testing work
17	200	400KV-WARORA-CHANDRAPU-II-1	5-Sep-20	09:00	5-Sep-20	17:00	Daily	Routine maintainance and diagonastic testing ,relay testing work etc//	MSETCL	Load will be managed on 400KV chandrapur Ckt-2 bay no 413
18	201	220KV-BOISAR-NALASOPARA-1	5-Sep-20	09:00	5-Sep-20	17:00	Daily	REPLACEMENT OF FAULTY INSULATOR //	MSETCL	REPLACEMENT OF FAULTY INSULATOR
19	207	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	5-Sep-20	08:00	5-Sep-20	18:00	Daily	To check healthiness of busbar system(400KV ABB RADSS busbar testing)//	MSETCL	outage not required on 400KV bus coupler (400KV ABB RADSS busbar testing)
20	220	220KV-TALEGAON-PUNE-PG-1	5-Sep-20	10:00	5-Sep-20	17:00	Daily	Half yearly maintenance, Diagnostic Testing work.//	MSETCL	--
21	221	NANDED - 400KV - BUS 1	5-Sep-20	10:30	5-Sep-20	18:00	Daily	Annual Maintenance & Relay Testing work.//	MSETCL	-
22	230	220KV-WARDHA-PUSAD-1	6-Sep-20	08:00	6-Sep-20	18:00	Daily	Routine line maintainace work//	MSETCL	NA
23	231	400KV-KALWA-KHARGHAR-1	6-Sep-20	08:00	6-Sep-20	18:00	Daily	Routine Maintenance work//	MSETCL	Routine Maintenance work
24	251	400KV-AKOLA-AURANGABAD-1	7-Sep-20	9:00	7-Sep-20	18:00	D	For AMP of Line Bay at Akola end & 400KV-AKOLA-AURANGABAD-2 A/R to be kept in Non-Auto mode for safety precautions//	POWERGRID_WRI	
25	256	400KV-RGPPL-NEW KOYNA-1	7-Sep-20	09:00	7-Sep-20	18:00	Daily	Routine maint. work//	MSETCL	Planned outage

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D	reason	Name of Requesting Agency	Remarks
26	265	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	7-Sep-20	10:00	7-Sep-20	17:30	Daily	Q.M work & diagnostic testing work//	MSETCL	NA
27	266	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE at ALKUD - 400KV	7-Sep-20	10:00	7-Sep-20	17:30	Daily	Q.M work & diagnostic testing work//	MSETCL	NA
28	267	400KV-KOLHAPUR-MS-ALKUD-1	7-Sep-20	10:00	7-Sep-20	17:30	Daily	Quarterly maintenance & diagnostic testing work//	MSETCL	NA
29	268	220KV-WARDHA-WARDHA-M-1	7-Sep-20	10:00	7-Sep-20	18:00	Daily	Routine line maintainace work//	MSETCL	NA
30	294	ALKUD - 400KV - BUS 1	8-Sep-20	10:00	8-Sep-20	17:30	Daily	Quarterly maintenance work//	MSETCL	Load will be managed on Bus-II
31	325	220KV-PARLI-PARLI-M-1	8-Sep-20	09:00	8-Sep-20	17:00	Daily	To attend loose nut bolt at Cut Point Loc. Nos. 28, 29 & 30 and tightening of nut bolts of Cross Arm pieces//	MSETCL	-
32	326	400KV-RGPPL-NEW KOYNA-2	8-Sep-20	09:00	8-Sep-20	18:00	Daily	Routine maint. work//	MSETCL	Planned outage
33	337	EKTUNI - 765KV - BUS 1	8-Sep-20	11:00	9-Sep-20	18:00	Daily	"Diagnostic Testing & Routine Maintainece "	MSETCL	765kV Main Bus-II will be in service
34	339	220KV-WARDHA-BHUGAON-1	8-Sep-20	08:00	10-Sep-20	18:00	Daily	Routine line maintainace work//	MSETCL	NA
35	357	220KV-PANDURNA-KALMESHVAR-1	9-Sep-20	08:00	9-Sep-20	18:00	Daily	Routine Maintenance work//	MSETCL	Outage proposed by LMU S/Dn Mankapur
36	372	220KV-PARLI-HARANGUL-1	9-Sep-20	09:00	9-Sep-20	17:00	Daily	To attend loose nut bolt at Cut Point Loc. Nos. 28, 29 & 30 and tightening of nut bolts of Cross Arm pieces//	MSETCL	-
37	373	132KV-PENCH-MP-KANHAN-1	9-Sep-20	09:00	9-Sep-20	17:00	Daily	Routine Maintenance work//	MSETCL	Outage proposed by LMU Kanhan
38	375	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	9-Sep-20	09:00	9-Sep-20	18:00	Daily	Bay Maintenance Activities//	MEGPTCL	Bay Maintenance Activities
39	376	400KV-PARLI-M-SOLAPUR-M-1	9-Sep-20	09:30	9-Sep-20	18:30	Daily	Work of replacement of suspension string insulators(SSN/DSN)//	MSETCL	-
40	385	400KV-RGPPL-NAGOTHANE-1	9-Sep-20	09:00	10-Sep-20	18:00	Daily	Routine maint. work//	MSETCL	Planned outage
41	411	220KV-PARLI-OSMANABAD-M-1	10-Sep-20	08:00	10-Sep-20	17:00	Daily	Line maintenance work//	MSETCL	-
42	422	400KV-BHILAI-KORADI	10-Sep-20	9:00	10-Sep-20	18:00	D	For AMP works//	POWERGRID_WRI	
43	443	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	11-Sep-20	09:00	11-Sep-20	18:00	Daily	DT & Maintenance work. //	MSETCL	---
44	456	400KV-KORADI-SATPURA	11-Sep-20	9:00	11-Sep-20	18:00	D	For AMP works//	POWERGRID_WRI	
45	467	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	11-Sep-20	09:00	11-Sep-20	18:00	Daily	Bay Maintenance Activities//	MEGPTCL	Bay Maintenance Activities
46	471	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	11-Sep-20	10:00	11-Sep-20	17:00	Daily	Routine maintenance and testing work//	MSETCL	Line will in service through Tie bay.
47	472	400KV-TAPTHITHANDA-EKTUNI-1	11-Sep-20	11:00	11-Sep-20	17:00	Daily	To attend the hotspot of 408, 89B isolator. Outage required alongwith Main bus -2//	MSETCL	Nil
48	473	TAPTHITHANDA - 400KV - BUS 2	11-Sep-20	11:00	11-Sep-20	17:00	Daily	To attend the hotspot of 408 89B Isolator. Outage required alongwith TAPTITANDA - EKTUNI CKT - 1//	MSETCL	Nil
49	477	400KV-RGPPL-NAGOTHANE-2	11-Sep-20	09:00	12-Sep-20	18:00	Daily	Routine maint. work//	MSETCL	Planned outage
50	478	400KV-BABLESHWAR-PADGHE-2	11-Sep-20	08:00	20-Sep-20	18:00	Daily	Carrying PID Work//	MSETCL	-
51	485	EKTUNI - 400KV - BUS 1	12-Sep-20	11:00	12-Sep-20	17:00	Daily	"Diagnostic Testing & Routine Maintainece" //	MSETCL	400kV Main Bus-II will be in service
52	502	400KV-BABLESHWAR-PADGHE-2	12-Sep-20	09:00	12-Sep-20	17:00	Daily	Chemical cleaning of insulator string at 400kV Babhaleshwar//	MSETCL	-
53	503	220KV-TARAPUR 1&2-BORIVALI-1	12-Sep-20	09:00	12-Sep-20	17:00	Daily	FIXING OF MISSING SPACERS//	MSETCL	FIXING OF MISSING SPACERS
54	505	220KV-TALEGAON-PUNE-PG-1	12-Sep-20	10:00	12-Sep-20	17:00	Daily	Half yearly maintenance, Diagnostic Testing work//	MSETCL	--
55	511	400KV-KALWA-PUNE-PG-1	13-Sep-20	9:00	13-Sep-20	18:00	D	For AMP works/Please reschedule outage on 13.09.2020/	POWERGRID_WRI	Others

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D	reason	Name of Requesting Agency	Remarks
56	517	400KV-WARDHA-KORADI-II-1	13-Sep-20	09:00	13-Sep-20	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work//	MSETCL	400 KV WARORA - DEOLI 2 Line is in ckt
57	518	400KV-WARDHA-KORADI-II-1	13-Sep-20	09:00	13-Sep-20	18:00	Daily	Line maintenance work//	MSETCL	Outage proposed by LM S/Dn Koradi
58	519	400KV-KALWA-PUNE-PG-1	13-Sep-20	09:00	13-Sep-20	18:00	Daily	Bay Maintenance & Testing work. //	MSETCL	Bay Maintenance & Testing work.
59	558	400KV-BABLESHWAR-PADGHE-1	14-Sep-20	09:00	14-Sep-20	17:00	Daily	Chemical cleaning of insulator string//	MSETCL	-
60	560	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND FUTURE at KORADI-III - 400KV	14-Sep-20	09:00	14-Sep-20	18:00	Daily	Bay Maintenance Activities//	MEGPTCL	Bay Maintenance Activities
61	565	400KV-ALKUD-SOLAPUR-1	14-Sep-20	10:00	14-Sep-20	17:30	Daily	Q.M work & diagnostic testing work//	MSETCL	NA
62	566	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	14-Sep-20	10:00	14-Sep-20	17:30	Daily	Q.M work & diagnostic testing work//	MSETCL	NA
63	567	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	14-Sep-20	10:00	14-Sep-20	17:30	Daily	Q.M work & diagnostic testing work//	MSETCL	NA
64	579	400KV/220KV CHANDRAPUR-ICT-2	14-Sep-20	09:00	19-Sep-20	18:00	Continuous	1) For replacement of old fan & pump control cubical of R & B-ph unit of ICT-2 by new one. 2) Replacement of old HCB Isolator with EB one side by new one. 3) For applying the high insulation coating to 33KV IPS tube, PTs and other allied equipments of external delta connection. //	MSETCL	During outage, ICT-1 and 220KV Chandrapur-2 ckt. Will be in service.
65	581	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	15-Sep-20	10:00	15-Sep-20	17:00	Daily	Routine maintenance and testing work.//	MSETCL	Line will be in service through Tie bay.
66	587	ALKUD - 400KV - BUS 2	15-Sep-20	10:00	15-Sep-20	17:30	Daily	Quarterly maintenance work//	MSETCL	Load will be managed on Bus 1
67	612	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 at WARORA - 400KV	15-Sep-20	09:00	15-Sep-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintainance work //	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.
68	618	EKTUNI - 400KV - BUS 2	15-Sep-20	11:00	15-Sep-20	17:00	Daily	"Diagnostic Testing & Routine Maintainence" //	MSETCL	400KV Main Bus-I will be in service
69	636	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	16-Sep-20	7:00	16-Sep-20	18:00	D	Replacement of Porcelain insulators at River crossing locations & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AR to be kept in Non-auto mode for safety of precautions.//	POWERGRID_WRI	
70	640	220KV-PARLI-PARLI-M-2	16-Sep-20	08:00	16-Sep-20	17:00	Daily	Line Maintenance work//	MSETCL	-
71	641	220KV-PANDURNA-KALMESHVAR-1	16-Sep-20	08:00	16-Sep-20	18:00	Daily	Routine Maintenance work.//	MSETCL	Outage proposed by LMU S/Dn Mankapur .
72	653	400KV-ALKUD-SOLAPUR-1	16-Sep-20	9:00	16-Sep-20	18:00	D	Line Terminal equipments AMP works//	POWERGRID_WRI	Others
73	659	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	16-Sep-20	09:00	16-Sep-20	17:00	Daily	quarterly maintenance//	MSETCL	-
74	660	400KV-WARDHA-WARORA-1	16-Sep-20	09:00	16-Sep-20	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work//	MSETCL	400KV WARORA-IEPL Line is in ckt
75	664	400KV-PARLI-M-SOLAPUR-M-1	16-Sep-20	09:30	16-Sep-20	18:30	Daily	Work of replacement of suspension string insulators(SSN/DSN)//	MSETCL	-
76	668	765KV-AKOLA (2)-KORADI-III-2	16-Sep-20	10:00	16-Sep-20	13:00	Daily	For replacement of bend members of gantry cross arm at koradi-III SS//	MEGPTCL	For replacement of bend members of gantry cross arm at koradi-III SS
77	669	SOLAPUR-M - 400KV - BUS 1	16-Sep-20	10:00	16-Sep-20	18:00	Daily	Diagnostic Testing work//	MSETCL	Load will be managed on 400KV Main bus II & Reactor will be in out of service
78	719	400KV-PARLI-M-PARLI-1	17-Sep-20	09:00	17-Sep-20	18:00	Daily	CB & CVTs testing work & Bay Maintenance//	MSETCL	-
79	721	TIE BAY - 765KV-AKOLA-EKTUNI-1 AND FUTURE at EKTUNI - 765KV	17-Sep-20	10:30	17-Sep-20	17:30	Daily	"Diagnostic Testing & Routine Maintainence" //	MSETCL	765KV Akola Ckt-I will be in service through its main (706) Bay and Main Bus-II
80	729	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	18-Sep-20	7:00	18-Sep-20	18:00	D	Replacement of Porcelain insulators at River crossing locations & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AR to be kept in Non-auto mode for safety of precautions.//	POWERGRID_WRI	
81	761	AURANGABAD-M (WALUJ) - 400KV - BUS 2	19-Sep-20	09:00	19-Sep-20	17:00	Daily	Quarterly Mainenance //	MSETCL	Quarterly Maintenance

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D	reason	Name of Requesting Agency	Remarks
82	771	220KV-TARAPUR 1&2-BOISAR-M-1	19-Sep-20	09:00	19-Sep-20	17:00	Daily	INSULATOR STRING REPLACEMENT//	MSETCL	INSULATOR STRING REPLACEMENT
83	772	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	19-Sep-20	09:00	19-Sep-20	18:00	Daily	Bay Maintenance Activities//	MEGPTCL	Bay Maintenance Activities
84	773	220KV-TALEGAON-PUNE-PG-2	19-Sep-20	10:00	19-Sep-20	17:00	Daily	Half yearly maintenance, Diagnostic Testing work//	MSETCL	---
85	779	BABLESHWAR - 400KV - BUS 1	20-Sep-20	08:00	20-Sep-20	18:00	Daily	For Bus CVT tan delta and other diagnostic testing//	MSETCL	-
86	781	220KV-WARDHA-BADNERA-1	20-Sep-20	10:00	20-Sep-20	18:00	Daily	Routine line maintainace work//	MSETCL	NA
87	790	TIRODA - 400KV - BUS 1	21-Sep-20	08:00	21-Sep-20	18:00	Daily	Maintenance of Bus Related Equipments.//	APML	Maintenance of Bus Related Equipments.
88	818	400KV/220KV CHANDRAPUR-ICT-2 ON TBC @ CHANDRAPUR GCR	21-Sep-20	03:00	25-Sep-20	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in ICT-2 and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. //	MSETCL	During this outage 400KV ICT-2 bay will be shift on TBC-1 bay, as the work of replacement of bus conductor of Main Bus-I is to be carried out in 400KV ICT-2 bay.
89	819	400KV-CHANDRAPUR-BHADRAWATI-4	21-Sep-20	03:00	25-Sep-20	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in ICT-2 and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. //	MSETCL	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 4 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
90	820	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	21-Sep-20	03:00	25-Sep-20	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in ICT-2 and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. //	MSETCL	Outage is required on 400KV Bus Coupler bay, as the work of replacement of bus conductor of Main Bus-I is to be carried out in 400KV Bus Coupler bay.
91	821	CHANDRAPUR-GCR - 400KV - BUS 1	21-Sep-20	03:00	25-Sep-20	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HV side ICT-2 bay and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. //	MSETCL	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
92	822	400KV-CHANDRAPUR-BHADRAWATI-3	21-Sep-20	03:00	25-Sep-20	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in ICT-2 and 400KV Bus Coupler bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. //	MSETCL	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 3 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
93	824	400KV-DHULE-MS-BABLESHWAR-1	21-Sep-20	08:00	30-Sep-20	18:00	Daily	Carrying PID Work//	MSETCL	-
94	825	400KV-DHULE-MS-BABLESHWAR-2	21-Sep-20	08:00	30-Sep-20	18:00	Daily	Carrying PID Work//	MSETCL	-
95	853	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND FUTURE at KORADI-III - 400KV	22-Sep-20	09:00	22-Sep-20	18:00	Daily	Bay Maintenance Activities//	MEGPTCL	Bay Maintenance Activities
96	856	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	22-Sep-20	10:30	22-Sep-20	17:30	Daily	"Diagnostic Testing & Routine Maintainece " //	MSETCL	"765/400KV ICT-I will be in service through its Main (710) & Main Bus-II. 765KV Bus Reactor will be in service through its Main Bay (711) & Main Bus-I"
97	870	400KV-WARORA-CHANDRAPU-II-2	23-Sep-20	08:00	23-Sep-20	17:00	Daily	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling//	MSETCL	for conductor & Earthwire Hardware tightening if found During Monkey Patrolling
98	878	220KV-TILLARI-AMONA-1	23-Sep-20	09:00	23-Sep-20	17:00	Daily	quarterly maintenance//	MSETCL	-
99	880	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	23-Sep-20	09:00	23-Sep-20	18:00	Daily	Bay Maintenance Activities//	APML	Bay Maintenance Activities
100	881	400KV-PARLI-M-SOLAPUR-M-1	23-Sep-20	09:30	23-Sep-20	18:30	Daily	Work of replacement of suspension string insulators(SSN/DSN)//	MSETCL	-
101	882	MAIN BAY - 765KV-AKOLA-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	23-Sep-20	10:30	23-Sep-20	17:30	Daily	"Diagnostic Testing & Routine Maintainece " //	MSETCL	765kV Akola Ckt-I Will be in service through its TIE (705) Bay and Main Bus-I
102	896	SOLAPUR-M - 400KV - BUS 2	24-Sep-20	10:00	24-Sep-20	18:00	Daily	Diagnostic testing work//	MSETCL	Load will be managed on 400KV Main Bus - I
103	913	TIE BAY - 400KV/11.5KV KORADI-II-ST-3 AND 400KV-KORADI-II-KORADI-III-2 at KORADI-II - 400KV	24-Sep-20	10:00	24-Sep-20	15:00	Daily	DCRM, IR Measurement of CB at Bay 405 & Tan delta measurement of Bus CT //	MSETCL	Station transformer-III will remain in service through Main Bay 404 and Koradi-II-Koradi-III Ckt-2 will remain in service through its Main Bay 406

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D	reason	Name of Requesting Agency	Remarks
104	914	MAIN BAY - 765KV-AKOLA-EKTUNI-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	24-Sep-20	10:30	24-Sep-20	17:30	Daily	"Diagnostic Testing & Routine Maintainece //	MSETCL	765kV Akola Ckt-II Will be in service through its TIE (702) Bay and Main Bus-II
105	949	AURANGABAD-M (WALUJ) - 400KV - BUS 1	25-Sep-20	09:00	25-Sep-20	17:00	Daily	Quarterly Maintenance //	MSETCL	Quarterly Maintenance
106	950	400KV-AKOLA-AURANGABAD-2 L/R@ AKOLA - 400KV	25-Sep-20	09:00	25-Sep-20	18:00	Daily	Reactor Annual Maintenance Activities//	MEGPTCL	Reactor Annual Maintenance Activities
107	951	NANDED - 400KV - BUS 2	25-Sep-20	10:30	25-Sep-20	18:00	Daily	Annual Maintenance & Relay Testing work//	MSETCL	-
108	960	BABLESHWAR - 400KV - BUS 2	26-Sep-20	08:00	26-Sep-20	18:00	Daily	For Bus CVT tan delta and other diagnostic testing//	MSETCL	-
109	964	400KV-PARLI-M-LONIKHAND-II-2	26-Sep-20	09:00	26-Sep-20	18:00	Daily	DT & Line Maintenance work//	MSETCL	---
110	965	MAIN BAY - 400KV-KORADI-II-KORADI-III-3 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	26-Sep-20	09:00	26-Sep-20	18:00	Daily	Bay Maintenance Activities//	MEGPTCL	Bay Maintenance Activities
111	966	220KV-TALEGAON-PUNE-PG-2	26-Sep-20	10:00	26-Sep-20	17:00	Daily	Half yearly maintenance, Diagnostic Testing work//	MSETCL	---
112	970	400KV-KALWA-PADGHE-2	27-Sep-20	08:00	27-Sep-20	18:00	Daily	Routine Maintenance work//	MSETCL	Routine Maintenance work
113	978	TIRODA - 400KV - BUS 2	27-Sep-20	08:00	27-Sep-20	18:00	Daily	Maintenance of Bus Related Equipments//	APML	Maintenance of Bus Related Equipments.
114	986	400KV-KORADI-II-KORADI-III-1	28-Sep-20	09:00	28-Sep-20	18:00	Daily	Line maintenance work//	MSETCL	Outage proposed by LM S/Dn Koradi
115	1001	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	28-Sep-20	09:00	28-Sep-20	17:00	Daily	Routine maintenance and diagnostic testing//	MSETCL	Na
116	1014	400KV-KORADI-II-KORADI-III-2	29-Sep-20	09:00	29-Sep-20	18:00	Daily	Line maintenance work//	MSETCL	Outage proposed by LM S/Dn Koradi
117	1024	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	29-Sep-20	09:00	29-Sep-20	17:00	Daily	Routine Maintenance & Dignostic testing work //	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
118	1025	220KV-PARLI-OSMANABAD-M-1	29-Sep-20	09:00	29-Sep-20	18:00	Daily	Vibration damper fixing//	MSETCL	-
119	1037	220KV-PARLI-PARLI-M-2	30-Sep-20	08:00	30-Sep-20	17:00	Daily	Line maintenance//	MSETCL	-
120	1042	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	30-Sep-20	09:00	30-Sep-20	17:00	Daily	Routine Maintenance & Diagnostic testing work //	MSETCL	Line will be charged through main CB 429.
121	1043	400KV-PARLI-M-SOLAPUR-M-1	30-Sep-20	09:30	30-Sep-20	18:30	Daily	Work of replacement of suspension string insulators(SSN/DSN)//	MSETCL	-

Additional Outage list for the Month of September 2020										
Sr. No	Line / Element	From	Time	To	Time	Daily/Con tinuous	Reason	Name of Requesting Agency	OCC-Remarks	
AD1	220KV-PARLI-HARANGUL-1	01-Sep-20	09:30	05-Sep-20	18:30	Daily	Tightening of nut bolt and fixing nut bolts to cross arms supporting pieces of line towers of newly commissioned LILO section of PGCIL ckt	MSETCL	Additional outage shall be facilitated subject to feasibility study on D-2. Additional outages have not considered in outage compilation	
AD4	220KV-PARLI-PARLI-M-1	07-Sep-20	09:30	12-Sep-20	18:30	Daily	Tightening of nut bolt and fixing nut bolts to cross arms supporting pieces of line towers of newly commissioned LILO section of PGCIL ckt	MSETCL	Additional outage shall be facilitated subject to feasibility study on D-2. Additional outages have not considered in outage compilation	

Maharashtra State Load Despatch Centre											
State Element Outage list for the month of September 2020											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	01-Sep-20	11:00	30-Sep-20	16:00	Daily	PID of 400 kV Akola-Nandgaonpeth line will be carried out by PID Unit Akola. A/R shall be kept in non- auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal line, 400 kV Koradi-Nandgaonpeth line & 400 kV Akola- Bhusawal line are in service
2	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	02-Sep-20	10:00	02-Sep-20	18:00	Daily	CTR Fire Fighting Testing work	MSETCL	MSETCL	Load will be managed on 400/220kV ICT II
3	400 KV	MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	03-Sep-20	09:00	03-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption
4	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	03-Sep-20	09:30	03-Sep-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	ICT- 1 & II will be in service.
5	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	03-Sep-20	08:00	04-Sep-20	18:00	Daily	For overhauling of NIPFS system and testing work etc	MSETCL	MSETCL	Nil
6	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	03-Sep-20	09:00	03-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption
7	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	03-Sep-20	09:00	03-Sep-20	18:00	Daily	C & Tan D measurement of CT's & Bay Maintenance.	MSETCL	MSETCL	-
8	400 KV	TBC @ Lonikand-I	03-Sep-20	09:00	03-Sep-20	18:00	Daily	DT & Maintenance work.	MSETCL	MSETCL	---
9	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	04-Sep-20	09:00	04-Sep-20	18:00	Daily	Routine diagnostic testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
10	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	04-Sep-20	09:00	04-Sep-20	17:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
11	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	05-Sep-20	06:00	05-Sep-20	18:00	Daily	For overhauling of NIPFS System of ICT	MSETCL	MSETCL	Nil
12	400 KV	KHADKA-AURANGABAD	07-Sep-20	06:00	09-Sep-20	18:00	Daily	Replacement of Faulty insulator strings	MSETCL	MSETCL	NIL
13	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	07-Sep-20	06:00	07-Sep-20	18:00	Daily	For the overhauling of NIPFS (CTR) of ICT I	MSETCL	MSETCL	For the overhauling of NIPFS (CTR) of ICT I
14	400 KV	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	08-Sep-20	09:00	08-Sep-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 418.
15	220 KV	MAIN BUS - 2 @ TALANDGE	08-Sep-20	09:00	13-Sep-20	20:00	Continuous	BUS Tension String Replacement work by Anti fog long Rod Insulators.	MSETCL	MSETCL	Annual B Bus & B Bus isolators of all Bays Maintenance work By Shifting all Bays to Main Bus 1
16	400 KV	MAIN BAY (407) OF DHARIWAL CKT - 1 @ CHANDRAPUR - 2	09-Sep-20	08:00	09-Sep-20	17:00	Daily	Diagnostic testing work main CB and Bus CT	MSETCL	MSETCL	line is in service through Tie Bay
17	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	09-Sep-20	10:00	09-Sep-20	18:00	Daily	RTV Coating work for 400/220/33KV ICT II & CTR Fire Fighting Testing work	MSETCL	MSETCL	Load will be managed on 400/220/33KV ICT I
18	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	09-Sep-20	10:00	09-Sep-20	17:00	Daily	Diagnostic Testing Work & Post monsoon Maintenance	MSETCL	MSETCL	-
19	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	09-Sep-20	09:00	09-Sep-20	18:00	Daily	Routine diagnostic testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
20	400 KV	NEW KOYNA-KARAD -CKT 1	10-Sep-20	09:00	10-Sep-20	18:00	Daily	Diagnostic testing & Relay Testing work	MSETCL	MSETCL	Planned outage
21	400 KV	LONIKAND2-LONIKANDI (INTERCONNECTOR 1)	11-Sep-20	09:00	11-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 2 will be in service for no supply interruption.
22	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	10-Sep-20	08:00	10-Sep-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
23	400 KV	400/220 125MVAr BUS REACTOR @ LAMBOTI	10-Sep-20	10:00	10-Sep-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Reactor will be in out of service
24	400 KV	TIE BAY (408) OF STATION TF 8B & FUTURE CKT - 2 @ CHANDRAPUR SWG S/S	10-Sep-20	09:00	10-Sep-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
25	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	10-Sep-20	09:00	10-Sep-20	18:00	Daily	IV CTs and breaker testing work & Bay Maintenance	MSETCL	MSETCL	-
26	400 KV	KHADKA - BABLESHWAR	10-Sep-20	06:00	12-Sep-20	18:00	Daily	Replacement of Faulty insulator strings	MSETCL	MSETCL	NIL
27	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	10-Sep-20	09:00	10-Sep-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.
28	400 KV	TIE BAY 421 OF LONIKANDI CKT-I AND LONIKANDI CKT-2 @LONIKAND 2	11-Sep-20	09:00	11-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 2 will be in service for no supply interruption.
29	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	11-Sep-20	09:00	11-Sep-20	18:00	Daily	Routine diagnostic testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
30	400 KV	Main Bay 412 of Chadrapur II ckt 2 @ C'pur Sw.	11-Sep-20	09:00	11-Sep-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
31	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	12-Sep-20	08:00	12-Sep-20	18:00	Daily	Quarterly Maintenance work & Relay Testing and other diagnostic testing	MSETCL	MSETCL	400/220kV 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT-IV will be in service
32	400 KV	NEW KOYNA -KARAD -CKT 2	14-Sep-20	09:00	14-Sep-20	18:00	Daily	Diagnostic testing & Relay Testing work	MSETCL	MSETCL	Planned outage
33	400 KV	DEEPNAGAR - THAPTI TANDA	14-Sep-20	06:00	16-Sep-20	18:00	Daily	For replacement of faulty insulator strings detected in PID	MSETCL	MSETCL	NIL
34	400 KV	KORADI 2-IEPL	14-Sep-20	09:00	14-Sep-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage proposed by LM Koradi
35	400 KV	DHARIWAL- CHANDRAPUR 2 CKT I	15-Sep-20	08:00	15-Sep-20	17:00	Daily	Tan delta measurement of Line CT	MSETCL	MSETCL	400KV Dhariwal CKT. 2 is in service
36	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	16-Sep-20	10:00	16-Sep-20	16:00	Daily	Diagnostic testing work on Line CVT	MSETCL	MSETCL	400KV Switching ckt. 1 is service.
37	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	16-Sep-20	10:00	16-Sep-20	17:00	Daily	Diagnostic Testing Work & Post monsoon Maintenance	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
38	400 KV	NEW KOYNA - STAGE IV CKT 1	17-Sep-20	09:00	17-Sep-20	18:00	Daily	Diagnostic testing & Relay Testing work.	MSETCL	MSETCL	Planned outage
39	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	17-Sep-20	08:30	17-Sep-20	14:30	Daily	Opportunity work of bay maintenance & Main CB DCRM testing work will be carried	MSETCL	MSETCL	opportunity work
40	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	17-Sep-20	06:00	19-Sep-20	18:00	Daily	For replacement of faulty insulator strings detected in PID	MSETCL	MSETCL	NIL
41	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	17-Sep-20	08:00	17-Sep-20	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
42	400 KV	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	17-Sep-20	09:30	17-Sep-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
43	400 KV	MAIN BAY- 414 OF YELWAN CKT-1 @ AKOLA	17-Sep-20	10:00	17-Sep-20	17:00	Daily	Routine maintenance and testing work.	MSETCL	MSETCL	Line will be in service through Tie bay.
44	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	17-Sep-20	09:00	17-Sep-20	17:00	Daily	Routine Maintenance at Waluj end	MSETCL	MSETCL	Routine Maintenance
45	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	18-Sep-20	09:00	18-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 1 will be in service for no supply interruption.
46	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	18-Sep-20	09:00	18-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 1 will be in service for no supply interruption.
47	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	18-Sep-20	09:00	18-Sep-20	17:00	Daily	Replacement of faulty strings	MSETCL	MSETCL	-
48	400 KV	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	18-Sep-20	10:00	18-Sep-20	17:00	Daily	Routine maintenance and testing work.	MSETCL	MSETCL	Line will be in service through Tie bay.
49	400 KV	NEW KOYNA - STAGE IV CKT 2	19-Sep-20	09:00	19-Sep-20	18:00	Daily	Diagnostic testing & Relay Testing work	MSETCL	MSETCL	Planned outage
50	400 KV	KHADKA - BABLESHWAR	19-Sep-20	09:00	19-Sep-20	17:00	Daily	Chemical cleaning of insulator string	MSETCL	MSETCL	-
51	400 KV	MAIN BAY - 404 OF STATION TF-3 @ KORADI 2	21-Sep-20	10:00	21-Sep-20	15:00	Daily	DCRM, IR Measurement of CB at Bay 404 & Tan delta measurement of Bus CT	MSETCL	MSETCL	Station transformer-III will remain in service through tie Bay 405
52	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	21-Sep-20	09:00	21-Sep-20	23:59	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Monday is Load Staggering day of Kolhapur
53	400 KV	WARORA - IEPL	22-Sep-20	09:00	22-Sep-20	17:00	Daily	1) Routine Maintenance & Diagnostic testing work , Nut Bolt of jumper Tightning work. 2) Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
54	400 KV	MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	22-Sep-20	10:00	22-Sep-20	13:30	Daily	Main CT tan delta testing & Main CB DCRM testing work	MSETCL	MSETCL	Ct tan delta testing is due as per diagnostic plan
55	400 KV	TIE BAY - 402 CHD SWITCHING CKT1 AND CHANDRAPUR GCR CKT-1 @ CHANDRAPUR 2	23-Sep-20	09:00	23-Sep-20	17:00	Daily	Diagnostic testing work on Tie CB	MSETCL	MSETCL	Both Lines are in service through main CB
56	400 KV	TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	23-Sep-20	10:00	23-Sep-20	17:00	Daily	Routine maintenance and testing work.	MSETCL	MSETCL	Line will be in service through Nam bay.
57	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	24-Sep-20	09:00	24-Sep-20	18:00	Daily	DT & Maintenance work.	MSETCL	MSETCL	Load will be managed by other 2 no. of ICTs and 220 kV Interconnector.
58	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	24-Sep-20	09:00	24-Sep-20	18:00	Daily	HV backup & LBB relay testing work & Bay Maintenance	MSETCL	MSETCL	-
59	400 KV	CHANDRAPUR-PARLI CKT-3	28-Sep-20	08:00	28-Sep-20	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
60	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	24-Sep-20	10:00	24-Sep-20	18:00	Daily	Routine maintenance and testing work.	MSETCL	MSETCL	Outage on both 412 and 413 bay. 400 kV Akola Bhusawal and 400 kV Koradi Nandgaonpeth line will be in service.
61	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	24-Sep-20	09:00	24-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	---
62	400 KV	SPARE LINE @ LONIKAND 2	24-Sep-20	09:00	24-Sep-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	spare future bay.
63	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	26-Sep-20	09:00	26-Sep-20	18:00	Daily	Earthwire stringing between loc. No. 824-826	MSETCL	MSETCL	-
64	400 KV	DHULE- - BABLESHWAR - II	26-Sep-20	09:00	26-Sep-20	17:00	Daily	Chemical cleaning of insulator string at 400kV Babhaleshwar	MSETCL	MSETCL	null
65	400 KV	DHULE- - BABLESHWAR - I	27-Sep-20	09:00	27-Sep-20	17:00	Daily	Chemical cleaning of insulator string at 400kV Babhaleshwar	MSETCL	MSETCL	-
66	400 KV	RPL(AMT) NANDGAON PETH - AKOLA II LINE I	28-Sep-20	08:00	28-Sep-20	19:00	Daily	Old design Line Protection CVT Replacement with New design CVT as per OEM recommendation	APTCL	MEGPTCL	Old design Line Protection CVT Replacement with New design CVT as per OEM recommendation
67	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	28-Sep-20	10:00	28-Sep-20	18:00	Daily	Routine maintenance and testing work.	MSETCL	MSETCL	ICT-1 will be in service.
68	400 KV	400 KV AUX BUS @ CHANDRAPUR	28-Sep-20	08:00	30-Sep-20	14:00	Daily	For on line PID testing of Insulator strings of 400KV Aux. Bus.	MSETCL	MSETCL	400KV Aux Bus is having 02 nos. sections and hence requires to shift the bay on TBC so that Aux bus will charge. It require to carry out the PID testing.
69	400 KV	400kv Stn. TF No 5 @ C'pur GCR	28-Sep-20	08:00	30-Sep-20	14:00	Daily	For on line PID testing of Insulator strings of 400KV Aux. Bus.	MSETCL	MSETCL	1) To charge the 400KV Aux Bus by shifting 400KV STN TF no.- 5 bay bay on TBC-1 bay. 2) Measurement of Timing & DCRM of Breaker.
70	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	28-Sep-20	08:00	30-Sep-20	14:00	Daily	For on line PID testing of Insulator strings of 400KV Aux. Bus.	MSETCL	MSETCL	To charge the 400KV Aux Bus by shifting 400KV HV side ICT-1 bay bay on TBC-1 bay.
71	400 KV	THAPTI TANDA - WALUJ	29-Sep-20	09:00	29-Sep-20	17:00	Daily	Routine Maint. at wahj end	MSETCL	MSETCL	Routine Maint. at wahj end
72	400 KV	RPL(AMT) NANDGAON PETH - AKOLA II LINE II	30-Sep-20	08:00	30-Sep-20	19:00	Daily	Old design Line Protection CVT Replacement with New design CVT as per OEM recommendation	APTCL	MEGPTCL	Old design Line Protection CVT Replacement with New design CVT as per OEM recommendation