

**Maharashtra State Load Despatch Centre**

**Monthly Outage list approved in WRLDC OCCM for the Month of SEPTEMBER'2024**

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
1	703	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-NANDED-1	C	(1) Bay equipments replacement work (CB, CT,CVT,LA,WT, PG & HCB isolators) under LES. (2)Distance M1 & M2 relays retrofitting work.3) Hardware tightening & fitting work	01/Sep/2024	09:00	15/Sep/2024	18:00	\\WRLDC-AT 400 kV Parli M, Karjat D/C AR in NA and Nanded outage planned simultaneously.\\-
2	932	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	To complete the balance work of replacement of existing conductor by HTLS conductor	01/Sep/2024	08:00	20/Sep/2024	22:00	Pre OCC-after MUML work\\WRLDC-Status of Padghe vikhroli and kharghar line to be informed.\\MH-Outage availed after charging of 400KV Padghe GIS -Kharghar line and 400KV Padghe GIS-Vikhroli GIS line\\To complete the balance work of replacement of existing conductor by HTLS conductor
3	1375	PLANNED	OCC_582	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	01/Sep/2024	11:00	29/Sep/2024	15:00	\\\\For PID work. A/R Out
4	1414	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	For OPGW installation replacing existing earth wire (AR Out)	01/Sep/2024	07:00	30/Sep/2024	19:00	\\\\OPGW work
5	1415	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID Testing work	01/Sep/2024	09:00	30/Sep/2024	18:00	\\\\Line maintenance work
6	1416	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID work	01/Sep/2024	09:00	30/Sep/2024	17:30	\\\\-
7	1417	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID work	01/Sep/2024	09:00	30/Sep/2024	17:30	\\\\-
8	1418	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	For OPGW installation replacing existing earth wire (AR Out)	01/Sep/2024	07:00	30/Sep/2024	19:00	\\\\OPGW work
9	1419	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/Sep/2024	08:00	30/Sep/2024	18:00	\\\\PID Work. A/R Out
10	1420	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/Sep/2024	08:00	30/Sep/2024	18:00	\\\\PID Work. A/R Out
11	1421	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/Sep/2024	08:00	30/Sep/2024	18:00	\\\\PID Work. A/R Out
12	1422	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-1	D	For OPGW installation replacing existing earth wire (AR Out)	01/Sep/2024	08:00	30/Sep/2024	18:00	\\WRLDC-At karjat, 400 kV Lonikhand II D/Cand 400 kV Parli DC AR planned. One at a time.\\MH-Some Lines are on S/C Towers, D/C towers & M/C Towers\\MTCIL work
13	1423	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	D	For OPGW installation replacing existing earth wire (AR Out)	01/Sep/2024	08:00	30/Sep/2024	18:00	\\WRLDC-At karjat, 400 kV Lonikhand II D/Cand 400 kV Parli DC AR planned. One at a time.\\MH-Some Lines are on S/C Towers, D/C towers & M/C Towers\\MTCIL work
14	1424	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	For OPGW installation replacing existing earth wire (AR Out)	01/Sep/2024	09:00	30/Sep/2024	18:00	Pre OCC-After Karhat lonikhand DC work\\WRLDC-At karjat, 400 kV Lonikhand II D/Cand 400 kV Parli DC AR planned. One at a time.\\MH-Some Lines are on S/C Towers, D/C towers & M/C Towers\\MTCIL work
15	1425	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID work AR in Non-auto mode	01/Sep/2024	09:00	30/Sep/2024	18:00	Pre OCC-After Karhat lonikhand DC work\\WRLDC-To be clubbed with already proposed AR off\\-
16	1426	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	For OPGW installation replacing existing earth wire (AR Out)	01/Sep/2024	09:00	30/Sep/2024	18:00	Pre OCC-After Karhat lonikhand DC work\\WRLDC-At karjat, 400 kV Lonikhand II D/Cand 400 kV Parli DC AR planned. One at a time.\\MH-Some Lines are on S/C Towers, D/C towers & M/C Towers\\MTCIL work
17	1427	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID work AR in Non-auto mode	01/Sep/2024	09:00	30/Sep/2024	18:00	Pre OCC-After Karhat lonikhand DC work\\WRLDC-To be clubbed with already proposed AR off\\-
18	1442	PLANNED	OCC_582	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01/Sep/2024	07:00:00	30/Sep/2024	18:00:00	Pre OCC-Double ckt tower\\WRLDC-one at a time.\\
19	1443	PLANNED	OCC_582	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01/Sep/2024	07:00:00	30/Sep/2024	18:00:00	Pre OCC-Double ckt tower\\WRLDC-one at a time.\\
20	1486	PLANNED	OCC_582	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	AR disable for replacement of insulator in live line method.	01/Sep/2024	08:00:00	30/Sep/2024	18:00:00	Pre OCC-No resp\\WRLDC-MSLDC consent is required. One at a time to be planned.\\MH-Two lines at a time. Subject to real time loading condition . Load below on 4 lines will be 2800 MW or below\\AR disable
21	9	PLANNED	OCC_582	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	02/Sep/2024	09:00	02/Sep/2024	18:00	\\\\Bay Outage
22	13	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Q/M of bay. Diagnostic testing of CB, CT	02/Sep/2024	09:00	02/Sep/2024	20:00	\\\\Outage required\\High loading. To be planned during less loading.
23	14	PLANNED	OCC_582	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of Hanger rod assembly on 400 kV Main Bus-II in Reactor-II Bay by Hot Line Method	02/Sep/2024	13:00	02/Sep/2024	18:00	\\\\Work will be done online through Hotline method
24	20	PLANNED	OCC_582	POWERGRID_WR1	220KV-SOLAPUR-JEUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	02/Sep/2024	08:00:00	02/Sep/2024	18:00:00	\\\\

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From	To	Remarks
25	22	PLANNED	OCC_582	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-1	D	AMP OF LINE TERMINAL EQUIPMENTS	02/Sep/2024	09:00:00	02/Sep/2024 18:00:00 \\AMP OF LINE TERMINAL EQUIPMENTS WITH DIA OPEN
26	28	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY OF 765KV-PUNE-GIS-AURANGABAD-1 AND AURANGABAD - 765KV - BUS 1 @AURANGABAD - 765KV at AURANGABAD - 765KV	D	For AMP	02/Sep/2024	07:00:00	02/Sep/2024 18:00:00 \\MH-Please reschedule on Thurs / Friday/ Sat/Sunday No other outage at 765KV & 400KV level in PUNE region/710
27	42	PLANNED	OCC_582	POWERGRID_WR2	MAIN BAY - 400KV-AURANGABAD-BOISAR-1 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	D	AMP	02/Sep/2024	09:00:00	02/Sep/2024 17:30:00 \\PG-WR2-BOISAR
28	63	PLANNED	OCC_582	NPCIL, TAPS 1&2	220KV-TARAPUR 1&2-BOISAR-M-1	C	220 kV-Tarapur 1&2 – Boisar outage is required to carry out routine annual maintenance of bay equipments.	02/Sep/2024	08:00:00	03/Sep/2024 20:00:00 \\Feeder outage is required to carry out routine annual maintenance of bay equipments
29	53	PLANNED	OCC_582	GETCO	220KV-NASIK-NAVSARI-2	D	Maintenance work	03/Sep/2024	09:00:00	03/Sep/2024 18:00:00 \\
30	62	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	03/Sep/2024	13:30	03/Sep/2024 17:00 \\--
31	71	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	D	For AMP	03/Sep/2024	07:00:00	03/Sep/2024 18:00:00 \\401
32	72	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 1 at Solapur - 400KV	D	Bay AMP Works	03/Sep/2024	08:00:00	03/Sep/2024 18:00:00 \\
33	73	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	03/Sep/2024	09:00:00	03/Sep/2024 17:30:00 \\Pune GIS Line_2 Line in service through the 408 TIE Bay
34	79	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY OF 400KV-KOLHAPUR-MS-ALKUD-1 AND KOLHAPUR-MS - 400KV - BUS 2 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	03/Sep/2024	08:00:00	03/Sep/2024 18:00:00 \\Outage required on CB only. Line can be kept in service through TBC.
35	87	PLANNED	OCC_582	POWERGRID_WR2	400KV-PADGHE-BOISAR-1	D	AMP works , A/R off of ckt 2 is required. Dia to be kept open at both ends.	03/Sep/2024	09:00:00	03/Sep/2024 17:30:00 Pre OCC-Friday after 12:00 hrs\\MH-It is suggested to plan the Outage on Friday / Saturday / Sunday / Public HolidayPG-WR2-BOISAR
36	111	PLANNED	OCC_582	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	04/Sep/2024	09:00	04/Sep/2024 18:00 \\Bay Outage
37	117	PLANNED	OCC_582	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	04/Sep/2024	09:00	04/Sep/2024 18:00 \\NIL
38	118	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	04/Sep/2024	09:00	04/Sep/2024 17:30 \\-
39	119	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-1	D	Overhauling of ABB make line CB. Routine maintenance work.	04/Sep/2024	07:00	04/Sep/2024 20:00 \\Communicated to PGCIL authority.
40	120	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Quarterly Maintenance	04/Sep/2024	10:00	04/Sep/2024 17:00 \\Breaker of PGCIL line at Jeur End will be made off
41	121	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work_x000D_	04/Sep/2024	09:00	04/Sep/2024 18:00 \\The said work is very important_x000D_
42	122	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	04/Sep/2024	08:00	04/Sep/2024 18:00 \\Outage
43	123	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	1) Routine Maintenance & Diagnostic testing work. 2) Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work.	04/Sep/2024	09:00	04/Sep/2024 17:00 \\400KV WARORA-IEPL Line is in ckt or Both Main & Tie Bay is in OFF condition.
44	124	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	04/Sep/2024	10:00	04/Sep/2024 13:00 \\--
45	125	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-2 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	D	Outage for CB and CT diagnostic testing work and routine maintenance work.	04/Sep/2024	11:00	04/Sep/2024 18:00 \\Please approve outage for routine diagnostics and maintenance work. Line will be in service throuh Tie Bay
46	126	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 765KV-AKOLA (2)-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	D	Routine testing, Diagnostic Testing and Maintenance Works	04/Sep/2024	10:00	04/Sep/2024 18:00 \\765KV Akola 2 will be in service via Main Bus 2 and 703 Main bay
47	134	PLANNED	OCC_582	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-2	D	Line terminal equipments AMP at 765kV Solapur Substation	04/Sep/2024	08:00:00	04/Sep/2024 18:00:00 \\
48	136	PLANNED	OCC_582	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	D	AMP of Line Equipment at Padghe GIS & MSETCL Kudus substation and Autoreclosure scheme checking at Padghe SS. AR IN NON AUTO MODE OF CKT#2	04/Sep/2024	09:00:00	04/Sep/2024 17:00:00 \\AR IN NON AUTO MODE OF CKT#2
49	137	PLANNED	OCC_582	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	D	For AMP	04/Sep/2024	07:00:00	04/Sep/2024 18:00:00 \\413L
50	144	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	04/Sep/2024	09:00:00	04/Sep/2024 17:30:00 \\Pune GIS Line_4 Line in service through the 411 TIE Bay
51	195	PLANNED	OCC_582	NPCIL, TAPS 1&2	220KV-TARAPUR 1&2-BHILAD-1	C	220 kV-Tarapur1&2 – Bhilad outage is required to carry out routine annual maintenance of bay equipments	04/Sep/2024	08:00:00	05/Sep/2024 20:00:00 \\Feeder outage is required to carry out routine annual maintenance of bay equipments

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Elelent	Daily / Continuo us	Reason	From		To		Remarks
52	186	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Routine maintenance work.	05/Sep/2024	07:00	05/Sep/2024	20:00	\\Communicated to PGCIL authority
53	187	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-1	D	Outage is required for Overhead Stringing of under construction of 400 kV twin conductor S/C (on D/C towers) transmission line of ReNEW Green Energy Solutions Pvt Ltd.	05/Sep/2024	06:00	05/Sep/2024	18:00	\\MH-Load will be managed on 132 kV Bus of Narangwadi ss/Overhead Stringing of under construction of 400 kV twin conductor S/C (on D/C towers) transmission line of ReNEW Green Energy Solutions Pvt Ltd.
54	188	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-2	D	Outage is required for Overhead Stringing of under construction of 400 kV twin conductor S/C (on D/C towers) transmission line of ReNEW Green Energy Solutions Pvt Ltd.	05/Sep/2024	06:00	05/Sep/2024	18:00	\\MH-Load will be managed on 132 kV Bus of Narangwadi ss/Overhead Stringing of under construction of 400 kV twin conductor S/C (on D/C towers) transmission line of ReNEW Green Energy Solutions Pvt Ltd.
55	189	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	05/Sep/2024	08:00	05/Sep/2024	18:00	\\Outage
56	190	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Diagnostic testing & Maintenance work	05/Sep/2024	10:00	05/Sep/2024	17:00	\\Load will be managed on 400KV Alkud-Kolhapur line
57	191	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KORADI-II-KORADI-III-2	D	Diagnostic Testing of Line CT	05/Sep/2024	10:00	05/Sep/2024	17:30	\\400kV Koradi-II -Koradi-III Ckt-I will be service as alternate soucre
58	192	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	Yearly testing and maintenance	05/Sep/2024	10:00	05/Sep/2024	18:00	\\-
59	193	PLANNED	OCC_582	MSLDC_OUTAGE	Main Bay (703) OF EKTUNI-AKOLA II ckt-2@ EKTUNI	D	Routine testing and Maintenance Works	05/Sep/2024	10:00	05/Sep/2024	18:00	\\MH-Wrong Element showing in WRLDC PORTAL:765kV Akola 2 will be in service via Tie bay
60	194	PLANNED	OCC_582	MSLDC_OUTAGE	NANDED - 400KV - BUS 2	D	Isolator Maintenance Work & CVT Tan D	05/Sep/2024	10:00	05/Sep/2024	18:00	\\-
61	208	PLANNED	OCC_582	POWERGRID_WR1	LINE BAY OF 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 at KOLHAPUR-MS - 400KV	D	Line Bay AMP and CT Oil sample collecting works at MSETCL	05/Sep/2024	08:00:00	05/Sep/2024	18:00:00	\\CT Oil sample collecting and Line Bay AMP works at MSETCL
62	267	PLANNED	OCC_582	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	C	For AMP Work	05/Sep/2024	22:00:00	06/Sep/2024	06:00:00	\\MH-Please reschedule other day in night hrs due to PUNE-GIS - 400KV - BUS 1 continuous outage /Line Owned By MSETCL
63	252	PLANNED	OCC_582	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	06/Sep/2024	09:00	06/Sep/2024	18:00	\\Bay Outage
64	257	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-AURANGABAD-M (WALUI)-1	D	Routine Maintenance and Diagnostic testing work	06/Sep/2024	10:00	06/Sep/2024	18:00	\\NIL
65	258	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Diagnostic testing work .	06/Sep/2024	09:00	06/Sep/2024	17:00	\\400 KV WARORA - DEOLI 2 Line is in ckt
66	259	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	06/Sep/2024	09:00	06/Sep/2024	17:00	\\400KV KORADI-WARDHA Line will be charged through Tie CB 414.
67	280	PLANNED	OCC_582	POWERGRID_WR1	PARLI NEW - 400KV - BUS 1	D	AMP OF BUS & ISOLATOR ALIGNMENT WORK	06/Sep/2024	08:00:00	06/Sep/2024	18:00:00	\\AMP OF BUS & ISOLATOR ALIGNMENT WORK
68	339	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	Erection of ERS towers in between Location No.1097 -1100 for continuation of 400KV Kalwa Padghe Ckt II line & Erection of 2 No. of QD+9 Tower in between Location No.1097 -1099 will be carried out. (The said Line will be on ERS for 10 Days) Work is proposed by Project Circle, Kalwa.	07/Sep/2024	22:00	08/Sep/2024	08:00	\\MH-Night Hours Outage for diverting Line on ERS. The said Line will be on ERS for 10-14 Days. Important NHSRCL project work./Erection of ERS towers in between Location No.1097 -1100 for continuation of 400KV Kalwa Padghe Ckt II line & Erection of 2 No. of QD+9 Tower in between Location No.1097 -1099 will be carried out.
69	340	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For safety purpose for Repair Sleeves for Conductor damaged at Loc No. 158-159 Top Ph of 220kV Borivali-Tarapur	08/Sep/2024	09:00	08/Sep/2024	18:00	\\For safety purpose for Repair Sleeves for Conductor damaged at Loc No. 158-159 Top Ph of 220kV Borivali-Tarapur
70	341	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Repair Sleeves for Conductor damaged at Loc No. 158-159 Top Ph.	08/Sep/2024	09:00	08/Sep/2024	17:00	\\Simultaneously outage is required on 220kV Borivali-PGCIL line for safety purpose.
71	342	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	08/Sep/2024	10:00	08/Sep/2024	18:00	\\NA
72	355	PLANNED	OCC_582	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	Replacement of 3 No's of Cooling fans of Pole-2, B-ph Converter transformer.	08/Sep/2024	20:00	09/Sep/2024	05:00	\\Pole-1 will be in service with power 750 MW.
73	350	PLANNED	OCC_582	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	09/Sep/2024	09:00	09/Sep/2024	18:00	\\Bay Outage
74	356	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	09/Sep/2024	10:00	09/Sep/2024	18:00	\\NA
75	357	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at 220kv Badnera S/s.	09/Sep/2024	09:00	09/Sep/2024	17:00	\\Outage
76	358	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic testing & Maintenance work	09/Sep/2024	10:00	09/Sep/2024	17:00	\\Load will be managed on 400KV Alkud-Solapur line/High loading. To be planned during less loading.
77	359	PLANNED	OCC_582	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	FOR DIAGNOSTIC AND ROUTINE MAINTENANCE WORK	09/Sep/2024	09:00	09/Sep/2024	17:00	\\OUTAGE REQUIRED
78	360	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	09/Sep/2024	10:00	09/Sep/2024	13:00	\\--
79	361	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Diagnostic testing & Maintenance work	09/Sep/2024	14:00	09/Sep/2024	17:00	\\--
80	362	PLANNED	OCC_582	POWERGRID_WR1	220KV-PARLI-OSMANABAD-M-1	D	AMP WORK	09/Sep/2024	08:30:00	09/Sep/2024	18:00:00	\\Outage is being taken for AMP work
81	368	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY OF 400KV-KOLHAPUR-MS-SOLAPUR-2 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	09/Sep/2024	08:00:00	09/Sep/2024	18:00:00	\\Outage required on CB only. Line can be kept in service through TBC.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
82	372	PLANNED	OCC_582	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment	09/Sep/2024	09:00:00	09/Sep/2024	17:00:00	\\AR IN NON AUTO MODE OF CKT#1
83	483	PLANNED	OCC_582	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-1	C	Overhauling of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS & AMP works	09/Sep/2024	08:00:00	11/Sep/2024	20:00:00	\\Overhauling of pantograph Isolator
84	400	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance work CT, CVT Tandelta testing CB CRM/DCRM Timing	10/Sep/2024	08:00	10/Sep/2024	18:00	\\400kv Ektuni ckt 1&II,400kv Bhusawal,400kv C'Sambhaji nagar and Dhule II will be in service
85	401	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	In view of outage on 400 KV Dhule Ckt I for Line maintenance work.Only AR will be in Non Auto	10/Sep/2024	08:00	10/Sep/2024	18:00	\\Only AR will be in Non Auto.Line will be in service.
86	402	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND FUTURE at EKTUNI - 765KV	D	Routine Testing, Diagnostic Testing and Maintenance Works	10/Sep/2024	10:00	10/Sep/2024	18:00	\\765/400kv 1500MVA ICT 1 will be in service via Main Bus 2
87	408	PLANNED	OCC_582	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	For AMP	10/Sep/2024	07:00:00	10/Sep/2024	18:00:00	\\PGHL
88	409	PLANNED	OCC_582	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2 L/R@ DHULE-MS - 400KV	D	For AMP	10/Sep/2024	07:00:00	10/Sep/2024	18:00:00	\\PGHR
89	411	PLANNED	OCC_582	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Winding Tan Delta, FDS, Moisture measurement of LR of 400KV-PADGHE-BOISAR-1.	10/Sep/2024	09:00:00	10/Sep/2024	17:00:00	\\
90	413	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-KHANDWA-DHULE-MS-2 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	For AMP	10/Sep/2024	07:00:00	10/Sep/2024	18:00:00	\\PGH
91	419	PLANNED	OCC_582	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND 400KV/220KV PUNE-PG-ICT-2 at PUNE-PG - 400KV	D	For AMP Work & SF6 Leak attend work	10/Sep/2024	09:00:00	10/Sep/2024	17:30:00	\\MH-Please reschedule on Sunday due to GANESH FESTIVAL\
92	430	PLANNED	OCC_582	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-1	D	AR Relay Retrofitting, A/R off of ckt 2 is required. Dia to be kept open at both ends.	10/Sep/2024	07:00:00	10/Sep/2024	21:00:00	\\PG-WR2-BOISAR
93	456	PLANNED	OCC_582	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	11/Sep/2024	09:00	11/Sep/2024	18:00	\\Bay Outage
94	464	PLANNED	OCC_582	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	11/Sep/2024	09:00	11/Sep/2024	18:00	\\NIL
95	465	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	11/Sep/2024	09:00	11/Sep/2024	18:00	\\The said work is very important
96	466	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	Routine Maint. Work	11/Sep/2024	09:00	11/Sep/2024	18:00	\\NIL
97	467	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	11/Sep/2024	09:00	11/Sep/2024	17:30	\\-
98	468	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	11/Sep/2024	08:00	11/Sep/2024	18:00	\\Outage
99	469	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	In view of outage on 400 KV Dhule Ckt II for Line maintenance work.Only AR will be in Non Auto	11/Sep/2024	08:00	11/Sep/2024	18:00	\\Only AR will be in Non Auto.Line will be in service.
100	470	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance work and Line 1 will be on non auto mode.	11/Sep/2024	08:00	11/Sep/2024	18:00	\\400kv Ektuni ckt 1&II,400kv Bhusawal,400kv C'Sambhaji nagar and Dhule I will be in service
101	471	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work. DCRM/CRM/CB Timings Testing works and isolator maintenance work .	11/Sep/2024	09:00	11/Sep/2024	17:00	\\Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
102	472	PLANNED	OCC_582	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	FOR DIAGNOSTIC AND ROUTINE MAINTENANCE WORK	11/Sep/2024	09:00	11/Sep/2024	17:00	\\OUTAGE REQUIRED
103	473	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 400KV-WARORA-CHANDRAPU-II-1 AND CHANDRAPU-II - 400KV - BUS 1 at CHANDRAPUR-II - 400KV	D	Diagnostic testing and allied bay maintenance work	11/Sep/2024	10:00	11/Sep/2024	16:00	\\Diagnostic testing and allied bay maintenance work
104	474	PLANNED	OCC_582	MSLDC_OUTAGE	Main Bay (706) OF EKTUNI-AKOLA II ckt-1 & LR @ EKTUNI	D	Routine testing, Diagnostic Testing and Maintenance Works	11/Sep/2024	10:00	11/Sep/2024	18:00	\\MH-Wrong Element showing in WRLDC PORTAL/765kv Akola I will be in service via Tie bay
105	475	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 400KV/11.5KV KORADI-II-ST-3 AND 400KV-KORADI-II-KORADI-III-2 at KORADI-II - 400KV	D	Diagnostic Testing of CB & CT	11/Sep/2024	10:00	11/Sep/2024	17:00	\\1) 400kv Koradi-II -Koradi-III Ckt-II will remain in service through Main Bay 406 2) Station Transformer -III will remain in service through Main bay 404
106	486	PLANNED	OCC_582	POWERGRID_WR1	220KV-SOLAPUR-KUMBHARI-1	D	Line terminal equipments AMP at 765kv Solapur Substation	11/Sep/2024	08:00:00	11/Sep/2024	18:00:00	\\
107	487	PLANNED	OCC_582	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For AMP work @ Pune765 GIS on NON SWITCHABLE LINE REACTOR AND LINE BAY	11/Sep/2024	09:00:00	11/Sep/2024	18:00:00	\\For AMP work @ Pune765
108	488	PLANNED	OCC_582	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP of 401L at MSETCL Kudus Substation. 400KV-KALA-KUDUS-1 A/R to be kept in Non-Auto mode.	11/Sep/2024	09:00:00	11/Sep/2024	17:00:00	\\AR IN NON AUTO MODE OF CKT#1
109	489	PLANNED	OCC_582	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	For relay upgradation works and testing	11/Sep/2024	09:00:00	11/Sep/2024	14:00:00	\\PGHL

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
110	497	PLANNED	OCC_582	POWERGRID_WR1	LINE BAY OF 400KV-KOLHAPUR-MS-SOLAPUR-2 at KOLHAPUR-MS - 400KV	D	Line Bay AMP works	11/Sep/2024	08:00:00	11/Sep/2024	18:00:00	\\Line Bay AMP and Relay testing works
111	499	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	11/Sep/2024	09:00:00	11/Sep/2024	17:30:00	\\MH-Please reschedule on Sunday due to GANESH FESTIVAL/Pune Chakan Line in service through the 402 TIE Bay
112	503	PLANNED	OCC_582	POWERGRID_WR1	PARLI - 220KV - BUS 1	D	AMP WORK	11/Sep/2024	08:30:00	11/Sep/2024	18:00:00	\\Outage is being taken for AMP work
113	599	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-1	C	For making LILO point connection at loc 1 and chargind of new CPRI substation	11/Sep/2024	09:00	13/Sep/2024	18:00	\\OCC Remark-loadings to be reviewed, MH-CTU permission is pending/the said outage is processed by line Project subdivision/
114	933	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	PID Testing Work	11/Sep/2024	08:00	20/Sep/2024	18:00	\\/-
115	549	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	12/Sep/2024	08:00	12/Sep/2024	18:00	\\Outage
116	550	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	Hardware tighten and cold washing	12/Sep/2024	09:00	12/Sep/2024	17:00	\\Load manage
117	556	PLANNED	OCC_582	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-1	D	For AMP work @ Pune765 GIS ON NON SWITCHABLE LINE REACTOR AND LINE BAY	12/Sep/2024	09:00:00	12/Sep/2024	18:00:00	\\For AMP work @ Pune765
118	558	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-KHANDWA-DHULE-MS-1 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	For AMP	12/Sep/2024	07:00:00	12/Sep/2024	18:00:00	\\During outage of BAY, Line to be shifted on TBC
119	559	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	12/Sep/2024	09:00:00	12/Sep/2024	17:30:00	\\MH-Please reschedule on Sunday due to GANESH FESTIVAL/Pune GIS Line_1 in service through the 405 TIE Bay
120	562	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY OF 400KV-SOLAPUR-M-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 @SOLAPUR - 400KV at Solapur - 400KV	D	Bay AMP Works	12/Sep/2024	08:00:00	12/Sep/2024	18:00:00	\\/-
121	600	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400	C	For replacement of 89A & 89B 400kV PG Isolator	12/Sep/2024	10:00	13/Sep/2024	21:00	\\/-
122	705	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-AURANGABAD-M (WALU)-1	C	CB pole overhauling work	12/Sep/2024	08:00	15/Sep/2024	18:00	\\400 KV Aurangabad will be in service through TBC
123	595	PLANNED	OCC_582	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	13/Sep/2024	09:00	13/Sep/2024	18:00	\\Bay Outage
124	601	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Hardware tighten and cold washing	13/Sep/2024	08:00:00	13/Sep/2024	20:00:00	\\Load manage on 400kv parli-karjat ckt 2
125	602	PLANNED	OCC_582	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	CVT Tandelta testing work	13/Sep/2024	08:00	13/Sep/2024	18:00	\\All feeders and ICT's on Main Bus 1 will be shifted on Main Bus II through TBC
126	603	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	D	1) Bay Maint work 2) Diagnostic Testing work 3) Replacement of Relay 4) MTAMC work	13/Sep/2024	09:00	13/Sep/2024	19:00	\\weather condition should be clear
127	615	PLANNED	OCC_582	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-2	D	For AMP work @ Pune765 GIS ON NON SWITCHABLE LINE REACTOR AND LINE BAY	13/Sep/2024	09:00:00	13/Sep/2024	18:00:00	\\For AMP work @ Pune765
128	616	PLANNED	OCC_582	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	D	For AMP Work	13/Sep/2024	09:00:00	13/Sep/2024	17:30:00	\\MH-Please reschedule on Sunday due to GANESH FESTIVAL TOTAL LOADING ON ALL Other three PUNE GIS to PUNE PG ckt's to be below 2100 MW. subject to real time loadings and consent from MSLDC/Line Owned By ADANI Trans
129	618	PLANNED	OCC_582	POWERGRID_WR1	400KV-WARORA-PG-WARORA (MSETCL)-1	D	For 400KV Warora (MSETCL) #1 Line Equipments AMP Work	13/Sep/2024	09:00:00	13/Sep/2024	18:00:00	\\400KV-WARDHA-WARORA -PG-1 AR OFF
130	622	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-KARAD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Bay AMP Works	13/Sep/2024	08:00:00	13/Sep/2024	18:00:00	\\/-
131	626	PLANNED	OCC_582	POWERGRID_WR1	PARLI - 220KV - BUS 2	D	AMP WORK	13/Sep/2024	08:30:00	13/Sep/2024	18:00:00	\\Outage is being taken for AMP work
132	628	PLANNED	OCC_582	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-BOISAR-2 AND 765KV/400KV AURANGABAD-ICT-2 at AURANGABAD - 400KV	D	For AMP	13/Sep/2024	07:00:00	13/Sep/2024	18:00:00	\\426
133	655	PLANNED	OCC_582	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1. For Replacement of Flashover Disc. 2. Fixing of Turbo Wind Bird Guard. 3. Diagnostic testing of Line Bay at 132kv Dharni S/s.	14/Sep/2024	09:00	14/Sep/2024	17:00	\\Outage
134	656	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work CT Tandelta testing work	14/Sep/2024	08:00	14/Sep/2024	18:00	\\400kV Padghe II will be in in service
135	657	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-II-2	D	Relay testing work & routine maintenance work. DCRM/CRM/CB Timings Testing works and isolator maintenance work .	14/Sep/2024	09:00	14/Sep/2024	17:00	\\Load manage on 400kV Chandrapur 2 Ckt 1, parallel ckt
136	658	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Disc Insulator broken replacement at Loc No. 107 Y-Ph PG/CIL side & Loc No. 150 B-Ph.	14/Sep/2024	09:00	14/Sep/2024	17:00	\\Simultaneously outage is required on 220kV Tarapur - Borivali Line (for safety purpose)

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Elelent	Daily / Continuo us	Reason	From		To		Remarks
137	659	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during work of Disc Insulator broken replacement at Loc No. 107 Y-Ph PGCIL side & Loc No. 150 B-Ph of 220kV PGCIL - Borivali Line.	14/Sep/2024	09:00	14/Sep/2024	17:00	\\Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during work of Disc Insulator broken replacement at Loc No. 107 Y-Ph PGCIL side & Loc No. 150 B-Ph of 220kV PGCIL - Borivali Line.
138	673	PLANNED	OCC_582	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation	14/Sep/2024	07:00:00	14/Sep/2024	18:00:00	\\
139	674	PLANNED	OCC_582	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1 L/R@ SOLAPUR - 400KV	D	PRV NC contact modification and Line Reactor AMP works at 765kV Solapur Substation.Note: Dia to be kept open	14/Sep/2024	07:00:00	14/Sep/2024	18:00:00	\\
140	704	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	To attend defects identified in Line patrolling and Replacement of Insulator String under Scheme and Faulty string identified under PID testing.	15/Sep/2024	08:00	15/Sep/2024	18:00	\\400kV Babhaleshwar-Padghe Ckt -1 will be in service.
141	706	PLANNED	OCC_582	MSLDC_OUTAGE	400KV/220KV KALWA-ICT-1	D	Bay maintenance & Diagnostic testing work.	15/Sep/2024	08:00	15/Sep/2024	20:00	\\Bay maintenance & Diagnostic testing work.
142	719	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	1) SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint. 2) Also Wave Trap & Jumper replacement work at 400kV RS Kalwa.	16/Sep/2024	08:00	16/Sep/2024	20:00	\\WRLDC-To be availed on Sunday/night hr.\\1) SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint. 2) Also Wave Trap & Jumper replacement work at 400kV RS Kalwa.
143	722	PLANNED	OCC_582	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Amp of Line Bay	16/Sep/2024	08:00:00	16/Sep/2024	20:00:00	\\Work @ Wardha SS
144	723	PLANNED	OCC_582	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element and AMP Work.	16/Sep/2024	08:00:00	16/Sep/2024	20:00:00	\\Work @ Wardha SS
145	725	PLANNED	OCC_582	POWERGRID_WR1	AKOLA - 400KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	16/Sep/2024	08:00:00	16/Sep/2024	20:00:00	\\Work @ Wardha SS
146	869	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. Line will be in service through TBC	16/Sep/2024	08:00	19/Sep/2024	18:00	\\400 KV Padghe I will be in service through TBC
147	1428	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing	16/Sep/2024	09:00	30/Sep/2024	17:00	\\WRLDC-already planned with different reason\\Line in service
148	742	PLANNED	OCC_582	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	17/Sep/2024	09:00	17/Sep/2024	18:00	\\Bay Outage
149	744	PLANNED	OCC_582	MSLDC_OUTAGE	400KV/220KV ALKUD-ICT-1	D	Diagnostic testing & Maintenance work	17/Sep/2024	10:00	17/Sep/2024	17:00	\\Load will be managed on 400KV Karad & Talandge S/S
150	745	PLANNED	OCC_582	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-I by Hot Line Method	17/Sep/2024	09:00	17/Sep/2024	12:00	\\Work will be done online through Hotline method_x000D_
151	746	PLANNED	OCC_582	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-II by Hot Line Method	17/Sep/2024	13:00	17/Sep/2024	16:00	\\Work will be done online through Hotline method
152	766	PLANNED	OCC_582	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	WTI replacement in Yph LR of 765kV Pune-Padghe Line at Padghe SS	17/Sep/2024	10:00:00	17/Sep/2024	12:00:00	\\
153	767	PLANNED	OCC_582	POWERGRID_WR1	AKOLA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element.	17/Sep/2024	08:00:00	17/Sep/2024	20:00:00	\\Work @ Wardha SS
154	777	PLANNED	OCC_582	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND 400KV-PUNE-GIS-PUNE-PG-3 at PUNE-PG - 400KV	D	For AMP Work	17/Sep/2024	09:00:00	17/Sep/2024	17:30:00	\\MH-Please reschedule on Thurs / Friday/ Sat/Sunday IN NIGHT HOURS & No other outage at 765KV & 400KV level in PUNE region (Ganesh festival).
155	812	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	18/Sep/2024	09:00	18/Sep/2024	17:30	\\-
156	813	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	18/Sep/2024	08:00	18/Sep/2024	18:00	\\Outage
157	814	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Replacement of disc Insulator, Nut Bolt tightening and line diagnostic works	18/Sep/2024	09:00	18/Sep/2024	18:00	\\Work will be carried out by AMC agency
158	815	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tighten and cold washing	18/Sep/2024	09:00	18/Sep/2024	17:00	\\Load manage on 400kv lamboti-PGCIL
159	816	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	18/Sep/2024	09:00	18/Sep/2024	17:00	\\Line will be charged through Tie CB 428.
160	817	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	D	Diagnostic Testing of CB	18/Sep/2024	10:00	18/Sep/2024	17:00	\\1) 400kV Koradi-II -Koradi-III Ckt-I will remain in service through Main Bay 409 2) Station Transformer -IIwill remain in service through Main bay 407
161	878	PLANNED	OCC_582	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Drive Mechanism Inspection Work by OEM	18/Sep/2024	07:00:00	19/Sep/2024	18:00:00	\\707L
162	879	PLANNED	OCC_582	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2 L/R@ AURANGABAD - 765KV	C	Drive Mechanism Inspection Work by OEM	18/Sep/2024	07:00:00	19/Sep/2024	18:00:00	\\707LR

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continu us	Reason	From		To		Remarks
163	938	PLANNED	OCC_582	NPCIL, TAPS 1&2	220KV-TARAPUR 1&2-VAPI-1	C	220 kV-Tarapur1&2 – Vapi outage is required to carry out routine annual maintenance of feeder equipments	18/Sep/2024	08:00:00	20/Sep/2024	20:00:00	\\220 kV-Tarapur1&2 – Vapi outage is required to carry out annual maintenance of feeder equipments
164	1412	PLANNED	OCC_582	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	For PID testing of line disc insulator strings at loc no. 265 to 305, M/C-22 to M/C-3, 2 to 1.	18/Sep/2024	09:00	30/Sep/2024	17:00	\\NLDC-Duplicate entry\\220 KV Mudshingi-Chikodi line will be in service. Only A/R is required to OFF for PID testing. All 220kV lines at 220kV Mudshingi will be in service.
165	1413	PLANNED	OCC_582	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	For PID testing of line disc insulator strings at loc no. 265 to 305, M/C-22 to M/C-3, 2 to 1.	18/Sep/2024	09:00	30/Sep/2024	17:00	\\NLDC-Duplicate entry\\220 KV Mudshingi-Chikodi line will be in service. Only A/R is required to OFF for PID testing. All 220kV lines at 220kV Mudshingi will be in service.
166	1429	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	For PID testing of line disc insulator strings at loc no. 265 to 305, M/C-22 to M/C-3, 2 to 1.	18/Sep/2024	09:00	30/Sep/2024	17:00	\\NLDC-Subjected to SRPC Approval\\220 KV Mudshingi-Chikodi line will be in service. Only A/R is required to OFF for PID testing. All 220kV lines at 220kV Mudshingi will be in service.
167	1430	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	For PID testing of line disc insulator strings at loc no. 265 to 305, M/C-22 to M/C-3, 2 to 1.	18/Sep/2024	09:00	30/Sep/2024	17:00	\\NLDC-Subjected to SRPC Approval\\220 KV Mudshingi-Chikodi line will be in service. Only A/R is required to OFF for PID testing. All 220kV lines at 220kV Mudshingi will be in service.
168	870	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	19/Sep/2024	08:00	19/Sep/2024	18:00	\\Outage
169	871	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	Routine Maintenance and DT	19/Sep/2024	10:00	19/Sep/2024	18:00	\\WRLDC-To be availed on Sunday/night hr.\\-
170	872	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARIJAT-LONIKHAND-II-1 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	19/Sep/2024	16:00:00	19/Sep/2024	23:00:00	\\WRLDC-if line outage is required?/ single bay outage to be availed.\\-
171	873	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIJAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	19/Sep/2024	16:00:00	19/Sep/2024	23:00:00	\\WRLDC-if line outage is required?\\-
172	880	PLANNED	OCC_582	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1	D	For AMP Work	19/Sep/2024	09:00:00	19/Sep/2024	17:30:00	\\Line Owned By ADANI Trans
173	890	PLANNED	OCC_582	POWERGRID_WR1	TIE BAY - 400KV-BHILAI-KORADI-1 AND 400KV-KORBA-NTPC-BHILAI-1 at BHILAI - 400KV	D	AMP at Raipur SS	19/Sep/2024	09:00:00	19/Sep/2024	17:00:00	\\AMP of Bay equipments
174	934	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For the installation of saver assembly sets at TL no. 201 (Total 06 sets out of 24 sets are to be installed)	20/Sep/2024	08:00	20/Sep/2024	15:00	\\Simultaneous outage is required on 220 KV Borivali-Boisar (PGCIL) & 220 kV Borivali-Tarapur for same work & M/C configuration.
175	935	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	For the installation of saver assembly sets at TL no. 201 (Total 06 sets out of 24 sets are to be installed)	20/Sep/2024	08:00	20/Sep/2024	15:00	\\Simultaneous outage is required on 220 KV Borivali-Boisar (PGCIL) & 220 kV Borivali-Tarapur for same work & M/C configuration.
176	936	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-2	D	(1) CT & CVT testing, (2) Bay maintenance work. (3) Hardware tightening & fitting work	20/Sep/2024	09:00	20/Sep/2024	18:00	\\/-
177	937	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	20/Sep/2024	09:00	20/Sep/2024	17:00	\\Line will be charged through Main CB 429.
178	944	PLANNED	OCC_582	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For AMP	20/Sep/2024	07:00:00	20/Sep/2024	18:00:00	\\401AL
179	946	PLANNED	OCC_582	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-1	D	Spare Changover of ICT, Taking Rph OUT of service & Spare IN Service	20/Sep/2024	10:00:00	20/Sep/2024	14:00:00	\\For attending Oil leakage in Rph Shutter Valve
180	952	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 220KV-PUNE-PG-URSE-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	For AMP Work	20/Sep/2024	09:00:00	20/Sep/2024	17:30:00	\\Future Bay
181	955	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-BHILAI-1 AND BHILAI - 400KV - BUS 2 at BHILAI - 400KV	D	AMP at Raipur SS	20/Sep/2024	09:00:00	20/Sep/2024	17:00:00	\\AMP of Bay equipments
182	997	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY OF 400KV/21KV CHANDRAPUR-GT-6 AND CHANDRAPUR - 400KV - BUS 1 @CHANDRAPUR - 400KV at CHANDRAPUR - 400KV	C	1. For dismantling of IPS tube of Bph PG-1 Isolator required for replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 2. GTR-6 will be in service via TBC-2	20/Sep/2024	04:00	21/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner\\GTR-6 will be in service via TBC-2
183	1037	PLANNED	OCC_582	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work.	20/Sep/2024	04:00	22/Sep/2024	18:00	\\ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work.
184	1038	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	Required for Main Bus -1 outage work.	20/Sep/2024	04:00	22/Sep/2024	18:00	Pre OCC-Staggering to be done\\WRLDC-To be planned in staggered manner\\This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
185	1039	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	Required for Main Bus -1 outage work.	20/Sep/2024	04:00	22/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner\\This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
186	1040	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work.	20/Sep/2024	04:00	22/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner\\1. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
187	1041	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	D	1. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work.	20/Sep/2024	16:00	22/Sep/2024	20:00	\\WRLDC-To be planned in staggered manner\\ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work.
188	1042	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -1 outage work.	20/Sep/2024	04:00	22/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner\\Required for Main Bus -1 outage work.
189	1043	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	C	For Replacement of 400kV Y phase BUS Span of 400kV TBC & BC and Routine Maintenance, Bus coupler Relay replacement Work	20/Sep/2024	08:00	22/Sep/2024	17:00	\\All the B Bus elements i.e 400kv Kalwa, 400kV Vikhroli-2 and ICT-1 will be shifted on A bus via TBC
190	1044	PLANNED	OCC_582	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	1. Replacement of cable of BUS-1 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6'. 3. Tan delta measurement of Bus CVT. 4. Nut Bolts and hardware tightening work.	20/Sep/2024	04:00	22/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner\\1. Replacement of cable of BUS-1 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadraple Bus conductor in span of HVDC CKT-1 to GTR-6'. 3. Tan delta measurement of Bus CVT. 4. Nut Bolts and hardware tightening work.
191	1045	PLANNED	OCC_582	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 2	C	For Replacement of 400kV Y phase BUS Span of 400kV TBC & BC and Routine Maintenance, Bus coupler Relay replacement Work	20/Sep/2024	08:00	22/Sep/2024	17:00	Pre OCC-not to availed with chandrapur outages.\\WRLDC-Planned simultaneously with chandrapur outages. \\All the B Bus elements i.e 400kv Kalwa, 400kV Vikhroli-2 and ICT-1 will be shifted on A bus via TBC
192	1066	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	CB pole overhauling work	20/Sep/2024	08:00	23/Sep/2024	18:00	\\MH-MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV (Line will be in service through TBC at Bableshwar End)/400 KV Padghe II will be in service through TBC
193	1252	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	1) Diagnostic Testing Work 2.Replacement of all phase LA.	20/Sep/2024	08:00	26/Sep/2024	23:00	\\weather condition should be clear
194	1444	PLANNED	OCC_582	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	20/Sep/2024	09:00:00	30/Sep/2024	17:00:00	Pre OCC-Meeting to be called..preference to other Pune outages\\WRLDC-discussed in previous OCC to avail in August month itself\\MH-Already discussed and approved in 580th OCCM/765 KV AURANGABAD PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
195	1445	PLANNED	OCC_582	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	20/Sep/2024	09:00:00	30/Sep/2024	18:00:00	Pre OCC-Meeting to be called..preference to other Pune outages\\WRLDC-discussed in previous OCC to avail in August month itself\\MH-Already discussed and approved in 580th OCCM/765 KV PUNE PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
196	1008	PLANNED	OCC_582	POWERGRID_WR1	220KV-SOLAPUR-NARANGWADI-1	D	Line terminal equipments AMP at 765kV Solapur Substation	21/Sep/2024	08:00:00	21/Sep/2024	18:00:00	\\
197	1046	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12)	21/Sep/2024	06:00	22/Sep/2024	17:00	\\1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. 2) Outage is also required on 220kV PGCIL - Boisar Line No. 1 on 20.09.2024 and Both outages are inter related for the said work.
198	1072	PLANNED	OCC_582	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	C	FOR ATTENDING SF6 GAS LEAKAGE WORK IN 407GD 7R ,7B SPACER	21/Sep/2024	06:00:00	23/Sep/2024	18:00:00	\\WRLDC-Pune Pune 2&3 outages planned simultaneously.\\MH-START FROM 22-sep-24 Morning. TOTAL LOADING ON ALL Other three PUNE GIS to PUNE PG ckts to be below 2100 MW. subject to real time loadings and consent from MSLDC\\GAS LEAKAGE IDENTIFIED IN LINE GIB COMPARTMENT , LINE OUTAGE IS REQUIRED.
199	1036	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	22/Sep/2024	08:00	22/Sep/2024	18:00	\\SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint
200	1047	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	1) For Line Maintenance Work. 2) Maintenance Work at S/stn.	22/Sep/2024	09:00	22/Sep/2024	17:00	\\1) For Line Maintenance Work. 2) Maintenance Work at S/stn.
201	1048	PLANNED	OCC_582	MSLDC_OUTAGE	400KV/220KV KALWA-ICT-2	D	Bay maintenance & Diagnostic testing work.	22/Sep/2024	08:00	22/Sep/2024	20:00	\\Bay maintenance & Diagnostic testing work.
202	1049	PLANNED	OCC_582	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Routine testing, Diagnostic Testing and Maintenance Works	22/Sep/2024	10:00	22/Sep/2024	18:00	Pre OCC-N-1 compliant/taptitanda ektuni tripping/ low demand period.\\WRLDC-high loading. To be planned during lean demand period.\\765/400kV 1500MVA ICT-1 will be in service
203	1050	PLANNED	OCC_582	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-1 by Hot Line Method IN 400 KV Padghe Bay	22/Sep/2024	08:00	22/Sep/2024	13:00	\\Work will be done online through Hotline method
204	1065	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14)	23/Sep/2024	09:00	23/Sep/2024	19:00	\\1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. 2) Outage is also required on 220kV PGCIL - Boisar Line No. 3 on 21.09.2024 and Both outages are inter related for the said work.
205	1067	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot line method. A/R Out.	23/Sep/2024	09:00	23/Sep/2024	17:00	\\Hot Line Work. A/R Out
206	1068	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Replacement of disc Insulator, Nut Bolt tightening and line diagnostic works	23/Sep/2024	09:00	23/Sep/2024	18:00	\\Work will be carried out by AMC agency



Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
207	1069	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Q/M of bay.	23/Sep/2024	09:00	23/Sep/2024	20:00	\\Outage required
208	1070	PLANNED	OCC_582	MSLDC_OUTAGE	AURANGABAD-M (WALUJ) - 400KV - BUS 2	D	Routine Maintenance and Diagnostic testing work	23/Sep/2024	10:00	23/Sep/2024	18:00	\\Outage on 400kv Main Bus-II
209	1073	PLANNED	OCC_582	POWERGRID_WR1	220KV-SOLAPUR-BALE-1	D	Line terminal equipments AMP at 765kV Solapur Substation	23/Sep/2024	08:00:00	23/Sep/2024	18:00:00	\\
210	1074	PLANNED	OCC_582	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element.	23/Sep/2024	08:00:00	23/Sep/2024	20:00:00	\\Work @ Wardha SS
211	1075	PLANNED	OCC_582	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	23/Sep/2024	08:00:00	23/Sep/2024	20:00:00	\\Work @ Wardha SS
212	1119	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	23/Sep/2024	09:00	24/Sep/2024	18:00	\\-
213	1274	PLANNED	OCC_582	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	D	Insulator replacement of 400kV Aurangabad Boisar Ckt#1, A/R off of ckt 2 is required. Dia to be kept open at both ends.	23/Sep/2024	08:00:00	26/Sep/2024	18:00:00	\\PG-WR2-BOISAR
214	1120	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	CB CRM/DCRM Timing	24/Sep/2024	08:00	24/Sep/2024	18:00	\\400kV Ektuni II will be in service through TBC
215	1121	PLANNED	OCC_582	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	D	1. Bus Bar Protection (ZIV) testing work. 2. MTAMC Project work ONLINE WORK	24/Sep/2024	08:00	24/Sep/2024	20:00	\\WRLDC-one by one. Planned simultaneously with BUS 2\\1. Tesing of ZIV Busbar will be carried out. 2. Main Bus-1 & 2 will be in service, however Bus-bar protection will be out of service during given period.
216	1122	PLANNED	OCC_582	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	D	1. Bus Bar Protection (ZIV) testing work. 2. MTAMC Project work ONLINE WORK	24/Sep/2024	08:00	24/Sep/2024	20:00	\\WRLDC-one by one. Planned simultaneously with BUS 1\\1. Tesing of ZIV Busbar will be carried out. 2. Main Bus-1 & 2 will be in service, however Bus-bar protection will be out of service during given period.
217	1123	PLANNED	OCC_582	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV	D	FOR DIAGNOSTIC AND ROUTINE MAINTENANCE WORK	24/Sep/2024	09:00	24/Sep/2024	17:00	\\OUTAGE REQUIRED
218	1130	PLANNED	OCC_582	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-1	D	PT 100 sensor check work	24/Sep/2024	09:00:00	24/Sep/2024	17:30:00	\\
219	1137	PLANNED	OCC_582	POWERGRID_WR1	LINE BAY OF 400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	D	Line Bay AMP works	24/Sep/2024	08:00:00	24/Sep/2024	18:00:00	\\Line Bay AMP and Relay testing works
220	1144	PLANNED	OCC_582	POWERGRID_WR1	TIE BAY - AURANGABAD - 400KV B/R 1 AND 400KV/220KV AURANGABAD-ICT-1 at AURANGABAD - 400KV	D	For AMP	24/Sep/2024	07:00:00	24/Sep/2024	18:00:00	\\402
221	1183	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	24/Sep/2024	08:00	25/Sep/2024	18:00	\\NA
222	1391	PLANNED	OCC_582	NPCIL, TAPS 1&2	220KV-TARAPUR 1&2-BORIVALI-1	C	220 kV-Tarapur1&2 - Borivali outage is required to carry out routine annual maintenance of bay equipments and replacement of Lightning Arrestor	24/Sep/2024	20:00:00	29/Sep/2024	20:00:00	\\WRLDC-outage duration to be squeezed / low demand period \\MH- It is suggested to plan the Outage from Friday to Sunday (3 days)\\220 kV-Tarapur1&2 - Borivali outage is required to carry out routine annual maintenance of bay equipments and replacement of Lightning Arrestor
223	1178	PLANNED	OCC_582	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	25/Sep/2024	09:00	25/Sep/2024	18:00	\\Bay Outage
224	1184	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	25/Sep/2024	09:00	25/Sep/2024	17:30	\\-
225	1185	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	25/Sep/2024	08:00	25/Sep/2024	18:00	\\Outage
226	1186	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tighten and cold washing	25/Sep/2024	09:00	25/Sep/2024	17:00	\\Load manage on 400kv lamboti-Parli
227	1187	PLANNED	OCC_582	MSLDC_OUTAGE	BALE - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	25/Sep/2024	10:00	25/Sep/2024	18:00	\\Breaker of PGCIL line at Bale End will be made off
228	1188	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Routine Diagnostic Testing and Maintenance Works	25/Sep/2024	10:00	25/Sep/2024	18:00	\\765/400kv 1500MVA ICT 1 will be in service via Tie bay
229	1200	PLANNED	OCC_582	POWERGRID_WR1	400KV-KALWA-PUNE-PG-1	D	Replacement of conductor Between WT to Line	25/Sep/2024	09:00:00	25/Sep/2024	17:30:00	\\MH-Please reschedule on Sunday or night hrs\\Line Owned By MSETCL
230	1201	PLANNED	OCC_582	POWERGRID_WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-2	D	Line Bay AMP works	25/Sep/2024	08:00:00	25/Sep/2024	18:00:00	\\NLDC-ATC Curtailment of 1000 MW in SR Export. Subjected to SRPC Approval\\Line Bay AMP and Relay testing works
231	1203	PLANNED	OCC_582	POWERGRID_WR1	765KV/400KV PUNE-GIS-ICT-1	D	For AMP Work	25/Sep/2024	09:00:00	25/Sep/2024	18:00:00	\\MH-No other outage at 765KV & 400KV level in PUNE region\\For AMP work @ Pune765
232	1209	PLANNED	OCC_582	POWERGRID_WR1	LINE BAY OF 400KV-KOLHAPUR GIS-NARENDRA KUDGI-2	D	Line Bay AMP works	25/Sep/2024	08:00:00	25/Sep/2024	18:00:00	\\Line Bay AMP and Relay testing works
233	1260	PLANNED	OCC_582	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1	C	Drive Mechanism Inspection Work by OEM	25/Sep/2024	07:00:00	26/Sep/2024	18:00:00	\\710L

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
234	1261	PLANNED	OCC_582	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1 L/R@ AURANGABAD - 765KV	C	Drive Mechanism Inspection Work by OEM	25/Sep/2024	07:00:00	26/Sep/2024	18:00:00	\\710LR
235	1253	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc. 2.Diagnostic testing of Line Bay at 220kv Badnera S/s.	26/Sep/2024	09:00	26/Sep/2024	17:00	\\Outage
236	1254	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	26/Sep/2024	08:00	26/Sep/2024	18:00	\\Outage
237	1255	PLANNED	OCC_582	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT	26/Sep/2024	10:00	26/Sep/2024	17:30	\\All feeders wil remain in service through 400kV Main Bus-1
238	1256	PLANNED	OCC_582	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	Routine Nut Bolt tightening & maintenance work & diagnostic testing of Bus CVT	26/Sep/2024	10:00	26/Sep/2024	17:30	\\All feeders wil remain in service through 400kV Main Bus-1  Due to unfavourable weather conditions on 15.07.2024, the outage was deferred and now it is rescheduled on 27.07.2024
239	1263	PLANNED	OCC_582	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	For Line bay and main Bay AMP work	26/Sep/2024	08:00:00	26/Sep/2024	20:00:00	\\Work @ Wardha SS
240	1300	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	26/Sep/2024	08:00	27/Sep/2024	18:00	\\NA
241	1301	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400	C	For replacement of 89A & 89B 400kV PG Isolator	26/Sep/2024	10:00	27/Sep/2024	21:00	\\-
242	1308	PLANNED	OCC_582	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-2 L/R@ SOLAPUR - 765KV	C	PRV NC contact modification. LR CB Drive Mechanism Inspection by OEM (M/s ABB) at 765kV Solapur Substation.	26/Sep/2024	07:00:00	27/Sep/2024	18:00:00	\\
243	1341	PLANNED	OCC_582	POWERGRID_WR1	TIE BAY - 765KV/400KV RAIPUR-PS (DURG)-ICT-1 AND FUTURE at RAIPUR-PS (DURG) - 400KV	C	New 400/220KV 500MVA ICT#1 first time Charging works	26/Sep/2024	08:30:00	28/Sep/2024	17:30:00	\\402 for Construction works
244	1296	PLANNED	OCC_582	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	27/Sep/2024	09:00	27/Sep/2024	18:00	\\Bay outage
245	1302	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) CT testing. (2) Bay maintenance work. (3)B Ph String replacement at location No 18	27/Sep/2024	09:00	27/Sep/2024	18:00	\\-
246	1303	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-RGPP-L-NAGOTHANE-1	D	Routine maint. Work	27/Sep/2024	08:00	27/Sep/2024	17:00	\\---
247	1304	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	D	Diagnostic Testing of CB & CT	27/Sep/2024	10:00	27/Sep/2024	17:00	\\NIL
248	1315	PLANNED	OCC_582	POWERGRID_WR1	MAIN BAY OF 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR-MS - 400KV - BUS 2 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	D	Main Bay AMP work	27/Sep/2024	08:00:00	27/Sep/2024	18:00:00	\\Outage required on CB only. Line can be kept in service through TBC.
249	1316	PLANNED	OCC_582	POWERGRID_WR1	PUNE-PG - 220KV - BUS#1	D	For Hostspot rectification	27/Sep/2024	09:00:00	27/Sep/2024	17:30:00	\\MH-Please reschedule on / Friday/ Sat/Sunday/Each bay will be taken on TBC bay
250	1376	PLANNED	OCC_582	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	D	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work.	27/Sep/2024	12:00	29/Sep/2024	16:00	\\WRLDC-To be planned in staggered manner.\\ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work.
251	1377	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-1	C	Required for Main Bus -2 outage work.	27/Sep/2024	04:00	29/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner.\\This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.
252	1378	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-2	C	Required for Main Bus -2 outage work.	27/Sep/2024	04:00	29/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner.\\This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are not in service.
253	1379	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work.	27/Sep/2024	04:00	29/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner.\\1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Nut Bolts and hardware tightening work.
254	1380	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	D	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work.	27/Sep/2024	16:00	29/Sep/2024	20:00	\\WRLDC-To be planned in staggered manner.\\ Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work.
255	1381	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Required for Main Bus -2 outage work.	27/Sep/2024	04:00	29/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner.\\Required for Main Bus -2 outage work.
256	1382	PLANNED	OCC_582	MSLDC_OUTAGE	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	C	For Replacement of 400kV R phase BUS Span of 400kV TBC & BC and Routine Maintenance Work	27/Sep/2024	08:00	29/Sep/2024	17:00	\\All the A Bus elements i.e 400kv Talegaon, 400kV Vikhroli-1 and ICT-2&3 will be shifted on B bus via TBC
257	1383	PLANNED	OCC_582	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	C	1. Replacement of cable of BUS-2 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 3. Tan delta measurement of Bus CVT.	27/Sep/2024	04:00	29/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner.\\*This circuits/bays which are connected to 400KV Main Bus-2 will be shifted on 400KV Main Bus-1 one by one via TBC-1 & TBC-2

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
258	1384	PLANNED	OCC_582	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	C	For Replacement of 400kV R phase BUS Span of 400kV TBC & BC and Routine Maintenance Work	27/Sep/2024	08:00	29/Sep/2024	17:00	\\WRLDC-Simultaneously planned with Chandrapur outages.\\All the A Bus elements i.e 400kv Talegaon, 400kV Vikhroli-1 and ICT-2&3 will be shifted on B bus via TBC
259	1385	PLANNED	OCC_582	MSLDC_OUTAGE	MAIN BAY OF 400KV/21KV CHANDRAPUR-GT-6 AND CHANDRAPUR - 400KV - BUS 1 @CHANDRAPUR - 400KV at CHANDRAPUR - 400KV	C	1. For replacement of old damaged quadruple Bus conductor in span of 'H'VDC CKT-1 to GTR-6'. 2. GTR-6 will be in service via TBC-2	27/Sep/2024	04:00	29/Sep/2024	18:00	\\WRLDC-To be planned in staggered manner.\\GTR-6 will be in service via TBC-2
260	1474	PLANNED	OCC_582	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	D	Insulator replacement of 400kV Aurangabad Boisar Ckt#2, A/R off of dkt 1 is required. Dia to be kept open at both ends.	27/Sep/2024	08:00:00	30/Sep/2024	18:00:00	\\PG-WR2-BOISAR
261	1490	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	1) Replacement of old CB with New CGL CB having rating of 3150A for HTLS work 2) A& B bus PG isolator maint work 3 400kV Kahwa -2 in service through TBC	27/Sep/2024	08:00	04/Oct/2024	23:00	\\Weather condition should be clear
262	1337	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	To attend defects identified in Line patrolling and Replacement of Insulator String under Scheme and Faulty string identified under PID testing.	28/Sep/2024	08:00	28/Sep/2024	18:00	\\400kV Babhaleshwar-Padghe Ckt -2 will be in service.
263	1338	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Routine maint. Work	28/Sep/2024	08:00	28/Sep/2024	17:00	\\---
264	1339	PLANNED	OCC_582	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2	D	For AMP Work	28/Sep/2024	09:00:00	28/Sep/2024	17:30:00	Pre OCC-not considered\\WRLDC-to be rescheduled. Pune Pune 2&3 outages planned simultaneously.\\MH-Please reschedule on Sunday or night hrs/Line Owned By ADANI Trans
265	1342	PLANNED	OCC_582	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	Replacement of conductor Between Jack bus between two Gantries	28/Sep/2024	09:00:00	28/Sep/2024	17:30:00	\\MH-Please reschedule on / Friday/ Sat/Sunday or night hrs/Line Owned By MSETCL
266	1345	PLANNED	OCC_582	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	D	WTI replacement in Yph LR of 765kV Aurangabad-Padghe Line at Padghe SS & SPARE Changeover Taking Rph in Service & SPARE Out of Service	28/Sep/2024	10:00:00	28/Sep/2024	12:00:00	\\MH-No other outage at 765KV & 400KV level in PUNE region/SPARE Reactor was taken at Service on 05.05.2024
267	1386	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph. & Loc No. 46-47 B-Ph.	29/Sep/2024	09:00	29/Sep/2024	17:00	\\Simultaneously outage is required on 220kV Tarapur - Borivali Line (for safety purpose)
268	1387	PLANNED	OCC_582	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) for work of Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph. & Loc No. 46-47 B-Ph on 220kV PGCIL - Borivali Line	29/Sep/2024	09:00	29/Sep/2024	17:00	\\Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) for work of Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph. & Loc No. 46-47 B-Ph on 220kV PGCIL - Borivali Line
269	1388	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work Distance M1 relay testing, CT tandem testing work	29/Sep/2024	08:00	29/Sep/2024	18:00	\\WRLDC-Simultaneously outage of kharghar pune line and Bableshtar padghe lines.\\400kV Padghe I will be in service
270	1389	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work	29/Sep/2024	08:00	29/Sep/2024	18:00	Pre OCC-Night hour/ sat/sun\\WRLDC-Simultaneously outage of kharghar pune line and Bableshtar padghe lines.\\SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint & insulator cleaning work
271	1390	PLANNED	OCC_582	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Routine Relay Testing, Diagnostic Testing and Maintenance Works	29/Sep/2024	10:00	29/Sep/2024	19:00	\\WRLDC-high loading. To be planned during lean demand period.\\765/400kV 1500MVA ICT 2 will be in service
272	1392	PLANNED	OCC_582	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	D	Replacement of conductor Between WT to Line	29/Sep/2024	09:00:00	29/Sep/2024	17:30:00	\\Line Owned By ADANI Trans
273	1393	PLANNED	OCC_582	POWERGRID_WR1	PUNE-PG - 220KV - BUS#2	D	Bay ISO Alignment work	29/Sep/2024	09:00:00	29/Sep/2024	17:30:00	\\Each bay will be taken on TBC bay
274	1489	PLANNED	OCC_582	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-1	C	CB pole overhauling work	29/Sep/2024	08:00	02/Oct/2024	18:00	\\MH-MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV ( ICT-1 will be in service through TB at Bableshtar400/220 KV ICT 1 HV will be in service through TBC
275	1431	PLANNED	OCC_582	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1. For Replacement of Flashover Disc. 2. Fixing of Turbo Wind Bird Guard. 3. Diagnostic testing of Line Bay at 132kv Dharni S/s.	30/Sep/2024	09:00	30/Sep/2024	17:00	\\Outage
276	1432	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-BHUSAWAL-AKOLA-1	D	FOR DIAGNOSTIC AND ROUTINE MAINTENANCE WORK	30/Sep/2024	09:00	30/Sep/2024	17:00	\\OUTAGE REQUIRED
277	1433	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint.	30/Sep/2024	08:00	30/Sep/2024	18:00	\\SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint.
278	1434	PLANNED	OCC_582	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware tighten and cold washing	30/Sep/2024	16:00	30/Sep/2024	21:00	\\Load manage on 400kv Parli - karjat ckt 1
279	1450	PLANNED	OCC_582	POWERGRID_WR1	220KV-PARLI-PARLI-M-1	D	AMP WORK	30/Sep/2024	08:30:00	30/Sep/2024	18:00:00	\\Outage is being taken for AMP work
280	1451	PLANNED	OCC_582	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	For Amp of Line Bay	30/Sep/2024	08:00:00	30/Sep/2024	20:00:00	\\Work @ Wardha SS
281	1456	PLANNED	OCC_582	POWERGRID_WR1	LINE BAY OF 400KV-KOLHAPUR-MS-Aikud-1 at KOLHAPUR-MS - 400KV	D	Line Bay AMP works	30/Sep/2024	08:00:00	30/Sep/2024	18:00:00	\\Line Bay AMP and Relay testing works

**Maharashtra State Load Despatch Centre**

**Monthly Outage list Not Considered in WRLDC OCCM for the Month of SEPTEMBER'2024**

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks	Final compilation remark
1	5	PLANNED	OCC_582	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 1	D	Main Bus -1 HV TEST	01/Sep/2024	07:00:00	01/Sep/2024	18:00:00	Pre OCC-Availing in Aug/WRLDC-club this outage with main bus 1 Interconnection work.MH-Clubbed this outage on 04.sep.2024 (Main Bus-1 Interconnection work /OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI SS93	Site availing outage in Aug.
2	8	PLANNED	OCC_582	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	D	Main Bus -2 HV TEST	02/Sep/2024	07:00:00	02/Sep/2024	18:00:00	WRLDC-club this outage with main bus 2 Interconnection work.MH-Clubbed this outage on 04.sep.2024 (Main Bus-2 Interconnection work /OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI SS93	Site availing outage in Aug.
3	9	PLANNED	OCC_582	POWERGRID_WR1	220 kV Korba CSEB - Budipadar #3 line	C	For Retrofitting of CT/CVT/CB/Isolator - works under Approved Add-Cap plan	03/Sep/2024	07:00:00	07/Sep/2024	18:00:00	\\	repeat entry.
4	12	PLANNED	OCC_582	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	C	400 kV GIS BUS MODULE CONNECTION WITH EXISTING 400 kV BUS-1, SIMULTENEOUS OUTAGE OF 400 KV PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED.	04/Sep/2024	09:00:00	06/Sep/2024	18:00:00	\\MH-Please reschedule on / Friday/ Sat/Sunday/OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI SS93	Site availing outage in Aug.
5	13	PLANNED	OCC_582	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 1	C	MAIN BUS-1 INTERCONNECTION WORK	04/Sep/2024	07:00:00	06/Sep/2024	18:00:00	WRLDC-on First weekend in Sept.MH-Please reschedule on / Friday/ Sat/Sunday/Outdoor GIB Erection OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI SS93	Site availing outage in Aug.
6	14	PLANNED	OCC_582	POWERGRID_WR1	RAIGARH-PS - 765KV - BUS 1	C	715 bay jumper dimentaling and BUS BAR protection modification	04/Sep/2024	09:00:00	14/Sep/2024	17:00:00	\\Construction- ICT5 &6. The outage required along with outage of Kotra champa 1	ICT 5&6 Construction work related outages availed on defferent dates.
7	15	PLANNED	OCC_582	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	C	400 kV GIS BUS MODULE CONNECTION WITH EXISTING 400 kV BUS-1, SIMULTENEOUS OUTAGE OF 400 KV PUNE AURANGABAD(WALUJ) CKT2 IS REQUIRED .	07/Sep/2024	09:00:00	09/Sep/2024	18:00:00	\\MH-Please reschedule to other date due to Ganesh festival /OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI SS93	Site availing outage in Aug.
8	16	PLANNED	OCC_582	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 2	C	MAIN BUS-2 INTERCONNECTION WORK	07/Sep/2024	09:00:00	09/Sep/2024	18:00:00	WRLDC-on Second weekend in Sept.MH-Please reschedule to other date due to Ganesh festival /Outdoor GIB Erection OUTAGE IS BEING TAKEN FOR 400/220 KV EXTENSION WORK (CONSTRUCTION) UNDER WRES XXVI SS93	Site availing outage in Aug.
9	39	PLANNED	OCC_582	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-2	D	For AMP Work	29/Sep/2024	09:00:00	29/Sep/2024	18:00:00	\\MH-In Night Hours TOTAL LOADING ON ALL Other three PUNE GIS to PUNE PG ckts to be below 2100 MW. subject to real time loadings and consent from MSLDCFor AMP work @ Pune/65	In view of Multiple Outages planned at same node/in Parallel corridor.

**State Element outage list for the month of SEPTEMBER '2024**

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	01-Sep-24	08:00	01-Sep-24	19:00	Daily	For Relay replacement and Routine Maintenance Work	MSETCL	MSETCL	Vikhroli end ICT's will be in service
2	400 KV	NEW KOYNA - STAGE IV CKT - 2	01-Sep-24	08:00	01-Sep-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
3	400 KV	TIE BAY - 402 CHD SWITCHING CKT1 AND CHANDRAPUR GCR CKT-1 @ CHANDRAPUR 2	02-Sep-24	10:00	02-Sep-24	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
4	400 KV	BUS REACTOR (125MVA) @ WARORA	02-Sep-24	09:00	02-Sep-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	Reactor kept in OFF position., Tie Bay No. 403 also kept in OFF position.
5	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	03-Sep-24	08:00	03-Sep-24	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -III. Bushing Tan delta testing work	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-III.
6	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	03-Sep-24	08:00	03-Sep-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT. HV CB DCRM ,Timing and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
7	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	03-Sep-24	10:00	03-Sep-24	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
8	400 KV	AKOLA - KHADKA (BHUSAWAL)	03-Sep-24	07:00	04-Sep-24	22:00	Daily	FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK BY AGENCY.	MSETCL	MSETCL	URGENT WORK.
9	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	04-Sep-24	09:00	04-Sep-24	17:00	Daily	FOR DIAGNOSTIC DCRM, CT TAN DELTA AND ROUTINE MAINTENANCE WORK	MSETCL	MSETCL	OUTAGE REQUIRED
10	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	05-Sep-24	08:00	05-Sep-24	18:00	Daily	For restoration ICT -III from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
11	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	05-Sep-24	08:00	05-Sep-24	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-III
12	400 KV	MAIN BAY (401) OF ICT -1 @ JEJURI	05-Sep-24	09:30	05-Sep-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-I will be in service through Tie bay
13	400 KV	KARAD - TALANDGE CKT - 1	05-Sep-24	09:00	05-Sep-24	20:00	Daily	Q/M of bay. Diagnostic testing of CB & CT	MSETCL	MSETCL	Outage required
14	400 KV	PADGHE - NAGOTHANE CKT - 1	06-Sep-24	08:00	06-Sep-24	21:00	Daily	1) Replacement of CT & CVT MK Box 2) Bay Maint work 3) MTAMC work	MSETCL	MSETCL	1) weather condition should be clear
15	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	06-Sep-24	08:00	06-Sep-24	18:00	Daily	SFRA Testing	MSETCL	MSETCL	315 MVA ICT II and 501 MVA ICT III,IV & V will be in service
16	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	06-Sep-24	09:00	06-Sep-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
17	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	06-Sep-24	08:00	06-Sep-24	18:00	Daily	Routine Line maintenance work LBB Relay testing	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
18	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	08-Sep-24	08:00	08-Sep-24	19:00	Daily	For Relay replacement and Routine Maintenance Work	MSETCL	MSETCL	Vikhroli end ICT's will be in service
19	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	09-Sep-24	08:00	09-Sep-24	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -IV.	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-IV.

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
20	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	09-Sep-24	08:00	09-Sep-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT,Differential HV ,LV Back up relay ,HV CB DCRM ,Timing HV CT Tan D and bay	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
21	400 KV	400/220 KV 167 MVA ICT @ PARLI	09-Sep-24	09:00	09-Sep-24	18:00	Daily	1) C & tan delta measurement of ICT Unit..2) Bay Maintenance work.	MSETCL	MSETCL	-
22	400 KV	MAIN BAY (422) OF FUTURE BAY II @ WARORA	09-Sep-24	09:00	09-Sep-24	17:00	Daily	Relay testing work & routine maintenance work. DCRM/CRM/CB Timings Testing works and isolator maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
23	400 KV	STATION TF No 5 @ CHANDRAPUR GCR	10-Sep-24	08:00	11-Sep-24	18:00	Daily	1. Maintenance and Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators.	MSETCL	MSETCL	During outage 400KV STN TF-4 will be in service.
24	400 KV	BUS REACTOR (125 MVar) @ ALKUD	11-Sep-24	08:00	11-Sep-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
25	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	11-Sep-24	08:00	11-Sep-24	12:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
26	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	11-Sep-24	13:00	11-Sep-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
27	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	11-Sep-24	08:00	11-Sep-24	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-IV
28	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	11-Sep-24	08:00	11-Sep-24	18:00	Daily	For restoration ICT -IV from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
29	400 KV	MAIN BAY (403) OF LONIKAND CKT @ JEJURI	12-Sep-24	09:30	12-Sep-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	400kv Lonikand ckt-I will be in service through Tie bay
30	400 KV	400KV 125MVar BUS REACTOR @ 400KV KUMBHARGAON SS	12-Sep-24	10:00	12-Sep-24	18:00	Daily	Diagnostic Testing & Bay Maintenance Work	MSETCL	MSETCL	-
31	400 KV	LONIKAND I - KOYNA STAGE-IV	12-Sep-24	08:00	12-Sep-24	18:00	Daily	DT and Bay Maintenance activities	MSETCL	MSETCL	-
32	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	13-Sep-24	09:00	13-Sep-24	23:00	Daily	Q/M of bay. Diagnostic Testing of CB, CT	MSETCL	MSETCL	Outage required
33	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	13-Sep-24	08:00	13-Sep-24	18:00	Daily	SFRA Testing	MSETCL	MSETCL	315 MVA ICT II and 501 MVA ICT III,IV & V will be in service
34	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	13-Sep-24	10:00	13-Sep-24	18:00	Daily	Routine Maintenance and Diagnostic testing work	MSETCL	MSETCL	NIL
35	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	14-Sep-24	08:00	14-Sep-24	18:00	Daily	1. Diagnostic testing of CT, Circuit Breaker etc. 2. Maintenance and alignment of Isolators. 3. Bay routine mainteance work.	MSETCL	MSETCL	During outage 400KV CHD-2 CKT-2, 400KV Parli CKT-3, 400KV Khaperkheda, 400KV HVDC CKT-1 &2, 400KV PGCIL CKT-1,2,3&4 will be in service.
36	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	14-Sep-24	10:00	15-Sep-24	21:00	Continuous	For Overhauling of SERGI make NIFPS	MSETCL	MSETCL	-
37	400 KV	KHADKA-AURANGABAD (WALUJ)	16-Sep-24	07:00	17-Sep-24	22:00	Daily	FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK BY AGENCY.	MSETCL	MSETCL	URGENT WORK.
38	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	17-Sep-24	10:00	17-Sep-24	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
39	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	17-Sep-24	10:00	17-Sep-24	13:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
40	400 KV	KHADKA - BABLESHWAR	17-Sep-24	08:00	17-Sep-24	18:00	Daily	Routine Line maintenance work LBB Relay testing	MSETCL	MSETCL	400kv C'Sambhaji nagar ,400kv Dhule ckt I&II, Ektuni I&II will be in service

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	PADGHE - NAGOTHANE CKT - 2	17-Sep-24	08:00	17-Sep-24	21:00	Daily	1) replacement of CT & CVT MK Box 2) Bay Maint work 3) MTAMC work	MSETCL	MSETCL	weather condition should be clear
42	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	18-Sep-24	09:00	18-Sep-24	18:00	Daily	1) Main-2 distance relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
43	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	18-Sep-24	09:00	18-Sep-24	18:00	Daily	1) HV CB testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
44	400 KV	TIE BAY (411) OF STATION TF 8A & CHANDRAPUR 2 CKT - 2 @ CHANDRAPUR SWG S/S	18-Sep-24	10:00	18-Sep-24	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
45	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	18-Sep-24	10:00	18-Sep-24	18:00	Daily	Diagnostic Relay Testing & Bay Maintenance Work	MSETCL	MSETCL	-
46	400 KV	400/220kV SPARE ICT @ JEJURI	19-Sep-24	09:30	19-Sep-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
47	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	19-Sep-24	09:30	19-Sep-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
48	400 KV	KORADI - KHADKA	19-Sep-24	07:00	20-Sep-24	22:00	Continuous	FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK BY AGENCY.	MSETCL	MSETCL	URGENT WORK.
49	400 KV	Main Bay 412 of Chadrapur II ckt 2 @ C'pur Sw.	19-Sep-24	10:00	19-Sep-24	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
50	400 KV	TBC @ LONIKAND	19-Sep-24	08:00	19-Sep-24	18:00	Daily	DT and Bay Maintenance activities	MSETCL	MSETCL	-
51	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	19-Sep-24	06:00	20-Sep-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NIL
52	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	20-Sep-24	10:00	20-Sep-24	17:00	Daily	Diagnostic Testing of Line CTs,Main Bay CTs & MV Side CTs	MSETCL	MSETCL	NIL
53	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	20-Sep-24	10:00	20-Sep-24	17:00	Daily	Diagnostic Testing of CB & CT	MSETCL	MSETCL	501 MVA 400/220/33KV ICT-I will remain service through Main Bay 430
54	400 KV	KHADKA - BABLESHWAR	21-Sep-24	08:00	v	18:00	Daily	PID Testing Work	MSETCL	MSETCL	-
55	400 KV	NEW KOYNA-KARAD CKT - 2	22-Sep-24	08:00	22-Sep-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
56	400 KV	KORADI-NANDGAONPETH (RPL)	23-Sep-24	06:00	23-Sep-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NIL
57	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	23-Sep-24	09:00	23-Sep-24	18:00	Daily	Earthwire Stringing Work loc.no.497-500 & Nut bolt hardware tightning work	MSETCL	MSETCL	-
58	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	23-Sep-24	09:00	23-Sep-24	22:00	Daily	Annual relay testing work	MSETCL	MSETCL	Monday is load staggering day for kolhapur
59	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	23-Sep-24	08:00	23-Sep-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
60	400 KV	KHADKA - BABLESHWAR	24-Sep-24	07:00	25-Sep-24	22:00	Daily	FOR MAIN-1 & MAIN-2 DISTANCE PROTECTION RELAY RETROFITTING WORK BY AGENCY.	MSETCL	MSETCL	URGENT WORK.
61	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	25-Sep-24	09:00	25-Sep-24	18:00	Daily	Bushing tan delta, Winding resistnace & CB diagnostic testing work	MSETCL	MSETCL	NIL

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
62	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	25-Sep-24	08:00	28-Sep-24	18:00	Continuous	CB pole overhauling work	MSETCL	MSETCL	400/220 KV ICT II HV will be in service through TBC
63	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	25-Sep-24	08:00	25-Sep-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
64	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	25-Sep-24	10:00	25-Sep-24	17:00	Daily	Diagnostic testing of CVT	MSETCL	MSETCL	NIL
65	400 KV	125 MVAR BUS REACTOR @ 400KV KHAPARKHEDA S/S	25-Sep-24	10:00	25-Sep-24	17:00	Daily	Diagnostic Testing of Line CTs & Bushing	MSETCL	MSETCL	NIL
66	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	25-Sep-24	10:00	25-Sep-24	18:00	Daily	Diagnostic Relay Testing & Bay Maintenance	MSETCL	MSETCL	-
67	400 KV	JEJURI- KOYNA STAGE-IV	26-Sep-24	08:00	26-Sep-24	18:00	Daily	@ Lonikand-I end (lines) DT and Line Maintenance activities. @ Jejuri : For Distance Protection Relay Retrofitting work. Work to be carried out by G. E.	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-2, 400 kV Jejuri-Lonikand Ckt-1 & 400 kV Jejuri-Karad will continue to remain in service
68	400 KV	CHANDRAPUR-PARLI CKT-3	26-Sep-24	09:00	26-Sep-24	18:00	Daily	1) Reactor backup relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
69	400 KV	400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	26-Sep-24	08:00	26-Sep-24	18:00	Daily	Bushing Tan delta testing work	MSETCL	MSETCL	105MVA Spare ICT 1 charged only HV Side and is on no load
70	400 KV	NEW KOYNA - STAGE IV CKT - 1	27-Sep-24	08:00	27-Sep-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
71	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	30-Sep-24	09:00	30-Sep-24	22:00	Daily	Annual relay testing work	MSETCL	MSETCL	Monday is load staggering day for kolhapur
72	400 KV	KORADI II - IEPL	30-Sep-24	10:00	30-Sep-24	17:00	Daily	Diagnostic Testing of Line CVT	MSETCL	MSETCL	400kV Koradi-II-Wardha Ckt. Will be service as alternate soucre
73	400 KV	JAIGAD - NEW KOYNA CKT - 2	30-Sep-24	08:00	30-Sep-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
74	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	30-Sep-24	09:00	30-Sep-24	18:00	Daily	1) NDR & IV backup relay testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-