

Outage Planning of Transmission elements during October 2015

SN	KV	Line	From		To		Basis	Reason	System	Agency
1	400	400KV Chandrapur-Parli Ckt-III line	01-Oct-15	12:00	01-Oct-15	18:30	Daily	Replacement of broken disc Insulator	MSETCL	MSETCL
2	400	Chandrapur II - Warora Ckt-I line	01-Oct-15	8:00	02-Oct-15	18:00	Cont	Fitting of Copper earth bond	MSETCL	MSETCL
3	400	Akola - Aurangabad Ckt - II (PGCIL) with bay numbers 406, 407 & reactor bay at 400 kV Akola	02-Oct-15	8:00	02--OCT-15	18:00	Daily	Routine maintenance and testing works.	MSETCL	MSETCL
4	500	BiPOLE Chandrapur-Padghe	05-Oct-15	8:00	06-Oct-15	8:00	Cont	Annual Maintenance work	MSETCL	MSETCL
5	400	Tie Bay 409 only between 400kv Akola - Bhusawal line and Wardha Ckt 01	05-Oct-15	9:00	07-Oct-15	18:00	Cont	Servicing and Overhauling of Areva make 400kv CB by agency	MSETCL	MSETCL
6	400	NAGOTHANE - DABHOL 1	06-Oct-15	10:00	06-Oct-15	18:00	Daily	Half Yearly maint. Work	MSETCL	MSETCL
7	400	Chandrapur II - Warora Ckt-II line	07-Oct-15	8:00	08-Oct-15	18:00	Cont	Fitting of Copper earth bond	MSETCL	MSETCL
8	400	NEW KOYNA- JAIGADCKT 1	08-Oct-15	10:00	08-Oct-15	18:00	Daily	cold line insulaor disc washing	MSETCL	MSETCL
9	400	400KV Chandrapur- Parali Ckt No. I	08-Oct-15	8:30	08-Oct-15	18:00	Daily	Replacement of Corona Ring, Arcing Horn, Fixing of Earth Bond, quarterly maintenance work, etc.	MSETCL	MSETCL
10	220	Kalmeshwar - Pandhurna	08-Oct-15	9:00	08-Oct-15	18:00	Daily	MAINTENANCE WORK	MSETCL	MSETCL
11	400	NAGOTHANE - DABHOL 2	09-Oct-15	9:00	09-Oct-15	18:30	Daily	Half Yearly maint. Work	MSETCL	MSETCL
12	400	DHULE - BABLESHWAR - I	10-Oct-15	9:00	10-Oct-15	18:00	Daily	Half Yearly maint. work	MSETCL	MSETCL
13	220	Nasik Navsari I	10-Oct-15	9:00	10-Oct-15	18:00	Daily	Half Yearly maint. Work	MSETCL	MSETCL
14	400	PADGHE - KALWA 1	11-Oct-15	11:00	11-Oct-15	18:00	Daily	Half Yearly maint. Work	MSETCL	MSETCL
15	400	KHADKA-AURANGABAD (WALUJ)	12-Oct-15	8:00	12-Oct-15	17:00	Daily	Quarterly Maintenance.	MSETCL	MSETCL
16	400	N.KOYNA-KARAD -CKT 2	13-Oct-15	8:00	13-Oct-15	17:00	Daily	Half Yearly maint. Work	MSETCL	MSETCL
17	400	Koradi - Khaperkheda II	14-Oct-15	8:00	14-Oct-2015	17:00	Daily	During the proposed outages line maint. works such as Line Signature by Taurus Kit, Faulty disc strings replacement, Fixing of Spacers, Dampers, Earthbond, Carona Rings etc. and various Diagnostic Testing works will be carried out.	MSETCL	MSETCL
18	400kv	Main Bay 402 only of 400/220 kv, 315 MVA ICT at 400 kV Akola.	15-Oct-15	9:00	15-Oct-15	18:00	Daily	Routine maintenance and testing works.	MSETCL	MSETCL
19	400	Koradi - Khaperkheda I	16-Oct-15	9:00	27-Oct-2015	17:00	Daily	CT Tan delta, CB CRM & DCRM measurement will carried out and various maintenance works.	MSETCL	MSETCL
20	400	Tie Bay 403 only between 400/220 kv, 315 MVA ICT and Aurangabad Ckt - I at 400 kV Akola.	16-Oct-15	10:00	16-Oct-15	18:00	Daily	Routine maintenance and testing works.	MSETCL	MSETCL
21	400	KALWA - TALEGAON(PGCIL)	18-Oct-15	10:00	18-Oct-15	17:30	Daily	Half Yearly maint. Work	MSETCL	MSETCL
22	400	Main bay 414 only of 400kV Akola - Yelwan Ckt -I at 400 kv Akola	19-Oct-15	15:00	19-Oct-15	18:00	Daily	Routine maintenance and testing works.	MSETCL	MSETCL
23	400	Akola-Aurangabad	20-Oct-15	7.30	25-Oct-15	19:00	Daily	OPGW work-A/R bypass	MSETCL	MSETCL
24	400	Bableshtar-Dhule D/C	20-Oct-15	8.00	19-Nov-15	17:00	Daily	OPGW work-A/R bypass	MSETCL	MSETCL
25	400	Bableshtar-Aurangabad	20-Oct-15	8.00	19-Nov-15	17:00	Daily	OPGW work-A/R bypass	MSETCL	MSETCL
26	400	Talegaon(PG)-Padghe	20-Oct-15	8.00	19-Nov-15	17:00	Daily	OPGW work-A/R bypass	MSETCL	MSETCL
27	400	Talegaon(PG)-Lonikand	20-Oct-15	8.00	19-Nov-15	17:00	Daily	OPGW work-A/R bypass	MSETCL	MSETCL
28	400	Kalwa-Padgha-D/c	20-Oct-15	8.00	19-Nov-15	17:00	Daily	OPGW work-A/R bypass	MSETCL	MSETCL
29	400	N.KOYNA-KARAD -CKT 1	20-Oct-15	10.00	20-Oct-15	17:00	Daily	Half Yearly maint. Work	MSETCL	MSETCL
30	400	400KV Chandrpur-I-Chandrapur-II ckt. No. - II	20-Oct-15	7:00	20-Oct-15	19:00	Cont	For Measurement C & Tan Delta of CT's & CVT's and Relay testing work.	MSETCL	MSETCL
31	400	Akola-Nandgaonpeth Line	20-Oct-15	10:00	20-Oct-15	18:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode.PID of 400kV Akola - Nandgaonpeth line shall be carried out under supervision of Hot line unit Akola at Railway Crossing Loc No. 374-374A, 481-482	MSETCL	MSETCL
32	400	Warora-ADANI CKT-2 (Bay no.414 & 415)	20-Oct-15	8.00	20-Oct-15	18:00	Daily	To Carry out DCRM of Tie CB, C & tan Delta of line CVT and metering CT and Line CT	MSETCL	MSETCL
33	400	400KV Chandrapur II - Parli Ckt-I line	21-Oct-15	9:00	21-Oct-15	12:00	Daily	Line Signature Test	MSETCL	MSETCL
34	400	400KV Chandrapur II - Parli Ckt-II line	21-Oct-15	14:00	21-Oct-15	17:00	Daily	Line Signature Test	MSETCL	MSETCL
35	400	Akola-Bhusawal Line	21-Oct-15	10:00	21-Oct-15	18:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode.PID of 400kV Akola - Bhusawal Line shall be carried out under supervision of Hot line unit Akola at Railway Crossing Loc No. 558-559.	MSETCL	MSETCL
36	400	NEW KOYNA- JAIGAD CKT 2	22-Oct-15	10.00	22-Oct-15	17:00	Daily	Cold line Insulator disc washing	MSETCL	MSETCL
37	400	400 kV Koradi -Bhusawal Line	23-Oct-15	10:00	23-Oct-15	18:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400kV Koradi - Bhusawal Line shall be carried out under supervision of Hot line unit Akola at Railway Crossing Loc No. 373-373A, 474-475	MSETCL	MSETCL
38	400	400KV Chandrapur-Khaperkheda line	23-Oct-15	9:00	23-Oct-15	12:00	Daily	Line Signature Test	MSETCL	MSETCL
39	400	BABHALESHWAR - PADGHE 2	23-Oct-15	10.00	23-Oct-15	17:00	Daily	Half Yearly maint. Work	MSETCL	MSETCL
40	400	400/220/33 kV 3*167 MVA ICT- 3 at Waluj	23-Oct-15	10.00	23-Oct-15	17:00	Daily	Quarterly Maint. CT & T/F Tan delta	MSETCL	MSETCL
41	400	400 kV Koradi -Bhusawal Line	24-Oct-15	10:00	24-Oct-15	18:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode.PID of 400kV Koradi - Bhusawal Line shall be carried out under supervision of Hot line unit Akola at Railway Crossing Loc No. 551-552	MSETCL	MSETCL
42	400	BABHALESHWAR - DHULE-I	26-Oct-15	10.00	28-Oct-15	17:00	Continuous	Main 2 distance protection relay replacement work	MSETCL	MSETCL
43	400	Main Bay 402 only of 400/220/33kv, 315 MVA ICT AKOLA	26-Oct-15	9:00	28-Oct-15	18:00	Continuous	Servicing and Overhauling of Areva make 400kv CB .ICT will be in service through its tie bay 403.Said work will be carried out by Agency.	MSETCL	MSETCL
44	400	400/220kv, 315 MVA ICT at 400kv R.S. Khadka	26-Oct-15	9:00	28-Oct-15	17:00	Continuous	R-Ph UNIT'S 33 KV Tertiary Bushing Replacement work, PT Repalcement & bay testing work etc.	MSETCL	MSETCL
45	400	400kv Thapiltanda-Deepnagar	26-Oct-15	9:00	29-Oct-15	18:00	Continuous	Balance rectification work observed in joint patrolling.	MSETCL	MSETCL
46	400	Khadka-Deepnagar-I at 400kv R.S. Khadka	27-Oct-15	7:00	28-Oct-15	17:00	Daily	Tighting of jumper & Nut Bolt of Suspesion Tower by 400 kv LM S/Dn Akot side, Khadka	MSETCL	MSETCL
47	500	BIPOLE (POLE-I & POLE-II) annual outage	28-Oct-15	8:00	29-Oct-15	20:00	Cont	Annual maintenance work	MSETCL	MSETCL
48	400	KARAD JAIGAD CKT 2	28-Oct-15	10:00	28-Oct-15	17:00	Daily	Cold line Insulator disc washing	MSETCL	MSETCL
49	400	Chandrapur Parali Circuit - III	28-Oct-15	8:00	28-Oct-15	18:00	Daily	Fixing and replacement of broken Spacer cum vibration dampers .Chandrapur Parali Circuit - I & II will be in service	MSETCL	MSETCL
50	400	ICT-II at 400KV GCR Chandrapur	29-Oct-15	8:00	29-Oct-15	18:00	Cont	For measurement for DCRM & timing of CB	MSETCL	MSETCL
51	400	Chandrapur Parali Circuit - II	29-Oct-15	8:00	29-Oct-15	18:00	Daily	Fixing and replacement of broken Spacer cum vibration dampers .Chandrapur Parali Circuit - I & III will be in service	MSETCL	MSETCL
52	400	Tie Bay 403 only between 400/220 kv ,315 MVA ICT AKOLA and Aurangabad Ckt - 01(At Akola S/S)	29-Oct-15	9:00	31-Oct-15	18:00	Continuous	Servicing and Overhauling of Areva make 400kv CB . ICT and A'bad Ckt 01 will be in service through their respective Main Bays	MSETCL	MSETCL

53	400	Bus Coupler bay @ Parli	29-Oct-15	9:00	29-Oct-15	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL
54	400	Chandrapur Parali Circuit - III	30-Oct-15	8:00	30-Oct-15	18:00	Daily	Fixing and replacement of broken Spacer cum vibration dampers .Chandrapur Parali Circuit - I & II will be in service.Said work will be carried out by Agency.	MSETCL	MSETCL
55	400	BABHALESHWAR - PADGHE 1	30-Oct-15	8:00	30-Oct-15	18:00	Daily	Q.M work and Relay/CB testing work	MSETCL	MSETCL
56	400	Chandrapur Parali Circuit - III	30-Oct-15	8:00	30-Oct-15	18:00	Daily	Fixing and replacement of broken Spacer cum vibration dampers .Chandrapur Parali Circuit - I & II	MSETCL	MSETCL
57	400	Chandrapur Parali Circuit - II	31-Oct-15	8:00	31-Oct-15	18:00	Daily	Fixing and replacement of broken Spacer cum vibration dampers.Chandrapur Parali Circuit - I & III will be in service.Said work will be carried out by Agency.	MSETCL	MSETCL
58	400	Chandrapur Parali Circuit - II	31-Oct-15	8:00	31-Oct-15	18:00	Daily	Fixing and replacement of broken Spacer cum vibration dampers .Chandrapur Parali Circuit - I & III will be in service	MSETCL	MSETCL
59	400	BABHALESHWAR - DHULE-2	31-Oct-15	10:00	31-Oct-15	17:00	Daily	Q.M work and Relay/CB testing work	MSETCL	MSETCL
60	400	Khadka-Akola Ckt along with Line	31-Oct-15	9:00	31-Oct-15	17:00	Daily	Routine bay Maintenance & attending high tempature point /Dignostic Testing work of Reactor Monitoring and CVT Monitoring/replacement work if reqd. LSA & line maintenance by 400 KV LM S/Dn Akot side, Khadka	MSETCL	MSETCL
61	400	400/220kV, 501 MVA ICT-1 at 400kV Deepnagar Substation	31-Oct-15	9:00	31-Oct-15	17:00	Daily	Relay testing, CB Timing, DCRM Measurement & routine bay Maintenance work.	MSETCL	MSETCL
62	400	Bus Coupler at 400kV R.S. Dhule	31-Oct-15	9:00	31-Oct-15	17:00	Daily	Quarterly Maintenance work & Routine Testing	MSETCL	MSETCL