

WRPC OCCM approved Monthly Outage list for the Month of October'2018

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
1	4	220	TAPS 1&2 switchyard zone III and TAPS3&4 tie line	01/Oct/18	8:00	01/Oct/18	19:00	Daily	For TAPS 1&2 switchyard Zone-III main bus outage	MSETCL	NPCL		
2	5	500	CHANDRAPUR - PADGHE HVDC POLE 1	01/Oct/18	07:00	01/Oct/18	16:00	Daily	Q M WORK	MSETCL	MSETCL	-	
3	29	400	NEW KOYNA -KARAD -CKT 2 at Karad	01/Oct/18	10:00	04/Oct/18	17:00	Continuous	Overhauling of CGL make SF6 CB Mechanism drive & Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 KV Koyana -1 & Load will be shifted on TBC	
4	32	400	KHADKA - BABLESHWAR CKT (ON TBC)	01/Oct/18	09:00	05/Oct/18	17:00	Continuous	Quarterly Maintenance, Repair scissors of 400KV P.G Isolator and Servicing, alignment of isolators	MSETCL	MSETCL	Line will be on TBC for Repairing of 29A & 29B P.G Isolator P.G Isolator Scissors (Hanger dropper assembly will be remove and reconnected on 400 kv bus 1 and bus 2, work will carryout by hot line unit Nashik)	
5	35	400	403 main bay of parli ckt at lamboti	01/Oct/18	10:00	08/Oct/18	18:00	Continuous	Overhauling of Circuit Breaker	MSETCL	MSETCL	400KV Parali line will be in service through 402-52 Tie Circuit Breaker.	
6	37	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01/Oct/18	06:00	15/Oct/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	AR switch to be kept on non auto mode. work by 400KV LM S/Dn, Yavatmal	
7	38	400	50 MVar BUS REACTOR @ KHADKA	01/Oct/18	06:00	15/Oct/18	18:00	Continuous	For Shifting of Existing 400kV 50 MVAR Reactor to newly erected bay.	MSETCL	MSETCL	-	
8	39	400	BABHALESHWAR - PADGHE 2	01/Oct/18	09:00	20/Oct/18	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Only A/R require to take out of service	
9	41	220	PUSAD - WARDHA (PG)	01/Oct/18	07:00	31/Oct/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Shifting of auto reclose switch to non auto mode. work by EHV LM S/Dn, Yavatmal/ Pused	
10	47	765	709LR Akola Line-1 Reactor at Koradi III SS	01/Oct/18	7:00	01/Oct/18	16:00	Daily	Testing and Maintenance of Reactor and Breaker Maintenance	MEGPTCL	MEGPTCL		
11	63	400	80 MVar Bus reactor @ Talandge	03/Oct/18	09:00	03/Oct/18	18:00	Daily	Quarterly. Maint. work	POWERGRID	MSETCL	-	
12	64	400	Main Bay (428) of 400 KV Warora Ckt-I @ Chandrapur - 2	03/Oct/18	09:00	03/Oct/18	15:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
13	65	220	JEUR - SOLAPUR PG	03/Oct/18	10:00	03/Oct/18	16:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	150 MW Approx load of 132KVparewadi, Karmala,Karjat,Rashin & 132KV Bhairavnath Co-gen & 132KV kurdwadi will get affected	
14	85	765	765 KV BUS-2 at Warora	03/Oct/18	9:00	03/Oct/18	18:00	Daily	For Guy wire arrangement work in future bay.	WRTS-I	WRTS-I	C	
15	99	400	MAIN BUS - 2 @ LONIKAND 2	03/Oct/18	09:00	03/Oct/18	18:00	Daily	Half yearly maint. And diag.testing	MSETCL	MSETCL	Load will be managed by 400 KV Bus A, load effected NIL	Outage is re-scheduled on 03.10..2018.
16	100	765	706 Main Bay of Bus Reactor at Koradi III SS	03/Oct/18	9:00	03/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
17	103	400	CHANDRAPUR 2 - WARORA CKT-2	04/Oct/18	08:00	04/Oct/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	-	Outage is re-scheduled on 04.10..2018.
18	104	220	SOUTH SOLAPUR (KUMBHARI)-PGCIL 1	04/Oct/18	11:00	04/Oct/18	16:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Load can be managed on other 220KV South Solapur - PGCIL Ckt 2	
19	109	400	400 KV SSNL - Dhule line No. 1	04/Oct/18	8:00	04/Oct/18	18:00	Daily	Maintenance Work	NCA	GETCO	Auto reclose of SSP- Dhule No. 2 will remain out	
20	114	400	PARLI - NANDED CKT - 2	04/Oct/18	09:00	04/Oct/18	17:00	Daily	CVT C & Tan delta measurement, CT replacement, Bay maintenance and line hardware tightening work.	MSETCL	MSETCL	-	
21	115	400	LONIKAND 1 - CHAKAN	04/Oct/18	08:00	04/Oct/18	19:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-	
22	116	220	KALMESHWAR-PANDHURNA	04/Oct/18	08:00	04/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
23	136	765	765KV PUNE(GIS)-SOLAPUR	04/Oct/18	8:00	05/Oct/18	18:00	Daily	For Line AMP works by Solapur to attend CC ring missing in tower 383(12 nos.+ 2nos from pilot) - Tension Tower,386(12 nos.) - Tension Tower,395(2 nos.)	WRTS-I	WRTS-I	R	
24	137	765	765KV Bus-2 at Parli(New)	04/Oct/18	9:00	05/Oct/18	18:00	Conti..	For Bus Isolator Alignment Problems rectification at New Parli	WRTS-I	WRTS-I	R	
25	138	400	Station Transformer 2 Main Bay 407 at Tiroda SS	04/Oct/18	9:00	04/Oct/18	18:00	Daily	Testing and Maintenance of Breaker and Isolator	APML	APML		
26	142	220	TALEGAON (AMBI)-TALEGAON (PG) CKT 1	05/Oct/18	09:00	05/Oct/18	17:00	Daily	Replacement of Cu palm by Al palm & relay testing work by testing team. Also half yearly maintenance to be carried out.	MSETCL	MSETCL	Load will be managed on 220kv Talegaon- PGCIL-2 ckt during the outage. Work will be carried out by EHV O&M Division-II Pune	
27	145	400	400 KV SSNL-Dhule - 2	05/Oct/18	8:00	05/Oct/18	18:00	Daily	Maintenance Work	NCA	GETCO	Auto reclose of SSP- Dhule No. 1 will remain out	
28	151	400	CHANDRAPUR 2-NANDED CKT - 2	05/Oct/18	10:00	05/Oct/18	18:00	Daily	DCRM, Timing testing of CB	MSETCL	MSETCL	-	
29	152	220	NASHIK-NAVASARI I	05/Oct/18	09:00	05/Oct/18	15:00	Daily	bay maintenance work	MSETCL	MSETCL	-	
30	153	220	BORIVALI - TARAPUR	05/Oct/18	08:00	05/Oct/18	17:00	Daily	Annual Maintenance & Signature Testing of line	MSETCL	MSETCL	-	
31	158	400	315 MVA ICT-1 at Boisar	05/Oct/18	9:00	05/Oct/18	17:30	Daily	For ICT AMP	POWERGRID	WR-II	R	
32	169	400	400KV PUNE(GIS)-PUNE(TALEGAON)_2	05/Oct/18	9:00	05/Oct/18	11:00	Daily	CVT oil Top Up	WRTS-I	WRTS-I	R	
33	178	400	KARAD - TALANDGE CKT 1 at Karad	05/Oct/18	10:00	08/Oct/18	17:00	Continuous	Overhauling of CGL make SF6 CB Mechanism drive & Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 KV Talandge Ckt-2 & Load will be shifted on TBC	
34	179	765	701 Main Bay of ICT HV Side at Akola II SS	05/Oct/18	9:00	05/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
35	193	400	CHANDRAPUR 2 - WARORA CKT-1	06/Oct/18	08:00	06/Oct/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	-	
36	194	400	KORADI 2-WARDHA (PG)	06/Oct/18	10:00	06/Oct/18	14:00	Daily	Tan delta Maasurement of Line CVT	MSETCL	MSETCL	400KV Koradi-II-IEPL line will be service	
37	204	400	400kv PUNE(GIS)-PUNE(TALEGAON)_4	06/Oct/18	9:00	06/Oct/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments	WRTS-I	WRTS-I	R	
38	208	400	400 KV Akola-Aurangabad-2 tie Bay 406 at Akola	06/Oct/18	9:00	06/Oct/18	18:00	Daily	AMP work at Akola end	WRTS-I	WRTS-I	R	
39	213	400	BABHALESHWAR - PADGHE 1 (ON TBC)	06/Oct/18	09:00	10/Oct/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work.	MSETCL	MSETCL	Line will be on TBC for Repairing of 29A & 29B P.G Isolator P.G Isolator Scissors (Hanger dropper assembly will be remove and reconnected on 400 kv bus 1 and bus 2, work will carryout by hot line unit Nashik)	
40	219	765	709 Main Bay of 765 KV Koradi - Akola Line-1 at Koradi III SS	06/Oct/18	9:00	06/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
41	224	400	400KV Talegaon-Kalwa Line at Talegaon Substation	07/Oct/18	9:00	07/Oct/18	17:00	Daily	For rectification of conductor unwind problem at line Isolator 'B' phase	WRTS-I	WRTS-I	R	Outage to be availed on 07.10..2018 considering real time loading.
42	233	220	TALEGAON (AMBI)-TALEGAON (PG) CKT 2	07/Oct/18	09:00	07/Oct/18	17:00	Daily	Replacement of Cu palm by Al palm & relay testing work by testing team. Also half yearly maintenance to be carried out.	MSETCL	MSETCL	Load will be managed on 220kv Talegaon-PGCIL-1 ckt during the outage. Work will be carried out by EHV O&M Division-II Pune	
43	240	400	KALWA - TALEGAON (PGCL)	07/Oct/18	08:00	07/Oct/18	18:00	Daily	Line Maintenance	MSETCL	MSETCL	Work will be carried out by 400 KV Lonikand 1 Sub-Division	Outage is re-scheduled on 07.10.2018.
44	260	400	ICT1 400/220kv WARDHA	08/Oct/18	9:00	08/Oct/18	18:00	Daily	For AMP work at Wardha end	WRTS-I	WRTS-I	R	
45	265	400	TIE BAY (428) OF WARORA - WARDHA(PG) @ WARDHA (PG)	08/Oct/18	09:00	12/Oct/18	17:00	Continuous	Routine Maintenance & Diagnostic testing work and replacement of R-ph pole complete wiring.	POWERGRID	MSETCL	-	
46	267	220	DEOLI(PGCIL)-BADNERA	08/Oct/18	07:00	13/Oct/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	Shifting of auto reclose switch to non auto mode. Work by LMSD Badnera	
47	270	765	702 Tie Bay of ICT HV Side and Bus Reactor at Akola II SS	08/Oct/18	9:00	08/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
48	305	400	NEW KOYNA-KARAD -CKT 1at karad	09/Oct/18	10:00	12/Oct/18	17:00	Continuous	Overhauling of CGL make SF6 CB Mechanism drive & Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 KV Koyana -2 & Load will be shifted on TBC	
49	307	765	708 Tie Bay of Akola Line-1 and Tiroda Line-2 at Koradi III SS	09/Oct/18	9:00	09/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
50	316	400	400kv AURANGABAD(PG)-BOISAR II	10/Oct/18	9:00	10/Oct/18	18:00	Daily	for line AMP works	WRTS-I	WRTS-I	-	
51	320	400	CHANDRAPUR 2- NANDED CKT - 1	10/Oct/18	10:00	10/Oct/18	17:00	Daily	n/b tightening at loc.no. 434	MSETCL	MSETCL	-	
52	344	400	PARLI-SOLAPUR (LAMBOTI)	10/Oct/18	09:00	10/Oct/18	17:00	Daily	CB DCRM & timing, Bay maintenance and line hardware tightening work.	MSETCL	MSETCL	-	Outage to be availed on 10.10.2018.
53	354	220	220KV Talegaon MSETCL Line # 1 at Talegaon Substation	11/Oct/18	9:00	11/Oct/18	17:00	Daily	AMP of Line Equipments	WRTS-I	WRTS-I	R	Outage is re-scheduled on 11.10..2018.
54	361	765	MAIN BAY - 701 OF 765/400KV 1500MVA ICT-1 @ KORADI 3	11/Oct/18	09:00	11/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	-	
55	362	400	PARLI - NANDED CKT - 2	11/Oct/18	10:00	11/Oct/18	18:00	Daily	DCRM, Timing testing of CB	MSETCL	MSETCL	-	
56	363	400	MAIN BUS - 1 @ LONIKAND-II	11/Oct/18	09:00	11/Oct/18	18:00	Daily	Half yearly maint. And diag.testing Work	MSETCL	MSETCL	Load will be managed by 400 KV Bus B, load effected NIL	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
57	364	400	BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	11/Oct/18	09:00	11/Oct/18	18:00	Daily	Quarterly Maint. work	MSETCL	MSETCL	-	
58	365	220	TILARI - AMONA LINE	11/Oct/18	08:00	11/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
59	383	400	400 kV Kohapur(MSETCL) CKT-II & BR Tie bay (411) at Kolhapur-GIS.	11/Oct/18	10:00	11/Oct/18	18:00	Daily	For AMP works.	WRTS-I	WRTS-I	R	
60	393	400	BABHALESHWAR - PADGHE 2 (ON TBC)	11/Oct/18	09:00	15/Oct/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400kV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	Line will be on TBC for Repairing of 29A & 29B P.G Isolator Scissors (Hanger dropper assembly will be remove and connected on 400 kv bus 1 and bus 2, work will carryout by hot line unit Nashik)	
61	396	765	701 Main Bay of ICT-1 at Koradi III SS	11/Oct/18	9:00	11/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
62	404	400	400 KV Bus -1 at Wardha	12/Oct/18	9:00	12/Oct/18	18:00	Daily	Alignment of newly erected bus isolator	WRTS-I	WRTS-I	C	
63	407	400	400kV PADGHE(GIS)-KUDUS(PADGHE MSETCL) I	12/Oct/18	10:00	12/Oct/18	18:00	Daily	For LA & CVT Testing of 400 Kudus Line-1 at Padghe GIS.	WRTS-I	WRTS-I	R	
64	410	765	MAIN BAY (703) BUS REACTOR @ AKOLA 2	12/Oct/18	09:00	12/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--	
65	411	400	PADGHE - NAGOTHANE 2	12/Oct/18	08:00	12/Oct/18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil	
66	421	400	400KV BHADRAVATI-CHANDRAPUR I	12/Oct/18	9:00	12/Oct/18	18:00	Daily	For AMP work at Chandrapur end.	WRTS-I	WRTS-I	R	
67	423	400	400KV Kalwa & ICT # 3 Tie bay (417) at Talegaon	12/Oct/18	9:00	12/Oct/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
68	428	765	703 Main Bay of Bus Reactor at Akola II SS	12/Oct/18	9:00	12/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
69	435	400	400 KV BUS -2 at Wardha	13/Oct/18	9:00	13/Oct/18	18:00	Daily	Alignment of newly erected bus isolator	WRTS-I	WRTS-I	C	
70	443	765	TIE BAY (702) OF ICT-1 & FUTURE BAY @ KORADI 3	13/Oct/18	09:00	13/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--	
71	444	400	KALWA - KHARGHAR	13/Oct/18	09:30	13/Oct/18	17:30	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	-	
72	450	400	404 Bay (Main bay of 400KV Pune GIS-1 at Talegaon	13/Oct/18	9:00	13/Oct/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
73	452	400	KARAD - SOLAPUR (PG)	13/Oct/18	10:00	16/Oct/18	17:00	Continuous	Overhauling of CGL make SF6 CB Mechanism drive & Quarterly Maint. Work	MSETCL	MSETCL	Now Ckt is hand tripped for O/V & in case of emergency ckt. will be shifted on TBC	
74	454	765	702 Tie Bay of ICT-1 and Future bay at Koradi III SS	13/Oct/18	9:00	13/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
75	455	400	CHANDRAPUR GCR - CHANDRAPUR HVDC - I	14/Oct/18	08:00	14/Oct/18	18:00	Daily	1) PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work). 2) For Measurement of Tan delta & capacitance of CT's. 3) Replacement of trip circuit supervision relay of TC- 1 & 2.	MSETCL	MSETCL	400 KV GCR- HVDC ckt No. - II will be in service.	
76	457	400	KHARGHAR - TALEGAON (PG)	14/Oct/18	08:00	14/Oct/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Nil	Outage is re-scheduled on 14.10. 2018.
77	460	400	KHARGHAR - TALEGAON (PG)	14/Oct/18	08:00	14/Oct/18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	Work will be carried out by 400 KV Lonikand 1 SS	Outage is re-scheduled on 14.10. 2018.
78	464	220	BOISAR II - PGCIL 1	14/Oct/18	08:00	14/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	Outage to be availed on 14.10.2018.
79	468	400	BUS REACTOR_400KV_50MVAR_WARDHA	14/Oct/18	9:00	14/Oct/18	18:00	Daily	For AMP work at Wardha end	WRTS-I	WRTS-I	R	
80	470	400	400kV Bus-1 at Parli(New)	14/Oct/18	9:00	14/Oct/18	18:00	Daily	For Bus Isolator Alignment Problems rectification at New Parli	WRTS-I	WRTS-I	R	
81	471	400	KHARGHAR - TALEGAON (PG)	14/Oct/18	08:00	14/Oct/18	18:00	Daily	Routine Maintenance & Diagnostic testing work, bay Maintenance & testing work	MSETCL	MSETCL	Outage is required by 400kV line S/Dn, Kalwa	
82	485	765	MAIN BAY (704) OF ICT - 2 @ KORADI 3	15/Oct/18	09:00	15/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--	
83	486	400	WARORA - Wardha(PG)	15/Oct/18	09:00	15/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	-	
84	487	220	TALANDAGE - CHIKODI	15/Oct/18	08:00	15/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
85	497	220	200KV Chitagaon-2 bay-206 at Aurangabad	15/Oct/18	9:00	15/Oct/18	18:00	Daily	for AMP works, load shall be shifted to TBC during the period	WRTS-I	WRTS-I	R	
86	499	400	400KV Pune GIS # 1 & ICT # 1 Tie bay (405) at Talegaon	15/Oct/18	9:00	15/Oct/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
87	507	765	704 Main Bay of ICT-2 at Koradi III SS	15/Oct/18	9:00	15/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
88	519	400	MAIN BUS - 1 @ TIRORA	16/Oct/18	08:00	16/Oct/18	21:00	Daily	Testing and Maintenance of Bus connected isolator and CVT	APML	APML	--	Will be reviewed based on available generation on that day.
89	520	400	NAGOTHANE - DABHOL 1	16/Oct/18	08:00	16/Oct/18	17:00	Daily	CT Replacement	MSETCL	MSETCL	Nil	
90	528	400	400KV BHADRAVATI-CHANDRAPUR II	16/Oct/18	9:00	16/Oct/18	18:00	Daily	For AMP work at Chandrapur end.	WRTS-I	WRTS-I	R	
91	529	400	400KV Chakan & Kharghar Tie bay (402) at Talegaon	16/Oct/18	9:00	16/Oct/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
92	532	400	ICT2_400/220kv_WARDHA	16/Oct/18	9:00	16/Oct/18	18:00	Daily	For AMP work at Wardha end	WRTS-I	WRTS-I	R	
93	535	400	BABLESHWAR- AURANGABAD (ON TBC)	16/Oct/18	09:00	20/Oct/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400kV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	Line will be on TBC for Repairing of 29A & 29B P.G Isolator P.G Isoalor Scissors (Hanger dropper assembly will be remove and connected on 400 kv bus 1 and bus 2, work will carryout by hot line unit.Nashik)	
94	537	400	CHANDRAPUR-PARLI CKT-3	16/Oct/18	6:00	31/Oct/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	AR switch Shifting on non auto mode. Work by 400kV LM S/Dn, Yavatmal	
95	538	400	CHANDRAPUR 2-NANDED CKT - 2	16/Oct/18	08:00	31/Oct/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	AR switch to be on non auto mode. work by 400kV LM S/Dn, Yavatmal	
96	552	400	KORADI 2-WARDHA PGCIL	17/Oct/18	09:00	17/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	-	
97	553	400	NAGOTHANE - DABHOL 2	17/Oct/18	08:00	17/Oct/18	17:00	Daily	CT Replacement	MSETCL	MSETCL	Nil	
98	562	400	416 Bay (Main Bay 400KV Kalwa Main Bay (416) at talegaon	17/Oct/18	9:00	17/Oct/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
99	567	220	NASHIK-NAVASARI II	18/Oct/18	09:00	18/Oct/18	15:00	Daily	bay maintenance wok	MSETCL	MSETCL	-	May be planned on 18.10.18. Both Navsari - Nashik line outage are requested by GETCO
100	575	220	400 KV Warora-2 (PG) Tie bay 408 at Wardha	18/Oct/18	9:00	18/Oct/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	
101	578	220	Navsari - Nasik line No. 1	18/Oct/18	6:00	18/Oct/18	19:00	Daily	220 KV Bus section - II outage at Navsari GETCO S/S for bus strengthening	GETCO	GETCO		
102	579	220	Navsari - Nasik line No. 2	18/Oct/18	6:00	18/Oct/18	19:00	Daily	220 KV Bus section - II outage at Navsari GETCO S/S for bus strengthening	GETCO	GETCO		
103	583	400	SOLAPUR PG - ALKUD	18/Oct/18	09:30	18/Oct/18	17:30	Daily	Quarterly Maint. Work	MSETCL	MSETCL	-	
104	584	400	LONIKAND 1 -JEJURI	18/Oct/18	08:00	18/Oct/18	18:00	Daily	Annual maintenance work, Line Maintenance & testing work	MSETCL	MSETCL	Total Load will be fed from 400kV Jejuri-Koyana Stage-IV Line	
105	591	220	220kV Bus-II at Talegaon	18/Oct/18	9:00	18/Oct/18	17:00	Daily	For AMP works, All Bus-II connect feeder will service through transfer Bus during this period.	WRTS-I	WRTS-I	R	Outage is re-scheduled on 18.10.2018.
106	598	400	400KV ICT2 & LAMBOTI TIE_BAY_408 at solapur	19/Oct/18	9:00	19/Oct/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I	R	
107	602	400	TIE BAY (421) OF WARDHA(PG) CKT & FUTURE CKT - 2 @ WARORA	19/Oct/18	08:00	19/Oct/18	17:00	Daily	Routine maintenance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintenance work and DCRM	MSETCL	MSETCL	400KV Bay No 422 charged on No Load	
108	603	400	B BUS WITH BUS COUPLER @ NAGOTHANE	19/Oct/18	08:00	19/Oct/18	18:00	Daily	Padgha 1 PG Isolator overhauling	MSETCL	MSETCL	Outage required on 400 kv B bus with Bus coupler	
109	604	400	400kV Boisar-Padghe at Boisar	19/Oct/18	9:00	19/Oct/18	17:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WR-II	R	
110	612	400	NAGOTHANE - DABHOL 2	20/Oct/18	08:00	22/Oct/18	18:00	Daily	Cold washing of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-I line	Outage is re-scheduled on 20.10.2018.
111	613	765	MAIN BAY (707) OF TIRORA CKT - 2 @ KORADI 3	20/Oct/18	09:00	20/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--	
112	615	400	400kV Boisar-Padghe at Boisar	20/Oct/18	14:00	20/Oct/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line OUTAGE REQUIRED)	POWERGRID	WR-II	R	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
113	619	765	707 Main Bay of 765 KV Tiroda - Koradi Line-2 at Koradi III SS	20/Oct/18	9:00	20/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
114	620	400	PADGHE - KALWA 2	21/Oct/18	08:00	21/Oct/18	18:00	Daily	Insulator Replacement work found faulty in PID testing. Bay Maintenance & testing work.	MSETCL	MSETCL	-	Outage to be availed on 21.10.2018.
115	621	400	CHANDRAPUR GCR - CHANDRAPUR HVDC - II	21/Oct/18	08:00	21/Oct/18	18:00	Daily	1) PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work). 2) For Measurement of Tan delta & capacitance of CT's. 3) Measurement of DCRM, Timing & CRM of breaker. 4) Replacement of trip circuit supervision relay of TC- 1 & 2.	MSETCL	MSETCL	400 KV GCR- HVDC ckt No. - I will be in service	
116	624	400	BUS COUPLER @ BABHALESHWAR	21/Oct/18	09:00	22/Oct/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400kV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	Bus will be separated (to work in Minimum time on 400kV Bus coupler Outage.. Outage taken on 400KV Aurganabad on TBC is taken at same time so that After Repairing P.G Isolator Utilized for 400KV Bus couper (Hanger dropper assembly of 400KV Bus coupler Bay will be removed and connected on 400 kv bus 1 and bus 2. work carried by hot line unit Nashik)	
117	631	400	BABHALESHWAR - PADGHE 1	21/Oct/18	09:00	31/Oct/18	18:00	Daily	To Off / Out Auto Reclose at Both Ends For Carriers out on Work.	MSETCL	MSETCL	Only A/R require to take out	
118	637	765	Main bay 710 of 1500MVA ICT-1 @ 765kv Ektuni	22/Oct/18	10:00	22/Oct/18	18:00	Daily	Routine Maintenance & Diagnostic Testing	MSETCL	MSETCL	765/400kV, 1500MVA ICT-II will be in service through its TIE (709) CB & Main Bus-I	
119	638	400	CHANDRAPUR-PARLI CKT-3	22/Oct/18	09:00	22/Oct/18	17:00	Daily	Line hardware tightening work.	MSETCL	MSETCL	-	
120	639	220	MUDSHINGI - CHIKODI	22/Oct/18	08:00	22/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
121	660	400	400/220 KV 315MVA ICT - 2 @ KARAD	22/Oct/18	10:00	25/Oct/18	17:00	Continuous	Overhauling of CGL make SF6 CB Mechanism drive & pole column & Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT's & Load will be shifted on TBC	
122	661	220	Navsari- Navsari 1 at Navsari	22/Oct/18	9:00	26/Oct/18	18:00	Cont.	03 nos CB Replacement work and at GETCO Navsari End	POWERGRID	WR-II	R	One ICT at Navsari to be made off. If require
123	662	400	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	22/Oct/18	09:00	05/Nov/18	0:00	Continuous	Replacement of B phase Unit	MSETCL	MSETCL	-	
124	663	400	400 KV Bus Reactor -1 at Tiroda SS	22/Oct/18	9:00	22/Oct/18	20:00	Daily	Shutdown maintenance of BR, Bay equipments and its relay testing	ATIL	ATIL		
125	671	400	400 KV Akola-Aurangabad-1 Line reactor	23/Oct/18	9:00	23/Oct/18	18:00	Daily	For AMP work at Akola end	WRTS-I	WRTS-I	R	
126	672	400	NAGOTHANE - DABHOL 1	23/Oct/18	08:00	25/Oct/18	18:00	Daily	Cold washing of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-II line	
127	675	765	Main bay 713 of 1500MVA ICT 2 @ 765kv Ektuni	23/Oct/18	10:00	23/Oct/18	18:00	Daily	Routine Maintenance & Diagnostic Testing	MSETCL	MSETCL	765/400kV, 1500MVA ICT-II will be in service through its TIE (712) CB	
128	676	400	MAIN BAY (411) OF TIRODA CKT - 1 @ WARORA	23/Oct/18	09:00	23/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MSETCL	ATIL	--	
129	677	400	Tie bay (408) of Ektuni line 1 @ Taptitanda	23/Oct/18	11:00	23/Oct/18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service	
130	692	400	0-51300-Line-2 (Tarapur-Padghe ckt-1)	23/Oct/18	9:00	24/Oct/18	18:00	Continuous	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	POWERGRID	NPCL		
131	694	400	DHULE - SSNNL CKT I (Ckt-2 A/R OUT)	23/Oct/18	08:00	24/Oct/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400kV SSNNL-2 A/R switch to be kept on non-auto mode	
132	696	400	411 Main Bay of 400 KV Tiroda - Warora Line-1 at Warora SS	23/Oct/18	9:00	23/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MSETCL	ATIL		
133	698	400	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	24/Oct/18	08:00	24/Oct/18	17:00	Daily	Routine maintenance and diagnostic testing such as CT tandelta,CRM,IR values,isolater maintenance work and DCRM	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.	Outage is re-scheduled on 24.10.2018.
134	701	765	Main bay 711 of 765 kv Bus Reactor @ Ektuni	24/Oct/18	10:00	24/Oct/18	18:00	Daily	Routine Maintenance & Diagnostic Testing	MSETCL	MSETCL	765KV Bus Reactor will be in service through TIE (712) CB & Main Bus-II	
135	702	400	PARLI-SOLAPUR (LAMBOTI)	24/Oct/18	10:00	24/Oct/18	18:00	Daily	Overhauling and Servicing of Isolators	MSETCL	MSETCL	Load will be managed on 400KV PGCIL	
136	703	400	MAIN BAY (409) OF EKTUNI CKT-1 @ TAPTITANDA	24/Oct/18	11:00	24/Oct/18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service	
137	704	220	SOUTH SOLAPUR (KUMBHARI)-PGCIL 2	24/Oct/18	11:00	24/Oct/18	16:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Load can be managed on other 220KV South Solapur - PGCIL Ckt-1	
138	705	220	MAHALAXMI - AMONA	24/Oct/18	08:00	24/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
139	714	400	400kV BHADRAVATI-CHANDRAPUR III	24/Oct/18	9:00	24/Oct/18	18:00	Daily	For AMP work at Chandrapur end.	WRTS-I	WRTS-I	R	
140	716	400	400KV Kharghar Mainb bay (403) at Talegaon	24/Oct/18	9:00	24/Oct/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
141	720	400	400 kV Kudgi Ckt-I & Mapusa Ckt-II Tie bay (402) at Kolhapur-GIS	24/Oct/18	10:00	24/Oct/18	18:00	Daily	For AMP works.	WRTS-I	WRTS-I	R	
142	726	400	414 Main Bay of 400 KV Tiroda - Warora Line-2 at Warora SS	24/Oct/18	9:00	24/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MSETCL	ATIL		
143	728	400	PARLI - LONIKAND 2 CKT 2	25/Oct/18	09:00	25/Oct/18	17:00	Daily	Relay testing. Line hardware tightening work and line signature analysis.	MSETCL	MSETCL	-	
144	734	765	BUS REACTOR (240 MVA) @ EKTUNI	25/Oct/18	10:00	25/Oct/18	18:00	Daily	Routine Maintenance & Diagnostic Testing	MSETCL	MSETCL	765KV Bus Reactor will be OUT OF SERVICE	
145	735	400	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	25/Oct/18	09:00	25/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	POWERGRID	MSETCL	-	
146	736	400	Tie bay (411) of Ektuni line 2 @ Taptitanda	25/Oct/18	11:00	25/Oct/18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service	
147	737	400	MAIN BAY (404) OF STATION TF - 1 @ TIRODA	25/Oct/18	09:00	25/Oct/18	18:00	Daily	Testing and Maintenance of Breaker and Isolator	APML	APML	--	
148	738	400	CHANDRAPUR 2-NANDED CKT - 2	25/Oct/18	07:00	25/Oct/18	18:00	Daily	For replacement of Damaged Earthwire Cross Arm .	MSETCL	MSETCL	-	
149	745	400	400kV BHADRAVATI-CHANDRAPUR IV	25/Oct/18	9:00	25/Oct/18	18:00	Daily	For AMP work at Chandrapur end.	WRTS-I	WRTS-I	R	
150	754	400	DHULE - SSNNL CKT II & A/R switch of CKT - I to be kept on non-auto mode	25/Oct/18	08:00	26/Oct/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	400kV SSNNL-1 A/R switch to be kept on non-auto mode	
151	760	400	400 KV Station Transformer 1 Main Bay 404 at Tiroda SS	25/Oct/18	9:00	25/Oct/18	18:00	Daily	Testing and Maintenance of Breaker and Isolator	APML	APML		
152	762	400	BABHALESHWAR - PADGHE 1	26/Oct/18	09:00	26/Oct/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400kV Babhaleshwar-Padghe-Ckt-2 will be in service	Outage is re-scheduled on 26.10.2018.
153	764	400	CHANDRAPUR-PARLI CKT-3	26/Oct/18	07:00	26/Oct/18	18:00	Daily	For replacement of Damaged Earthwire Cross Arm .	MSETCL	MSETCL	-	Outage is re-scheduled on 26.10.2018.
154	768	400	NEW KOYNA - DABHOL - I	26/Oct/18	08:00	27/Oct/18	18:00	Daily	Cold washing of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New Koyne CKT-2 line	
155	770	400	MAIN BAY (412) OF EKTUNI CKT - 2 @ TAPTITANDA	26/Oct/18	11:00	26/Oct/18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service	
156	771	400	TIE BAY (412) OF WARDHA (PG) CKT - 2 & NANGAON PETH CKT @ AKOLA	26/Oct/18	10:00	26/Oct/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	-	
157	772	220	NALASOPARA - BOISAR PG	26/Oct/18	09:00	26/Oct/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
158	774	220	220KV Pandhurna-Kamleshwar	26/Oct/18	9:00	26/Oct/18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
159	775	400	Bay No-408 Tie Bay of 400kv Boisar-Padghe Line & ICT-I at Boisar	26/Oct/18	9:00	26/Oct/18	13:00	Daily	For AMP	POWERGRID	WR-II	R	
160	780	400	400kV PADGHE(GIS)-KUDUS(PADGHE MSETCL) II	26/Oct/18	10:00	26/Oct/18	18:00	Daily	For LA & CVT Testing of 400 Kudus Line-2 at Padghe GIS.	WRTS-I	WRTS-I	R	
161	789	400	BUS COUPLER @ KARAD	26/Oct/18	10:00	31/Oct/18	17:00	Continuous	Overhauling of CGL make SF6 CB Mechanism drive & pole column & Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on BUS I& II	
162	790	400	406 Main Bay of Line-3 at Koradi III SS	26/Oct/18	9:00	26/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
163	794	400	BABHALESHWAR - PADGHE 2	27/Oct/18	09:00	27/Oct/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400kV Babhaleshwar-Padghe-Ckt-1 will be in service	Outage is re-scheduled on 27.10.2018.
164	798	765	MAIN BAY - 701 OF 765/400kV 1500MVA ICT @ AKOLA 2	27/Oct/18	09:00	27/Oct/18	18:00	Daily	ICT annual Maintenance Activity	MEGPTCL	MEGPTCL	--	
165	804	400	400kV KALA-KUDUS # 1	27/Oct/18	8:00	27/Oct/18	18:00	Daily	REPLACEMENT OF INSULATORS.	POWERGRID	WR-II	R	
166	805	220	220kV Bus-1 at Talegaon	27/Oct/18	9:00	27/Oct/18	17:00	Daily	For AMP works, All Bus-1 connect feeder will service through transfer Bus during this period.	WRTS-I	WRTS-I	R	
167	806	400	400 KV Koradi-Bhilai line	27/Oct/18	9:00	27/Oct/18	18:00	Daily	Replacement of Wave Trap at Koradi end	WRTS-I	WRTS-I	R	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
168	807	765	701 - 765/400KV ICT at Akola-II SS	27/Oct/18	9:00	27/Oct/18	18:00	Daily	ICT annual Maintenance Activity	MEGPTCL	MEGPTCL		
169	811	400	PADGHE - KALWA 1	28/Oct/18	08:00	28/Oct/18	18:00	Daily	Insulator Replacement work found faulty in PID testing. Bay Maintenance & testing work.	MSETCL	MSETCL	-	
170	820	400	400KV Talegaon Chakan Line at Talegaon Substation	28/Oct/18	9:00	28/Oct/18	17:00	Daily	AMP of Line Equipments	WRTS-I	WRTS-I	R	Outage to be availed on 28.10.2018.
171	823	400	EKTUNI - BABLESHWAR CKT 1	28/Oct/18	09:00	28/Oct/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service	
172	824	220	BOISAR II - PGCIL 2	28/Oct/18	08:00	28/Oct/18	17:00	Daily	Annual Maintenance & Signature Testing of line	MSETCL	MSETCL	-	Outage is re-scheduled on 28.10.2018.
173	832	400	NEW KOYNA - DABHOL - II	28/Oct/18	08:00	29/Oct/18	18:00	Daily	Cold washing of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New Koyna CKT-1 line	
174	837	400	400KV Talegaon Lonikand Line at Talegaon Substation	29/Oct/18	9:00	29/Oct/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments	WRTS-I	WRTS-I	R	Outage to be availed on 21.10..2018.
175	846	400	400 kV D/C Aurangabad - Pune (GIS)	29/Oct/18	6:00	30/Oct/18	20:00	Daily	Power line crossing of 400 kV D/C Aurangabad - Pune line at tower loc. no. 109 & 110 by 765 KV D/C LILO Aurangabad - Padghe Line	WRTMPL	CWRTL	Construction	
176	854	765	710 LR (TIRODA CKT - 1) REACTOR @ KORADI 3	29/Oct/18	09:00	29/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--	
177	855	400	MAIN BUS - 1 @ WARORA	29/Oct/18	08:00	29/Oct/18	17:00	Daily	Routine maintainance and diagnostic testing such as CT and delta CRM, IR values isolator maintainance work and DCRM	MSETCL	MSETCL	400KV MAIN BUS-2 WILL BE IN SERVICE.	
178	863	400	400KV AURANGABAD-BOISAR # 1	29/Oct/18	8:00	29/Oct/18	18:00	Daily	REPLACEMENT OF INSULATORS.	POWERGRID	WR-II	R	
179	876	765	710LR Tiroda Line-1 Reactor at Koradi III SS	29/Oct/18	9:00	29/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
180	885	765	MAIN BAY (704) OF EKTUNI CKT - 1 @ AKOLA 2	30/Oct/18	09:00	30/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--	
181	896	400	400KV AURANGABAD-BOISAR # 2	30/Oct/18	8:00	30/Oct/18	18:00	Daily	REPLACEMENT OF INSULATORS.	POWERGRID	WR-II	R	
182	900	400	400 kV Aurangabad-1 (408) Main Bay at Akola	30/Oct/18	9:00	30/Oct/18	18:00	Daily	AMP work at akola end	WRTS-I	WRTS-I	R	
183	902	765	704 Main Bay of 765 KV Ektuni Line-1 at Akola II SS	30/Oct/18	9:00	30/Oct/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
184	911	400	400 kv D/C Parli - Pune (GIS)	31/Oct/18	6:00	01/Nov/18	20:00	Daily	Power line crossing of 400 kV D/C Parli - Pune at tower loc. no. 658 & 659 by 765 KV D/C LILO Aurangabad - Padghe Line	WRTMPL	CWRTL	Construction	
185	914	400	LAMBOTI-SOLAPUR (PGCIL)	31/Oct/18	10:00	31/Oct/18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Load will be managed on 400KV Parali Line	

State Element outages for the Month of October' 2018

Sr.No.	Voltage	Line Equipment	From Date	From	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	NEW KOYNA-KARAD -CKT 1	01-Oct-18	08:00	01-Oct-18	18:00	Daily	Routine maintenance and relay testing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna-Karad CKT-II line
2	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	02-Oct-18	10:00	02-Oct-18	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Line will be out
3	400 KV	DEEPNAGAR - THAPTI TANDA	03-Oct-18	06:00	06-Oct-18	18:00	Daily	For PID of Insulator string (ckt will be in service only A/R will be in Non-Auto condition)	MSETCL	MSETCL	A/R will be in Non-Auto condition
4	400 KV	DEEPNAGAR AURANGABAD	03-Oct-18	06:00	06-Oct-18	18:00	Daily	For PID of Insulator string (ckt will be in service only A/R will be in Non-Auto condition)	MSETCL	MSETCL	The A/R of 400 Kv Deepnagar-Waluj is already in Non-Auto mode since commissioning.
5	400 KV	BUS COUPLER @ KORADI	03-Oct-18	09:00	03-Oct-18	18:00	Daily	Tan Delta of CTs, CRM,DCRM,CB Timings	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
6	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	03-Oct-18	08:00	03-Oct-18	18:00	Daily	Routine Testing & Maintenance work	MSETCL	MSETCL	-
7	400 KV	PADGHE - NAGOTHANE 1	03-Oct-18	08:00	03-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
8	400 KV	JEJURI- KOYNA STAGE-IV	04-Oct-18	09:00	04-Oct-18	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total Load will be fed from 400kv Jejuri-Lonikand Line
9	400 KV	PADGHE - NAGOTHANE 1	04-Oct-18	08:00	04-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
10	400 KV	400/220/33 KV 315 MVA ICT - 2 @ DHULE	04-Oct-18	08:00	04-Oct-18	18:00	Daily	Routine Testing & Maintenance work	MSETCL	MSETCL	-
11	400 KV	KORADI 2-IEPL	05-Oct-18	10:00	05-Oct-18	14:00	Daily	Tan delta Measurement of Line CVT	MSETCL	MSETCL	Koradi-II-Wardha line will be service.
12	400 KV	MAIN BAY (413) OF NANDGAON PETH CKT @ AKOLA (M)	05-Oct-18	10:00	05-Oct-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Line will be in service
13	400 KV	PADGHE - NAGOTHANE 1	05-Oct-18	08:00	05-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
14	400 KV	TBC @ KOLHAPUR(TALANDGE)	05-Oct-18	09:00	05-Oct-18	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	-
15	400 KV	PADGHE - NAGOTHANE 1	06-Oct-18	08:00	06-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
16	400 KV	KORADI-KHADKA	06-Oct-18	08:00	06-Oct-18	18:00	Daily	Reactor bushing and winding C& tan delta test.	MSETCL	MSETCL	-
17	400 KV	AKOLA - KHADKA (BHUSAWAL)	08-Oct-18	12:00	10-Oct-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	A/R shall be kept in non auto mode.
18	400 KV	DEEPNAGAR AURANGABAD	08-Oct-18	06:00	13-Oct-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	-
19	400 KV	SPARE LINE-1 BAY (401) @ TAPTITANDA	08-Oct-18	11:00	08-Oct-18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	-
20	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	08-Oct-18	08:00	09-Oct-18	18:00	Daily	RTV coating,routine maintenance & relay testing	MSETCL	MSETCL	Load can be managed on 315 MVA ICT -II
21	400 KV	KORADI-KHADKA	08-Oct-18	08:00	15-Oct-18	18:00	Daily	PID work by keeping A/R switch in non auto mode	MSETCL	MSETCL	-
22	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	08-Oct-18	09:00	08-Oct-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Bay 402 & 403 at akola will be out.
23	400 KV	TIE BAY (402) of WALUJ @ TAPTITANDA	09-Oct-18	11:00	09-Oct-18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service.
24	400 KV	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	09-Oct-18	10:00	09-Oct-18	17:00	Daily	"1) DCRM,CRM & Timing IR of 430-Q52 2) Tan delta measurement of Bus CT at Bay 430	MSETCL	MSETCL	ICT-I will remain in service through tie Bay 429
25	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	09-Oct-18	09:00	09-Oct-18	18:00	Daily	Annual Maintenance of bays & equipment And Diagnostic Testing of ICT.	MSETCL	MSETCL	ICT-2 will be in service.
26	400 KV	BABLESHWAR- AURANGABAD	09-Oct-18	10:00	13-Oct-18	17:00	Daily	PID Work, A/R needs to be made out of service.	MSETCL	MSETCL	A/R needs to be made out of service.
27	400 KV	KARAD - TALANDGE CKT 2	09-Oct-18	09:00	09-Oct-18	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	-
28	400 KV	PADGHE - NAGOTHANE 2	09-Oct-18	08:00	09-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
29	400 KV	KHADKA-AURANGABAD	09-Oct-18	09:00	09-Oct-18	17:00	Daily	Routine Maintenance & Testing Work	MSETCL	MSETCL	Line will be out
30	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	10-Oct-18	10:00	10-Oct-18	17:00	Daily	1) DCRM,CRM & Timing IR of 429-Q52	MSETCL	MSETCL	ICT-I will remain in service through Main Bay 430
31	400 KV	TIE BAY (411) OF STATION TF 8A & CHANDRAPUR 2 CKT - 2	10-Oct-18	09:00	10-Oct-18	15:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
32	400 KV	MAIN BAY (403) of WALUJ @ TAPTITANDA	10-Oct-18	11:00	10-Oct-18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service
33	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	10-Oct-18	08:00	10-Oct-18	18:00	Daily	Maintenance work & DIAGNOSTICS TESTING WORK	MSETCL	MSETCL	-
34	400 KV	PADGHE - NAGOTHANE 2	10-Oct-18	08:00	10-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
35	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	10-Oct-18	10:00	10-Oct-18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Load will be managed on 400KV ICT II
36	400 KV	KHADKA - BABLESHWAR	10-Oct-18	08:00	10-Oct-18	18:00	Daily	CB DCRM & Timing Test	MSETCL	MSETCL	-
37	400 KV	CHANDRAPUR - KHAPERKHEDA	10-Oct-18	08:00	10-Oct-18	18:00	Daily	Line Signature Test	MSETCL	MSETCL	-
38	400 KV	LONIKAND -I - KOYNA STAGE-IV	10-Oct-18	09:00	10-Oct-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service
39	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	10-Oct-18	08:00	11-Oct-18	18:00	Daily	RTV coating,routine maintenance & relay testing	MSETCL	MSETCL	Load can be managed on 315 MVA ICT -I
40	400 KV	JEJURI- KOYNA STAGE-IV	11-Oct-18	09:00	11-Oct-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Lonikand-Jejuri ckt will be in service
41	400 KV	PADGHE - NAGOTHANE 2	11-Oct-18	08:00	11-Oct-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	Nil
42	400 KV	SPARE LINE-2 BAY (404) @ TAPTITANDA	11-Oct-18	11:00	11-Oct-18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
43	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	11-Oct-18	09:00	11-Oct-18	18:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
44	400 KV	MAIN BAY- 414 OF YELWAN CKT-1 @ AKOLA	11-Oct-18	10:00	11-Oct-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	-
45	400 KV	Tie bay (405) of Deepnagar line @ Taptitanda	12-Oct-18	11:00	12-Oct-18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service
46	400 KV	LONIKAND 1 - KOYNA STAGE-IV	12-Oct-18	09:00	12-Oct-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service
47	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	15-Oct-18	12:00	17-Oct-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle	MSETCL	MSETCL	A/R shall be kept in non auto mode.
48	400 KV	DEEPNAGAR - THAPTI TANDA	15-Oct-18	06:00	17-Oct-18	18:00	Daily	For PID of insulator string (ckt will be in service only A/R will be in Non-Auto condition).	MSETCL	MSETCL	A/R will be in Non-Auto condition
49	400 KV	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	15-Oct-18	10:00	15-Oct-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	-
50	400 KV	DEEPNAGAR AURANGABAD	15-Oct-18	06:00	17-Oct-18	18:00	Daily	For PID of Insulator string	MSETCL	MSETCL	The A/R of 400 Kv Deepnagar-Waluj is
51	400 KV	TBC @ WALUJ	16-Oct-18	09:00	16-Oct-18	17:00	Daily	Routine Maintenance & Testing	MSETCL	MSETCL	-
52	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	16-Oct-18	09:00	16-Oct-18	18:00	Daily	Annual Maintenance of bays & equipment And Dignostic Testing of ICT.	MSETCL	MSETCL	ICT-1 will be in service.
53	400 KV	CHANDRAPUR - KHAPERKHEDA	16-Oct-18	08:00	23-Oct-18	18:00	Daily	PID work by keeping A/R switch in non auto mode	MSETCL	MSETCL	-
54	400 KV	WARORA - IEPL	16-Oct-18	09:00	16-Oct-18	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	-
55	400 KV	THAPTI TANDA - AURANGABAD	16-Oct-18	10:00	17-Oct-18	17:00	Daily	PID Work, A/R needs to be made out of service.	MSETCL	MSETCL	A/R needs to be made out of service.
56	400 KV	Main Bay 412 of Chadrapur II ckt 2 @ C'pur Sw.	17-Oct-18	09:00	17-Oct-18	15:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
57	400 KV	KHADKA- DEEPNAGAR CKT 1	17-Oct-18	08:00	17-Oct-18	18:00	Daily	CVT C & Tan delta test, CB DCRM	MSETCL	MSETCL	-
58	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	19-Oct-18	08:00	19-Oct-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Nil
59	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	19-Oct-18	07:00	19-Oct-18	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Bhusawal & 400 kv Koradi-Nandgaonpeth will be in service.
60	400 KV	400/220/33 KV 315 MVA ICT - 1 @ AURANGABAD	19-Oct-18	09:00	19-Oct-18	17:00	Daily	Routine Maintenance & Testing work	MSETCL	MSETCL	-
61	400 KV	AKOLA - KHADKA (BHUSAWAL)	20-Oct-18	08:00	20-Oct-18	18:00	Daily	Reactor bushing and winding C& tan delta test.	MSETCL	MSETCL	-
62	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	20-Oct-18	08:00	20-Oct-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I , 501 MVA ICT -III and ICT-IV will be in service
63	400 KV	Main bay (406) of Deepnagar line @ Taptitanda	22-Oct-18	11:00	22-Oct-18	17:00	Daily	CB Annual diagnostic testing work	MSETCL	MSETCL	Line will be in service
64	400 KV	TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	22-Oct-18	10:00	22-Oct-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	-
65	400 KV	BUS REACTOR - 1 @ TIRORA	22-Oct-18	09:00	22-Oct-18	20:00	Daily	Shutdown maintenance of BR, Bay equipments and its relay testing	ATIL	ATIL	--
66	400 KV	400KV KORADI-BHUSAWAL (Bhusawal end)	22-Oct-18	12:00	24-Oct-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	A/R shall be kept in non auto mode.
67	400 KV	DEEPNAGAR - THAPTI TANDA	22-Oct-18	06:00	27-Oct-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	-
68	400 KV	MAIN BAY - 404 OF STATION TF-3 @ KORADI 2	23-Oct-18	10:00	23-Oct-18	17:00	Daily	1) DCRM,CRM & Timing IR of 404-Q52	MSETCL	MSETCL	Station Transformer-III will remain in service through Tie Bay 405
69	400 KV	BABLESHWAR- AURANGABAD	23-Oct-18	10:00	27-Oct-18	17:00	Daily	PID Work, A/R needs to be made out of service.	MSETCL	MSETCL	A/R needs to be made out of service.
70	400 KV	CHANDRAPUR - KHAPERKHEDA	24-Oct-18	08:00	24-Oct-18	18:00	Daily	1) Measurment of DCRM, Timing & CRM of breaker. 2) Isolator maintenance works.	MSETCL	MSETCL	During this outage, The 400KV CHD-I - CHD-II Ckt. No.- I & II, 400KV Parli Ckt. No.-III, will be in service.
71	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	24-Oct-18	08:00	24-Oct-18	18:00	Daily	DCRM OF C.B of 400/7.6KV STATION 5A (416) at 400KV Khaperkheda S/s	MSETCL	MSETCL	-
72	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	24-Oct-18	09:00	24-Oct-18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
73	400 KV	STATION TF-3 @ KORADI 2	24-Oct-18	10:00	24-Oct-18	18:00	Daily	"1) Tan delta Maeasurement of Line CT of Bay 404 2)Tan delta Measurement of Bus CT of Bay 404	MSETCL	MSETCL	NOC required from Mahagenco
74	400 KV	JAIGAD-KARAD-II	25-Oct-18	14:00	25-Oct-18	18:00	Daily	Quarterly. Maint. Work & Repairing of Earth blade	MSETCL	MSETCL	Load manage on 400 KV KARAD-JAIGAD -1
75	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	25-Oct-18	09:00	25-Oct-18	17:00	Daily	Relay testing work.	MSETCL	MSETCL	-
76	400 KV	KHADKA - BABLESHWAR	25-Oct-18	09:00	25-Oct-18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	400 kv Auragabad ,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
77	400 KV	JAIGAD-KARAD-I	25-Oct-18	07:00	25-Oct-18	13:00	Daily	Quarterly. Maint. Work & Repairing of Earth blade	MSETCL	MSETCL	Load managed on 400 kv KARAD-JAIGAD-II
78	400 KV	400/220kv 500MVA ICT 2 ALONGWITH SPARE ICT @ JEJURI	25-Oct-18	09:00	25-Oct-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	As ICT-II Y-phase is on spare unit, ICT-II will be out of service. Load will be fed from ICT-I & ICT-III
79	400 KV	TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	25-Oct-18	10:00	25-Oct-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	-
80	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	26-Oct-18	08:00	26-Oct-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Nil
81	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	26-Oct-18	08:00	26-Oct-18	18:00	Daily	Maintenance work & DIAGNOSTICS TESTING WORK	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
82	400 KV	MAIN BAY (406) OF LINE- 3 @ KORADI 3	26-Oct-18	09:00	26-Oct-18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	--
83	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	26-Oct-18	08:00	26-Oct-18	17:00	Daily	Routine maintainance and diaganastic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM	MSETCL	MSETCL	400KV Bay No 422 charged on No Load
84	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	27-Oct-18	08:00	27-Oct-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT- II , 501 MVA ICT - III& IV will be in service
85	400 KV	DEEPNAGAR - THAPTI TANDA	29-Oct-18	06:00	31-Oct-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	-
86	400 KV	NEW KOYNA - STAGE IV CKT 1	29-Oct-18	08:00	29-Oct-18	18:00	Daily	Routine maintenance and relay testing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
87	400 KV	NEW KOYNA - STAGE IV CKT 2	30-Oct-18	08:00	31-Oct-18	18:00	Daily	Routine maintenance and relay testing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
88	400 KV	400220kv 167MVA SPARE ICT @ DEEPNAGAR	30-Oct-18	09:00	30-Oct-18	18:00	Daily	Annual Maintenance of bays & equipment And Dignostic	MSETCL	MSETCL	-
89	400 KV	TBC @ KHADKA	30-Oct-18	08:00	30-Oct-18	18:00	Daily	CB DCRM & Timing Test	MSETCL	MSETCL	-
90	400 KV	DEEPNAGAR AURANGABAD	30-Oct-18	10:00	30-Oct-18	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Line will be out
91	400 KV	STATION TRANSFORMER - 5B @ KHAPARKHEDA	31-Oct-18	08:00	31-Oct-18	18:00	Daily	DIAGNOSTICS TESTING AND ROUTINE MAINT.	MSETCL	MSETCL	-
92	400 KV	MAIN BAY (407) OF DHARIWAL CKT - 1 @ CHANDRAPUR - 2	31-Oct-18	09:00	31-Oct-18	18:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL	-