

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of October 2020

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
1	10	400KV-WARORA-CHANDRAPUR-II-1	1-Oct-20	09:00	1-Oct-20	17:00	Daily	MSETCL	Routine maintainance and diagonastic testing ,relay testing work etc	Load will be managed on 400KV chandrapur Ckt-2 bay no 413
2	15	400KV-CHAKAN-PUNE-PG-1	1-Oct-20	9:00	1-Oct-20	18:00	D	POWERGRID_WRI	For Replacment of CVT at Pune(Talegaon) end	Other
3	20	400KV-AKOLA-AURANGABAD-1	1-Oct-20	9:00	1-Oct-20	18:00	D	POWERGRID_WRI	For Line bay AMP works at Akola, 400KV-AKOLA-AURANGABAD-2 A/R to be keep in non auto mode for safety measures.	At Akola SS
4	28	MAIN BAY - 400KV-KORADI-II-KORADI-III-4 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	1-Oct-20	09:00	1-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
5	30	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	1-Oct-20	10:00	1-Oct-20	13:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance "	765KV Akola Ckt-1 will be in service through its TIE (705) Bay and Main Bus-I
6	34	400KV-PARLI-M-SOLAPUR-M-1	1-Oct-20	10:00	1-Oct-20	18:30	Daily	MSETCL	Work of replacement of suspension string insulators(SSN/DSN)	-
7	38	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	1-Oct-20	14:00	1-Oct-20	17:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance "	765/400KV ICT-1-II will be in service through its TIE (712) & Main Bus-II
8	43	400KV-KALWA-KHARGHAR-1	1-Oct-20	09:00	3-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
9	52	400KV-SSP-DHULE-MS-1	1-Oct-20	08:00	10-Oct-20	17:00	Daily	MSETCL	Online PID testing	Online PID testing
10	53	400KV-SSP-DHULE-MS-2	1-Oct-20	08:00	10-Oct-20	17:00	Daily	MSETCL	Online PID Testing	Online PID Testing
11	54	400KV-BABLESHWAR-PADGHE-1	1-Oct-20	08:00	10-Oct-20	18:00	Daily	MSETCL	For Carrying PID Work	-
12	55	400KV-KALWA-PADGHE-1	1-Oct-20	09:00	10-Oct-20	17:00	Daily	MSETCL	PID Test	PId test
13	57	400KV-CHAKAN-PUNE-PG-1	1-Oct-20	09:00	15-Oct-20	16:00	Daily	MSETCL	To carryout PID test.	Work is to be carried out by hot line team, line will be in service.
14	83	400KV-JEJURI-KOYNA STAGE IV-1	1-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for AR required in Non Auto mode
15	84	400KV-KOYNA STAGE IV-LONIKHAND-1	1-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for AR required in Non Auto mode
16	85	400KV-KARAD-KOLHAPUR-MS-1	1-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for AR required in Non Auto mode
17	86	400KV-KARAD-KOLHAPUR-MS-2	1-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for AR required in Non Auto mode
18	99	400KV-PARLI-M-LONIKHAND-II-1	1-Oct-20	10:00	31-Oct-20	17:00	Daily	MSETCL	PID testing of Insulator.	By pass the A/R switch, without interruption.
19	103	400KV-EKTUNI-BABLESHWAR-1	2-Oct-20	09:00	2-Oct-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing	-
20	113	400KV-RGPPL-New Koyana Line-1	2-Oct-20	10:00	3-Oct-20	18:00	Continuous	RGPPPL	402-52 A main bkr PM & testing.	
21	114	KHARGHAR - 400KV - BUS 1	2-Oct-20	08:00	4-Oct-20	18:00	Continuous	MSETCL	For replacement of quadraple bus conductor span between 400kV Talegaon & Kalwa line of 400kV 'A' Bus	400kV A bus load will be shifted on B bus
22	115	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	2-Oct-20	08:00	4-Oct-20	18:00	Continuous	MSETCL	1)For replacement of quadraple bus conductor span between 400kV Talegaon & Kalwa line of 400kV 'A' Bus	400kV A bus load will be shifted on B bus
23	120	220KV-PARLI-OSMANABAD-M-1	3-Oct-20	08:00	3-Oct-20	17:00	Daily	MSETCL	Vibration damper fixing work	-
24	124	400KV-EKTUNI-BABLESHWAR-2	3-Oct-20	09:00	3-Oct-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing	-
25	133	TIE BAY - 400KV-KORADI-II-KORADI-III-2 AND FUTURE at KORADI-III - 400KV	3-Oct-20	09:00	3-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
26	134	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	3-Oct-20	09:00	3-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
27	138	220KV-TALEGAON-PUNE-PG-1	3-Oct-20	10:00	3-Oct-20	17:00	Daily	MSETCL	Half yearly Maintenance, Diagnostic Testing.	---
28	151	220KV-BOISAR-BOISAR-M-1	4-Oct-20	09:00	4-Oct-20	17:00	Daily	MSETCL	Jumper NutBolt tightening work	Jumper NutBolt tightening work
29	158	AURANGABAD-M (WALUJ) - 400KV - BUS 2	5-Oct-20	09:00	5-Oct-20	17:00	Daily	MSETCL	Waluj-Bhusawal(Khadka)Bay @Waluj End Quarterly Maintenance	Waluj-Bhusawal(Khadka)Bay @Waluj End Quarterly Maintenance
30	168	220KV-WARDHA-BHUGAON-1	5-Oct-20	08:00	5-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA
31	182	220 kV Navsari-Nashik line no.1	5-Oct-20	9:00	5-Oct-20	18:00	Daily	GETCO	General bay maint.	

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
32	198	220KV-PARLI-OSMANABAD-M-1	5-Oct-20	09:00	5-Oct-20	18:00	Daily	MSETCL	Vibration damper fixing work	-
33	205	MAIN BAY - 400KV/11.5KV KORADI-II-ST-3 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	5-Oct-20	10:00	5-Oct-20	17:00	Daily	MSETCL	DCRM of CB 404-Q52 & Tan delta measurement of Bus CT at Bay 404	1)Station Transformer -III will remain in service through Tie Bay 405
34	218	WARORA - 400KV - BUS 1	5-Oct-20	09:00	6-Oct-20	17:00	Daily	MSETCL	PID WORK BY HOT LINE UNIT	Load will be managed by bus-2
35	229	400KV-BHUSAWAL-AKOLA-1 ON TBC @ KHADKA	5-Oct-20	08:00	8-Oct-20	18:00	Continuous	MSETCL	For own C.B mechanism overhauling work carry out.	During that period of time line will be shifted on TBC .
36	230	400KV-KALWA-KHARGHAR-1	5-Oct-20	09:00	8-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
37	287	765KV/400KV AKOLA (2)-ICT-1	6-Oct-20	10:00	6-Oct-20	14:00	Daily	MEGPTCL	ICT Annual Maintenance	ICT Annual Maintenance
38	302	220KV-NASIK-NAVSARI-1	6-Oct-20	08:00	8-Oct-20	18:00	Daily	MSETCL	For replacement of old disc insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixing if issued	-
39	303	220KV-PARLI-PARLI-M-1	6-Oct-20	09:00	8-Oct-20	17:00	Daily	MSETCL	To attend loose nut bolt at Cut Point Loc. Nos. 28, 29 & 30 and tightening of nut bolts of Cross Arm pieces	-
40	319	220KV-PANDURNA-KALMESHVAR-1	7-Oct-20	08:00	7-Oct-20	18:00	Daily	MSETCL	Routine Maintenance work	Outage proposed by LMU S/Dn Mankapur
41	322	WARORA - 400KV - BUS 2	7-Oct-20	09:00	7-Oct-20	17:00	Daily	MSETCL	PID work	Hotline work
42	323	132KV-MANSAR-MS-KANHAN-1	7-Oct-20	09:00	7-Oct-20	17:00	Daily	MSETCL	Routine Maintenance work	Outage proposed by LM Kanhan
43	339	400KV-AKOLA-AURANGABAD-2	7-Oct-20	9:00	7-Oct-20	18:00	D	POWERGRID_WRI	For AMP of Line Bay at akola & 400KV-AKOLA-AURANGABAD-1 A/R to be keep in non auto mode for safety measures.	At Akola SS
44	345	400KV-PARLI-M-SOLAPUR-M-1	7-Oct-20	09:00	7-Oct-20	18:00	Daily	MSETCL	CB testing work,Work of replacement of suspension string insulators(SSN/DSN)	-
45	348	400KV/11.5KV KORADI-II-ST-3	7-Oct-20	10:00	7-Oct-20	17:00	Daily	MSETCL	Tan delta measurement of Line CT at bay 404	Station transformer II & Station transformer-I will remain in service as alternate source of supply.
46	357	KUMBARI - 220KV - BUS 1	7-Oct-20	11:00	7-Oct-20	16:00	Daily	MSETCL	Outage is required for Quarterly Maintenance	Quarterly Maintenance
47	358	220KV-SOLAPUR-KUMBARI-1	7-Oct-20	11:00	7-Oct-20	16:00	Daily	MSETCL	Outage is required for Quarterly Maintenance	Quarterly Maintenance
48	359	TIE BAY - 765KV-AKOLA-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	7-Oct-20	11:00	7-Oct-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine maintenance "	765KV Akola Ckt-II will be in service through its main (703) Bay and Main Bus-II
49	365	220KV-WARDHA-BHUGAON-1	7-Oct-20	08:00	8-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA
50	370	220KV-SOLAPUR-KUMBARI-1	7-Oct-20	9:00	7-Oct-20	18:00	D	POWERGRID_WRI	CT and Line Terminal equipments AMP works	Other
51	377	400KV-CHANDRAPUR-BHADRAWATI-4	8-Oct-20	03:00	11-Oct-20	18:00	Continuous	MSETCL	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 4 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
52	378	400KV/11.5KV CHANDRAPUR-GCR-ST-4	8-Oct-20	03:00	11-Oct-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. 3) Measurement of Tan delta & Capaciatnce of CT's	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
53	379	400KV-CHANDRAPUR-BHADRAWATI-3	8-Oct-20	03:00	11-Oct-20	18:00	Continuous	MSETCL	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 3 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
54	380	400KV/21KV CHANDRAPUR-GT-6	8-Oct-20	03:00	11-Oct-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
55	391	400 kV-SSP-DHULE-MS-2	8-Oct-20	7:00	8-Oct-20	18:00	Daily	GETCO	Maintenance work (Auto reclose of SSP -Dhule - 1 will remain out)	
56	407	WARORA - 400KV - BUS 2	8-Oct-20	09:00	8-Oct-20	17:00	Daily	MSETCL	PID work	Hotline work
57	420	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	8-Oct-20	09:00	8-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
58	436	CHANDRAPUR-GCR - 400KV - BUS 1	8-Oct-20	03:00	11-Oct-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
59	437	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	8-Oct-20	03:00	11-Oct-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept
60	451	220KV-PARLI-OSMANABAD-M-1	9-Oct-20	08:00	9-Oct-20	17:00	Daily	MSETCL	LINE maintenance	-
61	475	TIE BAY - 400KV/11.5KV KORADI-II-ST-3 AND 400KV-KORADI-II-KORADI-III-2 at KORADI-II - 400KV	9-Oct-20	10:00	9-Oct-20	15:00	Daily	MSETCL	DCRM of CB 405-Q52	1)400KV Koradi-II Koradi-III Ckt.-II will remain service through Main Bay 406. 2) Station transformer-III will remain service through main bay 404 (FULL DIA)
62	476	TIE BAY - 400KV/220KV AKOLA-ICT-1 AND 400KV-AKOLA-AURANGABAD-1 at AKOLA - 400KV	9-Oct-20	10:00	9-Oct-20	16:00	Daily	MSETCL	Routine Maintenance and Testing work	ICT-1 & Aurangabad Ckt-1 will be in service through main bays 402 &404 respectively
63	483	400KV/11.5KV TIRODA-ST-4	9-Oct-20	09:00	10-Oct-20	18:00	Daily	APML	Transformer Maintenance Activities	Transformer Maintenance Activities
64	488	400KV-PADGHE-BOISAR-1	10-Oct-20	10:00	17-Oct-20	17:00	C	POWERGRID_WR1	Retrofitting of old BHEL make CB with New GE make CB for 400 KV Boisar Line Bay at Padghe MSETCL.	1) 400 KV Padghe Boisar Line shall remain chraged through TBC CB at Padghe MSETCL as Bus arrangement at MSETCL is DMT Scheme.2) In case of any emergency in any other bay at Padghe MSETCL, MSETCL may consider as per system requirement to handtrip the 400KV MSETCLPadghe-PG BOISAR Line during which this Boisar Line shall be out of service.3) In case during erection if clearance is not met w.r.t live buses then emergency shutdown may be required for 01 or 02 days. Kindly request to concur the as proposed.
65	491	220KV-TARAPUR 1&2-BORIVALI-1	10-Oct-20	08:00	10-Oct-20	17:00	Daily	MSETCL	Annual Diagnostic & Testing work	Annual Diagnostic & Testing work
66	493	400KV-PADGHE-BOISAR-1	10-Oct-20	9:00	10-Oct-20	17:00	D	POWERGRID_WR2	Line Equipment AMP work at Boisar. Line AMP works on opportunity, dia to be kept open at both ends.	PG-WR2-Boisar
67	495	AKOLA - 400KV - BUS 1	10-Oct-20	09:00	10-Oct-20	18:00	Daily	MSETCL	Routine Maintenance and Testing Work	Bus 2 will be in service
68	507	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 at WARORA - 400KV	10-Oct-20	09:00	10-Oct-20	17:00	Daily	MSETCL	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	400KV PGCIL Line will be charged through Tie CB 421.
69	515	DHULE-MS - 400KV B/R 1	10-Oct-20	9:00	10-Oct-20	18:00	D	POWERGRID_WR1	For AMP works	
70	520	220KV-PARLI-PARLI-M-2	10-Oct-20	09:00	10-Oct-20	18:00	Daily	MSETCL	CT testing work.	-
71	521	TIE BAY - 400KV-KORADI-II-KORADI-III-1 AND FUTURE at KORADI-III - 400KV	10-Oct-20	09:00	10-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
72	522	220KV-TALEGAON-PUNE-PG-1	10-Oct-20	10:00	10-Oct-20	17:00	Daily	MSETCL	Half yearly maintenance, Diagnostic Testing.	---
73	524	400KV-KALWA-KHARGHAR-1	10-Oct-20	09:00	11-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
74	526	400KV-KALWA-KHARGHAR-1	11-Oct-20	08:00	11-Oct-20	18:00	Daily	MSETCL	Routine Maintenance work	Routine Maintenance work
75	536	220KV-BOISAR-BOISAR-M-3	11-Oct-20	09:00	11-Oct-20	17:00	Daily	MSETCL	Jumper NutBolt tightening work	Jumper NutBolt tightening work
76	543	400KV-BABLESHWAR-PADGHE-2	11-Oct-20	08:00	20-Oct-20	18:00	Daily	MSETCL	For Carrying PID Work	-
77	547	400KV-CHANDRAPUR-BHADRAWATI-1	12-Oct-20	9:00	15-Oct-20	18:00	C	POWERGRID_WR1	Replacement of BHEL make CB	
78	549	765KV/400KV EKTUNI-ICT-1	12-Oct-20	10:30	12-Oct-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine maintainance "	765kv, 1500MVA ICT-II Will be in service
79	551	BUS COUPLER BAY - BHUSAWAL - 400KV - BUS 1 AND BHUSAWAL - 400KV - BUS 2 at BHUSAWAL - 400KV	12-Oct-20	08:00	14-Oct-20	18:00	Continuous	MSETCL	For C.B overhauling work carry out of 400 KV Bus coupler.	Nil
80	553	400KV-SSP-DHULE-MS-1	12-Oct-20	07:00	12-Oct-20	19:00	Daily	MSETCL	Replacement of damaged earthwire	400KV DHL-SSNNL C-II A/R switch to be kept in Non-Auto mode
81	556	400KV-PADGHE-NAGOTHANE-1	12-Oct-20	08:00	12-Oct-20	17:00	Daily	MSETCL	Jumper tightening and cold wasing work	nil
82	557	400KV-WARORA-CHANDRAPU-II-1	12-Oct-20	08:00	12-Oct-20	17:00	Daily	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode	for PID Testing Work,shifting autoreclose switch to Non auto Mode
83	562	220KV-WARDHA-PUSAD-1	12-Oct-20	08:00	12-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
84	569	220KV-NASIK-NAVSARI-2	12-Oct-20	9:00	12-Oct-20	18:00	Daily	GETCO	General bay maint.	
85	598	400KV/11.5KV TIRODA-ST-5	12-Oct-20	09:00	13-Oct-20	18:00	Daily	APML	Transformer Maintenance Activities and bay maintenance	Transformer Maintenance Activities
86	609	400KV-CHANDRAPUR-KHAPARKHEDA-1 ON TBC @ CHANDRAPUR GCR	12-Oct-20	03:00	21-Oct-20	18:00	Continuous	MSETCL	1) For capital overhauling of drive mechanism, poles and Interrupter of all 3 phases of 400KV CGL make Breaker. 2) Measurement of Timing, Contact Resistance and DCRM of breaker after overhauling work.	During outage, 400KV Khaparkhedha line will be in service via TBC-I bay .
87	611	TIE BAY - 765KV/400KV EKTUNI-ICT-1 AND FUTURE at EKTUNI - 765KV	12-Oct-20	11:00	12-Oct-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance "	765KV IC 1-I will be in service through its Main (710) Bay & Main Bus-II
88	612	400KV-WARORA-CHANDRAPU-II-2	12-Oct-20	08:00	17-Oct-20	17:00	Daily	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode	for PID Testing Work,shifting autoreclose switch to Non auto Mode
89	614	400KV-KALWA-PADGHE-2	12-Oct-20	09:00	22-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
90	615	400KV-SSP-DHULE-MS-2	12-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Online PID testing work	400KV SSNNL-II A/R switch to be kept on Non auto mode
91	617	765KV/400KV EKTUNI-ICT-2	13-Oct-20	10:30	13-Oct-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance "	765kV, 1500MVA ICT-I Will be in service
92	621	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	13-Oct-20	11:00	13-Oct-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance "	765/400KV IC 1-II will be in service through its TIE (712) & Main Bus-II
93	622	400KV-SSP-DHULE-MS-2	13-Oct-20	07:00	13-Oct-20	19:00	Daily	MSETCL	Replacement of damaged earthwire	400KV DHL-SSNNL C-I A/R switch to be kept in Non-Auto mode
94	638	220KV-Pandurna-MP-Kamleshwar	13-Oct-20	9:00	13-Oct-20	17:00	D	MP_SLDC	For bay equipment maintenance and testing work	
95	639	220KV-PARLI-HARANGUL-1	13-Oct-20	09:00	13-Oct-20	17:00	Daily	MSETCL	To attend loose nut bolt at Cut Point Loc. Nos. 28, 29 & 30 and tightening of nut bolts of Cross Arm pieces	-
96	645	400KV-AKOLA-WARDHA-1	13-Oct-20	9:00	13-Oct-20	18:00	D	POWERGRID_WR1	For AMP of Line Bay at Akola & 400KV-AKOLA-WARDHA-2 A/R to be kept in non auto mode for safety measures.	
97	652	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	13-Oct-20	09:00	13-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
98	656	220KV-WARDHA-WARDHA-M-1	13-Oct-20	10:00	13-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA
99	663	220KV-NASIK-NAVSARI-2	13-Oct-20	08:00	15-Oct-20	18:00	Daily	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixing if issued	-
100	669	400KV-KALWA-KHARGHAR-1	13-Oct-20	09:00	22-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
101	670	400KV-SSP-DHULE-MS-1	13-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Online PID testing work	400kV SSNNL-1 A/R switch kept on non auto mode
102	685	400KV-RGPPL-NAGOTHANE-1	14-Oct-20	08:00	14-Oct-20	17:00	Daily	MSETCL	Jumper tightening and cold wasing work	nil
103	686	220KV-PARLI-PARLI-M-2	14-Oct-20	08:00	14-Oct-20	17:00	Daily	MSETCL	Line maintenance	-
104	693	220KV-WARDHA-PUSAD-1	14-Oct-20	08:00	14-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA
105	700	220KV-TILLARI-AMONA-1	14-Oct-20	09:00	14-Oct-20	17:00	Daily	MSETCL	quarterly maintenance	-
106	701	132KV-MANSAR-MS-PENCH-1	14-Oct-20	09:00	14-Oct-20	17:00	Daily	MSETCL	Routine Maintenance work	Outage proposed by LM Kanhan S/Dn
107	717	400KV/11.5KV TIRODA-ST-2	14-Oct-20	09:00	14-Oct-20	18:00	Daily	APML	Transformer Maintenance Activities	Transformer Maintenance Activities
108	720	220KV-SOLAPUR-JEUR-1	14-Oct-20	10:00	14-Oct-20	17:00	Daily	MSETCL	Outage is required for Quarterly Maintenance	Quarterly Maintenance
109	724	400KV-PARLI-M-SOLAPUR-M-1	14-Oct-20	10:00	14-Oct-20	18:30	Daily	MSETCL	Work of replacement of suspension string insulators(SSN/DSN)	-
110	725	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	14-Oct-20	11:00	14-Oct-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance "	765KV Bus Reactor will be in service through its TIE (712) Bay & Main Bus-II
111	729	400KV/220KV BHUSAWAL-ICT-3	14-Oct-20	08:00	17-Oct-20	18:00	Continuous	MSETCL	For own C.B overhauling work carry out.	During that period ICT-3 will be shifted on 400 KV TBC bay.
112	735	400KV-BABLESHWAR-PADGHE-1	15-Oct-20	09:00	15-Oct-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing and for string replacement-	-
113	748	400KV-RGPPL-NAGOTHANE-2	15-Oct-20	08:00	15-Oct-20	17:00	Daily	MSETCL	Jumper tightening and cold wasing work	nil
114	749	400KV-DGEN-VAGHODIYA-1	15-Oct-20	8:00	15-Oct-20	18:00	D	TPL-DGEN	Offline washing of 402 bay equipments including LA, isolator, CT, EMVT,breaker etc.	

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
115	760	Main Bay - 400KV-Wardha-WARORA-1 AND Wardha - 400KV - Bus 2	15-Oct-20	09:00	15-Oct-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through Tie CB 428.
116	761	220KV-PARLI-HARANGUL-1	15-Oct-20	09:00	15-Oct-20	17:00	Daily	MSETCL	To attend loose nut bolt at Cut Point Loc. Nos. 28, 29 & 30 and tightening of nut bolts of Cross Arm pieces	-
117	767	PUNE-PG - 220KV - BUS 2	15-Oct-20	9:00	15-Oct-20	18:00	D	POWERGRID_WR1	For Replacment of CVT	
118	780	Tie Bay - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - Bus 1	15-Oct-20	09:00	15-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
119	784	220KV-WARDHA-BADNERA-1	15-Oct-20	10:00	15-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA
120	785	Main Bay - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - Bus 2	15-Oct-20	11:00	15-Oct-20	18:00	Daily	MSETCL	"Diagnostic Testing & routine maintenance "	765KV IC 1-I will be in service through its Tie (709) Bay and Main Bus-1
121	811	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	16-Oct-20	08:00	18-Oct-20	18:00	Continuous	MSETCL	2)For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV 'B' Bus	400kV B bus load will be shifted on A bus
122	812	KHARGHAR - 400KV - BUS 2	16-Oct-20	08:00	18-Oct-20	18:00	Continuous	MSETCL	2)For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV 'B' Bus	400kV B bus load will be shifted on A bus
123	819	400KV-SSP-DHULE-MS-1	16-Oct-20	07:00	16-Oct-20	19:00	Daily	MSETCL	Replacement of damaged earthwire	400KV DHL-SSNNL C-II A/R switch to be kept in Non-Auto mode
124	833	220KV-WARDHA-PUSAD-1	16-Oct-20	08:00	16-Oct-20	18:00	Daily	MSETCL	Routine line maintainace work	NA
125	837	220KV-PARLI-HARANGUL-1	16-Oct-20	09:00	16-Oct-20	17:00	Daily	MSETCL	To attend loose nut bolt at Cut Point Loc. Nos. 28, 29 & 30 and tightening of nut bolts of Cross Arm pieces	-
126	860	400KV-EKTUNI-BABLESHWAR-1	16-Oct-20	09:00	17-Oct-20	17:00	Daily	MSETCL	Replacement & Tightening of Jumper nut bolts	400kV Ektuni-Bhabaleshwar Ckt-II will be in service
127	872	220KV-TARAPUR 1&2-BOISAR-M-1	17-Oct-20	09:00	17-Oct-20	17:00	Daily	MSETCL	Insulator string Replacement work	Insulator string Replacement work
128	874	400KV-SSP-DHULE-MS-2	17-Oct-20	07:00	17-Oct-20	19:00	Daily	MSETCL	Replacement of damaged earthwire	400KV DHL-SSNNL C-I A/R switch to be kept in Non-Auto mode
129	875	BOISAR - 220KV - BUS 1	17-Oct-20	9:00	17-Oct-20	17:00	D	POWERGRID_WR2	Bus Amp	PG-WR2-Boisar
130	884	Tie Bay - 400KV-Wardha-WARORA-1 AND FUTURE	17-Oct-20	09:00	17-Oct-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
131	892	TIRODA - 400KV B/R 1	17-Oct-20	09:00	17-Oct-20	18:00	Daily	ATIL	Bay Isolator Maintenance Activities associated with Bus Reactor	Bay Isolator Maintenance Activities associated with Bus Reactor
132	902	400KV-DHULE-DHULE-MS-2	18-Oct-20	8:00	18-Oct-20	18:00	D	BDTCL	Annual Rectification Work	
133	905	220KV-BOISAR-NALASOPARA-1	18-Oct-20	09:00	18-Oct-20	17:00	Daily	MSETCL	Faulty string Replacement work found in PID test.	Faulty string Replacement work found in PID test.
134	912	400KV-DHULE-DHULE-MS-1	19-Oct-20	8:00	19-Oct-20	19:00	D	BDTCL	For 400KV LA Base Insulators change	
135	924	400KV-EKTUNI-BABLESHWAR-2	19-Oct-20	09:00	19-Oct-20	17:00	Daily	MSETCL	Corona Ring & Disc Replacement	400kV Ektuni-Bhabaleshwar ckt-I will be in service
136	933	400KV-AKOLA-WARDHA-2	19-Oct-20	9:00	19-Oct-20	18:00	D	POWERGRID_WR1	For AMP of Line Bay & 400KV-AKOLA-WARDHA-1 A/R to be keep in non auto mode for safety measures.	
137	941	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	19-Oct-20	09:00	19-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
138	942	Bus Coupler Bay - Koradi - 400KV - Bus 1 AND Koradi - 400KV - Bus 2	19-Oct-20	09:00	19-Oct-20	18:00	Daily	MSETCL	testing and setting work of PG isolator	Outages will be availed subject to weather conditions.
139	952	400KV-BHUSAWAL-BABLESHWAR-1 ON TBC @ BHUSAWAL	19-Oct-20	08:00	22-Oct-20	18:00	Continuous	MSETCL	For own C.B overhauling work carry out.	During that period line will be shifted on 400 KV TBC bay.
140	968	400KV-DHULE-DHULE-MS-1	20-Oct-20	8:00	20-Oct-20	18:00	D	BDTCL	Annual Rectification Work	
141	972	Main Bay - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - Bus 2	20-Oct-20	10:00	20-Oct-20	17:00	Daily	MSETCL	DCRM of CB 406-Q52 Tan delta measurement of Bus CT at Bay 406	400KV Koradi-II Koradi-III Ckt-II will remain service through Tie Bay 405
142	1004	400KV-DHULE-DHULE-MS-2	21-Oct-20	8:00	21-Oct-20	19:00	D	BDTCL	For 400KV LA Base Insulators change	
143	1007	400KV-LONIKHAND-PUNE-PG-1	21-Oct-20	9:00	21-Oct-20	18:00	D	POWERGRID_WR1	For line side equipment AMP Work	Other
144	1010	220KV-PARLI-OSMANABAD-M-1	21-Oct-20	08:00	21-Oct-20	17:00	Daily	MSETCL	Line maintenance	-
145	1022	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	21-Oct-20	09:00	21-Oct-20	17:00	Daily	MSETCL	quarterly maintenance	-
146	1032	400KV-WARDHA-AKOLA-2	21-Oct-20	9:00	21-Oct-20	18:00	D	POWERGRID_WR1	For AMP of Line Bay & 400KV-AKOLA-WARDHA-1 A/R to be keep in non auto mode for safety measures.	
147	1036	TIRODA - 400KV B/R 2	21-Oct-20	09:00	21-Oct-20	18:00	Daily	ATIL	Bay Isolator Maintenance Activities associated with Bus Reactor	Bay Isolator Maintenance Activities associated with Bus Reactor

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
148	1041	400KV-PARLI-M-SOLAPUR-M-1	21-Oct-20	10:00	21-Oct-20	18:30	Daily	MSETCL	Work of replacement of suspension string insulators(SSN/DSN)	-
149	1042	220KV-SOLAPUR-KUMBARI-2	21-Oct-20	11:00	21-Oct-20	16:00	Daily	MSETCL	Outage is required for Quarterly Maintenance	Quarterly Maintenance
150	1043	KUMBARI - 220KV - BUS 2	21-Oct-20	11:00	21-Oct-20	16:00	Daily	MSETCL	Outage is required for Quarterly Maintenance	Quarterly Maintenance
151	1046	400KV-DHULE-MS-BABLESHWAR-1	21-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	For Carrying PID Work	-
152	1047	400KV-DHULE-MS-BABLESHWAR-2	21-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	For Carrying PID Work	-
153	1049	PUNE-PG - 400KV - BUS 1	22-Oct-20	9:00	22-Oct-20	18:00	D	POWERGRID_WR1	For AMP Work	
154	1051	400KV-SSP-DHULE-MS-1	22-Oct-20	07:00	22-Oct-20	19:00	Daily	MSETCL	Replacement of damaged earthwire	400KV DHL-SSNNL C-II A/R switch to be kept in Non-Auto mode
155	1077	Tie Bay - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1	22-Oct-20	09:30	22-Oct-20	18:30	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
156	1085	BOISAR - 220KV - BUS 2	23-Oct-20	9:00	23-Oct-20	17:00	D	POWERGRID_WR2	Bus Amp	PG-WR2-Boisar
157	1086	400KV-SSP-DHULE-MS-2	23-Oct-20	07:00	23-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-I A/R switch kept on Non Auto mode
158	1087	400KV-CHAKAN-PUNE-PG-1	23-Oct-20	09:00	23-Oct-20	17:00	Daily	MSETCL	Half Yearly Maintenance.	--
159	1126	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2 ON TBC @ CHANDRAPUR GCR	23-Oct-20	03:00	31-Oct-20	18:00	Continuous	MSETCL	1) For capital overhauling of drive mechanism, poles and Interrupter of all 3 phases of 400KV CGL make Breaker. 2) Measurement of Timing, Contact Resistance and DCRM of breaker after overhauling work.	During outage, 400KV GCR CHD-CHD-2 Ckt. No.- 2 line will be in service via TBC-1 bay .
160	1127	400KV-KHARGHAR-PUNE-PG-1	23-Oct-20	09:00	31-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
161	1128	400KV-KALWA-PUNE-PG-1	23-Oct-20	09:00	31-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
162	1140	400KV-KALWA-PUNE-PG-1	24-Oct-20	08:00	24-Oct-20	18:00	Daily	MSETCL	Routine Maintenance work	Routine Maintenance work
163	1155	Main Bay - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - Bus 2	24-Oct-20	09:00	24-Oct-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
164	1156	220KV-TALEGAON-PUNE-PG-2	24-Oct-20	10:00	24-Oct-20	17:00	Daily	MSETCL	Half yearly maintenance, Diagnostic Testing.	---
165	1160	400KV-KALWA-PUNE-PG-1	24-Oct-20	09:00	24-Oct-20	17:00	Daily	MSETCL	Half Yearly Maintenance.	---
166	1161	400KV-KALWA-KHARGHAR-1	24-Oct-20	09:00	31-Oct-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
167	1163	400KV-KALWA-PADGHE-2	25-Oct-20	09:30	25-Oct-20	17:30	Daily	MSETCL	Bay maint work DCRM of CB	outage will be availed if weather condition is clear.
168	1168	220KV-BOISAR-BOISAR-M-2	25-Oct-20	09:00	25-Oct-20	17:00	Daily	MSETCL	Insulator string Replacement work.	Insulator string Replacement work.
169	1170	Tie Bay - 765KV/400KV AKOLA (2)-ICT-1 AND 400KV-AKOLA (2)-FUTURE-5	25-Oct-20	09:30	25-Oct-20	18:30	Daily	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
170	1181	400KV-SSP-DHULE-MS-1	26-Oct-20	07:00	26-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-II A/R switch kept on Non Auto mode
171	1183	400KV-KHARGHAR-PUNE-PG-1	26-Oct-20	08:00	26-Oct-20	18:00	Daily	MSETCL	For R&M and Diagnostic Testing Work	400kV Kalwa line will be in service
172	1210	400KV-KARAD-JAIGAD-1	26-Oct-20	08:00	31-Oct-20	18:00	Continuous	JPTL	Overhauling of GE make pole column & Drives & CT tan delta Measurement,Relay testing.	M/s. Eptech & availability of service engineer from M/s. GE T&D (OEM) is available Load will be managed on Jaigad Ckt-II
173	1219	400KV-SSP-DHULE-MS-2	27-Oct-20	07:00	27-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-I A/R switch kept on Non /Auto mode
174	1220	400KV-SSP-DHULE-MS-2	27-Oct-20	07:00	27-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-I A/R switch kept on Non Auto mode
175	1257	400KV-SSP-DHULE-MS-1	28-Oct-20	07:00	28-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-II A/R switch kept on Non Auto mode
176	1262	220KV-PARLI-PARLI-M-2	28-Oct-20	08:00	28-Oct-20	17:00	Daily	MSETCL	Line maintenance	-
177	1269	400KV-WARDHA-WARORA-1	28-Oct-20	09:00	28-Oct-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL. Line is in ckt
178	1270	220KV-MUDSHINGI-CHIKKODI-II-1	28-Oct-20	09:00	28-Oct-20	17:00	Daily	MSETCL	quarterly maintenance	-
179	1273	400KV-BHILAI-KORADI	28-Oct-20	9:00	28-Oct-20	18:00	D	POWERGRID_WR1	For AMP works, Line work permit shall be provided	At Koradi SS

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
180	1280	400KV-PARLI-M-SOLAPUR-M-1	28-Oct-20	10:00	28-Oct-20	18:30	Daily	MSETCL	Work of replacement of suspension string insulators(SSN/DSN)	-
181	1291	PUNE-PG - 220KV - BUS 1	29-Oct-20	9:00	29-Oct-20	18:00	D	POWERGRID_WR1	For AMP Work	
182	1293	220KV-TARAPUR 1&2-BORIVALI-1	29-Oct-20	09:00	29-Oct-20	17:00	Daily	MSETCL	Insulator string Replacement work.	Insulator string Replacement work.
183	1296	400KV-SSP-DHULE-MS-1	29-Oct-20	07:00	29-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-II A/R switch kept on Non Auto mode
184	1303	400KV-EKTUNI-BABLESHWAR-2	29-Oct-20	09:00	29-Oct-20	17:00	Daily	MSETCL	Corona ring & Disc replacement	400kV Ektuni-Bhabaleshwar ckt-I will be in service
185	1308	400KV-KORADI-SATPURA	29-Oct-20	9:00	29-Oct-20	18:00	D	POWERGRID_WR1	For AMP works, Line work permit shall be provided	At Koradi SS
186	1320	400KV-SSP-DHULE-MS-2	30-Oct-20	07:00	30-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-I A/R switch kept on Non Auto mode
187	1323	400KV-WARDHA-KORADI-II-1	30-Oct-20	09:00	30-Oct-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
188	1333	400KV-KALWA-PADGHE-2	31-Oct-20	08:00	31-Oct-20	18:00	Daily	MSETCL	Routine Maintenance work	Routine Maintenance work
189	1336	400KV-SSP-DHULE-MS-1	31-Oct-20	07:00	31-Oct-20	19:00	Daily	MSETCL	Replacement of damage earthwire	During the outage period 400KV SSNNL-II A/R switch kept on Non Auto mode

Maharashtra State Load Despatch Centre											
State Element Outage list for the month of October 2020											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	01-Oct-20	10:00	01-Oct-20	17:00	Daily	Tan delta measurement of Line CT at Bay 430	MSETCL	MSETCL	Load will be shifted to 400/220/33KV ICT-II
2	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	01-Oct-20	09:00	01-Oct-20	18:00	Daily	DT & Maintenance work.	MSETCL	MSETCL	Load will be managed by other 2 no. of ICTs and 220kV Interconnector.
3	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01-Oct-20	08:00	31-Oct-20	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode
4	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	02-Oct-20	09:00	08-Oct-20	17:00	Daily	for confirmation of healthiness of R-ph line CVT	MSETCL	MSETCL	Yes, 1)400 KV Switching Chandrapur II - Ckt -II (Main bay 412 & Tie bay 411) will be in service.2) on did 29.08.2020 400KV GT-9 is withdrawn due to boiler tube leakage.
5	400 KV	AKOLA - KHADKA (BHUSAWAL)	03-Oct-20	08:00	03-Oct-20	18:00	Daily	For Testing work on 400KV Khadka-akola ckt.	MSETCL	MSETCL	Nil
6	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	03-Oct-20	08:00	03-Oct-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	-
7	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	05-Oct-20	08:00	05-Oct-20	17:00	Daily	for buccholz relay replacement work	MSETCL	MSETCL	nil
8	400 KV	TBC @ KORADI-1	05-Oct-20	09:00	05-Oct-20	18:00	Daily	PG isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
9	400 KV	CHANDRAPUR GCR - CHANDRAPUR HVDC - II	05-Oct-20	03:00	05-Oct-20	18:00	Daily	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-1.	MSETCL	MSETCL	"The outage required only for 3 to 4 Hrs for dismantling of PG-1 Isolator. During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off. "
10	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	06-Oct-20	09:00	06-Oct-20	18:00	Daily	PG & CB isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
11	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	06-Oct-20	08:00	06-Oct-20	17:00	Daily	for buccholz relay replacement work	MSETCL	MSETCL	nil
12	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	07-Oct-20	08:00	07-Oct-20	17:00	Daily	for buccholz relay replacement work	MSETCL	MSETCL	nil
13	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	07-Oct-20	09:00	07-Oct-20	18:00	Daily	PG & CB isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
14	400 KV	TIE BAY (408) OF DHARIWAL CKT - 1 & GCR CKT-2 @ CHANDRAPUR - 2	07-Oct-20	11:00	07-Oct-20	14:00	Daily	Tan delta and capacitance measurement of Tie CT	MSETCL	MSETCL	400KV Dhariwal Ckt.1 service through main bay 407.
15	400 KV	STATION TRANSFORMER - 5B @ KHAPARKHEDA	07-Oct-20	10:00	07-Oct-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	_
16	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	07-Oct-20	09:00	07-Oct-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
17	400 KV	JEJURI- KOYNA STAGE-IV	08-Oct-20	09:30	08-Oct-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	400KV Jejuri- Lonikand line will be in service.
18	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	08-Oct-20	08:00	08-Oct-20	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
19	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	08-Oct-20	09:00	08-Oct-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage proposed by LM Koradi S/dn
20	400 KV	KORADI-NANDGAONPETH (RPL)	08-Oct-20	09:00	08-Oct-20	18:00	Daily	PG & CB isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
21	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	08-Oct-20	09:00	08-Oct-20	18:00	Daily	DT & Maintenance work.	MSETCL	MSETCL	Load will be managed by other 2 no of ICTs and 220kV Interconnector.
22	400 KV	TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	08-Oct-20	11:00	08-Oct-20	13:00	Daily	for Tie CT tan delta testing work	MSETCL	MSETCL	need to be done as per diagnostic plan
23	400 KV	MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	08-Oct-20	08:30	08-Oct-20	10:30	Daily	Main bus CT tan delta testing work	MSETCL	MSETCL	as per diagnostic plan
24	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	09-Oct-20	09:00	09-Oct-20	18:00	Daily	Hardware tightening & fitting work	MSETCL	MSETCL	-
25	400 KV	KORADI-NANDGAONPETH (RPL)	09-Oct-20	09:00	09-Oct-20	18:00	Daily	PG & CB isolators allignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
26	400 KV	MAIN BAY - 406 OF FUTURE BAY @ AKOLA 2	09-Oct-20	09:30	09-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
27	400 KV	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	09-Oct-20	09:00	09-Oct-20	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	400KV PGCL Line will be charged through Tie CB 418.
28	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	09-Oct-20	09:00	09-Oct-20	17:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
29	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	10-Oct-20	08:00	10-Oct-20	18:00	Daily	For CB DCRM testing.	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark .If any.
30	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	10-Oct-20	08:00	10-Oct-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT-IV will be in service
31	400 KV	KORADI-KHAPERKHEDA 1	10-Oct-20	09:00	10-Oct-20	18:00	Daily	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
32	400 KV	MAIN BAY (407) OF RPL CKT-1 @ AKOLA 2	10-Oct-20	09:30	10-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
33	400 KV	KORADI-KHAPERKHEDA 1	11-Oct-20	09:00	11-Oct-20	18:00	Daily	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
34	400 KV	GT - 7 @ KORADI-1	12-Oct-20	09:00	12-Oct-20	18:00	Daily	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
35	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	12-Oct-20	09:00	12-Oct-20	18:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Load will be shifted on ICT-02
36	400 KV	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	12-Oct-20	09:30	12-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
37	400 KV	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	12-Oct-20	10:00	12-Oct-20	17:00	Daily	DCRM of CB 430-Q52 Tan delta measurement of Bus CT at Bay 430	MSETCL	MSETCL	ICT-I will remain in service through its Tie bay 429
38	400 KV	PADGHE - NAGOTHANE 2	13-Oct-20	08:00	13-Oct-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
39	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	13-Oct-20	09:00	13-Oct-20	18:00	Daily	Mechanism Box replacement work of 29D and 29 B isolator	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
40	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	13-Oct-20	09:00	13-Oct-20	16:00	Daily	Diagnostic testing work on Line CVT	MSETCL	MSETCL	400KV Switching ckt. 1 is in service.
41	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	13-Oct-20	09:00	13-Oct-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
42	400 KV	Tie bay (405) of Deepnagar line @ Taptitanda	14-Oct-20	11:00	14-Oct-20	17:00	Daily	Testing of differential relay	MSETCL	MSETCL	Nil
43	400 KV	DEEPNAGAR - THAPTI TANDA	14-Oct-20	09:00	14-Oct-20	18:00	Daily	Testing of Teed Differential relay and Line routine maintenance work.	MSETCL	MSETCL	Nil
44	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	14-Oct-20	08:00	14-Oct-20	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	NA
45	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	14-Oct-20	09:00	15-Oct-20	18:00	Daily	PG isolators alignment , testing and setting work. Replacement of B ph 29 B Scissor assembly.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
46	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	14-Oct-20	10:00	14-Oct-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Load will be managed on 400 kv ICT-II
47	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	14-Oct-20	09:00	14-Oct-20	18:00	Daily	IV and HV breaker testing work	MSETCL	MSETCL	-
48	400 KV	400/220kV 167MVA SPARE ICT @ DEEPNAGAR	14-Oct-20	08:30	14-Oct-20	14:30	Daily	HV LV tertiary bushing Tan delta testing work also Main CB DCRM testing work	MSETCL	MSETCL	need to be complete as per yearly diagnostic plan
49	400 KV	MAIN BAY (409) OF AKOLA-1 CKT-1 @ AKOLA 2	14-Oct-20	09:30	14-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
50	400 KV	SPARE LINE-2 BAY (404) @ TAPTITANDA	14-Oct-20	11:00	14-Oct-20	17:00	Daily	Testing of differential relay	MSETCL	MSETCL	Nil
51	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	14-Oct-20	10:00	14-Oct-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	_
52	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	17-Oct-20	09:00	17-Oct-20	18:00	Daily	Hardware tightening & fitting work	MSETCL	MSETCL	-
53	400 KV	LONIKAND 1 -JEJURI	15-Oct-20	09:30	15-Oct-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	400KV Jejuri-Koyna stage IV Line will be in service.
54	400 KV	AKOLA - KHADKA (BHUSAWAL)	15-Oct-20	09:00	15-Oct-20	18:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Routine maintenance & testing Work
55	400 KV	MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	15-Oct-20	09:00	15-Oct-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.
56	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	15-Oct-20	08:00	15-Oct-20	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	NA
57	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	15-Oct-20	08:00	15-Oct-20	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
58	400 KV	KORADI-NANDGAONPETH (RPL)	15-Oct-20	09:00	15-Oct-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage proposed by LM Koradi S/Dn
59	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	15-Oct-20	09:00	15-Oct-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.
60	400 KV	DEEPNAGAR - THAPTI TANDA	15-Oct-20	09:00	15-Oct-20	18:00	Daily	Line routine maintenance work.	MSETCL	MSETCL	Nil
61	400 KV	THAPTI TANDA - WALUJ	16-Oct-20	09:00	16-Oct-20	18:00	Daily	Line routine maintenance work.	MSETCL	MSETCL	Nil
62	400 KV	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	16-Oct-20	10:00	16-Oct-20	16:00	Daily	Routine Maintenance & Testing Work	MSETCL	MSETCL	ICT-2 will be in service through Tie Bay 406

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
63	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	16-Oct-20	10:00	16-Oct-20	15:00	Daily	DCRM of CB 429-Q52	MSETCL	MSETCL	ICT-I will remain in service through its main Bay 430
64	400 KV	CHANDRAPUR-PARLI CKT-3	16-Oct-20	08:00	16-Oct-20	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	NA
65	400 KV	MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2	16-Oct-20	09:30	16-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
66	400 KV	MAIN BAY - 413 OF GT-9 @ KORADI-2	16-Oct-20	09:00	16-Oct-20	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
67	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16-Oct-20	08:00	31-Oct-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	NA
68	400 KV	TBC @ WALUJ	16-Oct-20	09:00	16-Oct-20	17:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance
69	400 KV	THAPTI TANDA - WALUJ	17-Oct-20	09:00	17-Oct-20	18:00	Daily	Line routine maintenance work	MSETCL	MSETCL	Nil
70	400 KV	TIE BAY (411) OF RPL CKT - 2 & AKOLA-1 CKT-2 @ AKOLA 2	17-Oct-20	09:30	17-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
71	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	17-Oct-20	09:00	17-Oct-20	18:00	Daily	Routine diagnostic testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
72	400 KV	CHANDRAPUR-PARLI CKT-3	17-Oct-20	08:00	31-Oct-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	NA
73	400 KV	KARAD - TALANDGE CKT 2	19-Oct-20	08:00	19-Oct-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
74	400 KV	TIE BAY (412) of THAPTITANDA @ DEEPNAGAR	19-Oct-20	08:30	19-Oct-20	14:30	Daily	Tie CT Tan delta testing & Tie CB DCRM testing work by testing team	MSETCL	MSETCL	need top be done as per diagnostic plan
75	400 KV	KARAD - TALANDGE CKT 1	20-Oct-20	08:00	20-Oct-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
76	400 KV	MAIN BAY (412) OF AKOLA -1 CKT-2 @ AKOLA 2	20-Oct-20	09:30	20-Oct-20	18:30	Daily	Bay Maintenance Activities	MEGPTCL	MEGPTCL	Bay Maintenance Activities
77	400 KV	MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	21-Oct-20	10:00	21-Oct-20	15:00	Daily	DCRM of CB 407-Q52	MSETCL	MSETCL	1)Station Transformer -II will remain in service through Tie Bay 408
78	400 KV	NEW KOYNA -KARAD -CKT 2	21-Oct-20	08:00	21-Oct-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
79	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	21-Oct-20	09:00	21-Oct-20	16:00	Daily	Diagnostic testing work on line CVT	MSETCL	MSETCL	400KV switching ckt.1 is in service.
80	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	21-Oct-20	10:00	21-Oct-20	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	-
81	400 KV	400/220 KV 167 MVA ICT @ PARLI	21-Oct-20	09:00	21-Oct-20	18:00	Daily	CB testing work.	MSETCL	MSETCL	-
82	400 KV	CHANDRAPUR-PARLI CKT-3	21-Oct-20	09:00	21-Oct-20	18:00	Daily	Hardware tightening & fitting work	MSETCL	MSETCL	-
83	400 KV	JEJURI- KOYNA STAGE-IV	22-Oct-20	08:00	22-Oct-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
84	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	22-Oct-20	08:00	22-Oct-20	18:00	Daily	Annual Maintenance, CT Tan-d testing & Relay Testing work.	MSETCL	MSETCL	-
85	400 KV	CHANDRAPUR - KHAPERKHEDA	22-Oct-20	09:00	22-Oct-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage proposed by LM Koradi S/Dn
86	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	22-Oct-20	09:30	22-Oct-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	400/220KV, ICT-No. I & III will be in service.
87	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	23-Oct-20	09:00	23-Oct-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 2 will be in service for no supply interruption.
88	400 KV	LONIKAND 1 - KOYNA STAGE-IV	23-Oct-20	08:00	23-Oct-20	18:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
89	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	23-Oct-20	09:00	23-Oct-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Interconnector 2 will be in service for no supply interruption.
90	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	23-Oct-20	08:00	23-Oct-20	18:00	Daily	For R&M and Diagnostic Testing Work	MSETCL	MSETCL	ICT-1 and ICT-2 will be in service
91	400 KV	CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT - 2	25-Oct-20	08:00	25-Oct-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	NA
92	400 KV	NEW KOYNA-KARAD -CKT 1	26-Oct-20	08:00	26-Oct-20	18:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
93	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	26-Oct-20	09:00	26-Oct-20	17:00	Daily	Quarterly Maintenance work & Relay Testing and for string replacement	MSETCL	MSETCL	Outage proposed for quarterly maintainance and for faulty string replacement by agency on daily basis from 9:00 hrs to 17:00 hrs
94	400 KV	KHADKA - BABLESHWAR	26-Oct-20	09:00	26-Oct-20	17:00	Daily	Breaker overhauling/Testing work	MSETCL	MSETCL	Outage required
95	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 1	28-Oct-20	11:00	28-Oct-20	14:00	Daily	Tan delta measurement of line CT.	MSETCL	MSETCL	400KV Dhariwal ckt. 2 is in service.

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
96	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	29-Oct-20	09:00	29-Oct-20	18:00	Daily	DT & Maintenance work.	MSETCL	MSETCL	---
97	400 KV	WARORA - IEPL	29-Oct-20	09:00	29-Oct-20	17:00	Daily	1) Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work. 2) Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	1) 400 KV KORADI 2-WARDHA PGCIL Line is in ckt
98	400 KV	THAPTI TANDA - WALUJ	29-Oct-20	09:00	29-Oct-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance