

Maharashtra State Load Despatch Centre													
Monthly Outage list approved in WRLDC OCCM for the Month of October' 2021													
Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks	
1	10	PLANNED	OCC_547	NCA	400 kV SSP Dhule Line # 2	Daily	Maintenance of open switchyard and breaker PM work-- Approved Outage dtd.02.09.2021 of the said line has been diffired by NCA/WRLDC	10/1/2021	08:00	10/1/2021	18:00	Preventive Maintenance	
2	14	PLANNED	OCC_547	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-1 AND PARLI-M - 400KV - BUS 1 at MSETCL PARLI	Daily	For bay AMP works	10/1/2021	08:00	10/1/2021	18:00		
3	15	PLANNED	OCC_547	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	Daily	For AMP	10/1/2021	08:00	10/1/2021	18:00		
4	23	PLANNED	OCC_547	MSETCL	KHARGHAR - 400KV - BUS 1	Daily	Online testing of 400kV Busbar System	10/1/2021	08:00	10/1/2021	18:00	1) SE TCC Vashi instructed to test the 400kV Busbar system. 2) All feeders and its own protection will be in service. 3) No any load will be affected.	
5	24	PLANNED	OCC_547	MSETCL	KHARGHAR - 400KV - BUS 2	Daily	Online testing of 400kV Busbar System	10/1/2021	08:00	10/1/2021	18:00	1) SE TCC Vashi instructed to test the 400kV Busbar system. 2) All feeders and its own protection will be in service. 3) No any load will be affected.	
6	25	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode	10/1/2021	08:00	10/1/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode	
7	40	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA (2) - 400KV - BUS 1	Daily	Annual Maintenance of Bay Equipment	10/1/2021	09:30	10/1/2021	18:30	Annual Maintenance of Bay Equipment	
8	41	PLANNED	OCC_547	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2	Daily	1) Diagnostic Testing work 2) Bay Maint work 3) MTAMC work (Relay Retrofitting)	10/1/2021	09:30	10/1/2021	18:45	1) HVDC tie CB in service required 2) Weather condition should be clear	
9	49	PLANNED	OCC_547	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-1	Continuous	Simultaneous Outage of 400kV Khandwa-Dhule-1 & 2 - for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam. Dia to be kept open. {{(Similar Line Outages proposed/approved for work to be done in May/21 can not be taken up due to Covid19 and delay in supply of towers)}}}	10/1/2021	08:00	10/8/2021	18:00	PG-WR2-Khandwa	
10	50	PLANNED	OCC_547	POWERGRID_WR2	400KV-KHANDWA-DHULE-MS-2	Continuous	Simultaneous Outage of 400kV Khandwa-Dhule-1 & 2 - for Construction work Modification of line towers 411,412&,413 - due to submergence in newly constructed Bham Dam. Dia to be kept open. {{(Similar Line Outages proposed/approved for work to be done in May/21 can not be taken up due to Covid19 and delay in supply of towers)}}}	10/1/2021	08:00	10/8/2021	18:00	PG-WR2-Khandwa	
11	59	PLANNED	OCC_547	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	for carrying PID work	10/1/2021	08:00	10/15/2021	18:00	-	
12	60	PLANNED	OCC_547	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Live line installation of OPGW by MTCIL, and PID Testing Auto-Reclose function to be out of service.	10/1/2021	08:00	10/15/2021	19:00	Live line installation of OPGW by MTCIL, and PID Testing Auto-Reclose function to be out of service.	
13	61	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing work	10/1/2021	09:00	10/30/2021	17:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode	
14	74	PLANNED	OCC_547	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	10/1/2021	08:00	10/31/2021	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III These lines are on DC tower so both lines require on same day A/R out.	
15	75	PLANNED	OCC_547	MSETCL	400KV-CHANDRAPU-II-NANDED-2	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	10/1/2021	08:00	10/31/2021	17:00	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III these two lines are on DC tower so both lines require on same day A/R out.	
16	76	PLANNED	OCC_547	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard	10/1/2021	08:00	10/31/2021	17:00	NIL	
17	84	PLANNED	OCC_547	MSETCL	400KV-WARDHA-KORADI-II-1	continuous	For Erection of two nos of inline monopole AP1(DB+0)&AP2(PD+9)) bewtween existing tower no192-193 and restringing between location AP1-AP2,AP2-AP3&AP3(DD+6)-193& dismantling of inline tower 192 at Samrudhi highway chainage 23+650	10/1/2021	06:00	10/10/2021	20:00		

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
18	85	PLANNED	OCC_547	MSETCL	400KV-IEPL-KORADI-II-1	continuous	For Erection of two nos of inline monopole AP1(DB+0)&AP2(PD+9)) bewtween existing tower no192-193 and restringing between location AP1-AP2,AP2-AP3&AP3(DD+6)-193& dismantling of inline tower 192 at Samrudhi highway chainage 23+650	10/1/2021	06:00	10/10/2021	20:00	
19	87	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Hardware Tightening and Broken Disc replacement of 500KV Chandrapur-Padghe HVDC Pole-I	10/2/2021	06:00	10/2/2021	19:00	Annual maint work of Hardware Tightening and Broken Disc replacement of 500KV Chandrapur-Padghe HVDC Pole-I
20	90	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/2/2021	08:00	10/2/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
21	93	PLANNED	OCC_547	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance, Relay Testing.	10/2/2021	10:00	10/2/2021	17:00	---
22	94	PLANNED	OCC_547	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	Diagnostic Testing & Routine Maintenance work	10/2/2021	10:00	10/2/2021	18:00	1500MVA ICT-II Will be in service
23	95	PLANNED	OCC_547	MSETCL	BOISAR-M - 220KV - BUS 1	Continuous	220kV A Bus Iso. r/m works & other Bus maintenance related works.	10/2/2021	06:00	10/3/2021	18:00	220kV Bus outage demands a lot of preparations and approval is required well in advance.
24	100	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID testing work	10/2/2021	09:00	10/30/2021	17:00	400kV Dhule-SSNNL ckt-2 A/R switch will be kept on non auto mode
25	101	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Hardware Tightening and Broken Disc replacement of 500KV Chandrapur-Padghe HVDC Pole-I	10/3/2021	06:00	10/3/2021	19:00	Annual maint work of Hardware Tightening and Broken Disc replacement of 500KV Chandrapur-Padghe HVDC Pole-I
26	104	PLANNED	OCC_547	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Diagnostic Testing & Routine Maintenance work	10/3/2021	10:00	10/3/2021	18:00	1500MVA ICT-I Will be in service
27	105	PLANNED	OCC_547	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	1) REPLACEMENT OF BROKEN/MISSING SPACERS by Boisar Line maintenance S/Dn. 2) Retrofitting work of Earth Isolator & R&M Work at Borivali end.	10/3/2021	10:00	10/3/2021	20:00	1) REPLACEMENT OF BROKEN/MISSING SPACERS by Boisar Line maintenance S/Dn. 2) Retrofitting work of Earth Isolator & R&M Work at Borivali end.
28	106	PLANNED	OCC_547	POWERGRID_WR2	400KV-KALA-KUDUS-1	Daily	For AMP works at Kala. Also, line AMP works. A/R OFF on ckt-2.	10/3/2021	09:30	10/3/2021	17:30	PG-WR2-Kala
29	107	PLANNED	OCC_547	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	Daily	Updating Siemens Distance Relay M1 7SA522(EN100 Module) to comply for IEC61850 and resolving front port communication issue of M1 Relay.	10/4/2021	07:00	10/4/2021	16:00	
30	120	PLANNED	OCC_547	POWERGRID_WR1	400KV-PARLI-M-PARLI-1	Daily	For AMP works. AR to be kept in non Auto mode for 400kV Parli-Parli-II	10/4/2021	08:00	10/4/2021	18:00	
31	127	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/4/2021	08:00	10/4/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode
32	128	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Earthwire replacement Work	10/4/2021	08:00	10/4/2021	18:00	Planned outage
33	133	PLANNED	OCC_547	POWERGRID_WR1	PUNE-PG - 400KV - BUS 1	Daily	For AMP Work	10/4/2021	08:30	10/4/2021	18:00	
34	138	PLANNED	OCC_547	MSETCL	400KV-WARDHA-WARORA-1	Daily	Routine Maintenance & Dignostic testing work .	10/4/2021	09:00	10/4/2021	17:00	400KV WARORA-IEPL Line is in ckt
35	140	PLANNED	OCC_547	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	Daily	For AMP works. Line outage is required.	10/4/2021	09:00	10/4/2021	17:30	PG-WR2-Boisar
36	145	PLANNED	OCC_547	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	Daily	1) Measurement of tan-delta & capacitance of 400KV R,Y & B-ph CT which are due since 2 year. 2) Maintenance and alignments of pg isolators and CB isolators. Line outage required	10/4/2021	09:00	10/4/2021	18:00	HVDC Ckt. No. 2 will be in service and there will be power restriction of 300 MW
37	149	PLANNED	OCC_547	MEGPTCL	TIE BAY - 765KV/400KV AKOLA (2)-ICT-1 AND 400KV-AKOLA (2)-FUTURE-5 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/4/2021	09:30	10/4/2021	18:30	Annual Maintenance of Bay Equipment
38	160	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1 ON TBC @ DHULE	Daily	C.B. Overhauling work. Line will taken on TBC from DHULE end	10/4/2021	08:00	10/6/2021	21:00	No interruption . Feeder to be shift on TBC at Dhule end
39	167	PLANNED	OCC_547	APML	765KV/21KV TIRODA-GT-5	Continuous	For GT-5 Main (709-52) and Tie (708-52) Bay Equipment Maintenance activities. Outage will be availed based on real time condition of Unit.	10/4/2021	09:00	10/9/2021	18:00	For GT-5 Main (709-52) and Tie (708-52) Bay Equipment Maintenance activities. Outage will be availed based on real time condition of Unit.

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
40	168	PLANNED	OCC_547	MSETCL	KOLHAPUR-MS - 400KV - BUS 1	Continuous	1. Annual Bus Maintenance. 2. Chemical cleaning of Bus Strings. 3. Replacement of faulty strings 4. 400kV Karad 2 B ph A Bus isolator replacement work. 5. Annual Maintenance of A Bus isolators of all Bays. 6. Annual Bus CVT testing	10/4/2021	09:00	10/10/2021	18:00	Load will be managed on 400kV Main Bus 2
41	180	PLANNED	OCC_547	POWERGRID_WR1	MAIN BAY - DHULE-MS - 400KV B/R 1 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	Daily	FOR AMP WORKS	10/5/2021	07:00	10/5/2021	18:00	Outage
42	189	PLANNED	OCC_547	NCA	400 kV SSP Dhule Line # 1	Daily	Maintenance of open switchyard and breaker PM work	10/5/2021	08:00	10/5/2021	18:00	Preventive Maintenance
43	200	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/5/2021	08:00	10/5/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
44	201	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Earthwire replacement Work	10/5/2021	08:00	10/5/2021	18:00	Planned outage
45	212	PLANNED	OCC_547	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	Daily	For AMP works. Line outage is required.	10/5/2021	09:00	10/5/2021	17:30	PG-WR2-Boisar
46	221	PLANNED	OCC_547	POWERGRID_WR2	400KV-KALA-KUDUS-2	Daily	For AMP works at Kala. Also, line AMP works. A/R OFF on ckt-1.	10/5/2021	09:30	10/5/2021	17:30	PG-WR2-Kala
47	227	PLANNED	OCC_547	MSETCL	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	10/5/2021	10:00	10/5/2021	18:00	NA
48	228	PLANNED	OCC_547	MSETCL	AURANGABAD-M (WALUJ) - 400KV - BUS 2	Daily	400kV Waluj Thaptitanda Bay at waluj end	10/5/2021	10:00	10/5/2021	18:00	Routine maintenance and CT TESTING WORK
49	233	PLANNED	OCC_547	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV	Continuous	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechanism.	10/5/2021	09:00	10/7/2021	18:00	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechanism.
50	238	PLANNED	OCC_547	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	Complete bay maintenance works.	10/6/2021	06:00	10/6/2021	18:00	Complete bay maintenance works.
51	239	PLANNED	OCC_547	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	Daily	Replacement of M1 REL521 Relay & CT of Padghe Tarapur 1 line at Padghe MSETCL SS.	10/6/2021	07:00	10/6/2021	17:00	
52	253	PLANNED	OCC_547	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance work	10/6/2021	08:00	10/6/2021	17:00	-
53	266	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/6/2021	08:00	10/6/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode
54	267	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	10/6/2021	08:00	10/6/2021	18:00	Planned outage
55	272	PLANNED	OCC_547	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work .	10/6/2021	09:00	10/6/2021	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
56	273	PLANNED	OCC_547	MSETCL	220KV-PANDURNA-KALMESHWAR-1	Daily	Routine Maintenance & Dignostic testing work	10/6/2021	09:00	10/6/2021	17:00	NA
57	274	PLANNED	OCC_547	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	10/6/2021	09:00	10/6/2021	17:00	NA
58	275	PLANNED	OCC_547	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	Daily	For AMP works. Line outage is required.	10/6/2021	09:00	10/6/2021	17:30	PG-WR2-Boisar
59	285	PLANNED	OCC_547	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	Diagnostic testing and allied bay maintenance	10/6/2021	09:00	10/6/2021	18:00	Bay 428 & Bay 429
60	286	PLANNED	OCC_547	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	Daily	1) Measurement of tan-delta 7 capacitance of 400KV R, Y & B ph CT which are due since 2 year 2) Testing of LBB relay 3) Maintenance and alignment of PG isolators and CB isolators. Line outage required	10/6/2021	09:00	10/6/2021	18:00	HVDC Ckt. No. 1 will be in service and there will be power restriction of 300 MW
61	289	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/6/2021	09:30	10/6/2021	18:30	Annual Maintenance of Bay Equipment
62	293	PLANNED	OCC_547	MSETCL	KUMBARI - 220KV - BUS 1	Daily	Outage is required for Quarterly Maintenance	10/6/2021	10:00	10/6/2021	16:00	Quarterly Maintenance

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
63	294	PLANNED	OCC_547	MSETCL	220KV-SOLAPUR-KUMBARI-1	Daily	Outage is required for Quarterly Maintenance	10/6/2021	10:00	10/6/2021	16:00	Quarterly Maintenance
64	296	PLANNED	OCC_547	MSETCL	220KV-SOLAPUR-JEUR-1	Daily	Outage is required for Quarterly Maintenance	10/6/2021	10:00	10/6/2021	17:00	Quarterly Maintenance
65	299	PLANNED	OCC_547	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 400KV - BUS 2 at EKTUNI - 400KV	Daily	Diagnostic Testing & Routine Maintenance work	10/6/2021	10:30	10/6/2021	18:00	"765/400kV ICT-II IV will be in service through its TIE (405) Bay & Main Bus-I"
66	300	PLANNED	OCC_547	MSETCL	220KV-AURANGABAD-CHITEGAON-2 on TBC @ CHITEGAON END	Daily	Replacement of TNC switch	10/6/2021	11:00	10/6/2021	14:00	The line will be in service through TBC
67	317	PLANNED	OCC_547	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-2 AND PARLI-M - 400KV - BUS 2 at MSETCL PARLI	Daily	For bay AMP works	10/7/2021	08:00	10/7/2021	18:00	
68	322	PLANNED	OCC_547	MSETCL	400KV-LONIKHAND-PUNE-PG-1	Daily	Routine Line & S/stn Maintenance work, Substation DT & MTAMC Work.	10/7/2021	08:00	10/7/2021	18:00	---
69	323	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Earthwire replacement Work	10/7/2021	08:00	10/7/2021	18:00	Planned outage
70	330	PLANNED	OCC_547	POWERGRID_WR2	220KV-BOISAR-BORIVALI	Daily	For AMP works. Line outage is required.	10/7/2021	09:00	10/7/2021	17:30	PG-WR2-Boisar
71	344	PLANNED	OCC_547	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 400KV - BUS 2 at EKTUNI - 400KV	Daily	Diagnostic Testing & Routine Maintenance work	10/7/2021	10:30	10/7/2021	18:00	"765/400kV ICT-I IV will be in service through its TIE (409) Bay & Main Bus-I"
72	359	PLANNED	OCC_547	POWERGRID_WR1	400KV-KALA-KUDUS-2	Daily	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTTING AT KUDUS END.	10/8/2021	07:00	10/8/2021	17:00	
73	364	PLANNED	OCC_547	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	Daily	For Testing of CVT	10/8/2021	07:00	10/8/2021	18:00	
74	378	PLANNED	OCC_547	POWERGRID_WR1	400KV-KORADI-SATPURA-1	Daily	For Line Bay AMP Work	10/8/2021	08:00	10/8/2021	18:00	
75	381	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/8/2021	08:00	10/8/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
76	382	PLANNED	OCC_547	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	10/8/2021	08:00	10/8/2021	18:00	NA
77	403	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/8/2021	09:30	10/8/2021	18:30	Annual Maintenance of Bay Equipment
78	410	PLANNED	OCC_547	MSETCL	BHUSAWAL - 400KV - BUS 1	Continuous	For testing of 400 KV BUS-I CVT	10/8/2021	06:00	10/9/2021	18:00	as per letter no MSETCL/CO/Tr/O&M/EE-I/WRPC/3022 dated 31.05.2021 There is large diff in Main Bus-I Voltage and Main Bus-II voltage hence testing and if required replace
79	435	PLANNED	OCC_547	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For Line Bay AMP and relay testing works . AR to be kept in on Auto mode for 400kV Akola-Wardha-I	10/9/2021	08:00	10/9/2021	18:00	
80	437	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/9/2021	08:00	10/9/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
81	439	PLANNED	OCC_547	POWERGRID_WR1	PUNE-PG - 400KV - BUS 2	Daily	For AMP Work	10/9/2021	08:30	10/9/2021	18:00	
82	450	PLANNED	OCC_547	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance, Relay Testing.	10/9/2021	10:00	10/9/2021	17:00	---
83	454	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Hardware tightening & Line signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole-II	10/9/2021	06:00	10/10/2021	19:00	Annual Maint. work of Hardware tightening & Line signature Analysis of 500KV Chandrapur-Padghe HVDC Line Pole-II
84	463	PLANNED	OCC_547	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	(1) Reactor backup relay retrofitting work.(2)Bay maintenance work.	10/10/2021	09:00	10/10/2021	18:00	-
85	464	PLANNED	OCC_547	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	1) REPLACEMENT OF BROKEN/MISSING SPACERS by Line maint. S/Dn Boisar. 2) R&M Work at Borivali end.	10/10/2021	10:00	10/10/2021	18:00	1) REPLACEMENT OF BROKEN/MISSING SPACERS by Line maint. S/Dn Boisar. 2) R&M Work at Borivali end.

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
86	483	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode	10/11/2021	08:00	10/11/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
87	488	PLANNED	OCC_547	MSETCL	400KV-WARDHA-WARORA-1	Daily	Attending isolator problem of 89LB of Bay no 420 and Line/Bus/Tie CT TAN DELTA,IR and isolater maintenance work etc	10/11/2021	09:00	10/11/2021	17:00	Load will be managed on 400KV IEPL Ckt
88	500	PLANNED	OCC_547	MEGPTCL	TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND 400KV-AKOLA-AKOLA (2)-1 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/11/2021	09:30	10/11/2021	18:30	Annual Maintenance of Bay Equipment
89	504	PLANNED	OCC_547	MSETCL	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	Daily	Annual Maintenance Work	10/11/2021	10:00	10/11/2021	18:00	Annual Maintenance Work
90	505	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	Daily	Annual Maintenance Work	10/11/2021	10:00	10/11/2021	18:00	Annual Maintenance Work
91	506	PLANNED	OCC_547	MSETCL	ALKUD - 400KV - BUS 1	Daily	Annual Maintenance Work	10/11/2021	10:00	10/11/2021	18:00	Annual Maintenance Work
92	507	PLANNED	OCC_547	MSETCL	400KV-ALKUD-SOLAPUR-1	Daily	Annual Maintenance work.	10/11/2021	10:00	10/11/2021	18:00	Annual Maintenance work.
93	509	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-EKTUNI-BABLESHWAR-2 AND 765KV/400KV EKTUNI-ICT-1 at EKTUNI - 400KV	Daily	Diagnostic Testing & Routine Maintenance work	10/11/2021	10:30	10/11/2021	18:00	"i) 400kV Bhambaleswar ckt-II will be in service through its Main (408) Bay & Main Bus-I. ii)765/400kV ICT-1 IV will be in service through its Main (410) Bay & Main Bus-II"
94	547	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/12/2021	08:00	10/12/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
95	548	PLANNED	OCC_547	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	10/12/2021	08:00	10/12/2021	18:00	NA
96	551	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	10/12/2021	09:00	10/12/2021	17:00	Only Tie CB 412 is in OFF condition, respective ckt charged through its own main CB.
97	568	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-EKTUNI-BABLESHWAR-1 AND FUTURE at EKTUNI - 400KV	Daily	Diagnostic Testing & Routine Maintenance work	10/12/2021	10:30	10/12/2021	18:00	400kV Bhambaleswar ckt-I will be in service through its Main (411) Bay & Main Bus-I.
98	571	PLANNED	OCC_547	MEGPTCL	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV at KORADI-III - 765KV	Continuous	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechanism.	10/12/2021	09:00	10/14/2021	18:00	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechanism.
99	575	PLANNED	OCC_547	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	Daily	401A Bay AMP @Waluj (MSETCL)	10/13/2021	07:00	10/13/2021	18:00	
100	590	PLANNED	OCC_547	POWERGRID_WR1	220KV-SOLAPUR-KUMBARI-1	Daily	Line side equipments AMP	10/13/2021	08:00	10/13/2021	18:00	
101	593	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/13/2021	08:00	10/13/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
102	594	PLANNED	OCC_547	MSETCL	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	10/13/2021	08:00	10/13/2021	18:00	Planned outage
103	599	PLANNED	OCC_547	MSETCL	132KV-PENCH-MP-KANHAN-1	Daily	Routine Maintenance work.	10/13/2021	09:00	10/13/2021	17:00	NA
104	600	PLANNED	OCC_547	POWERGRID_WR2	400KV-PADGHE-BOISAR-1	Daily	For AMP works at Boisar. Also, line AMP works, dia to be kept open at both ends.	10/13/2021	09:00	10/13/2021	17:30	PG-WR2-Boisar
105	607	PLANNED	OCC_547	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Hardware Tightening and Fitting Work.	10/13/2021	09:30	10/13/2021	18:30	-
106	608	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-1 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/13/2021	09:30	10/13/2021	18:30	Annual Maintenance of Bay Equipment
107	615	PLANNED	OCC_547	MSETCL	400KV-TAPTHITHANDA-EKTUNI-1	Daily	1. Relay testing work 2. Quarterly maint. work	10/13/2021	11:00	10/13/2021	17:00	Nil

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
108	621	PLANNED	OCC_547	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	Daily	403 Bay AMP @Waluj (MSETCL)	10/14/2021	07:00	10/14/2021	18:00	
109	622	PLANNED	OCC_547	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	Daily	For AMP Work	10/14/2021	07:00	10/14/2021	18:00	
110	625	PLANNED	OCC_547	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	Line maintenance work	10/14/2021	08:00	10/14/2021	17:00	-
111	633	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/14/2021	08:00	10/14/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
112	634	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	10/14/2021	09:00	10/14/2021	17:00	1) Load of Kala-2 Line shifted on 400KV Kala-Kudus Ckt-1 2) Simultaneously outage is required on the Main Bay no. 401 of said line.
113	635	PLANNED	OCC_547	MSETCL	MAIN BAY OF 400KV-KUDUS-PADGHE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	10/14/2021	09:00	10/14/2021	17:00	Annual Maintenance of bays equipment & Diagnostics Testing Work
114	636	PLANNED	OCC_547	MSETCL	MAIN BAY - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	10/14/2021	09:00	10/14/2021	17:00	Simultaneously outage is required on the Tie Bay no. 402 of said line.
115	637	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	10/14/2021	09:00	10/14/2021	17:00	Simultaneously outage is required on the Tie Bay no. 401 of said line.
116	638	PLANNED	OCC_547	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	Daily	For AMP works at Boisar. Also, line AMP works, A/R OFF on ckt-2 and dia to be kept open.	10/14/2021	09:00	10/14/2021	17:30	PG-WR2-Boisar
117	649	PLANNED	OCC_547	MSETCL	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	10/14/2021	10:00	10/14/2021	18:00	NA
118	660	PLANNED	OCC_547	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Routine maintenance work	10/15/2021	08:00	10/15/2021	18:00	Routine maintenance work
119	664	PLANNED	OCC_547	MSETCL	ALKUD - 400KV - BUS 2	Daily	Annual Maintenance work	10/15/2021	10:00	10/15/2021	18:00	Load will be managed on Main bus 1
120	667	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Hardware Tightening and Broken Disc replacement	10/16/2021	06:00	10/16/2021	19:00	Annual maint. work of Hardware Tightening and Broken Disc replacement
121	668	PLANNED	OCC_547	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	Daily	For AMP Work	10/16/2021	07:00	10/16/2021	18:00	
122	672	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/16/2021	08:00	10/16/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
123	673	PLANNED	OCC_547	MSETCL	NEW KOYNA - 400KV - BUS 2	Daily	for CVT replacement work	10/16/2021	08:00	10/16/2021	18:00	Planned outage
124	678	PLANNED	OCC_547	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	Daily	For AMP works at Boisar. Also, line AMP works, A/R OFF on ckt-1 and dia to be kept open.	10/16/2021	09:00	10/16/2021	17:30	PG-WR2-Boisar
125	693	PLANNED	OCC_547	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	PID testing work	10/16/2021	08:00	10/31/2021	18:00	-
126	694	PLANNED	OCC_547	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	Live line installation of OPGW by MTCIL, and PID Testing Auto-Reclose function to be out of service.	10/16/2021	08:00	10/31/2021	19:00	Live line installation of OPGW by MTCIL, and PID Testing Auto-Reclose function to be out of service.
127	696	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	Hardware Tightening and Broken Disc replacement	10/17/2021	06:00	10/17/2021	19:00	Annual maint. work of Hardware Tightening and Broken Disc replacement
128	699	PLANNED	OCC_547	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	CONDUCTOR REPLACEMENT WITH HTLS CONDUCTOR & Complete bay maintenance works.	10/17/2021	09:00	10/17/2021	17:00	CONDUCTOR REPLACEMENT WITH HTLS CONDUCTOR & Complete bay maintenance works.
129	705	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	jumper tightening work	10/18/2021	08:00	10/18/2021	17:00	...
130	717	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/18/2021	08:00	10/18/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
131	720	PLANNED	OCC_547	POWERGRID_WRI	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	Daily	For AMP Work	10/18/2021	08:30	10/18/2021	18:00	
132	726	PLANNED	OCC_547	MSETCL	CHANDRAPUR-GCR - 400KV - TRANSFER BUS 2	Daily	1)Measurment of BKR timing ,CRM DCRM 2)routine maintenace of PG isolator and CB isolators	10/18/2021	09:00	10/18/2021	18:00	TBC-2 will not be available TBC-1 will be available
133	730	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/18/2021	09:30	10/18/2021	18:30	Annual Maintenance of Bay Equipment
134	756	Planned	OCC_547	GETCO	400KV-SSP-DHULE-MS-1	Daily	PMM	10/19/2021	08:00	10/19/2021	18:00	Non auto reclose code for 400kv SSP-Dhule no-2 is to be required.
135	761	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	jumper tightening work	10/19/2021	08:00	10/19/2021	17:00	
136	766	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/19/2021	08:00	10/19/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
137	769	PLANNED	OCC_547	MEGPTCL	TIE BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND 400KV-AKOLA-AKOLA (2)-2 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/19/2021	09:30	10/19/2021	18:30	Annual Maintenance of Bay Equipment
138	780	PLANNED	OCC_547	ATIL	TIRODA - 400KV B/R 1	Daily	For B/R-1 Main and Tie Bay Equipment Maintenance activities & B/R-1 Transformer maintenance activities	10/19/2021	09:00	10/20/2021	19:00	For B/R-1 Main and Tie Bay Equipment Maintenance activities & B/R-1 Transformer maintenance activities
139	786	PLANNED	OCC_547	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	Continuous	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechnism.	10/19/2021	09:00	10/21/2021	18:00	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechnism.
140	793	PLANNED	OCC_547	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance work	10/20/2021	08:00	10/20/2021	17:00	-
141	806	PLANNED	OCC_547	MSETCL	KHAPARKHEDA - 400KV - BUS 1	Daily	Main Bus 1 Centre Break Isolator Maintenance Work	10/20/2021	08:00	10/20/2021	18:00	NA
142	807	PLANNED	OCC_547	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	10/20/2021	08:00	10/20/2021	18:00	NA
143	808	PLANNED	OCC_547	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 at WARORA - 400KV	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	10/20/2021	09:00	10/20/2021	10:00	PGCIL LINE CHARGED THROUGH TIE BAY NO 421.
144	810	PLANNED	OCC_547	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	10/20/2021	09:00	10/20/2021	17:00	NA
145	818	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	Daily	Annual Maintenance of Bay Equipment	10/20/2021	09:30	10/20/2021	18:30	Annual Maintenance of Bay Equipment
146	822	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	10/20/2021	10:00	10/20/2021	11:00	Only Tie CB 421 is in OFF condition ,respective ckt charged through its own main CB.
147	824	PLANNED	OCC_547	MSETCL	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	10/20/2021	16:00	10/20/2021	17:00	Only Tie CB 415 is in OFF condition, respective ckt charged through its own main CB.
148	830	Planned	OCC_547	NPCIL, TAPS 1&2	220kV Tarapur 1&2- Boisar-M1	continuous	Preventive maintenance of CTs, wave traps and condition monitoring of field cables, replacement of R phase CT, PM of drop jumper clamps, PM of isolator drop jumpers and cleaning of gantry insulators and reconditioning	10/20/2021	08:00	10/25/2021	18:00	Feeder outage is required
149	833	PLANNED	OCC_547	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Continuous	1) Dismantling of existing loc no.37 and erection of new loc no. 37a & 38a. 2) Railway crossing stringing between loc no.36-37a-38-a-38. 3) Previous outage proposed in September-2021 not availed due to rainy season.	10/20/2021	09:00	10/30/2021	18:00	1) Simultaneously outage is also required on 220KV Tarapur-Boisar-II Line. 2) The work is required to be carried out for rerouting of 220KV Tarapur-Boisar-II & 220KV Tarapur-Borivali D/C Line for DFCCIL. 3) Previous outage proposed in September-2021 not availed due to rainy season.

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
150	834	PLANNED	OCC_547	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Continuous	1) Dismantling of existing loc no.37 and erection of new loc no. 37a & 38a. 2) Railway crossing stringing between loc no.36-37a-38-a-38.	10/20/2021	09:00	10/30/2021	18:00	1) Simultaneously outage is also required on 220KV Tarapur-Borivali Line. 2) The work is required to be done for rerouting of 220KV Tarapur-Boisar-II & 220KV Tarapur-Borivali D/C Line for DFCCIL. 3) Previous outage in September-2021 not availed due to rainy season.
151	841	Planned	OCC_547	GETCO	400KV-SSP-DHULE-MS-2	Daily	Maintenance work. Auto reclose of 400 kV SSP - Dhule 1	10/21/2021	08:00	10/21/2021	18:00	Non auto reclose code for 400kv SSP-Dhule no-1 is to be required.
152	855	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/21/2021	08:00	10/21/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
153	858	PLANNED	OCC_547	MSETCL	MAIN BAY OF 400KV-WARORA-CHANDRAPUR-II-2 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	10/21/2021	09:00	10/21/2021	10:00	CHANDRAPUR 2 CKT 2 CHARGED THROUGH TIE BAY NO 415.
154	868	PLANNED	OCC_547	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	Hardware Tightening and Fitting Work.	10/21/2021	09:30	10/21/2021	18:30	-
155	872	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPUR-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	10/21/2021	10:00	10/21/2021	11:00	Only Tie CB 412 is in OFF condition ,respective ckt charged through its own main CB.
156	876	PLANNED	OCC_547	MSETCL	MAIN BAY OF 400KV-WARORA-CHANDRAPUR-II-1 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	10/21/2021	11:00	10/21/2021	12:00	CHANDRAPUR 2 CKT 1 CHARGED THROUGH TIE BAY NO 411.
157	882	Planned	OCC_547	NPCIL, TAPS 1&2	220kv Tarapur 1&2- Boisar-M1	continuous	Maintenance of line equipments	10/21/2021	08:00	10/22/2021	20:00	Simultaneous outage of 220kv Tarapur 1&2- Boisar and 220kv Tarapur 1&2Borivali Line is required for debris removal under the D/C 220KV MSETCL lines at INRP PROJECT, BARC, Tarapur
158	883	Planned	OCC-547	NPCIL, TAPS 1&2	220 kv-Tarapur1&2 -Borivali	continuous	Maintenance of line equipments	10/21/2021	08:00	10/22/2021	20:00	Simultaneous outage of 220kv Tarapur 1&2- Boisar and 220kv Tarapur 1&2Borivali Line is required for debris removal under the D/C 220KV MSETCL lines at INRP PROJECT, BARC, Tarapur
159	886	PLANNED	OCC_547	ATIL	TIRODA - 400KV B/R 2	Daily	For B/R-2 Main and Tie Bay Equipment Maintenance activities & B/R-2 Transformer maintenance activities.	10/21/2021	09:00	10/22/2021	19:00	For B/R-2 Main and Tie Bay Equipment Maintenance activities & B/R-2 Transformer maintenance activities.
160	888	PLANNED	OCC_547	MSETCL	400KV-BABLESHWAR-PADGHE-1 ON TBC @ PADGHE END	Continuous	1) CB Overhauling work 2) PG isolator replacement work 3) DCRM of CB	10/21/2021	09:30	10/24/2021	19:00	1) Weather condition should be clear 2) Line in service through TBC 3) Hot line work for hanger rod replacement
161	891	PLANNED	OCC_547	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Hill cutting work & stay erection Excavation work for tower loc. No.94 & Diagnostic testing & Relay testing work & Routine maint. Work	10/21/2021	08:00	10/31/2021	18:00	Planned outage
162	895	Planned	OCC_547	GETCO	220kv Navsari-Nashik line no.1	Daily	maintenance work	10/22/2021	08:00	10/22/2021	18:00	maintenance work
163	914	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/22/2021	08:00	10/22/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
164	918	PLANNED	OCC_547	POWERGRID_WR2	BOISAR - 220KV - BUS 1	Daily	For AMP works.	10/22/2021	09:00	10/22/2021	17:30	PG-WR2-Boisar
165	945	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/23/2021	08:00	10/23/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
166	946	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Pole II Base Filter for replacement of Y Ph Interrupter due to High CRM (116 micor ohm) of Breaker. POLE-2 BASE AC FILTER Z1- Z2(200MVAR) @ CHANDRAPUR HVDC	10/23/2021	08:00	10/23/2021	18:00	Both Pole will be in service with power restriction of 850 MW.
167	950	PLANNED	OCC_547	MP_SLDC	220KV-PANDHURNA-MP-KALMESHVAR-MH	Daily	FOR LINE MAINTENANCE WORK	10/23/2021	09:00	10/23/2021	18:00	
168	962	PLANNED	OCC_547	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Hardware tightening and broken disc replacement.	10/23/2021	06:00	10/24/2021	19:00	Annual maint. work of Hardware tightening and broken disc replacement.
169	968	PLANNED	OCC_547	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	PID FAULTY INSULATO STRING REPLACEMENT and Bay Maintenance and Dignostics testing	10/24/2021	09:00	10/24/2021	17:00	PID FAULTY INSULATO STRING REPLACEMENT and Bay Maintenance and Dignostics testing
170	972	PLANNED	OCC_547	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	Daily	Replacement of M1 REL521 Relay of Padghe Tarapur 2 line at Padghe MSETCL SS.	10/25/2021	07:00	10/25/2021	17:00	

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
171	977	Planned	OCC_547	GETCO	220kV Navsari-Nashik line no.2	Daily	maintenance work	10/25/2021	08:00	10/25/2021	18:00	maintenance work
172	990	PLANNED	OCC_547	POWERGRID_WR1	400KV-BHILAI-KORADI-1	Daily	For Line Bay AMP Work	10/25/2021	08:00	10/25/2021	18:00	
173	994	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/25/2021	08:00	10/25/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
174	997	PLANNED	OCC_547	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	Daily	For AMP works. Dia to be kept open on both sides.	10/25/2021	09:00	10/25/2021	17:30	PG-WR2-Boisar
175	1004	PLANNED	OCC_547	MSETCL	AKOLA - 400KV - BUS 1	Daily	Servicing & alignment of isolators /earth switches will be carried out by agency and routine maintenance & testing work	10/25/2021	09:00	10/25/2021	18:00	Bus-02 will be in service
176	1010	PLANNED	OCC_547	MSETCL	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	Daily	Annual Maintenance Work	10/25/2021	10:00	10/25/2021	18:00	Annual Maintenance Work
177	1011	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE at ALKUD - 400KV	Daily	Annual Maintenance Work	10/25/2021	10:00	10/25/2021	18:00	Annual Maintenance Work
178	1019	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	Continuous	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechnism.	10/25/2021	09:00	10/27/2021	18:00	Annual Maintenance of bay equipments & Complete Healthiness checking & Overhauling of Circuit Breaker & Mechnism.
179	1024	PLANNED	OCC_547	MSETCL	KOLHAPUR-MS - 400KV - BUS 2	Continuous	1. Annual Bus Maintenance. 2. Chemical cleaning of Bus Strings. 3. Replacement of faulty strings 4. 400kV Karad 2 B ph A Bus isolator replacement work. 5. Annual Maintenance of A Bus isolators of all Bays. 6. Annual Bus CVT testing	10/25/2021	09:00	10/31/2021	18:00	Load will be managed on 400kV Main Bus 1
180	1047	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/26/2021	08:00	10/26/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
181	1049	PLANNED	OCC_547	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	R Phase LINE CVT replacement by agency and Diagnostic testing work of CVT.	10/26/2021	09:00	10/26/2021	17:00	Load will managed by Chandrapur 2 ckt 1 Bay no 413.
182	1062	PLANNED	OCC_547	APML	TIRODA - 765KV B/R 1	Continuous	For B/R-1 Main and Tie Bay Equipment Maintenance activities B/R-1 Transformer maintenance activities	10/26/2021	09:00	10/27/2021	18:00	For B/R-1 Main and Tie Bay Equipment Maintenance activities B/R-1 Transformer maintenance activities
183	1065	Planned	OCC-547	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 –Borivali	continuous	Replacement of all three phases LA, Replacement of CVTs, PM of SF6 gas breakers, auxiliary relays, wave traps and isolator drop jumpers	10/26/2021	08:00	10/30/2021	20:00	Feeder outage is required
184	1079	PLANNED	OCC_547	MSETCL	220KV-PARLI-PARLI-M-2	Daily	Line maintenance	10/27/2021	08:00	10/27/2021	17:00	-
185	1091	PLANNED	OCC_547	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	10/27/2021	08:00	10/27/2021	18:00	NA
186	1101	PLANNED	OCC_547	MSETCL	AKOLA - 400KV - BUS 2	Daily	Servicing & alignment of isolators /earth switches will be carried out by agency and routine maintenance & testing work	10/27/2021	09:00	10/27/2021	18:00	Bus-01 will be in service
187	1106	PLANNED	OCC_547	MSETCL	220KV-SOLAPUR-KUMBARI-2	Daily	Outage is required for Quarterly Maintenance	10/27/2021	10:00	10/27/2021	16:00	Quarterly Maintenance
188	1107	PLANNED	OCC_547	MSETCL	KUMBARI - 220KV - BUS 2	Daily	Outage is required for Quarterly Maintenance	10/27/2021	10:00	10/27/2021	16:00	Quarterly Maintenance
189	1108	PLANNED	OCC_547	MSETCL	KORADI-II - 400KV - BUS 1	Daily	On line testing of 400KV BusBar Protection Scheme.	10/27/2021	10:00	10/27/2021	17:00	400KV Bus bar Protection will be out
190	1109	PLANNED	OCC_547	MSETCL	KORADI-II - 400KV - BUS 2	Daily	On line testing of 400KV BusBar Protection Scheme	10/27/2021	10:00	10/27/2021	17:00	400KV Bus bar Protection will be out
191	1112	PLANNED	OCC_547	MSETCL	132KV-DHARNI-NEPANAGAR-1	Daily	1)Replacement of R-ph metering PT 2) Line Signature Analysis & Other Maintenance Works of Line	10/27/2021	11:00	10/27/2021	16:00	Nil
192	1137	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/28/2021	08:00	10/28/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.

Sr. No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks
193	1140	PLANNED	OCC_547	MSETCL	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	10/28/2021	09:00	10/28/2021	17:00	Line will be charged through Tie CB 428.
194	1147	PLANNED	OCC_547	MSETCL	400KV-PARLI-M-PARLI-2	Daily	(1) DCRM & timing measurement work of breaker.(2)Bay maintenance work.	10/28/2021	09:00	10/28/2021	18:00	-
195	1157	PLANNED	OCC_547	TARAPUR 3&4	400 KV-TARAPUR 3&4-BOISAR-1	Continuous	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	10/28/2021	09:00	10/30/2021	18:00	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
196	1158	PLANNED	OCC_547	POWERGRID_WR1	400 KV-TARAPUR 3&4-BOISAR-1	Continuous	Annual PM of CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	10/28/2021	09:00	10/30/2021	18:00	
197	1170	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10/29/2021	08:00	10/29/2021	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
198	1175	PLANNED	OCC_547	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	10/29/2021	09:00	10/29/2021	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
199	1176	PLANNED	OCC_547	POWERGRID_WR2	BOISAR - 220KV - BUS 2	Daily	For AMP works.	10/29/2021	09:00	10/29/2021	17:30	PG-WR2-Boisar
200	1181	PLANNED	OCC_547	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	Daily	Annual Maintenance of bay equipment	10/29/2021	09:00	10/29/2021	18:00	Annual Maintenance of bay equipment
201	1185	PLANNED	OCC_547	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Annual Maintenance of bay equipment	10/29/2021	09:30	10/29/2021	18:30	Annual Maintenance of bay equipment
202	1204	PLANNED	OCC_547	MSETCL	220KV-BOISAR-BOISAR-M-3	Daily	Complete bay maintenance works.	10/30/2021	06:00	10/30/2021	18:00	Complete bay maintenance works.
203	1213	PLANNED	OCC_547	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire and PID suspicious disc insulator replacement, other maintenance work and 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	10/30/2021	08:00	10/30/2021	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
204	1214	PLANNED	OCC_547	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	10/30/2021	09:00	10/30/2021	17:00	Line will be charged through Main CB 429.
205	1216	PLANNED	OCC_547	POWERGRID_WR2	400kV-SATPURA-KORADI	Daily	For AMP works by Itarsi s/s.	10/30/2021	09:00	10/30/2021	18:00	PG-WR2-Itarsi
206	1225	PLANNED	OCC_547	MSETCL	220KV-BOISAR-BOISAR-M-1	Daily	CONDUCTOR REPLACEMENT WITH HTLS CONDUCTOR & Complete bay maintenance works.	10/31/2021	09:00	10/31/2021	17:00	CONDUCTOR REPLACEMENT WITH HTLS CONDUCTOR & Complete bay maintenance works.

STATE ELEMENT LIST FOR THE MONTH OF OCTOBER'21											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	01-Oct-21	08:00	01-Oct-21	17:00	Daily	Routine maintenance and Line/Bus/Tie CT TAN DELTA,IR and isolater maintenance work etc .	MSETCL	MSETCL	Bay No 404 charged upto line CT (400KV ICT No -1 handed over to 400kv Bableshtar)
2	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	01-Oct-21	08:00	01-Oct-21	16:00	Daily	COMPLETE BAY MAINTENANCE & CT TESTING WORK	MSETCL	MSETCL	COMPLETE BAY MAINTENANCE & CT TESTING WORK
3	400 KV	NEW KOYNA - STAGE IV CKT - 2	01-Oct-21	08:00	01-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
4	400 KV	JEJURI- KOYNA STAGE-IV	02-Oct-21	08:00	31-Oct-21	18:00	Daily	work of Chemical washing on disc insulator strings	MSETCL	MSETCL	work of Chemical washing on disc insulator strings
5	400 KV	PADGHE - NAGOTHANE CKT - 1	04-Oct-21	08:00	05-Oct-21	17:00	Daily	earth wire Replacement and jumper tightening work	MSETCL	MSETCL	..
6	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	12-Oct-21	09:00	12-Oct-21	18:00	Daily	Replacement of REF relay,Tan delta & capacitance testing of Bushing & winding	MSETCL	MSETCL	Load will be managed on other two ICTs
7	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	04-Oct-21	08:00	04-Oct-21	16:00	Daily	MAIN BAY CT TAN DELTA & CB DCRM & BUS CT TAN DELTA WORK	MSETCL	MSETCL	MAIN BAY CT TAN DELTA & CB DCRM & BUS CT TAN DELTA WORK
8	400 KV	TBC @ KORADI-1	04-Oct-21	08:00	05-Oct-21	18:00	Continuous	PG & CB isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
9	400 KV	WARORA - IEPL	05-Oct-21	09:00	05-Oct-21	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
10	400 KV	MAIN BAY (410) OF DHARIWAL CKT - 2 @ CHANDRAPUR - 2	05-Oct-21	10:00	05-Oct-21	17:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	410 main bay only
11	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	05-Oct-21	10:00	05-Oct-21	17:00	Daily	Tan delta measurement of Bushing & windings of ICT-I	MSETCL	MSETCL	ICT-II will remain in service, as alternate source of supply
12	400 KV	KORADI-NANDGAONPETH (RPL)	05-Oct-21	08:00	05-Oct-21	18:00	Daily	LINE MAINTENCE WORKS	MSETCL	MSETCL	NA
13	400 KV	400KV 125MVAR BUS REACTOR @ KARAD	05-Oct-21	09:00	05-Oct-21	16:00	Daily	Tan delta & capacitance testing of Bushing. Quarterly Maint. work	MSETCL	MSETCL	Nil
14	400 KV	THAPTI TANDA - WALUJ	05-Oct-21	10:00	05-Oct-21	18:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
15	400 KV	TIE BAY (418) OF ICT - 1 & ST 4B @ DEEPNAGAR	05-Oct-21	08:00	05-Oct-21	16:00	Daily	TIE BAY CB DCRM & TIE CT TAN DELTA WORK	MSETCL	MSETCL	TIE BAY CB DCRM & TIE CT TAN DELTA WORK
16	400 KV	400/220 KV 500 MVA ICT @ ALKUD	05-Oct-21	10:00	05-Oct-21	18:00	Daily	Quarterly Maintenance work & diagnostic testing work.	MSETCL	MSETCL	Tuesday is load staggering day for Sangli district.
17	400 KV	PADGHE - NAGOTHANE CKT - 2	06-Oct-21	08:00	07-Oct-21	17:00	Daily	earth wire Replacement and jumper tightening work	MSETCL	MSETCL	...
18	400 KV	KORADI-NANDGAONPETH (RPL)@ on TBC	06-Oct-21	08:00	07-Oct-21	18:00	Continuous	PG & CB isolators alignment , testing and setting work	MSETCL	MSETCL	1) 400 KV Bus reactor needs to be out. 2) 400kV Nandgaonpeth RPL will be shifted on 400kV TBC
19	400 KV	Waluj-Taptitanda on TBC @ Waluj	06-Oct-21	10:00	06-Oct-21	18:00	Daily	400kv waluj thaptitanda bay through TBC	MSETCL	MSETCL	CB TESTING WORK THROUGH TBC
20	400 KV	KHADKA- DEEPNAGAR CKT 2	06-Oct-21	08:00	06-Oct-21	18:00	Daily	For DCRM testing of own CB of 400 KV Deepnagar-II Bay	MSETCL	MSETCL	during above period line will be shifted on TBC hence there is no interruption
21	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	06-Oct-21	10:00	06-Oct-21	17:00	Daily	Tan delta measurement of Bushing & windings of ICT-I	MSETCL	MSETCL	ICT-II will remain in service, as alternate source of supply
22	400 KV	MAIN BAY (402) OF 500MVA ICT - 1 @ KHAPERKHEDA	06-Oct-21	10:00	06-Oct-21	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	NA
23	400 KV	TIE BAY - 403 OF 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	06-Oct-21	10:00	06-Oct-21	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	NA
24	400 KV	CHANDRAPUR-PARLI CKT-3	07-Oct-21	09:00	07-Oct-21	18:00	Daily	Line maint. Work	MSETCL	MSETCL	-
25	400 KV	MAIN BAY - 405 OF PARLI (GIRWALI) CKT-2 @ NANDED	07-Oct-21	10:30	07-Oct-21	18:00	Daily	For CB DCRM, CT Tan-d, Line CVT Tan-d & Bay Maintenance	MSETCL	MSETCL	-
26	400 KV	400/220KV SPARE ICT @ JEJURI	07-Oct-21	09:30	07-Oct-21	17:30	Daily	Annual Testing & Maintenance work. Also CTR fire protection system work.	MSETCL	MSETCL	---
27	400 KV	GTR - 8 @ CHANDRAPUR SWITCHING SS	07-Oct-21	09:00	07-Oct-21	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Bay 413 & Bay 414
28	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	09-Oct-21	08:00	09-Oct-21	18:00	Daily	Routine maintenance work, Diagnostic and relay testing work, auxiliary trials.	MSETCL	MSETCL	-
29	400 KV	MAIN BAY - 401 OF BUS REACTOR @ ALKUD	08-Oct-21	10:00	08-Oct-21	18:00	Daily	Annual Maintenance work	MSETCL	MSETCL	Annual Maintenance work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
30	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	08-Oct-21	10:00	08-Oct-21	18:00	Daily	Annual Maintenance work	MSETCL	MSETCL	Annual Maintenance work
31	400 KV	125 MVA BUS REACTOR @ ALKUD	08-Oct-21	10:00	08-Oct-21	18:00	Daily	Annual maintenance work.	MSETCL	MSETCL	Annual maintenance work.
32	400 KV	KORADI-NANDGAONPETH (RPL)	08-Oct-21	08:00	08-Oct-21	18:00	Daily	PG & CB isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
33	400 KV	NEW KOYNA - STAGE IV CKT - 1	08-Oct-21	08:00	08-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
34	400 KV	STATION TF - 1 @ KORADI -2	08-Oct-21	10:00	08-Oct-21	17:00	Daily	Tan delta measurement of Line CT & Bus CT Main Bay 422 & Tie Bay 423	MSETCL	MSETCL	Station Transformer II & III will remain service as alternate source of supply.
35	400 KV	JAIGAD - NEW KOYNA CKT - 1	09-Oct-21	08:00	09-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	-
36	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	11-Oct-21	08:00	11-Oct-21	17:00	Daily	Post monsoon maint work	MSETCL	MSETCL	
37	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END)	11-Oct-21	09:00	12-Oct-21	18:00	Continuous	1)Retrofitting of distance relay Main-1 & Main-2 and 3 ph master trip relay 86,under MTAMC project(subjected to drawing approval 2)Routine maintenance work.	MSETCL	MSETCL	400KV CHD-2 ckt no.2 &400kv kharkheda ckt,400kv PGCL ckt1,2,3 & 4 will be in service
38	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	11-Oct-21	09:00	11-Oct-21	18:00	Daily	1. Annual Maintenance work. 2. Annual Diagnostic Testing. 3. Chemical Cleaning of Strings & Equipments. 4. Replacement of Strings. 3.	MSETCL	MSETCL	Load will be managed on 501MVA ICT-1 & 501MVA ICT-3
39	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	11-Oct-21	08:00	11-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
40	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	11-Oct-21	09:00	11-Oct-21	18:00	Daily	(1) Main-2 distance relay testing and C & Tan delta measurement of CVTs. (2) Bay maintenance work.	MSETCL	MSETCL	Relay Routine Testing & Line CVT Tan-d & Bay Maintenance@400kv Kumbhargaoon(Nanded) SS
41	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	12-Oct-21	08:00	12-Oct-21	17:00	Daily	Post monsoon maint work	MSETCL	MSETCL	
42	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	12-Oct-21	09:00	12-Oct-21	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Bay 401 & Bay 402
43	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	12-Oct-21	10:00	12-Oct-21	17:00	Daily	Tan delta measurement of Line CT at 400KV Bay 421 & 220KV bay 201	MSETCL	MSETCL	ICT-1 will remain in service, as alternate source of supply
44	400 KV	TBC @ WALUJ	12-Oct-21	10:00	12-Oct-21	18:00	Daily	Routine maintenance and CT CB Testing work	MSETCL	MSETCL	Routine maintenance and CT CB Testing work
45	400 KV	MAIN BAY - 401 CHD SWITCHING CKT1 @ CHANDRAPUR 2	13-Oct-21	09:00	13-Oct-21	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	401 main bay only
46	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	13-Oct-21	08:00	13-Oct-21	17:00	Daily	Post monsoon maint work	MSETCL	MSETCL	...
47	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	13-Oct-21	09:00	13-Oct-21	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	Only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.
48	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	14-Oct-21	09:00	14-Oct-21	18:00	Daily	(1) HV backup protn. relay testing and IV CT testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
49	400 KV	LONIKAND I - KOYNA STAGE-IV	14-Oct-21	08:00	14-Oct-21	18:00	Daily	Substation DT & MTAMC Work.	MSETCL	MSETCL	---
50	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	14-Oct-21	09:30	14-Oct-21	17:30	Daily	Annual Testing & Maintenance work. Also CTR fire protection system work.	MSETCL	MSETCL	400/220/33kv ICT-2 & ICT-3 will be in service.
51	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	14-Oct-21	08:00	14-Oct-21	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	Only on Humming (Without load)
52	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	18-Oct-21	09:00	18-Oct-21	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Bay 417 & Bay 418
53	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	18-Oct-21	09:00	18-Oct-21	18:00	Daily	1. Annual Maintenance work. 2. Annual Diagnostic Testing work. 3. Chemical Cleaning of Strings & Equipments.	MSETCL	MSETCL	Load will be managed on 315 MVA ICT-2 & 501 MVA ICT-1. Mobday is load staggering day in Kolhapur.
54	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	18-Oct-21	08:00	18-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Isolator replacement work	MSETCL	MSETCL	Planned outage
55	400 KV	Akola II (Yelwan) - Akola I CKT - 1	18-Oct-21	09:00	18-Oct-21	18:00	Daily	Routine maintenance & testing work	APTCL	APTCL	Yelwan Ckt-02 will be in service
56	400 KV	JAIGAD - NEW KOYNA CKT - 2	19-Oct-21	08:00	19-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	--

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
57	400 KV	NEW KOYNA-KARAD CKT - 2	20-Oct-21	08:00	20-Oct-21	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	--
58	400 KV	MAIN BAY (433) OF 500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	20-Oct-21	10:00	20-Oct-21	17:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	433 Main bay only
59	400 KV	PADGHE - NAGOTHANE CKT - 1	20-Oct-21	08:00	20-Oct-21	17:00	Daily	jumper tightening work	MSETCL	MSETCL	..
60	400 KV	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	20-Oct-21	15:00	20-Oct-21	16:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	FUTURE LINE-1 PRESENTLY NO LOAD CONDITION.
61	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	20-Oct-21	11:00	20-Oct-21	12:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	FUTURE LINE-2 PRESENTLY NO LOAD CONDITION.
62	400 KV	MAIN BAY (417) OF IEPL @ WARORA	20-Oct-21	12:00	20-Oct-21	13:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	IEPL LINE CHARGED THROUGH TIE BAY NO 418.
63	400 KV	TIE BAY (406) OF 500MVA ICT - 2 @ KHAPERKHEDA	20-Oct-21	10:00	20-Oct-21	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	NA
64	400 KV	MAIN BAY (405) OF 500MVA ICT - 2 @ KHAPERKHEDA	20-Oct-21	10:00	20-Oct-21	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	NA
65	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	20-Oct-21	14:00	20-Oct-21	15:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	Only Tie CB 418 is in OFF condition , respective ckt charged through its own main CB.
66	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	21-Oct-21	09:00	21-Oct-21	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
67	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	21-Oct-21	10:30	21-Oct-21	18:00	Daily	Diagnostic testing and relay testing	MSETCL	MSETCL	-
68	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	21-Oct-21	09:00	21-Oct-21	18:00	Daily	(1) DCRM & timing measurement work of HV breaker and NDR relay testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
69	400 KV	LONIKAND I - JEJURI	21-Oct-21	08:00	21-Oct-21	18:00	Daily	DT/Line Maintenance (Insulator String Replacement work)	MSETCL	MSETCL	---
70	400 KV	KARAD - LONIKAND I	21-Oct-21	08:00	21-Oct-21	18:00	Daily	Routine Line & S/stn Maintenance work, Substation DT & MTAMC Work.	MSETCL	MSETCL	---
71	400 KV	PADGHE - NAGOTHANE CKT - 2	21-Oct-21	08:00	21-Oct-21	17:00	Daily	jumper tightening work	MSETCL	MSETCL	...
72	400 KV	MAIN BAY (402) OF 125MVAr BUS REACTOR @ WARORA	21-Oct-21	12:00	21-Oct-21	13:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	125MVAR REACTOR kept in OFF position.
73	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	21-Oct-21	09:30	21-Oct-21	17:30	Daily	Annual Testing & Maintenance work. Also CTR fire protection system work.	MSETCL	MSETCL	400/220/33kV ICT-1 & ICT-2 will be in service.
74	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	21-Oct-21	08:00	21-Oct-21	18:00	Daily	Half yearly maintenance and	MSETCL	MSETCL	400/220kV 501 MVA ICT-II will remain in service
75	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	21-Oct-21	09:00	22-Oct-21	18:00	Continuous	1)Retrofitting of distance relay Main-1 & Main-2 and 3 ph master trip relay 86,under MTAMC project(subjected to drawing approval 2)Routine maintenance work	MSETCL	MSETCL	400KV CHD-2 ckt no.1 & 400kv khaparkheda ckt,400kv PGCIL ckt1,2,3 & 4 will be in service
76	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	21-Oct-21	08:00	21-Oct-21	18:00	Daily	21/Oct/2021	MSETCL	MSETCL	NA
77	400 KV	TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	21-Oct-21	15:00	21-Oct-21	16:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	Only Tie CB 403 is in OFF condition, respective ckt charged through its own main CB.
78	400 KV	TIE BAY (406) OF ICT -2 @ WARORA	21-Oct-21	14:00	21-Oct-21	15:00	Daily	SF6 DUE POINT TEST OF CB BY AGENCY	MSETCL	MSETCL	Only Tie CB 406 is in OFF condition.
79	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	21-Oct-21	10:00	21-Oct-21	18:00	Daily	Routine maintenance CT Testing work	MSETCL	MSETCL	Routine maintenance CT Testing work
80	400 KV	Akola II (Yelwan) - Akola I CKT - 2	21-Oct-21	09:00	21-Oct-21	18:00	Daily	Routine maintenance & testing work	APTCL	APTCL	Yelwan Ckt-01 will be in service
81	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	22-Oct-21	09:00	22-Oct-21	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
82	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	22-Oct-21	08:00	22-Oct-21	18:00	Daily	Routine maintenance work, Diagnostic and relay testing work, auxiliary trials	MSETCL	MSETCL	-
83	400 KV	Main Bay (418) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	22-Oct-21	09:00	22-Oct-21	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Bay 418
84	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	22-Oct-21	10:00	22-Oct-21	18:00	Daily	CB TESTING WORK THROUGH TBC	MSETCL	MSETCL	CB TESTING WORK THROUGH TBC
85	400 KV	MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	22-Oct-21	08:00	22-Oct-21	16:00	Daily	MAIN BAY CB DCRM TESTING WORK	MSETCL	MSETCL	MAIN BAY CB DCRM TESTING WORK
86	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	23-Oct-21	08:00	23-Oct-21	18:00	Daily	For diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	Nil

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
87	400 KV	CHANDRAPUR-PARLI CKT-3	25-Oct-21	09:00	26-Oct-21	18:00	Continuous	1)Retrofitting of distance relay Main-1 & Main-2 and 3 ph master trip relay 86,under MTAMC project(subjected to drawing approval 2)Routine maintenance work.	MSETCL	MSETCL	400KV CHD-2 ckt no.1& 2 ,400kv khaparkheda ckt,400kv PGCIL ckt1,2,3 & 4 will be in service
88	400 KV	KOLHAPUR (TALANDGE) - ALKUD	25-Oct-21	10:00	25-Oct-21	18:00	Daily	Annual Maintenance Work	POWERGRID	MSETCL	Annual Maintenance Work
89	400 KV	TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	26-Oct-21	08:00	26-Oct-21	16:00	Daily	TIE BAY CB DCRM TESTING WORK	MSETCL	MSETCL	TIE BAY CB DCRM TESTING WORK
90	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	27-Oct-21	09:00	27-Oct-21	18:00	Daily	Bushing & widening tan delta testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
91	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	28-Oct-21	10:30	28-Oct-21	18:00	Daily	Diagnostic testing and relay testing	MSETCL	MSETCL	-
92	400 KV	JEJURI- KOYNA STAGE-IV	28-Oct-21	08:00	28-Oct-21	18:00	Daily	DT/Line Maintenance (Insulator String Replacement work).	MSETCL	MSETCL	---
93	400 KV	Tie Bay (417) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	28-Oct-21	09:00	28-Oct-21	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	417 TIE BAY ONLY
94	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	28-Oct-21	09:30	28-Oct-21	17:30	Daily	Annual Testing & Maintenance work. Also CTR fire protection system work.	MSETCL	MSETCL	400/220/33kv ICT-1 & ICT-3 will be in service.
95	400 KV	Koradi-Bhusawal	28-Oct-21	8:00	28-Oct-21	20:00	continuous	Line Maintenance work	MSETCL	MSETCL	
96	400 KV	Koradi-Nandgaonpeth (RPL)	29-Oct-21	8:00	29-Oct-21	20:00	continuous	Line Maintenance work	MSETCL	MSETCL	
97	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	30-Oct-21	08:00	30-Oct-21	18:00	Daily	For diagnostic testing and routine bay maintainance work	MSETCL	MSETCL	Nil