

Outage Planning of Transmission elements during the Duration 1.11.2017 to 30.11.2017

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
1	3	400	400 KV Lamboti-PGCIL Line @ Lamboti	01/Nov/17	8:00	01/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
2	10	765	765KV Toroda-Koradi-II	01/Nov/17	8:00	01/Nov/17	18:00	Daily	For pending construction works and OPGW striging at Power line crossing points Note: 400KV Mauda-Betul-Ckt-I, Ckt-II & 765kv Tiroda-Koradi-Ckt-I, Ckt-II S/D required on same day for attending crossing point pending works	Adani	WRTS-I	NLDC Consent is required / Subject to AMPL Tiroda / Mouda Generation / SPS at Mouda / AMPL Tiroda to be inservice/Outage my be availed when APML Generation is 1800MW Please review D/C outage is required simulteneously
3	11	765	765KV Toroda-Koradi-I	01/Nov/17	8:00	01/Nov/17	18:00	Daily	For pending construction works and OPGW striging at Power line crossing points Note: 400KV Mauda-Betul-Ckt-I, Ckt-II & 765kv Tiroda-Koradi-Ckt-I, Ckt-II S/D required on same day for attending crossing point pending works	Adani	WRTS-I	NLDC Consent is required / Subject to AMPL Tiroda / Mouda Generation / SPS at Mouda / AMPL Tiroda to be inservice/Outage my be availed when APML Generation is 1800MW Please review D/C outage is required simulteneously
4	21	400	ICT1_400/220kv_PUNE	01/Nov/17	9:00	01/Nov/17	18:00	Daily	For AMP works at Pune-Talegaon	WRTS-I	WRTS-I	
5	22	765	SWITCHABLE LR_765kv_PUNE(GIS)_SOLAPUR	01/Nov/17	9:00	01/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	If Volatge is less than 765kv
6	42	400	Kalwa - Padgha ckt - 1	01/Nov/17	8:00	15/Nov/17	18:00	Daily	For PID Testing by hot line unit (AR in Non-auto mode)	MSETCL	MSETCL	
7	43	400	400KV Karad -New Koyna ckt 1 & 2	01/Nov/17	7:00	30/Nov/17	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	
8	44	400	400KV Jejuri - Lonikand	01/Nov/17	7:00	30/Nov/17	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	
9	45	220	Pusad-Deoli(PGCIL) Line	01/Nov/17	8:00	30/Nov/17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	
10	55	400	Chandrapur 2 - Kumbhargao (Nanded) Ckt-II	01/Nov/17	6:00	15/Nov/17	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	
11	59	765	708-Bay - Tie Bay 765KV Ektuni Line-2 & 765KV Koradi-III Line-2 at Akola-II SS	02/Nov/17	8:00	02/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
12	60	400	Chandrapur II Nanded Ckt I	02/Nov/17	8:00	02/Nov/17	18:00	Daily	Damaged Conductor replacement work	MSETCL	MSETCL	
13	70	220	Badhera-Deoli(PGCIL) Line	02/Nov/17	8:00	04/Nov/17	18:00	Daily	PID testing work, shifting of auto reclose swich to non auto mode	MSETCL	MSETCL	
14	71	400	400KV Talegaon Kharghar Line	02/Nov/17	9:00	02/Nov/17	16:00	Daily	To replace the CVT ?'phase at Talegaon end	WRTS-I	WRTS-I	SLDC MSEB consent is required
15	73	765	765 kV Koradi-III Akola-II Line-2 at Koradi III SS	02/Nov/17	9:00	02/Nov/17	17:00	Daily	Line Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
16	74	400	400KV Lnknd1 -Lnkd 2 I/C Line @ Lonikand-1	02/Nov/17	9:00	02/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
17	77	400	SWITCHABLE LR_400kv_KARAD_SOLAPUR	02/Nov/17	9:00	02/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
18	96	400	Nagothane -Dabhol 1 line @Nagothane	03/Nov/17	8:00	03/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
19	98	400	400kv KOLHAPUR (GIS)-MAPUSA II	03/Nov/17	8:00	03/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
20	99	765	709-Bay - Main Bay of 765KV Koradi-III Line-2 at Akola-II SS	03/Nov/17	8:00	03/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	Already line shutdown is approved on 0211
21	103	400	Babhaleshwar-Aurangabad @BBLR	03/Nov/17	9:00	03/Nov/17	17:00	Daily	Quarterly Maintenance work & Servicing and alligrment of PG isolators work	MSETCL	MSETCL	
22	104	400	ICT-I AT BOISAR	03/Nov/17	9:00	03/Nov/17	18:00	Daily	AMP	POWERGRID	WR-II	SLDC:May be availed after comissioning of LTS at 400 KV Boisar PG Only after LTS commissioning
23	108	400	ICT2_400/200kv_AURANGABAD	03/Nov/17	9:00	03/Nov/17	18:00	Daily	for AMP works	WRTS-I	WRTS-I	
24	110	765	ICT1_765/400kv_SOLAPUR	03/Nov/17	9:00	03/Nov/17	18:00	Daily	Spare Switching Scheme Commissoing	WRTS-I	WRTS-I	
25	111	400	400KV KORADI-2 -WARDHA(PGCIL) LINE MAIN BAY 412 at Koradi-2	03/Nov/17	9:00	03/Nov/17	18:00	Daily	DCRM OF CB 412-Q52	MSETCL	MSETCL	
26	112	400	400 kv Bus 2 at Tiroda SS	03/Nov/17	9:00	03/Nov/17	21:00	Daily	Bus and Bus Connected Equipment Maintenance	APML	APML	SPS to be inservice at Tiroda
27	126	400	400 KV Main Bus -1 @ Khadka SStn	04/Nov/17	8:00	04/Nov/17	17:00	Daily	For replacement of PG isolator of 400/132 kv 315 MVA ICT-III (ICT-III should be shifted on TBC)	MSETCL	MSETCL	
28	127	400	Nagothane -Dabhol 2 line @Nagothane	04/Nov/17	8:00	04/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
29	134	400	400KV SOLAPUR-KOLHAPUR#2 WITH LR	04/Nov/17	9:00	04/Nov/17	18:00	Daily	AMP 17-18	MSETCL	WRTS-I	
30	136	765	702-Bay - Tie Bay of ICT-1 & Future bay at Koradi III SS	04/Nov/17	9:00	04/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
31	139	500	HVDC POLE-1 (C'pur-Padghe Link)	04/Nov/17	8:00	09/Nov/17	18:00	Continuous	Annual Maintenance of HVDC Outdoor/Indoor equipment, Line maintenance, Diagnostic testing etc	MSETCL	MSETCL	Please explore availing outage during night hours on daily basis Informed that Maintainance can't be carried in night hours
32	144	400	400KV Talegaon Chakan Line	05/Nov/17	9:00	05/Nov/17	16:00	Daily	To attend the conductor unwinding problem at Line Side (Gantry) 'R' & ?'phase at Talegaon	WRTS-I	WRTS-I	400KV Talegaon- Lonikand Line is sensitive to outage on Talegaon Chakan May be availed on Sunday
33	148	400	400 KV BUS-2 at Talegaon	05/Nov/17	9:00	05/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	May be availed along with 400KV Talegaon Chakan line on Sunday 05112017
34	156	765	765KV Bus Bar-1 at Akola-II SS	05/Nov/17	8:00	05/Nov/17	18:00	Daily	Bus Equipments Maintenance Activity	MEGPTCL	MEGPTCL	May be availed on Sunday 05112017 It is Bus outage
35	161	400	BC@ Kalwa	06/Nov/17	13:30	06/Nov/17	15:30	Daily	For connecting CT ciurit to New 400KV Numerical Bus-Bar Relay for commissioning of 400KV Numerical Bus-Bar Protection	MSETCL	MSETCL	

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
36	162	400	Padgha-I @ Kalwa	06/Nov/17	16:30	06/Nov/17	18:00	Daily	For connecting CT circuit to New 400kV Numerical Bus-Bar Relay for commissioning of 400kV Numerical Bus-Bar Protection	MSETCL	MSETCL	
37	168	400	Dabhol-Nagonathane Ckt 1 Line@Dabhol	06/Nov/17	8:00	06/Nov/17	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL	
38	173	400	Akola - Wardha Line Ckt-2 with bay 411 & 412 at Akola	06/Nov/17	9:00	06/Nov/17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
39	175	400	400KV SOLAPUR-KOLHAPUR#1 WITH LR (400 KV Solapur-Alkud)	06/Nov/17	9:00	06/Nov/17	18:00	Daily	AMP 17-18	MSETCL	WRTS-I	
40	176	765	765kV WARDHA - AURANGABAD(PG) IV	06/Nov/17	9:00	06/Nov/17	18:00	Daily	For construction of new wardha 1200/400kV stringing works	WRTS-I	WRTS-I	
41	177	400	400KV ICT-1 & Future Tie Bay (402) at Aurangabad	06/Nov/17	9:00	06/Nov/17	18:00	Daily	for AMP works	WRTS-I	WRTS-I	
42	179	765	ICT1_765/400kv_PUNE(GIS)	06/Nov/17	9:00	06/Nov/17	18:00	Daily	For commissioning and fine tuning of CSD	WRTS-I	WRTS-I	
43	194	220	TAPS-3&4 to Boisar	06/Nov/17	9:00	07/Nov/17	18:00	Continuous	For maintenance of its elements	POWERGRID	NPCIL	
44	201	400	400 KV Akola- Bhusawal Line	06/Nov/17	12:00	08/Nov/17	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola A/R shall be kept in non auto mode	MSETCL	MSETCL	
45	204	400	Dhule-SSNNL Ckt-1 @ Dhule	06/Nov/17	8:00	11/Nov/17	18:00	Daily	Repalcement of disc insulator by using porcelain long rod insulator	MSETCL	MSETCL	
46	206	400	Nagothane -Dabhol 1 line @Nagothane	06/Nov/17	8:00	06/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
47	214	765	765kV S/C,Aurangabad -Dhule Line	07/Nov/17	8:00	07/Nov/17	18:00	Daily	Annual maintenance of the Line	BDTCL	BDTCL	
48	228	765	SWITCHABLE LR_765KV_RAICHUR 1_SOLAPUR	07/Nov/17	9:00	07/Nov/17	18:00	Daily	COMMISSIONING OF SPARE SELECTION SCHEME	WRTS-I	WRTS-I	NLDC consent is required
49	229	765	765kV WARDHA - AURANGABAD(PG) III	07/Nov/17	9:00	07/Nov/17	18:00	Daily	For construction of new wardha 1200/400kV stringing works	WRTS-I	WRTS-I	NLDC consent is required
50	230	400	400KV ICT-2 Main Bay(404) at Aurangabad	07/Nov/17	9:00	07/Nov/17	18:00	Daily	for AMP works	WRTS-I	WRTS-I	
51	231	765	ICT2_765/400kv_PUNE(GIS)	07/Nov/17	9:00	07/Nov/17	18:00	Daily	For commissioning and fine tuning of CSDs and AMP works	WRTS-I	WRTS-I	
52	232	765	711- Tie Bay of Tiroda Line 1 and Akola Line 2 at Koradi III SS	07/Nov/17	9:00	07/Nov/17	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
53	245	400	SSP - Dhule -1	07/Nov/17	8:00	08/Nov/17	22:00	Continuous	Relay testing , New relay Retrofitting CVT Testing and Energy meter testing	SSP	NCA	
54	249	400	Dabhol-Nagonathane Ckt 2 @Dabhol	07/Nov/17	8:00	14/Nov/17	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL	
55	250	400	Nagothane -Dabhol 2 line @Nagothane	07/Nov/17	8:00	07/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
56	253	400	765/400KV ICT#3 & 400kv Raipur#2 Tie bay(411) at wardha	08/Nov/17	9:00	08/Nov/17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	
57	264	765	765kV Bus Bar-2 at Akola-II SS	08/Nov/17	8:00	08/Nov/17	18:00	Daily	Bus Equipments Maintenance Activity	MEGPTCL	MEGPTCL	NLDC consent is required
58	265	400/220	501MVA, ICT 2 @Lamboti	08/Nov/17	8:00	08/Nov/17	18:00	Daily	Maintenance work& Dignostic testing work	MSETCL	MSETCL	Load to be mananged by SLDC MSEB
59	271	400	Bus Coupler @ BBLR	08/Nov/17	9:00	08/Nov/17	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
60	276	765	765kV WARDHA - AURANGABAD(PG) I	08/Nov/17	9:00	08/Nov/17	18:00	Daily	For construction of new wardha 1200/400kV stringing works	WRTS-I	WRTS-I	
61	277	400	765/400KV ICT-1 Main Bay (428) at Aurangabad	08/Nov/17	9:00	08/Nov/17	18:00	Daily	for AMP works	WRTS-I	WRTS-I	
62	279	765	BUS REACTOR_765KV_240MVAR_PUNE(GIS)	08/Nov/17	9:00	08/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
63	280	765	ICT2_765/400kv_WARDHA	08/Nov/17	9:00	08/Nov/17	18:00	Daily	Spare Switching Scheme Commissioing	WRTS-I	WRTS-I	
64	288	400	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) I	08/Nov/17	10:00	08/Nov/17	18:00	Daily	For Line and main bay AMP works	WRTS-I	WRTS-I	
65	295	220	220KV Bus # 2 at Talegaon	09/Nov/17	9:00	09/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	May be availed on Thursday 0911207
66	298	765	765kV A'bad# 2 Main Bay (713) at Wardha	09/Nov/17	9:00	13/Nov/17	18:00	Continuous	MOM Box replacement of Main Bay CB - 713-52	WRTS-I	WRTS-I	
67	304	400	Girwali- PGCIL ckt-2 @ Girwali	09/Nov/17	9:00	09/Nov/17	18:00	Daily	CVT Tan Delta Measurement & CB DCRM testing work	MSETCL	MSETCL	
68	311	400	400KV BHADRAVATI-CHANDRAPUR IV	09/Nov/17	8:00	09/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
69	312	220	Badnera-Deoli(PGCIL) Line	09/Nov/17	8:00	11/Nov/17	18:00	Daily	PID testing work, shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	
70	316	765	707LR- Tiroda Line 2 Reactor at Koradi-III SS (Switchable)	09/Nov/17	9:00	09/Nov/17	16:00	Daily	Reactor Maintenance Activity	MEGPTCL	MEGPTCL	
71	323	765	765kV WARDHA - AJURANGABAD(PG) II	09/Nov/17	9:00	09/Nov/17	18:00	Daily	For construction of new wardha 1200/400kV stringing works	WRTS-I	WRTS-I	
72	324	400	765/400KV ICT-1 & Future Tie Bay(429) at Aurangabad	09/Nov/17	9:00	09/Nov/17	18:00	Daily	for AMP works	WRTS-I	WRTS-I	
73	325	400	ICT2_400/220kv_PUNE	09/Nov/17	9:00	09/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	
74	337	400	400KV HVDC ckt No-I Bay @400KV S/S Chandrapur	09/Nov/17	8:00	10/Nov/17	18:00	Daily	1) For attending the Hot spot 2) Routine maintenance of the bay	MSETCL	MSETCL	Restiction on HVDC flow informed that restriction on HVDC
75	351	400	koradi-satpura # 1	10/Nov/17	6:00	10/Nov/17	18:00	Daily	STRINGING WORK OF POWER LINE X-ING SECTION OF 765KV GADARWARA-WARORA T/L	POWERGRID	WR-II	
76	353	400	Tie bay 412 (Chandrapur 2 ckt 1 -Tirora Ckt 1) @Warora	10/Nov/17	8:00	10/Nov/17	17:00	Daily	Routine bay maintanance	MSETCL	MSETCL	

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
77	361	400	400KV BHADRAVATI-CHANDRAPUR III	10/Nov/17	8:00	10/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
78	362	765	701-Bay - Main Bay of ICT HV Side at Akola-II SS	10/Nov/17	8:00	10/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
79	372	220	220kv Pandurna-Kalmeshwar at 220KV S/s Pandhurna	10/Nov/17	9:00	10/Nov/17	18:00	Daily	Post moonson line maintenance work	MPPTCL	MPPTCL	
80	376	400	400KV Shikrapur GIS-4 main bay (410) at Talegaon	10/Nov/17	9:00	10/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	
81	382	220	220kv Mudshingi-Chikodi	10/Nov/17	10:00	10/Nov/17	15:00	Daily	Annual Maintenance of bays equipment & Dignostic testing	MSETCL	MSETCL	NLDC consent is required
82	384	400	409 (Tie Bay of Wardha ckt 1 & Bhusawal ckt) at Akola	10/Nov/17	10:00	10/Nov/17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
83	392	400	400kv Bus-1 at Aurangabad	10/Nov/17	9:00	11/Nov/17	18:00	Continuous	for Statcom jumpering works and stability test	WRTS-I	WRTS-I	
84	393	220	TAPS1&2 -Borivali	10/Nov/17	8:00	14/Nov/17	19:00	Daily	Annual maintenance Works	MSETCL	NPCIL	
85	396	400	400KV Pune-1 Main Bay (403) at Parli	11/Nov/17	10:00	11/Nov/17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	
86	398	400	400 KVBhadravati-1 Main Bay (407) at Parli	11/Nov/17	10:00	11/Nov/17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	approved along with line outage
87	399	400	Main Bay (406) of Line-3 at Koradi III Sub Station	11/Nov/17	9:00	11/Nov/17	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
88	407	765	765KV ICT2 & Solapur Line Tie bay (802Q0C) at Pune-GIS	11/Nov/17	9:00	11/Nov/17	13:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
89	410	400	Babhaleshwar-Padghe-Ckt-2 @BBLR	11/Nov/17	9:00	11/Nov/17	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
90	413	400	400KV/220KV ICT#1 Main Bay (410) at Solapur	11/Nov/17	9:00	11/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
91	414	400	400KV Lonikand Line & Bus Reactor Tie bay (414) at Talegaon	11/Nov/17	9:00	11/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	
92	415	765	SWITCHABLE LR_765KV_A'BAD 4_WARDHA	11/Nov/17	9:00	11/Nov/17	18:00	Daily	Spare Switching Scheme Commissioning	WRTS-I	WRTS-I	
93	427	400	400KV BHADRAVATI-PARLI- I & 400KV DHARIWAL TPP-PARLI- II	11/Nov/17	7:00	12/Nov/17	18:00	Daily	Construction work of 765 kV Warora - Parli Transmission Line Ckt I & Ckt II	WRTS-I	WRTS-I	
94	430	400	400 KV BUS-1 at Talegaon	12/Nov/17	9:00	12/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	May be availed on Sunday 12112017
95	434	400	SSP - Dhule -2	12/Nov/17	8:00	13/Nov/17	22:00	Continuous	Relay testing , New relay Retrofitting CVT Testing and Energy meter testing	SSP	NCA	
96	435	765	765 KV Bus 2 at Tiroda SS	12/Nov/17	9:00	12/Nov/17	21:00	Daily	Bus and Bus Connected Equipment Maintenance	MEGPTCL	MEGPTCL	APML Generation level to be reviewed prior to this outage Outage to be availed on Sunday 12112017
97	442	765	765KV PUNE(GIS)-SOLAPUR	13/Nov/17	9:00	13/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
98	444	400	Padgha II @Kalwa	13/Nov/17	6:00	13/Nov/17	19:00	Daily	Complete replacement of 29 D isolator and its alignment ,O/H of 29 C IsolatorRoutine Maintenance & testing work/For connecting CT circuit to New 400kV Numerical Bus-Bar Relay for commissioning of 400kV Numerical Bus-Bar Protection	MSETCL	MSETCL	
99	451	765	707LR- 765KV Ektuni Line-2- Line Reactor at Akola-II SS	13/Nov/17	8:00	13/Nov/17	15:00	Daily	Reactor Bay & Reactor Maintenance Activity	MEGPTCL	MEGPTCL	
100	457	220	Bay no-210 future bay AT BOISAR	13/Nov/17	9:00	13/Nov/17	17:00	Daily	AMP	POWERGRID	WR-II	
101	461	400	Akola- Aurgabad Line Ckt-1 with bay 403 & 404 at Akola	13/Nov/17	9:00	13/Nov/17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
102	463	400	400KV/220KV ICT#1 & 400KV LAMBOTI Tie Bay (411) at Solapur	13/Nov/17	9:00	13/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
103	466	220	Badnera-PGCIL @ Badnera S/Stn	13/Nov/17	9:00	13/Nov/17	18:00	Daily	Annual Maintanance & CT Replacement	MSETCL	MSETCL	
104	473	765	765kv Solapur Line Main bay (802Q0B) at Pune-GIS	13/Nov/17	14:00	13/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
105	475	400	400kv Bus-2 at Aurangabad	13/Nov/17	9:00	14/Nov/17	18:00	Continuous	for Statcom jumpering works and stability test	WRTS-I	WRTS-I	
106	479	400	Dhule-SSNNL Ckt-2 @ Dhule	13/Nov/17	8:00	18/Nov/17	18:00	Daily	Repalcement of disc insulator by using porcelain long rod insulator	MSETCL	MSETCL	
107	482	765	765kv Solapur Line Reactor bay (802Q0D) at Pune-GIS	13/Nov/17	9:00	13/Nov/17	13:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
108	483	400	400KV D/C Nanded-Parli Ckt-1&2	13/Nov/17	9:00	14/Nov/17	17:00	Continuous	For Construction of 765KV D/C Warora-Parli TL (Part-III)	MSETCL	WRTS-I	
109	488	400	400kv Talegaon @ Kalwa	14/Nov/17	13:30	14/Nov/17	15:30	Daily	For connecting CT circuit to New 400kV Numerical Bus-Bar Relay for commissioning of 400kV Numerical Bus-Bar Protection	MSETCL	MSETCL	
110	489	400	400kv Kharghar @ Kalwa	14/Nov/17	16:30	14/Nov/17	18:00	Daily	For connecting CT circuit to New 400kV Numerical Bus-Bar Relay for commissioning of 400kV Numerical Bus-Bar Protection	MSETCL	MSETCL	
111	491	765	SWITCHABLE LR_765KV_A'BAD 2_WARDHA	14/Nov/17	9:00	15/Nov/17	18:00	Continuous	Spare Switching Scheme Commissioning	WRTS-I	WRTS-I	
112	492	400	Main Bay (412) of400KV Line-1 of Koradi II - Kordadi III at Koradi III Sub Station	14/Nov/17	9:00	14/Nov/17	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
113	493	400	400 KV Khadka-Koradi	14/Nov/17	6:00	14/Nov/17	17:00	Daily	On Line PID by EHC (O&M) Circle.BSL	MSETCL	MSETCL	
114	504	220	Bay No-211 Boisar-Boisar -II AT BOISAR	14/Nov/17	9:00	14/Nov/17	17:00	Daily	AMP	POWERGRID	WR-II	line to be inservice through Tie bay
115	508	400	765/400KV ICT#1 Main bay (422) 400kV side at Solapur	14/Nov/17	9:00	14/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
116	515	400	400kV/KOLHAPUR (MSETCL)-I & FUTURE TIE BAY (408) at Kolhapur-GIS	14/Nov/17	10:00	14/Nov/17	18:00	Daily	For bay AMP works	WRTS-I	WRTS-I	
117	516	400	400kV Bhadravati-1 & Solapur-1 Tie Bay (408) at Parli	14/Nov/17	10:00	14/Nov/17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	
118	517	400	400kV Thapti-Tanda Ckt-II (401) Bay @ 765 kV Ektuni S/s	14/Nov/17	10:00	14/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
119	522	400	400 KV A bus Outage @Kalwa	15/Nov/17	7:00	19/Nov/17	20:00	Continuous	O/H of 29 A isolators of ICT I,B/C,ICT II, TBC,,Pad I,Kharghar Talegaon,Total -7 Nos Isolators Pad II 29 A isolator replacement	MSETCL	MSETCL	Contingency plans to be furnished by MSEB in case of N-1 before availing the outage
120	528	220	Pusad- Devalli @220KV Pusad S/Stn	15/Nov/17	8:00	15/Nov/17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
121	531	400	404 Bay - Main Bay of ICT LV Side at Akola-II SS	15/Nov/17	8:00	15/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
122	538	400	765/400KV ICT#1 & NTPC-2 Tie Bay (423) at Solapur	15/Nov/17	9:00	15/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
123	541	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_3	15/Nov/17	9:00	15/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
124	542	400	400kV Akola#2 & 50MVARs BR Tie bay (417) at wardha	15/Nov/17	9:00	15/Nov/17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	
125	543	400	Talandge - Alkud @ Talandge	15/Nov/17	9:00	15/Nov/17	18:00	Daily	Quarterly MaintWork	PGCIL	PGCIL	
126	544	400	408-Bay (Tie Bay of GCR Line-2 and Dhariwal Line-1) @ 400KV Chandrapur-2 Substation	15/Nov/17	9:00	15/Nov/17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
127	548	400	400KV SOLAPUR PGCIL @ Karad & Lamboti	15/Nov/17	10:00	15/Nov/17	17:00	Daily	Quarterly Maint At Karad And line maint Work by Lamboti	MSETCL	MSETCL	
128	550	400	400kV TIE-I bay (402 Bay) of 400KV Thapti-Tanda Ckt-II @ 765 kV Ektuni S/s	15/Nov/17	10:00	15/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
129	553	400	400kV RAIPUR-WARDHA I	15/Nov/17	7:00	16/Nov/17	18:00	Daily	Power Line Crossing of 765KV D/C Gadawara - Warora Tr Line between Tower No 155/0 & 156/0 (Existing 400kV D/C PGCIL Line Tower Nos 871 & 872)	WRTS-I	WRTS-I	
130	554	400	400kV RAIPUR-WARDHA II	15/Nov/17	7:00	16/Nov/17	18:00	Daily	Power Line Crossing of 765KV D/C Gadawara - Warora Tr Line between Tower No 155/0 & 156/0 (Existing 400kV D/C PGCIL Line Tower Nos 871 & 872)	WRTS-I	WRTS-I	
131	557	220	TAPS 1&2- Boisar	15/Nov/17	8:00	17/Nov/17	19:00	Daily	Annual maintenance Works	MSETCL	NPCIL	
132	560	400	New Koyna -Dabhol Ckt 2@Dabhol	15/Nov/17	8:00	19/Nov/17	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL	
133	561	400	400KV BHADRAVATI-PARLI I	15/Nov/17	8:00	17/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
134	563	400	400KV WARDHA-PARLI-I	16/Nov/17	6:00	30/Nov/17	18:00	Daily	Online OPGW work A/R to be kept in Non auto mode	WRTS-I	WRTS-I	
135	565	220	220KV Bus # 1 at Talegaon	16/Nov/17	9:00	16/Nov/17	18:00	Daily	For AMP works	WRTS-I	WRTS-I	May be availed on Thursday 1611207
136	578	400	400KV BUS-I At Koradi-III SS	16/Nov/17	8:00	16/Nov/17	18:00	Daily	BUS Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
137	579	220	Badhera-Deoli(PGCIL) Line	16/Nov/17	8:00	16/Nov/17	18:00	Daily	PID testing work, shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	
138	585	400	765/400KV ICT#2 Main Bay (428) at Solapur	16/Nov/17	9:00	16/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
139	586	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_4	16/Nov/17	9:00	16/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
140	587	400	Talandge - Solapur @ Talandge	16/Nov/17	9:00	16/Nov/17	18:00	Daily	Quarterly MaintWork	PGCIL	PGCIL	
141	588	400	400 kV Lonikand-II to Parali ckt- I bay No 412 and 413	16/Nov/17	9:00	16/Nov/17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
142	589	400	400 kV Bus 1 at Tiroda SS	16/Nov/17	9:00	16/Nov/17	21:00	Daily	Bus and Bus Connected Equipment Maintenance	APML	APML	
143	595	400	Thapti-Tanda ckt-I (404) Bay @ 765 kV Ektuni S/s	16/Nov/17	10:00	16/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
144	605	400	Kalwa - Padgha ckt - 2	16/Nov/17	8:00	30/Nov/17	18:00	Daily	For PID Testing by hot line unit (AR in Non-auto mode)	MSETCL	MSETCL	
145	606	400	Ramagundam- Chandrapur-1	16/Nov/17	6:00	16/Nov/17	20:00	Daily	Re-Routing of Line as per request of Singareni Collieries The line shall be shifted to ERS for 01 Month and shall make arrangements to carry 500 MW on continuous basis	POWERGRID	POWERGRID	Will be clubbed along with Pole-1 shutdown of BVT
146	616	400	413 Main Bay of 400 KV Chandrapur Ckt No 1@ Warora	17/Nov/17	8:00	17/Nov/17	17:00	Daily	Routine bay maintenance	MSETCL	MSETCL	
147	619	400	405 Bay - Tie Bay of ICT LV Side and Future Bay at Akola-II SS	17/Nov/17	8:00	17/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
148	620	220	Badhera-Deoli(PGCIL) Line	17/Nov/17	8:00	18/Nov/17	18:00	Daily	PID testing work, shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	
149	628	400	765/400KV ICT#2 & NTPC#4 Tie Bay (429) at Solapur	17/Nov/17	9:00	17/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
150	631	400	400kv PARLI-PUNE(GIS)_1	17/Nov/17	9:00	17/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
151	632	765	765kV Padghe-1 LR with Main & Tie Bays at Abad	17/Nov/17	9:00	17/Nov/17	18:00	Daily	PLCC commissioning and line charging works	WRTS-I	WRTS-I	
152	638	400	400kV KOLHAPUR (MSETCL)-II & BR Tie BAY (411) at Kolhapur-GIS	17/Nov/17	10:00	17/Nov/17	18:00	Daily	For bay AMP works	WRTS-I	WRTS-I	
153	639	400	400KV Dhariwal Main Bay (410) at Parli	17/Nov/17	10:00	17/Nov/17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	
154	641	400	400kV TIE-II bay (405 Bay) of 400KV Thapti-Tanda Ckt-I @ 765 kV Ektuni S/s	17/Nov/17	10:00	17/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
155	649	400	Ramagundam- Chandrapur-2	17/Nov/17	6:00	17/Nov/17	20:00	Daily	Re-Routing of Line as per request of Singareni Collieries The line shall be shifted to ERS for 01 Month and shall make arrangements to carry 500 MW on continuous basis	POWERGRID	POWERGRID	

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
156	654	400	400KV DHARIWAL TPP-PARLI II	18/Nov/17	8:00	20/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
157	660	400	400KV BUS REACTOR1 Main Bay (401) at Solapur	18/Nov/17	9:00	18/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
158	661	765	765KV Padghe-2 LR with Main & Tie Bays at Abad	18/Nov/17	9:00	18/Nov/17	18:00	Daily	PLCC commissioning and line charging works	WRTS-I	WRTS-I	
159	662	400	400kv PARLI-PUNE(GIS)_2	18/Nov/17	9:00	18/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
160	663	400	403 Bay - Main Bay of Line 4 at Koradi-III SS	18/Nov/17	9:00	18/Nov/17	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
161	669	220	TAPS 1&2- TAPP 3&4 tie line	18/Nov/17	8:00	20/Nov/17	19:00	Daily	Annual maintenance Works	MSETCL	NPCIL	
162	670	765	765KV A'bad# 1 Line Reactor (716) at Wardha	18/Nov/17	9:00	21/Nov/17	18:00	Continuous	MOM Box replacement of Reactor CB716-52R	WRTS-I	WRTS-I	
163	674	400	400KV AURANGABAD(PG)-AURANGABAD(MSETCL) I	18/Nov/17	9:00	18/Nov/17	18:00	Daily	CT drop jumper replacement at Msetcl, waluj SS	WRTS-I	WRTS-I	To be availed on 18112017 (Saturday instead of Monday)
164	675	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) I	18/Nov/17	9:00	18/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	To be availed on 18112017 (Saturday instead of Monday)
165	683	400	Chandrapur (Old GCR)-Parli ckt-III@Girwali	20/Nov/17	9:00	20/Nov/17	16:00	Daily	For tightening of earthwire clamp hardware at loc No911, 908	MSETCL	MSETCL	
166	684	400	400 KV B Bus Outage @ Kalwa	20/Nov/17	6:00	25/Nov/17	19:00	Continuous	O/H of 29 B isolators of ICT I,B/C,ICT II, TBC, Pad II, Pad I, Talegaon,Total -7 Nos Isolators Kharghar -29 B isolator replacement	MSETCL	MSETCL	
167	685	400	Padgha I @ Kalwa	20/Nov/17	6:00	20/Nov/17	17:00	Daily	O/H of 29 D and 29 C isolator Routine Maintenance & testing work	MSETCL	MSETCL	
168	687	220	220 KV PGCIL(DEOLI) - BHUGAON LINE	20/Nov/17	8:00	20/Nov/17	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
169	693	400	400KV BUS REACTOR1 & FUTURE Tie Bay (402) at Solapur	20/Nov/17	9:00	20/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
170	694	765	765 kv Wardha-1 Main bay (715) at Durg PS	20/Nov/17	9:00	20/Nov/17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	
171	695	400	400/220kV ICT#2 Main Bay (424) at wardha	20/Nov/17	9:00	20/Nov/17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	
172	702	400	410 (Main Bay of Bhusawal Ckt) at Akola	20/Nov/17	10:00	20/Nov/17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
173	714	400	400 KV Khadka- Aurangabad Line	20/Nov/17	6:00	22/Nov/17	17:00	Daily	On Line PID by EHC (O&M) Circle,BSL/PID testing of insulator strings by Hot line Uint Akola A/R shall be kept in non auto mode	MSETCL	MSETCL	
174	722	400	400KV S/C Chandrapur-Parli Ckt-III	20/Nov/17	9:00	21/Nov/17	18:00	Continuous	For Construction of 765KV D/C Warora-Parli TL (Part-III)	MSETCL	WRTS-I	
175	724	400	ICT1_400/200kv_AURANGABAD	21/Nov/17	9:00	21/Nov/17	18:00	Daily	for AMP works	WRTS-I	WRTS-I	
176	727	220	220 KV PGCIL(DEOLI) - BHUGAON LINE	21/Nov/17	8:00	21/Nov/17	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
177	728	400	Future ckt II (420), 400KV Tie bay (421) & 400 KV PGCIL Wardha Ckt (bay 422) @ Warora	21/Nov/17	8:00	21/Nov/17	17:00	Daily	Rotuine bay maintenance	MSETCL	MSETCL	
178	732	220	220KV Urse Line # 1 Main bay (203) at Talegaon	21/Nov/17	9:00	21/Nov/17	16:00	Daily	For AMP works	WRTS-I	WRTS-I	
179	735	765	765KV ICT#1 Main Bay (703) at Solapur	21/Nov/17	9:00	21/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
180	736	400	400kv AURANGABAD(PG)-AURANGABAD(MSETCL) II	21/Nov/17	9:00	21/Nov/17	18:00	Daily	CT drop jumper replacement at Msetcl, waluj SS	WRTS-I	WRTS-I	
181	737	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) II	21/Nov/17	9:00	21/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
182	738	400	405 Bay - Tie Bay of ICT LV Side and Line 3 at Koradi-III SS	21/Nov/17	9:00	21/Nov/17	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
183	745	400	400KV Dhariwal & Solapur-2 Tie Bay (411) at Parli	21/Nov/17	10:00	21/Nov/17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	
184	747	400	400KV Bhambaleswar Ckt-II (408) Bay @ 765 kV Ektuni S/s	21/Nov/17	10:00	21/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
185	756	400	400KV BHADRAVATI-PARLI I	21/Nov/17	7:00	22/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
186	763	400	Chandrapur 2 - Warora Ckt-2	22/Nov/17	8:00	22/Nov/17	17:00	Daily	Diagnostic Testing	MSETCL	MSETCL	
187	765	400	407 Bay - Main Bay of 400KV RPL Line - 1 at Akola-II SS	22/Nov/17	8:00	22/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
188	766	400	400KV Kolhapur Line Main bay (407) @ Alkud	22/Nov/17	9:00	22/Nov/17	12:00	Daily	Quarterly Maint Work	MSETCL	MSETCL	
189	768	220	220KV Chakan Line # 1 Main bay (210) at Talegaon	22/Nov/17	9:00	22/Nov/17	16:00	Daily	For AMP works	WRTS-I	WRTS-I	
190	771	765	765KV ICT#1 & Future Tie Bay (702) at Solapur	22/Nov/17	9:00	22/Nov/17	18:00	Daily	ERECTION OF PARLI MAIN BAY EQUIPMENT AND AMP 17-18	WRTS-I	WRTS-I	
191	773	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_1	22/Nov/17	9:00	22/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
192	782	400	400KV TIE-III bay (409 Bay) of 400kv Bhambaleswar Ckt-I @ 765 kV Ektuni S/s	22/Nov/17	10:00	22/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
193	783	400	400KV Kolhapur Line Tie bay (408) @ Alkud	22/Nov/17	13:30	22/Nov/17	16:30	Daily	Quarterly Maint Work	MSETCL	MSETCL	
194	786	400	400KV WARDHA-MAUDA I	22/Nov/17	7:00	23/Nov/17	18:00	Daily	Power Line Crossing of 765KV D/C Gadawara - Warora Tr Line between Tower No 152/0 & 153/0 (Existing 400KV D/C PGCIL Line Tower Nos 209 & 210)	WRTS-I	WRTS-I	Generation Restriction at NTPC Mouda Required

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
195	787	400	400KV WARDHA-MAUDA II	22/Nov/17	7:00	23/Nov/17	18:00	Daily	Power Line Crossing of 765KV D/C Gadanwara - Warora Tr Line between Tower No 152/0 & 153/0 (Existing 400KV D/C PGCIL Line Tower Nos 209 & 210)	WRTS-I	WRTS-I	Genereneration Restriction at NTPC Mouda Required
196	788	400	400KV Aurangabad-Pune-2 LR at Waluz	22/Nov/17	8:00	30/Nov/17	18:00	Continuous	For internal inspection proposed by CGL, Mumbai to attend bridging of Frame-body	WRTS-I	WRTS-I	
197	794	400	400KV DHARIWAL TPP-PARLI II	23/Nov/17	8:00	24/Nov/17	18:00	Daily	Replacement of Porcelain insulators with Polymer	WRTS-I	WRTS-I	
198	805	220	220 KV PGCIL(DEOLI) - PUSAD LINE	23/Nov/17	8:00	23/Nov/17	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
199	806	400	400KV Solapur Line Main bay (407) @ Alkud	23/Nov/17	9:00	23/Nov/17	12:00	Daily	Quarterly Maint Work	MSETCL	MSETCL	
200	810	765	765KV ICT2 & Future Tie Bay (705) at Solapur	23/Nov/17	9:00	23/Nov/17	18:00	Daily	ERECTION OF PARLI MAIN BAY EQUIPMENT AND AMP 17-18	WRTS-I	WRTS-I	
201	811	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_2	23/Nov/17	9:00	23/Nov/17	18:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
202	812	220	220KV Wardha-Wardha Bay (206) at Wardha	23/Nov/17	9:00	23/Nov/17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	
203	813	400	408 Bay - Tie Bay of 400KV Line 2 of Koradi-III koradi-II at Koradi-III SS	23/Nov/17	9:00	23/Nov/17	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	
204	819	400	400kv Bhabaleshwar Ckt-I (411) Bay @ 765 KV Ektuni S/s	23/Nov/17	10:00	23/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
205	820	400	400KV Solapur Line Tie bay (408) @ Alkud	23/Nov/17	13:30	23/Nov/17	16:30	Daily	Quarterly Maint Work	MSETCL	MSETCL	
206	829	400	400 KV Bus-1 at Wardha	24/Nov/17	9:00	24/Nov/17	18:00	Daily	Bus Extention work of Aurangabad extention work	WRTS-I	WRTS-I	
207	832	400	Kharghar @ Kalwa	24/Nov/17	6:00	24/Nov/17	18:00	Daily	29 C and 29 D with Earth isolator O/H work Routine Maintenance & testing work	MSETCL	MSETCL	
208	839	220	220 KV PGCIL(DEOLI) - PUSAD LINE	24/Nov/17	8:00	24/Nov/17	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
209	841	400	408 Bay- Tie Bay of 400KV RPL Line-1 and Akola-1 Line- 1 at Akola-II SS	24/Nov/17	8:00	24/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
210	843	400	400kv PUNE(GIS) 405 Bus Coupler	24/Nov/17	9:00	24/Nov/17	13:00	Daily	For NTAMC project integration for improvement of grid smoothly operation and control works	WRTS-I	WRTS-I	
211	844	400	ICT-III AT BOISAR	24/Nov/17	9:00	24/Nov/17	18:00	Daily	AMP	POWERGRID	WR-II	
212	848	765	765KV ICT#2 Main Bay (706) at Solapur	24/Nov/17	9:00	24/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
213	853	400	411 (Main Bay Wardha ckt -2) at Akola	24/Nov/17	10:00	24/Nov/17	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
214	856	400	400KV TIE-IV bay (412 Bay) of 400KV Bhabaleshwar Ckt-I @ 765 kv Ektuni S/s	24/Nov/17	10:00	24/Nov/17	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
215	866	400	400kv Bus Coupler @ Girwali	25/Nov/17	9:00	25/Nov/17	18:00	Daily	CT Tan Delta Measurement & CB DCRM & Timing work	MSETCL	MSETCL	
216	868	400	409 Bay- Main Bay of 400KV Akola-I at Akola-II SS	25/Nov/17	8:00	25/Nov/17	14:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
217	870	765	765KV PUNE Main Bay (712) at Soalpur	25/Nov/17	9:00	25/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
218	871	400	765/400KV ICT#1 & 400kv Parli#1 Tie bay(405) at wardha	25/Nov/17	9:00	25/Nov/17	18:00	Daily	AMP of Bay	WRTS-I	WRTS-I	
219	876	400	Talegaon @ Kalwa	25/Nov/17	6:00	25/Nov/17	18:00	Daily	29 C and 29 D with Earth isolator O/H work Routine Maintenance & testing work	MSETCL	MSETCL	
220	877	400	400KV BHADRAVATI-PARLI I	25/Nov/17	7:00	26/Nov/17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, NH, SH, Railway Crossings for public safety AR in Non Auto Mode for other ckt will be required during above period	WRTS-I	WRTS-I	
221	878	500	HVDC POLE-2 (C'pur-Padghe Link)	26/Nov/17	8:00	30/Nov/17	18:00	Continuous	Annual Maintenance of HVDC Outdoor/Indoor equipment, Line maintenance, Diagnostic testing etc	MSETCL	MSETCL	
222	881	500	500 kv HVDC Chandrapur - Padghe Transmission Line	27/Nov/17	6:00	29/Nov/17	18:00	Daily	Construction work of 765 kv D/C Warora - Parli Transmission Line Ckt I & Ckt II	MSETCL	WRTS-I	To be combined with bipole outage on 25112017 and 26112017
223	882	500	HVDC POLE- 1& POLE-2 BI-POLE (C'pur-Padghe Link)	27/Nov/17	18:00	29/Nov/17	18:00	Continuous	Annual Maintenance of DC yard equipment,33KV electorde station, smoke trials of valve hall,DG set on load trials, Diagnostic testing etc	MSETCL	MSETCL	
224	886	400	400 KV Khadka- Babhaleshwar Line	27/Nov/17	6:00	27/Nov/17	17:00	Daily	On Line PID by EHC (O&M) Circle,BSL	MSETCL	MSETCL	
225	887	400	410 Bay-Main Bay of 400KV RPL Line - 2 at Akola-II SS	27/Nov/17	8:00	27/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
226	898	400	KORADI-BHUSAWAL	27/Nov/17	8:00	28/Nov/17	17:00	Continuous	restringing of conductors between location no5-6 and 111-112, for increasing the low grond clearances	MSETCL	MSETCL	
227	908	765	704AT - 765/400KV ICT 2 at Koradi-III SS	28/Nov/17	8:00	28/Nov/17	18:00	Daily	ICT Mainteance Activity	MEGPTCL	MEGPTCL	
228	912	765	765KV BUS REACTOR Main Bay (718) at Soalpur	28/Nov/17	9:00	28/Nov/17	18:00	Daily	AMP 17-18	WRTS-I	WRTS-I	
229	913	765	ICT3_765/400kv_WARDHA	28/Nov/17	9:00	28/Nov/17	18:00	Daily	AMP of ICT	WRTS-I	WRTS-I	
230	926	400	411 Bay- Tie Bay of 400KV RPL Line-2 and Akola-1 Line- 2 at Akola-II SS	29/Nov/17	8:00	29/Nov/17	18:00	Daily	Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	
231	932	400	Koradi Main Bay at Bhilai SS	29/Nov/17	10:00	29/Nov/17	17:30	Daily	AMP	WRTS-I	WRTS-I	
232	944	400	400KV BUS#1 at Solapur	30/Nov/17	9:00	30/Nov/17	18:00	Daily	FOR STATCON ERECTION PURPOSE	WRTS-I	WRTS-I	
233	949	400	400KV BUS-II At Koradi-III SS	30/Nov/17	8:00	30/Nov/17	18:00	Daily	BUS Equipment Maintenance Activity	MSETCL	MEGPTCL	
234	950	220	Badhera-Deoli(PGCIL) Line	30/Nov/17	8:00	30/Nov/17	18:00	Daily	PID testing work, shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	

Sr.No.	OCCM Sr. No	Voltage	Line / Element	From	Time	To	Time	Basis	Reason	System	Agency	Remarks
235	953	400	400KV BUS#2 at Solapur	30/Nov/17	9:00	30/Nov/17	18:00	Daily	FOR STATCON ERECTION PURPOSE	WRTS-I	WRTS-I	Due to 400KV Bus 1 Outage at Girawli on 30/11/2017 , this outage may be availed on 29/11/2017