

WRPC OCCM approved Monthly Outage list for the Month of November'2018

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
				Date	Time	Date	Time					
1	24	400	Main Bus - 1 alongwith ICT - 2 @ Jejuri s/s	01/Nov/18	10:00	01/Nov/18	16:00	Daily	For ICT - 3, 408 Bus bay isolator alignment work and winching of repaired ICT-2 at its location	MSETCL	MSETCL	
2	39	765	TIE BAY (711) OF AKOLA CKT - 2 & TIRODA CKT - 1 @ KORADI - 3	01/Nov/18	08:00	01/Nov/18	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	
3	49	400	KHADKA - BABHALESHWAR ON TBC @ BABHALESHWAR	01/Nov/18	09:00	05/Nov/18	17:00	Continuous	Quarterly Maintenance work, Reapir scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	Khadka Bay will be on TBC for Repairing of 29A & 29B P.G Isolator P.G Isolator Scissoes (Hanger dropper assembly of Bhusawal bay will be remove and connected on 400 bus 1 and bus 2 work carried by hot line unit Nashik)
4	51	400	PADGHE - KALWA 1	01/Nov/18	09:00	10/Nov/18	18:00	Daily	PID Testing work of 400 Kalwa-Padgha Ckt-1 line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	-
5	52	220	PUSAD - WARDHA (PG)	01/Nov/18	07:00	14/Nov/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	A/R ON NON AUTO MODE
6	53	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01/Nov/18	08:00	15/Nov/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	A/R ON NON AUTO MODE
7	54	400	BABHALESHWAR - PADGHE 1	01/Nov/18	08:00	15/Nov/18	18:00	Daily	PID testing work	MSETCL	MSETCL	to take auto reclose out of service, line will be in service.
8	58	400	PARLI-SOLAPUR (LAMBOTI)	01/Nov/18	10:00	30/Nov/18	18:00	Daily	PID Testing work, Line will be in service but autoreclosure in non automode	MSETCL	MSETCL	A/R ON NON AUTO MODE.
9	100	765	BUS - 2 @ TIRODA	02/Nov/18	08:00	02/Nov/18	21:00	Daily	Annual Maintenance	APML	APML	
10	101	400	MAIN BAY (407) OF AURANGABAD (PG) - 2 @ AKOLA	02/Nov/18	10:00	02/Nov/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
11	108	400	Padgha - Kalwa ckt - 2	03/Nov/18	8:00	10/Nov/18	17:00	Continuous	1) Dismantling of conductor at loc. No. 1103 to 1106 2) Tower erection at loc. No. 1104 to 1105 3) Dismantling of Tower exsting Loc.No.1104 4) Stringing of conductor at Loc.No. 1103 to 1106	MSETCL	MSETCL	
12	119	400	ICT2_400/220kv_WARDHA	03/Nov/18	9:00	03/Nov/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R
13	132	765	MAIN BAY (712) OF AKOLA CKT - 2 @ KORADI 3	03/Nov/18	08:00	03/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
14	145	400	PADGHE - KALWA 2	04/Nov/18	08:00	04/Nov/18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
15	146	400	400 Talegaon Lonikand Line at Talegaon Substation	04/Nov/18	9:00	04/Nov/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Pune(T) end	WRTS-I	WRTS-I	R
16	147	400	LONIKAND 1 - TALEGAON (PGCIL)	04/Nov/18	08:00	04/Nov/18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-
17	173	765	TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	05/Nov/18	08:00	05/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
18	196	400	BABHALESHWAR - PADGHE 1 ON TBC @ BABHALESHWAR	06/Nov/18	09:00	10/Nov/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 Babhaleshwar-Padghe ckt-1 Bay is Take on TBC for Repairing of 29A & 29B P.G Isoaltor P.G Isolator Scissoes (Hanger dropper assembly of Padgha 01 bay will be remove and connected on 400 bus 1 and bus 2 work carried by hot line unit Nashik)
19	204	220	KALMESHWAR-PANDHURNA	07/Nov/18	09:00	07/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	NIL
20	206	220	220KV Talegaon MSETCL Line # 1 at Talegaon Substation	08/Nov/18	9:00	08/Nov/18	17:00	Daily	For Line Equipments AMP works at Pune(T) end	WRTS-I	WRTS-I	R
21	230	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	09/Nov/18	08:00	09/Nov/18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-
22	231	400	MAIN BAY (406) OF KORADI 3 CKT - 2 @ KORADI 2	09/Nov/18	10:00	09/Nov/18	18:00	Daily	"1) DCRM,CRM & Timing IR of CB 406-Q52 2)Tan delta Maeasurement of Bus CT of Bay 406"	MSETCL	MSETCL	Koradi-2-Koradi-3 Ckt-II line will remain service through the bay 405
23	250	400	400 Talegaon Kalwa Line at Talegaon	11/Nov/18	9:00	11/Nov/18	17:00	Daily	For rectifcation of conductor unwind problem at line Isolator 'B' phase at Pune(T) end	WRTS-I	WRTS-I	R
24	251	765	765kv Bus-2 at Solapur	11/Nov/18	8:00	11/Nov/18	21:00	Daily	For AMP works.	WRTS-I	WRTS-I	R
25	253	400	400 Akola-1 Main bay-415 at Aurangabad	11/Nov/18	9:00	11/Nov/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R
26	254	400	KALWA - TALEGAON (PGCIL)	11/Nov/18	08:00	11/Nov/18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
27	256	400	400 PUNE(GIS)-PUNE(TALEGOAN)_2	12/Nov/18	9:00	12/Nov/18	11:00	Daily	CVT oil Top Up at Pune(T) end at Pune(T) end	WRTS-I	WRTS-I	R
28	261	400	SSP - Dhule - 1	12/Nov/18	8:00	12/Nov/18	18:00	Daily	Maintenance work	NCA	GETCO	out
29	268	400	400 Akola-2 & Future Tie bay-417 at Aurangabad	12/Nov/18	9:00	12/Nov/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R
30	277	400	400 Wardha#2 Main bay (412) at Warora	12/Nov/18	10:00	12/Nov/18	11:00	Daily	For NTAMC Remote Operation Validation	WRTS-I	WRTS-I	C
31	280	400	400 Wardha-2 & Future Tie bay (411) at Warora	12/Nov/18	11:00	12/Nov/18	12:00	Daily	For NTAMC Remote Operation Validation	WRTS-I	WRTS-I	C
32	282	765	MAIN BAY (710) OF TIRODA CKT - 1 @ KORADI 3	12/Nov/18	08:00	12/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
33	283	400	AKOLA - AURANGABAD(PG) CKT - 2	12/Nov/18	09:00	12/Nov/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
34	284	220	MUDSHINGI - CHIKODI	12/Nov/18	10:00	12/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
35	293	400	BABHALESHWAR - PADGHE 2 ON TBC @ BABHALESHWAR	12/Nov/18	09:00	15/Nov/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 Babhaleshwar-Padghe ckt-2 Bay is Take on TBC for Rearing of 29A & 29B P.G Isoaltor P.G Isolator Scissoes (Hanger dropper assembly of Padghe 2 bay will be remove and connected on 400 bus 1 and bus 2 work carried by hot line unit Nashik)
36	295	400	NEW KOYNA -KARAD -CKT 2 ON TBC @ KARAD	12/Nov/18	10:00	16/Nov/18	17:00	Continuous	Overhauling of CGL make SF6 CB mechanism drive & quarterly maint. work	MSETCL	MSETCL	Load managed on 400KV New Koyana-I & Load will be shifted on TBC
37	298	220	DEOLI(PGCIL)-BADNERA	12/Nov/18	09:00	17/Nov/18	17:00	Daily	For PID work, Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL	A/R ON NON AUTO MODE.
38	299	400	KALWA - TALEGAON (PGCIL)	12/Nov/18	09:00	21/Nov/18	18:00	Daily	PID Testing work of 400 Kalwa-Talegaon & 400KV Kalwa-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	-
39	300	400	KALWA - KHARGHAR	12/Nov/18	09:00	21/Nov/18	18:00	Daily	PID Testing work of 400 Kalwa-Talegaon & 400KV Kalwa-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	-
40	301	400	400 PUNE(GIS)-PUNE(TALEGOAN)_4	13/Nov/18	9:00	13/Nov/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments at Pune(T) end	WRTS-I	WRTS-I	R

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
				Date	Time	Date	Time					
41	320	400	400 Wardha-1 Main bay (409) at Warora	13/Nov/18	10:00	13/Nov/18	11:00	Daily	For NTAMC Remote Operation Validation	WRTS-I	WRTS-I	C
42	324	400	400 Wardha-1 & Future Tie bay (408) at Warora	13/Nov/18	11:00	13/Nov/18	12:00	Daily	For NTAMC Remote Operation Validation	WRTS-I	WRTS-I	C
43	326	220	MAHALAXMI - AMONA	13/Nov/18	08:00	13/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
44	327	400	WARORA - Wardha(PG)	13/Nov/18	09:00	13/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	NIL
45	328	765	Tie bay (705) of Ektuni ckt - 1 & Koradi - 3 ckt - 1 @ Akola - 2	13/Nov/18	09:00	13/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
46	330	400	CHANDRAPUR GCR - CHANDRAPUR HVDC - II ON TBC	13/Nov/18	08:00	15/Nov/18	18:00	Continuous	Servicing & overhauling of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay.
47	335	400	SSP DHULE- 1	14/Nov/18	8:00	14/Nov/18	18:00	Daily	To carry out Signature Test	SSP	NCA	
48	350	400	400 Akola-2 Main bay-418 at Aurangabad	14/Nov/18	9:00	14/Nov/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R
49	361	400	BUS REACTOR - 2 @ TIRORA	14/Nov/18	08:00	14/Nov/18	18:00	Daily	Annual Maintenance	ATIL	ATIL	
50	362	400	PARLI - LONIKAND 2 CKT 1	14/Nov/18	09:00	14/Nov/18	17:00	Daily	LINE MAINT. WORK.	MSETCL	MSETCL	NIL
51	363	400	KOLHAPUR (TALANDGE) - ALKUD	14/Nov/18	09:30	14/Nov/18	17:30	Daily	Quarterly Maint. work	MSETCL	MSETCL	NA
52	364	400	MAIN BAY (408) OF WARDHA(PG) CKT - 1 @ AKOLA	14/Nov/18	10:00	14/Nov/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
53	365	220	DEOLI(PGCIL)-BADNERA	14/Nov/18	10:00	14/Nov/18	17:00	Daily	loc no 53,56,58 Suspension clamp and arcing horn nut bolt tightening	MSETCL	MSETCL	NIL
54	370	400	50MVAR LINE REACTOR OF LONIKAND-II CKT 1 @ PARLI	14/Nov/18	09:00	20/Nov/18	17:00	Continuous	For oil filtration in reactor, 50 MVAR Line reactor is to be taken out for 7 Days on continuous basis.	MSETCL	MSETCL	LINE WILL BE TAKEN IN SERVICE AFTER REMOVAL OF L/R AT PARLI END.
55	371	400	SSP - Dhule - 2	15/Nov/18	8:00	15/Nov/18	18:00	Daily	Maintenance work	NCA	GETCO	Auto reclose of SSP - Dhule 1 will remain out
56	404	400	400 Kalwa & ICT- 3 Tie bay (417) at Pune-Talegaon	15/Nov/18	14:00	15/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
57	408	400	KORADI 2-WARDHA PGCIL	15/Nov/18	09:00	15/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	NIL
58	409	220	PUSAD - WARDHA (PG)	15/Nov/18	09:00	15/Nov/18	17:00	Daily	For replacement of broken & flashover disc insulator of R-Phase of loc. No. 305, 325 & 326 no.	MSETCL	MSETCL	NIL
59	410	765	MAIN BAY (706) OF KORADI 3 CKT-1 @ AKOLA 2	15/Nov/18	09:00	15/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
60	411	400	PARLI - LONIKAND 2 CKT 1	15/Nov/18	09:00	15/Nov/18	18:00	Daily	Half yearly maint. And diag.testing	MSETCL	MSETCL	Load will be managed by 400 Parali ckt -II, load effected NIL
61	412	400	NAGOTHANE - DABHOL 2	15/Nov/18	08:00	16/Nov/18	18:00	Daily	cold washing & String replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane Ckt-I line
62	414	400	BUS REACTOR 80 MVAR @ DHULE	15/Nov/18	08:00	25/Nov/18	18:00	Daily	For installation & commissioning of CSD	MSETCL	MSETCL	NA
63	431	400	404 Bay (Main bay of 400 Pune G15-1 Main bay (404) at Pune-Talegaon	16/Nov/18	9:00	16/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
64	453	400	BABHALESHWAR - PADGHE 1	16/Nov/18	08:00	16/Nov/18	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	
65	454	400	KORADI 2 - KORADI 3 CKT-2	16/Nov/18	08:00	16/Nov/18	17:00	Daily	Line Signature Analysis & Routine Maintenance Work	MSETCL	MSETCL	NIL
66	455	400	PARLI - KUMBHARGAON (NANDED) CKT - 1	16/Nov/18	09:00	16/Nov/18	17:00	Daily	Disc replacement work at loc. No. 843	MSETCL	MSETCL	NIL
67	456	400	TIE BAY (409) OF WARDHA CKT-1 & BHUSAWAL CKT @ AKOLA	16/Nov/18	10:00	16/Nov/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
68	461	400	CHANDRAPUR-PARLI CKT-3	16/Nov/18	08:00	30/Nov/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	A/R ON NON AUTO MODE
69	462	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16/Nov/18	08:00	30/Nov/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	A/R ON NON AUTO.
70	463	220	PUSAD - WARDHA (PG)	16/Nov/18	09:00	30/Nov/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	A/R ON NON AUTO MODE
71	477	400	CHANDRAPUR GCR - CHANDRAPUR HVDC - I	17/Nov/18	08:00	18/Nov/18	18:00	Daily	1) PMU commissioning work under URTDSM project work (making provision for panel cable entry work and CT/ PT and DI status wiring work and testing work). 2) For Measurement of Tan delta & capacitance of CT's. 3) Replacement of trip circuit supervision relay of TC- 1 & 2. 4) Servicing & overhauling of PG-I & PG-II Isolators.	MSETCL	MSETCL	400 GCR- HVDC ckt No. - II will be in service.
72	479	500	CHANDRAPUR - PADGHE HVDC POLE 1	17/Nov/18	08:00	22/Nov/18	18:00	Continuous	For Hardware tightening & replacement of faulty disc insulators and Annual Outage maintenence work/Diagnostic work of Sub Station Equipment etc	MSETCL	MSETCL	Pole-2 will be in service with 750MW.These dates are already submitted for annual outage plan for year 2018-19 on 17.10.2017
73	480	400	SSP DHULE- 2	17/Nov/18	8:00	17/Nov/18	18:00	Daily	To carry out Signature Test	SSP	NCA	
74	485	765	BUS - II @ KORADI - 3	17/Nov/18	08:00	17/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
75	486	400	MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	17/Nov/18	10:00	17/Nov/18	18:00	Daily	DCRM,CRM & Timing IR of 407-Q52	MSETCL	MSETCL	Station Transformer-2 will remain in service through Tie Bay 408
76	487	400	BABLESHWAR - AURANGABAD (WALUJ) ON TBC @ BABHALESHWAR	17/Nov/18	09:00	21/Nov/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 Babhaleshwar-Aurangabad Bay is to be Take on TBC for Rpearing of 29A & 29B P.G Isoaltor P.G Isoaltor Scissoes (Hanger dropper assembly of Aurangabad bay will be remove and connected on 400 bus 1 and bus 2 work carried by hot line unit Nashik)
77	495	220	220 kV Pandhurna-Kamleshwar	17/Nov/18	9:00	17/Nov/18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
78	504	220	BORIVALI - TARAPUR	17/Nov/18	09:00	17/Nov/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
79	505	400	NAGOTHANE - DABHOL 1	17/Nov/18	08:00	18/Nov/18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane Ckt-II
80	511	220	BOISAR (MSETCL) - BOISAR PGCIL 3	18/Nov/18	08:00	18/Nov/18	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	-
81	517	765	MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	18/Nov/18	09:00	18/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
82	531	400	BUSBAR PROTECTION SCHEME @ DEEPNAGAR	19/Nov/18	09:00	19/Nov/18	17:00	Daily	Routine BB Testing	MSETCL	MSETCL	NA
83	546	400	400 KHANDWA-DHULE#1 (online work)	19/Nov/18	9:00	19/Nov/18	15:00	Daily	For replacement of BPL PLCC Ch-1 & Protection Coupler at both the ends without Line Outage	PGCIL	WR-II	R
84	547	400	400 Chakan & Kharghar Tie bay (402) at Pune-Talegaon	19/Nov/18	9:00	19/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
85	567	400	400 KHANDWA-DHULE#1	19/Nov/18	15:00	19/Nov/18	17:00	Daily	Line outage required for end to end to code checking after installation of new PLCC	PGCIL	WR-II	R
86	568	765	TIE BAY (708) OF KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2	19/Nov/18	09:00	19/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
				Date	Time	Date	Time					
87	569	220	TALANDAGE - CHIKODI	19/Nov/18	10:00	19/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
88	570	400	NEW KOYNA - DABHOL - II	19/Nov/18	08:00	20/Nov/18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New Koyna Ckt-I line
89	578	400	400 Chandrapur-1 Main Bay (406) at Bhadravati	19/Nov/18	9:00	30/Nov/18	18:00	Cont?	For Overhauling of BHEL CB	WRTS-I	WRTS-I	R
90	600	400	400 KHANDWA-DHULE#1 (online work)	20/Nov/18	9:00	20/Nov/18	15:00	Daily	For replacement of BPL PLCC Ch-2 & Protection Coupler at both the ends without Line Outage	PGCIL	WR-II	R
91	601	400	400 Kalwa Main bay (416) at Pune-Talegaon	20/Nov/18	9:00	20/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
92	624	400	400 KHANDWA-DHULE#1	20/Nov/18	15:00	20/Nov/18	17:00	Daily	Line outage required for end to end to code checking after installation of new PLCC	PGCIL	WR-II	R
93	626	400	MAIN BAY (404) OF STATION TF - 1 @ TIRODA	20/Nov/18	09:00	20/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
94	644	400	400 KHANDWA-DHULE#2 (online work)	21/Nov/18	9:00	21/Nov/18	15:00	Daily	For replacement of BPL PLCC Ch-1 & Protection Coupler at both the ends without Line Outage	PGCIL	WR-II	R
95	661	400	400 KHANDWA-DHULE#2	21/Nov/18	15:00	21/Nov/18	17:00	Daily	Line outage required for end to end to code checking after installation of new PLCC	PGCIL	WR-II	R
96	662	220	TILARI - AMONA LINE	21/Nov/18	08:00	21/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
97	663	400	DHULE - SSNNL I with DHULE - SSNNL II AR in Non Auto mode	21/Nov/18	08:00	21/Nov/18	18:00	Daily	LINE MAINT. WORK.	MSETCL	MSETCL	MODE.
98	664	765	MAIN BAY (709) OF KORADI 3 CKT-2 @ AKOLA 2	21/Nov/18	09:00	21/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
99	665	400	MAIN BAY (406) OF PGCIL @ LAMBOTI	21/Nov/18	10:00	21/Nov/18	18:00	Daily	Overhauling and servicing of 400 Centre Break Isolators at 400 Lamboti.	MSETCL	MSETCL	Load will be managed on 400 Lamboti-Parli Line
100	670	400	NEW KOYNA - DABHOL - I	21/Nov/18	08:00	22/Nov/18	18:00	Daily	cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New Koyna Ckt-II line
101	685	400	400 KHANDWA-DHULE#2 (online work)	22/Nov/18	9:00	22/Nov/18	15:00	Daily	For replacement of BPL PLCC Ch-2 & Protection Coupler at both the ends without Line Outage	PGCIL	WR-II	R
102	686	400	400 Kharghar Main bay (403) at Pune-Talegaon	22/Nov/18	9:00	22/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
103	709	400	400 KHANDWA-DHULE#2	22/Nov/18	15:00	22/Nov/18	17:00	Daily	Line outage required for end to end to code checking after installation of new PLCC	PGCIL	WR-II	R
104	710	220	BOISAR (MSETCL) - TARAPUR	22/Nov/18	08:00	22/Nov/18	17:00	Daily	Annual Maintenance & Signature Testing of line	MSETCL	MSETCL	-
105	711	765	765/400KV 1500 MVA ICT-2 @ KORADI 3	22/Nov/18	08:00	22/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
106	712	400	DHULE - SSNNL II with DHULE - SSNNL I AR in Non Auto mode	22/Nov/18	08:00	22/Nov/18	18:00	Daily	LINE MAINT. WORK.	MSETCL	MSETCL	MODE.
107	717	400	50MVar LINE REACTOR OF SOLAPUR (LAMBOTI) @ PARLI	22/Nov/18	09:00	28/Nov/18	17:00	Continuous	For oil filtration in reactor, 50 MVar Line reactor is to be taken out for 7 Days on continuous basis.	MSETCL	MSETCL	LINE WILL BE TAKEN IN SERVICE AFTER REMOVAL OF L/R AT PARLI END.
108	718	400	PADGHE - KALWA 2	22/Nov/18	09:00	30/Nov/18	18:00	Daily	PID Testing work of 400 Kalwa-Padgha Ckt-2 line insulator strings at various locations. Auto-Restore function to be out of service.	MSETCL	MSETCL	-
109	744	400	400 AURANGABAD (PG) -AKOLA I	23/Nov/18	9:00	23/Nov/18	18:00	Daily	For LR AMP works and line defects rectification works, other ckt-II A/R in N/A mode required.	WRTS-I	WRTS-I	R
110	756	400	PADGHA - BOISAR (PG)	23/Nov/18	08:00	23/Nov/18	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
111	757	400	BABLESHWAR- AURANGABAD (WALUJ)	23/Nov/18	09:00	23/Nov/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
112	768	765	MAIN BUS - 1 @ AKOLA 2	24/Nov/18	09:00	24/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
113	774	400	400 Boisar-Padghe at Boisar	24/Nov/18	9:00	24/Nov/18	17:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	R
114	794	400	400 Talegaon Chakan Line at Talegaon	25/Nov/18	9:00	25/Nov/18	17:00	Daily	For Line Equipments AMP works at Pune(T) end.	WRTS-I	WRTS-I	R
115	797	400	400 AURANGABAD (PG) -AKOLA 2	25/Nov/18	9:00	25/Nov/18	18:00	Daily	For LR AMP works and line defects rectification works, other ckt-I A/R in N/A mode required.	WRTS-I	WRTS-I	R
116	798	400	KALWA - KHARGHAR	25/Nov/18	08:00	25/Nov/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
117	805	500 KV	CHANDRAPUR - PADGHE HVDC POLE 2	26/Nov/18	08:00	30/Nov/18	18:00	Continuous	For Hardware tightening & replacement of faulty disc insulators and for Annual Outage maintenence work/Diagnostic work of Sub Station Equipment etc	MSETCL	MSETCL	Pole-1will be in service with 750MW.These dates are already submitted for annual outage plan for year 2018-19 on 17.10.2017
118	809	220	Navsari-Nashik Line No.1	26/Nov/18	8:00	26/Nov/18	17:00	Daily	General Bay Maintenance	GETCO	GETCO	
119	819	400	400 Pune-1 LR at Msetcl, Waluj	26/Nov/18	9:00	26/Nov/18	18:00	Daily	For AMP works, Line outage required for LR taken & In. during this period line will be in service without LR.	WRTS-I	WRTS-I	R
120	829	400	400 Padghe-GIS-1 Tie Bay (414) at Kudus	26/Nov/18	10:00	26/Nov/18	18:00	Daily	for DCRM,Timing of 414 CB.	WRTS-I	WRTS-I	R
121	831	400	400 Boisar-Padghe at Boisar (DIA WILL BE KEPT OPEN)	26/Nov/18	14:00	26/Nov/18	18:00	Daily	For tripping and A/R Trials of Main-I relay(Line outage required)	PGCIL	WR-II	R
122	832	400	DHULE - SSNNL CKT I & II	26/Nov/18	08:00	26/Nov/18	18:00	Daily	PID TESTING WORK. A/R ON NON AUTO MODE.	MSETCL	MSETCL	SSNL CKT 2 WILL ALSO BE ON NON AUTO MODE. BOTH CKTS PID WORK AT A TIME.
123	833	400	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	26/Nov/18	09:00	26/Nov/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	NIL
124	834	765	BUS - 2 @ AKOLA 2	26/Nov/18	09:00	26/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
125	835	400	MAIN BAY (411) OF WARDHA(PG) CKT - 2 @ AKOLA	26/Nov/18	10:00	26/Nov/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
126	836	765	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	26/Nov/18	10:00	26/Nov/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL	Spare ICT unit to be tested.
127	837	400	400 D/C Aurangabad - Pune (GIS)	26/Nov/18	6:00	27/Nov/18	20:00	Daily	Power line crossing of 400 D/C Aurangabad - Pune line at tower loc. no. 109 & 110 by 765 D/C LILO Aurangabad - Padghe Line	WRTMPL	CWRTL	Constrution
128	845	220	220KV Bus -2 at Pune-Talegaon	26/Nov/18	9:00	26/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
129	857	400	40kv Tarapur-Boisar-I at Boisar	27/Nov/18	9:00	27/Nov/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	PGCIL	WR-II	R
130	858	220	Navsari-Nashik Line No.2	27/Nov/18	9:00	27/Nov/18	17:00	Daily	General Bay Maintenance	GETCO	GETCO	
131	873	400	MAIN BUS - 2 @ WARORA	27/Nov/18	08:00	27/Nov/18	17:00	Daily	Routine maintenance and diagonastic testing such as CVT tandelta,IR values,isolater maintenance work.	MSETCL	MSETCL	400KV MAIN BUS-1 WILL BE IN SERVICE
132	874	400	B BUS @ NAGOTHANE	27/Nov/18	08:00	27/Nov/18	18:00	Daily	various bay PG isolator overhauling	MSETCL	MSETCL	Nil
133	875	400	DHULE - SSNNL CKT I & II	27/Nov/18	08:00	27/Nov/18	18:00	Daily	PID OF SSNL CKT 1 AND 2. A/R ON NON AUTO MODE FOR BOTH CKTS	MSETCL	MSETCL	SSNL CKT 1 AND 2 ON NON AUTO MODE.
134	876	765	BUS REACTOR (240 MVar) @ EKTUNI	27/Nov/18	10:00	27/Nov/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL	NIL

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type
				Date	Time	Date	Time					
135	884	765	BUS - I @ KORADI - 3	28/Nov/18	08:00	28/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
136	893	400	400 Koradi-Sarni Line	28/Nov/18	9:00	28/Nov/18	18:00	Daily	Replacement of Y&B phase CVT at Koradi end.	WRTS-I	WRTS-I	R
137	904	400	CHANDRAPUR 2 - WARORA CKT-2	28/Nov/18	08:00	28/Nov/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	NA
138	905	400	MAIN BAY - 404 OF 765/400KV 1500MVA ICT @ AKOLA 2	28/Nov/18	09:00	28/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	
139	906	765	765/400kv 1500 MVA ICT-1 @ EKTUNI	28/Nov/18	10:00	28/Nov/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL	765/400kv, 1500MVA ICT-II Will be in service
140	910	400	DHULE - - BABLESHWAR CKT - I & II	28/Nov/18	06:00	29/Nov/18	18:00	Daily	ONLINE PID WORK (FOR BOTH CKT)	MSETCL	MSETCL	NON AUTO MODE
141	920	400	MAIN BUS - 1 @ AKOLA	29/Nov/18	10:00	29/Nov/18	17:00	Daily	PID of insulator string of 400 Bus-1 by PID Unit	MSETCL	MSETCL	NIL
142	921	220	220KV Urse main bay (203) at Pune-Talegaon	29/Nov/18	9:00	29/Nov/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R
143	922	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	29/Nov/18	10:00	29/Nov/18	18:00	Daily	R.M. WORK BY YAWATMAL LINES S/DN.	MSETCL	MSETCL	NIL
144	932	400	400 Pune-2 LR at Msetcl, Waluj	29/Nov/18	9:00	29/Nov/18	18:00	Daily	For AMP works, Line outage required for LR taken & In. during this period line will be in service without LR.	WRTS-I	WRTS-I	R
145	934	400	400 Warora-1 Tie Bay 405 at Wardha	29/Nov/18	9:00	29/Nov/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R
146	946	400	MAIN BUS - 2 @ TIRORA	29/Nov/18	08:00	29/Nov/18	21:00	Daily	Annual Maintenance	APML	APML	Load will be managed by 400 Lonikand-II- Lonikand-I Interconnector I, load effected NIL
147	947	400	MAIN BUS - 1 @ AKOLA	29/Nov/18	10:00	29/Nov/18	14:00	Daily	PID of insulator string of 400 high level Bus by PID Unit	MSETCL	MSETCL	NIL
148	948	765	765/400kv 1500MVA ICT-2 @ EKTUNI	29/Nov/18	10:00	29/Nov/18	18:00	Daily	Routine Maintain & Diagnostic/Relay Testing	MSETCL	MSETCL	Routine
149	954	500	CHANDRAPUR - PADGHA POLE 1 & 2	29/Nov/18	08:00	30/Nov/18	18:00	Continuous	For Annual Outage maintenence work/Diagnostic work of Sub Station Equipment etc	MSETCL	MSETCL	Routine
150	957	400	MAIN BUS - 2 @ AKOLA	30/Nov/18	10:00	30/Nov/18	17:00	Daily	PID of insulator string of 400 Bus-2 by PID Unit	MSETCL	MSETCL	NIL
151	960	400	MAIN BUS - 2 @ AKOLA	30/Nov/18	15:00	30/Nov/18	19:00	Daily	PID of insulator string of 400 high level Bus by PID Unit	MSETCL	MSETCL	Load will be managed on 400KV Chandrapur Ckt-2
152	977	400	KALWA - KHARGHAR	30/Nov/18	08:00	30/Nov/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Nil
153	978	400	A BUS @ NAGOTHANE	30/Nov/18	08:00	30/Nov/18	18:00	Daily	various bay isolator overhauling	MSETCL	MSETCL	NIL
154	979	400	EKTUNI - BABLESHWAR CKT 2	30/Nov/18	09:00	30/Nov/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	
155	980	400	TIE BAY - 405 OF 765/400KV 1500MVA ICT & FUTURE BAY @ AKOLA 2	30/Nov/18	09:00	30/Nov/18	18:00	Daily	Annual Maintenance	MEGPTCL	MEGPTCL	

State Element Outages list for the month of November'18

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400	TBC @ CHAKAN	01-Nov-18	09:00	01-Nov-18	17:00	Daily	Half Yearly Maintenance and testing activities.	MSETCL	MSETCL	-
2	400	125MVAr BUS REACTOR @ WARORA	01-Nov-18	08:00	01-Nov-18	18:00	Daily	Routine maintainance and diagonastic testing bushing Tandelta,winding resistance etc.Testing works isolater maintainance work .	MSETCL	MSETCL	During outage reactor is in off condition
3	400	400/220/33KV 315MVA ICT - 3 @ LONIKAND	01-Nov-18	09:00	01-Nov-18	18:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
4	400	400/220/33 KV 500 MVA ICT - 2 @ NANDED	01-Nov-18	11:00	01-Nov-18	17:00	Daily	Outage on ICT-2 require to carry out the Maintenance work.	MSETCL	MSETCL	NA
5	400	DEEPNAGAR AURANGABAD	01-Nov-18	06:00	03-Nov-18	18:00	Daily	PID OF INSULATOR STRING. A/R ON NON AUTO MODE.	MSETCL	MSETCL	A/R ON DEEPNAGAR-WALUJ CKT IS ON NO AUTO MODE SINCE COMMISSIONING.
6	400	DEEPNAGAR - THAPTI TANDA	01-Nov-18	06:00	03-Nov-18	18:00	Daily	PID OF INSULATOR STRING. CKT ON A/R NON AUTO MODE.	MSETCL	MSETCL	A/R ON NON AUTO MODE.
7	400	TIE BAY (418) OF ICT - 1 & ST 4B @ DEEPNAGAR	02-Nov-18	09:00	02-Nov-18	17:00	Daily	Diagnostic testing and maintenance work	MSETCL	MSETCL	NIL
8	400	STATION TF-3 @ KORADI 2	02-Nov-18	10:00	02-Nov-18	18:00	Daily	"1) Tan delta Maeasurement of Line CT of Bay 404 2)Tan delta Maeasurement of Bus CT of Bay 404"	MSETCL	MSETCL	NOC required from Mahagenco
9	400	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	02-Nov-18	08:00	02-Nov-18	08:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	
10	400	KHADKA - BABLESHWAR ON TBC @ KHADKA	03-Nov-18	09:00	03-Nov-18	18:00	Daily	C.B. DCRM WORK.	MSETCL	MSETCL	CKT WILL BE IN SERVICE THROUGH TBC.
11	400	DEEPNAGAR AURANGABAD	03-Nov-18	09:00	03-Nov-18	17:00	Daily	Routine Maintenance & testing	MSETCL	MSETCL	NIL
12	400	NEW KOYNA-KARAD -CKT 1	05-Nov-18	09:00	07-Nov-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	N.Koyna-Karad ckt-II will be in service
13	400	JEJURI- KOYNA STAGE-IV	08-Nov-18	09:00	08-Nov-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Lonikand-Jejuri ckt will be in service
14	400	LONIKAND 1 - KOYNA STAGE-IV	10-Nov-18	09:00	11-Nov-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Koyna Stage IV- Jejuri ckt will be in service
15	400	KARAD - TALANDGE CKT 1	12-Nov-18	09:00	13-Nov-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	400KV Karad-Talandage ckt-II will be in service
16	400	CHANDRAPUR - KHAPERKHEDA	12-Nov-18	08:00	30-Nov-18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	NIL
17	400	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	12-Nov-18	08:00	12-Nov-18	18:00	Daily	Routine maintenance, Diagnostic testing & relay testing	MSETCL	MSETCL	Load can be managed on 315 MVA ICT-II
18	400	AKOLA - KHADKA (BHUSAWAL)	12-Nov-18	06:00	14-Nov-18	18:00	Daily	Replacement of faulty disc insulators ON DAILY BASIS.	MSETCL	MSETCL	NIL
19	400	KHADKA - BABLESHWAR	12-Nov-18	06:00	14-Nov-18	18:00	Daily	PID TESTING WORK. A/R ON NON AUTO MODE.	MSETCL	MSETCL	A/R ON NON AUTO MODE.
20	400	DEEPNAGAR - THAPTI TANDA	12-Nov-18	06:00	14-Nov-18	18:00	Daily	PID TESTING WORK. A/R ON NO AUTO MODE.	MSETCL	MSETCL	A/R ON NON AUTO MODE.
21	400	DEEPNAGAR AURANGABAD	12-Nov-18	06:00	14-Nov-18	18:00	Daily	PID TESTING WORK. A/R ON NON AUTO MODE.	MSETCL	MSETCL	BOTH CKTS ARE ON D/C TOWER
22	400	AKOLA - KHADKA (BHUSAWAL)	12-Nov-18	12:00	14-Nov-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Nandgaonpeth & 400 kv Koradi- Nandgaonpeth are in service.
23	400	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	13-Nov-18	08:00	13-Nov-18	18:00	Daily	Routine maintenance, diagnostic testing & relay testing	MSETCL	MSETCL	Load can be managed on 315 MVA ICT-I
24	400	THAPTI TANDA - WALUJ	14-Nov-18	09:00	14-Nov-18	17:00	Daily	Routine maintenance & testing	MSETCL	MSETCL	NIL
25	400	WARORA - IEPL	14-Nov-18	09:00	14-Nov-18	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	NIL
26	400	400/220/20 KV 300 MVA ICT - 1 @ KORADI	14-Nov-18	08:00	14-Nov-18	18:00	Daily	Relay testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
27	400	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	14-Nov-18	10:00	14-Nov-18	18:00	Daily	Diagnoistic Testing work & overhauling of 400 kv Centre Break Isolators.	MSETCL	MSETCL	Load will be managed on 400 kv ICT-II subject to 220 kv Osmanabad and Tuljapur will be in grid.
28	400	NEW KOYNA-KARAD -CKT 1	14-Nov-18	09:00	15-Nov-18	18:00	Daily	Insulator replacement work and Routine maintenance, diagnostic testing & relay testing	MSETCL	MSETCL	New Koyna-Karad ckt-2 will be in service
29	400	KORADI-KHADKA	15-Nov-18	06:00	17-Nov-18	18:00	Daily	Replacement of faulty disc insulators ON DAILY BASIS.	MSETCL	MSETCL	NIL.
30	400	JEJURI- KOYNA STAGE-IV	15-Nov-18	09:00	15-Nov-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Lonikand - Jejuri ckt will be in service
31	400	AKOLA-NANDGAONPETH (RPL-AMT)	15-Nov-18	12:00	17-Nov-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
32	400	NEW KOYNA -KARAD -CKT 2	16-Nov-18	08:00	16-Nov-18	18:00	Daily	Routine maintenance, diagnostic testing and relay testing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna - Karad Ckt-I
33	400	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	16-Nov-18	08:00	16-Nov-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Nil

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
34	400	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	16-Nov-18	09:00	16-Nov-18	17:00	Daily	Routine Maintenance & testing	MSETCL	MSETCL	NIL
35	400	TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	16-Nov-18	09:00	16-Nov-18	17:00	Daily	Diagnostic Testing and maintenance work	MSETCL	MSETCL	NIL
36	400	MAIN BAY - 402 OF 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	16-Nov-18	11:00	16-Nov-18	16:00	Daily	DCRM, Timing and IR value of CB.	MSETCL	MSETCL	ICT will be in service through Tie bay.
37	400	BABLESHWAR- AURANGABAD (WALUJ)	16-Nov-18	09:00	30-Nov-18	18:00	Daily	PID testing work	MSETCL	MSETCL	to take auto reclose out of service, line will be in service.
38	400	KARAD - TALANDGE CKT 2	17-Nov-18	09:00	18-Nov-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Karad-Talandge ckt-I will be in service
39	400	400/132 KV 200 MVA ICT - 1 @ KHADKA	17-Nov-18	09:00	17-Nov-18	18:00	Daily	For DCRM of Main breaker and ICT-I will be shifted on TBC	MSETCL	MSETCL	NA
40	400	400/220/33 KV 315MVA ICT - 3 @ KARAD	19-Nov-18	10:00	19-Nov-18	17:00	Daily	Annual Maint.Work	MSETCL	MSETCL	Load can be managed on other two ICTs
41	400	PADGHE - NAGOTHANE 1	19-Nov-18	08:00	21-Nov-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
42	400	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	19-Nov-18	08:00	19-Nov-18	17:00	Daily	Bay 418 CB DCRM ,CRM, Timing and maintainance work .	MSETCL	MSETCL	Ckt charged on the main CB 417
43	400	AKOLA-NANDGAONPETH (RPL-AMT)	19-Nov-18	09:00	19-Nov-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
44	400	DEEPNAGAR AURANGABAD	19-Nov-18	06:00	24-Nov-18	18:00	Daily	Replacement of Dead End & Mid Span Joint ON DAILY BASIS.	MSETCL	MSETCL	NIL.
45	400/220 kv	315MVA ICT 2@ KOLHAPUR	19-Nov-18	9:00	19-Nov-18	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	
46	400	KHADKA - BABLESHWAR	19-Nov-18	07:00	21-Nov-18	17:00	Daily	PID TESTING WORK. A/R ON NON AUTO MODE.	MSETCL	MSETCL	A/R ON NON AUTO MODE.
47	400	400KV KORADI-BHUSAWAL (Koradi end)	19-Nov-18	12:00	21-Nov-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Akola- Bhusawal, 400 kV Akola- Nandgaonpeth & 400 kV Koradi- Nandgaonpeth are in service.
48	400	MAIN BAY (405) OF 500MVA ICT - 2 @ KHAPERKHEDA	20-Nov-18	11:00	20-Nov-18	16:00	Daily	DCRM, Timing and IR value of CB.	MSETCL	MSETCL	ICT will be in service through Tie bay.
49	400	400220KV 167MVA SPARE ICT @ DEEPNAGAR	20-Nov-18	09:00	20-Nov-18	17:00	Daily	Diagnostic Testing and BAY maintenance work	MSETCL	MSETCL	NA
50	400	MAIN BAY (417) OF IEPL @ WARORA	20-Nov-18	08:00	20-Nov-18	17:00	Daily	works isolater maintainance work .	MSETCL	MSETCL	Ckt charged on the Tie CB 418
51	400	400KV Str. Tf No 3 @ C'pur GCR ON TBC	21-Nov-18	08:00	21-Nov-18	18:00	Daily	1) Measusrement of DCRM, Timing & CRM of breaker. 2) PG-I & PG-II Isolators maintenance works.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay.
52	400	MAIN BAY - 410 OF BHUSAWAL (KHADKA) - AKOLA	21-Nov-18	10:00	21-Nov-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
53	400	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	22-Nov-18	09:00	22-Nov-18	18:00	Daily	Half yearly maint. And diag. testing	MSETCL	MSETCL	Load will be managed by 400/220 kv 501MVA ICT-I , load effected NIL
54	400	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	22-Nov-18	09:00	22-Nov-18	17:00	Daily	Half Yearly Maintenance and testing activities.	MSETCL	MSETCL	-
55	400	KARAD - LONIKAND 1	22-Nov-18	08:00	22-Nov-18	18:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-
56	400	PADGHE - NAGOTHANE 2	22-Nov-18	08:00	24-Nov-18	17:00	Daily	Jumper tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
57	400	NEW KOYNA - STAGE IV CKT 1	23-Nov-18	08:00	24-Nov-18	18:00	Daily	Cold washing & insulator String replacement work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage IV Ckt-II line
58	400	400/132 KV 200 MVA ICT - 2 @ KHADKA ON TBC	24-Nov-18	09:00	24-Nov-18	18:00	Daily	For DCRM of Main breaker and ICT-II will be shifted on TBC	MSETCL	MSETCL	NA
59	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	24-Nov-18	08:00	24-Nov-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT- II , 501 MVA ICT - III& IV will be in service
60	400	NEW KOYNA - STAGE IV CKT 2	25-Nov-18	08:00	26-Nov-18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage IV Ckt-I
61	400	DEEPNAGAR - THAPTI TANDA	26-Nov-18	06:00	30-Nov-18	18:00	Daily	Replacement of Dead End & Mid Span Joint ON DAILY BASIS.	MSETCL	MSETCL	NIL
62	400	KHADKA - BABLESHWAR	26-Nov-18	09:00	26-Nov-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Auragabad ,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
63	400/220	315MVA ICT 1 @ KOLHAPUR	26-Nov-18	9:00	26-Nov-18	23:59	Daily	Quarterly. Maint. work	MSETCL	MSETCL	
64	400	BABLESHWAR- AURANGABAD (WALUJ)	26-Nov-18	11:00	30-Nov-18	18:00	Daily	PID work	MSETCL	MSETCL	Auto reclose should kept out of service from end of line.
65	400	KHADKA - BABLESHWAR	26-Nov-18	07:00	28-Nov-18	17:00	Daily	PID TESTING WORK. A/R ON NON AUTO MODE.	MSETCL	MSETCL	A/R ON NON AUTO MODE.
66	400	DEEPNAGAR - THAPTI TANDA	26-Nov-18	11:00	30-Nov-18	18:00	Daily	PID work	MSETCL	MSETCL	Auto reclose should kept out of service from end of line.
67	400	MAIN BAY (413) OF 500MVA ICT - 2 @ TAPTITANDA	27-Nov-18	11:00	27-Nov-18	17:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL	NIL

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
68	400	AKOLA - KHADKA (BHUSAWAL)	27-Nov-18	07:00	27-Nov-18	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Nandgaonpeth & 400 kv Koradi- Nandgaonpeth are in service.
69	400	400kV Stn. TF No 4 @ C'pur GCR ON TBC	27-Nov-18	08:00	27-Nov-18	18:00	Daily	1) Measurement of DCRM, Timing & CRM of breaker. 2) PG-I & PG-II Isolators maintenance works.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay.
70	400	MAIN BAY (404) OF ICT -1 @ WARORA	27-Nov-18	08:00	27-Nov-18	17:00	Daily	Rph CT tandelata, Isolator maintainance	MSETCL	MSETCL	(Bay No 404 charged upto line CT 400KV ICT No -1 handed over to 400kv Bableshtar)
71	400	KORADI-KHADKA	27-Nov-18	08:00	27-Nov-18	17:00	Daily	Line Signature Analysis & Routine Maintenance work	MSETCL	MSETCL	NIL
72	400	TIE BAY (406) OF 500MVA ICT - 2 @ KHAPERKHEDA	27-Nov-18	11:00	27-Nov-18	16:00	Daily	DCRM, timing and IR value of CB.	MSETCL	MSETCL	ICT will be in service threw main bay.
73	400	80 MVAR BUS REACTOR - 1 @ BABHALESHWAR	28-Nov-18	08:00	28-Nov-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -2 are in service
74	400	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	28-Nov-18	08:00	28-Nov-18	18:00	Daily	Diagonestic testing	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
75	400	MAIN BAY (416) OF 500MVA ICT - 1 @ TAPTITANDA	28-Nov-18	11:00	28-Nov-18	17:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL	NIL
76	400	AKOLA-NANDGAONPETH (RPL-AMT)	28-Nov-18	07:00	28-Nov-18	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Bhusawal & 400 kv Koradi- Nandgaonpeth are in service.
77	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	28-Nov-18	10:00	28-Nov-18	18:00	Daily	Overhauling and servicing of 400 kv Centre Break Isolators.	MSETCL	MSETCL	Load will be managed on 400 kv ICT-I Subject to 220 kv osmanabad and Tuljapur will be in grid.
78	400	400/220/33KV 315MVA ICT - 2 @ LONIKAND	29-Nov-18	09:00	29-Nov-18	18:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
79	400	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	29-Nov-18	09:00	29-Nov-18	17:00	Daily	Half Yearly Maintenance and testing activities.	MSETCL	MSETCL	-
80	400	80 MVAR BUS REACTOR - 2 @ BABHALESHWAR	29-Nov-18	08:00	29-Nov-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -1 are in service
81	400	TIE BAY (414) OF ICT-2 & FUTURE BAY @ TAPTITANDA	29-Nov-18	11:00	29-Nov-18	17:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL	NIL
82	400	TIE BAY (417) OF ICT-1 & FUTURE BAY @ TAPTITANDA	30-Nov-18	11:00	30-Nov-18	17:00	Daily	Annual Maintenance of bays equipment	MSETCL	MSETCL	NIL
83	400	TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	30-Nov-18	09:00	30-Nov-18	17:00	Daily	Diagnostic testing and maintenance work	MSETCL	MSETCL	NIL
84	400	400/220 KV 3X105 MVA ICT - 1 @ PADGHE	30-Nov-18	08:00	30-Nov-18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	
85	400	400/220/33 KV 315MVA ICT - 1 @ AKOLA	30-Nov-18	10:00	30-Nov-18	17:00	Daily	PID of insulator string of 400 kv ICT grantry by PID Unit	MSETCL	MSETCL	NO OUTAGE REQUIRED