

Maharashtra State Load Despatch Centre									
WRPC OCCM approved Monthly Outage list for the Month of November 2019									
Sr. No	Element	From	time	to	Time	D	reason	Name of Requesting Agency	Remarks
1	NEW KOYNA - 400KV - BUS 1	01/Nov/2019	08:00	04/Nov/2019	18:00	Continuous	Cold washing, condutor replacement, Isolator replacement & Routine maint. Work	MSETCL	Main Bus-II will be in service
2	400KV-DHULE-MS-BABLESHWAR-1	01/Nov/2019	08:00	10/Nov/2019	18:00	Daily	For Carrying PID Work	MSETCL	AR required in non auto mode
3	400KV-DHULE-MS-BABLESHWAR-2	01/Nov/2019	08:00	10/Nov/2019	18:00	Daily	For Carrying PID Work	MSETCL	AR required in non auto mode
4	400KV-KALWA-PADGHE-2	01/Nov/2019	08:00	09/Nov/2019	18:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	-
5	220KV-WARDHA-PUSAD-1	01/Nov/2019	08:00	30/Nov/2019	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	Except sundays.
6	400KV-JEJURI-KOYNA STAGE IV-1	01/Nov/2019	09:00	30/Nov/2019	17:00	Daily	PID testing work	MSETCL	Permission for AR required in Non Auto mode
7	400KV-KOYNA STAGE IV-LONIKHAND-1	01/Nov/2019	09:00	30/Nov/2019	17:00	Daily	PID testing work	MSETCL	Permission for AR required in Non Auto mode
8	400KV-KARAD-NEW KOYNA-1	01/Nov/2019	09:00	30/Nov/2019	17:00	Daily	PID testing work	MSETCL	Permission for AR required in Non Auto mode
9	400KV-KARAD-NEW KOYNA-2	01/Nov/2019	09:00	30/Nov/2019	17:00	Daily	PID testing work	MSETCL	Permission for AR required in Non Auto mode
10	AURANGABAD-M (WALUJ) - 400KV - BUS 1	01/Nov/2019	09:00	01/Nov/2019	17:00	Daily	Routine maintenance of 400KV Deepnagar bay @ Waluj	MSETCL	Routine maintenance
11	400KV-SOLAPUR-M-SOLAPUR-1	01/Nov/2019	10:00	15/Nov/2019	18:00	Daily	PID testing of Disc insulator	MSETCL	Without interruption
12	400KV-RGPL-NAGOTHANE-1	01/Nov/2019	10:00	15/Oct/2019	15:00	Daily	PID Test of insulators	MSETCL	A/R to be kept off during PID Test
13	400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1	02/Nov/2019	9:00	02/Nov/2019	18:00	D	For Transfer Bus Isolator rectification work at Msetcl(Waluj) & 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 AR in non auto mode for line AMP works.	POWERGRID_WVR1	-
14	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at Akola - 400KV	02/Nov/2019	9:00	10/Nov/2019	18:00	C	For Replacement of BHEL CB with GE CB.	POWERGRID_WVR1	-
15	BUS COUPLER @ KHADKA	02/Nov/2019	06:00	02/Nov/2019	18:00	Daily	For taking CT Tan Delta ,DCRM of CB, PG Isolator and Other Routine Bay maintenance	MSETCL	NA
16	220KV-TALEGAON-PUNE-PG-1	03/Nov/2019	09:00	03/Nov/2019	17:00	Daily	Half yearly maintenance , Diagnostic Testing	MSETCL	-
17	400KV-RGPL-NEW KOYNA-1	04/Nov/2019	9:00	09/Nov/2019	18:00	Continuous	PID testing online	RGPL	A/R off from koyna side
18	MAIN BAY - 765KV/400KV KORADI-III-HCT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	04/Nov/2019	09:00	04/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
19	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	04/Nov/2019	10:00	04/Nov/2019	17:00	Daily	Routine Maintenance & testing work	MSETCL	NIL
20	400KV/11.5KV KORADI-II-ST-2	04/Nov/2019	10:00	04/Nov/2019	16:00	Daily	Tan delta Measurement of Line CT	MSETCL	Station Transformer I & III will remain in service . Koradi-III-Koradi-II Ckt-I will remain in service through its end
21	400KV-PADGHE-BOISAR-1	04/Nov/2019	10:00	05/Nov/2019	12:00	C	For Replacement of Line CT due to oil leakage at Padghe-MSETCL	POWERGRID_WVR1	-
22	400KV-PADGHE-BOISAR-1	04/Nov/2019	9:00	04/Nov/2019	17:00	D	Main-I. relay replacement & For tripping and A/R Trials of Main-I relay (Line will be out of service). Dia to be kept open at both ends.	POWERGRID_WVR2	-
23	220KV-NASIK-NAVSAARI-1	04/Nov/2019	08:00	23/Nov/2019	18:00	Daily	For Carrying PID Work	MSETCL	AR required in non auto mode
24	220KV-NASIK-NAVSAARI-2	04/Nov/2019	08:00	23/Nov/2019	18:00	Daily	For Carrying PID Work	MSETCL	AR required in non auto mode
25	220KV-WARDHA-BADNERA-1	04/Nov/2019	08:00	04/Nov/2019	17:00	Daily	PID Work	MSETCL	Nil
26	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	05/Nov/2019	09:00	05/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
27	400KV-WARORA-CHANDRAPUR-II-2	05/Nov/2019	09:00	05/Nov/2019	17:00	Daily	Isolator maintenance, Routine maintenance & Dignostic testing work Nut Bolt Tightning work etc.	MSETCL	Load will be managed on 400KV Chandrapur Ckt-1
28	BUS - 2 @ NEW KOYNA	05/Nov/2019	08:00	08/Nov/2019	18:00	Continuous	Cold washing, condutor replacement, Isolator replacement & Routine maint. Work	MSETCL	Main Bus-I will be in service
29	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	06/Nov/2019	08:00	06/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
30	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	06/Nov/2019	08:00	06/Nov/2019	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	-
31	132KV-PENCH-KANHAN-1	06/Nov/2019	09:00	06/Nov/2019	17:00	Daily	Routine maintenance work	MSETCL	-
32	400KV-KALA-KUDUS-1	06/Nov/2019	10:00	06/Nov/2019	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	Outage required on 404-Bay & 405- Bay (Main Bay of 400KV Kala-kudus Line-1 & Tie bay respectively) & at Kudus Substation
33	220KV-WARDHA-BHUGAON-1	06/Nov/2019	10:00	06/Nov/2019	18:00	Daily	lightning of jumper nut bolt at loc.No. 02,04,16,17 & other work.	MSETCL	NA
34	BUSBAR PROTECTION SCHEME @ LONIKAND 2	07/Nov/2019	07:30	07/Nov/2019	23:00	Daily	400 kv online Bus bar protection scheme testing	MSETCL	The testing will be carried online, during outage only 400KV LBB and bus bar protection scheme will remain
35	220KV-WARDHA-PUSAD-1	07/Nov/2019	08:00	07/Nov/2019	17:00	Daily	For Routine Maintenance Work	MSETCL	Nil
36	MAIN BAY - 765KV-AKOLA-EKTUNI-2 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	07/Nov/2019	09:00	07/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
37	400KV-TIRODA-WARORA-2	07/Nov/2019	09:00	07/Nov/2019	10:00	Daily	Isolator Maintaine, Routin maintenance & Dignostic testing work Nut Bolt Tightning work etc.	MSETCL	load will be managed on 400KV Chandrapur Ckt-1.
38	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	07/Nov/2019	09:30	07/Nov/2019	10:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1) 400KV Koradi-II Koradi-III Ckt-II will remain in service through Tie Bay 405. 2) Outage subject to weather Condition & availability of Kit.
39	EKTUNI - 400KV - BUS 2	07/Nov/2019	10:00	07/Nov/2019	18:00	Daily	Routine Maintenance & Testing	MSETCL	400KV MAIN BUS-I will be in service
40	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	07/Nov/2019	10:00	07/Nov/2019	10:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)Station Transformer II will remain in service through Main Bay 407 & Koradi-II Ckt-I will remain service through Main Bay 409 2) Outage subject to weather Condition & availability of Kit.
41	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	07/Nov/2019	10:30	07/Nov/2019	11:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)400KV Koradi-II Koradi-III Ckt-I will remain service through Tie Bay 408. 2) Outage subject to weather Condition & availability of Kit.
42	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	07/Nov/2019	11:00	07/Nov/2019	11:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)400KV Wardha(PG) line will remain service through Tie Bay 411. 2) Outage subject to weather Condition & availability of Kit.
43	220KV-TALEGAON-PUNE-PG-1	07/Nov/2019	9:00	07/Nov/2019	18:00	D	For line equipments AMP work & Relay Testing.	POWERGRID_WVR1	My's MSETCL
44	220KV-TARAPUR 1&2-BORVALI-1	08/Nov/2019	08:00	08/Nov/2019	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	-
45	AKOLA - KHADKA (BHUSAWAL)	08/Nov/2019	08:00	15/Nov/2019	18:00	Continuous	Restringing of conductor due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line and also for maintenance works of line.	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
46	MAIN BAY - 765KV/400KV KORADI-III-HCT-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	08/Nov/2019	09:00	08/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
47	400KV-WARDHA-WARORA-1	08/Nov/2019	09:00	08/Nov/2019	17:00	Daily	Isolator maintenance, Routine maintenance & Dignostic testing work Nut Bolt Tightning work.	MSETCL	400KV Warora - HEPL Ckt is in service
48	MAIN BAY - 400KV/11.5KV KORADI-II-ST-3 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	08/Nov/2019	09:30	08/Nov/2019	10:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)Station Transformer III will remain in service through Tie Bay 405. 2) Outage subject to weather Condition & availability of Kit.
49	TIE BAY - 400KV/11.5KV KORADI-II-ST-3 AND 400KV-KORADI-II-KORADI-III-2 at KORADI-II - 400KV	08/Nov/2019	10:00	08/Nov/2019	10:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	Station Transformer III will remain in service through Main Bay 404 & Koradi-II Ckt-II will remain service through Main Bay 405
50	220KV-WARDHA-BHUGAON-1	08/Nov/2019	10:00	08/Nov/2019	18:00	Daily	lightning of jumper nut bolt at loc.No. 02,04,16,17 & other work.	MSETCL	NA
51	MAIN BAY - 400KV/11.5KV KORADI-II-ST-2 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	08/Nov/2019	10:30	08/Nov/2019	11:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1)Station Transformer II will remain in service through Tie Bay 408. 2) Outage subject to weather Condition & availability of Kit.
52	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	08/Nov/2019	11:00	08/Nov/2019	11:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	1) 400KV Wardha(PG) line will remain in service through Main Bay 412. 2) Outage subject to weather Condition & availability of Kit.
53	AURANGABAD-M (WALUJ) - 400KV - BUS 2	09/Nov/2019	09:00	09/Nov/2019	17:00	Daily	Routine maintenance of Thaptitanda bay @ waluj	MSETCL	Routine maintenance works
54	TIE BAY - 765KV-KORADI-III-AKOLA-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA - 765KV	09/Nov/2019	09:00	09/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
55	220KV-TARAPUR 1&2-BOISAR-M-1	09/Nov/2019	09:00	09/Nov/2019	17:00	Daily	POST MONSOON MAINTENANCE WORK	MSETCL	-

Sr. No	Element	From	time	to	Time	D	reason	Name of Requesting Agency	Remarks
56	400KV-KALWA-PADGHE-1	10/Nov/2019	08:00	10/Nov/2019	18:00	Daily	1)Routine Maintenance & Diagnostic Testing, 2) Replacement of faulty insulators found in PID	MSETCL	-
57	400KV-KHARGHAR-PUNE-PG-1	10/Nov/2019	9:00	10/Nov/2019	18:00	D	For line equipments AMP work & Relay Testing.	POWERGRID_WR1	M/s MSETCL
58	220KV-BOISAR-BOISAR-M-3	10/Nov/2019	09:00	10/Nov/2019	17:00	Daily	POST MANSON MAINTENANCE WORK	MSETCL	-
59	400KV-RGPPL-NAGOTHANE-1	11/Nov/2019	08:00	13/Nov/2019	18:00	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing, EMERGENCY TREE CUTTING WORK	MSETCL	Load can be managed on Dabhol-Nagothane Ckt-II line
60	TIE BAY - TIRODA - 400KV B/R 1 AND TIRODA - 400KV B/R 2 at TIRODA - 400KV	11/Nov/2019	08:00	11/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	APML	Reactors will be in service through Main Bays
61	220KV-WARDHA-WARDHA-M-1	11/Nov/2019	08:00	11/Nov/2019	18:00	Daily	Shifting and Charging of line through ERS from Loc No. 18 due to raising the height of tower due to NHAH from Loc 16 to 17 and railway crossing from Loc No. 17 to 18.	MSETCL	NA
62	400KV-BABLESHWAR-PADGHE-PG-2	11/Nov/2019	08:00	20/Nov/2019	18:00	Daily	For Carrying PID Work	MSETCL	AR required in non auto mode
63	400KV-SSP-DHULE-MS-2	11/Nov/2019	08:00	20/Nov/2019	17:00	Daily	Online PID work	MSETCL	Online PID work
64	400KV-SSP-DHULE-MS-1	11/Nov/2019	08:00	20/Nov/2019	17:00	Daily	Online PID work	MSETCL	Online PID work
65	220KV-WARDHA-BADNERA-1	11/Nov/2019	08:00	11/Nov/2019	17:00	Daily	PID work	MSETCL	Nil
66	TIE BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV B/R 1 at TIRODA - 765KV	11/Nov/2019	09:00	11/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
67	400KV-KHARGHAR-PUNE-PG-1	11/Nov/2019	09:00	16/Nov/2019	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	-
68	400KV-KALWA-PUNE-PG-1	11/Nov/2019	09:00	16/Nov/2019	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	-
69	400KV-RGPPL-NEW KOYNA-2	11/Nov/2019	9:00	16/Nov/2019	18:00	Continuous	PID testing online	RGPL	A/R off from koyna side
70	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	12/Nov/2019	08:00	12/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
71	220KV-WARDHA-WARDHA-M-1	12/Nov/2019	08:00	12/Nov/2019	18:00	Daily	Shifting and Charging of line through ERS from Loc No. 15-18 due to raising the height of tower due to NHAH from Loc 16 to 17 and railway crossing from Loc. 17 to 18.	MSETCL	NA
72	400KV-KALWA-PUNE-PG-1	12/Nov/2019	08:00	12/Nov/2019	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	-
73	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	13/Nov/2019	09:00	13/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
74	132KV-MANSAR-MS-PENCH-1	13/Nov/2019	09:00	13/Nov/2019	17:00	Daily	Routine maintenance work	MSETCL	Outage proposed by LM S/Dn
75	220KV-WARDHA-BHUGAON-1	13/Nov/2019	10:00	13/Nov/2019	18:00	Daily	lightning of jumper nut bolt at loc.No. 02,04,16,17 & other work.	MSETCL	NA
76	400KV-KALA-KUDUS-2	13/Nov/2019	10:00	13/Nov/2019	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	Outage required on 401-Bay & 402- Bay (Main Bay of 400KV Kala-kudus Line-2 & Tie bay respectively) & at Kodus Substation
77	400KV-KORADI-SATPURA-1	13/Nov/2019	9:00	13/Nov/2019	18:00	D	For AMP work	POWERGRID_WR1	
78	220KV-TILLARI-AMONA-1	13/Nov/2019	08:00	13/Nov/2019	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	-
79	220KV-PARLI-OSMANABAD-M-1	13/Nov/2019	08:00	13/Nov/2019	16:00	Daily	Line maintenance	MSETCL	-
80	220KV-PANDURNA-KALMESHWAR-1	13/Nov/2019	08:00	13/Nov/2019	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	Outage is proposed by LMU S/Dn Mankapur
81	400KV-RGPPL-NAGOTHANE-2	14/Nov/2019	08:00	16/Nov/2019	17:00	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing, EMERGENCY TREE CUTTING WORK	MSETCL	NIL
82	765KV-TIRODA-KORADI-III-2	14/Nov/2019	09:00	14/Nov/2019	14:00	Daily	Replacement of line -2 reactor. Line will be charged without reactor after disconnection of reactor	MEGPTCL	Replacement of line -2 reactor. Line will be charged without reactor after disconnection of reactor
83	765KV-TIRODA-KORADI-III-2/L/R@ TIRODA - 765KV	14/Nov/2019	09:00	26/Nov/2019	18:00	Continuous	Replacement of Line-2 reactor	MEGPTCL	Replacement of Line-2 reactor
84	400 KV FUTURE BAY II @ WARORA	14/Nov/2019	09:00	14/Nov/2019	17:00	Daily	Isolator maintenance, routine maintenance & dngnostic testing work Nut Bolt testing work etc.	MSETCL	400kv bay No.422 charged on No load
85	400KV-BABLESHWAR-PADGHE-PG-1	14/Nov/2019	09:00	14/Nov/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	400KV Padghe ckt II will be in service
86	MAIN BAY - 765KV/400KV AKOLA (2)-HCT-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	15/Nov/2019	09:00	15/Nov/2019	19:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
87	765KV/400KV KORADI-III-HCT-1	15/Nov/2019	08:00	15/Nov/2019	18:00	Daily	Maintenance of ICT-1	MEGPTCL	Maintenance of ICT-1
88	EKTUNI - 765KV B/R 1	15/Nov/2019	10:00	15/Nov/2019	18:00	Daily	Routine Maintenance & Testing	MSETCL	765KV, 3*80MVA/BUS REACTOR will be out of service
89	400KV-CHAKAN-PUNE-PG-1	15/Nov/2019	08:00	15/Nov/2019	18:00	Daily	1)Line Maintenance & Routine Diagnostic testing work 2) Half yearly testing and maintenance activities	MSETCL	-
90	765KV/400KV EKTUNI-HCT-1	16/Nov/2019	10:00	16/Nov/2019	18:00	Daily	Erection of removed 400KV RRS Female Arms of Isolator	MSETCL	765/400KV ICT-II will be in service.
91	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	16/Nov/2019	10:00	16/Nov/2019	18:00	Daily	Erection of removed 400KV RRS Female Arms of Isolator	MSETCL	Being SPARE unit, will be out of service
92	400KV-CHANDRAPUR-II-NANDED-2	16/Nov/2019	08:00	30/Nov/2019	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	Nil
93	400KV-CHANDRAPUR-GCR-PARLI-M-3	16/Nov/2019	08:00	30/Nov/2019	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	Nil
94	220KV-BOISAR-BOISAR-M-1	16/Nov/2019	09:00	16/Nov/2019	17:00	Daily	POST MANSON MAINTENANCE WORK	MSETCL	-
95	CHANDRAPUR-GCR - 400KV - BUS 1	16/Nov/2019	09:00	18/Nov/2019	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in HVDC- II and 400KV STN T/F No.- 5 bay section span. 2) Tightening of nut bolts & hardware of Main Bus-I.	MSETCL	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be left off.
96	400KV/11.5KV CHANDRAPUR-GCR-ST-5	16/Nov/2019	09:00	18/Nov/2019	18:00	Continuous	Permission for shifting of 400KV STN T/F No.- V bay on TBC-II bay.	MSETCL	During, this outage 400KV HVDC Ckt. No.- 1 will be in service. The 400KV STN T/F No.-V bay will be shift on TBC-2 bay, as the work of replacement of bus conductor of Main Bus-1 is to be carried out in STN-5 bay.
97	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	16/Nov/2019	09:00	18/Nov/2019	18:00	Continuous	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in HVDC- II and 400KV STN T/F No.- 5 bay section span. 2) Tightening of nut bolts & hardware of Main Bus-I.	MSETCL	During, this outage 400KV HVDC Ckt. No.- 1 will be in service. The outage on 400KV HVDC Ckt. No.-2 bay is required as the work of replacement of bus conductor of Main Bus-1 is to be carried out in HVDC Ckt. N-2 bay.
98	400KV-PARLI-M-SOLAPUR-M-1	16/Nov/2019	10:00	30/Nov/2019	18:00	Continuous	PID Testing of Disc Insulator	MSETCL	Without interruption
99	400KV-RGPPL-NEW KOYNA-2	16/Nov/2019	10:00	30/Nov/2019	15:00	Daily	PID Test of insulators	MSETCL	A/R to be kept off during PID Test
100	LONKHAND-II - 400KV - BUS 2	17/Nov/2019	10:00	17/Nov/2019	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	One and half breaker system ,no line interruption and TBC operations required
101	765KV/400KV EKTUNI-HCT-2	17/Nov/2019	10:00	17/Nov/2019	18:00	Daily	Erection of removed 400KV RRS Female Arms of Isolator	MSETCL	765/400KV ICT-I will be in service.
102	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	17/Nov/2019	10:00	17/Nov/2019	18:00	Daily	Erection of removed 400KV RRS Female Arms of Isolator	MSETCL	Being SPARE unit, will be out of service
103	220KV-BOISAR-BOISAR-M-2	17/Nov/2019	09:00	17/Nov/2019	17:00	Daily	POST MANSON MAINTENANCE WORK	MSETCL	-
104	400KV-RGPPL-NEW KOYNA-2	18/Nov/2019	08:00	20/Nov/2019	18:00	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing	MSETCL	Load can be managed on Dabhol-New Koyna -I line
105	220KV-WARDHA-BADNERA-1	18/Nov/2019	08:00	18/Nov/2019	17:00	Daily	PID work	MSETCL	Nil
106	AKOLA - 400KV - BUS 1	18/Nov/2019	09:00	18/Nov/2019	18:00	Daily	Routine Maintenance & testing work	MSETCL	NIL
107	400KV-KALWA-PADGHE-1	18/Nov/2019	09:00	23/Nov/2019	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	-
108	400KV-RGPPL-NAGOTHANE-1	18/Nov/2019	9:00	23/Nov/2019	18:00	Continuous	PID testing online	RGPL	A/R off from nagothane side
109	400KV-DHULE-DHULE-MS-1	19/Nov/2019	09:00	19/Nov/2019	18:00	Daily	Routine Maintenance and Testing Work	MSETCL	Routine Maintenance and Testing Work
110	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	19/Nov/2019	09:00	19/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
111	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	20/Nov/2019	09:00	21/Nov/2019	18:00	Continuous	1) For measurement of Timing, Contact Resistatnce and DCRM of CB. 2) Isolator Alignment & maintenance work.	MSETCL	During outage 400KV HVDC Ckt. No.- 1 will be shifted on TBC-2 bay
112	CHANDRAPUR - PADGHE HVDC POLE 2	20/Nov/2019	08:00	25/Nov/2019	18:00	Continuous	For annual maintenance & diagnostic testing work .	MSETCL	Pole-1 will be in service with 750MW capacity
113	400KV-RGPPL-NEW KOYNA-1	20/Nov/2019	08:00	21/Nov/2019	18:00	Daily	Routine maint. Work & Faulty string replacement Work	MSETCL	Load can be managed on Dabhol-New Koyna CKT-II line
114	220KV-WARDHA-BADNERA-1	20/Nov/2019	08:00	20/Nov/2019	17:00	Daily	PID work	MSETCL	Nil
115	765KV-TIRODA-KORADI-III-2	20/Nov/2019	09:00	20/Nov/2019	15:00	Daily	Replacement of line -2 reactor. Line will be charged without reactor after placement of new reactor	MEGPTCL	Replacement of line -2 reactor. Line will be charged without reactor after placement of new reactor

Sr. No	Element	From	time	to	Time	D	reason	Name of Requesting Agency	Remarks
116	400KV-WARDHA-WARORA-1	20/Nov/2019	09:00	20/Nov/2019	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning	MSETCL	400KV WARORA-IEPL Line is in Crt.
117	400KV-DHULE-DHULE-MS-2	20/Nov/2019	09:00	20/Nov/2019	18:00	Daily	Routine Maintenance and Testing Work	MSETCL	Routine Maintenance and Testing Work
118	400KV-BHILAI-KORADI-1	20/Nov/2019	9:30	21/Nov/2019	17:30	D	Auto Reclose Relay retrofitting works	POWERGRID_WR1	
119	220KV-WARDHA-PUSAD-1	21/Nov/2019	10:00	21/Nov/2019	18:00	Daily	Tightning of jumper nut bolt at loc. No. 76,17,01,12 & 78 corona ring nut bolt.	MSETCL	NA
120	220KV-WARDHA-PUSAD-1	21/Nov/2019	08:00	21/Nov/2019	08:00	Daily	For Routine Maintenance Work	MSETCL	Nil
121	400KV-BABLESHWAR-PADGHE-PG-1	21/Nov/2019	08:00	30/Nov/2019	18:00	Daily	For Carrying PID Work	MSETCL	AR required in non auto mode
122	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	21/Nov/2019	09:00	21/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
123	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	22/Nov/2019	08:00	22/Nov/2019	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	Maintenance of Bay Equipment
124	400KV-BABLESHWAR-PADGHE-PG-2	22/Nov/2019	08:00	22/Nov/2019	18:00	Daily	Bay Maintenance Work	MSETCL	Diagnostic Testing Work
125	220KV-WARDHA-BADNERA-1	22/Nov/2019	09:00	22/Nov/2019	17:00	Daily	For measurement of CT tan delta and Breaker CRM and Timming	MSETCL	Nil
126	TIE BAY (426) OF WARORA CKT - 2 @ CHANDRAPUR 2	22/Nov/2019	09:00	22/Nov/2019	18:00	Daily	Diagnostic Testing work	MSETCL	Diagnostic Testing work
127	220KV-TARAPUR 1&2-BORIVALI-1	22/Nov/2019	09:00	22/Nov/2019	17:00	Daily	POST MANSON MAINTENANCE WORK	MSETCL	-
128	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	22/Nov/2019	10:00	22/Nov/2019	17:00	Daily	Routine Maintenance & testing work	MSETCL	NIL
129	220KV-WARDHA-WARDHA-M-1	23/Nov/2019	08:00	24/Nov/2019	18:00	Daily	Restoration of line from ERS to new erected tower from Loc No. 15-18 due to raising the height of tower due to NHAI from Loc 16-17 and railway crossing from Loc No. 17-18.	MSETCL	NA
130	400KV-WARDHA-KORADI-II-1	23/Nov/2019	09:00	23/Nov/2019	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning work.	MSETCL	400KV WARORA-IEPL Line is in Crt.
131	400KV-KALWA-PADGHE-2	23/Nov/2019	08:00	23/Nov/2019	18:00	Daily	Routine Maintenance & Diagnostic Testing	MSETCL	-
132	220KV-WARDHA-BADNERA-1	25/Nov/2019	08:00	25/Nov/2019	17:00	Daily	PID work	MSETCL	Nil
133	BUS COUPLER @ CHANDRAPUR	25/Nov/2019	09:00	26/Nov/2019	18:00	Daily	1) For measurement of Tan Delta & Capacitance of R, Y & B-ph CT's. 2) For measurement of Timing, Contact Resistance and DCRM of CB. 3) Isolator Alignment & maintenance work.	MSETCL	During outage, the tie breaker of HVDC Substation will be act as Bus Coupler.
134	400KV-KALWA-KHARGHAR-1	25/Nov/2019	09:00	30/Nov/2019	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	-
135	400KV-KALWA-PUNE-PG-1	25/Nov/2019	09:00	30/Nov/2019	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	-
136	400KV-RGPP-1-NAGOTHANE-2	25/Nov/2019	9:00	30/Nov/2019	18:00	Continuous	PID testing online	RGPP	A/R off from nagothane side
137	MAIN BAY - 400KV-KORADI-II-KORADI-II-ST-3 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	25/Nov/2019	13:00	25/Nov/2019	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
138	MAIN BAY - 400KV-KORADI-II-KORADI-II-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	25/Nov/2019	15:00	25/Nov/2019	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
139	CHANDRAPUR - PADGHE HVDC POLE 1	26/Nov/2019	08:00	30/Nov/2019	18:00	Continuous	For annual maintenance & diagnostic testing work.	MSETCL	Pole-2 will be in service with 750MW capacity
140	400KV-DHULE-MS-BABLESHWAR-1 with 400KV-DHULE-MS-BABLESHWAR-2A/R switch kept on non-auto mode	26/Nov/2019	08:00	26/Nov/2019	18:00	Daily	suspicious strings found in PID , it will be replaced in this proposed outages	MSETCL	400KV DHL-BBLR-II A/R switch kept on non-auto mode
141	BUS COUPLER @ BABHALESHWAR	26/Nov/2019	09:00	26/Nov/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	All 4 nos of ICT and 400KV Lines will be in service
142	MAIN BAY - 400KV/11.5KV KORADI-II-ST-2 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	26/Nov/2019	09:00	26/Nov/2019	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
143	220KV-WARDHA-PUSAD-1	26/Nov/2019	10:00	26/Nov/2019	18:00	Daily	Tightning of jumper nut bolt at loc. NO. 76,17,01,08,12 & 78 corona ring nut bolt.	MSETCL	NA
144	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	26/Nov/2019	11:00	26/Nov/2019	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
145	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	26/Nov/2019	13:00	26/Nov/2019	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
146	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND FUTURE at KORADI-II - 400KV	26/Nov/2019	15:00	26/Nov/2019	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	Work will be carried out Online by PID Unit Nagpur.
147	400KV-KHARGHAR-PUNE-PG-1	26/Nov/2019	08:00	26/Nov/2019	18:00	Daily	Routine Maintenance & Diagnostic Testing	MSETCL	-
148	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	27/Nov/2019	09:00	27/Nov/2019	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning Work.	MSETCL	Line will be charged through tieCB 428.
149	400KV-WARDHA-AKOLA-1	27/Nov/2019	9:00	27/Nov/2019	18:00	D	For Rectification of Shutdown Defects, 400 Kv Wardha-Akola Ckt#2 AR to be keep in non auto mode for safety precautions.	POWERGRID_WR1	
150	LONIKHAND-II - 400KV - BUS 1	27/Nov/2019	10:00	27/Nov/2019	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	One and half breaker system ,no line interruption and TBC operations required
151	220KV-PARLI-PARLI-M-1	27/Nov/2019	08:00	27/Nov/2019	16:00	Daily	Line maintenance	MSETCL	-
152	400KV-DHULE-MS-BABLESHWAR-2 with 400KV 400KV-DHULE-MS-BABLESHWAR-1 A/R switch kept on non-auto mode	27/Nov/2019	08:00	27/Nov/2019	18:00	Daily	suspicious strings found in PID , it will be replaced in this proposed outages	MSETCL	PID work will be carried out on 01 to 09 Aug. 2019. if any strings found suspicious, it will be replaced in this proposed outages
153	400KV-SSP-DHULE-MS-1 with AR out of Ckt II	28/Nov/2019	08:00	28/Nov/2019	18:00	Daily	suspicious strings found in PID , it will be replaced in this proposed outages	MSETCL	AR out of Ckt II required. PID work will be carried out on 11 to 20 Nov. 2019. if any strings found suspicious, it will be replaced in this proposed outages
154	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	28/Nov/2019	09:00	28/Nov/2019	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt tightning work	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
155	TBC @ BABHALESHWAR	28/Nov/2019	09:00	28/Nov/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	All 4 nos of ICT and 400KV Lines will be in service
156	400KV-KALWA-KHARGHAR-1	28/Nov/2019	09:00	28/Nov/2019	18:00	Daily	Bay maint. And testing work	MSETCL	-
157	220KV-WARDHA-PUSAD-1	28/Nov/2019	10:00	28/Nov/2019	18:00	Daily	Tightning of jumper nut bolt at loc. No. 76,17,01,08,12 & 78 corona ring nut bolt.	MSETCL	NA
158	400KV-WARDHA-AKOLA-2	28/Nov/2019	9:00	28/Nov/2019	18:00	D	For Rectification of Shutdown Defects, 400 Kv Wardha-Akola Ckt#1 AR to be keep in non auto mode for safety precautions.	POWERGRID_WR1	
159	BUS COUPLER @ KHARGHAR	29/Nov/2019	08:00	02/Dec/2019	18:00	Continuous	For replacement of existing 400KV 0.5ACSR quadraple bus conductor of 400KV Talegaon and Kalwa line	MSETCL	Load will be shifted on A bus
160	KHARGHAR - 400KV - BUS 2	29/Nov/2019	08:00	02/Dec/2019	18:00	Continuous	For replacement of existing 400KV 0.5ACSR quadraple bus conductor of 400KV Talegaon and Kalwa line	MSETCL	Load will be shifted on A bus
161	400KV-SSP-DHULE-MS-2 with AR out of Ckt I	29/Nov/2019	08:00	29/Nov/2019	18:00	Daily	suspicious strings found in PID , it will be replaced in this proposed outages	MSETCL	AR out of Ckt I required. PID work will be carried out on 11 to 20 Nov. 2019. if any strings found suspicious, it will be replaced in this proposed outages
162	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	29/Nov/2019	09:00	29/Nov/2019	17:00	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightning work.	MSETCL	line will be charged through main CB 429.
163	400KV-BABLESHWAR-PADGHE-PG-2	30/Nov/2019	09:00	30/Nov/2019	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	400KV Padghe ckt I will be in service

Maharashtra State Load Despatch Centre												
State Element Outages list for the month of November'2019												
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	
1	400	400/220KV 167 MVA SPARE ICT @ DHULE	01-Nov-19	09:00	01-Nov-19	18:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL	Routine Maintenance and Testing Work	
2	400	400/220/33 KV 500 MVA ICT - 3 @ DHULE	01-Nov-19	09:00	01-Nov-19	18:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL	Routine Maintenance and Testing Work	
3	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01-Nov-19	08:00	15-Nov-19	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Nil	
4	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	02-Nov-19	08:00	02-Nov-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT - II , 501 MVA ICT -III& IV will be in service	
5	400	KHADKA-AURANGABAD	04-Nov-19	06:00	07-Nov-19	18:00	Daily	For Replacement of faulty String and for taking CT Tan Delta ,DCRM of CB, PG Isolator and Other Routine Bay maintenance	MSETCL	MSETCL	NA	
6	400	400/220 KV 3X105 MVA ICT -1 @ NAGOTHANE	04-Nov-19	08:00	04-Nov-19	17:00	Daily	POST MONSOON MAINT WORK	MSETCL	MSETCL	NIL	
7	400	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	05-Nov-19	08:00	05-Nov-19	17:00	Daily	POST MONSOON MAINT WORK	MSETCL	MSETCL	NIL	
8	400	KORADI 2-IEPL	05-Nov-19	10:00	05-Nov-19	16:00	Daily	Tan delta Measurement of Line CT	MSETCL	MSETCL	400KV Koradi-II -Wardha(PG) Ckt. will remain in service.	
9	400	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	05-Nov-19	09:00	05-Nov-19	18:00	Daily	1) For Measurement of Tan Delta of Bushings and Windings. 2) Attending the various oil leakages. 3) Isolator Alignment & maintenance work.	MSETCL	MSETCL	During outage, the ICT-2 will be in service.	
10	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	05-Nov-19	10:00	05-Nov-19	17:00	Daily	PID Works	MSETCL	MSETCL	A/R should be off from both ends	
11	400	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	06-Nov-19	10:00	06-Nov-19	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500 MVA ICT II	
12	400	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	06-Nov-19	08:00	06-Nov-19	17:00	Daily	POST MONSOON WORK	MSETCL	MSETCL	NIL	
13	400	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	06-Nov-19	09:00	06-Nov-19	18:00	Daily	1) For Measurement of Tan Delta of Bushings and Windings. 2) Attending the various oil leakages. 3) Isolator Alignment & maintenance work.	MSETCL	MSETCL	During outage, the ICT-2 will be in service.	
14	400	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	06-Nov-19	08:00	06-Nov-19	16:00	Daily	1.Main Bus CT Tan delta testing. 2.LV CB Timing measurement & LV CT Tan delta testing work	MSETCL	MSETCL	501 MVA ICT-I complete bay	
15	400	400KV KORADI-BHUSAWAL (Koradi end)	06-Nov-19	09:30	06-Nov-19	18:00	Daily	CVT tan delta and DCRM of CB	MSETCL	MSETCL	Outages will be availed subject to weather conditions.	
16	400	KORADI-KHAPERKHEDA II	06-Nov-19	10:00	06-Nov-19	17:00	Daily	Diagnostic Testing & Routine Maintenance Work	MSETCL	MSETCL	-	
17	400	CHANDRAPUR 2 - CHD SWITCHING CKT2	06-Nov-19	09:00	06-Nov-19	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work	
18	400	MAIN BAY - 418 OF IEPL @ KORADI-2	07-Nov-19	12:30	07-Nov-19	13:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)400KV IEPL Line will remain service through Tie Bay 417. 2) Outage subject to weather Condition & availability of Kit.	
19	400	TIE BAY-426 OF GT-8 @ KORADI-2	07-Nov-19	14:30	07-Nov-19	15:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)GT808 will remain in service through Main Bay 425. 2) Outage subject to weather Condition & availability of Kit.	
20	400	TIE BAY (423) OF STATION TF -1 @ KORADI 2	07-Nov-19	14:00	07-Nov-19	14:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Main Bay 422. 2) Outage subject to weather Condition & availability of Kit.	
21	400	TIE BAY-402 OF GT-10 @ KORADI-2	07-Nov-19	09:00	07-Nov-19	09:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1) GT10 will remain in service through Main Bay 401. 2) Outage subject to weather Condition & availability of Kit.	
22	400	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	07-Nov-19	15:00	07-Nov-19	15:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)CT-I will remain service through Tie Bay 429. 2) Outage subject to weather Condition & availability of Kit.	
23	400	TIE BAY - 414 OF GT-9 @ KORADI-2	07-Nov-19	12:00	07-Nov-19	12:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	GT809 will remain in service through Main Bay 413	
24	400	MIAN BAY-421 OF ICT - 2 @ KORADI - 2	07-Nov-19	13:00	07-Nov-19	13:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)CT-II will remain service through Tie Bay 420. 2) Outage subject to weather Condition & availability of Kit.	
25	400	JEJURI- KOYNA STAGE-IV	07-Nov-19	08:00	07-Nov-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical washing work	MSETCL	MSETCL	Jejuri- Lonikand ckt will be in service	
26	400	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	07-Nov-19	09:00	07-Nov-19	17:00	Daily	Quarterly testing & maint.	MSETCL	MSETCL	During the outage, 400/220 KV ICT-I & ICT-II will be in service	
27	400	400/220/33KV SPARE ICT @ KORADI 2	07-Nov-19	15:00	07-Nov-19	15:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)Spare ICT is On No Load 2) Outage subject to weather Condition & availability of Kit.	
28	400	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	07-Nov-19	09:00	07-Nov-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-	
29	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	07-Nov-19	10:00	07-Nov-19	17:00	Daily	PID works	MSETCL	MSETCL	A/R off from both ends	
30	400	MAIN BAY-401 OF GT-10 @ KORADI-2	08-Nov-19	09:00	08-Nov-19	09:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)GT10 will remain in service through Tie Bay 402. 2) Outage subject to weather Condition & availability of Kit.	
31	400	TIE BAY - 417 OF IEPL @ KORADI-2	08-Nov-19	12:00	08-Nov-19	12:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)400KV IEPL Line will remain service through Main Bay 418 2) Outage subject to weather Condition & availability of Kit.	
32	400	MIAN BAY-422 OF STATION TF -1 @ KORADI - 2	08-Nov-19	13:00	08-Nov-19	13:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Tie Bay 423. 2) Outage subject to weather Condition & availability of Kit.	
33	400	LONIKAND 1 - KOYNA STAGE-IV	08-Nov-19	08:00	08-Nov-19	18:00	Daily	Replacement of suspected polymer string	MSETCL	MSETCL	Stage4- Jejuri ckt will be in service	
34	400	KHADKA - BABLESHWAR	08-Nov-19	06:00	09-Nov-19	18:00	Daily	For replacement of Faulty String	MSETCL	MSETCL	NA	
35	400	TIE BAY-420 OF ICT - 2 @ KORADI - 2	08-Nov-19	12:30	08-Nov-19	13:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1) ICT-II will remain service through Main Bay 421. 2) Outage subject to weather Condition & availability of Kit.	
36	400	MAIN BAY-425 OF GT-8 @ KORADI-2	08-Nov-19	14:00	08-Nov-19	14:30	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)GT808 will remain in service through Tie Bay 426. 2) Outage subject to weather Condition & availability of Kit.	
37	400	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	08-Nov-19	09:00	08-Nov-19	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Diagnostic Testing work	
38	400	MAIN BAY - 413 OF GT-9 @ KORADI-2	08-Nov-19	11:30	08-Nov-19	12:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1) GT09 will remain in service through Tie Bay 414 2) Outage subject to weather Condition & availability of Kit.	
39	400	400/220 KV 500 MVA ICT - 5 @ PADGHA	08-Nov-19	08:00	08-Nov-19	18:00	Daily	To attend R ph CT leakage	MSETCL	MSETCL	M/s Damodartech agency will do work	
40	400	TIE BAY (429) OF ICT - 1 @ KORADI - 2	08-Nov-19	14:30	08-Nov-19	15:00	Daily	Dew Point Measurement of SF6 Gas of Circuit Breaker	MSETCL	MSETCL	1)CT-I will remain in service through Main Bay 430 2) Outage subject to weather Condition & availability of Kit	
41	400	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	09-Nov-19	08:00	09-Nov-19	18:00	Daily	CTR Make fire fighting system maintenance work & Dignostic testing work	MSETCL	MSETCL	Load can be managed on 315MVA ICT II	
42	400	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	09-Nov-19	08:00	09-Nov-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT - I & 501 MVA ICT -III& 501 MVA ICT-IV will be in service	
43	400	400/220 KV 3X200 MVA ICT - 2 @ KALWA	10-Nov-19	09:00	10-Nov-19	18:00	Daily	Bay maint. And testing work	MSETCL	MSETCL	-	
44	400	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	10-Nov-19	08:00	10-Nov-19	18:00	Daily	CTR Make fire fighting system maintenance work & Dignostic testing work	MSETCL	MSETCL	Load can be managed on 315MVA ICT II	
45	400	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	11-Nov-19	08:00	11-Nov-19	18:00	Daily	CTR Make fire fighting system maintenance work & Dignostic testing work	MSETCL	MSETCL	Load can be managed on 315MVA ICT I	
46	400	400/220KV 167 MVA SPARE ICT @ DHULE	11-Nov-19	09:00	11-Nov-19	18:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL	Routine Maintenance and Testing Work	
47	400	400/220/33 KV 500 MVA ICT - 3 @ DHULE	11-Nov-19	09:00	11-Nov-19	18:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL	Routine Maintenance and Testing Work	
48	400	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	12-Nov-19	08:00	12-Nov-19	18:00	Daily	CTR Make fire fighting system maintenance work & Dignostic testing work	MSETCL	MSETCL	Load can be managed on 315MVA ICT I	
49	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	13-Nov-19	10:00	13-Nov-19	17:00	Daily	PID works	MSETCL	MSETCL	A/R off from both ends	
50	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	13-Nov-19	10:00	13-Nov-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 440/220/33 KV ICT I	
51	400	400/220/33 KV 500MVA ICT - 1 @ WARORA	13-Nov-19	09:00	13-Nov-19	17:00	Daily	Isolator Maintainance, Routine Maintainance & Dignostic testing work Nut Bolt Tightning work etc.	MSETCL	MSETCL	500 MVA, ICT No.1 handed over 400KV Bableshwar.	
52	400	KORADI-KHAPERKHEDA I	13-Nov-19	10:00	13-Nov-19	17:00	Daily	Diagnostic Testing & Routine Maintenance Work	MSETCL	MSETCL	-	
53	400	JEJURI- KOYNA STAGE-IV	14-Nov-19	08:00	14-Nov-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical washing work	MSETCL	MSETCL	Jejuri- Lonikand ckt will be in service	
54	400	KORADI-NANDGAONPETH (RPL)	14-Nov-19	09:00	14-Nov-19	18:00	Daily	Line Signature Test and line maintenance work	MSETCL	MSETCL	-	
55	400	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	14-Nov-19	10:00	14-Nov-19	18:00	Daily	Tan delta Measurement of Line CT of 421 220KV side CT at Bay 201	MSETCL	MSETCL	400/220/33KV ICT-I will remain service.	
56	400	MIAN BAY-422 OF STATION TF -1 @ KORADI - 2	14-Nov-19	10:00	14-Nov-19	13:00	Daily	Tan delta measurement of Bus CT	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Tie Bay 423	
57	400	Akola II (Yelwan) - Akola I CKT - 2	15-Nov-19	09:00	15-Nov-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL	
58	400	LONIKAND 1 - KOYNA STAGE-IV	15-Nov-19	08:00	15-Nov-19	18:00	Daily	Replacement of suspected polymer string	MSETCL	MSETCL	Stage4- Jejuri ckt will be in service	
59	400	TIE BAY (423) OF STATION TF -1 @ KORADI 2	15-Nov-19	10:00	15-Nov-19	13:00	Daily	Tan delta measurement of Bus CT	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Main Bay 422	
60	400	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	15-Nov-19	09:00	15-Nov-19	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Diagnostic Testing work	
61	400	400/220/33 KV 500 MVA ICT - 3 @ WALLU	15-Nov-19	09:00	15-Nov-19	17:00	Daily	Daily Routine Maintenance	MSETCL	MSETCL	Daily routine maintenance of 501 MVA ICT 3 bay @400 KV Wallu	
62	400	MAIN BAY - 406 OF FUTURE BAY @ AKOLA 2	16-Nov-19	09:00	16-Nov-19	18:00	Daily	Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	Maintenance of Bay Equipment	
63	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	16-Nov-19	10:00	16-Nov-19	17:00	Daily	PID works	MSETCL	MSETCL	A/R should be off from both ends	
64	400	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	16-Nov-19	08:00	16-Nov-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220KV 315MVA ICT - I & 315 MVA ICT -II & 501 MVA ICT-IV will be in service	
65	400	NEW KOYNA - KARAD -CKT 2	16-Nov-19	08:00	16-Nov-19	18:00	Daily	Replacement of faulty insulator string found in PID & Cold washing	MSETCL	MSETCL	New Koyna-Karad ckt 1 will be in service	
66	400	CHANDRAPUR - KHAPERKHEDA	16-Nov-19	08:00	20-Nov-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.	
67	400	400/220/20 KV 500MVA ICT - 1 @ KALWA	17-Nov-19	09:00	17-Nov-19	18:00	Daily	Bay maint. And testing work	MSETCL	MSETCL	-	

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
68	400	MAIN BAY (413) OF 500MVA ICT - 2 @ TAPTITANDA	18-Nov-19	11:00	18-Nov-19	17:00	Daily	CB & CT diagnostic testing work	MSETCL	MSETCL	Nil
69	400	KHADKA- DEEPNAGAR CKT 1	18-Nov-19	06:00	18-Nov-19	18:00	Daily	For taking CT Tan Delta ,DCRM of CB, PG Isolator and Other Routine Bay maintenance	MSETCL	MSETCL	Load will be shifted on Deepnagar Ckt-II
70	400	KHADKA- DEEPNAGAR CKT 1	18-Nov-19	06:00	20-Nov-19	18:00	Daily	For replacement of Faulty strings & Other Maint.works	MSETCL	MSETCL	NA
71	400	PADGHE - NAGOTHANE 1	18-Nov-19	08:00	18-Nov-19	17:00	Daily	JUMPER TIGHTING WORK	MSETCL	MSETCL	NIL
72	400	400/220/33 KV 500 MVA ICT - 3 @ KOUHAPUR	18-Nov-19	09:00	18-Nov-19	18:00	Daily	QMW	MSETCL	MSETCL	-
73	400	PADGHE - NAGOTHANE 1	19-Nov-19	08:00	19-Nov-19	17:00	Daily	JUMPER TIGHTING WORK	MSETCL	MSETCL	NIL
74	400	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	19-Nov-19	09:00	19-Nov-19	19:00	Daily	Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	Maintenance of Bay Equipment
75	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	19-Nov-19	10:00	19-Nov-19	17:00	Daily	PID works	MSETCL	MSETCL	A/R should be off from both ends
76	400	TIE BAY (414) OF ICT-2 & FUTURE BAY @ TAPTITANDA	19-Nov-19	10:00	19-Nov-19	16:00	Daily	CB & CT diagnostic testing work	MSETCL	MSETCL	Nil
77	400	BABLESHWAR- AURANGABAD (WALLU)	20-Nov-19	09:00	20-Nov-19	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400KV Dhule ckt I & II 400KV Bhusawal will be in service
78	400	MAIN BAY (416) OF 500MVA ICT - 1 @ TAPTITANDA	20-Nov-19	10:00	20-Nov-19	16:00	Daily	CB & CT diagnostic testing work	MSETCL	MSETCL	Nil
79	400	400/220/20 KV 300 MVA ICT - 1 @ KORADI	20-Nov-19	09:30	20-Nov-19	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outage will be availed subject to weather conditions.
80	400	PADGHE - NAGOTHANE 2	20-Nov-19	08:00	20-Nov-19	17:00	Daily	JUMPER TIGHTING WORK	MSETCL	MSETCL	NIL
81	400	JEJURI- KOYNA STAGE- IV	20-Nov-19	09:00	20-Nov-19	17:00	Daily	PID testing work	MSETCL	MSETCL	Permission for AR required in Non Auto mode
82	400	CHANDRAPUR 2 - CHD SWITCHING CKT1	20-Nov-19	08:00	20-Nov-19	17:00	Daily	For Conductor & Earthwire Hardware tightening work	MSETCL	MSETCL	For Conductor & Earthwire Hardware tightening work
83	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	21-Nov-19	10:00	21-Nov-19	17:00	Daily	PID Works	MSETCL	MSETCL	A/R should be off from both ends
84	400	TIE BAY-420 OF ICT - 2 @ KORADI - 2	21-Nov-19	10:00	21-Nov-19	13:00	Daily	Tan delta measurement of Bus CT Bay 420	MSETCL	MSETCL	1)ICT-II will remain service through Main Bay 421. 2) Outage subject to weather Condition & availability of Kit.
85	400	WARORA - IEPL	21-Nov-19	09:00	21-Nov-19	17:00	Daily	Routine maintenance and dagnostic testing work, Nut Bolt of jumper Tightning work	MSETCL	MSETCL	400KV KPORADI-WARDHA line is in ckt.
86	400	TIE BAY (417) OF ICT-1 & FUTURE BAY @ TAPTITANDA	21-Nov-19	10:00	21-Nov-19	16:00	Daily	CB & CT diagnostic testing work	MSETCL	MSETCL	Nil
87	400	MAIN BAY 415 OF BR 2@ TIRORA	21-Nov-19	08:00	21-Nov-19	18:00	Daily	Maintenance of Bay Equipment	APML	APML	Reactor will be in service through Tie bay
88	400	KHADKA- DEEPNAGAR CKT 2	21-Nov-19	06:00	21-Nov-19	18:00	Daily	For taking CT Tan Delta ,DCRM of CB, PG Isolator and Other Routine Bay maintenance	MSETCL	MSETCL	Load will be shifted on Deepnagar-Ckt-I
89	400	KHADKA- DEEPNAGAR CKT 2	21-Nov-19	06:00	23-Nov-19	18:00	Daily	For Replacement of Faulty string & other Maint. work	MSETCL	MSETCL	N.A.
90	400	CHANDRAPUR - KHAPEKKHEDA	21-Nov-19	09:00	21-Nov-19	18:00	Daily	Line Signature Test and line maintenance work	MSETCL	MSETCL	-
91	400	PADGHE - NAGOTHANE 2	21-Nov-19	08:00	21-Nov-19	17:00	Daily	JUMPER TIGHTING WORK	MSETCL	MSETCL	NIL
92	400	NEW KOYNA - STAGE IV CKT 1	21-Nov-19	08:00	21-Nov-19	18:00	Daily	Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
93	400	JEJURI- KOYNA STAGE-IV	21-Nov-19	08:00	21-Nov-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical & Cold washline work	MSETCL	MSETCL	Jejuri- Lonikand ckt will be in service
94	400	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	21-Nov-19	09:00	21-Nov-19	17:00	Daily	Quarterly testing & maint.	MSETCL	MSETCL	During the outage, 400/220 kV ICT-I & ICT-II will be in service
95	400	CHANDRAPUR - KHAPEKKHEDA	21-Nov-19	08:00	30-Nov-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
96	400	NEW KOYNA - STAGE IV CKT 2	22-Nov-19	08:00	22-Nov-19	18:00	Daily	Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
97	400	TIE BAY - 417 OF IEPL @ KORADI-2	22-Nov-19	10:00	22-Nov-19	17:00	Daily	Tan delta Measurement of Bus CT at Bay 417	MSETCL	MSETCL	Koradi-II IEPL Ckt. will remain in service through Main Bay 418
98	400	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	22-Nov-19	08:00	22-Nov-19	18:00	Daily	R&M and Diagnostic testing work	MSETCL	MSETCL	----
99	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	23-Nov-19	10:00	23-Nov-19	17:00	Daily	PID Works	MSETCL	MSETCL	A/R should be kept off from both ends
100	400	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	23-Nov-19	08:00	23-Nov-19	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220KV 315MVA ICT - I & 315 MVA ICT -II will be in service
101	400	DEEPNAGAR - THAPTI TANDA	25-Nov-19	06:00	27-Nov-19	18:00	Daily	For replacement of Faulty string & other Maint. works	MSETCL	MSETCL	NA
102	400	KARAD - TALANDGE CKT 1	25-Nov-19	09:00	25-Nov-19	18:00	Daily	QMW	MSETCL	MSETCL	-
103	400	400/220/33 KV 315MVA ICT - 1 @ AKOLA	25-Nov-19	09:00	25-Nov-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
104	400	MAIN BAY-401 OF GT-10 @ KORADI-2	25-Nov-19	09:00	25-Nov-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
105	400	TIE BAY-402 OF GT-10 @ KORADI-2	25-Nov-19	11:00	25-Nov-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
106	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	26-Nov-19	10:00	26-Nov-19	17:00	Daily	PID Works	MSETCL	MSETCL	A/R to be kept off from both ends
107	400	MAIN BAY - 418 OF IEPL @ KORADI-2	27-Nov-19	15:00	27-Nov-19	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
108	400	TIE BAY - 417 OF IEPL @ KORADI-2	27-Nov-19	13:00	27-Nov-19	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
109	400	MAIN BAY - 413 OF GT-9 @ KORADI-2	27-Nov-19	09:00	27-Nov-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
110	400	TIE BAY - 414 OF GT-9 @ KORADI-2	27-Nov-19	11:00	27-Nov-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
111	400	DEEPNAGAR - AURANGABAD (WALLU)	28-Nov-19	06:00	30-Nov-19	18:00	Daily	For Replacement of faulty string & other Maint. works	MSETCL	MSETCL	NA
112	400	LONIKAND 1 - KOYNA STAGE-IV	28-Nov-19	08:00	28-Nov-19	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	-
113	400	400 KV WALLU (400 KV) - BABHALESHWAR CKT	28-Nov-19	10:00	28-Nov-19	17:00	Daily	PID works	MSETCL	MSETCL	A/R to be off from both ends
114	400	JEJURI- KOYNA STAGE-IV	24-Nov-19	08:00	24-Nov-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical washing work	MSETCL	MSETCL	Jejuri- Lonikand ckt will be in service
115	400	TIE BAY-420 OF ICT - 2 @ KORADI - 2	28-Nov-19	09:00	28-Nov-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
116	400	TIE BAY (423) OF STATION TF - 1 @ KORADI 2	28-Nov-19	15:00	28-Nov-19	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
117	400	MIAN BAY-422 OF STATION TF - 1 @ KORADI - 2	28-Nov-19	13:00	28-Nov-19	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
118	400	MIAN BAY-421 OF ICT - 2 @ KORADI - 2	28-Nov-19	11:00	28-Nov-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
119	400	PADGHE - NAGOTHANE 1	29-Nov-19	08:00	29-Nov-19	18:00	Daily	Bay Maintenance Work	MSETCL	MSETCL	Diagnostic Testing Work
120	400	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	29-Nov-19	15:00	29-Nov-19	17:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
121	400	MAIN BAY-425 OF GT-8 @ KORADI-2	29-Nov-19	09:00	29-Nov-19	11:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
122	400	TIE BAY-426 OF GT-8 @ KORADI-2	29-Nov-19	11:00	29-Nov-19	13:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
123	400	TIE BAY (429) OF ICT - 1 @ KORADI - 2	29-Nov-19	13:00	29-Nov-19	15:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.
124	400	431 BAY OF 167 MVA SPARE ICT @ KORADI II	29-Nov-19	17:00	29-Nov-19	18:00	Daily	PID test for Insulator string of 400KV Bay in Switchyard.	MSETCL	MSETCL	Work will be carried out Online by PID Unit Nagpur.