

Maharashtra State Load Despatch Centre										
WRPC OCCM approved Monthly Outage list for the Month of November 2020										
Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
1	2	220KV-BOISAR-BOISAR-M-1	1-Nov-20	09:00	1-Nov-20	17:00	D	MSETCL	POST MANSOON MAINTENANCE WORK	POST MANSOON MAINTENANCE WORK
2	3	400KV-AKOLA-AURANGABAD-1	1-Nov-20	9:00	1-Nov-20	18:00	D	POWERGRID_WRI	For AMP of Line Bay At Akola SS & for line AMP 400KV-AKOLA-AURANGABAD-2 A/R to be kept in non auto mode for safety precautions.	
3	16	400KV-BABLESHWAR-PADGHE-1	1-Nov-20	08:00	10-Nov-20	18:00	D	MSETCL	PID testing work	-
4	18	400KV-KALWA-KHARGHAR-1	1-Nov-20	09:00	20-Nov-20	17:00	D	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	-
5	22	400KV-CHANDRAPUR-II-NANDED-2	1-Nov-20	08:00	30-Nov-20	17:00	D	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III are on DC tower so both lines require on same day A/R out.
6	23	400KV-CHANDRAPUR-GCR-PARLI-M-3	1-Nov-20	08:00	30-Nov-20	17:00	D	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III these lines are on DC tower so both lines require on same day A/R out.
7	25	400KV-JEJURI-KOYNA STAGE IV-1	1-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
8	26	400KV-KARAD-KOLHAPUR-MS-1	1-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
9	27	400KV-KOYNA STAGE IV-LONIKHAND-1	1-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
10	28	400KV-KARAD-KOLHAPUR-MS-2	1-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
11	56	400KV-PARLI-M-LONIKHAND-II-2	1-Nov-20	10:00	30-Nov-20	18:00	D	MSETCL	PID Testing Work.	AR Switch to be bypassed. Without Interruption.
12	76	400 kV-SSP-Dhule-MS-1	2-Nov-20	7:00	2-Nov-20	18:00	D	GETCO	Maintenance work. Auto reclose of SSP -Dhule line No. 2 will remain out.	Auto reclose of SSP -Dhule line No. 2 will remain out.
13	78	400KV-SSP-DHULE-MS-1	2-Nov-20	08:00	2-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
14	79	400KV-SSP-DHULE-MS-2	2-Nov-20	08:00	2-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
15	83	400KV-WARORA-CHANDRAPUR-II-1	2-Nov-20	09:00	2-Nov-20	17:00	D	MSETCL	Routine maintainance and diagonastic testing such as CVT/ CT tandelta,and ,isolater maintainance work	Earth will be managed on 400kv chandrapur Ckt-2 bay no 413
16	89	220KV-TALANGADE(MS)-CHIKKODI-II-1	2-Nov-20	09:00	2-Nov-20	18:00	D	MSETCL	CT Tan delta Testing QM Work	Line is idly charged from Chikkodi End
17	106	765KV-AKOLA (2)-KORADI-III-2	2-Nov-20	10:00	2-Nov-20	14:00	D	MEGPTCL	Maintenance of Line related Equipements.	Maintenance of Line related Equipements.
18	117	BHUSAWAL - 400KV - TRANSFER BUS 1	2-Nov-20	8:00	4-Nov-20	18:00	C	MSETCL	For overhauling of 400 KV Bus-I & Bus-II PG isolator	
19	121	220KV-TILLARI-AMONA-1	2-Nov-20	09:00	2-Dec-20	18:00	C	MSETCL	220kv Amona Bay old CB replacement (civil, errection and commisioning ,testing) work at 220kv Tillari Switch yard.	220 KV Halkarni -Tillari-2 /220 KV Halkarni-Mahalaxmi-1/ 220 KV Mahalaxmi -Amona lines will be remain in service
20	122	400KV-WARORA-CHANDRAPUR-II-1	2-Nov-20	08:00	11-Nov-20	17:00	D	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode	for PID Testing Work,shifting autoreclose switch to Non auto Mode
21	125	220KV-TILLARI-AMONA-1	2-Nov-20	8:30	12-Nov-20	18:00	D	MSETCL	Earth wire replacement work	Consent from Goa required
22	126	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	2-Nov-20	8:30	12-Nov-20	18:00	D	MSETCL	Earth wire replacement work	Consent from Goa required
23	135	EKTUNI - 765KV B/R 1	3-Nov-20	10:30	3-Nov-20	18:00	D	MSETCL	Diagnostic Testing & routine maintainance "	765kV Bus Reactor Will be out of service
24	154	MAIN BAY - 765KV/400KV AKOLA-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA - 765KV	3-Nov-20	09:00	3-Nov-20	18:00	D	MEGPTCL	Bay maintenance activities	Bay maintenance activities
25	180	220KV-NASIK-NAVSARI-1	3-Nov-20	08:00	4-Nov-20	18:00	C	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixing if issued.	-
26	188	BABLESHWAR - 400KV B/R 1 ON TBC @ BABHALESHWAR	3-Nov-20	09:00	11-Nov-20	18:00	C	MSETCL	CB Overhauling work	400kV Reactor I will be on TBC, no interruption
27	189	GTR - 3 @ CHANDRAPUR SS	3-Nov-20	09:00	12-Nov-20	18:00	C	MSETCL	1) For capital overhauling of drive mechanism, poles and Interrupter of all 3 phases of 400KV CGL make Breaker. 2) Measurement of Timing, Contact Resistance and DCRM of breaker after overhauling work.	During this outage 400KV GTR-3 will be shift on TBC-1 as the work of capital overhauling of drive mechanism poles and interrupter of all three phases of 400KV CGL make main breaker & Measurement of Timing, Contact Resistance and DCRM of breaker after overhauling work.
28	190	400KV-WARORA-CHANDRAPUR-II-2	3-Nov-20	08:00	11-Nov-20	17:00	D	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode	for PID Testing Work,shifting autoreclose switch to Non auto Mode

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
29	192	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	3-Nov-20	10:30	3-Nov-20	18:00	D	MSETCL	Diagnostic Testing & Routine Maintenance	Hot Sandby unit Hence on No Load
30	220	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	4-Nov-20	09:00	4-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
31	243	400KV-SSP-DHULE-MS-2	4-Nov-20	08:00	4-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
32	252	400KV-WARDHA-WARORA-1	5-Nov-20	09:00	5-Nov-20	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL Line is in ckt
33	258	400KV-RGPPL-NAGOTHANE-1	5-Nov-20	08:00	5-Nov-20	17:00	D	MSETCL	Tree cutting work	nil
34	267	220KV-WARDHA-BADNERA-1	5-Nov-20	09:00	5-Nov-20	17:00	D	MSETCL	For Diagnostic testing work	Proposed by Shri. Sandeep Vitalkar, Add. E.E. 220kV S/Stn Badnera M.N. 8554989269
35	270	400KV-PADGHE-PG-KUDUS-2	5-Nov-20	9:00	5-Nov-20	17:00	D	POWERGRID_WRI	FOR LINE SIDE EQUIPMENTS AMP & LINE AMP, 400KV-PADGHE-PG-KUDUS-1 line to be kept in Non-Auto mode for safety precautions	
36	273	220 kV Navsari-Nashik line No.1	5-Nov-20	9:00	5-Nov-20	18:00	D	GETCO	Maintenance work. Auto reclose of 220 kV Navsari - Nashik line No. 2 will remain out	
37	274	TIE BAY - AKOLA - 765KV B/R 1 AND 765KV/400KV AKOLA-ICT-1 at AKOLA - 765KV	5-Nov-20	09:00	5-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
38	289	400KV-PARLI-M-LONIKHAND-II-1	5-Nov-20	09:30	5-Nov-20	18:30	D	MSETCL	Bay maintenance work.	-
39	292	NANDED - 400KV - BUS 2	5-Nov-20	10:30	5-Nov-20	18:00	D	MSETCL	Annual Maintenance & Relay Testing work.	-
40	294	NEW KOYNA - 400KV - BUS 1	5-Nov-20	08:00	6-Nov-20	18:00	C	MSETCL	Replacement of damage conductor	Planned outage
41	295	400KV-KOYNA STAGE IV-NEW KOYNA-1	5-Nov-20	08:00	6-Nov-20	18:00	C	MSETCL	line required to out during Bus Outage	Outage required during bus 1 outage
42	296	BUS COUPLER @ NEW KOYNA	5-Nov-20	08:00	6-Nov-20	18:00	C	MSETCL	For Main Bus- I Outage	Planned outage
43	297	220KV-NASIK-NAVSARI-2	5-Nov-20	08:00	6-Nov-20	18:00	C	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling,signature analysis,TLS fixing if issued.	-
44	304	400KV-BHUSAWAL-DEEPNAGAR-2 ON TBC @ BHUSAWAL	5-Nov-20	8:00	7-Nov-20	18:00	C	MSETCL	For overhauling of 400 KV Bus-I & Bus-II PG isolator	During that period of time line will be shifted on TBC .
45	306	400KV-CHANDRAPUR-KHAPARKHEDA-1	5-Nov-20	09:00	7-Nov-20	19:00	C	MSETCL	RESTRINGING OF CONDUCTOR BETWEEN TOWER NO 30-34	Restrstring work is done to increase the clearance of conductor from ground which is currently 08 meters.
46	309	400KV-SSP-DHULE-MS-1	5-Nov-20	08:00	6-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-2 A/R switch will be kept on non auto mode
47	312	400KV-KALWA-PADGHE-1	5-Nov-20	09:30	7-Nov-20	17:30	C	MSETCL	400KV Kalwa I on TBC for Replacement of A bus PG Isolator 2) Maint & Testing Work	M/s Bimco Hyderabad representative will be available on site for the work
48	315	400KV-SSP-DHULE-MS-2	6-Nov-20	08:00	6-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
49	316	400KV-SSP-DHULE-MS-1	6-Nov-20	08:00	6-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-2 A/R switch will be kept on non auto mode
50	318	400KV-LONIKHAND-PUNE-PG-1	6-Nov-20	9:00	6-Nov-20	18:00	D	POWERGRID_WRI	For AMP Work	Others
51	321	400 kV-SSP-Dhule-MS-2	6-Nov-20	7:00	6-Nov-20	18:00	D	GETCO	Maintenance work. Auto reclose of SSP -Dhule line No. 1 will remain out.	
52	322	400KV-WARORA-CHANDRAPU-II-1	6-Nov-20	08:00	6-Nov-20	17:00	D	MSETCL	For Conductor & Earthwire H/W tightening work	For Conductor & Earthwire H/W tightening work
53	328	400KV-RGPPL-NAGOTHANE-2	6-Nov-20	08:00	6-Nov-20	17:00	D	MSETCL	Tree cutting work	nil
54	343	220 kV Navsari-Nashik line No.2	6-Nov-20	9:00	6-Nov-20	18:00	D	GETCO	Maintenance work. Auto reclose of 220 kV Navsari - Nashik line No. 1 will remain out	
55	344	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	6-Nov-20	09:00	6-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
56	363	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	6-Nov-20	10:00	6-Nov-20	17:00	D	MSETCL	DCRM of CB 406-Q52 Tan delta measurement of Bus CT at Bay406	400KV Koradi-II Koradi-III Ckt.-II will remain service through Tie Bay 405
57	366	220KV-WARDHA-WARDHA-M-1	6-Nov-20	10:00	6-Nov-20	18:00	D	MSETCL	Routine line maintainace work	NA
58	373	400KV-SSP-DHULE-MS-1	7-Nov-20	08:00	7-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
59	376	400KV-WARORA-CHANDRAPU-II-2	7-Nov-20	08:00	7-Nov-20	17:00	D	MSETCL	For Conductor & Earthwire H/W tightening work Routine maintainance and diaganostic testing such as CVT/ CT tandelta,and isolater maintainance work	For Conductor & Earthwire H/W tightening work

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
60	380	TIE BAY - 765KV-AKOLA-EKTUNI-1 AND FUTURE at EKTUNI - 765KV	7-Nov-20	10:30	7-Nov-20	18:00	D	MSETCL	Diagnostic Testing & Routine Maintenance	765KV Akola Ckt-I will be in service through its Main (706) Bay and Main Bus-II
61	383	400KV-SSP-DHULE-MS-1	7-Nov-20	08:00	7-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
62	386	220KV-BOISAR-BOISAR-M-3	7-Nov-20	09:00	7-Nov-20	17:00	D	MSETCL	POST MANSOON MAINTENANCE WORK	POST MANSOON MAINTENANCE WORK
63	391	MAIN BAY - AKOLA - 765KV B/R 1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	7-Nov-20	09:00	7-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
64	405	220KV-TALEGAON-PUNE-PG-1	7-Nov-20	10:00	7-Nov-20	17:00	D	MSETCL	Half yearly maintenance, Diagnostic Testing.	---
65	412	220KV-TALEGAON-PUNE-PG-1	7-Nov-20	9:00	7-Nov-20	18:00	D	POWERGRID_WRI	For AMP Work	Others
66	413	400KV-RGPPL-NAGOTHANE-2	7-Nov-20	09:00	10-Nov-20	18:00	D	MSETCL	Cold washing & Faulty string replacement Work	Planned outage
67	414	400KV-SSP-DHULE-MS-2	7-Nov-20	08:00	7-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
68	424	400KV-SSP-DHULE-MS-2	8-Nov-20	08:00	8-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
69	426	400KV-WARDHA-KORADI-II-1	8-Nov-20	09:00	8-Nov-20	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
70	428	400KV-AKOLA-AURANGABAD-2	8-Nov-20	9:00	8-Nov-20	18:00	D	POWERGRID_WRI	For AMP of Line Bay & For line AMP 400kV Akola-Aurangabad-1 A/R to be keep in non auto mode for safety measures.	
71	432	220KV-TARAPUR 1&2-BOISAR-M-1	8-Nov-20	09:00	8-Nov-20	17:00	D	MSETCL	POST MANSOON MAINTENANCE WORK	POST MANSOON MAINTENANCE WORK
72	441	AURANGABAD-M (WALUJ) - 400KV - BUS 1	9-Nov-20	09:00	9-Nov-20	17:00	D	MSETCL	Quarterly Maintenance of 400kV Deepnagar- Waluj Bay	Quarterly Maintenance
73	455	MAIN BAY - 400KV/11.5KV TIRODA-ST-1 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	9-Nov-20	09:00	9-Nov-20	18:00	D	APML	Bay Maintenance Activities	Bay Maintenance Activities
74	472	MAIN BAY - 400KV/11.5KV KORADI-II-ST-2 AND KORADI-II - 400KV - BUS 1 at KORADI-II - 400KV	9-Nov-20	10:00	9-Nov-20	15:00	D	MSETCL	DCRM of CB 407-Q52	Station Transformer -II will remain in service through Tie Bay 408
75	474	Tie Bay (414) of 400 KV Padghe Kudus Line 1 at Kudus MSETCL SS.	9-Nov-20	10:00	9-Nov-20	17:00	D	POWERGRID_WRI	AMP of 414 Tie Bay of 400 KV Padghe Kudus Line 1 at Kudus MSETCL SS.	
76	475	220KV-WARDHA-BADNERA-1	9-Nov-20	10:00	9-Nov-20	18:00	D	MSETCL	Routine line maintainace work	NA
77	484	400KV-BHUSAWAL-DEEPNAGAR-1 ON TBC @ BHUSAWAL	9-Nov-20	08:00	11-Nov-20	18:00	C	MSETCL	For overhauling of 400 KV Bus-I & Bus-II PG isolator	During that period of time line will be shifted on TBC .
78	486	400KV-KORADI-BHUSAWAL-1	9-Nov-20	09:00	11-Nov-20	19:00	C	MSETCL	RESTRINGING OF CONDUCTOR BETWEEN TOWER NO 06-16	Restringing work is done to increase the clearance of conductor from ground which is currently 08 meters.
79	487	400KV-BABLESHWAR-PADGHE-2 ON TBC @ PADGHE	9-Nov-20	09:30	11-Nov-20	17:30	C	MSETCL	400kV Babhaleshwar 2 on TBC for A bus PG Isolator replacement work	M/s Bimco Ltd hyderabad representative & team will be available on site for the replacemet of isolator
80	488	400KV-SSP-DHULE-MS-1	9-Nov-20	08:00	9-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
81	494	400KV-SSP-DHULE-MS-2	10-Nov-20	08:00	10-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
82	503	220KV-WARDHA-BHUGAON-1	10-Nov-20	08:00	10-Nov-20	18:00	D	MSETCL	Routine line maintainace work	NA
83	508	220KV-Pandurna-MP-Kamleshwar	10-Nov-20	9:00	10-Nov-20	17:00	D	MP	For bay equipment maintenance and testing work	
84	516	765KV/400KV KORADI-III-ICT-2	10-Nov-20	09:00	10-Nov-20	18:00	D	MEGPTCL	ICT Maintenance Activities	ICT Maintenance Activities
85	535	400KV-SSP-DHULE-MS-2	10-Nov-20	08:00	10-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-2 A/R switch will be kept on non auto mode
86	541	BABLESHWAR - 400KV - BUS 2	11-Nov-20	09:00	11-Nov-20	18:00	D	MSETCL	CVT C & Tan D testing work	400kv BUS-1 will be in service
87	546	400KV-SSP-DHULE-MS-2	11-Nov-20	08:00	11-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
88	547	220KV-PANDURNA-KALMESHVAR-1	11-Nov-20	08:00	11-Nov-20	18:00	D	MSETCL	Routine Maintenance work.	Outage proposed by LMU S/Dn Mankapur.
89	548	220KV-WARDHA-BHUGAON-1	11-Nov-20	08:00	11-Nov-20	18:00	D	MSETCL	Routine line maintainace work	NA
90	552	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	11-Nov-20	09:00	11-Nov-20	17:00	D	MSETCL	quarterly maintenance	-
91	553	220KV-PARLI-PARLI-M-1	11-Nov-20	09:00	11-Nov-20	17:00	D	MSETCL	Tightening of loose nut bolts from Loc. Nos. 1 to 9.	-

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
92	561	MAIN BAY - 400KV/KV TIRODA-ST-3 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	11-Nov-20	09:00	11-Nov-20	18:00	D	APML	Bay maintenance Activities	Bay maintenance Activities
93	572	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	11-Nov-20	10:00	11-Nov-20	17:00	D	MSETCL	Annual Maintenance of bays equipment & Diagnostics Testing Work of ICT-1 and Bay 408 for safety purpose.	For safety purpose
94	578	220KV-SOLAPUR-JEUR-1	11-Nov-20	9:00	11-Nov-20	17:00	D	WTPL	For Annual Shutdown maintenance. AR Mode to be kept OFF for 400KV-KARAD-SOLAPUR-1	
95	579	400KV-SSP-DHULE-MS-1	11-Nov-20	08:00	11-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
96	580	400KV-BABLESHWAR-PADGHE-2	11-Nov-20	08:00	20-Nov-20	18:00	D	MSETCL	PID testing work	-
97	590	PUNE-PG - 400KV - BUS 2	12-Nov-20	9:00	12-Nov-20	18:00	D	POWERGRID_WRI	For rectification of Conductor unwind	
98	600	JEUR - 220KV - BUS 1	12-Nov-20	10:00	12-Nov-20	18:00	D	MSETCL	Quarterly Maintenance Work	220 kV PGCIL Line CB needs to be made off at 220 kV Jeur S/Sn end during outage.
99	602	220KV-PARLI-OSMANABAD-M-1	12-Nov-20	08:00	12-Nov-20	17:00	D	MSETCL	LINE maintenance	-
100	609	MAIN BAY - 765KV-AKOLA-EKTUNI-1 AND AKOLA - 765KV - BUS 1 at AKOLA - 765KV	12-Nov-20	09:00	12-Nov-20	18:00	D	MEGPTCL	Bay maintenance Activities	Bay maintenance Activities
101	627	400KV-SSP-DHULE-MS-2	12-Nov-20	08:00	12-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-2 A/R switch will be kept on non auto mode
102	637	400KV-SSP-DHULE-MS-1	13-Nov-20	08:00	13-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
103	640	220KV-PARLI-PARLI-M-1	13-Nov-20	09:00	12-Nov-20	18:00	D	MSETCL	Tightening of loose nut bolts from Loc. Nos. 1 to 9.	-
104	643	220KV-WARDHA-BHUGAON-1	13-Nov-20	08:00	13-Nov-20	18:00	D	MSETCL	Routine line maintainance work	NA
105	645	220KV-BOISAR-NALASOPARA-1	13-Nov-20	09:00	13-Nov-20	17:00	D	MSETCL	PID FAULTY INSULATO STRING REPLACEMENT	PID FAULTY INSULATO STRING REPLACEMENT
106	663	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	14-Nov-20	9:00	14-Nov-20	18:00	D	POWERGRID_WRI	For Line side equipment AMP works at Pune-GIS & For line AMP 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 A/R to be kept in Non-Auto mode for safety precautions	
107	668	400KV-SSP-DHULE-MS-1	14-Nov-20	08:00	14-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
108	669	400KV-PARLI-M-LONIKHAND-II-1	14-Nov-20	08:00	14-Nov-20	18:00	D	MSETCL	Routine Diagnostic testing work and Chemical Cleaning.	---
109	675	400KV-KALWA-KHARGHAR-1	15-Nov-20	08:00	15-Nov-20	18:00	D	MSETCL	Routine Maintenance work	Routine Maintenance work
110	676	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	15-Nov-20	08:00	15-Nov-20	18:00	D	MSETCL	Routine Dignostic testing and bay maintenance work.	---
111	686	400KV-PARLI-M-LONIKHAND-II-2	16-Nov-20	09:30	16-Nov-20	18:00	D	MSETCL	Hardware Tightening and Fitting Work.	-
112	687	BABLESHWAR - 400KV - BUS 1	16-Nov-20	09:00	16-Nov-20	18:00	D	MSETCL	CVT C & Tan D testing work	400kv BUS-II will be in service
113	695	400KV-KORADI-SATPURA	16-Nov-20	9:00	16-Nov-20	18:00	D	POWERGRID_WRI	For AMP works & PLCC Work, Line work permit shall be provided	
114	705	400KV-PADGHE-BOISAR-1	16-Nov-20	10:00	23-Nov-20	17:00	C	POWERGRID_WRI	Retrofitting of old BHEL make CB with New GE make CB for 400 KV Boisar Line Bay at Padghe MSETCL. 400 KV Boisar Line to be taken on TBC at Padghe MSETCL.	1) 400 KV Padghe Boisar Line shall remain chraged through TBC CB at Padghe MSETCL as Bus arrangement at MSETCL is DMT Scheme.2) In case of any emergency in any other bay at Padghe MSETCL, MSETCL may consider as per system requirement to handrip the 400KV MSETCLPadghe-PG BOISAR Line during which this Boisar Line shall be out of service.3) In case during erection if clearance is not met w.r.t live buses then emergency shutdown may be required for 01 or 02 days. Kindly request to concur the as proposed
115	719	220KV-WARDHA-PUSAD-1	17-Nov-20	08:00	17-Nov-20	18:00	D	MSETCL	Routine line maintainance work	NA
116	729	400KV-BHILAI-KORADI	17-Nov-20	9:00	17-Nov-20	18:00	D	POWERGRID_WRI	For AMP works & PLCC Work, Line work permit shall be provided.	
117	737	400KV-RGPPL-NEW KOYNA-1	17-Nov-20	9:00	21-Nov-20	18:00	C	RGPPL	New Koyna Line-1 isolator overhauling to be done.	
118	739	JEJURI - 400KV - BUS 1 and JEJURI - 400KV - BUS 2	17-Nov-20	10:00	30-Nov-20	18:00	D	MSETCL	Online PID testing work	PID of Insulator strings in Switchyard
119	744	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	17-Nov-20	8:30	20-Nov-20	18:00	D	MSETCL	Earth wire replacement work	Consent from Goa required

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
120	745	220KV-TILLARI-AMONA-1	17-Nov-20	8:30	30-Nov-20	18:00	D	MSETCL	Earth wire replacement work	Consent from Goa required
121	756	400KV-SSP-DHULE-MS-2	18-Nov-20	08:00	18-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
122	757	220KV-WARDHA-PUSAD-1	18-Nov-20	08:00	18-Nov-20	18:00	D	MSETCL	Routine line maintainace work	NA
123	762	220KV-TILLARI-AMONA-1	18-Nov-20	09:00	18-Nov-20	17:00	D	MSETCL	quarterly maintenance	-
124	765	MAIN BAY - 400KV/11.5KV TIRODA-ST-5 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	18-Nov-20	09:00	18-Nov-20	18:00	D	APML	Bay maintenance Activities	Bay maintenance Activities
125	773	400KV-AKOLA-WARDHA-1	18-Nov-20	9:00	18-Nov-20	18:00	D	POWERGRID_WRI	For AMP of Line Bay & For line AMP 400kV Akola-Wardha-2 A/R to be keep in non auto mode for safety measures.	
126	778	400KV-PARLI-M-SOLAPUR-M-1	18-Nov-20	09:30	18-Nov-20	18:00	D	MSETCL	Hardware Tightening and Fitting Work.	-
127	783	CHANDRAPUR-GCR - 400KV - BUS 1	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
128	784	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
129	785	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, HVDC-II shift on TBC-II & all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
130	786	400KV-CHANDRAPUR-BHADRAWATI-3	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	Outage is required on 400KV GCR C'pur - PGCIL Bhadravati Ckt. No.- 3 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
131	787	400KV-CHANDRAPUR-BHADRAWATI-4	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	Outage is required on 400KV GCR C'pur - PGCIL Bhadravati Ckt. No.- 4 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
132	788	400KV/11.5KV CHANDRAPUR-GCR-ST-4	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. 3) Measurement of Tan delta & Capaciatnce of CT's	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
133	789	400KV/21KV CHANDRAPUR-GT-6	18-Nov-20	04:00	21-Nov-20	18:00	C	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, GTR-6 shift on TBC-2 & all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
134	791	400KV-SSP-DHULE-MS-1	18-Nov-20	08:00	18-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
135	796	PUNE-PG - 220KV - BUS 1	19-Nov-20	9:00	19-Nov-20	18:00	D	POWERGRID_WRI	For AMP Work	
136	803	400KV-SSP-DHULE-MS-1	19-Nov-20	08:00	19-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
137	811	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	19-Nov-20	09:00	19-Nov-20	18:00	D	MEGPTCL	Bay maintenance Activities	Bay maintenance Activities
138	818	400KV-AKOLA-WARDHA-2	19-Nov-20	9:00	19-Nov-20	18:00	D	POWERGRID_WRI	For AMP of Line Bay & 400kV Akola-Wardha-1 A/R to be keep in non auto mode for safety measures.	
139	829	400KV-BHUSAWAL-BABLESHWAR-1 ON TBC @ BABHALESHWAR	19-Nov-20	04:00	25-Nov-20	18:00	C	MSETCL	CB Overhauling work	400kv BBLR-Bhusawal line will be on TBC, no interruption
140	833	400KV-SSP-DHULE-MS-2	19-Nov-20	08:00	19-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-2 A/R switch will be kept on non auto mode
141	848	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	20-Nov-20	7:00	20-Nov-20	18:00	D	POWERGRID_WRI	Replacement of Porcelain insulators at River crossing locations & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 line to be kept in Non-Auto mode for safety precautions	
142	851	400KV-SSP-DHULE-MS-2	20-Nov-20	08:00	20-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
143	852	220KV-WARDHA-PUSAD-1	20-Nov-20	08:00	20-Nov-20	18:00	D	MSETCL	Routine line maintainace work	NA
144	860	TIE BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV B/R 1 at TIRODA - 765KV	20-Nov-20	09:00	20-Nov-20	18:00	D	APML	Bay Maintenance Activities	Bay Maintenance Activities
145	876	400KV-RGPPL-NEW KOYNA-1	20-Nov-20	09:00	21-Nov-20	18:00	D	MSETCL	Cold washing & Faulty string replacement Work	Planned Outage
146	877	400KV-SSP-DHULE-MS-1	20-Nov-20	08:00	20-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-1 A/R switch will be kept on non auto mode
147	884	400KV-SSP-DHULE-MS-1	21-Nov-20	08:00	21-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
148	894	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	21-Nov-20	09:00	21-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
149	907	220KV-MAHALAXMI(KONALKATTA)-HALKARNI-1	21-Nov-20	8:30	30-Nov-20	18:00	D	MSETCL	Earth wire replacement work	Consent from Goa required
150	909	400KV-SSP-DHULE-MS-2	21-Nov-20	08:00	21-Nov-20	18:00	D	MSETCL	Online PID testing work	400kv SSNNL ckt-2 A/R switch will be kept on non auto mode
151	910	400KV-DHULE-MS-BABLESHWAR-2	21-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	PID testing work	-
152	911	400KV-DHULE-MS-BABLESHWAR-1	21-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	PID testing work	-
153	920	400KV-PARLI-M-LONIKHAND-II-2	22-Nov-20	08:00	22-Nov-20	18:00	D	MSETCL	Routine Diagnostic testing work and Chemical Cleaning	---
154	921	400KV-RGPPL-NAGOTHANE-1	22-Nov-20	09:00	24-Nov-20	18:00	D	MSETCL	Cold washing & Faulty string replacement Work	Planned outage
155	922	400KV-TARAPUR 3&4-PADGHE-1	22-Nov-20	9:00	24-Nov-20	18:00	C	TARAPUR 3&4	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM
156	923	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	22-Nov-20	11:00	22-Nov-20	16:00	D	MSETCL	DCRM of CB 408-Q52	Station Transformer -II will remain in service through Main bay 407
157	933	400KV-SSP-DHULE-MS-2	23-Nov-20	08:00	23-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
158	937	400KV-TARAPUR 3&4-PADGHE-1	23-Nov-20	8:00	23-Nov-20	18:00	D	POWERGRID_WR2	For line AMP works. A/R OFF of ckt-2 and dia to be kept open at both ends.	PG-WR2-Boisar
159	942	220KV-MUDSHINGI-CHIKKODI-II-1	23-Nov-20	09:00	23-Nov-20	17:00	D	MSETCL	quarterly maintenance	-
160	949	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-AKOLA-EKTUNI-1 at AKOLA - 765KV	23-Nov-20	09:00	23-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
161	964	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	23-Nov-20	10:30	23-Nov-20	18:00	D	MSETCL	Diagnostic testing & routine maintenance "	Hot Sandby unit Hence on No Load
162	971	400KV/220KV BHUSAWAL-ICT-3 ON TBC @ KHADKA	23-Nov-20	09:00	25-Nov-20	17:00	C	MSETCL	For overhauling of 400 KV Bus-I & Bus-II PG isolator And CB Overhauling work	During that period ICT-3 will be shifted on 400 KV TBC bay.
163	975	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	23-Nov-20	9:00	28-Nov-20	18:00	C	POWERGRID_WR1	for replacement of old BHEL CB with new GE CB	
164	980	400KV/220KV AKOLA-ICT-2	23-Nov-20	09:00	12-Dec-20	19:00	C	MSETCL	1. Draining,filtration &refilling of oil for internal inspection of 3-phase ICT-02 due to the higher values of DGA. 2. Internal inspection work & repairing work if any abnormality observed during inspection. 3. All testing activities required before charging & maintenance work.	1.Work will be carried out by manufacturer IMP Powers limited 2.Load will be shifted on ICT-01 during outage period.
165	985	HVDC 500KV CHANDRAPUR HVDC POLE 1	23-Nov-20	08:00	30-Nov-20	18:00	C	MSETCL	Annual maintenance work of equipment in AC/DC yard of Pole-1	Pole 1 outage for annual maintenance and testing activities
166	996	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	24-Nov-20	9:00	30-Nov-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola.	
167	998	400KV-SSP-DHULE-MS-1	24-Nov-20	08:00	24-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
168	999	WARORA - 400KV - BUS 1	24-Nov-20	08:00	24-Nov-20	18:00	D	MSETCL	Routine maintainance and diagonastic testing such as CVT/ CT tandelta,and ,isolater maintenance work	400KV MAIN BUS-2 WILL BE IN SERVICE
169	1004	220KV-PARLI-HARANGUL-M-1	24-Nov-20	9:00	24-Nov-20	13:00	D	POWERGRID_WR1	For CT oil sample collection	Others
170	1009	TIE BAY - 765KV-KORADI-III-AKOLA-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	24-Nov-20	09:00	24-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
171	1019	EKTUNI - 765KV B/R 1	24-Nov-20	10:30	24-Nov-20	18:00	D	MSETCL	Diagnostic testing & routine maintenance "	765kv Bus Reactor Will be out of service
172	1029	NAGOTHANE - 400KV - BUS 1	25-Nov-20	08:00	25-Nov-20	17:00	D	MSETCL	Regular maintenance work	nil

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
173	1036	400KV-KORADI-II-KORADI-III-2	25-Nov-20	10:00	25-Nov-20	17:00	D	MSETCL	DCRM of CB 406-Q52 Tan delta measurement of Bus CT at Bay406	400KV Koradi-II Koradi-III Ckt.-1 will remain service as alternate supply.
174	1040	220KV-PARLI-PARLI-M-2	25-Nov-20	08:00	25-Nov-20	17:00	D	MSETCL	Line Maintenance	-
175	1043	400KV-SSP-DHULE-MS-2	25-Nov-20	08:00	25-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
176	1047	220KV-PARLI-PARLI-M-1	25-Nov-20	9:00	25-Nov-20	13:00	D	POWERGRID_WRI	For CT oil sample collection	Others
177	1052	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	25-Nov-20	09:00	25-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
178	1055	400KV-WARDHA-WARORA-PG-1	25-Nov-20	9:00	25-Nov-20	18:00	D	POWERGRID_WRI	Relay testing work at warora end & 400KV-WARDHA-WARORA-PG-2 A/R to be kept in non auto mode for line maintenance works for safety.	
179	1058	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	25-Nov-20	10:00	25-Nov-20	17:00	D	MSETCL	Annual Maintenance of bays equipment & Diagnostics Testing Work	ICT-1 will be in service at the time of Outage
180	1062	400KV/220KV SOLAPUR-M-ICT-2	25-Nov-20	10:00	27-Nov-20	18:00	C	MSETCL	400/220/33kV 501MVA ICT II B-Phase LV Bushing replacement.	Load will be managed on 400/220/33kV 501MVA ICT I
181	1069	NAGOTHANE - 400KV - BUS 2	26-Nov-20	08:00	26-Nov-20	17:00	D	MSETCL	Regular maintenance work	nil
182	1089	MAIN BAY - 765KV-KORADI-III-AKOLA-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	26-Nov-20	09:00	26-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
183	1093	400KV-PARLI-M-PARLI-2	26-Nov-20	09:30	26-Nov-20	18:30	D	MSETCL	Bay maintenance work.	-
184	1099	400KV-BHUSAWAL-BABLESHWAR-1 ON TBC @ BABHALESHWAR	26-Nov-20	09:00	28-Nov-20	18:00	C	MSETCL	For overhauling of 400 KV Bus-I & Bus-II PG isolator And CB Overhauling work	During that period line will be shifted on 400 KV TBC bay.
185	1100	BABLESHWAR - 400KV - TRANSFER BUS 1	26-Nov-20	09:00	5-Dec-20	18:00	C	MSETCL	CB Overhauling work	
186	1108	400KV-RGPPL-NEW KOYNA-2	27-Nov-20	9:00	30-Nov-20	18:00	C	RGPPL	New Koyna Line-2 isolator overhauling to be done.	
187	1111	400KV-RGPPL-NEW KOYNA-2	27-Nov-20	09:00	28-Nov-20	18:00	D	MSETCL	Cold washing & Faulty string replacement Work	Planned Outage
188	1115	400KV-WARDHA-WARORA-PG-2	27-Nov-20	9:00	27-Nov-20	18:00	D	POWERGRID_WRI	Relay testing work at warora end 400KV-WARDHA-WARORA-PG-1 A/R to be kept in non auto mode for line maintenance works for safety.	
189	1116	TIE BAY - 765KV-AKOLA-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	27-Nov-20	10:30	27-Nov-20	18:00	D	MSETCL	Diagnostic testing & Routine Maintenance "	765kV Akola Ckt-II will be in service through its Main (703) Bay and Main Bus-II
190	1121	400KV-SSP-DHULE-MS-1	27-Nov-20	08:00	27-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
191	1126	400KV-KOLHAPUR-MS-SOLAPUR-2	27-Nov-20	9:00	27-Nov-20	16:00	D	WTPCL	For Annual Shutdown Maintenance. AR Mode to be kept OFF for 400KV-KOLHAPUR-MS-ALKUD-1	
192	1148	400KV-SSP-DHULE-MS-2	28-Nov-20	08:00	28-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
193	1154	220KV-BOISAR-BOISAR-M-2	28-Nov-20	09:00	28-Nov-20	17:00	D	MSETCL	REPLACEMENT OF INSULATOR STRINGS	REPLACEMENT OF INSULATOR STRINGS
194	1160	TIE BAY - 765KV-KORADI-III-AKOLA-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA - 765KV	28-Nov-20	09:00	28-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
195	1161	MAIN BAY - 220KV-SOLAPUR-KUMBARI-2 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV	28-Nov-20	9:00	28-Nov-20	18:00	D	POWERGRID_WRI	BAY AMP WORKS	
196	1162	DHULE-MS - 400KV B/R 1	28-Nov-20	9:00	28-Nov-20	18:00	D	POWERGRID_WRI	for AMP works	
197	1165	220KV-TALEGAON-PUNE-PG-2	28-Nov-20	10:00	28-Nov-20	17:00	D	MSETCL	Half yearly maintenance, Diagnostic Testing	---
198	1175	400KV-KALWA-PADGHE-2	29-Nov-20	08:00	29-Nov-20	18:00	D	MSETCL	Routine Maintenance work	Routine Maintenance work
199	1180	MAIN BAY - 765KV-AKOLA-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA - 765KV	29-Nov-20	09:00	29-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities
200	1188	220KV-TARAPUR 1&2-BORIVALI-1	29-Nov-20	09:00	29-Nov-20	17:00	D	MSETCL	REPLACEMENT OF INSULATOR STRINGS	REPLACEMENT OF INSULATOR STRINGS
201	1189	400KV-SOLAPUR-M-SOLAPUR-1	29-Nov-20	9:00	29-Nov-20	17:00	D	WTPCL	For Annual Shutdown maintenance. AR Mode to be kept OFF for Ckt-2	
202	1190	220KV-WARDHA-WARDHA-M-1	29-Nov-20	9:00	29-Nov-20	18:00	D	POWERGRID_WRI	For AMP works	
203	1191	KORADI - 400KV - TRANSFER BUS 1	29-Nov-20	09:00	12-Dec-20	18:00	C	MSETCL	CB pole overhauling work	Outages will be availed subject to weather conditions.

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	Reason	Remarks
204	1192	400KV-KHARGHAR-PUNE-PG-1	30-Nov-20	9:00	30-Nov-20	18:00	D	POWERGRID_WR1	For AMP Work	Others
205	1194	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	30-Nov-20	10:30	30-Nov-20	18:00	D	MSETCL	"Diagnostic Testing & Routine Maintainece"	765kV ICT-II will be in service through its Main (713) & Main Bus II and 765 kV Bus Reactor will be in service through its Main Bay (711) & Main Bus I
206	1195	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	30-Nov-20	09:00	30-Nov-20	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
207	1197	400KV-KHARGHAR-PUNE-PG-1	30-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	Routine Diagnostic testing work and Chemical Cleaning.	---
208	1199	400KV-SSP-DHULE-MS-1	30-Nov-20	08:00	30-Nov-20	18:00	D	MSETCL	Replacement of Damaged earth wire	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
209	1203	220KV-MUDSHINGI-CHIKKODI-II-1	30-Nov-20	09:00	30-Nov-20	17:00	D	MSETCL	quarterly maintenance	-
210	1206	MAIN BAY - 765KV-KORADI-III-AKOLA-2 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	30-Nov-20	09:00	30-Nov-20	18:00	D	MEGPTCL	Bay Maintenance Activities	Bay Maintenance Activities

Maharashtra State Load Despatch Centre											
State Element Outage list for the month of November 2020											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	02-Nov-20	10:00	02-Nov-20	17:00	Daily	Tan delta measurement of Line CT at Bay 430	MSETCL	MSETCL	Load will be shifted to 400/220/33KV ICT-II
2	400 KV	PADGHE - NAGOTHANE 1	02-Nov-20	08:00	02-Nov-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
3	400 KV	NEW KOYNA-KARAD -CKT 1	02-Nov-20	09:00	02-Nov-20	18:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	Planned outage
4	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	02-Nov-20	11:00	14-Nov-20	16:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Akola- Nandgaonpeth line shall be carried out by PID unit Akola.	MSETCL	MSETCL	A/R shall be kept in non auto mode.
5	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	02-Nov-20	09:00	04-Nov-20	18:00	Daily	Replacement of old WTI & OTI by new PT100 sensor WTI & OTI of 03 Nos of 105 MVA ICT's	MSETCL	MSETCL	Load will be managed on other Two ICTs
6	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	03-Nov-20	10:00	03-Nov-20	17:00	Daily	Diagnostic testing Work	MSETCL	MSETCL	During this outage Swt. ckt. I will be in service
7	400 KV	PADGHE - NAGOTHANE 2	03-Nov-20	08:00	03-Nov-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
8	400 KV	NEW KOYNA -KARAD -CKT 2	04-Nov-20	09:00	04-Nov-20	18:00	Daily	Diagnostic testing & Relay testing work	MSETCL	MSETCL	Planned outage
9	400 KV	SPARE LINE-I BAY (401) @ TAPTITANDA	04-Nov-20	11:00	04-Nov-20	17:00	Daily	1. CT , Tan delta measurement 2. Routine maint. work	MSETCL	MSETCL	Nil
10	400 KV	CHANDRAPUR - KHAPERKHEDA	04-Nov-20	08:00	04-Nov-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
11	400 KV	WARORA - IEPL	04-Nov-20	09:00	04-Nov-20	17:00	Daily	1) Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work. 2) Bay NO 418 CB Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
12	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	05-Nov-20	08:00	05-Nov-20	18:00	Daily	Routine Diagnostic testing and bay maintenance work.	MSETCL	MSETCL	---
13	400 KV	MAIN BAY (419) OF 400/220/33kv 500MVA ICT-I @ LONIKAND 2	05-Nov-20	09:00	05-Nov-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption.
14	400 KV	TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	05-Nov-20	10:00	05-Nov-20	16:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Yelwan ckt-02 will be in service through main bay 417
15	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	05-Nov-20	09:30	05-Nov-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	400/220KV ICT-No. I & II will be in service.
16	400 KV	TIE BAY 418 OF ICT-I @ LONIKAND 2	05-Nov-20	09:00	05-Nov-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption.
17	400 KV	400/220/33 KV 315MVA ICT - 3 @ KARAD	05-Nov-20	09:00	06-Nov-20	18:00	Daily	Replacement of old WTI & OTI by new PT100 sensor WTI & OTI of 315 MVA ICT's	MSETCL	MSETCL	Load will be managed on other ICT's
18	400 KV	KHADKA-AURANGABAD	05-Nov-20	09:00	05-Nov-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
19	400 KV	TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	06-Nov-20	10:00	06-Nov-20	16:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Yelwan ckt-01 will be in service through main bay 414
20	400 KV	DHULE- - BABLESHWAR - I	06-Nov-20	09:00	06-Nov-20	17:00	Daily	line maintenance work	MSETCL	MSETCL	400kV Babhaleshwar-Dhule -II will be in service
21	400 KV	KARAD - TALANDGE CKT 2	06-Nov-20	08:00	06-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
22	400 KV	TBC @ KORADI-I	06-Nov-20	09:00	06-Nov-20	18:00	Daily	CB CRM DCRM Timing	MSETCL	MSETCL	The outage is taken to shift the 400kV Koradi- Khaperkheda Ckt 2 on TBC. The outage will be availed subject to weather conditions.
23	400 KV	JEJURI- KOYNA STAGE-IV	07-Nov-20	08:00	07-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
24	400 KV	KORADI-KHAPERKHEDA II	07-Nov-20	09:00	07-Nov-20	18:00	Daily	Relay testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
25	400 KV	KARAD - TALANDGE CKT 1	07-Nov-20	08:00	07-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
26	400 KV	DHULE- - BABLESHWAR - II	07-Nov-20	09:00	07-Nov-20	17:00	Daily	line maintenance work	MSETCL	MSETCL	400kV Babhaleshwar-Dhule -I will be in service
27	400 KV	NEW KOYNA -KARAD -CKT 2	09-Nov-20	08:00	09-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
28	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	09-Nov-20	08:30	09-Nov-20	11:00	Daily	Main bus CT tan delta testing work	MSETCL	MSETCL	due for dignostic testing as per yearly plan

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
29	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	09-Nov-20	09:00	09-Nov-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
30	400 KV	125MVAr BUS REACTOR @ WARORA	09-Nov-20	09:00	09-Nov-20	18:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work.	MSETCL	MSETCL	During outage reactor is in off condition
31	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	09-Nov-20	09:00	09-Nov-20	18:00	Daily	1. QM Work 2. C & tan delta testing of ICT Bushing & Wdg	MSETCL	MSETCL	Monday is road staggering day in Kolhapur. Also, if load on ICT 3 at 400kV Talandge is not managed then 220kV Talandge must be taken off to avoid this
32	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	09-Nov-20	08:00	09-Nov-20	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
33	400 KV	NEW KOYNA -KARAD-CKT 2	10-Nov-20	08:00	10-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
34	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	10-Nov-20	08:00	10-Nov-20	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
35	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	10-Nov-20	09:00	10-Nov-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
36	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	11-Nov-20	09:00	11-Nov-20	18:00	Daily	Routine maintenance & testing Work.	MSETCL	MSETCL	1.400 kv Akola- Bhusawal line is in service 2.400 kv Koradi Nandgaon Line is in service
37	400 KV	400/220/33KV 500 MVA ICT - 1 @ KUDUS	11-Nov-20	10:00	11-Nov-20	17:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work of ICT-1 and Bay 408 for safety purpose.	MSETCL	MSETCL	DG will be in service at the time of Outage.
38	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	11-Nov-20	10:00	11-Nov-20	17:00	Daily	Diagnostic Testing Work of Circuit Breaker	MSETCL	MSETCL	NA
39	400 KV	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	11-Nov-20	10:00	11-Nov-20	17:00	Daily	DCRM of CB 430-Q52 Tan delta measurement of Bus CT at Bay 430	MSETCL	MSETCL	ICT-1 will remain in service through its Tie bay 429
40	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	11-Nov-20	08:00	11-Nov-20	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
41	400 KV	STATION TF 8B @ CHANDRAPUR SWITCHING	12-Nov-20	09:00	12-Nov-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
42	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	12-Nov-20	09:00	12-Nov-20	18:00	Daily	1. C & Tan delta measurement of CTs. 2. Bay maintenance work. 3. Line Maintenance Work	MSETCL	MSETCL	-
43	400 KV	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	12-Nov-20	09:30	12-Nov-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	Tie CB.
44	400 KV	LONIKAND 1 - KOYNA STAGE-IV	14-Nov-20	08:00	14-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
45	400 KV	AKOLA - KHADKA (BHUSAWAL)	16-Nov-20	08:00	30-Nov-20	16:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Akola- Bhusawal line shall be carried out by PID unit Akola.	MSETCL	MSETCL	A/R shall be kept in non auto mode.
46	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	17-Nov-20	08:00	17-Nov-20	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode
47	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	18-Nov-20	09:30	18-Nov-20	18:30	Daily	1. Bay maintenance work. 2 Line Maintenance Work	MSETCL	MSETCL	-
48	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	18-Nov-20	10:00	20-Nov-20	18:00	Continuous	Replacement of 52kV Territory Bushing of 400/220/33KV Spare ICT.	MSETCL	MSETCL	Uninterrupted load as it is of spare unit.
49	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	18-Nov-20	10:00	18-Nov-20	17:30	Daily	Quarterly Maint. Work & Diagnostic Testing Work	MSETCL	MSETCL	NA
50	400 KV	DEEPNAGAR - THAPTI TANDA	18-Nov-20	09:00	18-Nov-20	17:00	Daily	Routine Maint. of 400kV Deepnagar Thaptitanda @ waluj end	MSETCL	MSETCL	Routine Maint. of 400kV Deepnagar Thaptitanda @ waluj end
51	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	19-Nov-20	10:00	19-Nov-20	17:30	Daily	Quarterly Maint. Work & Diagnostic Testing Work	MSETCL	MSETCL	NA
52	400 KV	MAIN BAY (408) OF ICT - 3 @ JEJURI	19-Nov-20	09:30	19-Nov-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
53	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	19-Nov-20	09:00	19-Nov-20	18:00	Daily	1. HV backup relay & HV CTs testing work. 2. Bay maintenance work.	MSETCL	MSETCL	-
54	400 KV	GTR - 8 @ CHANDRAPUR SWITCHING SS	19-Nov-20	09:00	19-Nov-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
55	400 KV	LONIKAND 1 - KOYNA STAGE-IV	20-Nov-20	08:00	20-Nov-20	18:00	Daily	Routine Diagnostic testing and bay maintenance work.	MSETCL	MSETCL	---
56	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	20-Nov-20	10:00	20-Nov-20	15:00	Daily	DCRM of CB 429-Q52	MSETCL	MSETCL	ICT-1 will remain in service through its main Bay 430
57	400 KV	KHADKA - BABLESHWAR	20-Nov-20	09:00	20-Nov-20	17:00	Daily	line maintenance work	MSETCL	MSETCL	-
58	400 KV	MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	20-Nov-20	08:30	20-Nov-20	11:30	Daily	Main CT Tan delta testing work	MSETCL	MSETCL	due for dignostic testing as per yearly plan
59	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	20-Nov-20	09:00	20-Nov-20	17:00	Daily	Quarterly Maintenance of bay	MSETCL	MSETCL	Quarterly Maintenance

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
60	400 KV	400 KV KHADKA-KORADI CKT	21-Nov-20	8:00	21-Nov-20	18:00	Daily	For testing and routine bay maintenance work	MSETCL	MSETCL	
61	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	21-Nov-20	09:00	21-Nov-20	17:00	Daily	line maintenance work	MSETCL	MSETCL	-
62	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	21-Nov-20	08:00	21-Nov-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
63	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	21-Nov-20	08:00	21-Nov-20	17:00	Daily	Routine maintenance work & For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt-III are on DC tower so both lines require on same day A/R out.
64	400 KV	500 MVA 400/220 KV ICT - II @ Chandrapur 2	23-Nov-20	09:00	24-Nov-20	18:00	Continuous	Applying high insulation resistance coating on tertiary side equipment like 33KV PT, BPLIPS tube, LA & tertiary bushings.	MSETCL	MSETCL	Above work will carried in continuous for two days, during this outage ICT-1 will be in service.
65	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	23-Nov-20	09:00	23-Nov-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned Outage
66	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	24-Nov-20	09:00	24-Nov-20	18:00	Daily	1. IV CTs and breaker testing work. 2. Bay maintenance work.	MSETCL	MSETCL	-
67	400 KV	400/220 KV 500 MVA ICT @ ALKUD	24-Nov-20	10:00	24-Nov-20	17:30	Daily	Quarterly maintenance work and diagnostic testing work	MSETCL	MSETCL	NA
68	400 KV	400/220/33KV 3x105 MVA ICT-I @ KHARGHAR	24-Nov-20	9:00	24-Nov-20	17:00	Daily	For routine maintenance & Diagnostic Test	MSETCL	MSETCL	400KV ICT-II & ICT-III will be in service.
69	400 KV	NEW KOYNA-KARAD-CKT 1	25-Nov-20	08:00	25-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
70	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	25-Nov-20	08:00	25-Nov-20	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	Nil
71	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	25-Nov-20	08:00	25-Nov-20	14:00	Daily	ICt LV CT & HV Transformer CT tan delta testing work & Bay maint work	MSETCL	MSETCL	due for dignostic testing as per yearly plan
72	400 KV	JEJURI- KOYNA STAGE-IV	26-Nov-20	08:00	26-Nov-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
73	400 KV	400/220kV SPARE ICT @ JEJURI	26-Nov-20	09:30	26-Nov-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	---
74	400 KV	500 MVA 400/220 KV ICT - I @ Chandrapur 2	26-Nov-20	09:00	27-Nov-20	18:00	Continuous	Applying high insulation resistance coating on tertiary side equipments like 33KV PT, BPI, IPS tube, LA.	MSETCL	MSETCL	This outage will be carried out for two continuous days. During this outage ICT-2 will be in service.
75	400 KV	GTR - 9 @ CHANDRAPUR SWITCHING SS	26-Nov-20	09:00	26-Nov-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
76	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	26-Nov-20	09:00	26-Nov-20	17:00	Daily	Half yearly testing and maintenance activities.	MSETCL	MSETCL	---
77	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	26-Nov-20	10:00	26-Nov-20	18:00	Daily	For Annual Tan-d of ICT Bushings, Winding & Relay testing work	MSETCL	MSETCL	-
78	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	27-Nov-20	08:00	27-Nov-20	18:00	Daily	Routine Diagnostic testing and bay maintenance work.	MSETCL	MSETCL	---
79	400 KV	400/220kV 315 MVA ICT-II @ KHARGHAR	27-Nov-20	9:00	27-Nov-20	17:00	Daily	R&M Work and Diagnostic testing Work	MSETCL	MSETCL	ICT-I & ICT-III will be in service.
80	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	28-Nov-20	09:00	28-Nov-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
81	400 KV	CHANDRAPUR-PARLI CKT-3	29-Nov-20	08:00	29-Nov-20	17:00	Daily	Routine maintenance work & For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt-III these lines are on DC tower so both lines require on same day A/R out.
82	400 KV	NEW KOYNA - STAGE IV CKT 1	29-Nov-20	09:00	29-Nov-20	18:00	Daily	Cold washing & Faulty string replacement Work	MSETCL	MSETCL	Planned Outage
83	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	30-Nov-20	08:00	30-Nov-20	17:00	Daily	Routine Maint.work & For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt-III are on DC tower so both lines require on same day A/R out.
84	400 KV	NEW KOYNA - STAGE IV CKT 2	30-Nov-20	09:00	30-Nov-20	18:00	Daily	Cold washing & Faulty string replacement Work	MSETCL	MSETCL	Planned Outage
85	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	30-Nov-20	08:00	30-Nov-20	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	400/220kV 315MVA ICT- I & 501 MVA ICT -III& 501 MVA ICT-IV will be in service
86	400 KV	KARAD - TALANDGE CKT 1	30-Nov-20	09:00	30-Nov-20	18:00	Daily	QM Work CT Tan delta measurement CB Timing DCRM measurement work	MSETCL	MSETCL	Monday is load Staggering day in kolhapur. Loan will be managed on 400kV Talandge-Karad 2 line.