

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of NOVEMBER' 2022

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks	
1	3	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY - 400KV/220KV PADGHE-ICT-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	Continuo us	1) Replacement of old Bhel make CB with new CGL make CB of HV side under LES scheme . (ICT will be in service through TBC) 2) Replacement of B bus all phase PG isolator	31/Oct/22	09:30	10/Nov/22 22:51	1) Weather condition should be clear 2) Agency will be present on site for the work .
2	4	PLANNED	OCC_560	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	Continuo us	1) Replacement of Hanger assembly of all phases B bus PG isolator of 315MVA ICT-2 (All elements on bus 1 and bus 2 will be in service only hot line work for 3 days)	31/Oct/22	11:00	10/Nov/22 17:00	1) Weather condition should be clear for HOT line work
3	6	PLANNED	OCC_560	POWERGRID_WRI	400KV/220KV PUNE-PG-ICT-1	D	For AMP and Realy testing works.	1/Nov/22	7:00	1/Nov/22 18:00	
4	32	PLANNED	OCC_560	POWERGRID_WRI	400KV-PUNE-GIS-PARLI-1	Daily	For AMP and relay testing works	1/Nov/22	9:00	1/Nov/22 18:00	
5	50	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	1/Nov/22	08:00	2/Nov/22 18:00	NA
6	51	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	1/Nov/22	08:00	2/Nov/22 18:00	.
7	52	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-LONIKHAND-PUNE-PG-1 AND LONIKHAND - 400KV - BUS 1 @LONIKHAND - 400KV at LONIKHAND - 400KV	Continuo us	O/H & Serviceing of 29B PG isolator & Replacement of PGI mechanism box.(line will be shifted on TBC)	1/Nov/22	08:00	2/Nov/22 20:00	Line to be shifted on TBC
8	53	PLANNED	OCC_560	MSLDC_OUTAGE	Pole-2 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC(Element not found)	Continuo us	To carry out the work of replacing interconnecting jumpers of AC filter capacitor bank & its accessories like washer, clapms, round bars etc. It is necessary to carry out above work to nullify the frequent Hotspots in filter.	1/Nov/22	08:00	2/Nov/22 22:00	1.Work will be carried out through agency i.e. M/s BHEL. 2) Both Pole will be in service & there is no Power Restriction . 3)Pole-1 Z3 filter will be available.
9	59	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	Daily	To carryout PID scanning	1/Nov/22	08:00	3/Nov/22 18:00	-
10	64	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	1) Replacement of rusted hardware under R&M Scheme. 2) Line Maintenance work. 3) Bay maintenance at 220KV Boisar-II S/stn	1/Nov/22	07:00	4/Nov/22 17:00	1) Replacement of rusted hardware under R&M Scheme. 2) Line Maintenance work. 3) Bay maintenance at 220KV Boisar-II S/stn
11	65	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	1/Nov/22	09:00	4/Nov/22 18:00	PID Testing of Insulators Auto-Reclose function to be out of service.
12	68	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	08:00	5/Nov/22 17:00	-
13	70	PLANNED	OCC_560	MSLDC_OUTAGE	TBC @ KOLHAPUR(TALANDGE) (ELEMENT NOT FOUND)	Continuo us	Overhauling of A bus, B Bus, C Bus PG isolators.	1/Nov/22	09:00	7/Nov/22 23:59	Overhauling of A bus, B Bus, C Bus PG isolators.
14	73	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-2	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	1/Nov/22	08:00	12/Nov/22 18:00	.
15	76	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	Daily	PID testing work	1/Nov/22	08:00	15/Nov/22 18:00	-
16	77	PLANNED	OCC_560	WTPL	400KV-KHARGHAR-PUNE-PG-1	Continuo s	Line diversion work due to expansion of MIDC road at Talegaon	1/Nov/22	9:00	15/Nov/22 18:00	
17	78	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	Daily	PID testing	1/Nov/22	10:00	15/Nov/22 18:00	without load interruption
18	79	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	1/Nov/22	08:00	17/Nov/22 18:00	.
19	82	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	for replacement of heavily Rusted Hardware along with replacement of all insulator strings and rusted hardware at replacement of old conductor with new conductor	1/Nov/22	7:00	30/Nov/22 17:00	NIL
20	106	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	Daily	OPGW Stringing and removal of Earthwire work on Ektuni-Thapatitanda Ckt-1 by MTCIL	1/Nov/22	08:00	30/Nov/22 18:00	Work will be carried out by MTCIL
21	107	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	Daily	OPGW Stringing and removal of Earthwire work on Ektuni-Thapatitanda Ckt-1 by MTCIL	1/Nov/22	08:00	30/Nov/22 18:00	Work will be carried out by MTCIL
22	117	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	09:00	30/Nov/22 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
23	118	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	09:00	30/Nov/22 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
24	119	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	09:00	30/Nov/22 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
25	120	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	09:00	30/Nov/22 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
26	121	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	09:00	30/Nov/22 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
27	122	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1/Nov/22	09:00	30/Nov/22 17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
28	123	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	Daily	PID Testing Hotline Work	1/Nov/22	09:00	30/Nov/22 17:00	-
29	124	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	Daily	PID Testing Hotline Work	1/Nov/22	09:00	30/Nov/22 17:30	-
30	128	PLANNED	OCC_560	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-	Continuo s	AR in non auto for replacement of Faulty insulators in Live line method	1/Nov/22	9:00	30/Nov/22 18:00	
31	129	PLANNED	OCC_560	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	Continuo s	AR in non auto due to planned annual maintenance of 220KV LILO Jeur - Solapur	1/Nov/22	9:00	30/Nov/22 18:00	
32	130	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	Daily	PID testing work.	1/Nov/22	09:00	30/Nov/22 18:00	-
33	131	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	Daily	Online PID work	1/Nov/22	10:00	30/Nov/22 14:00	Auto recloser switch to be kept on non auto for 400 KV Dhule- SSNNL ckt 1
34	132	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	Daily	Online PID work	1/Nov/22	10:00	30/Nov/22 14:00	Auto reclose switch to be keep on non auto mode for 400 KV Dhule- SSNNL ckt 2
35	133	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	Daily	For PID work, Shifting of auto reclose switch to non auto mode	1/Nov/22	11:00	30/Nov/22 15:00	-

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
36	144	PLANNED	OCC_560	POWERGRID_WR1	WARDHA - 400KV - BUS 2	D	Bus Splitting converting bus#2 into bus2A and bus2B for charging of Series Reactor under substation package SS11 (new construction element) and Isolator upgradation work	2/Nov/22	6:00	4/Nov/22	18:00	
37	145	PLANNED	OCC_560	POWERGRID_WR1	AURANGABAD - 220KV - TRANSFER BUS 1	D	For Bus AMP	2/Nov/22	7:00	2/Nov/22	18:00	
38	146	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND 400KV-PUNE-GIS-PUNE-PG-3 at PUNE-PG - 400KV	D	For AMP WORK	2/Nov/22	7:00	2/Nov/22	18:00	
39	147	PLANNED	OCC_560	POWERGRID_WR1	400KV/220KV SOLAPUR-ICT-1	Daily	For AMP Works and relay testing works Note : Dia to be kept open	2/Nov/22	7:00	2/Nov/22	18:00	
40	155	PLANNED	OCC_560	POWERGRID_WR1	WARDHA - 400KV - BUS 1	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.	2/Nov/22	8:00	2/Nov/22	19:00	4BB1
41	159	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-PARLI-SOLAPUR-2 AND 400KV-DHARIWAL-PARLI-1	D	AMP Work	2/Nov/22	8:30	2/Nov/22	18:00	
42	169	PLANNED	OCC_560	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment	2/Nov/22	09:00	2/Nov/22	18:00	Annual Maintenance of Bay Equipment
43	187	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.	2/Nov/22	14:00	2/Nov/22	19:00	413L
44	192	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	Daily	Cold washing work	2/Nov/22	08:00	5/Nov/22	18:00	Planned Outage
45	208	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-1	Daily	DT & Line Maintenance, Cold line washing	3/Nov/22	08:00	3/Nov/22	18:00	NIL
46	209	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARIAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	Daily	Diagnostic testing and Maintenance(line outage required)	3/Nov/22	08:00	3/Nov/22	18:00	NIL
47	210	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Maintenance work.	3/Nov/22	08:00	3/Nov/22	18:00	.
48	211	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	Daily	OPGW Stringing and removal of Earthwire work on Ektuni-Thapatitanda Ckt-1 by MTCIL	3/Nov/22	08:00	3/Nov/22	18:00	Work will be carried out by MTCIL
49	212	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND FUTURE at LONIKHAND-II - 400KV	Daily	Diagnostic testing and Maintenance(line outage required)	3/Nov/22	08:00	3/Nov/22	18:00	NIL
50	227	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-2 AND PARLI - 400KV - BUS 2	D	AMP Work	3/Nov/22	8:30	3/Nov/22	18:00	
51	232	PLANNED	OCC_560	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	3/Nov/22	09:00	3/Nov/22	18:00	Annual Maintenance of Bay Equipment
52	233	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	Continuous	(1) Main-2 distance relay testing. (2)Bay maintenance work. (3) Hardware tightening & fitting work.	3/Nov/22	09:00	3/Nov/22	18:00	-
53	234	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	Daily	For Replacement of PID Suspecious Disc & other Maintenance work.	3/Nov/22	09:00	3/Nov/22	18:00	400 KV DHL-SSNNL CKT 2 A/R switch will be put on Non Auto mode.
54	253	PLANNED	OCC_560	MSLDC_OUTAGE	BUS COUPLER BAY - AURANGABAD-M (WALUJ) - 400KV - BUS 1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 2	Daily	1) Diagnostic Testing Work 2) Routine Maintenance Work	3/Nov/22	10:00	3/Nov/22	18:00	NIL
55	260	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	Daily	O/H & Serviceing of 29C PG Isolator & Replacement of PGI mechanism box.	3/Nov/22	08:00	4/Nov/22	20:00	NIL
56	261	PLANNED	OCC_560	MSLDC_OUTAGE	Pole-2 Non base AC filter 24 (80 MVAR) @ Chandrapur HVDC(Element not found)	Continuous	To replace interconnecting jumpers of AC Filter capacitor bank & its accessories like Clamps, Round bar, Washers etc. It is necessary to carry out above work to avoid frequent Hotspots in AC filter.	3/Nov/22	08:00	4/Nov/22	22:00	1.Work will be carried out through agency i.e. M/s BHEL 2) Both Pole will be in service & there is no Power Restriction . 3)Pole-1 24 filter will be available.
57	269	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND FUTURE at LONIKHAND-II - 400KV	Daily	Diagnostic testing and Maintenance	4/Nov/22	08:00	4/Nov/22	18:00	NIL
58	272	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	415 Bay AMP	4/Nov/22	7:00	4/Nov/22	18:00	
59	273	PLANNED	OCC_560	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-2	D	For AMP and Realy testing works.	4/Nov/22	7:00	4/Nov/22	18:00	
60	275	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.AR to be kept in non Auto mode for 400KV-WARDHA-Aurangabad-2	4/Nov/22	8:00	4/Nov/22	13:00	422L
61	281	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	4/Nov/22	08:00	4/Nov/22	18:00	NA
62	295	PLANNED	OCC_560	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	For AMP works	4/Nov/22	9:00	4/Nov/22	17:30	PG-WR2-BOISAR
63	297	PLANNED	OCC_560	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment	4/Nov/22	09:00	4/Nov/22	18:00	Annual Maintenance of Bay Equipment
64	314	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-2	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.AR to be kept in non Auto mode for 400KV-WARDHA-Aurangabad-1	4/Nov/22	14:00	4/Nov/22	19:00	425L
65	315	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	4/Nov/22	08:00	5/Nov/22	17:00	--
66	320	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	Daily	To carryout PID scanning	4/Nov/22	08:00	6/Nov/22	18:00	-
67	322	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	C	Conductor replacement in span between loc. No. 33 to 34 for all phases, and replacement of discs type insulator with AF long rod insulator at loc 33 and 34(Talegaon side).	4/Nov/22	07:00	7/Nov/22	18:00	NIL
68	323	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	4/Nov/22	08:00	8/Nov/22	17:00	---
69	324	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	4/Nov/22	08:00	8/Nov/22	17:00	--
70	327	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	4/Nov/22	08:00	9/Nov/22	18:00	.
71	329	PLANNED	OCC_560	POWERGRID_WR1	220KV-RAIPUR-URLA-CHHATTISGARH-1	D	220KV Busbar retrofitting works	5/Nov/22	15:00	5/Nov/22	17:30	220KV Busbar retrofitting works

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
72	330	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV- WARDHA-AKOLA-1	5/Nov/22	8:00	5/Nov/22	13:00	416L
73	334	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	Daily	For Replacement of PID Suspecious Disc & other Maintenance work.	5/Nov/22	09:00	5/Nov/22	18:00	400 KV DHL-SSNNL CKT 2 A/R switch will be put on Non Auto mode.
74	337	PLANNED	OCC_560	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-1	D	For AMP WORK	5/Nov/22	7:00	5/Nov/22	18:00	
75	342	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	Daily	All diagnostic testing work, Bay Bay maintenance work.	5/Nov/22	08:00	5/Nov/22	18:00	All diagnostic testing work, Bay Bay maintenance work.
76	355	PLANNED	OCC_560	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	Daily	Updating Siemens Distance Relay to Comply IEC61850 and Resolving Front Port Communication Issue of M1 Relay of Padghe Boisar Line at Padghe MSETCL SS.	5/Nov/22	9:00	5/Nov/22	17:00	400 KV Padghe Boisar LINE will be out of service.
77	356	PLANNED	OCC_560	POWERGRID_WR2	BUS COUPLER BAY - BOISAR - 220KV - BUS 1 AND BOISAR - 220KV - BUS 2 at BOISAR - 220KV	D	For AMP works	5/Nov/22	9:00	5/Nov/22	17:30	PG-WR2-BOISAR
78	358	PLANNED	OCC_560	MEGPTCL	TIE BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-AKOLA (2)-EKTUNI-1 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	5/Nov/22	09:00	5/Nov/22	18:00	Annual Maintenance of Bay Equipment
79	376	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	Daily	Chemical Cleaning of insulator string and Routine Line maintenance work	5/Nov/22	08:00	6/Nov/22	18:00	400KV Ektuni ckt I&II,400KV Aurangabad , Dhule I&II will be in in service
80	377	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR-M - 220KV - BUS 1 @BOISAR-M - 220KV at BOISAR-M - 220KV	Continuo us	CB Overhauling Work by shifting the line on TBC.	5/Nov/22	09:00	6/Nov/22	17:00	BOISAR II - BOISAR (PG) CKT - 3 will be in service through TBC.
81	378	PLANNED	OCC_560	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	Continuo us	Annual Maintenance work AC & DC yard Equipment, Valve Hall,Diagnostic testing, Line Maintenance, etc.	5/Nov/22	08:00	12/Nov/22	22:00	Pole-1 will be service with in 750 MW
82	379	PLANNED	OCC_560	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	Continuo us	Replacement of A bus PG Isolator Hanger Assembly of 400 kV HVDC- 2 Bay by hot line	5/Nov/22	09:00	12/Nov/22	17:00	Weather condition should be clear
83	380	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-2	Continuo us	1. Bay maint. work 2. Diagnostic testing work 3. Bhel CB Pole Overhauling work 4. A bus PG Isolator Replacement work under LES 5. If pole Overhauling work not completed due to any reason line will be charge on TBC. 6. Hot line work for Replacement of Hanger assembly of A bus PG Isolator 7. Outage Should be Reschedule with annual outage of HVDC Pole if any date change .	5/Nov/22	09:00	12/Nov/22	21:00	1. Weather condition should be clear for pole overhauling and PG Isolator Replacement
84	389	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Daily	For restoration of 400KV Kalwa -Padgha ckt 2 from diverted route to its original rout (400KV Kalwa-Padgha-@ line is proposed to be diverted between loc no. 3 to 46 on 400KV Padgha-Kharghar dead line on 01.10.2022) .	6/Nov/22	06:00	6/Nov/22	18:00	For restoration of 400KV Kalwa -Padgha ckt 2 from diverted route to its original rout (400KV Kalwa-Padgha-@ line is proposed to be diverted between loc no. 3 to 46 on 400KV Padgha-Kharghar dead line on 01.10.2022) .
85	393	PLANNED	OCC_560	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Line Bay AMP works & attedning Shutdown nature defects	6/Nov/22	7:00	6/Nov/22	18:00	400KV-KOLHAPUR MS-KOLHAPUR GIS-1 AR to be kept in Non-auto mode for safety in TLM works.
86	394	PLANNED	OCC_560	KAPP	220 KV KAPS-UKAI -MOTA Line	Countino us	Bay APM check with 220KV Main Bus#2	6/Nov/22	8:00	6/Nov/22	20:00	
87	395	PLANNED	OCC_560	POWERGRID_WR2	400KV-KALA-KUDUS-1	D	For Line AMP works by Vapi TLM. A/R off of Ckt 2 and Dia to be kept open at both ends.	6/Nov/22	9:00	6/Nov/22	18:00	PG-WR2-VAPI
88	397	PLANNED	OCC_560	POWERGRID_WR2	400KV-KALA-KUDUS-2	D	For Line AMP works by Vapi TLM. A/R off of Ckt 1 and Dia to be kept open at both ends.	6/Nov/22	9:00	6/Nov/22	18:00	PG-WR2-VAPI
89	400	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-AURANGABAD-M (WALUJ)- AURANGABAD-2 AND 400KV/220KV AURANGABAD- ICT-3 at AURANGABAD - 400KV	D	408 Bay AMP	7/Nov/22	7:00	7/Nov/22	18:00	
90	401	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-KALWA-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-3 at PUNE-PG - 400KV	D	For AMP WORK	7/Nov/22	7:00	7/Nov/22	18:00	
91	403	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-4 AND BHADRAWATI - 400KV - BUS 2 at BHADRAWATI - 400KV	Daily	AMP WORK	7/Nov/22	7:00	7/Nov/22	18:00	AMP WORK
92	405	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV- WARDHA-AKOLA-1	7/Nov/22	8:00	7/Nov/22	13:00	416L
93	406	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	For insulator strings cleaning at T.L no 282 to 295 in MIDC area.	7/Nov/22	08:00	7/Nov/22	16:00	Other 220kV lines at 220 KV Mudshingi s/s will be in service.
94	416	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	Daily	For Replacement of Flashover Disc by Cold Line Method	7/Nov/22	09:00	7/Nov/22	17:00	.
95	420	PLANNED	OCC_560	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	D	For Line AMP works. A/R OFF OF CKT # 1 AND DIA TO BE KEPT OPEN AT BOTH ENDS.	7/Nov/22	9:00	7/Nov/22	17:30	PG-WR2-BOISAR
96	423	PLANNED	OCC_560	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	7/Nov/22	09:00	7/Nov/22	18:00	Annual Maintenance of Bay Equipment
97	448	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	7/Nov/22	08:00	8/Nov/22	17:00	---
98	450	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing work	7/Nov/22	08:00	8/Nov/22	18:00	Planned outage
99	457	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-LONIKHAND-JEJURI-1 AND JEJURI - 400KV - BUS 2 @JEJURI - 400KV at JEJURI - 400KV	Continuo us	O/H & Servicing of 29A PG Isolator & Replacement of Pgi mechanism box.(line will be shifted on TBC)	7/Nov/22	08:00	9/Nov/22	20:00	Line to be shifted on TBC
100	459	PLANNED	OCC_560	TAPS-3&4	220KV-TARAPUR 3&4-BOISAR(Line-2)	C	To implement Distance Protection Scheme	7/Nov/22	9:00	10/Nov/22	19:00	Sample Remarks
101	460	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	7/Nov/22	08:00	11/Nov/22	17:00	---
102	462	PLANNED	OCC_560	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1	Continuo us	For attending SF6 gas leakage .	7/Nov/22	9:00	10/Nov/22	18:00	
103	465	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	Daily	PID testing of insulator strings	7/Nov/22	08:00	12/Nov/22	18:00	NIL
104	466	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	Daily	To carryout PID scanning	7/Nov/22	08:00	12/Nov/22	18:00	-

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
105	469	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	7/Nov/22	09:00	12/Nov/22	18:00	PID Testing of Insulators Auto-Reclose function to be out of service.
106	470	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV PARLI-M-ICT-2 AND PARLI-M - 400KV - BUS 1 @PARLI-M - 400KV at PARLI-M - 400KV	Continuous	Overhauling of 400KV Circuit Breaker (CGL Make) of 400/220KV, 315 MVA ICT-2 @ Girwal. 400/220KV, 315 MVA ICT-2 @ Girwal will remain charged through TBC	7/Nov/22	09:00	12/Nov/22	18:00	400/220KV, 315 MVA ICT-2 @ Girwal will remain charged through TBC
107	477	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 220KV-PUNE-PG-URSE-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	For AMP WORK	8/Nov/22	7:00	8/Nov/22	18:00	
108	478	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-3 AND BHADRAWATI - 400KV - BUS 1 at BHADRAWATI - 400KV	Daily	AMP WORK	8/Nov/22	7:00	8/Nov/22	18:00	AMP WORK
109	479	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV-WARDHA-AURANGABAD-2	8/Nov/22	8:00	8/Nov/22	13:00	422L
110	484	PLANNED	OCC_560	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	Daily	To carry out all Diagnostic Testing work including DCRM, CT Tan Delta etc	8/Nov/22	08:00	8/Nov/22	17:00	To carry out all Diagnostic Testing work including DCRM, CT Tan Delta etc
111	493	PLANNED	OCC_560	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment	8/Nov/22	09:00	8/Nov/22	18:00	Annual Maintenance of Bay Equipment
112	499	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-2	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. AR to be kept in non Auto mode for 400KV-WARDHA-AURANGABAD-1	8/Nov/22	14:00	8/Nov/22	19:00	425L
113	502	PLANNED	OCC_560	RGPL	400KV-RGPL-Nagothane Line-1	Daily	Replacement of Surge Arrestor for all the three poles	8/Nov/22	8:00	10/Nov/22	18:00	
114	503	PLANNED	OCC_560	MSLDC_OUTAGE	TBC @ KHARGHAR(ELEMENT NOT FOUND)	Continuous	400KV CB Mechanism Overhauling work	8/Nov/22	08:00	11/Nov/22	18:00	No load on TBC
115	504	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARAD-KOLHAPUR-MS-2 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV(ELEMENT NOT FOUND)	Continuous	Overhauling of A bus, B Bus PG isolators (line will be shifted on TBC bay)	8/Nov/22	09:00	12/Nov/22	23:59	The bay will be shifted online on 400 kv TBC.
116	509	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-KARAD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	Daily	Bay AMP Works	9/Nov/22	7:00	9/Nov/22	18:00	
117	511	PLANNED	OCC_560	MSLDC_OUTAGE	KORADI - 400KV - BUS 2	Daily	Outage on 400KV BUS-2 required for attending 400KV khaperkheda Ckt-2 29B B phase PG isolator rotary problem.	9/Nov/22	07:00	9/Nov/22	22:00	Outages will be availed subject to weather conditions.
118	516	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	Daily	Routine Maintenance & Dignostic testing work restringing of bottom ph conductor.	9/Nov/22	08:00	9/Nov/22	18:00	NA
119	528	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.	9/Nov/22	8:00	9/Nov/22	19:00	413L
120	531	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	Daily	Routine Maintenance & Dignostic testing work .	9/Nov/22	09:00	9/Nov/22	17:00	400KV WARORA-IEPL Line is in ckt
121	532	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-HALKARNI-1	Daily	For cold washing of Bus & Bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments.	9/Nov/22	09:00	9/Nov/22	17:00	220KV Halkarni-Tilari Line & 220KV Tilari-Amona Line will be in service.
122	533	PLANNED	OCC_560	MSLDC_OUTAGE	132KV-PENCH-MP-KANHAN-1	Daily	Routine Maintenance work.	9/Nov/22	09:00	9/Nov/22	17:00	NA
123	534	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	Daily	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode. For PID work, Shifting of auto reclose switch to non auto mode.	9/Nov/22	09:00	9/Nov/22	17:00	.
124	540	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	Continuous	Line / s/s Maintenance	9/Nov/22	09:00	9/Nov/22	17:30	-
125	542	PLANNED	OCC_560	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA -765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	9/Nov/22	09:00	9/Nov/22	18:00	Annual Maintenance of Bay Equipment
126	543	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	Daily	Annual maintenance work. At 220KV Mahalaxmi S/s for cold washing of Bus & Bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments.	9/Nov/22	09:00	9/Nov/22	18:00	The said work is very important
127	576	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	9/Nov/22	10:30	9/Nov/22	18:00	765KV 240Mvar Bus Reactor will be in service through its TIE 712 Bay & Main Bus-II
128	585	PLANNED	OCC_560	MSLDC_OUTAGE	400/132 KV 200 MVA ICT - 1 @ KHADKA (TAKEN ON TBC AT BHUSAWAL) ELEMENT NOT FOUND	Continuous	For HV CB Mechanism overhauling work	9/Nov/22	08:00	12/Nov/22	18:00	ICT-1 HV will be in service through TBC hence no interruption
129	588	PLANNED	OCC_560	MSLDC_OUTAGE	NEW KOYNA - 400KV - BUS 1	Continuous	1) 09/11/2022 to 10/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay	9/Nov/22	09:00	16/Nov/22	16:00	1) Insulator replacement of Bus-I considered in scheme (LE/2020-21/005-1-01)
130	589	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV	D	Isolator upgradation work of 41489B, 41589A, FSC Isolators, By Pass isolator under substation package SS11 (Construction outage)	9/Nov/22	8:00	18/Nov/22	18:00	
131	590	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	Daily	For Replacement of PID Suspecious String & Other maintenance work	9/Nov/22	09:00	9/Nov/22	18:00	400 KV DHL-SSNCL CKT 1 A/R Switch will be put on Non Auto mode.
132	591	PLANNED	OCC_560	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	10/Nov/22	7:00	24/Nov/22	17:00	For Stringing of Kolhapur- Kolhapur#1, outage will require on Kolhapur- Mapusa#2
133	598	PLANNED	OCC_560	POWERGRID_WR1	PUNE-PG - 220KV - BUS 1	D	For AMP WORK	10/Nov/22	7:00	10/Nov/22	18:00	
134	599	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 220KV-SOLAPUR-KUMBARI-2 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV	Daily	Bay AMP Works	10/Nov/22	7:00	10/Nov/22	18:00	
135	602	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Maintenance Work	10/Nov/22	08:00	10/Nov/22	18:00	.
136	610	PLANNED	OCC_560	POWERGRID_WR1	WARDHA - 400KV - BUS 2	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.	10/Nov/22	8:00	10/Nov/22	19:00	4B82

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line /Element	Daily / Continuo us	Reason	From	To	Remarks	
137	614	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-2 AND FUTURE @KUDUS - 400kv at KUDUS - 400KV	Daily	R PH CT Replacement of 417 Bay at Kudus SS.	10/Nov/22	9:00	10/Nov/22 17:00	400 KV Padghe Kudus Line 2 will be in service through Main Bay 418.
138	619	PLANNED	OCC_560	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV- TIRODA-KORADI-III-2 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment	10/Nov/22	09:00	10/Nov/22 18:00	Annual Maintenance of Bay Equipment
139	637	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	Daily	Diagnostic testing & allied bay maintenance work	10/Nov/22	10:00	10/Nov/22 18:00	Diagnostic testing & allied bay maintenance work
140	638	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance	10/Nov/22	10:00	10/Nov/22 18:00	-
141	640	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	10/Nov/22	10:30	10/Nov/22 18:00	765/400kv 1500MVA ICT-II will be in service through its Main 713 Bay & Main Bus-II & 765kv 240Mvar will be in service through its Main Bay 711 Bay & Main Bus- I
142	650	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-2	Continuo us	Required for Main Bus -2 outage work.	10/Nov/22	08:00	11/Nov/22 18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 Isolators are not in service.
143	651	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-1	Continuo us	Required for Main Bus -2 outage work.	10/Nov/22	08:00	11/Nov/22 18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 Isolators are not in service.
144	652	PLANNED	OCC_560	MSLDC_OUTAGE	CHANDRAPUR - 400KV - BUS 2	Continuo us	1. Tan delta measurement of Bus CVT. 2. Nut Bolts and hardware tightening work	10/Nov/22	08:00	11/Nov/22 18:00	This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 Isolators are not in service.
145	657	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	Continuo us	Conductor restringing Work between Loc No 89-92 & PID Faulty disc insulator replacement work	10/Nov/22	08:00	12/Nov/22 17:00	Conductor restringing Work between Loc No 89-92 & PID Faulty disc insulator replacement work
146	665	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BORIVALI-1	Daily	1) Replacement of rusted hardware under R&M Scheme. 2) Line Maintenance work.	11/Nov/22	07:00	14/Nov/22 17:00	1) Replacement of rusted hardware under R&M Scheme. 2) Line Maintenance work.
147	668	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	Daily	Bay Maintenance Work	11/Nov/22	07:00	11/Nov/22 17:00	Bay Maintenance Work
148	670	PLANNED	OCC_560	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-1	D	For AMP and relay testing works	11/Nov/22	7:00	11/Nov/22 18:00	
149	689	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work .	11/Nov/22	09:00	11/Nov/22 17:00	400 KV WARORA - DEOLI 2 Line is in ckt
150	693	PLANNED	OCC_560	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	Daily	B PH Line CT Replacement of Padghe Kudus Line 1 at Kudus SS.	11/Nov/22	9:00	11/Nov/22 17:00	400 KV Padghe Kudus Line 1 will be out of service.
151	699	PLANNED	OCC_560	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	D	For AMP works.DIA TO BE KEPT OPEN	11/Nov/22	9:00	11/Nov/22 17:30	PG-WR2-BOISAR
152	702	PLANNED	OCC_560	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV- AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	11/Nov/22	09:00	11/Nov/22 18:00	Annual Maintenance of Bay Equipment
153	733	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	Continuo us	Conductor replacement in span between loc. No. 33 to 34 for R and B phase, and replacement of discs type insulator with AF long rod insulator at loc 33 and 34(Talegaon side).	11/Nov/22	07:00	13/Nov/22 18:00	NIL
154	734	PLANNED	OCC_560	MSLDC_OUTAGE	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR(TAKEN ON TBC AT KHARGHAR) ELEMENT NOT FOUND	Continuo us	400KV CB Mechanism Overhauling work. 400KV CB will be off and ICT-3 will be on TBC	11/Nov/22	08:00	13/Nov/22 18:00	400KV CB will be off and ICT-3 will be on TBC
155	735	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Continuo us	Replacement of existing conductor by HTLS Conductor.	11/Nov/22	09:00	13/Nov/22 18:00	Replacement of existing conductor by HTLS Conductor.
156	737	Planned	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	11/Nov/22	08:00	16/Nov/22 18:00	.
157	740	PLANNED	OCC_560	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	For AMP works at Boisar PG end. LINE OUTAGE IS REQUIRED	12/Nov/22	9:00	12/Nov/22 17:30	PG-WR2-BOISAR
158	744	PLANNED	OCC_560	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	D	For AMP and relay testing works	12/Nov/22	7:00	12/Nov/22 18:00	
159	756	PLANNED	OCC_560	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	For AMP works.DIA TO BE KEPT OPEN	12/Nov/22	9:00	12/Nov/22 17:30	PG-WR2-BOISAR
160	761	PLANNED	OCC_560	POWERGRID_WR2	400KV-KALA-KUDUS-2	D	For AMP WORKS. A/R OFF OF CKT # 1 AND DIA TO BE KEPT OPEN AT BOTH ENDS.	12/Nov/22	9:00	12/Nov/22 18:00	PG-WR2-KALA
161	778	PLANNED	OCC_560	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	Continuo us	Bus Isolator R/M & other R/M Work.	12/Nov/22	07:00	13/Nov/22 20:00	Bus Isolator R/M & other R/M Work.
162	787	PLANNED	OCC_560	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	D	For AMP and relay testing works	13/Nov/22	7:00	13/Nov/22 18:00	
163	789	PLANNED	OCC_560	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	D	For AMP works at Boisar PG end. LINE OUTAGE IS REQUIRED	13/Nov/22	9:00	13/Nov/22 17:30	PG-WR2-BOISAR
164	790	PLANNED	OCC_560	POWERGRID_WR2	400KV-KALA-KUDUS-1	D	For AMP WORKS. A/R OFF OF CKT # 2 AND DIA TO BE KEPT OPEN AT BOTH ENDS.	13/Nov/22	9:00	13/Nov/22 18:00	PG-WR2-KALA
165	792	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	Daily	For Replacement of PID Suspecious String & Other maintenance work	13/Nov/22	09:00	13/Nov/22 18:00	400 KV DHL-SSNNL CKT 1 A/R Switch will be put on Non Auto mode.
166	793	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-BOISAR-NALASOPARA-1	Daily	Line Maintenance Work	13/Nov/22	07:00	13/Nov/22 14:00	Line Maintenance Work
167	795	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-WARORA-1	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.	13/Nov/22	8:00	13/Nov/22 13:00	429L
168	796	PLANNED	OCC_560	POWERGRID_WR1	WARDHA - 400KV - BUS 2	D	Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators.	13/Nov/22	8:00	13/Nov/22 19:00	48B2
169	810	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	Daily	Conductor & Earthwire Hardware tightening work	14/Nov/22	08:00	14/Nov/22 17:00	Conductor & Earthwire Hardware tightening work
170	832	PLANNED	OCC_560	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	14/Nov/22	09:00	14/Nov/22 18:00	Annual Maintenance of Bay Equipment
171	841	PLANNED	OCC_560	MP_SLDC	220KV-PANDURNA-KALMESHWAR-1	D	FOR LINE MAINTENANCE WORK	14/Nov/22	9:00	14/Nov/22 18:00	
172	849	PLANNED	OCC_560	POWERGRID_WR1	765KV-PUNE-PADGHE-PG-1	Continuo us	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway.	14/Nov/22	9:00	30/Nov/22 18:00	765 KV PUNE PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
173	850	PLANNED	OCC_560	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	Continuo us	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway.	14/Nov/22	9:00	30/Nov/22 18:00	765 KV AURANGABAD PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
174	855	Planned	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	Daily	Routine line maintenance work	14/Nov/22	10:00	14/Nov/22 18:00	NA

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks	
175	860	PLANNED	OCC_560	MSLDC_OUTAGE	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR(TAKEN ON TBC AT KHARGHAR) ELEMENT NOT FOUND	Continuo us	400KV CB Mechanism Overhauling work. 400KV CB will be off and ICT-1 will be on TBC	14/Nov/22	08:00	16/Nov/22 18:00	400KV CB will be off and ICT-1 will be on TBC
176	861	PLANNED	OCC_560	MSLDC_OUTAGE	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	Continuo us	O/H & Serviceing of 29A PG Isolator & Replacement of PGI mechanism box.	14/Nov/22	08:00	16/Nov/22 20:00	400KV BC bay will not be in service
177	866	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-BHUSAWAL-KORADI-1 AND BHUSAWAL - 400KV - BUS 1 @BHUSAWAL - 400KV at BHUSAWAL - 400KV(ELEMENT NOT FOUND)	Continuo us	For CB Mechanism Overahuling work by agency (line will be in service through TBC)	14/Nov/22	08:00	17/Nov/22 18:00	During outage line will be in service through TBC hence no interruption
178	867	PLANNED	OCC_560	MSLDC_OUTAGE	POLE-1 BASE AC FILTER Z1- Z2(200MVAR) @ CHANDRAPUR(Elemnet not found)	Continuo us	To replace interconnecting jumpers of AC Filter capacitor bank & its accessories like Clamps, Round bar, Washers etc. It is necessary to carry out above work to avoid frequent Hotspots in AC filter.	14/Nov/22	08:00	17/Nov/22 22:00	1.Work will be carried out through agency i.e. M/s BHEL. 2. Both Pole will be in service & there is Bi-Power Restriction of 850 MW 3 Pole-II base filter will be available. 4. Due to any reason Pole-II base filter get tripped both Pole will get tripped.
179	869	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-1	Daily	PID testing of insulator strings	14/Nov/22	08:00	19/Nov/22 18:00	NIL
180	870	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARAD-KOLHAPUR-MS-1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	Continuo us	Overhauling of A bus, 8 Bus PG isolators.(line will be shifted on TBC bay)	14/Nov/22	09:00	19/Nov/22 23:59	400 kv Karad 1 will be shifted online on 400 kv TBC.
181	871	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY OF 400KV/220KV SOLAPUR-M-ICT-1 AND 400KV-PARLI-M-SOLAPUR-M-1 @SOLAPUR-M - 400KV at SOLAPUR-M - 400KV	Continuo us	Overhauling of 402-52 CB (ICT will be in service through main bay)	14/Nov/22	10:00	19/Nov/22 18:00	With out interruption as 400 kv Parli & 400 KV ICT-1 will be in service via Main C.B's.
182	873	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	14/Nov/22	09:00	25/Nov/22 18:00	PID Testing of Insulators Auto-Reclose function to be out of service.
183	874	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	Daily	PID work	14/Nov/22	09:00	30/Nov/22 18:00	Online
184	875	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-2	Daily	PID work	14/Nov/22	09:00	30/Nov/22 18:00	PID Work
185	896	PLANNED	OCC_560	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	Daily	Bus CVT Testing. 400 KV BUS -1 feeders and ICTs to be shifted on 400 KV Bus-II	15/Nov/22	09:00	15/Nov/22 17:00	400 KV BUS -1 feeders and ICTs to be shifted on 400 KV Bus-II
186	897	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	Daily	AMP of 414 Bay	15/Nov/22	9:00	15/Nov/22 17:00	400 KV Padghe Kudus Line 1 will be in service through Main Bay 415.
187	901	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	Continuo us	Line, s/s Maintenance	15/Nov/22	09:00	15/Nov/22 17:30	-
188	903	PLANNED	OCC_560	MEGPTCL	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment Equipment	15/Nov/22	09:00	15/Nov/22 18:00	Annual Maintenance of Bay Equipment
189	924	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	Daily	Relay Testing and Routine Maintenance	15/Nov/22	10:00	15/Nov/22 18:00	400kv Ektuni-Thapti-Tanda ckt-II will be in service
190	925	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	Daily	Routine line maintenance work	15/Nov/22	10:00	15/Nov/22 18:00	NA
191	929	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	Daily	Conductor & Earthwire Hardware tightening work & Replacement of Broken disc Insulator	15/Nov/22	08:00	16/Nov/22 17:00	Conductor & Earthwire Hardware tightening work & Replacement of Broken disc Insulator
192	930	PLANNED	OCC_560	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continuo us	To carry out following test on Pole-1 Y phase Converter transformer as per OEM recommendation 1.Ratio Test 2.Tan Delta of A-B1B2 Winding 3.DFRA Test 4. Winding Resistance S.Measurement IR & Pi of AB1-B2 winding 6.Core Insulation Measurement	15/Nov/22	08:00	16/Nov/22 22:00	1.Pole-2 will be in service with 750 MW
193	931	PLANNED	OCC_560	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 2	Continuo us	400KV Busbar Relay Testing Work(All elements will be in service through bus 1 and bus 2 only Bus bar relay protection will be out)	15/Nov/22	10:00	16/Nov/22 18:00	Other Protections will be in service except 400KV Busbar Protection and LBB Protection. All Bays will be in service
194	932	PLANNED	OCC_560	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 1	Continuo us	400KV Busbar Relay Testing Work (All elements will be in service through bus 1 and bus 2 only Bus bar relay protection will be out) Other Protections will be in service except 400KV Busbar Protection and LBB Protection. All Bays will be in service	15/Nov/22	10:00	16/Nov/22 18:00	Other Protections will be in service except 400KV Busbar Protection and LBB Protection. All Bays will be in service
195	936	PLANNED	OCC_560	RGPPL	400KV-RGPPL-NewKoyna Line-2	Daily	Replacement of Surge Arrestor for all the three poles	15/Nov/22	8:00	17/Nov/22 18:00	
196	962	PLANNED	OCC_560	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	16/Nov/22	09:00	16/Nov/22 17:00	NA
197	968	PLANNED	OCC_560	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay	16/Nov/22	09:00	16/Nov/22 18:00	Annual Maintenance of Bay Equipment
198	969	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	Daily	Annual maintenance work	16/Nov/22	09:00	16/Nov/22 18:00	The said work is very important
199	994	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	Daily	String replacement work	16/Nov/22	10:00	16/Nov/22 18:00	Load will be managed on 400kv Lamboti PGCIL Line
200	1000	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	Daily	PID testing work	16/Nov/22	08:00	30/Nov/22 18:00	-
201	1001	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	Daily	PID Testing	16/Nov/22	10:00	30/Nov/22 18:00	without load interruption
202	1008	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	17/Nov/22	08:00	21/Nov/22 17:00	--
203	1017	PLANNED	OCC_560	POWERGRID_WR1	220KV-PARLI-PARLI-M-2	D	AMP work line terminal equipment	17/Nov/22	7:00	17/Nov/22 18:00	

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
204	1024	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	Daily	1. Replacemnt of old master trip relays (86 relays) under MTAMC work. 2) Maintenance and alignment of isolators.	17/Nov/22	08:00	17/Nov/22	18:00	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No- 1, 400KV KHAPARKHEDA ckt. 400KV Parli-3 ckt. 400KV CHANDRAPUR-PGOL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service.
205	1025	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	Daily	OT & Line Maintenance, Cold line washing	17/Nov/22	08:00	17/Nov/22	18:00	NIL
206	1026	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Maintenance Work	17/Nov/22	08:00	17/Nov/22	18:00	.
207	1037	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	17/Nov/22	09:00	17/Nov/22	17:00	only Tie CB 415 is in OFF condition, respective ckt charged through its own main CB.
208	1044	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	Daily	(1) Main-1 distance relay testing. (2) Bay maintenance work. (3) Hardware tightening & fitting work.	17/Nov/22	09:00	17/Nov/22	18:00	-
209	1045	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	Daily	Replacement of PID suspicious disc insulator & other maintenancance work	17/Nov/22	09:00	17/Nov/22	18:00	A/R s/w of 400 KV Dhule- SSNNL 2 to be keep non auto mode
210	1051	PLANNED	OCC_560	POWERGRID_WR2	400KV/220KV KALA-ICT-1	D	For AMP Works. Dia to be kept open	17/Nov/22	9:00	17/Nov/22	18:00	PG-WR2-KALA
211	1056	PLANNED	OCC_560	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	D	AMP and relay testing works.	17/Nov/22	9:00	17/Nov/22	18:00	80 MVar Bus reactor
212	1063	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance	17/Nov/22	10:00	17/Nov/22	18:00	NIL
213	1064	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	Daily	Relay Testing and Routine Maintenance	17/Nov/22	10:30	17/Nov/22	18:00	400kv Ektuni-Thapti-Tanda ckt-I will be in service
214	1069	PLANNED	OCC_560	POWERGRID_WR1	400KV-WARDHA-KORADI-II-1	D	Isolator upgradation work of 41489A isolator under substation package SS11 (Construction	17/Nov/22	8:00	18/Nov/22	18:00	
215	1070	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Isolator upgradation work of 41489A isolator under substation package SS11 (Construction	17/Nov/22	8:00	18/Nov/22	18:00	
216	1071	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	Continuo us	O/H & Servicing of 29D PG Isolator.	17/Nov/22	08:00	18/Nov/22	20:00	NIL
217	1073	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	Continuo us	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators and Routine Testing and Maintenance Work.	17/Nov/22	10:00	18/Nov/22	18:00	The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so isolator overhauling is to be carried out by dismantling the Isolator. So time is required for Dismantling and Erection alongwith Overhauling.
218	1074	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	Continuo us	Conductor restrining Work Between Loc No 89-90 & PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	17/Nov/22	08:00	19/Nov/22	17:00	Conductor restrining Work Between Loc No 89-90 & PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
219	1075	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	Daily	Cold washing work	17/Nov/22	08:00	19/Nov/22	18:00	Planned Outage
220	1079	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPU-II-NANDED-2	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	17/Nov/22	08:00	30/Nov/22	18:00	.
221	1089	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	Daily	Bay Maintenance Work	18/Nov/22	07:00	18/Nov/22	17:00	Bay Maintenance Work
222	1099	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	Daily	cold line washing of insulator string and routine line maintenance work, CT Tan D & Bay maintenance work (Dhule Bableshtar ckt 1 AR out required)	18/Nov/22	08:00	18/Nov/22	18:00	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in in service
223	1107	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARORA-CHANDRAPU-II-2 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	18/Nov/22	09:00	18/Nov/22	17:00	Only Main CB 416 is in OFF condition,Ckt charged through Tie CB no.415.
224	1110	PLANNED	OCC_560	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	18/Nov/22	09:00	18/Nov/22	18:00	Annual Maintenance of Bay Equipment
225	1111	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	Daily	Replacement of PID suspicious disc insulator & other maintenancance work	18/Nov/22	09:00	18/Nov/22	18:00	A/R s/w of 400 KV Dhule- SSNNL 2 to be keep non auto mode
226	1144	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Continuo us	Replacement of existing conductor by HTLS conductor	18/Nov/22	09:00	20/Nov/22	18:00	Replacement of existing conductor by HTLS conductor
227	1145	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	18/Nov/22	08:00	23/Nov/22	18:00	.
228	1151	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	Daily	During the work on Dhule 2 line (cold line washing of insulator string and routine Line maintenance work) Dhule 1 line required AR	19/Nov/22	08:00	19/Nov/22	18:00	Dhule 1 line required AR out required during work on Dhule 2 line
229	1166	PLANNED	OCC_560	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 1	Daily	400kv Bus Bar Testing	19/Nov/22	08:00	19/Nov/22	20:00	Online work of bus bar testing
230	1167	PLANNED	OCC_560	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 2	Daily	400kv Bus Bar Testing	19/Nov/22	08:00	19/Nov/22	20:00	Online work of bus bar testing
231	1188	PLANNED	OCC_560	MEGPTCL	BOISAR-M - 220KV - BUS 2	Continuo us	Bus Isolator R/M & other R/M Work.	19/Nov/22	07:00	20/Nov/22	20:00	Bus Isolator R/M & other R/M Work.
232	1189	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work	19/Nov/22	08:00	20/Nov/22	18:00	400kv Padghe i will be in in service
233	1190	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	Continuo us	400KV CB Mechanism Overhauling work. 400KV CB will be off and Line will be on TBC	19/Nov/22	08:00	21/Nov/22	18:00	400KV CB will be off and Line will be on TBC
234	1191	PLANNED	OCC_560	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continuo us	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance, etc	19/Nov/22	08:00	26/Nov/22	22:00	Pole-2 will be in service with in 750 MW
235	1192	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	Continuo us	1. Bay Mant work 2. Diagnostic testing work	19/Nov/22	09:00	26/Nov/22	21:00	Weather condition should be clear for pole overhauling and PG isolator
236	1193	PLANNED	OCC_560	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	Continuo us	Replacement of Hanger assembly of A bus PG Isolator of 400KV HVDC- 1 Bay by hot line method.	19/Nov/22	09:00	29/Nov/22	17:00	Weather condition Should be clear.
237	1194	PLANNED	OCC_560	POWERGRID_WR1	400KV-KALA-KUDUS-2	Daily	AMP of Line Equipment.	20/Nov/22	9:00	20/Nov/22	17:00	400 KV Kala Kudus Line 2 will be out of service.
238	1197	PLANNED	OCC_560	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	Daily	ZIV BUS BAR Testing, ZIV BUS BAR to be taken out of Service during the outage period. Both will be in service	20/Nov/22	08:00	20/Nov/22	20:00	ZIV BUS BAR to be taken out of Service during the outage period
239	1200	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	Daily	Routine Testing and Maintenance Work.	20/Nov/22	10:00	20/Nov/22	18:00	-
240	1203	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-PARLI-M-3	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	20/Nov/22	08:00	30/Nov/22	18:00	.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
241	1220	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	Daily	OPGW Stringing and removal of Earthwire work on Ektuni-Thapatitanda Ckt-1 by MTCIL	21/Nov/22	08:00	21/Nov/22	18:00	Work will be carried out by MTCIL
242	1232	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-PARLI-SOLAPUR-1 AND 400KV-BHADRAWATI-PARLI-1	D	AMP Work	21/Nov/22	8:30	21/Nov/22	18:00	
243	1233	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	21/Nov/22	09:00	21/Nov/22	17:00	Line will be charged through Tie CB 428.
244	1263	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY - 765KV-AKOLA (2)-EKTUNI-2 AND FUTURE at EKTUNI - 765KV	Daily	Diagnostic Testing of CB & Routine Maintenance	21/Nov/22	10:30	21/Nov/22	18:00	765KV Akola ckt-II will be in service through its Main Bay 703 & Main Bus-I
245	1271	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	Daily	To carryout PID scanning	21/Nov/22	08:00	23/Nov/22	18:00	-
246	1276	PLANNED	OCC_560	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	Continuo us	For attending SF6 gas leakage .	21/Nov/22	9:00	25/Nov/22	18:00	
247	1277	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KARIAT-LONIKHAND-II-2	Daily	PID testing of insulator strings	21/Nov/22	08:00	26/Nov/22	18:00	NIL
248	1280	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV KOLHAPUR-MS-ICT-1 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	Continuo us	Overhauling of A bus, B Bus PG isolators. ICT will be in service through TBC	21/Nov/22	09:00	26/Nov/22	23:59	400 kv ICT 1 bay will be shifted online on 400 kv TBC.
249	1281	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 765KV/400KV SOLAPUR-M-ICT-2 AND SOLAPUR-M - 400KV - BUS 1 @SOLAPUR-M - 400KV	Continuo us	Over hauling of 404-52 of 400 kv ICT-II C.B	21/Nov/22	10:00	26/Nov/22	18:00	With out interruption as 400 kv ICT-II will be in service via 405-52 Tie C.B
250	1283	PLANNED	OCC_560	MSLDC_OUTAGE	NEW KOYNA - 400KV - BUS 2	Continuo us	1) 21/11/2022 to 22/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 23/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 3) 24/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 25/11/2022 Bus Insulator replacement work at section Koyna -I & II and damage conductor replacement work 5) 26/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 27/11/2022 to 28/11/2022 Bus Insulator replacement work at section Jaigad -I & II	21/Nov/22	08:00	28/Nov/22	17:00	1) Insulator replacement of Bus-I considered in scheme (LE/2020-21/005-1-01) 2)Damage conductor replacement work in between Koyana-I & Koyana-II etc. section 3) In outage period TBC operation will be inseatad. 4) for every section, One feeder is to be kept on TB C & anther feeder should be kept off.
251	1289	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-SOLAPUR-M-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	Daily	Bay AMP Works	22/Nov/22	7:00	22/Nov/22	18:00	
252	1298	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	Daily	CT Tan D, LBB Testing, MTAMC Work & Bay maintenance work	22/Nov/22	08:00	22/Nov/22	18:00	400KV Ektuni-II will be in in service
253	1312	PLANNED	OCC_560	POWERGRID_WR1	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND 400KV/220KV AKOLA-ICT-2 at AKOLA - 400KV	D	AMP of 406 Bay at Akola	22/Nov/22	8:00	22/Nov/22	18:00	406A
254	1313	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	D	AMP of 407 Bay at Akola	22/Nov/22	8:00	22/Nov/22	18:00	407A
255	1316	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	22/Nov/22	09:00	22/Nov/22	17:00	400KV KORADI-WARDHA. Line will be charged through Tie CB 414.
256	1317	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator	22/Nov/22	09:00	22/Nov/22	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
257	1320	PLANNED	OCC_560	APML-ADANI	TIE BAY- 400KV TIRORA-WARORA-1 AND STATION TRANSFORMER-1 AT TIRORA SS	Daily	For bay equipment maintenance and testing work	22/Nov/22	9:00	22/Nov/22	18:00	Bay Outage
258	1322	PLANNED	OCC_560	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment	22/Nov/22	09:00	22/Nov/22	18:00	Annual Maintenance of Bay Equipment
259	1337	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	Daily	Diagnostic testing & allied bay maintenance work	22/Nov/22	10:00	22/Nov/22	17:00	Diagnostic testing & allied bay maintenance work
260	1345	PLANNED	OCC_560	RGPL	400KV-RGPL-NewKoyana Line-1	Daily	Replacement of Surge Arrestor for all the three poles	22/Nov/22	8:00	24/Nov/22	18:00	
261	1347	PLANNED	OCC_560	MSLDC_OUTAGE	KORADI - 400KV - BUS 1	Daily	CVT Tan Delta	23/Nov/22	06:00	23/Nov/22	22:00	Outages will be availed subject to weather conditions.
262	1348	PLANNED	OCC_560	POWERGRID_WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-2	D	Line Bay AMP works & attedning Shutdown nature defects. AR to be kept in non Auto mode for 400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	23/Nov/22	7:00	23/Nov/22	18:00	KOLHAPUR-GIS
263	1350	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPL-NEW KOYNA-2	Daily	Bus Insulator replacement work at section Dabhol 1 & 2	23/Nov/22	08:00	23/Nov/22	17:00	Planned outage
264	1353	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	Daily	MTAMC Work & Bay maintenance work	23/Nov/22	08:00	23/Nov/22	18:00	400KV Ektuni-I will be in in service
265	1360	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	D	AMP of 411 Bay at Akola	23/Nov/22	8:00	23/Nov/22	18:00	411A
266	1365	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	23/Nov/22	09:00	23/Nov/22	17:00	Line will be charged through Main CB 429.
267	1366	PLANNED	OCC_560	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	23/Nov/22	09:00	23/Nov/22	17:00	NA
268	1367	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	Daily	Line, s/s Maintenance	23/Nov/22	09:00	23/Nov/22	17:30	-
269	1369	PLANNED	OCC_560	APML-ADANI	MAIN BAY- 400KV TIRORA-WARORA-1 AND 400KV BUS-2 AT TIRORA SS	Daily	For bay equipment maintenance and testing work	23/Nov/22	9:00	23/Nov/22	18:00	Bay Outage
270	1370	PLANNED	OCC_560	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	Daily	Annual Maintenance of Bay Equipment	23/Nov/22	09:00	23/Nov/22	18:00	Annual Maintenance of Bay Equipment
271	1371	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	Continuo us	(1) Bay maintenance work. (2) Hardware tightening & fitting work.	23/Nov/22	09:00	23/Nov/22	18:00	-
272	1372	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	Annual maintenance work	23/Nov/22	09:00	23/Nov/22	18:00	The said work is very important
273	1400	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	Daily	String replacement work	23/Nov/22	10:00	23/Nov/22	18:00	Load will be managed on 400kv Lamboti PGCIL Line
274	1406	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-BHILAI-KORADI-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of Bhilai Line CGL CB at Koradi SS, Line to be shifted on TBC for 3 days and for bay isolators overhauling.	23/Nov/22	8:00	25/Nov/22	18:00	BHI
275	1407	PLANNED	OCC_560	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - AUXILIARY BUS 1	Daily	For PID testing work of Aux bus section-1(The feeder will be shifted on TBC-1 for PID testing work of Aux bus section-1)	23/Nov/22	08:00	26/Nov/22	18:00	For PID testing work of Aux bus section-1
276	1408	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-1	Daily	For PID testing work of Aux bus section-1(The feeder will be shifted on TBC-1 for PID testing work of Aux bus section-1)	23/Nov/22	08:00	26/Nov/22	18:00	The feeder will be shifted on TBC-1 for PID testing work of Aux bus section-1

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
277	1413	PLANNED	OCC_560	MSLDC_OUTAGE	TIE BAY OF 400KV-KARIAT-LONIKHAND-II-1 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	Daily	Diagnostic testing and Maintenance	24/Nov/22	08:00	24/Nov/22	18:00	-
278	1414	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARIAT-LONIKHAND-II-1 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	Daily	Diagnostic testing and Maintenance	24/Nov/22	08:00	24/Nov/22	18:00	NIL
279	1415	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	Maintenance Work	24/Nov/22	08:00	24/Nov/22	18:00	-
280	1425	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	AMP of 419 Bay	24/Nov/22	8:00	24/Nov/22	18:00	419
281	1431	PLANNED	OCC_560	APML-ADANI	TIE BAY- 400KV TIRORA-WARORA-2 AND STATION TRANSFORMER-2 AT TIRORA SS	Daily	For bay equipment maintenance and testing work	24/Nov/22	9:00	24/Nov/22	18:00	Bay Outage
282	1433	PLANNED	OCC_560	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipment	24/Nov/22	09:00	24/Nov/22	18:00	Annual Maintenance of Bay Equipment
283	1434	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	Daily	Replacement of PID suspicious disc insulator & other maintenance work	24/Nov/22	09:00	24/Nov/22	18:00	A/R S/W to be keep in non auto mode for 400 KV Dhule- SSNNL ckt 1
284	1455	PLANNED	OCC_560	MSLDC_OUTAGE	KARAD - LONIKAND I (Taken on TBC at Lonikhand) (Element not found)	Continuous	O/H & Servicing of 298 PG Isolator & Replacement of PGI mechanism box.	24/Nov/22	08:00	26/Nov/22	20:00	Line to be shifted on TBC
285	1456	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	Daily	To carryout PID scanning	24/Nov/22	08:00	28/Nov/22	18:00	-
286	1459	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	Daily	Bay Maintenance Work	25/Nov/22	07:00	25/Nov/22	17:00	Bay Maintenance Work
287	1460	PLANNED	OCC_560	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	Daily	For replacement of R&B phase Bus CVT and Bay maintenance work(400KV B Bus will be in service. all lines & ICT's will be on B bus, Load will be shifted via TBC)	25/Nov/22	07:00	25/Nov/22	18:00	400kv B Bus will be in service. all lines & ICT's will be on B bus, Load will be shifted via TBC
288	1466	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-NEW KOYNA-2	Daily	Bus Insulator replacement work at section Koyna -I & II and damage conductor replacement work	25/Nov/22	08:00	25/Nov/22	17:00	Planned outage
289	1479	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	Daily	Replacement of PID suspicious disc insulator & other maintenance work	25/Nov/22	09:00	25/Nov/22	18:00	A/R S/W to be keep in non auto mode for 400 KV Dhule- SSNNL ckt 1
290	1480	PLANNED	OCC_560	MEGPTCL	AKOLA (2) - 400KV - BUS 2	Daily	Annual Maintenance of Bus Equipment	25/Nov/22	09:00	25/Nov/22	18:00	Annual Maintenance of Bus Equipment
291	1505	PLANNED	OCC_560	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	Continuous	To attend the sag corection in tower no. 534, to stop the deforming of tower members in the first section.	25/Nov/22	08:00	26/Nov/22	18:00	To attend the sag corection in tower no. 534, to stop the deforming of tower members in the first section.
292	1506	PLANNED	OCC_560	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	Daily	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765KV Line.	25/Nov/22	08:00	26/Nov/22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765KV Line.
293	1507	PLANNED	OCC_560	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	Daily	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section.	25/Nov/22	08:00	26/Nov/22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section.
294	1509	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	Continuous	Replacement of existing conductor by HTLS conductor	25/Nov/22	09:00	27/Nov/22	18:00	Replacement of existing conductor by HTLS conductor
295	1512	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	Daily	For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode.	25/Nov/22	08:00	30/Nov/22	18:00	-
296	1515	PLANNED	OCC_560	POWERGRID_WR1	400KV BHADRAWATI-CHANDRAPUR-3	D	Line A/R in non auto mode to facilitate outage on 400KV BHADRAWATI-	26/Nov/22	6:00	26/Nov/22	19:00	
297	1516	PLANNED	OCC_560	POWERGRID_WR1	400kv BHADRAWATI-CHANDRAPUR-4	D	Line A/R in non auto mode to facilitate outage on 400KV BHADRAWATI-	26/Nov/22	6:00	26/Nov/22	19:00	
298	1517	PLANNED	OCC_560	POWERGRID_WR1	400KV CHADRAPUR-WARORA-MS-1	D	Line outage required for OPGW erection between Tower no 477 to 478 of 400kv	26/Nov/22	6:00	26/Nov/22	19:00	
299	1518	PLANNED	OCC_560	POWERGRID_WR1	400KV CHADRAPUR-WARORA-MS-2	D	Line outage required for OPGW erection between Tower no 477 to 478 of 400kv BHADRAWATI-RAMAGUNDAM-1 at crossing point.	26/Nov/22	6:00	26/Nov/22	19:00	
300	1530	PLANNED	OCC_560	MEGPTCL	AKOLA (2) - 400KV - BUS 1	Daily	Annual Maintenance of Bus Equipment	26/Nov/22	09:00	26/Nov/22	18:00	Annual Maintenance of Bus Equipment
301	1546	PLANNED	OCC_560	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	Continuous	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, Line Maintenance etc.	26/Nov/22	06:00	29/Nov/22	22:00	Both Pole Will not be in Service, Loss of Capacity: 1500 MW
302	1547	PLANNED	OCC_560	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	Continuous	Annual Maintenance work , Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, Line Maintenance, etc.	26/Nov/22	22:00	29/Nov/22	22:00	Both Pole will not be in service,loss of capacity 1500 MW
303	1550	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	Daily	OPGW Stringing and removal of Earthwire work on Ektuni-Thapatitanda Ckt-1 by MTCIL	27/Nov/22	08:00	27/Nov/22	18:00	Work will be carried out by MTCIL
304	1551	PLANNED	OCC_560	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	AMP of Line Bay	27/Nov/22	8:00	27/Nov/22	18:00	206L
305	1560	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	28/Nov/22	08:00	30/Nov/22	17:00	--
306	1573	PLANNED	OCC_560	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	Continuous	AR in non auto due to planned annual maintenance of 400 kv Alkud - Kolhapur	28/Nov/22	9:00	28/Nov/22	18:00	
307	1574	PLANNED	OCC_560	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	Continuous	Planned annual maintenance.	28/Nov/22	9:00	28/Nov/22	18:00	
308	1575	PLANNED	OCC_560	MEGPTCL	MAIN BAY - 400KV-KORADI-II-KORADI-III-4 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	Daily	Annual Maintenance of Bay Equipment	28/Nov/22	09:00	28/Nov/22	18:00	Annual Maintenance of Bay Equipment
309	1590	PLANNED	OCC_560	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	Daily	For Replacement of Flashover Disc by Cold Line Method	28/Nov/22	09:00	29/Nov/22	17:00	
310	1594	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV-LONIKHAND-JEJURI-1 AND JEJURI - 400KV - BUS 2 @JEJURI - 400KV at JEJURI - 400KV	Continuous	O/H & Servicing of 298 PG Isolator & Replacement of PGI mechanism box.(Line to be shifted on TBC)	28/Nov/22	08:00	30/Nov/22	20:00	Line to be shifted on TBC
311	1595	PLANNED	OCC_560	POWERGRID_WR1	MAIN BAY - 765KV-RAIGARH-PS-TAMNAR-2 AND RAIGARH-PS - 765KV - BUS 2 at RAIGARH-PS - 765KV	Daily	AMP	28/Nov/22	9:00	30/Nov/22	17:30	AMP as per Maintenance schedule
312	1596	PLANNED	OCC_560	MSLDC_OUTAGE	400 kv DHI-BBLR-II	Daily	On line PID work	28/Nov/22	09:00	30/Nov/22	18:00	400 kv DHI-BBLR-II A/R switch will be kept on non auto mode
313	1597	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	28/Nov/22	09:00	30/Nov/22	18:00	PID Testing of Insulators Auto-Reclose function to be out of service.

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
314	1598	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV KOLHAPUR-MS-ICT-2 AND KOLHAPUR-MS - 400KV - BUS 1 @KOLHAPUR-MS - 400KV at KOLHAPUR-MS - 400KV	Continuous	Overhauling of A bus, B Bus PG isolators. ICT will be in service through TBC	28/Nov/22	09:00	3/Dec/22	23:59	400 kv ICT 2 bay will be shifted online on 400 kv TBC.
315	1601	PLANNED	OCC_560	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	Continuous	Testing of backup OC/EF Relay and it's integration with SCADA under MTAMC project.	29/Nov/22	08:00	29/Nov/22	18:00	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No - 1, 400KV KHAPARKHEDA ckt. 400kv Parli-3 ckt.
316	1607	PLANNED	OCC_560	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-3 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	For AMP works. ICT WILL REMAIN IN SERVICE THROUGH TBC BAY	29/Nov/22	9:00	29/Nov/22	17:30	PG-WR2-BOISAR
317	1615	PLANNED	OCC_560	POWERGRID_WR2	TIE BAY - 400KV-KHANDWA-DHULE-MS-2 AND KHANDWA - 400KV B/R 2 at KHANDWA - 400KV	D	For AMP works	29/Nov/22	9:00	29/Nov/22	18:00	PG-WR2-KHANDWA
318	1624	PLANNED	OCC_560	APTCL	400KV-AKOLA-AKOLA (2)-2	Daily	DCRM, CT, CVT Tandelta, relay testing and diagnostic, routine maintenance work	29/Nov/22	10:00	29/Nov/22	17:00	Yelwan Ckt -01 will be in service
319	1625	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	Daily	Cold washing work	29/Nov/22	08:00	30/Nov/22	18:00	Planned outage
320	1626	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	Daily	On line PID work	29/Nov/22	09:00	30/Nov/22	18:00	400 kv Dhi-BBLR-I A/R switch will be kept on non auto mode
321	1632	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	Continuous	Line, s/s Maintenance	30/Nov/22	09:00	30/Nov/22	17:30	-
322	1634	PLANNED	OCC_560	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	Annual maintenance work	30/Nov/22	09:00	30/Nov/22	18:00	The said work is very important
323	1635	PLANNED	OCC_560	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	Annual maintenance work	30/Nov/22	09:00	30/Nov/22	18:00	The said work is very important
324	1642	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-KORADI-II-KORADI-III-1	Daily	Diagnostic testing of Line CVT at Bay 409	30/Nov/22	10:00	30/Nov/22	17:00	400Koradi-II Koradi-III Ckt-2 will remain in service as alternate source.
325	1644	PLANNED	OCC_560	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	Daily	Relay Testing and Routine Maintenance	30/Nov/22	10:00	30/Nov/22	18:00	400kv Ektuni-Bhabaleshwar ckt-II will be in service
326	1647	PLANNED	OCC_560	MSLDC_OUTAGE	MAIN BAY - 400KV/220KV PADGHE-ICT-4 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV(ELEMENT NOT FOUND	Continuous	1. Replacement of B-Ph Unit due to PD and Increasing Key gases Presence of thermal fault. 2. Filtration of Yph Unit	30/Nov/22	00:02	13/Dec/22	23:59	Weather condition should be clear.

State Element outage list for the month of NOVEMBER'2022

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	125MVAr BUS REACTOR @ WARORA	1-Nov-22	08:00	1-Nov-22	17:00	Daily	Bushing Tan delta ,Diagnostic testing work	MSETCL	MSETCL	During outage reactor is in off condition
2	400 KV	STATION TF-3 @ KORADI 2	1-Nov-22	10:00	1-Nov-22	17:00	Daily	Tan delta measurement of Line CT	MSETCL	MSETCL	400kv Station Transformer I & II will remain in service as alternate source of supply
3	400 KV	CHANDRAPUR - KHAPERKHEDE	1-Nov-22	08:00	19-Nov-22	17:00	Daily	For PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	For PID Testing Work,shifting autoreclose switch to Non auto Mode
4	400 KV	LONIKAND I -JEJURI	1-Nov-22	08:00	5-Nov-22	18:00	Daily	PID testing of insulator strings	MSETCL	MSETCL	NIL
5	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	1-Nov-22	10:00	30-Nov-22	16:00	Daily	PID of 400 kV Akola- Nandgaonpeth line will be carried out by PID unit Akola & Hot line Unit Akola	MSETCL	MSETCL	PID of 400 kV Akola- Nandgaonpeth line will be carried out by PID unit Akola & Hot line Unit Akola
6	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	2-Nov-22	10:00	2-Nov-22	17:00	Daily	For testing of healthiness of CTR Fire protection system of 400 KV ICT-2	MSETCL	MSETCL	Load will be managed on 400 kv ICT-1
7	400 KV	JEJURI- KOYNA STAGE-IV	3-Nov-22	08:00	3-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
8	400 KV	TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	3-Nov-22	09:00	3-Nov-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and Isolater maintenance work .	MSETCL	MSETCL	Reactor (Bay no 402) & ICT-1 (bay No.404) is Charged through own Main CB.
9	400 KV	CHANDRAPUR-PARLI CKT-3	3-Nov-22	08:00	3-Nov-22	18:00	Daily	1) Circuit Breaker timing, CRM & DCRM. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators. 3) Dismantling of old reactor relay panel along with its wiring.	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No. - 1 & 2, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service.
10	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	3-Nov-22	10:00	4-Nov-22	18:00	Continuou	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators and Routine Testing and Maintenance Work.	MSETCL	MSETCL	The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is to be carried out by dismantling the Isolator. So time is required for Dismantling and Erection alongwith Overhauling.
11	400 KV	MAIN BAY (401) OF ICT -1 @ JEJURI	3-Nov-22	09:30	3-Nov-22	17:30	Daily	Testing and Maintenance Work	MSETCL	MSETCL	ICT 1 will be in service through Tie Bay 402
12	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	4-Nov-22	08:00	4-Nov-22	17:00	Daily	Bushing Winding Tan D, HV, MV CT Tan D, NDR and bay maintenance work	MSETCL	MSETCL	ICT 2, 3 and 4 will be in service
13	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	4-Nov-22	10:00	4-Nov-22	17:00	Daily	Diagnostic Testing of CT and routine bay maintenance work	MSETCL	MSETCL	501 MVA 400/220/33 KV ICT-1I will remain in service as alternate source of supply
14	400 KV	KARAD - LONIKAND I	4-Nov-22	08:00	4-Nov-22	17:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work
15	400 KV	KHADKA - BABLESHWAR	5-Nov-22	08:00	6-Nov-22	18:00	Daily	Chemical Cleaning of Insulator string and Routine Line maintenance work	MSETCL	MSETCL	400KV Ektuni ckt I&II,400kv Aurangabad , Dhule I&II will be in in service
16	400 KV	NEW KOYNA-KARAD CKT - 1	5-Nov-22	08:00	5-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
17	400 KV	JEJURI- KOYNA STAGE-IV	6-Nov-22	08:00	6-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
18	400 KV	KARAD - TALANDGE CKT - 1	7-Nov-22	08:00	7-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
19	400 KV	80 MVAr BUS REACTOR - 1 @ BABHALESHWAR	7-Nov-22	10:00	7-Nov-22	17:00	Daily	DFRA and bay maintenance work	MSETCL	MSETCL	Reactor will be taken in service after 18:00 hrs i.e at peak voltage hours
20	400 KV	MAIN BAY - 404 OF STATION TF-3 @ KORADI 2	7-Nov-22	10:00	7-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	Station Transformer-III will remain service in service through Tie Bay 405
21	400 KV	DHULE - BABLESHWAR - I	7-Nov-22	09:00	7-Nov-22	18:00	Daily	Replacement of PID suspicious strings & other maintenance.	MSETCL	MSETCL	400 kv Dhi-BBLR-2 Line will be in service & AR switch will be put on not auto mode.
22	400 KV	500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2	7-Nov-22	10:00	7-Nov-22	17:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
23	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 1	8-Nov-22	10:00	8-Nov-22	18:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
24	400 KV	JAIGAD - KARAD CKT - 1	8-Nov-22	09:00	8-Nov-22	18:00	Daily	CVT replacement work	JSWEL	JSWEL	CVT replacement work
25	400 KV	KORADI - KHAPERKHEDE CKT - 2	9-Nov-22	09:00	9-Nov-22	18:00	Daily	Inspection & Attending 400KV khaperkheda Ckt-2 29B B phase PG Isolator rotary problem by agency.	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
26	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	9-Nov-22	09:00	9-Nov-22	13:00	Daily	CB Timing	MSETCL	MSETCL	167 MVA Spare ICT-II is under breakdown
27	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	9-Nov-22	10:00	9-Nov-22	18:00	Daily	Testing of healthiness of Nitrogen Injection Fire Prevention & Protection System of CTR make.	MSETCL	MSETCL	Without Load Interruption. Load will be managed on ICT II.
28	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	9-Nov-22	09:00	9-Nov-22	18:00	Daily	Overhauling of 400KV Circuit Breaker (CGL Make) of 400/220kv, 315 MVA ICT-2 @ Girwal	MSETCL	MSETCL	-
29	400 KV	MAIN BAY (404) OF ICT -1 @ WARORA	9-Nov-22	09:00	9-Nov-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Reactor (Bay no 402) is charged through Tie Bay no 403.(ICT-1 hand over to 400KV Bhableshwar)
30	400 KV	JAIGAD - KARAD CKT - 2	9-Nov-22	09:00	9-Nov-22	18:00	Daily	CVT replacement work	JSWEL	JSWEL	CVT replacement work
31	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDE	9-Nov-22	10:00	9-Nov-22	17:00	Daily	Diagnostic Testing of CBs	MSETCL	MSETCL	NA
32	400 KV	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	10-Nov-22	09:30	10-Nov-22	17:30	Daily	Testing and Maintenance Work	MSETCL	MSETCL	-
33	400 KV	LONIKAND I -JEJURI	10-Nov-22	08:00	10-Nov-22	20:00	Daily	O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box.	MSETCL	MSETCL	NIL
34	400 KV	400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	10-Nov-22	09:00	10-Nov-22	16:00	Daily	Bushing C & Tan D	MSETCL	MSETCL	105 MVA Spare ICT-II not charged
35	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	10-Nov-22	10:00	11-Nov-22	18:00	Continuous	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators, Replacement of 220KV Rph IV CT and Routine Testing and Maintenance Work.	MSETCL	MSETCL	1. The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is to be carried out by dismantling the Isolator. So time is required for Dismantling and Erection alongwith Overhauling. 2. Replacement of 220KV Y phase IV CT due to Higher Tan Delta Value.
36	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 2	10-Nov-22	10:00	10-Nov-22	17:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
37	400 KV	JAIGAD - NEW KOYNA CKT - 1	10-Nov-22	09:00	10-Nov-22	18:00	Daily	Bay equipment maintenance/washing	JSWEL	JSWEL	Bay equipment maintenance/washing

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
38	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	10-Nov-22	08:00	10-Nov-22	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
39	400 KV	MAIN BAY (419) OF 400/220/33kv 500MVA ICT-I @ LONIKAND 2	10-Nov-22	08:00	10-Nov-22	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
40	400 KV	WARORA - IEPL	10-Nov-22	09:00	10-Nov-22	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL. Line is in ckt
41	400 KV	TIE BAY (405) OF STN T/F-3 & KORADI 3 CKT-2	10-Nov-22	10:00	10-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	Station Transformer-III will remain service in service through main bay 404 & 400kv Koradi-II -Koradi-III Ckt-II will remain in service through its main bay 405(full DIA)
42	400 KV	CHANDRAPUR - KHAPERKHEDA	11-Nov-22	08:00	11-Nov-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
43	400 KV	LONIKAND I-JEJURI	11-Nov-22	08:00	11-Nov-22	20:00	Daily	O/H & Serviceing of 29C PG Isolator & Replacement of PGI mechanism box.	MSETCL	MSETCL	NIL
44	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	11-Nov-22	10:00	11-Nov-22	18:00	Daily	1) Diagnostic Testing Work 2) Routine Maintenance Work	MSETCL	MSETCL	HV Bay Diagnostic Testing work Through TBC
45	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	11-Nov-22	07:00	11-Nov-22	18:00	Daily	Diagnostic testing & RM Work	MSETCL	MSETCL	ICT-1,2 will be in service
46	400 KV	TIE BAY (406) OF ICT -2 @ WARORA	11-Nov-22	09:00	11-Nov-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	Presently this bay is not charged codition.
47	400 KV	JAIGAD - NEW KOYNA CKT - 2	11-Nov-22	09:00	11-Nov-22	18:00	Daily	Bay equipment maintenance/washing	JSWEL	JSWEL	Bay equipment maintenance/washing
48	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	11-Nov-22	10:00	11-Nov-22	18:00	Daily	Transformer diagnostic testing and quarterly maintenance work	MSETCL	MSETCL	Nil
49	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	11-Nov-22	09:00	11-Nov-22	17:00	Daily	Differential, HV MV Back Up, REF, NDR Bushing Tan D, LV CT Tan D, SFRA and bay maintenance work	MSETCL	MSETCL	ICT 1, 3 and 4 will be in service
50	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	13-Nov-22	08:00	13-Nov-22	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	.
51	400 KV	JEJURI- KOYNA STAGE-IV	13-Nov-22	08:00	13-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
52	400 KV	CHANDRAPUR 2 - KUMBHARGAON (NANDED) CKT - 2	13-Nov-22	08:00	13-Nov-22	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	.
53	400 KV	KARAD - TALANDGE CKT - 2	14-Nov-22	08:00	14-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
54	400 KV	DHULE- - BABLESHWAR - II	14-Nov-22	09:00	14-Nov-22	18:00	Daily	Replacement work of PID suspicious strings & other maintenance work	MSETCL	MSETCL	400 kv Dhl-BBLR-1 line will be in service & AR switch will be put on Non auto mode.
55	400 KV	TBC @ BABHALESHWAR	14-Nov-22	09:00	14-Nov-22	16:00	Daily	CT Tan D	MSETCL	MSETCL	Outage will be availed if 400 KV TBC is free
56	400 KV	400KV TIE BAY 432 OF 500MVA 400/220KV ICT 1 @ CHANDRAPUR 2	14-Nov-22	10:00	14-Nov-22	17:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
57	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	14-Nov-22	10:00	19-Nov-22	18:00	Daily	1) String Disc Replacement Work 2) Maintenance Work	MSETCL	MSETCL	NIL
58	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	14-Nov-22	08:00	16-Nov-22	18:00	Daily	For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
59	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	14-Nov-22	09:00	14-Nov-22	18:00	Daily	(1) HV breaker & CTs testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
60	400 KV	KARAD - LONIKAND I	14-Nov-22	08:00	19-Nov-22	18:00	Daily	To carryout PID scanning	MSETCL	MSETCL	-
61	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	15-Nov-22	10:00	15-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	501 MVA 400/220/33 KV ICT-1 will remain in service through main bay 430
62	400 KV	TBC 1 @ CHANDRAPUR GCR	15-Nov-22	08:00	15-Nov-22	18:00	Daily	1) Circuit Breaker timing, CRM & DCRM. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators.	MSETCL	MSETCL	400KV CHANDRAPURPGCIL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service.
63	400 KV	MAIN BAY (407) OF ICT - 2 @ WARORA	15-Nov-22	09:00	15-Nov-22	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	Presently this bay is not charged codition.
64	400 KV	NEW KOYNA-KARAD CKT - 2	15-Nov-22	08:00	15-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
65	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	16-Nov-22	10:00	16-Nov-22	17:00	Daily	Diagnostic Testing of CBs	MSETCL	MSETCL	NA
66	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	16-Nov-22	09:00	16-Nov-22	18:00	Daily	400KV CT TAN DELTA, SFRA & DFRA OF ICT & OIL TOP UP OF ICT	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
67	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	16-Nov-22	10:00	16-Nov-22	18:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
68	400 KV	NEW KOYNA-KARAD CKT - 1	16-Nov-22	08:00	16-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
69	400 KV	CHANDRAPUR-PARLI CKT-3	17-Nov-22	08:00	17-Nov-22	18:00	Daily	For replacement ofpolymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
70	400 KV	MAIN BAY (403) OF LONIKAND CKT @ JEJURI	17-Nov-22	09:30	17-Nov-22	17:30	Daily	Testing and Maintenance Work	MSETCL	MSETCL	400kv Lonikand line will be in service through Tie Bay 402
71	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	17-Nov-22	09:00	17-Nov-22	17:00	Daily	MTAMC Work and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 4 will be in service
72	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	17-Nov-22	09:00	17-Nov-22	18:00	Daily	400KV CT TAN DELTA, SFRA & DFRA OF ICT & OIL TOP UP OF ICT	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
73	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	17-Nov-22	08:00	17-Nov-22	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
74	400 KV	MAIN Bay - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	17-Nov-22	08:00	17-Nov-22	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
75	400 KV	DHULE- - BABLESHWAR - I	17-Nov-22	08:00	17-Nov-22	18:00	Daily	cold line washing of insulator string and routine Line maintenance work, CT Tan D & Bay maintenance work	MSETCL	MSETCL	400kv Ektuni ckt I&II/400kv Bhusawal,400kv Aurangabad and Dhule II will be in in service
76	400 KV	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	17-Nov-22	10:00	17-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	501 MVA 400/220/33 KV ICT-1 will remain in service throughtie bay 429
77	400 KV	CHANDRAPUR-PARLI CKT-3	18-Nov-22	08:00	19-Nov-22	18:00	Daily	For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
78	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	18-Nov-22	08:00	18-Nov-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
79	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	18-Nov-22	10:00	18-Nov-22	18:00	Daily	1) Diagnostic Testing Work 2) Routine Maintenance Work	MSETCL	MSETCL	HV Bay Diagnostic Testing Work Through TBC
80	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	18-Nov-22	07:00	18-Nov-22	18:00	Daily	Diagnostic testing & RM work	MSETCL	MSETCL	Diagnostic testing & RM work
81	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	18-Nov-22	10:00	18-Nov-22	18:00	Daily	Transformer diagnostic testing and quarterly maintenance work	MSETCL	MSETCL	Nil
82	400 KV	JEJURI- KOYNA STAGE-IV	20-Nov-22	08:00	20-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
83	400 KV	MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	21-Nov-22	10:00	21-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	Station Transformer-III will remain service in service through Tie bay 408
84	400 KV	KARAD - TALANDGE CKT - 1	21-Nov-22	08:00	21-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
85	400 KV	400/220 KV 167 MVA ICT @ PARLI	21-Nov-22	09:00	21-Nov-22	18:00	Daily	(1) C & Tan delta measurement of ICT unit & CT. (2) Bay maintenance work.	MSETCL	MSETCL	-
86	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	21-Nov-22	08:00	21-Nov-22	18:00	Daily	For quarterly ICT & bay maintenance work	MSETCL	MSETCL	as per plan
87	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	21-Nov-22	10:00	26-Nov-22	18:00	Daily	1) String Disc Replacement Work 2) Maintenance Work	MSETCL	MSETCL	NIL
88	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	21-Nov-22	08:00	30-Nov-22	17:00	Daily	For PID Testing Work,shifting autoreclose switch to Non auto Mode .	MSETCL	MSETCL	For PID Testing Work,shifting autoreclose switch to Non auto Mode .
89	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	22-Nov-22	08:00	22-Nov-22	18:00	Daily	1. DFRA test of R, & Y & B-ph ICT units. 2) Maintenance and alignment of Isolators.	MSETCL	MSETCL	During outage, 315MVA ICT-1 and 220kV Chandrapur-2 ckt. Will be in service.
90	400 KV	KARAD - TALANDGE CKT - 2	22-Nov-22	08:00	22-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
91	400 KV	MAIN BAY (402) OF 315MVA ICT - 1 @ AKOLA	22-Nov-22	10:00	22-Nov-22	17:00	Daily	For DCRM, Tandelta & diagnostic work & routine maintenance	MSETCL	MSETCL	Tie bay 403 Will be in service
92	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	23-Nov-22	10:00	23-Nov-22	17:00	Daily	Diagnostic Testing of CBs	MSETCL	MSETCL	NA
93	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	24-Nov-22	08:00	24-Nov-22	17:00	Daily	Bus Insulator replacement work at section ICT I & ICT-II	MSETCL	MSETCL	Planned outage
94	400 KV	FUTURE CKT - 1 @ WARORA	24-Nov-22	09:00	24-Nov-22	17:00	Daily	Routine maintenance and Relay Testing works and isolator maintenance work, CT tan delta .	MSETCL	MSETCL	In Dia the IEPL ckt charged on its Main Bay CB
95	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	24-Nov-22	10:00	25-Nov-22	18:00	Continuous	For Overhauling of Bus C 89C Rph, Yph and Bph PG Isolators and Routine Testing and Maintenance Work.	MSETCL	MSETCL	The Existing 89 C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is to be carried out by dismantling the Isolator. So time is required for Dismantling and Erection alongwith Overhauling.
96	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	24-Nov-22	09:00	24-Nov-22	18:00	Daily	(1) Main-1 distance relay testing. (2)Bay maintenance work. (3) Hardware tightening & fitting work.	MSETCL	MSETCL	-
97	400 KV	LONIKAND I - KOYNA STAGE-IV	24-Nov-22	08:00	24-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
98	400 KV	TIE BAY (408) OF STN T/F-2 & KORADI 3 CKT-1 @ KORADI 2	24-Nov-22	10:00	24-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	Station Transformer-II will remain service in service through main bay 407& 400kv Koradi-II -Koradi-III Ckt-I will remain in service through its Main bay 409
99	400 KV	MAIN BAY (404) OF ICT - 2 @ JEJURI	24-Nov-22	09:30	24-Nov-22	17:30	Daily	Testing and Maintenance Work	MSETCL	MSETCL	ICT 2 will be in service through Tie Bay 405
100	400 KV	400 KV FUTURE BAY II @ WARORA	25-Nov-22	09:00	25-Nov-22	17:00	Daily	Routine maintenance, Relay Testing works and isolator maintenance work .	MSETCL	MSETCL	Tie BayCB 421 required to kept OFF position
101	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	25-Nov-22	10:00	25-Nov-22	17:00	Daily	DCRM, LV CT Tandelta & diagnostic & routine maintenance	MSETCL	MSETCL	load will be on ICT -01
102	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	26-Nov-22	09:00	26-Nov-22	17:00	Daily	MV CB Timing,DFRA and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 3 will be in service
103	400 KV	NEW KOYNA-KARAD CKT - 1	26-Nov-22	08:00	26-Nov-22	17:00	Daily	Bus Insulator replacement work at section Karad - I & II	MSETCL	MSETCL	Planned outage
104	400 KV	JEJURI- KOYNA STAGE-IV	27-Nov-22	08:00	27-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
105	400 KV	JAGAD - NEW KOYNA CKT - 2	27-Nov-22	08:00	28-Nov-22	17:00	Daily	Bus Insulator replacement work at section Jagad - I & II	MSETCL	MSETCL	Planned outage
106	400 KV	CHANDRAPUR-PARLI CKT-3	28-Nov-22	09:00	28-Nov-22	18:00	Daily	(1) Reactor testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work.	MSETCL	MSETCL	-
107	400 KV	NEW KOYNA-KARAD CKT - 2	28-Nov-22	08:00	28-Nov-22	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
108	400 KV	MIAN BAY-422 OF STATION TF - 1 @ KORADI -2	28-Nov-22	10:00	28-Nov-22	17:00	Daily	Diagnostic Testing of CT & CB and routine bay maintenance work	MSETCL	MSETCL	Station transformer-1 will remain in service through Tie Bay 423
109	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	28-Nov-22	08:00	28-Nov-22	18:00	Daily	Main-I & Main -II Distance relay testing	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I&II will be in service
110	400 KV	JEJURI- KOYNA STAGE-IV	28-Nov-22	08:00	30-Nov-22	18:00	Daily	PID testing of insulator strings	MSETCL	MSETCL	NIL
111	400 KV	DHULE - BABLESHWAR - I	28-Nov-22	09:00	28-Nov-22	18:00	Daily	On line PID work	MSETCL	MSETCL	400 kV Dhi-BBLR-I A/R switch will be kept on non auto mode
112	400 KV	KARAD - LONIKAND I	29-Nov-22	08:00	29-Nov-22	17:00	Daily	Cold line washing work	MSETCL	MSETCL	Cold line washing work