

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of NOV' 2023

Sr.No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
1	1	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1 (Taken on TBC at Bableshtar end)	C	CB pole overhauling work	29-Oct-23	09:00	2-Nov-23	18:00	400 KV Aurangabad will be in service through TBC. Outage in taken at 400KV BBLR Substation.
2	2	PLANNED	OCC_572	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator by Hot Line Method. 2.All Feeders on B Bus will be in service.	30-Oct-23	09:00	7-Nov-23	18:30	Weather condition should be clear for Hot Line Work.
3	3	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV (Element not found)	C	1.CB Mechanism Pole Overhauling Work. 2. A & B Bus PG Isolator Maintenance Work. 3.B Bus PG Isolator Replacement work under LES Scheme 4.BBLR-2 in service through TBC .	30-Oct-23	09:00	7-Nov-23	18:30	Weather condition should be clear.
4	38	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	1-Nov-23	08:00	1-Nov-23	18:00	--
5	39	PLANNED	OCC_572	MSLDC_OUTAGE	BALE - 220KV - BUS 2	D	Outage is required for Removing of 220KV Hybrid pass Bus Jumpers	1-Nov-23	09:00	1-Nov-23	16:00	If the load on 132kV Mohol & Chincholiatti increases, beyond permissible limit at certain time, Outage should be rescheduled.
6	40	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	1-Nov-23	09:00	1-Nov-23	17:30	-
7	53	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	A/R off for PID Testing work	1-Nov-23	09:00	3-Nov-23	18:00	A/R off for PID Testing work
8	54	PLANNED	OCC_572	DHARIWAL	400KV/6.9KV- DHARIWAL-STATION TRANSFORMER 2	D	Bay equipments PM, heavy oil leakages arresting work of Trans. HV bushing and Bay equipments testing work (CT Tan Delta, CB CRM& DCRM)	01-Nov-2023	9:00	04-Nov-2023	18:00	No Generation loss
9	66	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Nov-23	08:00	15-Nov-23	17:00	AR in Non-auto mode
10	67	PLANNED	OCC_572	POWERGRID-WR1	400KV-PARLI NEW-PARLI-M-2	C	For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS". AR to be kept in non Auto mode for 400KV-PARLI NEW-PARLI-M-1 for	1-Nov-2023	7:00	20-Nov-23	17:00	
11	83	PLANNED	OCC_572	POWERGRID-WR1	400KV-PARLI NEW-PARLI-M-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	1-Nov-2023	7:00	30-Nov-23	18:00	
12	84	PLANNED	OCC_572	POWERGRID-WR1	400KV-PARLI NEW-PARLI-M-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	1-Nov-2023	7:00	30-Nov-23	18:00	
13	85	PLANNED	OCC_572	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
14	86	PLANNED	OCC_572	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
15	87	PLANNED	OCC_572	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
16	88	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
17	89	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
18	90	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
19	91	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of faulty insulator in live line method.	01-Nov-2023	8:00	30-Nov-2023	18:00	AR disable
20	106	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Online PID (Puncture insulation Detection)Work 400 KV Dhule-SSNNL CKT 2. Auto jReclose switch will be kept on Non-Auto mode during Outage period.	1-Nov-23	08:00	30-Nov-23	16:00	400 KV Dhule-SSNNL CKT 2 Auto-reclose switch will be kept on Non Auto mode during Outage period
21	107	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Online PID (Puncture insulation Detection)Work 400 KV Dhule-SSNNL CKT 1. Auto jReclose switch will be kept on Non-Auto mode during Outage period.	1-Nov-23	08:00	30-Nov-23	16:00	400 KV Dhule-SSNNL CKT 1 Auto-reclose switch will be kept on Non Auto mode during Outage period.
22	109	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Installation 48F OPGW cable on Padghe II line	1-Nov-23	08:00	30-Nov-23	19:00	MTCL is planning to install 48F OPGW in live line condition. Hence, we request to issue permission to work
23	110	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Nov-23	09:00	30-Nov-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
24	111	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Nov-23	09:00	30-Nov-23	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
25	112	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	1-Nov-23	09:00	30-Nov-23	17:30	-
26	113	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Online PID work of 400 KV Dhule-Babhaleshwar line 2.	1-Nov-23	10:00	30-Nov-23	16:00	Only Auto reclose switch of 400kv Dhule-BBLR line 2 is required on non auto mode.
27	114	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Online PID work of 400kv Dhule -BBLR line-1	1-Nov-23	10:00	30-Nov-23	16:00	Only Auto reclose switch of 400 kv DHL-BBLR -1 line is required on non
28	115	PLANNED	OCC_572	POWERGRID-WR1	765KV-PUNE-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. New Construction Works	1-Nov-2023	8:00	15-Nov-23	18:00	765 KV PUNE PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
29	116	PLANNED	OCC_572	POWERGRID-WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. New Construction Works	1-Nov-2023	8:00	15-Nov-23	18:00	765 KV AURANGABAD PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE
30	128	PLANNED	OCC_572	POWERGRID-WR1	400KV-AKOLA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	2-Nov-2023	7:00	2-Nov-23	13:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacement of

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
31	131	PLANNED	OCC_572	POWERGRID-WR1	AKOLA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	2-Nov-2023	7:00	2-Nov-23	20:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacement of
32	143	PLANNED	OCC_572	POWERGRID-WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	D	Line Bay AMP works & attending Shutdown nature defects	2-Nov-2023	8:00	2-Nov-23	18:00	400KV-KOLHAPUR GIS-NARENDRA KUDGI-2 AR to be kept in Non-auto mode for safety in TLM works.
33	144	PLANNED	OCC_572	POWERGRID-WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-2	D	AR IN NON AUTO MODE IS REQUIRED	2-Nov-2023	8:00	2-Nov-23	18:00	
34	145	PLANNED	OCC_572	POWERGRID-WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	D	AR IN NON AUTO MODE IS REQUIRED	2-Nov-2023	8:00	2-Nov-23	18:00	
35	189	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	Cold washing of Insulator Strings	2-Nov-23	08:00	2-Nov-23	18:00	NIL
36	190	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	For PID detected Insulator strings	2-Nov-23	08:00	2-Nov-23	18:00	NIL
37	191	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	2-Nov-23	08:00	2-Nov-23	18:00	--
38	192	PLANNED	OCC_572	MSLDC_OUTAGE	BUS COUPLER BAY OF KOYNA - 400KV - BUS 1 AND KOYNA - 400KV - BUS 2 @KOYNA - 400KV at KOYNA - 400KV	D	Bus coupler time testing work	2-Nov-23	11:00	2-Nov-23	17:00	For checking of smooth operation of Bus Coupler.
39	198	PLANNED	OCC_572	MSLDC_OUTAGE	400KV/220KV CHAKAN-ICT-1	C	For Overhauling of SERGINIFPS Fire system for ICT No.1, Repairing and Overhauling of 89A PG isolators, Routine Maintenance and DT.	2-Nov-23	10:00	3-Nov-23	21:00	NIL
40	200	PLANNED	OCC_572	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-4	C	Rapid Restoration Scheme work; LV LBB relay,LV CT tan D, Bushing tan D, DFRA;Quarterly bay maintenance work	2-Nov-23	09:00	4-Nov-23	18:00	315 MVA ICT I and II and 501 MVA ICT III will be in service
41	201	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-DHULE-DHULE-MS-1	C	Own Circuit Breaker overhauling by OEM. line will be shift on 400kv TBC	2-Nov-23	09:00	5-Nov-23	18:00	Outage on Own CB and line will be shifted on 400KV TBC. i.e. interruption will be nil
42	202	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	2-Nov-23	09:00	7-Nov-23	17:30	-
43	210	PLANNED	OCC_572	POWERGRID-WR1	400KV-DHARIWAL-PARLI-2	D	Dead End permanent rectification at tower No 217 of Wardha- Nizamabad Ckt#1	3-Nov-2023	7:00	3-Nov-2023	18:00	Dead End permanent rectification at tower No 217 of Wardha- Nizamabad Ckt#1
44	266	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only for Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	3-Nov-23	06:00	3-Nov-23	10:00	For safety purpose only for Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220KV Boisar - PGCIL (Dead Line).
45	267	PLANNED	OCC_572	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	3-Nov-23	09:00	3-Nov-23	17:00	During 400KV Busbar Protection Relay testing works Outage , (1) 400KV Bus-I and 400KV Bus-II
46	268	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	Diagnostic Testing & Routine Maintenance	3-Nov-23	09:00	3-Nov-23	18:00	restoration will be kept out of commission. Diagnostic Testing & Routine Maintenance
47	269	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	1.Bay Maintenance work. 2.Diagnostic Testing Work. 3.Replacement of B ph CVT due to voltage variation of all cores & Minor oil Leakage. 4.Replacement 29C Bus PG Isolator under LES scheme .	3-Nov-23	09:00	3-Nov-23	18:00	Weather Condition should be clear.
48	273	PLANNED	OCC_572	APML	400KV/11.5KV TIRODA-ST-3	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	03-Nov-2023	9:00	04-Nov-2023	18:00	ST-5 will be in service with main bay
49	279	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	3-Nov-23	08:00	7-Nov-23	18:00	--
50	282	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	Replacement of old hardware at critical location	4-Nov-23	06:00	5-Nov-23	10:00	Simultaneously outage is required on 220kV Boisar-PGCIL-3 Line for Replacement of old hardware at
51	283	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Replacement of old hardware at critical location.	4-Nov-23	06:00	5-Nov-23	10:00	Simultaneously outage is required on 220kV Tarapur-Boisar Line for Replacement of old hardware at critical location & as both lines are on
52	330	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	Bay maintenance & equipment testing.	4-Nov-23	10:00	4-Nov-23	16:00	Bay maintenance & equipment testing.
53	333	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	C	400KV Kalwa-Talegaon(PG) line tap on 400KV Kalwa-Kharghar line For bunching between 400KV Kalwa-Talegaon & 400KV Kalwa-Kharghar Line between Loc no. 153-154 for erection of newly proposed 2 nos. of tower in between Loc no. 195-197 for MMRDA Katai Naka Bridge.	4-Nov-23	22:00	5-Nov-23	16:00	1)Simultaneously outage will be availed on 400KV Kalwa-Talegaon Line and 400KV Kalwa-Kharghar line for tapping. CB of 400KV Kalwa-Kharghar line will closed at both the end 2) The arrangement will be kept for 15 days
54	334	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	400KV Kalwa-Talegaon(PG) line tap on 400KV Kalwa-Kharghar line For bunching between 400KV Kalwa-Talegaon & 400KV Kalwa-Kharghar Line between Loc no. 153-154 for erection of newly proposed 2 nos. of tower in between Loc no. 195-197 for MMRDA Katai Naka Bridge.	4-Nov-23	22:00	5-Nov-23	16:00	1)Simultaneously outage will be availed on 400KV Kalwa-Talegaon Line and 400KV Kalwa-Kharghar line for tapping. CB of 400KV Kalwa-Kharghar line will closed at both the end 2) The arrangement will be kept for 15
55	338	PLANNED	OCC_572	POWERGRID-WR1	PUNE-PG - 400KV - BUS 1	D	AMP WORK	5-Nov-2023	9:00	5-Nov-2023	18:00	
56	339	PLANNED	OCC_572	POWERGRID-WR1	400KV-PUNE-GIS-PUNE-PG-4	D	Line Bay AMP WORK	5-Nov-2023	9:00	5-Nov-2023	17:00	

Sr.No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From	To	Remarks	
57	350	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	5-Nov-23	06:00	5-Nov-23 18:00	For safety purpose only. Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
58	351	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KARIJAT-LONIKHAND-II-2	D	Cold washing of Insulator Strings	5-Nov-23	08:00	5-Nov-23 18:00	NIL
59	352	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha	5-Nov-23	08:30	5-Nov-23 18:30	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also
60	353	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	(1) C & tan delta measurement of CTs. (2) Bay maintenance work. (3) Hardware tightening & fitting work & Clod washing work	5-Nov-23	09:00	5-Nov-23 18:00	-
61	354	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1. Bay Maintenance Work. 2. Diagnostic Testing Work. 3.Replacement of Old CT wit new CT having ratio 3000/1A. 4. Replacement of 29C Bus PG Isolator under LES Scheme.	5-Nov-23	09:30	5-Nov-23 18:00	weather Condition should be clear.
62	355	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Tapping Arrangement at Loc.No09 of 400KV Padgha-Kharghar (Dead)line thereby formation of Temporary 400kv Padghe - kharghar- Talegaon line for HTLS of 400KV Kalwa-Padgha-II line.	5-Nov-23	18:30	5-Nov-23 22:00	Above arrangement will be kept till 12.11.2023
63	356	PLANNED	OCC_572	MSLDC_OUTAGE	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	C	CB pole overhauling work	5-Nov-23	09:00	7-Nov-23 18:00	400 KV Main Bus I and II will be separated
64	368	PLANNED	OCC_572	POWERGRID-WR1	400KV-AURANGABAD-BOISAR-2	D	Line Bay AMP Work. AR OF CKT#1 TO BE KEPT IN NON AUTO MODE	6-Nov-23	8:00	6-Nov-23 16:00	427L
65	392	PLANNED	OCC_572	POWERGRID-WR1	TIE BAY - 400KV-KALWA-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-3 at PUNE-PG - 400KV	D	AMP WORK	6-Nov-2023	9:00	6-Nov-23 18:00	
66	402	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 for HTLS of 400KV Kalwa-Padgha II line.	6-Nov-23	08:30	6-Nov-23 08:00	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with 400KV Kharghar-Talegaon line to form 400kv Padghe - kharghar.
67	403	PLANNED	OCC_572	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Connection of 501 MVA ICT V isolator jumps to Main Bus 1 by Hotline method	6-Nov-23	09:00	6-Nov-23 13:00	Work will be done online through Hotline method
68	404	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	Diagnostic Testing & Routine Maintenance	6-Nov-23	09:00	6-Nov-23 18:00	Diagnostic Testing & Routine Maintenance
69	406	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	6-Nov-23	10:00	6-Nov-23 18:00	NA
70	407	PLANNED	OCC_572	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of 501 MVA ICT V isolator jumps to Main Bus II by Hotline method	6-Nov-23	13:00	6-Nov-23 18:00	Work will be done online through Hotline method
71	411	PLANNED	OCC_572	APML	400KV/11.5KV TIRODA-ST-5	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	06-Nov-2023	9:00	07-Nov-2023 18:00	ST-3 will be in service with main bay
72	415	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	6-Nov-23	08:00	7-Nov-23 18:00	NA
73	421	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-DHULE-DHULE-MS-2	C	Circuit Breaker overhauling work by OEM. Line will be shifted on 400KV TBC	6-Nov-23	09:00	9-Nov-23 18:00	Line will be shifted on 400kv TBC. ie No interruption in power supply.
74	425	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	A/R off for PID Testing work	6-Nov-23	09:00	10-Nov-23 18:00	A/R off for PID Testing work
75	432	PLANNED	OCC_572	POWERGRID-WR1	PARLI-M - 400KV - BUS 2	D	For erection of 89B isolator of 400KV New Parli- Parli-M-2 at mstcl girwali	7-Nov-2023	7:00	7-Nov-23 17:00	For ongoing project of "Upgradation of 400KV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to
76	471	PLANNED	OCC_572	POWERGRID-WR1	MAIN BAY - 400KV/220KV PUNE-PG-ICT-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	AMP WORK	7-Nov-2023	9:00	7-Nov-23 18:00	220kv 205 Main BAY Will shift to Transfer Bus Coupler Bay 204 BAY (TBC) before 205 Bay Shut down
77	495	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 for HTLS of 400KV Kalwa-Padgha II line.	7-Nov-23	08:30	7-Nov-23 08:00	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with 400KV Khatghar-Talegaon line to form 400kv Padghe - kharghar.
78	496	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	7-Nov-23	09:00	7-Nov-23 17:00	400KV-Khatghar-Talegaon line to only Tie CB 415 is in OFF condition, respective ckt charged through its own main CB.
79	498	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	7-Nov-23	10:00	7-Nov-23 18:00	NA
80	503	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Cold washing & Earthwire replcement	7-Nov-23	08:00	8-Nov-23 18:00	...
81	514	PLANNED	OCC_572	POWERGRID-WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element	8-Nov-2023	7:00	8-Nov-23 20:00	Insulator replacement work is proposed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line.
82	515	PLANNED	OCC_572	POWERGRID-WR1	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element	8-Nov-2023	7:00	8-Nov-23 20:00	Insulator replacement work is proposed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line.
83	516	PLANNED	OCC_572	POWERGRID-WR1	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element	8-Nov-2023	7:00	8-Nov-23 20:00	Insulator replacement work is proposed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line.
84	524	PLANNED	OCC_572	POWERGRID-WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-2	D	Line Bay AMP works & attending Shutdown nature defects	8-Nov-2023	8:00	8-Nov-23 18:00	400KV-KOLHAPUR GIS-NARENDRA KUDGI-1 AR to be kept in Non-auto mode for safety in TLM works.

Sr.No.	OCCM Sr.No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
85	535	PLANNED	OCC_572	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	D	AMP WORKS. A/R OFF OF CKT # 2 AND DIA TO BE KEPT OPEN AT BOTH ENDS.	08-Nov-2023	9:00	08-Nov-2023	18:00	PG-WR2-BOISAR
86	550	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	8-Nov-23	08:00	8-Nov-23	18:00	NA
87	551	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	8-Nov-23	08:00	8-Nov-23	18:00	--
88	552	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 for HTLS of 400KV Kalwa-Padgha II line.	8-Nov-23	08:30	8-Nov-23	08:00	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with 400KV Khatghar-Talegaon line to form 400kv Padgha - Kharghar-Talegaon line.
89	553	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	8-Nov-23	09:00	8-Nov-23	17:30	-
90	554	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	8-Nov-23	09:00	8-Nov-23	18:00	The said work is very important
91	556	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-1	D	Diagonestic testing (CT tan delta measurement work) & routine maint. work.	8-Nov-23	10:00	8-Nov-23	17:00	-
92	557	PLANNED	OCC_572	MSLDC_OUTAGE	JEUR - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	8-Nov-23	10:00	8-Nov-23	18:00	Quarterly Maintenance
93	564	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	Replacement of old hardware at critical location	8-Nov-23	06:00	9-Nov-23	10:00	Simultaneously outage is required on 220kV Borivali-Boisar(PG) Line for Replacement of old hardware at critical location & as both lines are on same M/C tower.
94	565	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Replacement of old hardware at critical location.	8-Nov-23	06:00	9-Nov-23	10:00	Simultaneously outage is required on 220kV Tarapur-Boisar Line for Replacement of old hardware at critical location & as both lines are on same M/C tower.
95	566	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	1) String replacement work. (2) Bay maintenance work.	8-Nov-23	09:00	9-Nov-23	18:00	-
96	568	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work	8-Nov-23	08:00	11-Nov-23	18:00	400 KV Padghe 1 will be in service through TBC
97	569	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	8-Nov-23	09:00	30-Nov-23	17:30	-
98	578	PLANNED	OCC_572	POWERGRID-WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries at intersection of both the Busses.	9-Nov-2023	7:00	9-Nov-23	19:00	Replacement of Old BHEL Insulators on gantries at intersection of both the Busses.
99	579	PLANNED	OCC_572	POWERGRID-WR1	WARDHA - 220KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries at intersection of both the Busses.	9-Nov-2023	7:00	9-Nov-23	19:00	Replacement of Old BHEL Insulators on gantries at intersection of both the Busses.
100	580	PLANNED	OCC_572	POWERGRID-WR1	400KV-PADGHE-PG-KUDUS-2	D	AMP of 418L at MSETCL Kudus substation	9-Nov-2023	8:00	9-Nov-23	16:00	400kV Padghe Kudus circuit 2 will be out of service.
101	598	PLANNED	OCC_572	POWERGRID-WR1	400KV-CHAKAN-PUNE-PG-1	D	Line Bay AMP WORK	9-Nov-2023	9:00	9-Nov-23	18:00	Line Owned by the MSETCL
102	608	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	D	1.PID testing work on Disc insulator of stub bus in 400KV HVDC CKT-1 bay. 2. Shifting of AR switch from Auto to Non Auto mode is not required	9-Nov-23	08:00	9-Nov-23	12:00	Online PID work will be carried out.
103	609	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	For PID detected Insulator strings	9-Nov-23	08:00	9-Nov-23	18:00	NIL
104	610	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	9-Nov-23	08:00	9-Nov-23	18:00	--
105	611	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	9-Nov-23	08:00	9-Nov-23	18:00	NA
106	612	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 for HTLS of 400KV Kalwa-Padgha II line.	9-Nov-23	08:30	9-Nov-23	08:00	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with 400KV Khatghar-Talegaon line to form 400kv Padghe - kharghar-Talegaon line.
107	614	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	D	1.PID testing work on Disc insulator of stub bus in 400KV HVDC CKT-2 bay. 2. Shifting of AR switch from Auto to Non Auto mode is not required	9-Nov-23	15:00	9-Nov-23	18:00	Online PID work will be carried out.
108	628	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	10-Nov-2023	8:00	10-Nov-2023	18:00	Outage
109	629	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	10-Nov-2023	8:00	10-Nov-2023	18:00	Outage
110	634	PLANNED	OCC_572	POWERGRID-WR1	PUNE-PG - 220KV - BUS 1	D	AMP WORK	10-Nov-2023	9:00	10-Nov-23	18:00	

No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continu- ous	Reason	From		To		Remarks
111	644	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 for HTLS of 400KV Kalwa-Padgha II line.	10-Nov-23	08:30	10-Nov-23	18:00	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with 400KV Khatghar-Talegaon line to form 400kv Padghe - kharghar-Talegaon line.
112	648	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	10-Nov-23	08:00	15-Nov-23	18:00	--
113	654	PLANNED	OCC_572	POWERGRID-WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	Bay AMP Work	11-Nov-23	7:00	11-Nov-23	18:00	415
114	655	PLANNED	OCC_572	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	D	AMP. DIA TO BE KEPT OPEN AT BOTH SIDES	11-Nov-2023	7:00	11-Nov-2023	21:00	PG-WR2-BOISAR
115	656	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	11-Nov-2023	8:00	11-Nov-2023	18:00	Outage
116	657	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	11-Nov-2023	8:00	11-Nov-2023	18:00	Outage
117	658	PLANNED	OCC_572	POWERGRID-WR1	TIE BAY OF 400KV-PADGHE-PG-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	AMP of Tie bay (414 bay) at MSETCL Kodus Substation	11-Nov-2023	8:00	11-Nov-23	18:00	414 bay will be out of service at MSETCL Kodus Substation.
118	663	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	For bunching arrangement of 400kv kalwa padgha Ckt 2 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 for HTLS of 400KV Kalwa-Padgha II line.	11-Nov-23	08:30	11-Nov-23	18:00	Above arrangement will be kept for 1 week approx. where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with
119	668	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kv Boisar - PGCIL (Dead Line).	11-Nov-23	06:00	12-Nov-23	18:00	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220KV Boisar - PGCIL (Dead Line).
120	674	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	Replacement of existing conductor by HTLS conductor	12-Nov-23	08:30	12-Nov-23	18:30	Replacement of existing conductor by HTLS conductor
121	677	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	12-Nov-2023	8:00	12-Nov-2023	18:00	Outage
122	678	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	12-Nov-2023	8:00	12-Nov-2023	18:00	Outage
123	680	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Removing of Bunching at Loc.No.03 for 400kv Kalwa padgha ckt 2 & 132 of 400KV padghe kharghar line & removing Tapping arrangement at Loc.No.09 (Kharghar Talegaon line) to restore 400KV Kharghar-Talegaon & 400KV Kalwa- Padgha-2 lines.	12-Nov-23	08:30	12-Nov-23	15:00	Removing of Bunching at Loc.No.03 for 400kv Kalwa padgha ckt 2 & 132 of 400KV padghe kharghar line & removing Tapping arrangement at Loc.No.09 (Kharghar Talegaon line) to restore 400KV Kharghar-Talegaon & 400KV Kalwa- Padgha-2 lines.
124	681	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	Removing of Bunching at Loc.No.03 for 400kv Kalwa padgha ckt 2 & 132 of 400KV padghe kharghar line & removing Tapping arrangement at Loc.No.09 (Kharghar Talegaon line) to restore 400KV Kharghar-Talegaon & 400KV Kalwa- Padgha-2 lines.	12-Nov-23	15:00	12-Nov-23	20:00	Removing of Bunching at Loc.No.03 for 400kv Kalwa padgha ckt 2 & 132 of 400KV padghe kharghar line & removing Tapping arrangement at Loc.No.09 (Kharghar Talegaon line) to restore 400KV Kharghar-Talegaon & 400KV Kalwa- Padgha-2 lines.
125	690	PLANNED	OCC_572	POWERGRID-WR1	400KV-KALA-KUDUS-2	D	AMP of 401L at MSETCL Kodus Substation.	13-Nov-2023	8:00	13-Nov-23	18:00	400KV Kala Kodus Circuit-2 will be out of service.
126	695	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Tapping Arrangement at Loc.No09 of 400KV Padgha-Kharghar (Dead)line thereby formation of Temporary 400kv Padghe - kharghar- Talegaon line for HTLS of 400KV Kalwa-Padgha-I line.	13-Nov-23	19:00	13-Nov-23	22:00	Above arrangement will be kept till 45 days
127	700	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	For bunching arrangement of 400kv kalwa padgha Ckt 1 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 using ERS for HTLS of 400KV Kalwa-Padgha I line.	13-Nov-23	08:30	31-Dec-23	18:30	Above arrangement will be kept for approximately 45 days where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with
128	708	PLANNED	OCC_572	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2 L/R@ BOISAR - 400KV	D	AMP	14-Nov-2023	9:00	14-Nov-2023	18:00	PG-WR2-BOISAR
129	716	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	C	400KV Kalwa-Kharghar line tap 400KV Kalwa-Talegaon(PG) at Loc no. 153-154. For stringing of newly erected 2 Nos, towers in between location no.195 to 197, after erection of newly proposed 2 No. tower in between loc no. 195 to 197. MMRDA Katni Naka Bridge.	11/14/2023	22:00	11/15/2023	06:00	1)Tap line 400KV Talegaon(PG)-Kalwa-Kharghar line outage will be availed for 400KV Kalwa-Kharghar line tap on 400KV Kalwa-Talegaon(PG). CB of 400KV Kalwa-Talegaon (PG) line closed at both end
130	717	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	C	400KV Kalwa-Kharghar line tap on 400KV Kalwa-Talegaon(PG) at Loc no. 153-154. For stringing of newly erected 2 Nos, towers in between location no.195 to 197, after erection of newly proposed 2 No. tower in between loc no. 195 to 197. MMRDA Katni Naka Bridge.	11/14/2023	22:00	11/15/2023	06:00	1)Tap line 400KV Talegaon(PG)-Kalwa-Kharghar line outage will be availed for 400KV Kalwa-Kharghar line tap on 400KV Kalwa-Talegaon(PG). CB of 400KV Kalwa-Talegaon (PG) line closed at both the
131	723	PLANNED	OCC_572	POWERGRID-WR1	400KV-SOLAPUR-M-SOLAPUR-1	D	Line side equipment AMP at 765kV Solappur Substation	15-Nov-2023	8:00	15-Nov-23	16:00	
132	724	PLANNED	OCC_572	POWERGRID-WR1	220KV-WARDHA-YAVATMAL-1	D	For Amp of Line Bay & Main Bay	15-Nov-2023	8:00	15-Nov-23	16:00	Newly charged element on Anti theft on 13.04.2023 name not found in data
133	730	PLANNED	OCC_572	POWERGRID-WR1	400KV-KALA-KUDUS-1	D	AMP of 404L at MSETCL Kodus Substation.	15-Nov-2023	8:00	15-Nov-23	18:00	400KV Kala Kodus Circuit-2 will be out of service.
134	737	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	15-Nov-23	09:00	15-Nov-23	17:30	-

Sr.No.	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continu- ous	Reason	From	To	To	Remarks	
135	738	PLANNED	OCC_572	POWERGRID-WR1	400KV-BHILAI-KORADI-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Bhilai Line Out of Service.	15-Nov-2023	7:00	16-Nov-23	19:00	
136	741	PLANNED	OCC_572	POWERGRID-WR1	MAIN BAY - 400KV-BHILAI-KORADI-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of BHI CGL CB at Koradi SS, 400kv Koradi-Bhilai Line	15-Nov-2023	7:00	20-Nov-23	19:00	
137	746	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	PID work	15-Nov-23	08:00	30-Nov-23	18:00	only A/R out of service during PID work.
138	756	PLANNED	OCC_572	POWERGRID-WR1	220KV-WARDHA-YAVATMAL-2	D	For Amp of Line Bay & Main Bay	16-Nov-2023	7:00	16-Nov-23	20:00	Newly charged element on Anti theft on 29.05.2023 name not found in data base.
139	760	PLANNED	OCC_572	POWERGRID-WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	For taking Line Reactor in service and out of service only	16-Nov-23	8:00	16-Nov-23	16:00	401L (Waluj)
140	761	PLANNED	OCC_572	POWERGRID-WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	Aircel replacement work	16-Nov-23	8:00	16-Nov-23	16:00	401LR (Waluj)
141	762	PLANNED	OCC_572	POWERGRID-WR1	KOLHAPUR-MS - 400KV B/R 2	D	Reactor AMP	16-Nov-2023	8:00	16-Nov-23	16:00	80 MVAr Bus reactor
142	769	PLANNED	OCC_572	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1 L/R@ BOISAR - 400KV	D	AMP	16-Nov-2023	9:00	16-Nov-2023	18:00	PG-WR2-BOISAR
143	775	PLANNED	OCC_572	POWERGRID-WR1	220KV-TALEGAON-PUNE-PG-1	D	Line Bay AMP WORK	16-Nov-2023	9:00	16-Nov-23	18:00	Line Owned by the MSETCL
144	785	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	16-Nov-23	08:00	16-Nov-23	18:00	--
145	786	PLANNED	OCC_572	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	16-Nov-23	09:00	16-Nov-23	18:00	The said work is very important
146	787	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Repairing and Overhauling of 89A PG isolators, Routine Maintenance and DT.	16-Nov-23	10:00	16-Nov-23	18:00	NIL
147	790	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Replacement of old hardware at critical location.	16-Nov-23	06:00	17-Nov-23	10:00	Simultaneously outage is required on 220kV Tarapur-Borivali Line for Replacement of old hardware at
148	791	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Replacement of old hardware at critical location	16-Nov-23	06:00	17-Nov-23	10:00	Simultaneously outage is required on 220kV Borivali-Boisar(PG) Line for Replacement of old hardware at
149	797	PLANNED	OCC_572	POWERGRID-WR1	400KV-BHILAI-KORADI-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Bhilai line on TBC Bay.	16-Nov-2023	7:00	20-Nov-23	19:00	
150	799	PLANNED	OCC_572	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 - Bhilad	C	220kV Bhilad Feeder SF-6 breaker major overhauling. Feeder outage is not required. Feeder will be on transferred on bus coupler.	16-Nov-2023	8:00	25-Nov-2023	20:00	Feeder outage is not required; feeder will be on bus coupler; code is required during bus transfer process while taking out the breaker and also while
151	801	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	16-Nov-23	08:00	30-Nov-23	17:00	
152	820	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	17-Nov-2023	8:00	17-Nov-2023	18:00	Outage
153	821	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	17-Nov-2023	8:00	17-Nov-2023	18:00	Outage
154	822	PLANNED	OCC_572	POWERGRID-WR1	220KV-MAPUSA-AMONA-1	D	AMP Works	17-Nov-2023	8:00	17-Nov-23	18:00	
155	823	PLANNED	OCC_572	POWERGRID-WR1	BUS COUPLER BAY - SOLAPUR - 220KV - BUS 1 AND SOLAPUR - 220KV - BUS 2 at Solapur - 220KV	D	Bay AMP Works	17-Nov-2023	8:00	17-Nov-23	18:00	
156	845	PLANNED	OCC_572	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 2	D	Regular Maint work and Dignostic testing work	17-Nov-23	08:00	17-Nov-23	17:00	NA
157	846	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY - 400KV-EKTUNI-BABLESHWAR-2 AND 765KV/400KV EKTUNI-ICT-1 at EKTUNI - 400KV	D	Diagnostic Testing & Routine Maintenance	17-Nov-23	09:00	17-Nov-23	17:00	Diagnostic Testing & Routine Maintenance
158	850	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Replacement of discs type insulators with AF Long rod insulators.	17-Nov-23	08:00	18-Nov-23	18:00	NIL
159	851	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	A/R off for PID of the line.	17-Nov-23	09:00	19-Nov-23	18:00	A/R off for PID of the line.
160	853	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	17-Nov-23	08:00	22-Nov-23	18:00	--
161	854	PLANNED	OCC_572	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	17-Nov-23	08:00	24-Nov-23	20:00	Chandrapur has been informed
162	855	PLANNED	OCC_572	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	17-Nov-23	08:00	24-Nov-23	20:00	Pole-2 will be in service with 750MW capacity
163	863	PLANNED	OCC_572	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	AMP. DIA TO BE KEPT OPEN AT BOTH SIDES	18-Nov-2023	7:00	18-Nov-2023	21:00	PG-WR2-BOISAR
164	868	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	18-Nov-2023	8:00	18-Nov-2023	18:00	Outage
165	869	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	18-Nov-2023	8:00	18-Nov-2023	18:00	Outage
166	880	PLANNED	OCC_572	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 2	D	Regular Maint work and Dignostic testing work	18-Nov-23	08:00	18-Nov-23	17:00	NA
167	882	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	C	1.Bay Maintenance Work. 2. Diagnostic Testing Work. 3. MTAMC work.	18-Nov-23	09:00	25-Nov-23	18:00	Weather Condition should be clear.
168	888	PLANNED	OCC_572	POWERGRID-WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line Bay AMP and relay testing	19-Nov-2023	8:00	19-Nov-23	16:00	Outage required on line for Line bay equipment AMP works

Sr.No.	OCCM Sr.No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuous	Reason	From		To		Remarks
169	889	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Maintenance	19-Nov-2023	8:00	19-Nov-2023	18:00	Outage
170	890	PLANNED	OCC_572	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	19-Nov-2023	8:00	19-Nov-2023	18:00	Outage
171	893	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) Main-1 distance relay testing, (2) Bay maintenance work, (3) Hardware tightening & fitting work & Clod washing work	19-Nov-23	09:00	19-Nov-23	18:00	-
172	894	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	SSN to DSN replacement of insulator string Project & FWC mid span joint	19-Nov-23	09:00	19-Nov-23	18:30	SSN to DSN replacement of insulator string Project & FWC mid span joint
173	895	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Bay maintenance & equipment testing.	19-Nov-23	10:00	19-Nov-23	16:00	Bay maintenance & equipment testing.
174	897	PLANNED	OCC_572	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-1	C	CB pole overhauling work	19-Nov-23	09:00	22-Nov-23	18:00	400/220 KV ICT1 HVV will be in service through TBC
175	898	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	C	Scheme work of replacement of existing 0.5 ACSR conductor by HTLS conductor	19-Nov-23	06:00	9-Dec-23	17:00	for enhancing the capacity of this line.
176	907	PLANNED	OCC_572	POWERGRID-WR1	MAIN BAY - 400KV-PARLI-SOLAPUR-1 AND PARLI - 400KV - BUS 2 at PARLI - 400KV	D	CT SEEPAGE ARRESTING	20-Nov-2023	8:00	20-Nov-23	18:00	
177	913	PLANNED	OCC_572	POWERGRID-WR1	400KV-PUNE-GIS-PARLI-1	D	FOR AMP	20-Nov-2023	9:00	20-Nov-23	17:00	FOR AMP
178	934	PLANNED	OCC_572	MSLDC_OUTAGE	BUS COUPLER BAY OF NAGOTHANE - 400KV - BUS 1 AND NAGOTHANE - 400KV - BUS 2 @NAGOTHANE - 400KV at NAGOTHANE	D	for 400 kv CB replacement work	20-Nov-23	08:00	20-Nov-23	17:00	NA
179	936	PLANNED	OCC_572	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	20-Nov-23	09:00	20-Nov-23	18:00	The said work is very important
180	937	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY - 400KV-TAPTHITHANDA-EKTUNI-2 AND FUTURE at EKTUNI - 400KV	D	Diagnostic Testing & Routine Maintenance	20-Nov-23	09:00	20-Nov-23	18:00	Diagnostic Testing & Routine Maintenance (402 TIE BAY)
181	948	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-BHUSAWAL-AURANGABAD-M (WALUJ)-1	D	Routine Line maintenance and Insulator cleaning work	20-Nov-23	08:00	21-Nov-23	18:00	400kV Ektuni ckt 1&II,400kV Bhusawal,400kv Aurangabad and Dhule I will be in service
182	949	PLANNED	OCC_572	RGPP	MAIN BAY OF 400KV/15.7KV RGPP-LGT-1A AND RGPP - 400KV - BUS 2 @RGPP - 400KV at RGPP - 400KV	C	Attending SF6 leakages and gasket replacement	20-Nov-23	8:00	22-Nov-23	18:00	
183	954	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND FUTURE @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	C	CB mechanism overhauling work by M/s CGL service engineer.	20-Nov-23	11:00	23-Nov-23	18:00	C outage required for CB mechanism overhauling work by M/s CGL service engineer.
184	959	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Diagnostic testing work of CT, CB. 2. Bay maintenance work.	20-Nov-23	08:00	25-Nov-23	18:00	400KV HVDC-2 will be in service. There will be power restriction of 750MW on HVDC Bipole during
185	1007	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work .	21-Nov-23	09:00	21-Nov-23	17:00	400KV WARORA-IEPL Line is in ckt
186	1008	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	D	Diagnostic testing and allied bay maintenance	21-Nov-23	10:00	21-Nov-23	17:00	Diagnostic testing and allied bay maintenance
187	1011	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-RGPP-L-NAGOTHANE-1	D	Cold washing & Earthwire replcement	21-Nov-23	08:00	22-Nov-23	18:00	...
188	1071	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	22-Nov-23	09:00	22-Nov-23	17:30	-
189	1072	PLANNED	OCC_572	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Diagnostic Testing & Routine Maintenance	22-Nov-23	09:00	22-Nov-23	18:00	Diagnostic Testing & Routine Maintenance (ICT-2 UNIT)
190	1073	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	22-Nov-23	09:00	22-Nov-23	18:00	The said work is very important
191	1083	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Replacement of old hardware at critical location.	22-Nov-23	06:00	23-Nov-23	10:00	Simultaneously outage is required on 220kV Tarapur-Borivali Line for Replacement of old hardware at
192	1086	PLANNED	OCC_572	POWERGRID-WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of SRN CGL CB at Koradi SS, 400kv Koradi-Sami Line	22-Nov-2023	7:00	27-Nov-23	19:00	
193	1102	PLANNED	OCC_572	POWERGRID-WR1	MAIN BAY - 400KV-PARLI-M-PARLI-1 AND PARLI - 400KV - BUS 2 at PARLI - 400KV	D	CT SEEPAGE ARRESTING	23-Nov-2023	8:00	23-Nov-23	18:00	
194	1107	PLANNED	OCC_572	POWERGRID-WR1	400KV/220KV PUNE-PG-ICT-2	D	AMP WORK	23-Nov-2023	9:00	23-Nov-23	17:00	
195	1109	PLANNED	OCC_572	POWERGRID_WR2	220KV-BOISAR-PANCHALI-1	D	AMP	23-Nov-2023	9:00	23-Nov-2023	17:30	PG-WR2-BOISAR
196	1132	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	23-Nov-23	08:00	23-Nov-23	18:00	--
197	1133	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	23-Nov-23	09:00	23-Nov-23	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
198	1134	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenance work.	23-Nov-23	09:00	23-Nov-23	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
199	1141	PLANNED	OCC_572	RGPP	TIE BAY OF 400KV/15.7KV RGPP-LGT-3B AND 400KV/15.7KV RGPP-LGT-3X @RGPP - 400KV at RGPP - 400KV	C	Attending SF6 leakages and gasket replacement	23-Nov-23	8:00	25-Nov-23	18:00	

Sr.No	OCCM Sr.No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From	To	Remarks		
200	1145	PLANNED	OCC_572	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-3	C	Rapid Restoration Scheme work;DFRA/Quarterly bay maintenance work	23-Nov-23	09:00	25-Nov-23	18:00	315 MVA ICT I and II and 501 MVA ICT IV will be in service
201	1147	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV (Element not found)	C	CB pole overhauling work	23-Nov-23	09:00	26-Nov-23	18:00	400 KV Padghe II will be in service through TBC
202	1151	PLANNED	OCC_572	POWERGRID-WR1	400KV-PUNE-GIS-PUNE-PG-4	C	For attending SF6 Gas Leakage & AMP works	24-Nov-2023	7:00	26-Nov-23	7:00	SF6 Gas Leakage Attend
203	1152	PLANNED	OCC_572	POWERGRID-WR1	SOLAPUR - 220KV - BUS 2	D	220KV Bus#2 AMP Works Note 1 : Before shutdown , All the elements connected with 220kV Bus#2 shall be shifted to 220kV Bus#1 Note 2: Each element shall be shifted to TBC one by one for maintenance of Bus#2 Isolators.	24-Nov-2023	7:00	24-Nov-23	18:00	
204	1190	PLANNED	OCC_572	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 1	D	Regular Maint work and Dignostic testing work	24-Nov-23	08:00	24-Nov-23	17:00	NA
205	1191	PLANNED	OCC_572	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT tan delta & maintenance work	24-Nov-23	09:00	24-Nov-23	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV,125MVAR reactor kept off position during outage.
206	1192	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY - 400KV-TAPTHITHANDA-EKTUNI-1 AND 765KV/400KV EKTUNI-ICT-2	D	Diagnostic Testing & Routine Maintenance	24-Nov-23	09:00	24-Nov-23	18:00	Diagnostic Testing & Routine Maintenance (405 TIE BAY)
207	1196	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	24-Nov-23	06:00	26-Nov-23	10:00	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
208	1197	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	for the work of replacement of existing 0.5 ACSR conductor to HTLS Conductor on 400KV 400KV Chandrapur GCR- Chand-2-ckt-2	24-Nov-23	06:00	26-Nov-23	18:00	This line is under crossing at Loc. No. L1LO-2-L1LO3 of 400KV Chandrapur GCR -Chand2- ckt-2. Hence for safety point of view Non -Auto Mode is required..
209	1198	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	for the work of replacement of existing 0.5 ACSR conductor to HTLS Conductor on 400KV 400KV Chandrapur GCR- Chand-2-ckt-2	24-Nov-23	06:00	26-Nov-23	18:00	This line is under crossing at Loc. No. L1LO-2-L1LO3 of 400KV Chandrapur GCR -Chand2- ckt-2. Hence for safety point of view Non -Auto Mode is required..
210	1199	PLANNED	OCC_572	POWERGRID-WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Sarni line on TBC Bay.	24-Nov-2023	7:00	27-Nov-23	19:00	
211	1200	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	24-Nov-23	08:00	29-Nov-23	18:00	--
212	1201	PLANNED	OCC_572	POWERGRID-WR1	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	24-Nov-2023	7:00	24-Nov-2023	13:00	
213	1202	PLANNED	OCC_572	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-1	C	Stringing of diversion work for bullet train between loc no 197-199. Simultaneous outage of 400KV Aurangabad-Boisar # 1&2 and 400KV Magarwada-Boisar # 1&2 are required due to multicircuit towers and Dia to be kept open at both ends	25-Nov-2023	9:00	30-Nov-2023	19:00	PG-WR2-BOISAR TLC
214	1203	PLANNED	OCC_572	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	C	Stringing of diversion work for bullet train between loc no 197-199. Simultaneous outage of 400KV Aurangabad-Boisar # 1&2 and 400KV Magarwada-Boisar # 1&2 are required due to multicircuit towers and Dia to be kept open at both ends	25-Nov-2023	9:00	30-Nov-2023	19:00	PG-WR2-BOISAR TLC
215	1214	PLANNED	OCC_572	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	Annual Maintenance	25-Nov-2023	8:00	25-Nov-2023	18:00	Outage
216	1215	PLANNED	OCC_572	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	AR disable for annual maintenance in 400KV Pune (GIS)-Aurangabad-1	25-Nov-2023	8:00	25-Nov-2023	18:00	AR disable
217	1222	PLANNED	OCC_572	POWERGRID_WR2	TIE BAY - 400KV-KHANDWA-DHULE-MS-2 AND KHANDWA - 400KV B/R 2 at KHANDWA - 400KV	D	AMP WORK	25-Nov-2023	9:00	25-Nov-2023	18:00	PG-WR2-KHANDWA
218	1223	PLANNED	OCC_572	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	AMP	25-Nov-2023	9:00	25-Nov-2023	18:00	PG-WR2-BOISAR
219	1244	PLANNED	OCC_572	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 1	D	Regular Maint work and Dignostic testing work	25-Nov-23	08:00	25-Nov-23	17:00	NA
220	1245	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II -	D	Diagnostic testing and Maintenance	25-Nov-23	08:00	25-Nov-23	18:00	NIL
221	1246	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND FUTURE	D	Diagnostic testing and Maintenance	25-Nov-23	08:00	25-Nov-23	18:00	NIL
222	1247	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage is required for taking half bus section I for jumpering of hybrid switchgear bus sectionaliser work.	25-Nov-23	08:00	25-Nov-23	20:00	-
223	1253	PLANNED	OCC_572	POWERGRID-WR1	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	25-Nov-2023	14:00	25-Nov-2023	19:00	
224	1259	PLANNED	OCC_572	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	Annual Maintenance	26-Nov-2023	8:00	26-Nov-2023	18:00	Outage
225	1260	PLANNED	OCC_572	WTPL	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	AR disable for annual maintenance in 400KV Pune (GIS)-Aurangabad-2	26-Nov-2023	8:00	26-Nov-2023	18:00	AR disable

Sr.No	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	Daily / Continuo us	Reason	From		To		Remarks
226	1262	PLANNED	OCC_572	MSLDC_OUTAGE	KALWA - 400KV - BUS 1	D	400KV Padgha I & II stub bus erection work.	26-Nov-23	09:00	26-Nov-23	17:00	Partial outage will be taken on 400KV A-Bus
227	1263	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN replacement of insulator string Project & FWC mid span joint	26-Nov-23	09:00	26-Nov-23	18:30	SSN to DSN replacement of insulator string Project & FWC mid span joint
228	1264	PLANNED	OCC_572	RGPPL	TIE BAY OF 400KV-RGPPL- NAGOTHANE-2 AND 400KV/15.7KV RGPPL-GT-3A @RGPPL - 400KV at RGPPL - 400KV	C	Attending SF6 leakages and gasket replacement	26-Nov-23	8:00	29-Nov-23	18:00	
229	1265	PLANNED	OCC_572	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	26-Nov-23	08:00	1-Dec-23	20:00	Chandrapur has been informed
230	1266	PLANNED	OCC_572	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	26-Nov-23	08:00	1-Dec-23	20:00	1.Pole-1 will be in service with 750 MW
231	1269	PLANNED	OCC_572	POWERGRID-WR1	SOLAPUR - 220KV - BUS 1	D	220KV Bus#1 AMP Works Note : Before shutdown , All the elements connected with 220kV Bus#1 shall be shifted to 220kV Bus#2 Note 2: Each element shall be shifted to TBC one by one for maintenance of Bus#1 Isolators.	27-Nov-2023	7:00	27-Nov-23	18:00	
232	1284	PLANNED	OCC_572	GETCO	220KV-TARAPUR 1&2-BHILAD-1	D	PMM work	27-Nov-23	9:00	27-Nov-23	18:00	
233	1292	PLANNED	OCC_572	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Bus CVT tan D testing	27-Nov-23	08:00	27-Nov-23	18:00	All feeders and ICT on Main Bus I will be shifted on Main Bus II through TBC
234	1304	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-BHUSAWAL-AURANGABAD- M (WALUJ)-1	D	Routine Line maintenance and Insulator cleaning work	27-Nov-23	08:00	28-Nov-23	18:00	400KV Ektuni ckt I&II,400kV Bhusawal,400kv Aurangabad and Dhule.I will be in service
235	1309	PLANNED	OCC_572	NPCIL, TAPS 1&2	220 kV-Tanapur1&2 – Borivali	C	220kV Borivali Feeder SF-6 breaker major overhauling. Feeder outage is not required. Feeder will be on transferred on bus coupler.	27-Nov-2023	8:00	06-Dec-2023	20:00	Feeder outage is not required; feeder will be on bus coupler; code is required during bus transfer process while taking out the breaker and also while
236	1350	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA- WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	28-Nov-23	08:00	28-Nov-23	17:00	Line will be charged through Tie CB 428.
237	1351	PLANNED	OCC_572	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	28-Nov-23	09:00	28-Nov-23	17:00	During 400KV Busbar Protection Relay testing works Outage . (1). 400KV Bus-I and 400KV Bus-II
238	1352	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY - 400KV-EKTUNI- BABLESHWAR-2 AND EKTUNI - 400KV - BUS 1 at EKTUNI - 400KV	D	Diagnostic Testing & Routine Maintenance	28-Nov-23	09:00	28-Nov-23	18:00	Diagnostic Testing & Routine Maintenance (408 MAIN BAY)
239	1364	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-BABLESHWAR- AURANGABAD-M (WALUJ)-1 (Taken on TBC at Bableshtar end)	C	CB pole overhauling work	28-Nov-23	09:00	1-Dec-23	18:00	400 KV Aurangabad will be in service through TBC
240	1365	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR- CHANDRAPUR HVDC-2	C	1. CB pole overhauling work. 2.Diagnostic testing work of CT, CB. 3. Bay maintenance work.	28-Nov-23	08:00	5-Dec-23	18:00	400KV HVDC-1 will be in service. There will be power restriction of 750MW on HVDC Bipole during outage
241	1366	PLANNED	OCC_572	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-2	C	1.Bay Maintenance Work. 2.Diagnostic Testing Work. 3.MTAMC work. 4.Replacement of old BHEL Make 7 Core CT with New 7 Core CT of CGL make. 5.Replacement of A Bus B Ph PG Isolator under LES Scheme.	28-Nov-23	09:00	5-Dec-23	18:00	Weather condition should be clear.
242	1370	PLANNED	OCC_572	POWERGRID-WR1	KORADI - 400KV - BUS 1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Nov-2023	7:00	29-Nov-23	19:00	
243	1398	PLANNED	OCC_572	POWERGRID-WR1	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Nov-2023	14:00	29-Nov-23	19:00	
244	1399	PLANNED	OCC_572	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA- KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	29-Nov-23	08:00	29-Nov-23	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
245	1400	PLANNED	OCC_572	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	BUS PT Capacitance and tan D testing	29-Nov-23	09:00	29-Nov-23	18:00	All feeders and ICTs on Main Bus I will be shifted on Main Bus II through
246	1401	PLANNED	OCC_572	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Diagnostic Testing & Routine Maintenance	29-Nov-23	09:00	29-Nov-23	19:00	Diagnostic Testing & Routine Maintenance (ICT-1 UNIT)
247	1412	PLANNED	OCC_572	POWERGRID-WR1	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	30-Nov-2023	7:00	30-Nov-23	13:00	
248	1414	PLANNED	OCC_572	POWERGRID-WR1	KORADI - 400KV - BUS 2	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	30-Nov-2023	7:00	30-Nov-23	19:00	
249	1441	PLANNED	OCC_572	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA- 1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	30-Nov-23	08:00	30-Nov-23	17:00	Line will be charged through Main CB 429.
250	1442	PLANNED	OCC_572	MSLDC_OUTAGE	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	D	DT Work & Bay Maintenance	30-Nov-23	08:00	30-Nov-23	18:00	NIL
251	1443	PLANNED	OCC_572	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	30-Nov-23	08:00	30-Nov-23	18:00	--
252	1446	PLANNED	OCC_572	RGPPL	MAIN BAY OF 400KV-RGPPL-NEW KOYNA-1 AND RGPPPL - 400KV - BUS 1 @RGPPPL - 400KV at RGPPPL - 400KV	C	Attending SF6 leakages and gasket replacement	30-Nov-23	8:00	1-Dec-23	18:00	Line shutdown on continuous basis is required to accommodate the crane for safe working from New Koyna-1 Line Jumper.
253	1447	PLANNED	OCC_572	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1. replacement of hanger assembly of A Bus B Ph PG Isolator by hot line method of 400kV HVDC-2. 2.All feeders on A Bus will be in service.	30-Nov-23	09:00	3-Dec-23	18:30	1.Weather Condition should be clear. 2. Hot line team will be present in side.

State Element outage list for the month of NOV'2023

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	MAIN BAY - 401 CHD SWITCHING CKT1 @ CHANDRAPUR 2	01-Nov-23	10:00	01-Nov-23	17:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
2	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	01-Nov-23	09:00	30-Nov-23	18:00	Daily	PID testing work by Hot line Unit Parli. AR will be in Non Auto Mode. Line will be in service.	MSETCL	MSETCL	-
3	400 KV	WARORA - IEPL	02-Nov-23	09:00	02-Nov-23	17:00	Daily	Line CT, CVT Tan delta, IR values & Routine maintenance and and isolater maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
4	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	02-Nov-23	08:00	02-Nov-23	18:00	Daily	1. Relay testing work. 2. Routine bay maintenance work.	MSETCL	MSETCL	During outage, 400/220/33KV ICT-2, 220KV CHD-2 will be in service. The outage is subjected weather condition.
5	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	02-Nov-23	10:30	02-Nov-23	18:00	Daily	ICT-2 R-Ph Bay Maintenance and Annual Routine Testing works	MSETCL	MSETCL	ICT-2 R-Ph Bay Maintenance and Annual Routine Testing works
6	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	02-Nov-23	08:00	02-Nov-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	NIL
7	400 KV	KHADKA- DEEPNAGAR CKT 1	02-Nov-23	08:00	03-Nov-23	18:00	Continuous	Main -2 distance relay retrofitting work under MTAMC Project.	MSETCL	MSETCL	For replacement of Main - 2 relay will requires 02 days - removal of existing relay connection, providing of new relay ,
8	400 KV	Tie Bay (417) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	02-Nov-23	10:00	02-Nov-23	17:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
9	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	02-Nov-23	08:00	02-Nov-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal, and Dhule I &II will be in service
10	400 KV	JEJURI- KOYNA STAGE-IV	02-Nov-23	08:00	02-Nov-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	Planned outage
11	400 KV	GTR - 3 @ CHANDRAPUR SS	02-Nov-23	08:00	02-Nov-23	12:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
12	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	02-Nov-23	08:00	02-Nov-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
13	400 KV	400KV NANDED(KUMBHARGAON)- PARLY CKT 2	02-Nov-23	09:00	02-Nov-23	18:00	Daily	(1) Main-2 distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work	MSETCL	MSETCL	-
14	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	02-Nov-23	08:00	02-Nov-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
15	400 KV	GTR - 4 @ CHANDRAPUR	02-Nov-23	15:00	02-Nov-23	18:00	Daily	For PID testing work on Disc Insulator String	MSETCL	MSETCL	Online PID work will be carried out.
16	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	03-Nov-23	09:00	03-Nov-23	17:00	Daily	1) Routine Maintenance and Diagnostic testing work at Ss. 2) Line Maintenance Work.	MSETCL	MSETCL	NIL
17	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	03-Nov-23	08:00	03-Nov-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal, and Dhule I &II will be in service
18	400 KV	GTR - 5 @ CHANDRAPUR	03-Nov-23	08:00	03-Nov-23	12:00	Daily	For PID testing work on Disc Insulator String	MSETCL	MSETCL	Online PID work will be carried out.
19	400 KV	STATION TF No 3 @ CHANDRAPUR GCR	03-Nov-23	15:00	03-Nov-23	18:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
20	400 KV	KHADKA-AURANGABAD (WALUJ)	04-Nov-23	08:00	05-Nov-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I&II will be in service
21	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	04-Nov-23	08:00	04-Nov-23	18:00	Daily	1. Relay testing work. 2. Bay routine maintenance work.	MSETCL	MSETCL	During outage, 400/220/33KV ICT-2, 220KV CHD-2 will be in service.
22	400 KV	Main Bay (418) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	04-Nov-23	10:00	04-Nov-23	17:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
23	400 KV	GTR - 6 @ CHANDRAPUR	04-Nov-23	08:00	04-Nov-23	12:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
24	400 KV	STATION TF No 4 @ CHANDRAPUR GCR	04-Nov-23	15:00	04-Nov-23	18:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
25	400 KV	NEW KOYNA - STAGE IV CKT - 1	06-Nov-23	08:00	06-Nov-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	Planned Outage
26	400 KV	TIE BAY (402) of WALUJ @ TAPITTANDA	06-Nov-23	11:00	09-Nov-23	18:00	Continuous	CB mechanism Overhauling by M/s CGL service Engineer	MSETCL	MSETCL	Continuous outage required for CB mechanism overhauling work
27	400 KV	KHADKA- DEEPNAGAR CKT 2	06-Nov-23	08:00	07-Nov-23	18:00	Continuous	Main - 2 distance relay retrofitting work under MTAMC Project.	MSETCL	MSETCL	For replacement of Main - 2 relay will requires 02 days - removal of existing relay connection, providing of new relay , retrofitting work and final new relay testing work etc.
28	400 KV	PADGHE - NAGOTHANE CKT - 1	06-Nov-23	08:00	06-Nov-23	17:00	Daily	String replacement work & jumper tightning work	MSETCL	MSETCL	NA
29	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	06-Nov-23	09:00	06-Nov-23	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition , respective ckt charged through its own main CB.
30	400 KV	KARAD - TALANDGE CKT - 1	06-Nov-23	09:00	06-Nov-23	23:59	Daily	Protection coupler work	MSETCL	MSETCL	Monday is load staggering day in Kolhapur
31	400 KV	GTR - 7 @ CHANDRAPUR	06-Nov-23	08:00	06-Nov-23	12:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
32	400 KV	STATION TF No 5 @ CHANDRAPUR GCR	06-Nov-23	15:00	06-Nov-23	18:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
33	400 KV	BUS REACTOR (80 MVAr) - 1 @ BABHALESHWAR	07-Nov-23	10:00	07-Nov-23	15:00	Daily	CB DCRM/Timing	MSETCL	MSETCL	Reactor is out of service during day hours
34	400 KV	PADGHE - NAGOTHANE CKT - 2	07-Nov-23	08:00	07-Nov-23	17:00	Daily	String replacement work & jumper tightning work	MSETCL	MSETCL	NA
35	400 KV	KARAD - TALANDGE CKT - 2	07-Nov-23	09:00	07-Nov-23	23:59	Daily	1.Protection coupler work 2.C and Tan-Delta testing of CT	MSETCL	MSETCL	Tuesday is load staggering day in Karad
36	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END)	07-Nov-23	08:00	07-Nov-23	12:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
37	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	07-Nov-23	15:00	07-Nov-23	18:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
38	400 KV	CHANDRAPUR-PARLI CKT-3	08-Nov-23	09:00	08-Nov-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
39	400 KV	MAIN BAY (433) OF 500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	08-Nov-23	10:00	08-Nov-23	17:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
40	400 KV	CHANDRAPUR - KHAPERKHEDA	08-Nov-23	15:00	08-Nov-23	18:00	Daily	1.PID testing work on Disc insulator of stub bus in 400KV Khaperkheda bay 2. AR switch will be in Non Auto mode.	MSETCL	MSETCL	Online PID work will be carried out.
41	400 KV	CHANDRAPUR-PARLI CKT-3	08-Nov-23	08:00	08-Nov-23	12:00	Daily	For PID testing work on Disc Insulator String.	MSETCL	MSETCL	Online PID work will be carried out.
42	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	09-Nov-23	08:00	09-Nov-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	NIL
43	400 KV	TIE BAY - 411 OF PARLI (GIRWALI) CKT- 1 @ NANDED	09-Nov-23	10:30	09-Nov-23	18:00	Daily	TIE CT Tan-d Test	MSETCL	MSETCL	TIE CT Tan-d Test
44	400 KV	LONIKAND 1 - KOYNA STAGE-IV	09-Nov-23	08:00	09-Nov-23	17:00	Daily	Restinging of Conductor between Loc No 90-93 Due to low sag clearance	MSETCL	MSETCL	Restinging of Conductor between Loc No 90-93 Due to low sag clearance
45	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	11-Nov-23	09:00	11-Nov-23	18:00	Daily	Differential relay,LV CB DCRM/timing,DFRA,Excitation current;Quarterly bay maintenance work	MSETCL	MSETCL	315 MVA ICT I;501 MVA ICT III and IV will be in service
46	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	14-Nov-23	09:00	14-Nov-23	18:00	Daily	1) String replacement work at location No 843 (2) Bay maintenance work.	MSETCL	MSETCL	-
47	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	15-Nov-23	09:00	15-Nov-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
48	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	15-Nov-23	10:00	15-Nov-23	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
49	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	16-Nov-23	09:30	16-Nov-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-3 will continue to remain in service
50	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	17-Nov-23	10:00	17-Nov-23	18:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
51	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	17-Nov-23	09:00	17-Nov-23	17:00	Daily	1) Routine Maintenance work and Diagnostic Testing Work. 2) Line Maintenance work	MSETCL	MSETCL	NIL
52	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	18-Nov-23	09:00	18-Nov-23	18:00	Daily	LV CB DCRM/timing and Quarterly bay maintenance work	MSETCL	MSETCL	315 MVA ICT I;501 MVA ICT III and IV will be in service
53	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	18-Nov-23	08:00	18-Nov-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
54	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	19-Nov-23	08:00	19-Nov-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
55	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	20-Nov-23	09:00	20-Nov-23	23:59	Daily	1. C & tan delta testing of winding & bushing. 2. Diagnostic testing of HV & IV bays. 3.QM of HV & IV bays	MSETCL	MSETCL	1. Load will be managed on 501 MVA ICT 1 & 3
56	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	20-Nov-23	08:00	22-Nov-23	18:00	Daily	1. Testing of CVT 2. Nutbolt tightening of LA, CT, CB 3. Bay routine maintenance work	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV Khaperkheda, 400KV PARLI CKT-3, 400KV CHANDRAPUR-PGCIL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service.
57	400 KV	FUTURE CKT - 1 @ WARORA	21-Nov-23	09:00	21-Nov-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
58	400 KV	105 MVA SPARE ICT @ AKOLA	21-Nov-23	09:00	21-Nov-23	18:00	Daily	DCRM, Tandelta for CT & routine maintenance work	MSETCL	MSETCL	N.A.
59	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	22-Nov-23	09:00	22-Nov-23	18:00	Daily	(1) REF & NDR relays testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
60	400 KV	400 KV FUTURE BAY II @ WARORA	22-Nov-23	09:00	22-Nov-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
61	400 KV	WARORA - IEPL	22-Nov-23	09:00	22-Nov-23	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL. Line is in ckt
62	400 KV	CHANDRAPUR-PARLI CKT-3	22-Nov-23	09:00	22-Nov-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
63	400 KV	400/220kV SPARE ICT @ JEJURI	23-Nov-23	09:30	23-Nov-23	18:00	Daily	For WRM kit demo	MSETCL	MSETCL	Only charged from HV side
64	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	23-Nov-23	10:00	24-Nov-23	21:00	Continuous	For Overhauling of SERGI NIFPS Fire system for ICT No.2, Repairing and Overhauling of 89B PG isolators, Routine Maintenance and DT.	MSETCL	MSETCL	NIL
65	400 KV	JEJURI- KOYNA STAGE-IV	23-Nov-23	08:00	24-Nov-23	17:00	Continuou	Restinging of Conductor between Loc No 90-93 Due to low sag clearance	MSETCL	MSETCL	Restinging of Conductor between Loc No 90-93 Due to low sag clearance
66	400 KV	LONIKAND 1 - KOYNA STAGE-IV	23-Nov-23	08:00	23-Nov-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	
67	400 KV	LONIKAND 1 - KOYNA STAGE-IV	23-Nov-23	08:00	23-Nov-23	18:00	Daily	PID faulty insulator strings replacement and Cold washing of Insulator Strings	MSETCL	MSETCL	NIL
68	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	23-Nov-23	09:00	23-Nov-23	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Monday is load staggering day Load will be managed from ICT 1 & 2
69	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	23-Nov-23	08:00	23-Nov-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	NIL
70	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	23-Nov-23	10:30	23-Nov-23	18:00	Daily	Routine Relay Testing, CT Tan-d and Bay Maintenance Works	MSETCL	MSETCL	Routine Relay Testing, CT Tan-d and Bay Maintenance Works
71	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	23-Nov-23	06:00	24-Nov-23	18:00	Continuous	for the work of replacement of existing 0.5 ACSR conductor to HTLS Conductor on 400KV Chandrapur GCR- Chand-2-ckt-2	MSETCL	MSETCL	This line is under crossing at Loc. No. LIL0-1-LILO2 of 400KV Chandrapur GCR - Chand2- ckt-2. Hence for safety point of need Non -Auto Mode is required.
72	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	24-Nov-23	10:00	24-Nov-23	18:00	Daily	Routine Maintenance and Diagnostic Testing Work.	MSETCL	MSETCL	NIL
73	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	25-Nov-23	08:00	26-Nov-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, and Dhule I &II will be in service
74	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	27-Nov-23	09:00	27-Nov-23	23:00	Daily	1.C & Tan delta Testing of winding & bushing 2.Quarterly maintenance work	MSETCL	MSETCL	1.Load will be managed from ICT - 1 & 3 2. Monday is load staggering day in Kolhapur

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
75	400 KV	WARORA - JEPL	27-Nov-23	09:00	27-Nov-23	17:00	Daily	Routine maintenance and diagnostic testing such as CVT/ CT tan delta, and ,isolater maintenance work	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt .
76	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	29-Nov-23	09:00	29-Nov-23	18:00	Daily	1) REF relay & CT testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
77	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	29-Nov-23	09:00	29-Nov-23	18:00	Daily	line maintenance work & spacer replacement	MSETCL	MSETCL	-
78	400 KV	400KV TIE BAY 432 OF 500MVA 400/220KV ICT 1 @ CHANDRAPUR 2	29-Nov-23	10:00	29-Nov-23	15:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
79	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	30-Nov-23	09:30	30-Nov-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-2 & ICT-3 will continue to remain in service
80	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	30-Nov-23	08:00	30-Nov-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
81	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	30-Nov-23	10:00	30-Nov-23	18:00	Daily	Repairing and Overhauling of 89B PG isolators, routine Maintenance and DT.	MSETCL	MSETCL	NIL
82	400 KV	400KV TIE BAY 435 OF 500MVA 400/220KV ICT 2 @ CHANDRAPUR 2	30-Nov-23	10:00	30-Nov-23	16:00	Daily	Diagnostic testing and allied bay maintenance	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance
83	400 KV	NEW KOYNA - STAGE IV CKT - 2	30-Nov-23	08:00	30-Nov-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	
84	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	30-Nov-23	08:00	30-Nov-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	NIL
85	400 KV	LONIKAND I - KOYNA STAGE-IV	30-Nov-23	08:00	30-Nov-23	17:00	Daily	Restinging of Conductor between Loc No 90-93 Due to low sag clearance	MSETCL	MSETCL	Restinging of Conductor between Loc No 90-93 Due to low sag clearance
86	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	30-Nov-23	10:30	30-Nov-23	18:00	Daily	ICT-1 Y-Ph Bay Maintenance and Annual Routine Testing works	MSETCL	MSETCL	ICT-1 Y-Ph Bay Maintenance and Annual Routine Testing works