

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of NOVEMBER '2024

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
1	1	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-Nov-2024	07:00	30-Nov-2024	18:00	
2	2	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-Nov-2024	07:00	30-Nov-2024	18:00	
3	3	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	96F OPGW installation on 400KV Lonikand-Chakan Transmission Line by replacing existing Earth wire in live line condition	01-Nov-2024	08:00	14-Nov-2024	19:00	-
4	4	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	C	Shifting of line bay on TBC for replacement of 400 kV line circuit breaker due aging & frequent troubles in operation.1) Line will be shifted on TBC at Parli End. 2) Line will be in service through TBC bay . Till the CB replacement work completion. 3) All other line & ICT bays will remain in service	01-Nov-2024	09:00	11-Nov-2024	20:00	
5	9	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work AR in Non-auto mode	01-Nov-2024	09:00	15-Nov-2024	18:00	-
6	13	PLANNED	OCC_584	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	01-Nov-2024	08:00	10-Nov-2024	18:00	AR disable
7	14	PLANNED	OCC_584	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	01-Nov-2024	08:00	10-Nov-2024	18:00	AR disable
8	28	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work.AR in Non-auto mode	01-Nov-2024	09:00	30-Nov-2024	17:30	-
9	29	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work.AR in Non-auto mode	01-Nov-2024	09:00	30-Nov-2024	17:30	-
10	36	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-Nov-2024	07:00	30-Nov-2023	18:00	On the same peak of 400KV-KHANDWA-DHULE-MS-2

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
11	37	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-Nov-2024	07:00	30-Nov-2023	18:00	OPGW Erection on 400KV-KHANDWA-DHULE-MS-2
12	51	PLANNED	OCC_584	RGPPL	TIE BAY OF 400KV-RGPPL-NEW KOYNA-1 AND 400KV/15KV RGPPL-GT-1A @RGPPL - 400KV at RGPPL - 400KV	C	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND BAY MAINTENANCE	01-Nov-2024	08:00	03-Nov-2024	20:00	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND BAY MAINTENANCE
13	52	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV/15.7KV RGPPL-GT-1A AND RGPPL - 400KV - BUS 2 @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	01-Nov-2024	08:00	03-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
14	53	PLANNED	OCC_584	RGPPL	400KV/11.9KV RGPPL-ST-2	D	Deluge Test for SST- 2	01-Nov-2024	08:00	01-Nov-2024	20:00	SST-1 WILL BE IN SERVICE
15	57	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-4 AND BHADRAWATI - 400KV - BUS 2 AT BHADRAWATI - 400KV at BHADRAWATI - 400KV	D	AMP works	02-Nov-2024	09:00	02-Nov-2024	18:00	AMP works-416 bay
16	62	PLANNED	OCC_584	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	D	Insulator Replacement Work, A/R OF 400 KV AURANGABAD-BOISAR-1 IN NON AUTO MODE, Dia to be kept open at both ends.	02-Nov-2024	07:00	02-Nov-2024	18:00	PG-WR2-BOISAR
17	69	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Repair Sleeves for Conductor damaged at Loc No. 158-159 Top Ph.	03-Nov-2024	09:00	03-Nov-2024	17:00	Simultaneous outage is required on 220kV PGCIL - Borivali Line (for safety purpose)
18	70	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	outage is required on 220kV PGCIL - Borivali Line (for safety purpose) for attending Conductor damage at Loc No. 158-159 Top Ph of 220kV Tarapur - Borivali Line by repair sleeve.	03-Nov-2024	09:00	03-Nov-2024	17:00	outage is required on 220kV PGCIL - Borivali Line (for safety purpose) for attending Conductor damage at Loc No. 158-159 Top Ph of 220kV Tarapur - Borivali Line by repair sleeve.
19	81	PLANNED	OCC_584	MEGPTCL	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV at KORADI-I	D	Bay Outage	04-Nov-2024	09:00	04-Nov-2024	18:00	Bay Outage
20	88	PLANNED	OCC_584	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	04-Nov-2024	10:00	04-Nov-2024	13:00	--
21	89	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Diagnostic testing & Maintenance work	04-Nov-2024	10:00	04-Nov-2024	17:00	Load will be managed on 400KV Alkud Kolhapur line

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
22	90	PLANNED	OCC_584	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	04-Nov-2024	14:00	04-Nov-2024	17:00	--
23	131	PLANNED	OCC_584	RGPPL	TIE BAY OF 400KV-RGPPL-NEW KOYNA-2 AND FUTURE @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	04-Nov-2024	08:00	06-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
24	132	PLANNED	OCC_584	RGPPL	400KV-RGPPL-NEW KOYNA-2	C	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND EXHIBITING OIL SWEATING	04-Nov-2024	08:00	05-Nov-2024	20:00	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND EXHIBITING OIL SWEATING
25	133	PLANNED	OCC_584	RGPPL	400KV/11.9KV RGPPL-ST-1	D	Relay Testing of SST- 1	04-Nov-2024	08:00	05-Nov-2024	20:00	SST-2 WILL BE IN SERVICE
26	152	PLANNED	OCC_584	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For AMP of terminal equipments	05-Nov-2024	08:00	05-Nov-2024	18:00	401AL
27	154	PLANNED	OCC_584	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-1	D	Line and Bay AMP	05-Nov-2024	08:00	05-Nov-2024	18:00	Line and Bay AMP
28	155	PLANNED	OCC_584	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-2	D	AR in Non-Auto	05-Nov-2024	08:00	05-Nov-2024	18:00	AR in Non-Auto
29	158	PLANNED	OCC_584	POWERGRID_WR1	PARLI NEW - 400KV - BUS 1	D	AMP OF BUS & ISOLATOR ALIGNMENT WORK	05-Nov-2024	08:00	05-Nov-2024	00:00	AMP OF BUS & ISOLATOR ALIGNMENT WORK
30	160	PLANNED	OCC_584	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-1	D	Fine tuning of CSD of ICT	05-Nov-2024	09:00	05-Nov-2024	15:00	Repeated closing/opening of ICT on NO Load will be done
31	161	PLANNED	OCC_584	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	D	Winding Tan Delta, FDS, Moisture measurement of LR of 400KV-PADGHE-BOISAR-1.	05-Nov-2024	09:00	05-Nov-2024	17:00	
32	163	PLANNED	OCC_584	POWERGRID_WR1	TIE BAY - 400KV-PUNE-GIS-PUNE-PG-2 AND 400KV-PUNE-GIS-PUNE-PG-3 at PUNE-PG - 400KV	D	For AMP Work	05-Nov-2024	09:00	05-Nov-2024	17:30	
33	185	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV-RGPPL-NEW KOYNA-2 AND RGPPL - 400KV - BUS 1 @RGPPL - 400KV at RGPPL - 400KV	D	BAY MAINTENANCE AND TESTING	05-Nov-2024	08:00	07-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
34	187	PLANNED	OCC_584	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Kolhapur-MS-Solapur Line-2	05-Nov-2024	08:00	05-Nov-2024	18:00	AR disable

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
35	188	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for annual maintenance in 400KV Kolhapur-MS-Solapur Line-2	05-Nov-2024	08:00	05-Nov-2024	18:00	AR disable
36	189	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Annual Maintenance	05-Nov-2024	08:00	05-Nov-2024	18:00	Outage
37	205	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Bay Outage	06-Nov-2024	09:00	06-Nov-2024	18:00	Bay Outage
38	209	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	06-Nov-2024	09:00	06-Nov-2024	17:30	-
39	210	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Diagnostic testing and allied bay maintenance work	06-Nov-2024	10:00	06-Nov-2024	17:00	Diagnostic testing and allied bay maintenance work
40	211	PLANNED	OCC_584	MSLDC_OUTAGE	JEUR - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	06-Nov-2024	10:00	06-Nov-2024	17:00	Breaker of PGCIL line at Jeur End will be made off
41	212	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Quarterly Maintenance	06-Nov-2024	10:00	06-Nov-2024	17:00	Breaker of PGCIL line at Jeur End will be made off
42	252	PLANNED	OCC_584	RGPPL	400KV-RGPPL-NEW KOYNA-2	D	REPLACEMENT OF LA MORE THAN 20 YRS OLD	06-Nov-2024	08:00	07-Nov-2024	20:00	REPLACEMENT OF LA MORE THAN 20 YRS OLD
43	254	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Annual Maintenance	06-Nov-2024	08:00	06-Nov-2024	18:00	Outage
44	255	PLANNED	OCC_584	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Kolhapur-MS-Solapur Line-2	06-Nov-2024	08:00	06-Nov-2024	18:00	AR disable
45	256	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for annual maintenance in 400KV Kolhapur-MS-Solapur Line-2	06-Nov-2024	08:00	06-Nov-2024	18:00	AR disable
46	257	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	Cold Washing of Insulator strings	07-Nov-2024	16:00	08-Nov-2024	22:00	-
47	268	PLANNED	OCC_584	MEGPTCL	AKOLA (2) - 765KV - BUS 1	D	Bus Outage	07-Nov-2024	09:00	07-Nov-2024	18:00	Bus Outage
48	272	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	07-Nov-2024	07:00	14-Nov-2024	18:00	---

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
49	273	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	@Lonikand-I : DT and Line Maintenance activities @ Jejuri : Diagnostic testing and Half Yearly Maintenance	07-Nov-2024	22:00	08-Nov-2024	06:00	-
50	274	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	07-Nov-2024	08:00	07-Nov-2024	18:00	Outage
51	275	PLANNED	OCC_584	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	07-Nov-2024	16:00	07-Nov-2024	22:00	-
52	276	PLANNED	OCC_584	MSLDC_OUTAGE	TIE BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Half Yearly Maintenance	07-Nov-2024	16:00	07-Nov-2024	22:00	-
53	277	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware tightening and cold line washing	07-Nov-2024	16:00	07-Nov-2024	22:00	Load managed on 400kv parli-Karjat ckt-1
54	290	PLANNED	OCC_584	POWERGRID_WR1	PARLI NEW - 400KV - BUS 2	D	AMP OF BUS & ISOLATOR ALIGNMENT WORK	07-Nov-2024	08:00	07-Nov-2024	18:00	AMP OF BUS & ISOLATOR ALIGNMENT WORK
55	294	PLANNED	OCC_584	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-3	D	Fine tuning of CSD of ICT	07-Nov-2024	09:00	07-Nov-2024	15:00	Repeated closing/opening of ICT on NO Load will be done
56	296	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 220KV-PUNE-PG-ICT-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	For AMP Work	07-Nov-2024	09:00	07-Nov-2024	17:30	ICT BAY
57	323	PLANNED	OCC_584	WTPL	400KV-ALKUD-SOLAPUR-1	D	Annual Maintenance	07-Nov-2024	08:00	07-Nov-2024	18:00	Outage
58	324	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Alkud-MS- Solapur -1	07-Nov-2024	08:00	07-Nov-2024	18:00	AR disable
59	333	PLANNED	OCC_584	MEGPTCL	TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV	D	Bay Outage	08-Nov-2024	09:00	08-Nov-2024	18:00	Bay Outage
60	334	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Bay Outage	08-Nov-2024	09:00	08-Nov-2024	18:00	Bay Outage
61	338	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Line Bay shifting at 220KV Boisar-II S/S. (From Bay No. 12 to Bay No. 14)	08-Nov-2024	06:00	08-Nov-2024	19:00	1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
62	339	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work & CT tan delta measurement work.	08-Nov-2024	08:00	08-Nov-2024	18:00	400KV Padghe II will be in in service
63	340	PLANNED	OCC_584	MSLDC_OUTAGE	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2 at PARLI-M - 400KV	D	1) CB testing work. (2) Bay maintenance work.	08-Nov-2024	09:00	08-Nov-2024	18:00	-
64	341	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	1) Reactor Backup relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	08-Nov-2024	16:00	08-Nov-2024	22:00	-
65	343	PLANNED	OCC_584	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV	C	For AMP of Bay and Overhauling of CB.	08-Nov-2024	08:00	12-Nov-2024	20:00	Work @ Wardha SS
66	344	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	D	For AMP	08-Nov-2024	08:00	08-Nov-2024	18:00	403
67	348	PLANNED	OCC_584	POWERGRID_WR1	PARLI NEW - 765KV - BUS 2	D	AMP OF BUS & ISOLATOR ALIGNMENT WORK	08-Nov-2024	08:00	08-Nov-2024	18:00	AMP OF BUS & ISOLATOR ALIGNMENT WORK
68	353	PLANNED	OCC_584	POWERGRID_WR1	400KV-WARORA-PG-WARORA (MSETCL)-1	D	For 400KV Warora (MSETCL) #1 Line Equipments AMP Work	08-Nov-2024	09:00	08-Nov-2024	16:00	400KV-WARDHA-WARORA -PG-1 AR OFF
69	354	PLANNED	OCC_584	POWERGRID_WR1	PUNE-PG - 220KV - BUS#1	D	For AMP Work	08-Nov-2024	09:00	08-Nov-2024	17:30	Each bay will be taken on TBC bay
70	376	PLANNED	OCC_584	RGPPL	400KV-RGPPL-NAGOTHANE-1	D	REPLACEMENT OF LA MORE THAN 20 YRS OLD	08-Nov-2024	08:00	10-Nov-2024	20:00	REPLACEMENT OF LA MORE THAN 20 YRS OLD
71	377	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV-RGPPL-NAGOTHANE-1 AND RGPPL - 400KV - BUS 1 @RGPPL - 400KV at RGPPL - 400KV	D	BAY MAINTENANCE AND TESTING	08-Nov-2024	08:00	10-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
72	379	PLANNED	OCC_584	WTPL	400KV-ALKUD-SOLAPUR-1	D	Annual Maintenance	08-Nov-2024	08:00	08-Nov-2024	18:00	Outage
73	380	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Alkud-MS- Solapur Line-1	08-Nov-2024	08:00	08-Nov-2024	18:00	AR disable

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
74	381	PLANNED	OCC_584	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	HVDC POLE-1 annual outage work such as O-ring replacement,AC/DC yard maintenace, valve hall, valve cooling system, smoothing reactor, converter transformer, 33kv GIS, Dry type transformer, filter areas, 400KV C.B & isolator maintenace work, testing of	09-Nov-2024	08:00	16-Nov-2024	20:00	HVDC chandrapur had been informed
75	382	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR- CHANDRAPUR HVDC-1	C	HVDC POLE-1 annual outage work such as O-ring replacement,AC/DC yard maintenace, valve hall, valve cooling system, smoothing reactor, converter transformer, 33kv GIS, Dry type transformer, filter areas, 400KV C.B & isolator maintenace work, testing of	09-Nov-2024	09:00	16-Nov-2024	19:00	Along with HVDC pole-1
76	393	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12)	09-Nov-2024	06:00	10-Nov-2024	17:00	1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to
77	394	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	C	Diagnostic Testing	09-Nov-2024	23:00	10-Nov-2024	07:00	-
78	395	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work & CT tan delta measurement & M1 dist. Relay testing work.	09-Nov-2024	08:00	09-Nov-2024	18:00	400kV Padghe I will be in in service
79	403	PLANNED	OCC_584	POWERGRID_WR1	220KV SOLAPUR-BALE-1	D	Line terminal equipments AMP at 765kV Solapur Substation	09-Nov-2024	08:00	09-Nov-2024	18:00	Temporary Diverted to Dharashiv SS
80	407	PLANNED	OCC_584	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-2	D	For AMP Work	09-Nov-2024	09:00	09-Nov-2024	17:30	XMER
81	431	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	Annual Maintenance	09-Nov-2024	08:00	09-Nov-2024	18:00	Outage
82	432	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Kohlapur- MS- Alkud Line -1	09-Nov-2024	08:00	09-Nov-2024	18:00	AR disable

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
83	433	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-CHANDRAPUR-KHAPARKHEDA-1	C	Monopole tower erection work between tower No.34 &35	10-Nov-2024	09:00	19-Nov-2024	22:00	Day1- Monopole erection work PB1. Day2 &3- Monopole erection work PD1. Day3&4- Monopole erection work PD2.(Towerof B & D type respectively) Day5:- Dismantling of existing tower 34 & 35 Day6- stringing of conductor hardwares on tower PB1, PD1 & PD2 . Day7 &8- stringing between existing tower no 33D & PB1. Day8&9- Stringing between tower No. PD1 & PD2 & PD2 to existing tower No 35. Day10:- Remaining balance work. This ht raising work is being carried out for propose (Undergoing) work for Nagpur Metro railway-crossing
84	434	PLANNED	OCC_584	ATIL	400KV-TIRODA-WARORA-1	D	AR IN NON AUTO. Line will be in service.	10-Nov-2024	08:00	30-Nov-2024	18:00	AR IN NON AUTO
85	437	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	For Line Maintenance Work.	10-Nov-2024	09:00	10-Nov-2024	17:00	For Line Maintenance Work.
86	450	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Alkud-MS- Kolhapur-1	10-Nov-2024	08:00	10-Nov-2024	08:00	AR disable
87	451	PLANNED	OCC_584	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	Annual Maintenance	10-Nov-2024	08:00	10-Nov-2024	18:00	Outage
88	452	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-1	D	FOR PID WORK (JAIGAD NEWKOYNA CKT 1 AR OUT)	11-Nov-2024	09:00	30-Nov-2024	18:00	FOR PID WORK (JAIGAD NEWKOYNA CKT 1 AR OUT)
89	453	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	FOR PID WORK (JAIGAD-NEWKOYNA CKT 2 AR OUT)	11-Nov-2024	09:00	30-Nov-2024	18:00	FOR PID WORK (JAIGAD-NEWKOYNA CKT 2 AR OUT)
90	454	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode of 400KV Kalwa - Talegoan line & 400kV Kalwa-Kharghar D/C line (both line)	11-Nov-2024	09:00	30-Nov-2024	18:00	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode of 400KV Kalwa - Talegoan line & 400kV Kalwa-Kharghar D/C line (both line)

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
91	469	PLANNED	OCC_584	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Bay Outage	11-Nov-2024	09:00	11-Nov-2024	18:00	Bay Outage
92	470	PLANNED	OCC_584	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND FUTURE at KORADI-III - 400KV	D	Bay Outage	11-Nov-2024	09:00	11-Nov-2024	18:00	Bay Outage
93	476	PLANNED	OCC_584	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	11-Nov-2024	08:00	23-Nov-2024	18:00	For PID work
94	477	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	online PID work.AR kept on non auto mode.	11-Nov-2024	08:00	20-Nov-2024	18:00	Only auto reclose will be out line will be in service
95	478	PLANNED	OCC_584	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	11-Nov-2024	10:00	11-Nov-2024	13:00	--
96	479	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic testing & Maintenance work	11-Nov-2024	10:00	11-Nov-2024	17:00	Load will be managed on 400KV
97	480	PLANNED	OCC_584	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Diagnostic testing & Maintenance work	11-Nov-2024	14:00	11-Nov-2024	17:00	--
98	493	PLANNED	OCC_584	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	C	Main Bay AMP and CB Overhauling work	11-Nov-2024	08:00	13-Nov-2024	18:00	Outage required on CB only. Bus reactor can be kept in service through TBC.
99	495	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY OF 400KV-PADGHE-PG-KHARGHAR-1 AND PADGHE-PG - 400KV - BUS 1 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	C	Breaker Close/open & spring Charge/Discharge Indication replacement	11-Nov-2024	09:00	13-Nov-2024	17:00	
100	501	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	For AMP of terminal equipments. AND CKT 1 AR IN NON AUTO MODE IS REQUIRED	11-Nov-2024	08:00	11-Nov-2024	18:00	PGHL
101	502	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2 L/R@ DHULE-MS - 400KV	D	For AMP	11-Nov-2024	08:00	11-Nov-2024	18:00	PGHR
102	513	PLANNED	OCC_584	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-1	D	Spare Changover of ICT, Taking Rph OUT of service & Spare IN Service	11-Nov-2024	10:00	11-Nov-2024	15:00	
103	541	PLANNED	OCC_584	RGPPL	400KV-RGPPL-NEW KOYNA-1	C	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND EXHIBITING OIL SWEATING	11-Nov-2024	08:00	14-Nov-2024	20:00	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND EXHIBITING OIL SWEATING

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
104	542	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV-RGPPL-NEW KOYNA-1 AND RGPPL - 400KV - BUS 1 @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	11-Nov-2024	08:00	13-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
105	543	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV/15.7KV RGPPL-GT-2B AND RGPPL - 400KV - BUS 2 @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	11-Nov-2024	08:00	13-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
106	577	PLANNED	OCC_584	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-I by Hot Line Method	12-Nov-2024	09:00	12-Nov-2024	17:00	Work will be done online through Hotline method
107	592	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-KARAD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Bay AMP Works	12-Nov-2024	08:00	12-Nov-2024	18:00	
108	594	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	D	AMP of Bay Equipment	12-Nov-2024	09:00	12-Nov-2024	17:00	
109	652	PLANNED	OCC_584	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Bay Outage	13-Nov-2024	09:00	13-Nov-2024	18:00	Bay Outage
110	653	PLANNED	OCC_584	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-EKTUNI-1 AND AKOLA (2) - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Bay Outage	13-Nov-2024	09:00	13-Nov-2024	18:00	Bay Outage
111	658	PLANNED	OCC_584	MSLDC_OUTAGE	400KV/220KV KHAPARKHEDA-ICT-1	C	Transformer Oil Filtration & Painting Work of R Y & B Ph Unit	13-Nov-2024	08:00	16-Nov-2024	18:00	NA
112	659	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	For Diagnostic Testing Work CT Tan Delta , CRM & Timing of CB and Routine maintainance work	13-Nov-2024	08:00	13-Nov-2024	18:00	Outage
113	660	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening and cold line washing	13-Nov-2024	09:00	13-Nov-2024	17:00	Load managed on 400kv lamboti-Parli
114	661	PLANNED	OCC_584	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Tightening of Hanger rod of assembly on 400 kV Main Bus-II by Hot Line Method	13-Nov-2024	09:00	13-Nov-2024	17:00	Work will be done online through Hotline method
115	662	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	13-Nov-2024	09:00	13-Nov-2024	17:30	-
116	663	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHVAR-1	D	For routine maintenance work	13-Nov-2024	09:00	13-Nov-2024	18:00	NA

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
117	664	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	13-Nov-2024	09:00	13-Nov-2024	18:00	The said work is very important
118	665	PLANNED	OCC_584	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	13-Nov-2024	09:00	13-Nov-2024	18:00	NA
119	666	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	Diagnostic testing and allied bay maintenance work	13-Nov-2024	10:00	13-Nov-2024	15:00	Diagnostic testing and allied bay maintenance work
120	676	PLANNED	OCC_584	POWERGRID_WR1	DHULE-MS - 400KV B/R 2	C	For old CT replacement work	13-Nov-2024	08:00	14-Nov-2024	18:00	PGGR
121	681	PLANNED	OCC_584	POWERGRID_WR1	220KV-WARDHA-YAVATMAL-1	D	For Amp of Line Bay	13-Nov-2024	08:00	13-Nov-2024	20:00	Work @ Wardha SS
122	682	PLANNED	OCC_584	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	WTI replacement in Yph LR of 765KV Pune-Padghe Line at Padghe SS	13-Nov-2024	09:00	13-Nov-2024	17:00	
123	683	PLANNED	OCC_584	POWERGRID_WR1	220 KV TALEGAON-PUNE-PG-1	D	For AMP Work	13-Nov-2024	09:00	13-Nov-2024	17:30	
124	730	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	Routine bay and line Maintenance and DT	14-Nov-2024	22:00	15-Nov-2024	06:00	-
125	731	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	14-Nov-2024	08:00	14-Nov-2024	18:00	Outage
126	740	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-2 AND PARLI - 400KV - BUS 2 AT PARLI - 400KV at PARLI - 400KV	D	Bay AMP	14-Nov-2024	08:00	14-Nov-2024	18:00	Bay AMP
127	741	PLANNED	OCC_584	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2 at KOLHAPUR-MS - 400KV	D	80MVAR Reactor AMP Works	14-Nov-2024	08:00	14-Nov-2024	18:00	80 MVAr Bus reactor AMP , LBB Retrofitting and Relay testing works
128	744	PLANNED	OCC_584	POWERGRID_WR1	220KV-WARDHA-YAVATMAL-2	D	For Amp of Line Bay	14-Nov-2024	08:00	14-Nov-2024	20:00	Work @ Wardha SS
129	745	PLANNED	OCC_584	POWERGRID_WR1	TIE BAY - 400KV-PADGHE-PG-KUDUS-1 AND 765KV/400KV PADGHE-PG-ICT-1 AT PADGHE-PG - 400KV at PADGHE-PG - 400KV	D	AMP of Bay Equipment	14-Nov-2024	09:00	14-Nov-2024	17:00	
130	746	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	14-Nov-2024	09:00	14-Nov-2024	17:30	

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
131	782	PLANNED	OCC_584	RGPPL	TIE BAY OF 400KV-RGPPL-NEW KOYNA-2 AND FUTURE @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	14-Nov-2024	08:00	16-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
132	806	PLANNED	OCC_584	MEGPTCL	TIE BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-AKOLA (2)-EKTUNI-1 at AKOLA (2) - 765KV	D	Bay Outage	15-Nov-2024	09:00	15-Nov-2024	18:00	Bay Outage
133	807	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Bay Outage	15-Nov-2024	09:00	15-Nov-2024	18:00	Bay Outage
134	808	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Bay Outage	15-Nov-2024	09:00	15-Nov-2024	18:00	Bay Outage
135	810	PLANNED	OCC_584	MSLDC_OUTAGE	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	D	Diagnostic Testing of CT	15-Nov-2024	10:00	15-Nov-2024	17:00	1) 400kV Koradi-II -Koradi-III Ckt-II will remain in service through Tie Bay 405
136	812	PLANNED	OCC_584	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-1	C	Overhauling of pantograph isolator of bus-2 and auxiliary bus at Chandrapur MSETCL SS & AMP works	15-Nov-2024	08:00	17-Nov-2024	20:00	Ovehauling of pantograph Isolator
137	821	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV/220KV PUNE-PG-ICT-3 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	For AMP Work	15-Nov-2024	09:00	15-Nov-2024	17:30	
138	836	PLANNED	OCC_584	RGPPL	400KV-RGPPL-NEW KOYNA-1	C	REPLACEMENT OF CVT MORE THAN 20 YRS OLD AND EXHIBITING HIGH HUMMING NOISE	15-Nov-2024	08:00	16-Nov-2024	20:00	REPLACEMENT OF CVT MORE THAN 20 YRS OLD AND EXHIBITING HIGH HUMMING NOISE
139	845	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work AR in Non-auto mode	16-Nov-2024	09:00	30-Nov-2024	18:00	-
140	848	PLANNED	OCC_584	WTPL	400KV-PARLI-KALLAM PS-1	D	AR disable require for replacement of earth wire with OPGW	16-Nov-2024	08:00	25-Nov-2024	18:00	AR disable
141	849	PLANNED	OCC_584	WTPL	400KV-PARLI-KALLAM PS-2	D	AR disable require for replacement of earth wire with OPGW	16-Nov-2024	08:00	25-Nov-2024	18:00	AR disable
142	869	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV/220KV PUNE-PG-ICT-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	For AMP Work	16-Nov-2024	09:00	16-Nov-2024	17:30	

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
143	895	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	C	(1) Bay equipments replacement work (CT,CVT,LA,WT, PG & HCB isolators) under LES. (2)Distance M1 & M2 relays retrofitting work.3) Hardware tightening & fitting work	17-Nov-2024	09:00	30-Nov-2024	18:00	-
144	896	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and cold line washing	17-Nov-2024	16:00	17-Nov-2024	22:00	Load managed on 400kv Lamboti-PGCIL line
145	897	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint	17-Nov-2024	08:00	17-Nov-2024	18:00	SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint
146	898	PLANNED	OCC_584	MSLDC_OUTAGE	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	D	Bay maintenance & Diagnostic testing work.	17-Nov-2024	08:00	17-Nov-2024	20:00	Bay maintenance & Diagnostic testing work.
147	899	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Disc Insulator broken replacement at Loc No. 107 Y-Ph PGCIL side & Loc No. 150 B-Ph.	17-Nov-2024	09:00	17-Nov-2024	17:00	Also outage is required on 220kV Tarapur - Borivali Line (for safety purpose)
148	900	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during Disc Insulator broken replacement at Loc No. 107 Y-Ph PGCIL side & Loc No. 150 B-Ph. of 220kV PGCIL - Borivali Line	17-Nov-2024	09:00	17-Nov-2024	17:00	Outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during Disc Insulator broken replacement at Loc No. 107 Y-Ph PGCIL side & Loc No. 150 B-Ph. of 220kV PGCIL - Borivali Line
149	933	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Bay Outage	18-Nov-2024	09:00	18-Nov-2024	18:00	Bay Outage
150	934	PLANNED	OCC_584	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Bay Outage	18-Nov-2024	09:00	18-Nov-2024	18:00	Bay Outage
151	937	PLANNED	OCC_584	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	18-Nov-2024	09:00	18-Nov-2024	18:00	The said work is very important
152	938	PLANNED	OCC_584	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	18-Nov-2024	09:00	18-Nov-2024	18:00	The said work is very important
153	939	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	Routine Line maintenance work	18-Nov-2024	08:00	18-Nov-2024	18:00	AR will be in Non Auto.Dhule II Line will be in service.
154	940	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	AR will be in Non Auto.Dhule II Line will be in service.	18-Nov-2024	08:00	18-Nov-2024	18:00	AR will be in Non Auto.Dhule II Line will be in service.

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
155	941	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	18-Nov-2024	09:00	18-Nov-2024	18:00	The said work is very important
156	952	PLANNED	OCC_584	POWERGRID_WR1	400KV-SOLAPUR-M-SOLAPUR-1	D	Line terminal equipments AMP at 765kV Solapur Substation.	18-Nov-2024	07:00	18-Nov-2024	18:00	
157	957	PLANNED	OCC_584	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-3	D	For AMP Work	18-Nov-2024	09:00	18-Nov-2024	17:30	XMER
158	995	PLANNED	OCC_584	RGPPL	TIE BAY OF 400KV-RGPPL-NAGOTHANE-2 AND 400KV/15.7KV RGPPL-GT-3A @RGPPL - 400KV at RGPPL - 400KV	C	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND BAY MAINTENANCE	18-Nov-2024	08:00	20-Nov-2024	20:00	REPLACEMENT OF CT MORE THAN 20 YRS OLD AND BAY MAINTENANCE
159	996	PLANNED	OCC_584	RGPPL	TIE BAY OF 400KV/15.7KV RGPPL-GT-2B AND 400KV/15.7KV RGPPL-GT-2A @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	18-Nov-2024	08:00	20-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
160	1007	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	C	Complete Maintenance of AC & DC Yard including valve hall, Diagnostic Testing of all Equipments, Chemical Cleaning of AC yard, Line Maintenance Activity	19-Nov-2024	08:00	26-Nov-2024	20:00	Pole 1 will be in service with 750 MW capacity. Also 400KV GCR HVDC Ckt-2 will be required out as & when required during Pole-2 outage.
161	1008	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-2	C	1. Bay Maintenance work. 2. Diagnostic Testing Work. 3.MTAMC Work.	19-Nov-2024	09:00	29-Nov-2024	19:00	Weather conditions should be clear
162	1009	PLANNED	OCC_584	APML	MAIN BAY - 400KV/11.5KV TIRODA-ST-1 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	D	Bay equipment maintenance work	19-Nov-2024	09:00	19-Nov-2024	18:00	ST-1 will be in service on TIE bay
163	1031	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Diagnostic testing & Relay testing work , Routine maint. Work	19-Nov-2024	08:00	19-Nov-2024	18:00	---
164	1099	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Bay Outage	20-Nov-2024	09:00	20-Nov-2024	18:00	Bay Outage
165	1100	PLANNED	OCC_584	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	D	Bay Outage	20-Nov-2024	09:00	20-Nov-2024	18:00	Bay Outage
166	1104	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-II-1	D	for conductor & earthwire hardware tightening fitting workl at various tower location.	20-Nov-2024	08:00	20-Nov-2024	17:00	for conductor & earthwire hardware tightening fitting workl at various tower location.

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
167	1105	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	20-Nov-2024	09:00	20-Nov-2024	17:30	-
168	1106	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	Hardware tightening and cold line washing	20-Nov-2024	09:00	20-Nov-2024	18:00	Load managed
169	1107	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	20-Nov-2024	09:00	20-Nov-2024	18:00	The said work is very important
170	1108	PLANNED	OCC_584	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	20-Nov-2024	09:00	20-Nov-2024	18:00	NA
171	1116	PLANNED	OCC_584	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element.	20-Nov-2024	08:00	20-Nov-2024	20:00	Work @ Wardha SS
172	1117	PLANNED	OCC_584	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	20-Nov-2024	08:00	20-Nov-2024	20:00	Work @ Wardha SS
173	1118	PLANNED	OCC_584	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element.	20-Nov-2024	08:00	20-Nov-2024	20:00	Work @ Wardha SS
174	1160	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-1	C	The following work is to be done during the said outage -a. Dismantling of existing tower loc. no. 70 & 71. b. Destringing of conductor & earthwire from 69-70 & 71-72. c. Tower Erection of new locations 70, 71 & 70A. (all inline towers).d. Conductor final stringing from loc. 69-70-70A & 70A-71-72.e. Jumpering works at all above loc.e. Jumpering works at all above loc. f. making LILO point arrangement at Loc. 70A.	21-Nov-2024	08:00	28-Nov-2024	18:00	

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
175	1161	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-2	C	The following work is to be done during the said outage -a. Dismantling of existing tower loc. no. 70 & 71. b. Destrining of conductor & earthwire from 69-70 & 71-72. c. Tower Erection of new locations 70, 71 & 70A. (all inline towers).d. Conductor final stringing from loc. 69-70-70A & 70A-71-72.e. Jumpering works at all above loc.e. Jumpering works at all above loc. f. making LILO point arrangement at Loc. 70A.	21-Nov-2024	08:00	28-Nov-2024	18:00	
176	1162	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode of 400KV Kalwa - Talegoan line & 400kV Kharghar-Talegaon D/C line (both line).	21-Nov-2024	09:00	30-Nov-2024	18:00	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode of 400KV Kalwa - Talegoan line & 400kV Kharghar-Talegaon D/C line (both line).
177	1163	PLANNED	OCC_584	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	HVDC POLE-2 annual outage work such as O-ring replacement,P-2 B-ph converter transformer repalcement	21-Nov-2024	08:00	28-Nov-2024	20:00	HVDC Chandrapur had been informed
178	1164	PLANNED	OCC_584	APML	MAIN BAY - 400KV/KV TIRODA-ST-3 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	D	Bay equipment maintenance work	21-Nov-2024	09:00	21-Nov-2024	18:00	ST-3 will be in service on TIE bay
179	1178	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	online PID work. AR kept on non auto mode	21-Nov-2024	08:00	30-Nov-2024	18:00	Only Auto Reclose will be out line will be in service
180	1179	PLANNED	OCC_584	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400	C	For Replacement of 89A & 89B isolators	21-Nov-2024	10:00	22-Nov-2024	21:00	-
181	1180	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Hardware tightening and cold line washing	21-Nov-2024	16:00	21-Nov-2024	22:00	Load managed on 400kv parli-karjat ckt-2
182	1199	PLANNED	OCC_584	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	D	For AMP Work	21-Nov-2024	09:00	21-Nov-2024	17:30	Line owned by MSETCL
183	1228	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV/15.7KV RGPPL-GT-2B AND RGPPL - 400KV - BUS 2 @RGPPL - 400KV at RGPPL - 400KV	C	REPLACEMENT OF UNIT 2B CVT MORE THAN 20 YRS OLD AND EXHIBITING HIGH HUMMING NOISE	21-Nov-2024	08:00	23-Nov-2024	20:00	REPLACEMENT OF UNIT 2B CVT MORE THAN 20 YRS OLD AND EXHIBITING HIGH HUMMING NOISE

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
184	1229	PLANNED	OCC_584	RGPPL	TIE BAY OF 400KV-RGPPL-NAGOTHANE-1 AND 400KV/15.7KV RGPPL-GT-2X @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	21-Nov-2024	08:00	23-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
185	1231	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) CB testing & Reactor Backup relay testing. (2) Bay maintenance work. (3) Hardware tightening & fitting work	22-Nov-2024	22:00	23-Nov-2024	06:00	-
186	1232	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Hardware tightening and cold line washing	22-Nov-2024	22:00	23-Nov-2024	06:00	Load managed on 400kv Parli-Karjat ckt-2 line
187	1241	PLANNED	OCC_584	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	D	Bay Outage	22-Nov-2024	09:00	22-Nov-2024	18:00	Bay Outage
188	1242	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	D	Bay Outage	22-Nov-2024	09:00	22-Nov-2024	18:00	Bay Outage
189	1244	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	for conductor & earthwire hardware tightening fitting work at various tower location.	22-Nov-2024	08:00	22-Nov-2024	17:00	for conductor & earthwire hardware tightening fitting workl at various tower location.
190	1245	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Diagnostic testing & Relay testing work , Routine maint. Work	22-Nov-2024	08:00	22-Nov-2024	18:00	---
191	1250	PLANNED	OCC_584	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Line Bay AMP work. AR OF CKT 2 IN NON AUTO IS REQUIRED	22-Nov-2024	08:00	22-Nov-2024	18:00	Line Bay AMP , LBB Retrofitting works
192	1257	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	For AMP Work	22-Nov-2024	09:00	22-Nov-2024	17:30	
193	1264	PLANNED	OCC_584	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	D	For AMP work @ Pune765_GIS ON NON SWITCHABLE LINE REACTOR AND LINE BAY	22-Nov-2024	09:00	22-Nov-2024	18:00	For AMP work @ Pune765
194	1287	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	Routine Line maintenance work	23-Nov-2024	08:00	23-Nov-2024	18:00	AR will be in Non Auto.Dhule I Line will be in service.
195	1288	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	AR IN NON AUTO MODE IS REQUIRED	23-Nov-2024	08:00	23-Nov-2024	18:00	AR will be in Non Auto.Dhule I Line will be in service.

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
196	1289	PLANNED	OCC_584	POWERGRID_WR1	WARDHA - 220KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element.	23-Nov-2024	08:00	23-Nov-2024	20:00	Work @ Wardha SS
197	1290	PLANNED	OCC_584	POWERGRID_WR1	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	23-Nov-2024	08:00	23-Nov-2024	20:00	Work @ Wardha SS
198	1298	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	Half yearly testing and maintenance	23-Nov-2024	10:00	23-Nov-2024	18:00	-
199	1303	PLANNED	OCC_584	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Line Bay AMP work. AR OF CKT 1 IN NON AUTO IS REQUIRED	23-Nov-2024	08:00	23-Nov-2024	18:00	CT Oil sample collecting, Line Bay AMP , LBB Retrofitting works
200	1304	PLANNED	OCC_584	POWERGRID_WR1	BUS COUPLER BAY - WARDHA - 220KV - BUS 1 AND WARDHA - 220KV - BUS 2 at Wardha - 220KV	D	For Bay AMP Works.	23-Nov-2024	08:00	23-Nov-2024	20:00	Work @ Wardha SS
201	1321	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BORIVALI-1	D	outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph. & Loc No. 46-47 B-Ph. for 220kV PGCIL - Borivali Line	24-Nov-2024	09:00	24-Nov-2024	17:00	outage is required on 220kV Tarapur - Borivali Line (for safety purpose) during Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph. & Loc No. 46-47 B-Ph. for 220kV PGCIL - Borivali Line
202	1322	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	Repair Sleeves for Conductor damaged at Loc No. 143-144 Top Ph. & Loc No. 46-47 B-Ph	24-Nov-2024	09:00	24-Nov-2024	17:00	Simultaneous outage is required on 220kV Tarapur - Borivali Line (for safety purpose)
203	1332	PLANNED	OCC_584	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	D	Replacement of conductor Between WT /line isolator to Line	25-Nov-2024	09:00	25-Nov-2024	17:30	Line Owned By MSETCL
204	1347	PLANNED	OCC_584	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Bay Outage	25-Nov-2024	09:00	25-Nov-2024	18:00	Bay Outage
205	1348	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	D	Bay Outage	25-Nov-2024	09:00	25-Nov-2024	18:00	Bay Outage
206	1351	PLANNED	OCC_584	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	25-Nov-2024	09:00	25-Nov-2024	18:00	The said work is very important
207	1352	PLANNED	OCC_584	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	25-Nov-2024	09:00	25-Nov-2024	18:00	The said work is very important

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
208	1353	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	25-Nov-2024	09:00	25-Nov-2024	18:00	The said work is very important
209	1357	PLANNED	OCC_584	POWERGRID_WR1	TIE BAY OF PADGHE-PG - 400KV B/R 1 AND 400KV-PADGHE-PG-KHARGHAR-2 @PADGHE-PG - 400KV at PADGHE-PG - 400KV	C	Breaker Close/open & spring Charge/Discharge Indication replacement	25-Nov-2024	09:00	27-Nov-2024	17:00	400 KV Padghe Khargar 2 is now 400 Kv Padghe Navi Mumbai
210	1360	PLANNED	OCC_584	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element and AMP Work.	25-Nov-2024	08:00	25-Nov-2024	13:00	Work @ Wardha SS
211	1363	PLANNED	OCC_584	POWERGRID_WR1	PARLI - 220KV - BUS 1	D	Bus AMP	25-Nov-2024	08:00	25-Nov-2024	18:00	Bus AMP
212	1364	PLANNED	OCC_584	POWERGRID_WR1	400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	D	Line Bay AMP work. AR OF CKT 2 IN NON AUTO IS REQUIRED	25-Nov-2024	08:00	25-Nov-2024	18:00	Line Bay AMP work
213	1368	PLANNED	OCC_584	POWERGRID_WR1	AKOLA - 400KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element.	25-Nov-2024	08:00	25-Nov-2024	20:00	Work @ Wardha SS
214	1369	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	D	For AMP of Bay	25-Nov-2024	08:00	25-Nov-2024	20:00	Work @ Wardha SS
215	1370	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	D	For AMP of Bay	25-Nov-2024	08:00	25-Nov-2024	20:00	Work @ Wardha SS
216	1375	PLANNED	OCC_584	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-1	D	For AMP work @ Pune765_GIS ON NON SWITCHABLE LINE REACTOR AND LINE BAY	25-Nov-2024	09:00	25-Nov-2024	18:00	For AMP work @ Pune765(kallam_1)
217	1377	PLANNED	OCC_584	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element and AMP Work.	25-Nov-2024	14:00	25-Nov-2024	20:00	Work @ Wardha SS
218	1389	PLANNED	OCC_584	POWERGRID_WR2	400KV-KALA-KUDUS-1	D	Terminal Equipment AMP, A/R off of ckt 2 is required. Dia to be kept open at both ends.	25-Nov-2024	09:00	25-Nov-2024	18:00	PG-WR-2-KALA
219	1401	PLANNED	OCC_584	RGPPPL	TIE BAY OF 400KV-RGPPL-NAGOTHANE-2 AND 400KV/15.7KV RGPPL-GT-3A @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	25-Nov-2024	08:00	27-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
220	1407	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	26-Nov-2024	09:00	30-Nov-2024	18:00	PID testing of insulator A/R function required to be in non auto mode
221	1420	PLANNED	OCC_584	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	C	765KV Line-2 will be in service on Tie bay	26-Nov-2024	09:00	27-Nov-2024	18:00	765KV Line-2 will be in service on Tie bay

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
222	1426	PLANNED	OCC_584	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	HVDC Bipole annual Outage work such as anjur isolator maintenace,auxillary trials,400Kv Tie bay maintenace,neutral bay equipment C.B,Isolator maintenace work etc	26-Nov-2024	20:00	29-Nov-2024	20:00	HVDC Chandrapur had been informed
223	1427	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Cold Washing work	26-Nov-2024	08:00	26-Nov-2024	18:00	---
224	1431	PLANNED	OCC_584	POWERGRID_WR1	SOLAPUR - 220KV - BUS 2	D	220KV Bus#2 AMP Works Note1 : Before shutdown , All the elements connected with 220KV Bus#2 shall be shifted to 220kV Bus#1 Note 2: Each element shall be shifted to TBC one by one for maintenance of Bus#2 Isolators.	26-Nov-2024	07:00	26-Nov-2024	18:00	
225	1432	PLANNED	OCC_584	POWERGRID_WR1	400KV-WARDHA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element and AMP Work.	26-Nov-2024	08:00	26-Nov-2024	13:00	Work @ Wardha SS
226	1437	PLANNED	OCC_584	POWERGRID_WR1	AKOLA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element.	26-Nov-2024	08:00	26-Nov-2024	20:00	Work @ Wardha SS
227	1438	PLANNED	OCC_584	POWERGRID_WR1	220 KV TALEGAON-PUNE-PG-2	D	For Hotspot rectification	26-Nov-2024	09:00	26-Nov-2024	17:30	Line Owned By MSETCL
228	1485	PLANNED	OCC_584	MEGPTCL	TIE BAY - 400KV-KORADI-II-KORADI-III-2 AND FUTURE at KORADI-III - 400KV	D	Bay Outage	27-Nov-2024	09:00	27-Nov-2024	18:00	Bay Outage
229	1491	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Cold Washing work	27-Nov-2024	08:00	27-Nov-2024	18:00	---
230	1492	PLANNED	OCC_584	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	27-Nov-2024	09:00	27-Nov-2024	17:30	-
231	1493	PLANNED	OCC_584	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	For routine maintenance work	27-Nov-2024	09:00	27-Nov-2024	18:00	NA
232	1495	PLANNED	OCC_584	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE	27-Nov-2024	09:00	29-Nov-2024	17:30	For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
233	1497	PLANNED	OCC_584	POWERGRID_WR1	PARLI - 220KV - BUS 2	D	Bus AMP	27-Nov-2024	08:00	27-Nov-2024	18:00	Bus AMP

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
234	1498	PLANNED	OCC_584	POWERGRID_WR1	400KV-KOLHAPUR-MS-Alkud-1 at KOLHAPUR-MS - 400KV	D	Line Bay AMP work. AR OF CKT 2 IN NON AUTO IS REQUIRED	27-Nov-2024	08:00	27-Nov-2024	18:00	Line Bay AMP , LBB Retrofitting and Relay testing works
235	1501	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-BHILAI-1 AND BHILAI - 400KV - BUS 2 at BHILAI - 400KV	D	AMP at Bhilai SS	27-Nov-2024	09:00	27-Nov-2024	17:30	AMP at Bhilai SS
236	1502	PLANNED	OCC_584	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-1	D	PT 100 sensor work	27-Nov-2024	09:00	27-Nov-2024	17:30	XMER
237	1521	PLANNED	OCC_584	RGPPPL	TIE BAY OF 400KV/11.9KV RGPPL-ST-2 AND FUTURE @RGPPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	27-Nov-2024	08:00	29-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
238	1538	PLANNED	OCC_584	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Bus Isolator Maintenance Work	28-Nov-2024	09:00	28-Nov-2024	17:00	Work will be carried out by agency and also DCRM of 41052 CB will carried out by Testing Unit which is recommended by AREVA representative.
239	1539	PLANNED	OCC_584	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 2	D	Routine Maintenance and DT	28-Nov-2024	10:00	28-Nov-2024	18:00	Routine Maintenance and DT
240	1540	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Hardware tightening and cold line washing	28-Nov-2024	16:00	28-Nov-2024	22:00	Load managed on 400kv parli-karjat ckt-1
241	1544	PLANNED	OCC_584	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	D	For AMP	28-Nov-2024	08:00	28-Nov-2024	18:00	401A
242	1546	PLANNED	OCC_584	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	For Line bay and main Bay AMP work	28-Nov-2024	08:00	28-Nov-2024	20:00	Work @ Wardha SS
243	1547	PLANNED	OCC_584	POWERGRID_WR1	PUNE-PG - 220KV - BUS#2	D	For AMP Work	28-Nov-2024	09:00	28-Nov-2024	17:30	Each bay will be taken on TBC bay
244	1565	PLANNED	OCC_584	RGPPPL	TIE BAY OF 400KV/15.7KV RGPPL-GT-3B AND 400KV/15.7KV RGPPL-GT-3X @RGPPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	28-Nov-2024	08:00	30-Nov-2024	20:00	BAY MAINTENANCE AND TESTING
245	1576	PLANNED	OCC_584	MEGPTCL	TIE BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV B/R 1 at TIRODA - 765KV	C	765KV TIRODA KORADI-III-2 WILL BE IN SERVICE ON main BAY	29-Nov-2024	09:00	30-Nov-2024	18:00	765KV TIRODA KORADI-III-2 WILL BE IN SERVICE ON main BAY
246	1577	PLANNED	OCC_584	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	D	Bay Outage	29-Nov-2024	09:00	29-Nov-2024	18:00	Bay Outage
247	1581	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	29-Nov-2024	08:00	29-Nov-2024	18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint
248	1582	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	1) SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint 2) Also Bay maintenance & Diagnostic testing work at 400kV RS Kalwa.	29-Nov-2024	08:00	29-Nov-2024	18:00	1) SSN to DSN insulator string Conversion work, and installation of fire wedge connector at mid-span joint 2) Also Bay maintenance & Diagnostic testing work at 400kV RS Kalwa.

SL	OCC M Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Contin ous	Reason	From Date	From Time	To Date	To Time	Remarks
249	1583	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work	29-Nov-2024	08:00	29-Nov-2024	18:00	400kV Padghe II will be in in service
250	1589	PLANNED	OCC_584	POWERGRID_WR1	TIE BAY - 400KV-PARLI-M-PARLI-1 AND PARLI - 400KV B/R 1 AT PARLI - 400KV at PARLI - 400KV	D	Bay AMP	29-Nov-2024	08:00	29-Nov-2024	18:00	Bay AMP
251	1590	PLANNED	OCC_584	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2 at KOLHAPUR-MS - 400KV	D	Line Bay AMP work. AR OF CKT 1 IN NON AUTO IS REQUIRED	29-Nov-2024	08:00	29-Nov-2024	18:00	Line Bay AMP , LBB Retrofitting and Relay testing works
252	1592	PLANNED	OCC_584	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	For Amp of Line Bay	29-Nov-2024	08:00	29-Nov-2024	20:00	Work @ Wardha SS
253	1609	PLANNED	OCC_584	MEGPTCL	AKOLA - 765KV - BUS 2	D	Bus Outage	30-Nov-2024	09:00	30-Nov-2024	18:00	Bus Outage
254	1610	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work	30-Nov-2024	08:00	30-Nov-2024	18:00	400kV Padghe I will be in in service
255	1612	PLANNED	OCC_584	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	Replacement of conductor Between WT /line isolator to Line	30-Nov-2024	09:00	30-Nov-2024	17:30	Line owned by MSETCL
256	1626	PLANNED	OCC_584	RGPPL	MAIN BAY OF 400KV/11.9KV RGPPL-ST-2 AND RGPPL - 400KV - BUS 2 @RGPPL - 400KV at RGPPL - 400KV	C	BAY MAINTENANCE AND TESTING	30-Nov-2024	08:00	02-Nov-2024	20:00	BAY MAINTENANCE AND TESTING

Maharashtra State Load Despatch Centre

Monthly Outage list Not Considered in WRLDC OCCM for the Month of NOVEMBER'2024

SL	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks	RLDC Remark
113	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode of 400KV Kalwa -Talegoan line & 400kV Kalwa-Kharghar D/C line (both line)	01-Nov-2024	09:00	20-Nov-2024	18:00	Replacement of existing 48F OPGW with 96F OPGW by MTCIL, A/R function to be in non auto mode of 400KV Kalwa - Talegoan line & 400kV Kalwa-Kharghar D/C line (both line)	one at a time/ At kalwa, Pune, Kharghar and padghe line planned simultaneously.
114	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	To complete balance work of replacement of existing conductor by HTLS conductor.	01-Nov-2024	09:00	20-Nov-2024	22:00	To complete balance work of replacement of existing conductor by HTLS conductor	one at a time/ At kalwa, Pune, Kharghar and padghe line planned simultaneously.
146	PLANNED	OCC_584	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	Complete Maintenance of AC & DC yard including Valve Hall, Testing of Equipments, Chemical Cleaning of AC Yard, Isolator Maintenance Work, HVDC Pole I Line Maintenance etc.	09-Nov-2024	08:00	16-Nov-2024	20:00	Pole II will be in service with 750 MW Capacity. Also 400KV GCR HVDC Ckt-1 will be required out as & when required during Pole-1 outage	Not considered/repeat entry
147	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	C	1) Bay Maintenance work 2) Diagnostic Testing work 3) MTAMC Work.	09-Nov-2024	09:00	16-Nov-2024	19:00	Weather conditions should be clear	Not Considered/Element name not as per portal
148	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	10-Nov-2024	08:00	10-Nov-2024	18:00	SSN to DSN insulator string Conversion work, and installation of fridge wedge connector at mid-span joint	reschedule/Pune PG
168	PLANNED	OCC_584	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	To carryout PID of insulator strings.	15-Nov-2024	10:00	30-Nov-2024	18:00	-	Planned with Kalwa/Pune outages
185	PLANNED	OCC_584	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	Complete Maintenance of AC & DC Yard including valve hall, Diagnostic Testing of all Equipments, Chemical Cleaning of AC yard, Line Maintenance Activity	19-Nov-2024	08:00	26-Nov-2024	20:00	Pole I will be in service with 750 MW capacity. Also 400KV GCR HVDC Ckt-2 will be required out as & when required during Pole-2 outage.	to be discussed/MH election
209	PLANNED	OCC_584	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	Bipole Neutral Bay Maintenance, Chincholi Electrde Station Maintenance, Electrode Line Maintenance, HVDC Pole I	26-Nov-2024	20:00	29-Nov-2024	20:00	Both Pole will be out of Service	Not considered/repeat entry

Maharashtra State Load Despatch Centre

State Element outage list for the month of NOVEMBER '2024

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	KARAD - TALANDGE CKT - 1	01-Nov-24	09:00	15-Nov-24	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
2	400 KV	KARAD - TALANDGE CKT - 2	01-Nov-24	09:00	15-Nov-24	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
3	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	01-Nov-24	09:00	30-Nov-24	18:00	Daily	PID testing work. AR in Non-auto mode	MSETCL	MSETCL	-
4	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	05-Nov-24	08:00	05-Nov-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
5	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	05-Nov-24	08:00	05-Nov-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT. HV CB DCRM ,Timing and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
6	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	05-Nov-24	08:00	05-Nov-24	18:00	Daily	For verification of RRS Scheme along with 501 MVA ICT -III.	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken in service through 501 MVA ICT-III.
7	400 KV	400 /7.6KV Station T/F-5 A @ KHAPERKHEDA	06-Nov-24	11:00	06-Nov-24	17:00	Daily	Breaker DCRM Testing	MSETCL	MSETCL	NA
8	400 KV	BUS REACTOR (125 MVA) @ ALKUD	06-Nov-24	10:00	06-Nov-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
9	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	06-Nov-24	10:00	06-Nov-24	17:00	Daily	Circuit Breaker maintenance work	MSETCL	MSETCL	--
10	400 KV	MAIN BAY - 404 OF STATION TF-3 @ KORADI 2	06-Nov-24	10:00	06-Nov-24	17:00	Daily	Diagnostic Testing of CB	MSETCL	MSETCL	Station Transformer-III will remain in service through Tie Bay 405.
11	400 KV	JEJURI- KOYNA STAGE-IV	07-Nov-24	08:00	07-Nov-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	92/8 scheme insulator replacement work
12	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	07-Nov-24	10:00	07-Nov-24	18:00	Daily	Diagnostic Testing & Bay Maintenance Work	MSETCL	MSETCL	Testing & Maintenance Work
13	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	07-Nov-24	09:00	07-Nov-24	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
14	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	07-Nov-24	08:00	07-Nov-24	18:00	Daily	For restoration ICT -III from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service
15	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	07-Nov-24	08:00	07-Nov-24	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-III
16	400 KV	NEW KOYNA-KARAD CKT - 1	08-Nov-24	08:00	08-Nov-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work

Sr.n o.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
17	400 KV	NEW KOYNA-KARAD CKT - 1	08-Nov-24	08:00	08-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
18	400 KV	MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	08-Nov-24	10:00	08-Nov-24	17:00	Daily	Diagnostic Testing of CB	MSETCL	MSETCL	Station Transformer-II will remain in service through Tie Bay 408
19	400 KV	NEW KOYNA-KARAD CKT - 2	09-Nov-24	08:00	09-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
20	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	09-Nov-24	08:00	09-Nov-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT.Differential HV ,LV Back up relay ,HV CB DCRM ,Timing HV CT Tan D and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
21	400 KV	105 MVA SPARE ICT @ CHAKAN	09-Nov-24	10:00	09-Nov-24	18:00	Daily	Routine Maintenance and DT	MSETCL	MSETCL	Routine Maintenance and DT
22	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	09-Nov-24	08:00	09-Nov-24	20:00	Daily	Fire wall & ICT painting work	MSETCL	MSETCL	Fire wall & ICT painting work
23	400 KV	NEW KOYNA-KARAD CKT - 2	09-Nov-24	07:00	09-Nov-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
24	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	09-Nov-24	08:00	09-Nov-24	18:00	Daily	For verification of RRS Scheme along with Spare ICT.Differential HV ,LV Back up relay ,HV CB DCRM ,Timing HV CT Tan D and bay maintenance work	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
25	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	10-Nov-24	08:00	10-Nov-24	20:00	Daily	Fire wall & ICT painting work	MSETCL	MSETCL	Fire wall & ICT painting work
26	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	11-Nov-24	08:00	13-Nov-24	18:00	Daily	For replacement of polymer insulator string with long rod porcelain insulator string.	MSETCL	MSETCL	Outage
27	400 KV	KARAD - TALANDGE CKT - 1	11-Nov-24	08:00	11-Nov-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
28	400 KV	JAIGAD - NEW KOYNA CKT - 2	11-Nov-24	08:00	11-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
29	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	11-Nov-24	08:00	11-Nov-24	18:00	Daily	For restoration ICT -IV from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service
30	400 KV	MAIN BAY-422 OF STATION TF - 1 @ KORADI -2	11-Nov-24	10:00	11-Nov-24	17:00	Daily	Diagnostic Testing of CB	MSETCL	MSETCL	Station Transformer-I will remain in service through Tie Bay 423
31	400 KV	400/220KV 167 MVA SPARE ICT - 2 @ BABHALESHWAR	11-Nov-24	08:00	11-Nov-24	18:00	Daily	For restoration Spare ICT-2 from RRS Scheme after verification	MSETCL	MSETCL	167 MVA Spare ICT-2 will be taken out of service from 501 MVA ICT-IV
32	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	11-Nov-24	09:00	11-Nov-24	17:00	Daily	1)Quarterly Maintenance Work of ICT's & Bay Equipment 2)Diagnostic Testing Work	MSETCL	MSETCL	Nil

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
33	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	11-Nov-24	09:00	11-Nov-24	18:00	Daily	Earthwire Stringing Work loc.no.497-500 & Nut bolt hardware tightning work	MSETCL	MSETCL	-
34	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	11-Nov-24	09:00	11-Nov-24	18:00	Daily	Quarterly maintenance work and for attending Oil leakage	MSETCL	MSETCL	1.Load will be managed on ICT 2 & ICT 3 2.Monday is load Staggering day at Kolhapur
35	400 KV	KARAD - TALANDGE CKT - 2	12-Nov-24	08:00	12-Nov-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
36	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	12-Nov-24	08:00	12-Nov-24	18:00	Daily	1. Diagnostic testing of Circuit Breaker. 2. Maintenance and alignment of PG-1 & PG-2 Isolators. 3. The Circuit will be in service via TBC-1	MSETCL	MSETCL	During outage 400KV CHD-2 CKT-2, 400KV Parli CKT-3, 400KV Khaperkheda, 400KV HVDC CKT-1 & 2, 400KV PGCIL CKT-1,2,3&4 will be in service.
37	400 KV	TBC @ PARLI	12-Nov-24	09:00	12-Nov-24	18:00	Daily	1) Back up relay testing work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
38	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	12-Nov-24	09:00	12-Nov-24	18:00	Daily	Quarterly maintenance work and for attending Oil leakage	MSETCL	MSETCL	1.Load will be managed on ICT 1 & ICT 3
39	400 KV	JAIGAD - NEW KOYNA CKT - 1	13-Nov-24	08:00	13-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
40	400 KV	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	13-Nov-24	10:00	13-Nov-24	17:00	Daily	Diagnostic Testing of CB	MSETCL	MSETCL	ICT-I will remain inservice through Tie Bay 429
41	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	13-Nov-24	10:00	13-Nov-24	17:00	Daily	For Carrying out diagnostic testing of bushing, winding, HV CT, LV CT, breaker, and routine maintenance.	MSETCL	MSETCL	Load will be managed on ICT-II.
42	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	13-Nov-24	09:00	13-Nov-24	18:00	Daily	Quarterly maintenance work and for attending Oil leakage	MSETCL	MSETCL	1.Load will be managed on ICT 1 & ICT 2
43	400 KV	LONIKAND I - KOYNA STAGE-IV	14-Nov-24	08:00	14-Nov-24	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
44	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	14-Nov-24	09:00	14-Nov-24	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
45	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	14-Nov-24	09:00	14-Nov-24	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
46	400 KV	MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	14-Nov-24	09:00	14-Nov-24	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
47	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	14-Nov-24	10:00	14-Nov-24	17:00	Daily	For carrying out diagnostic testing of bushing, winding, CT and routine maintenance.	MSETCL	MSETCL	Load will be managed on ICT-I & ICT-II.
48	400 KV	400/220 KV 167 MVA ICT @ PARLI	14-Nov-24	09:00	14-Nov-24	18:00	Daily	1) HV CTtesting work of ICT Unit..2) Bay Maintenance work.	MSETCL	MSETCL	-
49	400 KV	167 MVA SPARE ICT @ TALANDGE	14-Nov-24	09:00	14-Nov-24	18:00	Daily	Quarterly maintenance work and for attending Oil leakage	MSETCL	MSETCL	Only charged condition.

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
50	400 KV	LONIKAND - JEJURI CKT - 2	15-Nov-24	08:00	15-Nov-24	18:00	Daily	@Lonikand-I:DT and Bay Maintenance activities @Jejuri:Annual maintenance work & testing work	MSETCL	MSETCL	-
51	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	15-Nov-24	08:00	15-Nov-24	18:00	Daily	Routine Line maintenance work & LBB relay testing work	MSETCL	MSETCL	400kV Ektuni I & II will be in service
52	400 KV	BUS REACTOR (125 MVar) - 2 @ KOLHAPUR (TALANDGE)	15-Nov-24	09:00	15-Nov-24	18:00	Daily	Quarterly maintenance work and for attending Oil leakage	MSETCL	MSETCL	-
53	400 KV	JEJURI- KOYNA STAGE-IV	16-Nov-24	08:00	16-Nov-24	18:00	Daily	Cold Washing of Insulator strings	MSETCL	MSETCL	-
54	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	16-Nov-24	10:00	17-Nov-24	21:00	Continuous	For Overhauling of SERGI make NIFPS	MSETCL	MSETCL	-
55	400 KV	JEJURI- KOYNA STAGE-IV	16-Nov-24	09:00	30-Nov-24	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
56	400 KV	LONIKAND I - KOYNA STAGE-IV	16-Nov-24	09:00	30-Nov-24	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	MSETCL	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
57	400 KV	LONIKAND - JEJURI CKT - 1	17-Nov-24	08:00	17-Nov-24	18:00	Daily	Cold Washing of Insulator strings	MSETCL	MSETCL	-
58	400 KV	TIE BAY (405) OF STN T/F-3 & KORADI 3 CKT-2 @KORADI 2	18-Nov-24	10:00	18-Nov-24	17:00	Daily	Diagnostic Testing of CB & CT	MSETCL	MSETCL	1) 400kV Koradi-II -Koradi-III Ckt-II will remain in service through Main Bay 406 2) Station Transformer -III will remain in service through Main bay 404
59	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	18-Nov-24	06:00	18-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
60	400 KV	BUS REACTOR (125 MVar) @ LAMBOTI	19-Nov-24	10:00	19-Nov-24	17:00	Daily	Outage is required for carrying out the diagnostic testing of bushing, winding and routine maintenance.	MSETCL	MSETCL	No need of reactor in service.
61	400 KV	400KV TIE BAY 432 OF 500MVA 400/220KV ICT 1 @ CHANDRAPUR 2	19-Nov-24	10:00	19-Nov-24	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
62	400 KV	400/220 KV 500 MVA ICT @ ALKUD	19-Nov-24	10:00	19-Nov-24	18:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	Load will be managed on 400KV Karad & Talandge S/S
63	400 KV	400KV 125 MVAR BUS REACTOR @ AKOLA	19-Nov-24	09:00	19-Nov-24	17:00	Daily	Routine maintenance work, DCRM of 41652 CB, CTR Trials	MSETCL	MSETCL	DCRM will be carried out by Testing Unit where as CTR trials will be taken by agency.
64	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	19-Nov-24	14:00	19-Nov-24	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
65	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	19-Nov-24	10:00	19-Nov-24	13:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
66	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	20-Nov-24	09:00	20-Nov-24	18:00	Daily	CT / Winding Tan Delta , DFRA	MSETCL	MSETCL	The outage time may be varied as per site & weather condition

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
67	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	20-Nov-24	10:00	20-Nov-24	17:00	Daily	Outage is required for carrying out the diagnostic testing of bushing, winding, breaker and routine maintenance.	MSETCL	MSETCL	Load will be managed on ICT-I.
68	400 KV	400KV TIE BAY 435 OF 500MVA 400/220KV ICT 2 @ CHANDRAPUR 2	20-Nov-24	10:00	20-Nov-24	15:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
69	400 KV	MAIN BAY (414) OF KORADI CKT - 2 @ KHAPARKHEDA 2	20-Nov-24	11:00	20-Nov-24	17:00	Daily	Breaker DCRM Testing	MSETCL	MSETCL	NA
70	400 KV	TBC 2 @ CHANDRAPUR	20-Nov-24	08:00	20-Nov-24	18:00	Daily	1. Diagnostic Testing of Circuit Breaker and CT. 2. Maintenance and alignment of Isolators. 3. Bay routine maintenance work.	MSETCL	MSETCL	Diagnostic Testing and routine maintenance of various equipment.
71	400 KV	STATION TF-3 @ KORADI 2	20-Nov-24	10:00	20-Nov-24	17:00	Daily	Diagnostic Testing of CT	MSETCL	MSETCL	1) NOC required from Mahagenco.
72	400 KV	NEW KOYNA - STAGE IV CKT - 1	21-Nov-24	08:00	21-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
73	400 KV	JEJURI - KARAD	21-Nov-24	09:00	21-Nov-24	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
74	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	21-Nov-24	08:00	21-Nov-24	18:00	Daily	DT and Bay Maintenance activities	MSETCL	MSETCL	-
75	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	21-Nov-24	09:00	21-Nov-24	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-
76	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	21-Nov-24	10:00	21-Nov-24	18:00	Daily	Diagnostic Testing & Bay Maintenance Work	MSETCL	MSETCL	Testing & Maintenance Work
77	400 KV	JEJURI - KARAD	21-Nov-24	08:00	21-Nov-24	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
78	400 KV	MAIN BAY (404) OF ICT - 2 @ KORADI 3	22-Nov-24	09:00	22-Nov-24	18:00	Daily	Bay Outage	MEGPTCL	MEGPTCL	Bay Outage
79	400 KV	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	22-Nov-24	09:00	22-Nov-24	17:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	400/220/33 kV ICT 2 will be in service through 406 Tie bay
80	400 KV	400/220/20 KV 500MVA ICT - 1 @ KALWA	23-Nov-24	08:00	23-Nov-24	20:00	Daily	Bay maintenance & Diagnostic testing work.	MSETCL	MSETCL	Bay maintenance & Diagnostic testing work.
81	400 KV	400/220KV 315 MVA ICT - 3 @ NEW KOYNA	25-Nov-24	06:00	25-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
82	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	26-Nov-24	09:00	26-Nov-24	18:00	Daily	1) HV CB & HV CT Tan delta testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
83	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	27-Nov-24	10:00	27-Nov-24	17:00	Daily	Outage is required for carrying out diagnostic testing of bushing, winding, HV CT, LV CT, breaker and routine maintenance.	MSETCL	MSETCL	Load will be managed on ICT-II.
84	400 KV	33KV HVDC AUXILIARY SUPPLY 2 @ PADGHE-400 KV	27-Nov-24	09:00	29-Nov-24	19:00	Continuous	1.Bay Maintenance Work. 2.Diagnostic Testing Work.	MSETCL	MSETCL	Weather conditions should be clear
85	400 KV	NEW KOYNA - STAGE IV CKT - 2	28-Nov-24	08:00	28-Nov-24	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
86	400 KV	TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI	28-Nov-24	09:00	28-Nov-24	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
87	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	28-Nov-24	10:00	28-Nov-24	18:00	Daily	Diagnostic Testing & Bay Maintenance Work	MSETCL	MSETCL	Testing & Maintenance Work

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
88	400 KV	400/220KV 167 MVA SPARE ICT - 3 @ BABHALESHWAR	28-Nov-24	08:00	28-Nov-24	18:00	Daily	Outage is required for RRS live trials on 400/220kV 501 MVA IcT 5 with 167 MVA Spare ICT 3	MSETCL	MSETCL	-
89	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	29-Nov-24	09:00	29-Nov-24	18:00	Daily	1) HV CB testing work of ICT Unit..2) Bay Maintenance work.	MSETCL	MSETCL	-
90	400 KV	CHANDRAPUR - KHAPERKHEDA	30-Nov-24	09:00	30-Nov-24	16:00	Daily	for conductor & earthwire hardware tightening fitting workl at various tower location.	MSETCL	MSETCL	for conductor & earthwire hardware tightening fitting workl at various tower location.