

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of December'2018

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
1	24	220	BOISAR II - PGCIL 1 In Non auto mode	01/Dec/18	08:00	01/Dec/18	18:00	Daily	PID work	MSETCL	MSETCL	PID work, for shifting of auto reclose switch tonon-auto mode	
2	25	765	BUS - 1 @ TIRODA	01/Dec/18	08:00	01/Dec/18	21:00	Daily	Testing & Maintenance of Bus Connected Isolator & CVT	APML	APML		Based on availability of generation
3	26	220	EKLAHARA-(OCR)-NAVASARI I	01/Dec/18	09:00	01/Dec/18	15:00	Daily	maint. work	MSETCL	MSETCL	-	
4	27	400	NAGOTHANE - DABHOL 2	01/Dec/18	08:00	02/Dec/18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load managed on Dabhol Nagothane-I line	
5	28	400	KHADKA - BABLESHWAR ON TBC @ BABHALESHWAR	01/Dec/18	09:00	05/Dec/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 kv Babhaleshwar-Bhusawal Bay is Take on TBC for Rpearing of 29A & 29B P.G Isolator P.G Isolator Scissors (Hanger dropper assembly of Bhusawal bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)	
6	29	400	Padgha - Kalwa ckt - 2	01/Dec/18	8:00	10/Dec/18	17:00	Continuous	1) Dismantling of conductor at loc. No. 1103 to 1106 2) Tower erection at loc. No. 1104 to 1105 3) Dismantling of Tower existing Loc.No.1104 4) Stringing of conductor at Loc.No. 1103 to 1106	MSETCL	MSETCL		
7	30	400	CHANDRAPUR-PARLI CKT-3	01/Dec/18	07:00	15/Dec/18	19:00	Daily	PID work	MSETCL	MSETCL	other ckt will be in non auto mode	
8	31	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	01/Dec/18	08:00	15/Dec/18	17:00	Daily	PID work	MSETCL	MSETCL	PID work shifting of auto reclose switch to NON auto mode	
9	32	400	BABHALESHWAR - PADGHE 1	01/Dec/18	08:00	15/Dec/18	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	A/R to be taken out of service	
10	33	220	FUSAD - WARDHA (PG)	01/Dec/18	07:00	19/Dec/18	17:00	Daily	PID work	MSETCL	MSETCL	PID work, for shifting of auto reclose switch tonon-auto mode	
11	38	220	BHUGAON - WARDHA (PG)	01/Dec/18	08:00	31/Dec/18	18:00	Daily	PID work from location no.33 (LILO Point) to PGCIL End	MSETCL	MSETCL	Need to out the A/R for BRANCH Line.	
12	39	400	PARLI-SOLAPUR (LAMBOTI)	01/Dec/18	10:00	31/Dec/18	18:00	Daily	PID testing work.	MSETCL	MSETCL	Line will be In service.	
13	41	220	220KV Bus-I at Boisar	02/Dec/18	9:00	02/Dec/18	17:30	Daily	For AMP	POWERGRID	WR-II	R	Please schedule outage on 02.12.2018 (on Sunday)
14	46	400	PADGHE - KALWA 2	02/Dec/18	08:00	02/Dec/18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	1st to 10th already approved	
15	77	220	BOISAR II - PGCIL 3 In Non auto mode	03/Dec/18	08:00	03/Dec/18	18:00	Daily	PID work	MSETCL	MSETCL	PID work, for shifting of auto reclose switch tonon-auto mode	
16	78	400	TBC @ PARLI	03/Dec/18	09:00	03/Dec/18	17:00	Daily	(1) CB DCRM and Timing test. (2) Bay maint.work.	MSETCL	MSETCL	-	
17	79	220	DEOLI(PGCI)-BADNERA	03/Dec/18	09:00	03/Dec/18	17:00	Daily	PID Work	MSETCL	MSETCL	For PID work, shifting of Auto reclose switch to non-auto mode	
18	80	400	TIE BAY (411) LINE - 1 OF KORADI-2 @ KORADI 3	03/Dec/18	09:00	03/Dec/18	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTCL	MEGPTCL		
19	81	400	Tie bay (408) of Ektuni line 1 @ Tapitlinda	03/Dec/18	11:00	03/Dec/18	17:00	Daily	CB diagnostic testing	MSETCL	MSETCL	(408) Ektuni-I tie bay CB diagnostic testing	
20	83	400	SSP DHULE - 2	03/Dec/18	8:00	04/Dec/18	18:00	Continue	New relay ABB make REL 670 Retrofitting & relay testing work	SSP/getco/MH	GSECL	System ownership to be mentioned clearly.	
21	90	400	MAIN BUS - 1 @ KORADI	03/Dec/18	08:00	05/Dec/18	18:00	Daily	Online PID testing work	MSETCL	MSETCL	Online Work proposed on 400KV Main Bus-1 alongwith line bays.Online Work will be availed as per PID unit.	
22	94	400	KARAD - TALANDGE CKT 1 ON TBC @ KARAD	03/Dec/18	10:00	07/Dec/18	17:00	Continuous	Overhauling of CGI make SF6 CB Pole column	MSETCL	MSETCL	Load managed on 400KV Talandge-2 & load shifted on TBC on 03.12.2018	
23	95	400	NAGOTHANE - DABHOL 1	03/Dec/18	08:00	13/Dec/18	18:00	Daily	LE scheme for insulator string replacement & Cold washing of insulators	MSETCL	MSETCL	Load managed on Dabhol- Nagothane-II	
24	97	400	CHANDRAPUR 2 - KUMBHARGAON (NANDED) CKT - 1	03/Dec/18	08:00	15/Dec/18	17:00	Daily	For PID work	MSETCL	MSETCL	For, PID work, shifting of Auto reclose switch to non-auto mode	
25	138	400	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	04/Dec/18	08:00	04/Dec/18	17:00	Daily	Routine maintenance and diagnostic testing such as CT tandelita,CRM,IR values,isolator maintenance work and DCRM	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.	
26	139	400	CHANDRAPUR 2 - WARORA CKT-2	04/Dec/18	08:00	04/Dec/18	17:00	Daily	Tightening of earthwire & conductor	MSETCL	MSETCL	Tightening of earthwire & conductor	
27	140	400	Main bay (409) of Tirora - Warora ckt-2 @ TIRORA	04/Dec/18	09:00	04/Dec/18	18:00	Daily	Testing and maintenance of Breaker	ATIL	ATIL		
28	141	400	MAIN BAY (409) OF EKTUNI CKT-1 @ TAPITLINDA	04/Dec/18	11:00	04/Dec/18	17:00	Daily	(409) Ektuni-I CB diagnostic testing	MSETCL	MSETCL	CB Diagnostic testing work	
29	148	400	400KV Kudgi-Kolhapur-1	04/Dec/18	11:00	04/Dec/18	13:00	DAILY	Attending the Hotspot in Y-phase of WAVE trap & B-phase line jumper	SRPC	POWERGRID		
30	150	400	DHULE - SSNLI I & II on Non auto mode	05/Dec/18	08:00	06/Dec/18	17:00	Daily	Online PID testing of Insulators	MSETCL	MSETCL	400KV DHL-SSNLI Ckt-1&2 on Non Auto mode	
31	162	400	Bay No-408 Tie Bay of 400kv Boisar-Padghe Line & ICT-I at Boisar	05/Dec/18	9:00	05/Dec/18	13:00	Daily	For AMP	POWERGRID	WR-II	R	
32	187	400	CHANDRAPUR 2 - WARORA CKT-1	05/Dec/18	08:00	05/Dec/18	17:00	Daily	Tightening of conductor ,Earthwire hardware	MSETCL	MSETCL	Tightening of conductor ,Earthwire hardware	
33	188	400	AKOLA - AURANGABAD(PG) CKT - 1	05/Dec/18	09:00	05/Dec/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA	
34	189	400	MAIN BAY (409) LINE - 2 OF KORADI-2 @ KORADI 3	05/Dec/18	09:00	05/Dec/18	18:00	Daily	Annual Maintenance of Bay equipment	MEGPTCL	MEGPTCL		
35	190	400	Tie bay (411) of Ektuni line 2 @ Tapitlinda	05/Dec/18	11:00	05/Dec/18	17:00	Daily	(411) Ektuni-II tie bay CB diagnostic testing	MSETCL	MSETCL	CB diagnostic testing	
36	196	400	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	05/Dec/18	08:00	07/Dec/18	18:00	Continuous	Overhauling of OLTC and Oil Filtration work(Agency- Ajaydeep Cor. Aurangabad)	MSETCL	MSETCL	Load can be managed on 315MVA 400/220KV ICT II	
37	205	400	CHANDRAPUR-PARLI CKT-3	06/Dec/18	09:00	06/Dec/18	17:00	Daily	(1) Line maint. Work. (2) Bay maint.work.	MSETCL	MSETCL	-	Outage to be scheduled on 06.12.2018
38	213	400	400KV Talegaon Pune GIS-1 Main bay (404) at Pune-Talegaon.	06/Dec/18	9:00	06/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
39	234	400	LOWKAND 1 - CHAKAN	06/Dec/18	09:00	06/Dec/18	17:00	Daily	Half yrly maintenance & testing activities	MSETCL	MSETCL	-	
40	235	400	TIE BAY - 405 OF 765/400KV 1500MVA ICT & FUTURE BAY @ AKOLA 2	06/Dec/18	09:00	06/Dec/18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
41	236	400	TIE BAY (408) OF STN T/J- 2 & KORADI 3 CKT-1 @ KORADI 2	06/Dec/18	10:00	06/Dec/18	17:00	Daily	DCRM,IR measurement of CB 408-QS2	MSETCL	MSETCL	Station transformer-II will remain service through Main Bay 407 & Koradi-II-Koradi-III Ckt-I will remain in service through its main Bay 409	
42	237	400	KOLHAPUR - KOLHAPUR (PG) CKT - 1	06/Dec/18	10:00	06/Dec/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
43	238	400	MAIN BAY (412) OF EKTUNI CKT - 2 @ TAPITLINDA	06/Dec/18	11:00	06/Dec/18	17:00	Daily	(412) Ektuni II bay CB diagnostic testing	MSETCL	MSETCL	CB diagnostic testing work	
44	243	400	MAIN BUS - 2 @ KORADI	06/Dec/18	08:00	08/Dec/18	18:00	Daily	Online PID testing work	MSETCL	MSETCL	Online work will be availed as per PID unit.Online work will be done on main bus 2 alongwith line bays.	
45	244	400	BABHALESHWAR - PADGHE 1 ON TBC @ BABHALESHWAR	06/Dec/18	09:00	10/Dec/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 kv Babhaleshwar-Padghe ckt-1 Bay is Take on TBC for Rpearing of 29A & 29B P.G Isolator P.G Isolator Scissors (Hanger dropper assembly of Padgha 01 bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)	
46	266	400	315 MVA ICT-II at Boisar (Dia will be kept open)	07/Dec/18	9:00	07/Dec/18	17:30	Daily	For ICT AMP	POWERGRID	WR-II	R	
47	285	400	Tie Bay (405) of ICT-2 & Line-3 @ Koradi 3	07/Dec/18	09:00	07/Dec/18	18:00	Daily	Annual Maintenance of Bay Equipement	MEGPTCL	MEGPTCL		
48	286	220	CHITEGAON- CHITERNIPALGAON (PG) CKT-II	07/Dec/18	09:00	07/Dec/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	NIL	
49	287	400	MAIN BAY (409) OF KORADI 3 CKT- 1 @ KORADI 2	07/Dec/18	10:00	07/Dec/18	17:00	Daily	DCRM,IR measurement of CB 409-QS2	MSETCL	MSETCL	Koradi-II-Koradi-III Ckt-I will remain in service through its Tie Bay 408	
50	288	400	KOLHAPUR - KOLHAPUR (PG) CKT - 2	07/Dec/18	10:00	07/Dec/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	-	
51	299	220	BOISAR II - TARAPUR	08/Dec/18	08:00	08/Dec/18	17:00	Daily	Post monsoon maintenance of the line	MSETCL	MSETCL	-	
52	304	400	400KV Pune GIS # 1 & ICT # 1 Tie bay (405) at Pune-Talegaon	08/Dec/18	9:00	08/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
53	311	220	EKALAHARA(OCR)-NAVASARI II	08/Dec/18	09:00	08/Dec/18	14:00	Daily	maint. work	MSETCL	MSETCL	-	
54	312	400	TIE BAY (408) OF WARORA CKT - 2 @ TIRORA	08/Dec/18	09:00	08/Dec/18	18:00	Daily	Testing and maintenance of Breaker	ATIL	ATIL		
55	314	400	PARLI - KUMBHARGAON(NANDED) CKT - 2	08/Dec/18	10:00	08/Dec/18	18:00	Daily	DCRM measurement	MSETCL	MSETCL	-	
56	315	400	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	08/Dec/18	08:00	10/Dec/18	18:00	Continuous	Overhauling of OLTC and Oil Filtration work (Agency-Ajaydeep Cor. Aurangabad)	MSETCL	MSETCL	Load can be managed on 315MVA 400/220KV ICT I	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
57	316	220	BOISAR II - PGCL 1	09/Dec/18	07:00	09/Dec/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
58	328	400	PADGHE - KALWA 2	09/Dec/18	08:00	09/Dec/18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work	
59	332	400	400 KV Bus-1 at Wardha	10/Dec/18	9:00	10/Dec/18	18:00	Daily	Alignment of newly erected bus isolator	WRTS-I	WRTS-I	R	
60	350	400	400KV Talegaon Pune GIS-3 Main bay (409) at Pune-Talegaon.	10/Dec/18	9:00	10/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
61	373	400	KORADI 2 - KORADI 3 CKT-2	10/Dec/18	10:00	10/Dec/18	17:00	Daily	Tan delta measurement of Line CT at Bay 406 & CT at Bay 405	MSETCL	MSETCL	400KV Koradi-II-Koradi-III Ckt-1 will remain in service as alternate supply.	
62	376	400	DHULE - SSNNL I & II on Non auto mode	10/Dec/18	08:00	11/Dec/18	17:00	Daily	PID testing of insulators	MSETCL	MSETCL	400KV DHL-SSNNL Ckt-1&2 on Non Auto mode	
63	379	220	DEOLI(PGCL)-BADNERA	10/Dec/18	09:00	15/Dec/18	17:00	Daily	PID work	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non-auto mode	
64	380	765	765KV AURANGABAD(PG)-PADGHE(GIS) 1	10/Dec/18	10:00	16/Dec/18	18:00	Conti?	for attending SF6 gas leakage in chamber of R-PH line & Ckt-2 A/R in Non-auto mode required during this period.	WRTS-I	WRTS-I	R	
65	381	400	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	10/Dec/18	09:00	20/Dec/18	0:00	Continuous	Replacement of ICT 3 B phase unit with repaired job	MSETCL	MSETCL	Subject to total ICT loading	
66	384	400	PADGHE - KALWA 1	11/Dec/18	09:00	20/Dec/18	18:00	Daily	PID Testing work of 400 KV Kalwa-Padgha Ckt-1 line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	To be deleted as Kalwa-Padghe Ckt-2 approved on same date	After completion of outage on Kalwa - Padgha ckt -2
67	385	400	400KV Kalwa Main bay (416) at Pune-Talegaon	11/Dec/18	9:00	11/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
68	390	400	MAIN BAY (406) OF LINE- 3 @ KORADI 3	11/Dec/18	09:00	11/Dec/18	18:00	Daily	Annual Maintenance of Bay equipment	MEGPTCL	MEGPTCL		
69	409	400	400KV WARORA-PARLI-I	11/Dec/18	9:00	11/Dec/18	18:00	Daily	AMP of Transmission line & Other ckt A/R in Non-auto mode required.	WRTS-I	WRTS-I	R	
70	410	400	400KV Warora-1 Main Bay (401) at Parli	11/Dec/18	9:00	11/Dec/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	
71	421	400	400 KV KOLHAPUR MSETCL - SOLAPUR-II	11/Dec/18	10:00	11/Dec/18	18:00	Daily	For Bay AMP works, Line outage required for bays and Line side equipment AMP works at Kolhapur (MSETCL) end.	WTPCL	WRTS-I	To be clarified by Utility which line, also owners of the asset changed to Adani to be written clearly not reliance	is outage required on alkud LULO line or direct line?
72	428	400	CHANDRAPUR-PARLI CKT-3	11/Dec/18	07:00	11/Dec/18	19:00	Daily	Replacement of damaged earthwire cross arms	MSETCL	MSETCL	Replacement of damaged earthwire cross arms	
73	429	400	MAIN BAY (412) OF NANDED CKT-2 @ CHANDRAPUR - 2	11/Dec/18	08:00	11/Dec/18	17:00	Daily	replacement of damaged earthwire cross arm	MSETCL	MSETCL	replacement of damaged earthwire cross arm	
74	430	400	BUS COUPLER @ DHULE	11/Dec/18	08:00	11/Dec/18	18:00	Daily	For routine testing & maint work	MSETCL	MSETCL	For routine testing & maint work	
75	431	400	MAIN BUS - 1 @ WARORA	11/Dec/18	08:00	11/Dec/18	18:00	Daily	Routine maintenance and diagnostic testing such as CVT/ CT tan delta, and isolator maintenance work	MSETCL	MSETCL	400KV MAIN BUS-2 WILL BE IN SERVICE	
76	432	400	MAIN BAY (413) OF PARALI CKT - 1 @ LONIKAND 2	11/Dec/18	09:00	11/Dec/18	17:00	Daily	Testing work	MSETCL	MSETCL	Line will be in service through Tie - bay 412	
77	433	400	MAIN BAY - 406 OF FUTURE BAY @ AKOLA 2	11/Dec/18	09:00	11/Dec/18	18:00	Daily	Testing and Maintenance of Bay equipments	MEGPTCL	MEGPTCL		
78	441	400	BABHALESHWAR - PADGHE 2 ON TBC @ BABHALESHWAR	11/Dec/18	09:00	16/Dec/18	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of Isolators work	MSETCL	MSETCL	400 KV Babhaleshwar-Padghe ckt-2 Bay is Take on TBC for Rpearing of 29A & 29B P.G Isolator P.G Isolator Scissors (Hanger dropper assembly of Padghe 2 bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)	
79	442	400	PADGHE - KALWA 2	11/Dec/18	09:00	20/Dec/18	18:00	Daily	PID Testing work of 400 KV Kalwa-Padgha Ckt-2 line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	Line will remain in service	
80	446	400	400KV ICT-3 & Kalwa Tie bay (417) at Pune-Talegaon	12/Dec/18	9:00	12/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
81	471	400	400KV WARORA-PARLI-II	12/Dec/18	9:00	12/Dec/18	18:00	Daily	AMP of Transmission line & Other ckt A/R in Non-auto mode required.	WRTS-I	WRTS-I	R	
82	472	400	400KV Warora-2 Main Bay (404) at Parli	12/Dec/18	9:00	12/Dec/18	18:00	Daily	For AMP works at Parli	WRTS-I	WRTS-I	R	
83	491	400	TIE BAY (429) OF WARORA CKT-1 @ CHANDRAPUR 2	12/Dec/18	09:00	12/Dec/18	18:00	Daily	Routine Maintenance & Diagnostic testing Work	MSETCL	MSETCL	Routine Maintenance & Diagnostic testing Work	
84	492	400	MAIN BAY (401) OF ICT - 1 @ KORADI 3	12/Dec/18	09:00	12/Dec/18	18:00	Daily	Annual Maintenance of Bay equipment	MEGPTCL	MEGPTCL		
85	493	220	SOUTH SOLAPUR (KUMBHARI)-PGCL 2	12/Dec/18	11:00	12/Dec/18	15:00	Daily	QM work	MSETCL	MSETCL	Outage is required for QM work & diagnostic testing work.	
86	494	220	KALMESHWAR-PANDHURNA	12/Dec/18	08:00	13/Dec/18	18:00	Daily	Restraining of bottom ph conductor and Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
87	499	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_2	13/Dec/18	9:00	13/Dec/18	11:00	Daily	CVT oil Top Up	WRTS-I	WRTS-I	R	400KV Kalwa - Padgha D/C should be in service.
88	521	400	400kv Boisar-Padghe at Boisar	13/Dec/18	9:00	13/Dec/18	17:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WR-II	R	
89	531	400	400KV WARDHA-WARORA-2_LILOPOINT_PG	13/Dec/18	9:00	13/Dec/18	18:00	Daily	Replacement of B phase CVT	WRTS-I	WRTS-I	R	
90	541	400	CHANDRAPUR 2 - WARORA CKT-2	13/Dec/18	08:00	13/Dec/18	18:00	Daily	Routine maintenance and diagnostic testing such as CT tan delta, CRM, IR values, isolator maintenance work and DCRM	MSETCL	MSETCL	Load will be managed on 400KV chandrapur Ckt-1 bay no 413	
91	542	400	MAIN BAY (406) OF WARORA CKT - 1 @ TIRODA	13/Dec/18	09:00	13/Dec/18	18:00	Daily	Testing and maintenance of breaker	ATIL	ATIL		
92	552	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_4	14/Dec/18	9:00	14/Dec/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments & Other ckt A/R in Non-auto mode required.	WRTS-I	WRTS-I	R	400KV Kalwa - Padgha D/C should be in service.
93	594	400	MAIN BUS - 1 @ WALLU	14/Dec/18	08:00	14/Dec/18	17:00	Daily	Routine Maintenance & Testing	MSETCL	MSETCL	NIL	
94	595	400	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	14/Dec/18	09:00	14/Dec/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	400KV KORADI-WARDHA. Line will be charged through Tie CB 414.	
95	604	400	PARLI - LONIKAND 2 CKT 2	15/Dec/18	09:00	15/Dec/18	17:00	Daily	(1) Distance relay testing work. (2) Line maint. Work. (3) Bay maint. work.	MSETCL	MSETCL	-	
96	615	400	AKOLA - WARDHA(PG) CKT - 2	15/Dec/18	09:00	15/Dec/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA	
97	616	400	MAIN BUS - 2 @ KORADI-3	15/Dec/18	09:00	15/Dec/18	18:00	Daily	Testing & Maintenance of Bus connected Isolator & CVT	MEGPTCL	MEGPTCL		
98	630	400	400kv Boisar-Padghe at Boisar	15/Dec/18	14:00	15/Dec/18	18:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	POWERGRID	WR-II	R	
99	636	400	400KV Talegaon Lonikand Line at Pune-Talegaon	16/Dec/18	9:00	16/Dec/18	17:00	Daily	For line Isolator Alignment & AMP of Line Equipments	WRTS-I	WRTS-I	R	
100	640	400	SSP DHULE - 1	16/Dec/18	8:00	17/Dec/18	18:00	Daily	relay testing work	SSP	GSECL		
101	645	220	220KV Talegaon MSETCL Line # 2 at Pune-Talegaon	16/Dec/18	9:00	16/Dec/18	17:00	Daily	AMP of Line Equipments	WRTS-I	WRTS-I	R	Please schedule outage on 16.12.2018 (on Sunday)
102	646	400	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	16/Dec/18	09:00	16/Dec/18	18:00	Daily	Testing & Maintenance of Bay equipments	MEGPTCL	MEGPTCL		
103	650	220	BOISAR II - PGCL 2	16/Dec/18	08:00	16/Dec/18	17:00	Daily	Post monsoon maintenance of the line	MSETCL	MSETCL	-	
104	651	400	BABHALESHWAR - PADGHE 2	16/Dec/18	08:00	20/Dec/18	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	A/R require to take out of service	
105	652	400	NEW KOYNA - DABHOL - II	16/Dec/18	08:00	25/Dec/18	18:00	Daily	LE scheme for insulator string replacement & cold washing of insulators	MSETCL	MSETCL	Load managed on Dabhol-New Koyna -I line	
106	654	400	BUS COUPLER @ KHARGHAR	16/Dec/18	08:00	16/Dec/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	NIL	Outage to be scheduled on 16.12.2018 (on Sunday)
107	655	400 KV	400KV Talegaon - Lonikand	16/Dec/18	10:00	16/Dec/18	12:00	Daily	Major maintenance activities in transmission line	WTPCL	WTPCL	R	
108	659	400	KHARGHAR - TALEGAON (PG)	17/Dec/18	08:00	17/Dec/18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	nil	
109	679	220	220 KV Pused Bay 202 at Wardha	17/Dec/18	9:00	17/Dec/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	
110	690	400	MAIN BAY - 406 OF 765/400KV ICT-2 @ EKTUNI	17/Dec/18	10:00	17/Dec/18	18:00	Daily	Routine Maintain & Diagnostic Testing	MSETCL	MSETCL	ICT will be in service through 400KV TIE-II (405) Bay & Main Bus-I	
111	691	400	MAIN BUS - 1 @ KORADI - 2	17/Dec/18	11:00	17/Dec/18	14:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to Main Bus-II	
112	694	400	DHULE - BABHLESHWAR - I & II on Non auto mode	17/Dec/18	08:00	18/Dec/18	17:00	Daily	PID testing of insulators	MSETCL	MSETCL	400KV DHL-BBLR Ckt-1&2 on Non-Auto mode	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
113	697	400	MAIN BUS - 1 @ TALANDGE	17/Dec/18	09:00	20/Dec/18	23:55	Continuous	Replacement of Isolator of 400KV Karad 1 A Bus PG Isolator and 400KV Alkud line Bus Hanger	MSETCL	MSETCL	-	
114	698	400	BABLESHWAR- AURANGABAD (WALLU) ON TBC @ BABHALESHWAR	17/Dec/18	09:00	23/Dec/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400KV P.G Isolator and Servicing and alignment of Isolators work	MSETCL	MSETCL	400 kv Babhaleshwar-Aurangabad Bay is Take on TBC for Rpearing of 29A & 29B P.G Isolator P.G Isolator Scissors (Hanger dropper assembly of Aurangabad bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)	
115	700	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	17/Dec/18	08:00	31/Dec/18	17:00	Daily	For PID Work	MSETCL	MSETCL	For PID Work, shifting of auto reclose in non-auto mode. And Chadrapur-II-Nanded-II cke and Chandrapur-II-Parali ckt-III these both lines are on same tower hence both lines require on same day A/R out	
116	701	400	400KV CHANDRAPUR 1-PARALI 3 (CHPR 1 IEND))	17/Dec/18	08:00	31/Dec/18	17:00	Daily	PID work	MSETCL	MSETCL	For PID Work, shifting of auto reclose in non-auto mode. And Chadrapur-II-Nanded-II ckt and Chandrapur-II-Parali ckt-III these both lines are on same tower hence both lines require on same day A/R out	
117	721	400	400KV Lonikand & BR Tie bay (414) at Pune-Talegaon	18/Dec/18	9:00	18/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
118	728	400	400KV PARLI-PUNE(GIS)_2	18/Dec/18	9:00	18/Dec/18	18:00	Daily	AMP of Bay and Line Reactor	WRTS-I	WRTS-I	R	
119	731	400	400 KV Warora-2 Tie bay 408 at Wardha	18/Dec/18	9:00	18/Dec/18	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	
120	739	132	DHARANI - NEPANAGAR	18/Dec/18	10:00	18/Dec/18	17:00	Daily	For jumper tightening work at loc. no.63&64 and line signature Analysis test	MSETCL	MSETCL	For jumper tightening work at loc. no.63&64 and line signature Analysis test	
121	740	765	TIE BAY - 712 OF 765/400KV ICT-2 AND BUS RECTOR @ EKTUNI	18/Dec/18	10:00	18/Dec/18	18:00	Daily	Routine Maintain & Diagnostic Testing	MSETCL	MSETCL	240Mvar Bus Reactor will be in service though MAIN (711) Bay & MAIN Bus -I	
122	741	400	MAIN BUS - 2 @ KORADI 2	18/Dec/18	11:00	18/Dec/18	14:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to Main Bus-I	
123	742	220	0-51700 Line-1 (TAPS-3&4 - TAPS-1&2 tie line)	19/Dec/18	9:00	19/Dec/18	18:00	Continuous	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	NPCL	NPCL		
124	753	400	WARORA - Wardha(PG)	19/Dec/18	09:00	19/Dec/18	17:00	Daily	Routine Maintenance & Dgnostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400KV WARORA-IEPL Line is in ckt	
125	761	400	400KV Chakan& Kharghar Tie bay (402) at Pune-Talegaon	19/Dec/18	9:00	19/Dec/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
126	777	400	MAIN BUS - 2 @ LAMBOTI	19/Dec/18	13:00	19/Dec/18	15:00	Daily	Bus Bar Testing	MSETCL	MSETCL	Load will be managed on Main Bus - I	Time to be change i.e.from 13:00 - 15:00hrs
127	778	400	TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	19/Dec/18	09:00	19/Dec/18	18:00	Daily	Routine maintenance & daignostice testing work	MSETCL	MSETCL	Routine maintenance & diagnostic testing work	
128	779	400	MAIN BUS - 1 @ LAMBOTI	19/Dec/18	10:00	19/Dec/18	12:00	Daily	Bus Bar Testing	MSETCL	MSETCL	Load will be managed on Main Bus - 2	
129	780	765	Main bay 711 of 765 kv Bus Reactor @ Ektuni	19/Dec/18	10:00	19/Dec/18	18:00	Daily	Routine Maintain & Diagnostic Testing	MSETCL	MSETCL	240Mvar Bus Reactor will be in service though TIE (712) Bay & Main Bus-II	
130	781	400	MAIN BAY (406) OF KORADI 3 CKT - 2 @ KORADI 2	19/Dec/18	10:00	19/Dec/18	18:00	Daily	1) DCRM, CRM & Timing IR of CB 406-QS2 2)Tan delta Measurement of Bus CT of Bay 406	MSETCL	MSETCL	Koradi-2-Koradi-3 Ckt-II line will remain service through tie bay 405	
131	782	400	MAIN BAY (414) OF TIRODA CKT - 2 @ WARORA	19/Dec/18	10:00	19/Dec/18	18:00	Daily	Testing and maintenance of Bay Equipment	ATIL	ATIL		
132	811	220	220KV Shendra-2 Main Bay-208 at Aurangabad	20/Dec/18	9:00	20/Dec/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
133	816	220	220KV_Solapur-Kumbhari-1_Line_206 at Solapur	20/Dec/18	9:00	20/Dec/18	18:00	Daily	For AMP Works.	MSETCL	WRTS-I	R	
134	820	400	MAIN BUS - 1 @ DEEPNAGAR	20/Dec/18	08:00	20/Dec/18	18:00	Daily	Bus Bar relay Testing and Bus CVT diagnostic testing	MSETCL	MSETCL	Testing work	
135	821	400	PARLI - KUMBHARGAON(NANDED) CKT - 2	20/Dec/18	09:00	20/Dec/18	17:00	Daily	(1) Distance relay testing work. (2) Bay manit. Work. (3) String replacement work at Loc. 878.	MSETCL	MSETCL	-	
136	822	220	PUSAD - WARDHA (PG)	20/Dec/18	09:00	20/Dec/18	17:00	Daily	For routine maintenance work	MSETCL	MSETCL	For routine maintenance work	
137	833	400	KORADI 2-WARDHA PGCL	21/Dec/18	09:00	21/Dec/18	17:00	Daily	Routine Maintenance & Dgnostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400KV WARORA-IEPL Line is in ckt	
138	845	220	220KV Pandhurna-Kamleshwar	21/Dec/18	9:00	21/Dec/18	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R	
139	846	220	220KV Shendra-2 Main Bay-209 at Aurangabad	21/Dec/18	9:00	21/Dec/18	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R	
140	852	220	220KV_Solapur-Kumbhari-2_Line_207 at Solapur	21/Dec/18	9:00	21/Dec/18	18:00	Daily	For AMP Works.	MSETCL	WRTS-I	R	
141	858	220	NALASOPARA - BOISAR PG	21/Dec/18	08:00	21/Dec/18	17:00	Daily	Post monsoon maintenance of the line	MSETCL	MSETCL	Outage required on PGCL- NALASOPARA(VASAI)	
142	859	400	BABHALESHWAR - PADGHE 1	21/Dec/18	08:00	21/Dec/18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work	
143	861	220	PUSAD - WARDHA (PG)	21/Dec/18	09:00	31/Dec/18	17:00	Daily	PID Work	MSETCL	MSETCL	For PID Work, shifting of auto reclose switch to non auto mode	
144	862	400	KHARGHAR - TALEGAON (PG) & KALWA - TALEGAON (PGCL)	21/Dec/18	09:00	31/Dec/18	18:00	Daily	PID Testing work of 400 KV Kalwa-Talegaon & 400KV Kharghar-Talegaon (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	Line will remain in service	
145	865	220	B BUS @ BOISAR 1 (NOC required for TBC operations from Tarapur & PGCL)	22/Dec/18	07:00	23/Dec/18	19:00	Continuous	Annual Maintenance of 220KV B Bus Isolators and Bus hot spot attending works.	MSETCL	MSETCL	NOC required for TBC operations from Tarapur & PGCL NOC for outage will be required from Adani group. Bus will be separated 1 to work in Minimum time on 400KV Bus coupler Outage, outage taken on 400KV Aurganabad on TBC is taken at same time so that After Repairing P.G Isolator Utilized for 400KV Bus couper (Hanger dropper assembly of 400KV Bus coupler Bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)	Outage to be scheduled on 22.12.2018 - 23.12.2018
146	871	400	BUS COUPLER @ BABHALESHWAR	22/Dec/18	09:00	23/Dec/18	17:00	Continuous	Quarterly Maintenance work & Reapir scissors of 400KV P.G Isolator and Servicing and alignment of Isolators work	MSETCL	MSETCL		Outage to be scheduled on 22.12.2018 - 23.12.2018
147	884	220	BORIVALI - TARAPUR	22/Dec/18	08:00	22/Dec/18	17:00	Daily	post monsoon maintenance of the line	MSETCL	MSETCL		
148	888	400	400KV Talegaon Chakan Line at Talegaon Substation	23/Dec/18	9:00	23/Dec/18	17:00	Daily	AMP of Line Equipments	WRTS-I	WRTS-I	R	Outage to be scheduled on 23.12.2018 (on Sunday)
149	892	400	ICT1_400/220kv_WARDHA	23/Dec/18	9:00	23/Dec/18	18:00	Daily	AMP work at Wardha end & installation of backup imedence relay	WRTS-I	WRTS-I	R	
150	894	400 KV	400 KV Talegaon - Chakan	23/Dec/18	10:00	23/Dec/18	12:00	Daily	Major maintenance activities in transmission line	WTPCL	WTPCL	Outage to be scheduled on 23.12.2018 (on Sunday)	
151	899	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR) @ LONIKAND 2	24/Dec/18	09:00	24/Dec/18	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400 KV Lonikand-II- Lonikand-I Interconnector I, load affected NIL	
152	901	400	PADGHE - KALWA 1	24/Dec/18	08:00	24/Dec/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	-	
153	902	400	MAIN BUS - 1 @ TIRODA	24/Dec/18	08:00	24/Dec/18	21:00	Daily	Testing & Maintenance of Bus Connected Isolator & CVT	APML	APML		
154	909	400	Bay No-414 Tie Bay of 400kv Tarapur-Boisar-I Line & ICT-II at Boisar	24/Dec/18	9:00	24/Dec/18	17:30	Daily	For Bay AMP	POWERGRID	WR-II	R	
155	924	220	TALANDAGE - CHIKODI	24/Dec/18	08:00	24/Dec/18	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-	
156	925	400	DHULE - BABLESHWAR - I & II	24/Dec/18	08:00	24/Dec/18	17:00	Daily	PID testing of insulators	MSETCL	MSETCL	400KV DHL-BBLR Ckt-1&2 on Non-Auto mode	
157	932	400	BABHALESHWAR - PADGHE 1	25/Dec/18	09:00	25/Dec/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400KV Babhaleshwar-Padghe-Ckt-2 will be in service	
158	933	765	712 LR (AKOLA CKT - 2) REACTOR @ KORADI 3	25/Dec/18	09:00	25/Dec/18	18:00	Daily	Annual Maintenance of Reactor & related equipments	MEGPTCL	MEGPTCL		
159	939	400 KV	400 kv D/C Parli - Pune (GIS)	25/Dec/18	6:00	26/Dec/18	20:00	Daily	Power line crossing of 400 KV D/C Parli - Pune at tower loc. no. 658 & 659 by 765 KV D/C ULCO Aurangabad - Padghe Line	WRTMPL	CWRTL	Maharashtra consent required. Shall be planned in coordination with SLDC Maharashtra	
160	952	220	Navsari-Nashik line no.1	26/Dec/18	9:00	26/Dec/18	18:00	Daily	General bay maint.	GETCO	GETCO	Inter state line, Requested by GETCO.	
161	959	220	220KV Bus-2 at Solapur	26/Dec/18	9:00	26/Dec/18	18:00	Daily	AMP WORKS	WRTS-I	WRTS-I	R	
162	960	400	400KV BHLAI-KORADI	26/Dec/18	9:00	26/Dec/18	18:00	Daily	along with Bays for AMP work at Koradi end	WRTS-I	WRTS-I	R	
163	970	400	400KV Aurangabad-Boisar # 1	26/Dec/18	17:00	26/Dec/18	17:30	Daily	To charge Line without L/R at Boisar end.	POWERGRID	WR-II	R	
164	971	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	26/Dec/18	08:00	26/Dec/18	17:00	Daily	Polymer Insulator string Replacement	MSETCL	MSETCL	Polymer Insulator string Replacement	
165	972	400	BUS - 1 @ AKOLA 2	26/Dec/18	09:00	26/Dec/18	18:00	Daily	Bus Bar Equipments Maintenance Activity	MEGPTCL	MEGPTCL		
166	973	220	JEUR - SOLAPUR PG	26/Dec/18	10:00	26/Dec/18	16:00	Daily	Quarterly maintenance work & diagnostic testing work	MSETCL	MSETCL	Outage is required for OM work & diagnostic testing work	
167	974	400	MAIN BAY (406) OF PGCL @ LAMBOTI	26/Dec/18	10:00	26/Dec/18	18:00	Continuous	Diagnostic Testing Work	MSETCL	MSETCL	Load will be managed on 400KV Lamboti- Parali Line	

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
168	977	400	400kV AKOLA-2 LR at Aurangabad	26/Dec/18	9:00	27/Dec/18	18:00	Daily	For Neutral Bushing replacement works, Line outage required for 15 min for Take out/take in non switchable line reactor at A'bad end.	WRTS-I	WRTS-I	R	
169	994	220	Navsari-Nashik line no.2	27/Dec/18	9:00	27/Dec/18	18:00	Daily	General bay maint.	GETCO	GETCO	Inter state line, Requested by GETCO.	
170	999	400	400KV KORADI-SATPURA	27/Dec/18	9:00	27/Dec/18	18:00	Daily	Replacement of B Phase Wave trap at koradi end	WRTS-I	WRTS-I	R	
171	1005	400	CHANDRAPUR 2 - KUMBHARGAON (NANDED) CKT - 1	27/Dec/18	08:00	27/Dec/18	17:00	Daily	For Polymer Insulator string replacement	MSETCL	MSETCL	For Polymer Insulator string replacement	
172	1006	765	765/400KV 1500MVA ICT-1 @ KORADI 3	27/Dec/18	08:00	27/Dec/18	18:00	Daily	Annual Maintenance of ICT and related equipments	MEGPTCL	MEGPTCL		
173	1007	400	B BUS @ NAGOTHANE	27/Dec/18	08:00	27/Dec/18	18:00	Daily	various bay pg isolator overhauling	MSETCL	MSETCL	NIL	
174	1008	400	MAIN BUS - 2 @ DEEPNAGAR	27/Dec/18	08:00	27/Dec/18	18:00	Daily	Bus Bar relay Testing and Bus CVT diagnostic testing	MSETCL	MSETCL	Testing work	
175	1009	400	TBC @ CHAKAN	27/Dec/18	09:00	27/Dec/18	18:00	Daily	Half yrly maintenance & testing activities	MSETCL	MSETCL	-	
176	1010	400	TIE BAY (405) OF WARORA CKT - 1 & STN TF - 1 @ TIRORA	27/Dec/18	09:00	27/Dec/18	18:00	Daily	Testing and maintenance of breaker	ATIL	ATIL		
177	1011	400	KOLHAPUR - SOLAPUR (PG) CKT - 2	27/Dec/18	10:00	27/Dec/18	18:00	Daily	Routine Maintenance work	ADANI	MSETCL	System ownership to be written clearly, this element belongs to Adani, And outage shall be proposed by Adani,	
178	1013	400	SSNL-Dhule-1	28/Dec/18	8:00	28/Dec/18	18:00	Daily	Maintenance work	NCA	GETCO	Auto reclose of SSP- Dhule - 2 will remain out.	
179	1016	400	BABHALESHWAR - PADGHE 2	28/Dec/18	09:00	28/Dec/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400kv Babhaleshwar-Padghe-Ckt-1 will be in service	
180	1038	400	DHULE - SSNNL I alongwith A/R switch of SSNNL-2 to be kept on non-auto mode	28/Dec/18	08:00	28/Dec/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
181	1039	400	BUS - 2 @ AKOLA 2	28/Dec/18	09:00	28/Dec/18	18:00	Daily	Bus Bar Equipments Maintenance Activity	MEGPTCL	MEGPTCL		
182	1040	400	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	28/Dec/18	10:00	28/Dec/18	18:00	Daily	DCRM measurement	MSETCL	MSETCL	-	
183	1043	400	SSNL-Dhule-2	29/Dec/18	8:00	29/Dec/18	18:00	Daily	Maintenance work	NCA	GETCO	Auto reclose of SSP- Dhule No. 1 will remain out	
184	1045	400	LUNIKANDU2-LUNIKANDU1 (INTERCONNECTING) - 1 @ LUNIKANDU 1	29/Dec/18	10:00	29/Dec/18	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-	
185	1058	400	DHULE - SSNNL II alongwith A/R switch of SSNNL-1 to be kept on non-auto mode	29/Dec/18	08:00	29/Dec/18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL		
186	1059	400	EKTUNI - BABLESHWAR CKT 2	29/Dec/18	09:00	29/Dec/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-1 will be in service	
187	1063	400 kV	400 kV Talegaon - Kharghar	30/Dec/18	15:00	30/Dec/18	17:00	Daily	Major maintenance activities in transmission line	WTPL	WTPL	Please schedule outage on 30.12.2018 (on Sunday) from 15:00 - 17:00hrs after completion of Kalwa - Talegaon(PG) outage	
188	1066	400 kV	400 kV Talegaon - Kalwa	30/Dec/18	10:00	30/Dec/18	12:00	Daily	Major maintenance activities in transmission line	WTPL	WTPL	R	
189	1067	220	BOISAR II - PGCIL 3	30/Dec/18	08:00	30/Dec/18	17:00	Daily	Post monsoon maintenance of the line	MSETCL	MSETCL	-	
190	1068	400	KALWA - TALEGAON (PGCIL)	30/Dec/18	08:00	30/Dec/18	15:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Please schedule time from 08:00 - 15:00hrs	
191	1076	400	A BUS @ NAGOTHANE	31/Dec/18	08:00	31/Dec/18	18:00	Daily	various bay pg isolator overhauling	MSETCL	MSETCL	NIL	

State Element Outages list for the month of December'18											
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400	400/220/20 KV 500MVA ICT - 1 @ KALWA	02-Dec-18	09:30	02-Dec-18	17:30	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	-
2	400	KORADI-KHADKA	03-Dec-18	08:00	03-Dec-18	18:00	Daily	Reactor bushing and winding C& tan delta test.	MSETCL	MSETCL	Routine testing
3	400	DEEPNAGAR AURANGABAD	03-Dec-18	06:00	08-Dec-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Maint work
4	400	KARAD - TALANDGE CKT 1	03-Dec-18	10:00	03-Dec-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
5	400	400/220/33 KV 315 MVA ICT - 1 @ DHULE	04-Dec-18	08:00	04-Dec-18	18:00	Daily	For routine testing & maint work	MSETCL	MSETCL	For routine testing & maint work
6	400	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	04-Dec-18	08:00	04-Dec-18	18:00	Daily	Maintenance work	MSETCL	MSETCL	Maintenance work
7	400	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	04-Dec-18	10:00	04-Dec-18	17:00	Daily	Tan delta measurement of Line CT at Bay 430 and CT at Bay 205	MSETCL	MSETCL	ICT-II will remain in service
8	400	BABLESHWAR- AURANGABAD (WALUJ)	04-Dec-18	09:00	05-Dec-18	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Alternate supply available
9	400	400/220 KV 500 MVA ICT @ ALKUD	04-Dec-18	09:30	04-Dec-18	17:30	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
10	400	400kv Stn. TF No 4 @ C'pur GCR	04-Dec-18	08:00	04-Dec-18	18:00	Daily	measurements of DCRM Timing & CRM breaker & maintenance & alignments work of PG-I & PG-II Isolators	MSETCL	MSETCL	measurements of DCRM Timing & The work will be carried out by shifting this bay on 400KV TBC-II bay
11	400	KHADKA - BABLESHWAR	04-Dec-18	07:00	05-Dec-18	17:00	Daily	PID Testing	MSETCL	MSETCL	Non Autoreclose only
12	400	MAIN BAY (414) OF KORADI CKT - 2 @ KHAPARKHEDA 2	05-Dec-18	09:00	05-Dec-18	13:00	Daily	Breaker DCRM & Timings	MSETCL	MSETCL	All work will be performed by MSETCL
13	400	125MVar BUS REACTOR @ WARORA	05-Dec-18	08:00	05-Dec-18	18:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	During outage reactor is in off condition
14	400	400kv Stn. TF No 5 @ C'pur GCR	05-Dec-18	08:00	05-Dec-18	18:00	Daily	measurements of DCRM of breaker 2. Miantenncae & alignments work of PG-I & PG-II Isolators	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay
15	400	TIE BAY (415) OF KORADI CKT - 2 & STN TF 5A @ KHAPERKHEDA	05-Dec-18	13:00	05-Dec-18	17:00	Daily	Breaker DCRM & Timings	MSETCL	MSETCL	All the work will be done by MSETCL
16	400	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	05-Dec-18	10:00	05-Dec-18	18:00	Daily	Diagnoistic Testing Work	MSETCL	MSETCL	Load will be managed on ICT-II subject to 220KV Osmanabad and Tulapur is in Grid.
17	400	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	05-Dec-18	08:00	05-Dec-18	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	NIL
18	400	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	06-Dec-18	08:00	06-Dec-18	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	NIL
19	400	400kv Stn. TF No 3 @ C'pur GCR	06-Dec-18	08:00	06-Dec-18	18:00	Daily	Measuremnts of DCRM of breaker 2.Maintenance & alignments work of PG-I & PG-II Isolators	MSETCL	MSETCL	the work will be carried out by shifting this bay on 400KV TBC-II bay
20	400	MAIN BAY (401) OF ICT -1 @ JEIURI	06-Dec-18	09:00	06-Dec-18	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
21	400	MAIN BAY (401) OF 167 MVA SPARE ICT @ WARORA	06-Dec-18	08:00	06-Dec-18	17:00	Daily	Routine Spare ICT unit diagnostic and maint. and ,isolater maintainance work.	MSETCL	MSETCL	Spare ICT is on No Load
22	400	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	06-Dec-18	10:00	06-Dec-18	17:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
23	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	06-Dec-18	12:00	08-Dec-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola- Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service.
24	400	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	07-Dec-18	08:00	07-Dec-18	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	NIL
25	400	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	07-Dec-18	08:00	07-Dec-18	17:00	Daily	Routine maintainance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM	MSETCL	MSETCL	400KV PGCIIL Line will be charged through Tie CB 421.
26	400	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	07-Dec-18	08:00	07-Dec-18	17:00	Daily	Routine maintenance & Testing	MSETCL	MSETCL	Nil
27	400	400/220 KV 3X200 MVA ICT - 2 @ KALWA	09-Dec-18	09:30	09-Dec-18	17:30	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	-
28	400	LONIKAND 1 - KOYNA STAGE-IV	10-Dec-18	09:00	12-Dec-18	18:00	Daily	Cold line cleaning of insulators	MSETCL	MSETCL	Koyna Satge 4-Jejuri ckt will be in service
29	400	PADGHE - NAGOTHANE 1	10-Dec-18	08:00	10-Dec-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
30	400	DEEPNAGAR AURANGABAD	10-Dec-18	06:00	12-Dec-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Maint work
31	400	400/220 KV 315MVA ICT - 1 @ KARAD	10-Dec-18	08:00	10-Dec-18	17:00	Daily	Application of RTV Silicon coating of 33 KV insulator portion of tertiary delta connection & 52 KV Tertiary & neutral bushing	MSETCL	MSETCL	Load manage on other Two ICT'S
32	400	400/132 KV 200 MVA ICT - 1 @ KHADKA	10-Dec-18	08:00	10-Dec-18	18:00	Daily	CB DCRM Test	MSETCL	MSETCL	Load 'will be shifted on TBC, ICT will remain in service.
33	400	400/220/33 KV 315MVA ICT - 1 @ AKOLA	10-Dec-18	09:00	10-Dec-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
34	400	PADGHE - NAGOTHANE 1	11-Dec-18	08:00	11-Dec-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
35	400	400/220 KV 315MVA ICT - 2 @ KARAD	11-Dec-18	08:00	11-Dec-18	17:00	Daily	Application of RTV Silicon coating of 33 KV insulator portion of tertiary delta connection & 52 KV Tertiary & neutral bushing	MSETCL	MSETCL	Load manage on other Two ICT'S
36	400	DEEPNAGAR AURANGABAD	11-Dec-18	09:00	12-Dec-18	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Nil
37	400	KHADKA - BABLESHWAR	11-Dec-18	07:00	13-Dec-18	17:00	Daily	PID Testing of insulators	MSETCL	MSETCL	Non Auto re-close mode only
38	400	JAIGAD-KARAD-I	12-Dec-18	07:00	12-Dec-18	13:00	Daily	Quarterly. Maint. Work & Repairing of Earth blade by adding counterweight	MSETCL	JPTL	Load manage on 400 kV JAIGAD -2
39	400	MAIN BAY (405) OF 500MVA ICT - 2 @ KHAPERKHEDA	12-Dec-18	09:00	12-Dec-18	17:00	Daily	MV Breaker CRM and Breaker timing.	MSETCL	MSETCL	All work conducted by MSETCL

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
40	400	400/220/33 KV 315 MVA ICT - 2 @ KORADI	12-Dec-18	09:00	12-Dec-18	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
41	400	PADGHE - NAGOTHANE 1	12-Dec-18	08:00	12-Dec-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
42	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	12-Dec-18	10:00	12-Dec-18	18:00	Continuous	Diagnoistic Testing	MSETCL	MSETCL	Load will be managed on 400KV ICT-I subject to Osmanabad and Tuljapur will be in Grid
43	400	JAIGAD-KARAD-II	13-Dec-18	14:00	13-Dec-18	18:00	Daily	Quarterly. Maint. Work & Repairing of Earth blade by adding counterweight	MSETCL	JPTL	Load manage on 400 kV JAIGAD -1
44	400	JEJURI- KOYNA STAGE-IV	13-Dec-18	09:00	13-Dec-18	18:00	Daily	Insulator replacement work & Annual maintenance work & testing work	MSETCL	MSETCL	Lonikand-Jejuri ckt will be in service
45	400	400/220/33 KV 500 MVA ICT - 1 @ NANDED	13-Dec-18	10:00	13-Dec-18	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
46	400	DEEPNAGAR - THAPTI TANDA	13-Dec-18	06:00	15-Dec-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Maint Work
47	400	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	13-Dec-18	10:00	13-Dec-18	17:00	Daily	DCRM,IR measurement of CB 430-Q52	MSETCL	MSETCL	ICT-I will remain service through Tie Bay 429
48	400	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	13-Dec-18	09:00	13-Dec-18	18:00	Daily	Half yrly maintenance & testing activities	MSETCL	MSETCL	-
49	400	AKOLA-NANDGAONPETH (RPL-AMT)	13-Dec-18	12:00	15-Dec-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.
50	400	LONIKAND 1 - KOYNA STAGE-IV	14-Dec-18	10:00	15-Dec-18	17:00	Daily	Line Maintenance & Routine Dignostic testing work and cold line washing	MSETCL	MSETCL	-
51	400	JAIGAD-NEW KOYNA-I	14-Dec-18	08:00	14-Dec-18	18:00	Daily	Circuit breaker ovehauling	MSETCL	MSETCL	Load can be managed on New Koyna-Jaigad CKT-II line
52	400	TIE BAY (429) OF ICT - 1 @ KORADI - 2	14-Dec-18	10:00	14-Dec-18	17:00	Daily	DCRM,IR measurement of CB 429-Q52	MSETCL	MSETCL	ICT-I will remain in service through Main Bay 430
53	400	400/220 KV 500 MVA ICT - 5 @ PADGHA	14-Dec-18	08:00	14-Dec-18	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
54	400	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	15-Dec-18	09:00	15-Dec-18	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400/220 kV 501MVA ICT-II, load affected NIL
55	400	JAIGAD-NEW KOYNA-II	15-Dec-18	08:00	15-Dec-18	18:00	Daily	Circuit breaker ovehauling	MSETCL	MSETCL	Load can be managed on New Koyna-Jaigad CKT-I line
56	400	KHADKA- DEEPNAGAR CKT 1	15-Dec-18	08:00	15-Dec-18	18:00	Daily	CVT C& Tan delta test,CB DCRM	MSETCL	MSETCL	testing work
57	400	400/220/20 KV 500MVA ICT - 3 @ KALWA	16-Dec-18	09:30	16-Dec-18	17:30	Daily	Bay Maintenance & Testing work.	MSETCL	MSETCL	-
58	400	400/220 125MVar BUS REACTOR @ LAMBOTI	17-Dec-18	10:00	17-Dec-18	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	No effect on Load
59	400	PADGHE - NAGOTHANE 2	17-Dec-18	08:00	17-Dec-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
60	400	NEW KOYNA-KARAD -CKT 1	17-Dec-18	09:00	19-Dec-18	18:00	Daily	Cold line cleaning of insulators	MSETCL	MSETCL	New Koyna-Karad 2 will be in service
61	400	DEEPNAGAR - THAPTI TANDA	17-Dec-18	06:00	22-Dec-18	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Maint work
62	400	MAIN BAY (409) OF AKOLA-1 CKT-1 @ AKOLA 2	17-Dec-18	09:00	17-Dec-18	18:00	Daily	Testing and Maintenance of Bay equipments.	MEGPTCL	MEGPTCL	
63	400	400/220/33 KV 315MVA ICT - 2 @ AKOLA	17-Dec-18	09:00	17-Dec-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
64	400	CHANDRAPUR - KHAPERKHEDA	17-Dec-18	08:00	31-Dec-18	17:00	Daily	PID work	MSETCL	MSETCL	PID shifting of auto reclose switch to non auto mode
65	400	KHADKA-AURANGABAD	18-Dec-18	08:00	18-Dec-18	18:00	Daily	400 KV Distance Relay testing work	MSETCL	MSETCL	Testing work
66	400	PADGHE - NAGOTHANE 2	18-Dec-18	08:00	18-Dec-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
67	400	KHADKA - BABLESHWAR	18-Dec-18	07:00	20-Dec-18	17:00	Daily	PID Testing	MSETCL	MSETCL	Non Autoreclose only
68	400	PADGHE - NAGOTHANE 2	19-Dec-18	08:00	19-Dec-18	17:00	Daily	Jumper Tightening and bay maintenance at SS	MSETCL	MSETCL	NIL
69	400	WARORA - IEPL	19-Dec-18	09:00	19-Dec-18	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400KV KORADI-WARDHA Line is in ckt
70	400	MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	20-Dec-18	10:00	20-Dec-18	18:00	Daily	DCRM,CRM & Timing IR of 407-Q52	MSETCL	MSETCL	Station Transformer-2 will remain in service through Tie Bay 408
71	400	LONIKAND 1 -JEJURI	20-Dec-18	10:00	20-Dec-18	17:00	Daily	Line Maintenance , Annual maintenance work & testing work	MSETCL	MSETCL	400KV Jejuri-Koyna line will be in service
72	400	400/220/33 KV 500 MVA ICT - 2 @ NANDED	20-Dec-18	10:00	20-Dec-18	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
73	400	JEJURI- KOYNA STAGE-IV	20-Dec-18	09:00	20-Dec-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Lonikand-jejuri ckt will be in service
74	400	TIE BAY (411) OF RPL CKT - 2 & AKOLA-1 CKT-2 @ AKOLA 2	20-Dec-18	09:00	20-Dec-18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	
75	400	125 MVar BUS REACTOR @ ALKUD	20-Dec-18	09:30	20-Dec-18	17:30	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
76	400	400KV KORADI-BHUSAWAL (Bhusawal end)	20-Dec-18	12:00	22-Dec-18	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Akola- Bhusawal, 400 kV Akola-Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service
77	400	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	21-Dec-18	08:00	21-Dec-18	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	NIL
78	400	KARAD - TALANDGE CKT 1	21-Dec-18	09:00	22-Dec-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Karad-Talandge ckt-II will be in service
79	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	21-Dec-18	09:00	21-Dec-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
80	400	BABLESHWAR- AURANGABAD (WALUJ)	21-Dec-18	08:00	31-Dec-18	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	A/R to be taken out of service
81	400	MAIN BAY (412) OFAKOLA -1 CKT-2 @ AKOLA 2	22-Dec-18	09:00	22-Dec-18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	
82	400	KARAD - TALANDGE CKT 2	24-Dec-18	09:00	26-Dec-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Karad-Talandge ckt I will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
83	400	DEEPNAGAR - THAPTI TANDA	24-Dec-18	06:00	26-Dec-18	18:00	Daily	For PID of Insulator string	MSETCL	MSETCL	ckt will be in service only A/R will be in Non-Auto condition.
84	400	DEEPNAGAR AURANGABAD	24-Dec-18	06:00	26-Dec-18	18:00	Daily	For PID of Insulator string	MSETCL	MSETCL	ckt will be in service only A/R will be in Non-Auto condition
85	400	400/220/33 KV 500 MVA ICT - 3 @ PARLI	26-Dec-18	09:00	26-Dec-18	17:00	Daily	(1) Relay testing work. (2) Bay maint. Work.	MSETCL	MSETCL	-
86	400	KOLHAPUR (TALANDGE) - ALKUD	26-Dec-18	10:00	26-Dec-18	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	-
87	400	NEW KOYNA - DABHOL - I	26-Dec-18	08:00	27-Dec-18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New Koyna CKT-II
88	400	KHADKA - BABLESHWAR	26-Dec-18	07:00	28-Dec-18	17:00	Daily	PID Testing	MSETCL	MSETCL	Non Auto re-close mode only
89	400	400/220/33 KV 500 MVA ICT - 1 @ JEIURI	27-Dec-18	09:00	27-Dec-18	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	400/220KV ICT-NO. II CGL and 400/220kv ICT-NO.III ALSTOM will be in service
90	400	BABLESHWAR- AURANGABAD (WALUJ)	27-Dec-18	09:00	27-Dec-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
91	400	JEIURI- KOYNA STAGE-IV	27-Dec-18	09:00	27-Dec-18	18:00	Daily	Insulator replacement work	MSETCL	MSETCL	Lonikand-Jejuri ckt will be in service
92	400	NEW KOYNA - STAGE IV CKT 1	28-Dec-18	08:00	29-Dec-18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II
93	400	KHADKA - BABLESHWAR	28-Dec-18	09:00	28-Dec-18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators	MSETCL	MSETCL	400 kV Auragabad ,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
94	400	MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2	29-Dec-18	09:00	29-Dec-18	18:00	Daily	Testing and Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	
95	400	THAPTI TANDA - WALUJ	29-Dec-18	08:00	29-Dec-18	17:00	Daily	Routine Maintenance & Testing	MSETCL	MSETCL	Nil
96	400	400/132 KV 200 MVA ICT - 2 ON TBC @ KHADKA	29-Dec-18	08:00	29-Dec-18	18:00	Daily	CB DCRM Test	MSETCL	MSETCL	Load will be shifted on TBC,ICT will remain in service
97	400	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	29-Dec-18	08:00	29-Dec-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT- I , 501 MVA ICT -III& IV will be in service
98	400	NEW KOYNA - STAGE IV CKT 2	30-Dec-18	08:00	31-Dec-18	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I
99	400	80 MVAR BUS REACTOR - 1 @ BABHALESHWAR	30-Dec-18	08:00	30-Dec-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -2 will be in service
100	400	80 MVAR BUS REACTOR - 2 @ BABHALESHWAR	31-Dec-18	08:00	31-Dec-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -1 will be in service