

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of December'2019

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	Daily/Continuous	Name of Requesting Agency	reason
1	3	400KV-KALWA-PADGHE-1	01/Dec/2019	08:00	10/Dec/2019	18:00	Continuous	MSETCL	For work of Height rising at Loc. No.1118 to 1120 for MMRDA.
2	8	400KV-RGPPL-NAGOTHANE-1	01/Dec/2019	08:00	04/Dec/2019	18:00	Daily	MSETCL	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing
3	12	400KV-DHULE-MS-BABLESHWAR-1	01/Dec/2019	08:00	10/Dec/2019	18:00	Daily	MSETCL	PID testing work
4	13	400KV-DHULE-MS-BABLESHWAR-2	01/Dec/2019	08:00	10/Dec/2019	18:00	Daily	MSETCL	PID testing work
5	14	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	01/Dec/2019	9:00	10/Dec/2019	18:00	Continuous	POWERGRID WR1	For Replacement of BHEL CB with GE CB.
6	17	400KV-KOLHAPUR-MS-SOLAPUR-2	01/Dec/2019	9:00	15/Dec/2019	17:00	Daily	WTPL	A/R mode to be kept OFF for PID Scanning Work
7	18	400KV-KOLHAPUR-MS-ALKUD-1	01/Dec/2019	9:00	15/Dec/2019	17:00	Daily	WTPL	A/R mode to be kept OFF for PID Scanning Work
8	19	400KV-RGPPL-NAGOTHANE-1	01/Dec/2019	10:00	15/Dec/2019	15:00	Daily	MSETCL	PID Test of insulators
9	20	220KV-WARDHA-PUSAD-1	01/Dec/2019	07:00	31/Dec/2019	17:00	Daily	MSETCL	For PID Work
10	27	400KV-KOYNA STAGE IV-LONIKHAND-1	01/Dec/2019	09:00	31/Dec/2019	17:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
11	28	400KV-JEJURI-KOYNA STAGE IV-1	01/Dec/2019	09:00	31/Dec/2019	17:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
12	29	400KV-KARAD-KOLHAPUR-MS-2	01/Dec/2019	09:00	31/Dec/2019	17:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
13	30	400KV-KARAD-KOLHAPUR-MS-1	01/Dec/2019	09:00	31/Dec/2019	17:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
14	50	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	02/Dec/2019	09:00	02/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
15	74	400KV-RGPPL-NAGOTHANE-1	02/Dec/2019	08:00	03/Dec/2019	17:00	Daily	MSETCL	for emergency tree cutting
16	84	DHULE-MS - 400KV - BR	02/Dec/2019	7:00	07/Dec/2019	18:00	Continuous	POWERGRID_WR1	For internal inspection on Acetylene raising
17	85	400KV-KALWA-PADGHE-1	02/Dec/2019	08:00	07/Dec/2019	18:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
18	88	400KV-SSP-DHULE-MS-1	02/Dec/2019	08:00	13/Dec/2019	16:00	Daily	MSETCL	ONLINE PID TESTING WORK.
19	89	400KV-SSP-DHULE-MS-2	02/Dec/2019	08:00	13/Dec/2019	16:00	Daily	MSETCL	ONLINE PID TESTING WORK
20	137	400KV-TARAPUR 3&4-PADGHE-1	03/Dec/2019	10:00	03/Dec/2019	17:00	D	POWERGRID_WR1	AMP of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.
21	150	220KV-PARLI-OSMANABAD-M-1	04/Dec/2019	08:00	04/Dec/2019	16:00	Daily	MSETCL	LINE maintenance
22	151	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	04/Dec/2019	8:00	04/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work
23	162	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	04/Dec/2019	09:00	04/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
24	163	400KV-PARLI-M-SOLAPUR-M-1	04/Dec/2019	09:00	04/Dec/2019	18:00	Daily	MSETCL	Distance relay testing work.
25	191	400KV-KORADI-BHUSAWAL-1	04/Dec/2019	08:00	11/Dec/2019	18:00	Continuous	MSETCL	Restranging of conductor of all three phases of 400 kV Koradi- Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line and also for other maintenance works of line
26	199	400KV-RGPPL-NAGOTHANE-2	05/Dec/2019	08:00	06/Dec/2019	17:00	Continuous	MSETCL	emergency tree cutting work
27	207	400KV-AURANGABAD-BOISAR-2	05/Dec/2019	9:00	05/Dec/2019	9:15	D	POWERGRID_WR2	To isolate L/R at Boisar for AMP Works
28	208	400KV-WARDHA-WARORA-1	05/Dec/2019	09:00	05/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work
29	209	220KV-TALEGAON-PUNE-PG-1	05/Dec/2019	09:00	05/Dec/2019	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostics Testing

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	Daily/Continuous	Name of Requesting Agency	reason
30	212	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	05/Dec/2019	09:00	05/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
31	213	220KV-WARDHA-PUSAD-1	05/Dec/2019	09:00	05/Dec/2019	18:00	Daily	MSETCL	For Routine Maintainance Work
32	226	JEJURI - 400KV - BUS 1	05/Dec/2019	09:30	05/Dec/2019	17:30	Daily	MSETCL	Annual testing & maint.
33	229	95 MVA STN TF - II @KORADI 2	05/Dec/2019	10:00	05/Dec/2019	16:00	Daily	MSETCL	Tan delta Measurement of Bus CT & Line CT at Bay 407.
34	256	BUSBAR PROTECTION SCHEME @ LONIKAND 2	06/Dec/2019	07:30	06/Dec/2019	23:00	Daily	MSETCL	400 kv online Bus bar protection Relay scheme testing
35	258	KHAPARKHEDA - 400KV - BUS 2	06/Dec/2019	08:00	06/Dec/2019	17:00	Daily	MSETCL	Diagnostic Testing of BUS CVT & Routine Maintenance Work
36	272	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	06/Dec/2019	09:00	06/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
37	286	220KV-WARDHA-BHUGAON-1	06/Dec/2019	10:00	06/Dec/2019	18:00	Daily	MSETCL	Routine maintainance work
38	296	400KV-SSP-DHULE-MS-2	07/Dec/2019	7:00	07/Dec/2019	18:00	D	GETCO	PMM work.
39	297	400KV-RGPPL-NEW KOYNA-1	07/Dec/2019	9:00	07/Dec/2019	18:00	Daily	RGPPL	Cold line washing of insulator string
40	309	400KV-KORADI-II-KORADI-III-1	07/Dec/2019	10:00	07/Dec/2019	18:00	Daily	MSETCL	Tan delta measurement of Line CT & CVT
41	311	BHUSAWAL - 400KV - BUS 1	07/Dec/2019	06:00	07/Dec/2019	18:00	Daily	MSETCL	for BUS-I CVT Tan delta & replacement of CVT if required and other routine bay maintenance work
42	317	TIE BAY - 765KV-KORADI-III-AKOLA-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	07/Dec/2019	09:00	07/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
43	326	TALEGAON - 220KV - BUS 1	07/Dec/2019	9:00	07/Dec/2019	17:00	D	POWERGRID_WR1	For Replacment of Clamps & Connectors
44	328	BOISAR-M - 220KV - BUS 1	07/Dec/2019	07:00	08/Dec/2019	18:00	Continuous	MSETCL	Routine Maintenance & Dignostic testing works.
45	335	400KV-RGPPL-NEW KOYNA-2	08/Dec/2019	08:00	11/Dec/2019	18:00	Daily	MSETCL	Earth Wire replacement Routine maint. Work & Faulty string replacement Work & cold washing
46	343	400KV-WARDHA-KORADI-II-1	08/Dec/2019	09:00	08/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work
47	344	BOISAR - 400KV - BUS 1	08/Dec/2019	9:00	08/Dec/2019	17:00	D	POWERGRID_WR2	FOR AMP
48	348	400KV-KALWA-PADGHE-1	08/Dec/2019	08:00	08/Dec/2019	18:00	Daily	MSETCL	Faulty Insulator replacement found in PID
49	350	MAIN BAY - 765KV-KORADI-III-AKOLA-2 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	08/Dec/2019	09:00	08/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
50	368	220 KV Mudshingi-Chikodi	09/Dec/2019	8:00	09/Dec/2019	18:00	Daily	MSETCL	Quartely Maintenance Work i.e Line Singnature Analysis
51	388	220KV-MUDSHINGI-CHIKKODI-II-1	09/Dec/2019	10:00	09/Dec/2019	17:00	Daily	MSETCL	Quartely Maintenance Work i.e Line Singnature Analysis
52	390	220KV-WARDHA-BHUGAON-1	09/Dec/2019	10:00	09/Dec/2019	18:00	Daily	MSETCL	Routine maintainance work
53	394	MAIN BAY - AKOLA - 765KV B/R 1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	09/Dec/2019	09:00	11/Dec/2019	18:00	Daily	MEGPTCL	C&D Commissioning Activities
54	396	400KV-KALWA-PADGHE-2	09/Dec/2019	09:00	14/Dec/2019	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
55	438	400KV-PADGHE-NAGOTHANE-2	10/Dec/2019	08:00	12/Dec/2019	17:00	Continuous	MSETCL	jumper tightening and monkey patrolling
56	450	220KV-TARAPUR 1&2-BOISAR-M-1	11/Dec/2019	08:00	11/Dec/2019	17:00	Daily	MSETCL	R/M of bay & Dignostic testing works.
57	451	220KV-TILLARI-AMONA-1	11/Dec/2019	08:00	11/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work
58	478	SOLAPUR-M - 400KV - BUS 1	11/Dec/2019	10:00	11/Dec/2019	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUS-I, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
59	479	400KV-PARLI-M-SOLAPUR-M-1	11/Dec/2019	10:00	11/Dec/2019	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUS-I, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
60	482	220KV-WARDHA-WARDHA-M-1	11/Dec/2019	08:00	12/Dec/2019	18:00	Daily	MSETCL	Shifting and Charging of line through ERS from Loc No 15-18 due to raising the height of tower due to NHAI from Loc 16 to 17 and railway crossing from Loc No 17 to 18.

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	Daily/Continuous	Name of Requesting Agency	reason
61	487	400KV-BABLESHWAR-PADGHE-PG-2	11/Dec/2019	08:00	20/Dec/2019	18:00	Daily	MSETCL	PID testing work
62	488	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	11/Dec/2019	9:00	20/Dec/2019	18:00	C	POWERGRID WR1	For Replacement of BHEL CB with GE CB.
63	494	PUNE-PG - 400KV - BUS 2	12/Dec/2019	9:00	12/Dec/2019	17:00	D	POWERGRID_WR1	For Replacment of Clamps & Connectors
64	502	400KV-RGPPL-NAGOTHANE-2	12/Dec/2019	08:00	15/Dec/2019	18:00	Daily	MSETCL	Earth Wire replacement ,Routine maint. Work, Faulty string replacement Work & cold washing
65	507	TIE BAY (412) OF CHANDRAPUR-1 & ADANI - 1 @ WARORA	12/Dec/2019	08:00	12/Dec/2019	16:00	Daily	MSETCL	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
66	516	MAIN BAY - 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	12/Dec/2019	9:00	12/Dec/2019	17:00	D	POWERGRID_WR2	FOR AMP. Line will be in service through TBC bay.
67	519	400KV-PARLI-M-PARLI-1	12/Dec/2019	09:00	12/Dec/2019	18:00	Daily	MSETCL	C & Tan delta measurement work of CTs.
68	535	220KV-WARDHA-BHUGAON-1	12/Dec/2019	10:00	12/Dec/2019	18:00	Daily	MSETCL	AMP
69	537	TIE BAY - 400KV-KALWA-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-3 at PUNE-PG - 400KV	12/Dec/2019	9:00	12/Dec/2019	17:00	D	POWERGRID_WR1	For AMP works
70	542	TIE BAY - AKOLA - 765KV B/R 1 AND 765KV/400KV AKOLA-ICT-1	12/Dec/2019	09:00	14/Dec/2019	18:00	Daily	MEGPTCL	CSD Commissioning Activities
71	546	400KV-CHAKAN-PUNE-PG-1	13/Dec/2019	9:00	13/Dec/2019	17:00	D	POWERGRID_WR1	FOR AMP WORK
72	549	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	13/Dec/2019	08:00	13/Dec/2019	17:00	Daily	MSETCL	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
73	551	BUS COUPLER @ CHANDRAPUR	13/Dec/2019	05:00	15/Dec/2019	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV Bus Coupler and 400KV ICT-2 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
74	552	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	13/Dec/2019	05:00	15/Dec/2019	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV Bus Coupler and 400KV ICT-2 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
75	553	CHANDRAPUR - 400KV - BUS 1	13/Dec/2019	05:00	15/Dec/2019	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV Bus Coupler and 400KV ICT-2 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
76	561	MAIN BAY - 400KV/11.5KV TIRODA-ST-2 AND TIRODA - 400KV - BUS 1 at TIRODA - 400KV	13/Dec/2019	08:00	13/Dec/2019	18:00	Daily	APML	Maintenance of Bay Equipments.
77	566	220KV-AURANGABAD-CHITEGAON-2	13/Dec/2019	09:00	13/Dec/2019	18:00	Daily	MSETCL	Routine Maintenance and Diagnostic testing work
78	576	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	13/Dec/2019	10:00	13/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & testing work
79	597	TIE BAY - 400KV-TIRODA-WARORA-2 AND 400KV/11.5KV TIRODA-ST-2 at TIRODA - 400KV	14/Dec/2019	08:00	14/Dec/2019	18:00	Daily	APML	Maintenance of Bay Equipments.
80	599	220KV-PARLI-PARLI-M-1	14/Dec/2019	08:00	14/Dec/2019	16:00	Daily	MSETCL	LINE maintenance
81	600	400KV-SSP-DHULE-MS-1	14/Dec/2019	08:00	14/Dec/2019	18:00	Daily	MSETCL	PID work will be carried out on 02 to 13 DEC. 2019. if any strings found suspicious, it will be replaced in this proposed outage.
82	625	400KV-KALWA-KHARGHAR-1	15/Dec/2019	08:00	15/Dec/2019	18:00	Daily	MSETCL	R&M and Diagnostic testing work
83	635	400KV-RGPPL-NAGOTHANE-1	16/Dec/2019	9:00	16/Dec/2019	18:00	Daily	RGPPPL	Tie breker mechnaism healthiness checking
84	639	400KV-KALWA-PADGHE-2	16/Dec/2019	08:00	16/Dec/2019	18:00	Daily	MSETCL	Faulty Insulator replacement found in PID
85	647	220KV-BOISAR-BOISAR-M-1	16/Dec/2019	07:00	16/Dec/2019	17:00	Daily	MSETCL	Line Isolator repairing & Dignostic testing works.
86	652	765/400kv 1500 MVA ICT-2 @ KORADI 3	16/Dec/2019	09:00	16/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of ICT-2
87	653	AKOLA - 400KV - BUS 2	16/Dec/2019	09:00	16/Dec/2019	18:00	Daily	MSETCL	Routine Maintenance & testing work
88	671	132KV-DHARNI-NEPANAGAR-1	16/Dec/2019	10:00	16/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work
89	672	ALKUD - 400KV - BUS 2	16/Dec/2019	10:00	16/Dec/2019	17:30	Daily	MSETCL	Quarterly Maint. Work
90	685	400KV-KALWA-PUNE-PG-1	16/Dec/2019	09:00	21/Dec/2019	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
91	686	400KV-KHARGHAR-PUNE-PG-1	16/Dec/2019	09:00	21/Dec/2019	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	Daily/Continuous	Name of Requesting Agency	reason
92	690	BUS COUPLER @ PARLI	16/Dec/2019	09:00	26/Dec/2019	18:00	Continuous	MSETCL	Replacement of 400kV Circuit Breaker at 400kV Girwali
93	691	400KV-DHULE-MS-BABLESHWAR-2	16/Dec/2019	08:00	27/Dec/2019	16:00	Daily	MSETCL	ONLINE PID WORK WILL BE CARRIED OUT.
94	693	400KV-RGPPL-NEW KOYNA-2	16/Dec/2019	10:00	30/Dec/2019	15:00	Daily	MSETCL	PID Test of insulators
95	700	KALWA - 400KV - BUS 1	17/Dec/2019	09:00	17/Dec/2019	18:00	Daily	MSETCL	Bus maint. and CVT testing work
96	703	400KV-RGPPL-NEW KOYNA-1	17/Dec/2019	08:00	20/Dec/2019	18:00	Daily	MSETCL	Routine maint. Work , Faulty string replacement Work & cold washing
97	707	400KV-ALKUD-SOLAPUR-1	17/Dec/2019	10:00	17/Dec/2019	17:30	Daily	MSETCL	Quarterly Maint. Work
98	720	220KV Pandhurna-Kalmeshwar	17/Dec/2019	9:00	17/Dec/2019	18:00	D	MP_SLDC	For line maintenance work
99	725	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-3 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	17/Dec/2019	9:00	17/Dec/2019	18:00	D	POWERGRID_WR1	FOR AMP WORKS
100	731	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	17/Dec/2019	9:00	17/Dec/2019	18:00	D	POWERGRID WR1	For AMP works.
101	732	TIE BAY - 400KV-WARDHA-WARORA-2 AND WARORA - FUTURE at WARORA - 400KV	17/Dec/2019	9:00	17/Dec/2019	18:00	D	POWERGRID WR1	For AMP works
102	743	400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	17/Dec/2019	9:00	18/Dec/2019	18:00	C	POWERGRID WR1	Insulator replacement work to rectify Partial Discharge in GIS duct at Kolhapur end & 400KV-KOLHAPUR GIS-NARENDRA KUDGI-2 AR to be in non auto mode for line AMP works for safety measures.
103	747	DHULE- - BABLESHWAR - I	17/Dec/2019	08:00	27/Dec/2019	16:00	Daily	MSETCL	ONLINE PID WORK WILL BE CARRIED OUT.
104	751	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	18/Dec/2019	9:00	18/Dec/2019	17:00	D	POWERGRID_WR1	For AMP works
105	753	AURANGABAD-M (WALUJ) - 400KV - BUS 1	18/Dec/2019	09:00	18/Dec/2019	17:00	Daily	MSETCL	29A bus isolator maintenance with main bus 1 outage & Routine Maintenance
106	764	220KV-PANDURNA-KALMESHWAR-1	18/Dec/2019	08:00	18/Dec/2019	18:00	Daily	MSETCL	Routine Maintenance & Diagnostic testing work
107	768	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	18/Dec/2019	09:00	18/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work
108	783	MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	18/Dec/2019	10:00	18/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & testing work
109	785	220KV-SOLAPUR-JEUR-1	18/Dec/2019	10:00	18/Dec/2019	18:00	Daily	MSETCL	Quarterly Maintenance
110	796	400KV-BHUSAWAL-AKOLA-1	18/Dec/2019	08:00	25/Dec/2019	18:00	Continuous	MSETCL	Restranging of conductor of all three phases of 400 kV Akola- Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola
111	798	TALEGAON - 220KV - BUS 2	19/Dec/2019	9:00	19/Dec/2019	17:00	D	POWERGRID_WR1	For Replacment of Clamps & Connectors
112	808	400KV-CHANDRAPU-II-NANDED-2	19/Dec/2019	08:00	19/Dec/2019	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.
113	809	400KV-CHANDRAPU-II-NANDED-1	19/Dec/2019	08:00	19/Dec/2019	17:00	Daily	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.
114	811	400KV-EKTUNI-BABLESHWAR-1	19/Dec/2019	08:00	19/Dec/2019	18:00	Daily	MSETCL	Quarterly maintenance work
115	818	765KV-TIRODA-KORADI-III-1 L/R@ KORADI-III - 765KV	19/Dec/2019	09:00	19/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Line Reactor & Related Equipments
116	819	400KV-PARLI-M-PARLI-2	19/Dec/2019	09:00	19/Dec/2019	18:00	Daily	MSETCL	Distance relay testing work.
117	840	SOLAPUR-M - 400KV - BUS 2	19/Dec/2019	10:00	19/Dec/2019	18:00	Daily	MSETCL	Diagnostic testing work
118	849	NEW KOYNA - 400KV - BUS 2	19/Dec/2019	08:00	21/Dec/2019	18:00	Continuous	MSETCL	Conductor replacement, Isolator servicing / overhauling work & Routine maint. Work
119	875	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	20/Dec/2019	09:00	20/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work
120	876	220KV-BOISAR-NALASOPARA-1	20/Dec/2019	09:00	20/Dec/2019	17:00	Daily	MSETCL	Routine & Bay Maintenance Work
121	880	MAIN BUS - 1 @ AKOLA 2	20/Dec/2019	09:00	20/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bus Equipment
122	893	TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV	20/Dec/2019	10:00	20/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance & testing work

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	Daily/Continuous	Name of Requesting Agency	reason
123	898	MAIN BAY (409) OF KORADI 3 CKT- 1 @ KORADI 2	20/Dec/2019	10:30	20/Dec/2019	11:00	Daily	MSETCL	Tan delta measurement of Bus CT at Bay 409
124	910	NEW KOYNA - 400KV - BUS 1	21/Dec/2019	08:00	22/Dec/2019	18:00	Continuous	MSETCL	conductor replacement, Isolator servicing / overhauling work & Routine maint. Work
125	914	400KV-EKTUNI-BABLESHWAR-2	21/Dec/2019	09:00	21/Dec/2019	18:00	Daily	MSETCL	Quarterly maintenance work
126	918	400KV-SSP-DHULE-MS-2	21/Dec/2019	08:00	21/Dec/2019	18:00	Daily	MSETCL	PID work will be carried out on 02 to 13 DEC. 2019. If any strings found suspicious, it will be replaced in this proposed outage.
127	924	MAIN BAY - 765KV-KORADI-III-AKOLA-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	21/Dec/2019	09:00	21/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
128	932	TIE BAY (408) OF STN T/F-2 & KORADI 3 CKT-1 @ KORADI 2	21/Dec/2019	10:00	21/Dec/2019	10:30	Daily	MSETCL	Tan delta measurement of Bus CT at Bay 408
129	933	400KV-PARLI-M-LONIKHAND-II-2	21/Dec/2019	10:00	21/Dec/2019	17:00	Daily	MSETCL	Distance relay testing work, Hardware Tightening & Fitting work, bay maintenance work.
130	937	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	21/Dec/2019	9:00	30/Dec/2019	18:00	C	POWERGRID WR1	For Replacement of BHEL CB with GE CB.
131	940	400KV-BABLESHWAR-PADGHE-PG-1	21/Dec/2019	08:00	31/Dec/2019	18:00	Daily	MSETCL	PID testing work
132	946	400KV-KALWA-PUNE-PG-1	22/Dec/2019	09:00	26/Dec/2019	18:00	Daily	MSETCL	CB pole overhauling work
133	956	400KV-KHARGHAR-PUNE-PG-1	22/Dec/2019	08:00	22/Dec/2019	18:00	Daily	MSETCL	Line Maintenance & Routine Diagnostic testing work. Insulator Replacement & SSN to DSN
134	957	220KV-BOISAR-BOISAR-M-3	22/Dec/2019	09:00	22/Dec/2019	17:00	Daily	MSETCL	Line Isolator repairing & Dignostic testing works.
135	958	400KV/11.5KV CHANDRAPUR-GCR-ST-5 ON TBC - II	23/Dec/2019	05:00	25/Dec/2019	18:00	Continuous	MSETCL	Permission for shifting of 400KV STN T/F No.- V bay on TBC-II bay.
136	959	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	23/Dec/2019	05:00	25/Dec/2019	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-II in HVDC- II and 400KV STN T/F No.- 5 bay section span. 2) For measuremnet of Tan delta & capacitance of CVT's of Main Bus-II. 3)Tightening of nut bolts & hardware of Main Bus-II.
137	960	CHANDRAPUR - 400KV - BUS 2	23/Dec/2019	05:00	25/Dec/2019	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-II in HVDC- II and 400KV STN T/F No.- 5 bay section span. 2) For measuremnet of Tan delta & capacitance of CVT's of Main Bus-II. 3)Tightening of nut bolts & hardware of Main Bus-II.
138	970	220 KV Talandage-Chikodi	23/Dec/2019	8:00	23/Dec/2019	18:00	Daily	MSETCL	Quartely Maintenance Work i.e Line Singnature Analysis
139	974	AKOLA - 765KV - BUS 2	23/Dec/2019	09:00	23/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bus Equipment
140	984	220KV-WARDHA-WARDHA-M-1	23/Dec/2019	9:00	23/Dec/2019	18:00	D	POWERGRID WR1	Line Impedance Kit commissioning
141	988	220KV-KOLHAPUR-CHIKKODI-II-1	23/Dec/2019	10:00	23/Dec/2019	17:00	Daily	MSETCL	Quartely Maintenance Work i.e Line Singnature Analysis
142	989	220KV-WARDHA-PUSAD-1	23/Dec/2019	10:00	23/Dec/2019	18:00	Daily	MSETCL	Routine maintainace work
143	993	220KV-WARDHA-WARDHA-M-1	23/Dec/2019	08:00	24/Dec/2019	18:00	Daily	MSETCL	Restoration of line from ERS to new erected tower from Loc No 15-18 due to raising the height of tower due to NHAI from Loc 16 to 17 and railway crossing from Loc No 17 to 18.
144	1002	400KV-KALWA-PADGHE-2	23/Dec/2019	09:00	28/Dec/2019	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
145	1008	KALWA - 400KV - BUS 2	24/Dec/2019	09:00	24/Dec/2019	18:00	Daily	MSETCL	Bus maint. and CVT testing work
146	1027	220KV-WARDHA-BADNERA-1	24/Dec/2019	9:00	24/Dec/2019	18:00	D	POWERGRID WR1	Line Impedance Kit commissioning
147	1040	400KV-KALWA-PADGHE-2	25/Dec/2019	08:00	31/Dec/2019	18:00	Continuous	MSETCL	ORC MMRDA Work of Shifting/Height raising
148	1045	BUS COUPLER @ KHARGHAR	25/Dec/2019	08:00	27/Dec/2019	18:00	Continuous	MSETCL	Replacement of existing 0.5 ACSR quadraple bus conductor
149	1046	KHARGHAR - 400KV - BUS 1	25/Dec/2019	08:00	27/Dec/2019	18:00	Continuous	MSETCL	Replacement of existing 0.5 ACSR quadraple bus conductor
150	1054	220kv Navsari-Nashik line no.1	25/Dec/2019	9:00	25/Dec/2019	18:00	Daily	GETCO	Bay Maintenance
151	1055	MAIN BAY - 765KV-AKOLA-EKTUNI-1 AND AKOLA - 765KV - BUS 1 at AKOLA - 765KV	25/Dec/2019	09:00	25/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
152	1058	400KV-SOLAPUR-M-SOLAPUR-1	25/Dec/2019	10:00	25/Dec/2019	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bus-II, Spare ICT and 400 kv PGCIL Line outage is also required. 400 KV Bus reactor will be out of service.

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	Daily/Continuous	Name of Requesting Agency	reason
153	1059	SOLAPUR-M - 400KV - BUS 1	25/Dec/2019	10:00	25/Dec/2019	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main BUS-II, Spare ICT and 400 kv PGCIL Line outage is also required. 400 KV Bus reactor will be out of service.
154	1066	220KV-TALEGAON-PUNE-PG-2	26/Dec/2019	09:00	26/Dec/2019	17:00	Daily	MSETCL	Half yearly maintenance , Diagnostics Testing
155	1067	CHANDRAPU-II - 400KV - BUS 1	26/Dec/2019	08:00	26/Dec/2019	17:00	Daily	MSETCL	Diagnostic testing work
156	1069	400KV-TIRODA-WARORA-1	26/Dec/2019	08:00	26/Dec/2019	18:00	Daily	ATIL	Annual Line Maintenance
157	1077	220kV Navsari-Nashik line no.2	26/Dec/2019	9:00	26/Dec/2019	18:00	Daily	GETCO	Bay Maintenance
158	1079	220KV-WARDHA-PUSAD-1	26/Dec/2019	09:00	26/Dec/2019	18:00	Daily	MSETCL	For Routine Maintenance Work
159	1087	765KV-AURANGABAD-PADGHE-PG-2 L/R@ AURANGABAD - 765KV	26/Dec/2019	9:00	26/Dec/2019	18:00	D	POWERGRID_WR1	FOR AMP WORKS
160	1090	TIE BAY - 400KV-PARLI-SOLAPUR-1 AND 400KV-ALKUD-SOLAPUR-1 at Solapur - 400KV	26/Dec/2019	9:00	26/Dec/2019	18:00	D	POWERGRID WR1	To change Bph CT below due to low oil level.
161	1095	400KV-PARLI-M-LONIKHAND-II-2	26/Dec/2019	10:00	26/Dec/2019	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.
162	1096	TIE BAY -409 of PARALI CKT-2 @ LONIKAND 2	26/Dec/2019	10:00	26/Dec/2019	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.
163	1119	400KV-TIRODA-WARORA-2	27/Dec/2019	08:00	27/Dec/2019	18:00	Daily	ATIL	Annual Line Maintenance.
164	1153	AURANGABAD-M (WALUJ) - 400KV - BUS 1	28/Dec/2019	10:00	28/Dec/2019	17:00	Daily	MSETCL	Babhaleshwar Bay @waluj end
165	1163	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-AKOLA-EKTUNI-1 at AKOLA - 765KV	28/Dec/2019	09:00	28/Dec/2019	18:00	Daily	MEGPTCL	Maintenance of Bay Equipment
166	1174	220KV-WARDHA-PUSAD-1	28/Dec/2019	10:00	28/Dec/2019	18:00	Daily	MSETCL	Routine maintainace work
167	1176	400KV-KALWA-PUNE-PG-1	29/Dec/2019	08:00	29/Dec/2019	18:00	Daily	MSETCL	Conductor Replacement at Loc. No. 95-96
168	1179	KHARGHAR - 400KV - BUS 2	29/Dec/2019	08:00	31/Dec/2019	18:00	Continuous	MSETCL	Replacement of existing 0.5 ACSR quadruple bus conductor
169	1180	BUS COUPLER @ KHARGHAR	29/Dec/2019	08:00	31/Dec/2019	18:00	Continuous	MSETCL	Replacement of existing 0.5 ACSR quadruple bus conductor
170	1183	220KV-BOISAR-BOISAR-M-2	29/Dec/2019	09:00	29/Dec/2019	17:00	Daily	MSETCL	Routine Maintenance Work
171	1198	400KV-ALKUD-SOLAPUR-1	30/Dec/2019	9:00	30/Dec/2019	17:00	Daily	WTPL	Annual maintenance of transmission line
172	1216	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	30/Dec/2019	10:00	30/Dec/2019	14:00	Daily	MEGPTCL	Reactor Changeover Activities.
173	1220	400KV-KALWA-KHARGHAR-1	30/Dec/2019	09:00	31/Dec/2019	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
174	1227	400KV-KOLHAPUR-MS-ALKUD-1	31/Dec/2019	9:00	31/Dec/2019	17:00	Daily	WTPL	Annual maintenance of transmission line

Maharashtra State Load Despatch Centre

State Element Outages list for the month of December'19

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400KV-CHANDRAPU-II-NANDED-1	01-Dec-19	08:00	15-Dec-19	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	nil
2	400 KV	400KV-NANDGAONPETH-KORADI-1	01-Dec-19	09:00	15-Dec-19	18:00	Daily	PID test (With A/R switch in Non Auto mode)	MSETCL	MSETCL	Outage proposed by LM S/Dn Koradi
3	400 KV	400KV-KARAD-NEW KOYNA-1	02-Dec-19	08:00	02-Dec-19	18:00	Daily	Diagnostic testing & routine maint. Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Karad CKT-II line
4	400 KV	TBC @ PARLI	02-Dec-19	09:00	02-Dec-19	18:00	Daily	Bay Maintenance work	MSETCL	MSETCL	-
5	400 KV	400KV-BHUSAWAL-DEEPNAGAR-1	02-Dec-19	06:00	04-Dec-19	18:00	Daily	For replacement of faulty string detected in PID & for Tan delta of CT,DCRM of CB and Isolator and bay maintenance work	MSETCL	MSETCL	400kv Khadka-Deepnagar-II will be in service
6	400 KV	400KV-KARAD-KOLHAPUR-MS-1	02-Dec-19	10:00	02-Dec-19	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on 400 kv Karad-Talandge 2
7	400 KV	FUTURE CKT - 1 @ WARORA	03-Dec-19	09:00	03-Dec-19	17:00	Daily	Bus/Line/Tie CT's Tan delta & Routine Maintenance & Dignostic testing work etc	MSETCL	MSETCL	400KV Bay No 421 charged on No Load
8	400 KV	400KV-AURANGABAD-M (WALUJ)-DEEPNAGAR-1	03-Dec-19	10:00	04-Dec-19	17:00	Daily	Spike guard fixing	MSETCL	MSETCL	Spike guard fixing
9	400 KV	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-1	04-Dec-19	09:00	04-Dec-19	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
10	400 KV	400KV-KARAD-NEW KOYNA-2	04-Dec-19	08:00	04-Dec-19	18:00	Daily	Diagnostic testing & routine maint. work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Karad CKT-I line
11	400 KV	400KV-PADGHE-NAGOTHANE-2	04-Dec-19	09:30	04-Dec-19	17:30	Daily	Dignostic Testing & Bay Maint work	MSETCL	MSETCL	400kv Nagothane I will be in service
12	400 KV	400 KV FUTURE BAY II @ WARORA	04-Dec-19	09:00	04-Dec-19	17:00	Daily	Bus/Line/Tie CT's Tan delta & Routine Maintenance & Dignostic testing work etc	MSETCL	MSETCL	400KV Bay No 422 charged on No Load
13	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	05-Dec-19	09:00	05-Dec-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
14	400 KV	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-2	05-Dec-19	09:00	05-Dec-19	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
15	400 KV	400KV-KARAD-LONIKHAND-1	05-Dec-19	08:00	05-Dec-19	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	-
16	400 KV	400KV-BHUSAWAL-DEEPNAGAR-2	05-Dec-19	06:00	07-Dec-19	18:00	Daily	For replacement of Faulty string detected in PID	MSETCL	MSETCL	400kv Khadka-Deepnagar-I will be in service
17	400 KV	400KV-JEJURI-KOYNA STAGE IV-1	05-Dec-19	08:00	05-Dec-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical washing work	MSETCL	MSETCL	Jejuri- Lonikand ckt will be in service
18	400 KV	400KV-IEPL-WARORA-1	06-Dec-19	09:00	06-Dec-19	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400KV KORADI-WARDHA Line is in ckt
19	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	06-Dec-19	09:00	06-Dec-19	17:00	Daily	ICT 2 Bay Routine maintenance	MSETCL	MSETCL	ICT 2 Bay routine Maintenance
20	400 KV	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	07-Dec-19	10:00	07-Dec-19	17:00	Daily	PID works	MSETCL	MSETCL	A/R off from both ends
21	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	07-Dec-19	09:00	07-Dec-19	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	-
22	400 KV	400KV-PADGHE-NAGOTHANE-1	09-Dec-19	08:00	09-Dec-19	17:00	Daily	jumper tighting and monkey patrolling	MSETCL	MSETCL	nil
23	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	09-Dec-19	09:00	09-Dec-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
24	400 KV	400KV-TAPTHITHANDA-DEEPNAGAR-1	09-Dec-19	06:00	11-Dec-19	18:00	Daily	For replacement of Faulty string & AMC works	MSETCL	MSETCL	NA
25	400 KV	400KV 125MVAR BUS REACTOR @ KARAD	09-Dec-19	10:00	09-Dec-19	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL	NA
26	400 KV	400KV-JAIGAD-NEW KOYNA-1	09-Dec-19	08:00	09-Dec-19	18:00	Daily	Diagnostic testing & routine maint. work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Jaigad CKT-II line
27	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	10-Dec-19	10:00	10-Dec-19	17:00	Daily	Quarterly Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S
28	400 KV	MAIN BAY (417) OF IEPL @ WARORA	10-Dec-19	08:00	10-Dec-19	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Ckt charged on the Tie CB 418
29	400 KV	400KV/11.5KV TIRODA-ST-4	10-Dec-19	08:00	11-Dec-19	18:00	Continuou s	Maintenance of Bay Equipment	APML	APML	Maintenance of Bay Equipment
30	400 KV	400KV-PARLI-M-NANDED-1	10-Dec-19	09:00	10-Dec-19	18:00	Daily	Quarterly Bay Maintenance	MSETCL	MSETCL	-
31	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	11-Dec-19	10:00	11-Dec-19	18:00	Daily	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUS-I, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.	MSETCL	MSETCL	For successful operation of scheme the outage is necessary.

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
32	400 KV	400KV-JAIGAD-NEW KOYNA-2	11-Dec-19	08:00	11-Dec-19	18:00	Daily	Diagnostic testing & routine maint. work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Jaigad CKT-I line
33	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	11-Dec-19	10:00	11-Dec-19	18:00	Daily	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-1, 220 KV Main bus-1, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.	MSETCL	MSETCL	For successful operation of scheme outage is required.
34	400 KV	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	11-Dec-19	08:00	11-Dec-19	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Bus CT line CT Main CB
35	400 KV	400KV-KOYNA STAGE IV-LONIKHAND-1	12-Dec-19	08:00	12-Dec-19	18:00	Daily	Replacement of suspected faulty polymer string	MSETCL	MSETCL	Stage IV- Jejuri ckt will be in service
36	400 KV	400/220/33KV SPARE ICT @ KORADI 2	12-Dec-19	15:00	12-Dec-19	15:30	Daily	DCRM of CB 431-Q52	MSETCL	MSETCL	Subject to weather condition
37	400 KV	400KV-LONIKHAND-II-LONIKHAND-1 2]	12-Dec-19	10:00	12-Dec-19	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	One and half breaker system , Load will manage on Interconnector I Bay
38	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	12-Dec-19	10:00	12-Dec-19	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	One and half breaker system , Load will manage on Interconnector I Bay
39	400 KV	400KV-LONIKHAND-JEJURI-1	12-Dec-19	09:30	12-Dec-19	17:30	Daily	Annual testing & maint.	MSETCL	MSETCL	-
40	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	12-Dec-19	09:00	12-Dec-19	17:00	Daily	Routine Diagnostic testing & maintenance work	MSETCL	MSETCL	-
41	400 KV	400KV-AURANGABAD-M (WALUJ)-DEEPNAGAR-1	12-Dec-19	06:00	14-Dec-19	18:00	Daily	For replacement of Faulty string & AMC works	MSETCL	MSETCL	NA
42	400 KV	400KV-AKOLA-NANDGAONPETH-1	12-Dec-19	12:00	17-Dec-19	18:00	Daily	PID testing of insulator strings	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth
43	400 KV	400KV-IEPL-KORADI-II-1	13-Dec-19	10:00	13-Dec-19	18:00	Daily	Tan delta measurement of Line CT & CVT	MSETCL	MSETCL	-
44	400 KV	GT 5 @ KORADI	13-Dec-19	09:30	13-Dec-19	18:00	Daily	CVT tan delta	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
45	400 KV	400/220/33 KV 315 MVA ICT - 3 @ PADGHE	13-Dec-19	09:30	13-Dec-19	17:30	Daily	for Checking Tand value of Rph CT Dignostic Testing Work Bay Maint Work	MSETCL	MSETCL	315MVA ICT 2 , 500MVA ICT 5 & 600MVA ICT 4 in service
46	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	14-Dec-19	09:00	14-Dec-19	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	-
47	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	14-Dec-19	06:00	14-Dec-19	18:00	Daily	for Tan delta of CT,DCRM of CB and Isolator and bay maintainance work	MSETCL	MSETCL	NA
48	400 KV	KHADKA-AURANGABAD	16-Dec-19	06:00	19-Dec-19	18:00	Daily	For string replacement work & AMC works	MSETCL	MSETCL	NA
49	400 KV	400KV-CHANDRAPUR-GCR-PARLI-M-3	16-Dec-19	08:00	31-Dec-19	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Nil
50	400 KV	400/220 KV 315MVA ICT - 1 @ KARAD	16-Dec-19	10:00	16-Dec-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S
51	400 KV	400/220 KV 315MVA ICT - 3 @ KARAD	16-Dec-19	9:00	16-Dec-19	18:00	Daily	Quarterly. Maint. Work, LV B/U relay Replacement work	MSETCL	MSETCL	
52	400 KV	400KV-CHANDRAPU-II-NANDED-2	16-Dec-19	08:00	31-Dec-19	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Nil
53	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	16-Dec-19	08:00	16-Dec-19	17:00	Daily	regular maint work	MSETCL	MSETCL	nil
54	400 KV	400KV-CHANDRAPUR-KHAPARKHEDA-1	16-Dec-19	08:00	30-Dec-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
55	400 KV	400KV-KOYNA STAGE IV-NEW KOYNA-1	17-Dec-19	08:00	18-Dec-19	18:00	Daily	Routine maint. Work , Faulty string replacement Work & cold washing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
56	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	17-Dec-19	08:00	17-Dec-19	17:00	Daily	regular maint work	MSETCL	MSETCL	nil
57	400 KV	400KV/11.5KV TIRODA-ST-5	17-Dec-19	08:00	18-Dec-19	18:00	Continuou s	Maintenance of Bay Equipment	APML	APML	Maintenance of Bay Equipment
58	400 KV	400KV-KARAD-KOLHAPUR-MS-1	17-Dec-19	08:00	17-Dec-19	18:00	Daily	Replacement of Disc Insulator String by Porcelain Insulator (Scheme Work)	MSETCL	MSETCL	400KV Karad - Talandge ckt 2 will be in service
59	400 KV	400KV-CHANDRAPU-II-NANDED-1	18-Dec-19	08:00	18-Dec-19	17:00	Daily	For Replacement of Disc Insulator if found During PID Testing	MSETCL	MSETCL	For Replacement of Disc Insulator if found During PID Testing
60	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	18-Dec-19	08:00	18-Dec-19	17:00	Daily	regular maint work	MSETCL	MSETCL	nil
61	400 KV	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-2	18-Dec-19	08:00	18-Dec-19	17:00	Daily	diagnostic testing work	MSETCL	MSETCL	line CT, CB
62	400 KV	400/220/33 KV 315MVA ICT - 3 @ KARAD	18-Dec-19	10:00	18-Dec-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT'S
63	400 KV	400KV-KARAD-KOLHAPUR-MS-2	18-Dec-19	08:00	18-Dec-19	18:00	Daily	Replacement of Disc Insulator String by Porcelain Insulator (Scheme Work)	MSETCL	MSETCL	400KV Karad - Talandge ckt I will be in service
64	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	18-Dec-19	09:30	18-Dec-19	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
65	400 KV	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	19-Dec-19	09:00	19-Dec-19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
66	400 KV	400KV-KOYNA STAGE IV-NEW KOYNA-2	19-Dec-19	08:00	20-Dec-19	18:00	Daily	Routine maint. Work , Faulty string replacement Work & cold washing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
67	400 KV	400KV-JEJURI-KOYNA STAGE IV-1	19-Dec-19	08:00	19-Dec-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical washing work	MSETCL	MSETCL	400KV Jejuri- Lonikand ckt will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
68	400 KV	TBC @ CHAKAN	19-Dec-19	09:00	19-Dec-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
69	400 KV	400KV-LONIKHAND-II-LONIKHAND-1	19-Dec-19	10:00	19-Dec-19	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	One and half breaker system , Load will manage on Interconnector II Bay
70	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	19-Dec-19	10:00	19-Dec-19	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	One and half breaker system , Load will manage on Interconnector II Bay
71	400 KV	400KV-KORADI-KHAPARKHEDA-1	19-Dec-19	09:00	19-Dec-19	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage is proposed by LM S/Dn Koradi
72	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	19-Dec-19	09:30	19-Dec-19	17:30	Daily	Annual testing & maint.	MSETCL	MSETCL	-
73	400 KV	400KV-LONIKHAND-JEJURI-1	19-Dec-19	08:00	19-Dec-19	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	-
74	400 KV	400KV-BHUSAWAL-BABLESHWAR-1	20-Dec-19	06:00	23-Dec-19	18:00	Daily	For string replacement work & AMC work	MSETCL	MSETCL	NA
75	400 KV	400KV-NANDGAONPETH-KORADI-1	20-Dec-19	09:30	20-Dec-19	18:00	Daily	CT Tan delta and CRM work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
76	400 KV	400KV-KORADI-KHAPARKHEDA-II	20-Dec-19	09:00	20-Dec-19	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage is proposed by LM S/dn Koradi
77	400 KV	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-1	20-Dec-19	08:00	20-Dec-19	17:00	Daily	For Conductor & Earthwire Hardware tightening work	MSETCL	MSETCL	For Conductor & Earthwire Hardware tightening work
78	400 KV	400KV-KARAD-JAIGAD-1	20-Dec-19	08:00	20-Dec-19	18:00	Daily	OUTAGE WORK	JPTL	JPTL	INSULATOR REPLACEMENT WORKS
79	400 KV	400KV-KARAD-JAIGAD-2	21-Dec-19	08:00	21-Dec-19	18:00	Daily	OUTAGE WORK	JPTL	JPTL	INSULATOR REPLACEMENT
80	400 KV	400KV-BHUSAWAL-AURANGABAD-M (WALUJ)-1	21-Dec-19	10:00	21-Dec-19	17:00	Daily	PID works	MSETCL	MSETCL	PID works A/R off both ends
81	400 KV	400KV-JAIGAD-NEW KOYNA-1	22-Dec-19	08:00	22-Dec-19	18:00	Daily	OUATAGE WORK	JPTL	JPTL	INSULATOR REPLACEMENT
82	400 KV	400KV-JAIGAD-NEW KOYNA-2	23-Dec-19	08:00	23-Dec-19	18:00	Daily	OUTAGE WORK	JPTL	JPTL	INSULATOR REPLACEMENT
83	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	23-Dec-19	08:00	24-Dec-19	18:00	Daily	CTR Make fire fighting system maintenance work & Dignostic testing work	MSETCL	MSETCL	Load can be managed on 315MVA ICT I
84	400 KV	400KV-KARAD-KOLHAPUR-MS-1	23-Dec-19	08:00	23-Dec-19	18:00	Daily	Replacement of Disc Insulator String by Procelain Insulator (Scheme Work)	MSETCL	MSETCL	400KV Karad - Talandge 2 ckt will be in service
85	400 KV	400KV-PARLI-M-NANDED-2	23-Dec-19	09:00	23-Dec-19	18:00	Daily	Reactor backup relay testing work.	MSETCL	MSETCL	-
86	400 KV	400KV-KARAD-KOLHAPUR-MS-2	24-Dec-19	08:00	24-Dec-19	18:00	Daily	Replacement of Disc Insulator String by Procelain Insulator (Scheme Work)	MSETCL	MSETCL	400KV Karad - Talandge I ckt will be in service
87	400 KV	400KV-JEJURI-KOYNA STAGE IV-1	25-Dec-19	08:00	25-Dec-19	18:00	Daily	Replacement of suspected faulty polymer string & Chemical & Cold washing work	MSETCL	MSETCL	400KV Jejuri- Lonikand ckt will be in service
88	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	25-Dec-19	10:00	25-Dec-19	18:00	Daily	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUS-II, Spare ICT and 400 kv PGCIL Line outage is also required.	MSETCL	MSETCL	For successful operation of scheme outage is required.
89	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	25-Dec-19	10:00	25-Dec-19	18:00	Daily	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUS-II, Spare ICT and 400 kv PGCIL Line outage is also required. 400 KV Bus reactor will be out of service.	MSETCL	MSETCL	For successful operation of scheme outage is required.
90	400 KV	400KV-JEJURI-KOYNA STAGE IV-1	26-Dec-19	08:00	26-Dec-19	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	-
91	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	26-Dec-19	09:00	26-Dec-19	19:00	Daily	HV & IV protn. Relay testing work.	MSETCL	MSETCL	-
92	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	26-Dec-19	09:30	26-Dec-19	17:30	Daily	Annual testing & maint.	MSETCL	MSETCL	-
93	400 KV	400KV-KOYNA STAGE IV-LONIKHAND-1	26-Dec-19	08:00	26-Dec-19	18:00	Daily	Replacement of suspected polymer string & Cold washing work on disc Insulator	MSETCL	MSETCL	400KV Stage4- Jejuri ckt will be in service
94	400 KV	400KV-AKOLA-NANDGAONPETH-1	27-Dec-19	08:00	28-Dec-19	18:00	Daily	replacement of faulty strings having 03 & above no. of punctured discs	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
95	400 KV	TIE BAY (423) OF STATION TF - 1 @ KORADI 2	27-Dec-19	10:00	27-Dec-19	13:00	Daily	DCRM of CB 423-Q52	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Main Bay 422
96	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	27-Dec-19	09:30	27-Dec-19	18:00	Daily	DFRA test	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
97	400 KV	400KV-DHULE-MS-BABLESHWAR-1	28-Dec-19	08:00	28-Dec-19	18:00	Daily	PID work will be carried out on 16 to 27 DEC. 2019. if any strings found suspicious, it will be replaced in this proposed outage.	MSETCL	MSETCL	B8LR-II A/R SHOULD BE KEPT ON NON AUTO MODE.
98	400 KV	400KV-DHULE-MS-BABLESHWAR-2	30-Dec-19	08:00	30-Dec-19	18:00	Daily	PID work will be carried out on 16 to 27 DEC. 2019. if any strings found suspicious, it will be replaced in this proposed outage.	MSETCL	MSETCL	B8LR-I A/R SHOULD BE KEPT IN NON AUTO MODE.