

Maharashtra State Load Despatch Centre										
WRPC OCCM approved Monthly Outage list for the Month of December 2020										
Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
1	2	MSETCL	400KV-SSP-DHULE-MS-2	1-Dec-20	07:00	1-Dec-20	18:00	Daily	Replacement of damaged earthwire ,PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
2	3	MSETCL	220KV-PARLI-PARLI-M-1	1-Dec-20	08:00	1-Dec-20	17:00	Daily	Tightening of loose nut bolts of Cut Point Locations - 1, 3, 5, 9.	-
3	12	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	1-Dec-20	09:00	1-Dec-20	13:00	Daily	AMR Meter commissioning Quarterly Maint. Work & Diagnostic Testing Work	Tuesday is staggering day for Sangli District
4	13	MSETCL	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV	1-Dec-20	09:00	1-Dec-20	17:00	Daily	Routine maintenance and diagnostics testing such as CT tandelta.	Only Tie CB 412 is in OFF condition ,respective ckt charged through its own main CB.
5	21	POWERGRID_WRI	400KV-AKOLA-AURANGABAD-1	1-Dec-20	9:00	1-Dec-20	18:00	Daily	For AMP of Line Bay at Akola end & 400KV-Akola-Aurangabad-2 AR to be kept in Non-auto mode for safety of precautions.	
6	30	MSETCL	400KV-ALKUD-SOLAPUR-1	1-Dec-20	14:00	1-Dec-20	18:00	Daily	AMR Meter commissioning Quarterly Maint. Work & Diagnostic Testing Work	Tuesday is staggering day for Sangli District
7	45	POWERGRID_WRI	400KV-PADGHE-BOISAR-1	1-Dec-20	10:00	8-Dec-20	17:00	Continuous	Recommissioning of old DTLL make CB with new GE make CB for 400 KV Boisar Line Bay at Padghe MSETCL. Line shall be in service with TBC bay at Padghe and if TBC bay is not free then line sd is	
8	47	MSETCL	BABLESHWAR - 400KV B/R 1 ON TBC	1-Dec-20	09:00	12-Dec-20	18:00	Continuous	400kV CGL make CB pole and mechanism overhauling work	400kV Reactor I on TBC
9	52	MSETCL	400KV-KALWA-PADGHE-2	1-Dec-20	09:00	5-Dec-20	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
10	55	MSETCL	400KV-BABLESHWAR-PADGHE-1	1-Dec-20	08:00	10-Dec-20	18:00	Daily	For Carrying PID Work	-
11	58	MSETCL	400KV-WARORA-CHANDRAPU-II-1	1-Dec-20	08:00	12-Dec-20	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	for PID Testing Work,shifting autoreclose switch to Non auto Mode
12	59	MSETCL	400KV-WARORA-CHANDRAPU-II-2	1-Dec-20	08:00	12-Dec-20	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	for PID Testing Work,shifting autoreclose switch to Non auto Mode
13	60	MSETCL	JEJURI - 400KV - BUS 2	1-Dec-20	10:00	15-Dec-20	18:00	Daily	Online PID testing work.	1) On Thursdays regular Scheduled outages will be carried out and PID work will not be done. 2) The work on 220 kV Main Bus I and 220kV Main Bus II will be carried out alternately.
14	61	MSETCL	JEJURI - 400KV - BUS 1	1-Dec-20	10:00	15-Dec-20	18:00	Daily	Online PID testing work.	1) On Thursdays regular Scheduled outages will be carried out and PID work will not be done. 2) Work on 220 kV Main Bus I and 220kV Main Bus II will be carried out alternately.
15	65	MSETCL	220KV-Wardha-PUSAD-1	1-Dec-20	07:00	31-Dec-20	17:00	Daily	PID Work	NIL
16	71	MSETCL	400KV-KARAD-KOLHAPUR-MS-1	1-Dec-20	08:00	31-Dec-20	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
17	72	MSETCL	400KV-KOYNA STAGE IV-LONIKHAND-1	1-Dec-20	08:00	31-Dec-20	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
18	73	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	1-Dec-20	08:00	31-Dec-20	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
19	74	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	1-Dec-20	08:00	31-Dec-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt-III These lines are on DC tower so both lines require on same day A/R out.
20	75	MSETCL	400KV-CHANDRAPU-II-NANDED-2	1-Dec-20	08:00	31-Dec-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt-III These lines are on DC tower so both lines require on same day A/R out.

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
21	76	MSETCL	400KV-KARAD-KOLHAPUR-MS-2	1-Dec-20	08:00	31-Dec-20	17:00	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
22	87	MSETCL	400KV-DHULE-DHULE-MS-1	1-Dec-20	08:00	31-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-1 will be kept on Non Auto mode
23	90	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	1-Dec-20	10:00	31-Dec-20	18:00	Daily	PID Testing Work	Bypass Auto reclosure Switch. Without Load Interruption
24	109	MSETCL	400KV-SSP-DHULE-MS-1	2-Dec-20	08:00	2-Dec-20	18:00	Daily	Replacement of damaged earthwire , replacement PID suspicious disc insulator and other maintenance work	00kV SSNNL-2 A/R switch will be kept on non auto mode
25	110	MSETCL	132KV-MANSAR-MS-KANHAN-1	2-Dec-20	08:00	2-Dec-20	18:00	Daily	Routine Maintenance work.	Outage proposed by LM S/dn Kanhan
26	118	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	2-Dec-20	09:00	2-Dec-20	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	only Tie CB 421 is in OFF condition ,respective ekt charged through its own main CB.
27	119	MSETCL	220KV-PARLI-PARLI-M-2	2-Dec-20	09:00	2-Dec-20	17:00	Daily	line maintenance work	-
28	129	POWERGRID_WR1	220KV-AURANGABAD-CHITEGAON-2	2-Dec-20	9:00	2-Dec-20	18:00	D	for line CT AMP works	
29	134	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	2-Dec-20	09:00	2-Dec-20	18:00	Daily	Bay Maintenance Activities	Main Bay 404
30	148	GETCO	400 kV-SSP-Dhule-MS-1	2-Dec-20	7:00	2-Dec-20	18:00	Daily	Maintenance work. Auto reclose of 400 kV SSP - Dhule line No. 2 will remain out.	
31	150	MSETCL	SOLAPUR-M - 400KV - BUS 2	2-Dec-20	10:00	2-Dec-20	18:00	Daily	Routine Maintenance. Diagnostic Testing work.	400kV LBT -Parali & 400kV LBT-PGCIL will be in service via Tie Bay
32	151	MSETCL	400KV-SSP-DHULE-MS-2	2-Dec-20	08:00	3-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
33	152	MSETCL	400KV-BHUSAWAL-AKOLA-1	2-Dec-20	08:00	5-Dec-20	17:00	Continuous	For the overhauling of own circuit breaker and Bus-1&2 P.G isolator	During the above period line will be shifted on 400KV TBC(A/R Out)
34	160	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	3-Dec-20	7:00	3-Dec-20	18:00	Daily	For Replacement of Porcelain insulators at River crossing locations & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AR to be kept in Non-auto mode for safety of precautions. Dia to be kept open .	
35	164	MSETCL	400KV-CHAKAN-PUNE-PG-1	3-Dec-20	08:00	3-Dec-20	18:00	Daily	Line Maintenance work	---
36	179	POWERGRID_WR1	220KV-AURANGABAD-SHENDRA-1	3-Dec-20	9:00	3-Dec-20	18:00	Daily	for line CT AMP works	
37	182	MSETCL	400KV-KOLHAPUR-MS-Kolhapur GIS-1	3-Dec-20	09:00	3-Dec-20	18:00	Daily	Annual Maintenance Work.	Combine Testing & maintenance work with M/s PGCIL.
38	183	MEGPTCL	AKOLA (2) - 400KV - BUS 1	3-Dec-20	09:00	3-Dec-20	19:00	Daily	Maintenance of Bus Related Equipments	400KV BUS - 1
39	186	MSETCL	TIE BAY - 400KV/11.5KV KORADI-II-ST-3 AND 400KV-KORADI-II-KORADI-III-2 at KORADI-II - 400KV	3-Dec-20	10:00	3-Dec-20	14:00	Daily	Tan delta measurement of BCT of Bay 405	1)Station Transformer-III will remain in service through Main bay 404 And 2) Koradi-II Koradi-III Ckt.-2 will remain in service through Main Bay 406
40	213	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	4-Dec-20	09:00	4-Dec-20	18:00	Daily	1. For replacement of faulty Main-1 distance relay with new at 400kV Girwali S/S. 2.Bay maintenance work.	-
41	218	MEGPTCL	765KV/400KV KORADI-III-ICT-2	4-Dec-20	08:00	4-Dec-20	18:00	Daily	Maintenance of ICT	ICT - 2
42	219	MSETCL	400KV-SSP-DHULE-MS-2	4-Dec-20	08:00	4-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
43	227	MSETCL	TIE BAY (415) OF CHANDRAPUR-2 & ADANI - 2 @ WARORA	4-Dec-20	09:00	4-Dec-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work	Only Tie CB 415 is in OFF condition ,respective ckt charged through its own main CB.
44	228	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	4-Dec-20	09:00	4-Dec-20	17:30	Daily	Replacement of Rph CB pole to Stub bus jumper Attending Hot Spot on Bph stub bus to CB pole jumper at stub bus Diagnostic testing work.	400 KV Tie Breaker will in service at 500 HVDC Terminal.
45	237	MSETCL	400KV-KOLHAPUR-MS-Kolhapur GIS-2	4-Dec-20	09:00	4-Dec-20	18:00	Daily	Annual Maintenance Work	Combine Testing & Maintenance with M/s PGCIL
46	244	MSETCL	400KV/220KV DEEPNAGAR-ICT-2	4-Dec-20	08:30	5-Dec-20	18:00	Daily	for quarterly bay maintenance work for HV & LV bay	bay maint is due
47	268	MSETCL	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	5-Dec-20	10:00	5-Dec-20	17:00	Daily	DCRM of CB 406-Q52 Tan delta measurement of Bus CT at Bay406	400KV Koradi-II Koradi-III Ckt.-II will remain in service through Tie Bay 405
48	274	MSETCL	400KV/220KV BABLESHWAR-ICT-2	5-Dec-20	08:00	5-Dec-20	18:00	Daily	LTS relay retrofitting	400/220kV 315MVA ICT- I & 501 MVA ICT -III& 501 MVA ICT-IV will be in service
49	275	MSETCL	400KV-SSP-DHULE-MS-1	5-Dec-20	08:00	5-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
50	276	MSETCL	400KV-SSP-DHULE-MS-2	5-Dec-20	08:00	5-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
51	281	MSETCL	MAIN BAY (413) OF CHANDRAPUR ckt-1 @ WARORA	5-Dec-20	09:00	5-Dec-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	Chandrapur 2 ckt 1 charged through the Tie CB 412.
52	282	MSETCL	400KV-BABLESHWAR-PADGHE-1	5-Dec-20	09:00	5-Dec-20	17:00	Daily	CT & CVT C & tan D testing	400kV Padghe ckt II will be inservice
53	310	MSETCL	400KV-KALWA-PADGHE-1	6-Dec-20	08:00	6-Dec-20	18:00	Daily	Routine Maintenance work	Routine Maintenance work
54	315	POWERGRID_WRI	400KV-AKOLA-AURANGABAD-2	7-Dec-20	9:00	7-Dec-20	18:00	Daily	For AMP of Line Bay at Akola end & 400KV-Akola-Aurangabad-1 AR to be kept in Non-auto mode for safety of precautions.	
55	317	POWERGRID_WRI	220KV-AURANGABAD-SHENDRA-2	7-Dec-20	9:00	7-Dec-20	18:00	Daily	for line CT AMP works	
56	328	MSETCL	400KV-SSP-DHULE-MS-2	7-Dec-20	08:00	7-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
57	347	MEGPTCL	AKOLA (2) - 400KV - BUS 2	7-Dec-20	09:00	7-Dec-20	19:00	Daily	Maintenance of Bus Related Equipments	400KV BUS - 2
58	358	MSETCL	MAIN BAY (417) OF IEPL @ WARORA	7-Dec-20	09:00	9-Dec-20	17:00	Continuous	CB overhauling ,replacement of Dynamic contact.	400KV IEPL ckt charged through the Tie CB 418
59	362	MSETCL	BUS COUPLER BAY - BHUSAWAL - 400KV - BUS 1 AND BHUSAWAL - 400KV - BUS 2 at BHUSAWAL - 400KV	7-Dec-20	08:00	10-Dec-20	17:00	Continuous	For the overhauling of own circuit breaker and isolator For the overhauling of own circuit breaker and Bus-1&2 P.G isolator	NA
60	363	MSETCL	KOLHAPUR-MS - 400KV - BUS 1	7-Dec-20	09:00	13-Dec-20	18:00	Continuous	1.Replacement of faulty Bus strings. 2. Annual Bus isolator Maintenance by 1 by 1 TBC shifing of all 220kV Bays. 3. Annual PT/CVT testing.	1.Load will be managed on 220kV Main Bus 2. 2. TBC Shifing of all bays CBs are required during outage for Bus Isolator Maintenance.
61	369	MSETCL	400KV-KALWA-PADGHE-1	7-Dec-20	09:00	12-Dec-20	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto- Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
62	370	MSETCL	400KV/220KV PARLI-M-ICT-1	8-Dec-20	09:00	9-Dec-20	18:00	Continuous	1. Replacement of 400kV (HV) & 33kV (LV) Bushings of R Phase Unit due to high Tan D values 2. C & Tan delta measurement of Bushing & wdg of ICT Units. 3. Bay maintenance work.	Complete oil drain is required. Complete Filtration process to follow. ICT-II & III will be in service
63	377	MSETCL	220KV-PARLI-PARLI-M-1	8-Dec-20	08:00	8-Dec-20	17:00	Daily	Tightening of loose nut bolts of Cut Point Locations - 11, 17, 21, 23.	-
64	380	MSETCL	400KV-SSP-DHULE-MS-1	8-Dec-20	08:00	8-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
65	400	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND FUTURE at KORADI-III - 400KV	8-Dec-20	09:00	8-Dec-20	18:00	Daily	Bay Maintenance Activities	Tie Bay 405

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
66	409	MSETCL	220KV-NASIK-NAVSARI-1	8-Dec-20	08:00	9-Dec-20	18:00	Daily	maintenance work	-
67	410	MSETCL	220KV-Wardha-BHUGAON-1	8-Dec-20	08:00	9-Dec-20	18:00	Daily	Routine line maintainace work	NA
68	423	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	8-Dec-20	09:00	12-Dec-20	17:00	Continuous	Samrudhhi Highway crossing 400kV Tower erection & dismantaling .	400kV Ektuni ckt I&II,400kV Bhusawal and lines will be in service
69	424	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	8-Dec-20	09:00	12-Dec-20	17:00	Continuous	Samrudhhi Highway crossing 400kV Tower erection & dismantaling .	400kV Ektuni ckt I&II,400kV Bhusawal and lines will be in service
70	438	MSETCL	400KV-RGPPL-NAGOTHANE-1	9-Dec-20	08:00	9-Dec-20	17:00	Daily	Emergency tree cutting work	nil
71	439	MSETCL	400KV-WARORA-CHANDRAPU-II-1	9-Dec-20	08:00	9-Dec-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	For Conductor & Earthwire H/W tightening work
72	444	MSETCL	132KV-PENCH-KANHAN-1	9-Dec-20	08:00	9-Dec-20	18:00	Daily	Routine Maintenance work.	Outage proposed by LM Kanhan S/DN
73	449	POWERGRID_WR1	400KV-KALA-KUDUS-1	9-Dec-20	9:00	9-Dec-20	17:00	DAILY	AMP OF KALA KUDUS LINE 1 EQUIPMENTS/RELAY TESTING at Kudus End.	
74	450	MSETCL	400KV-Wardha-WARORA-1	9-Dec-20	09:00	9-Dec-20	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL Line is in ckt
75	463	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	9-Dec-20	09:30	9-Dec-20	18:00	Daily	Hardware Tightening and Fitting Work.	-
76	464	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	9-Dec-20	10:00	9-Dec-20	14:00	Daily	Testing of ICT	ICT - 1
77	466	MSETCL	SOLAPUR-M - 400KV - BUS 1	9-Dec-20	10:00	9-Dec-20	18:00	Daily	Routine Maintenance. Diagnostic Testing Work.	420kV, 125Mvar Bus Reactor will be out of Service.
78	472	MSETCL	220KV-PANDURNA-KALMESHVAR-1	9-Dec-20	08:00	9-Dec-20	18:00	Daily	Routine Maintenance work.	Outage proposed by LMU S/Dn Mankapur
79	481	MSETCL	400KV-RGPPL-NAGOTHANE-2	10-Dec-20	08:00	10-Dec-20	17:00	Daily	Emergency tree cutting work	nil
80	482	MSETCL	400KV-WARORA-CHANDRAPU-II-2	10-Dec-20	08:00	10-Dec-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	For Conductor & Earthwire H/W tightening work
81	498	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	10-Dec-20	9:00	10-Dec-20	18:00	Daily	For Reactor AMP works, After completion of AMP works, reactor will be charged through TBC.	
82	507	MEGPTCL	TIE BAY - 400KV-KORADI-II-KORADI-III-2 AND FUTURE at KORADI-III - 400KV	10-Dec-20	09:00	10-Dec-20	18:00	Daily	Bay Maintenance Activities	Tie Bay 408
83	511	POWERGRID_WR1	PUNE-PG - 400KV - BUS 2	10-Dec-20	9:00	10-Dec-20	18:00	Daily	For rectification of Conductor unwind	
84	515	MSETCL	220KV-NASIK-NAVSARI-2	10-Dec-20	09:00	11-Dec-20	18:00	Daily	maintenance work	-
85	520	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	10-Dec-20	9:00	12-Dec-20	18:00	C	Bus reactor CB mechanism overhauling works & Outage required on CB only for mechanism overhauling works. Reactor will be in service through TBC.	
86	528	POWERGRID_WR1	400KV-LONIKHAND-PUNE-PG-1	11-Dec-20	9:00	11-Dec-20	18:00	Daily	For AMP Work	
87	531	MSETCL	400KV-LONIKHAND-PUNE-PG-1	11-Dec-20	08:00	11-Dec-20	18:00	Daily	Line Maintenance work.	---
88	539	MSETCL	400KV-SSP-DHULE-MS-1	11-Dec-20	08:00	11-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
89	540	MSETCL	400KV-SSP-DHULE-MS-2	11-Dec-20	08:00	11-Dec-20	18:00	Continuous	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
90	547	POWERGRID_WR1	400KV-KALA-KUDUS-2	11-Dec-20	9:00	11-Dec-20	17:00	DAILY	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTING AT KUDUS END.	
91	548	MSETCL	400KV-Wardha-KORADI-II-1	11-Dec-20	09:00	11-Dec-20	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
92	559	MSETCL	220KV-Wardha-PUSAD-1	11-Dec-20	08:00	12-Dec-20	18:00	Daily	Routine line maintainace work	NA
93	568	MSETCL	400KV-BABLESHWAR-PADGHE-2	11-Dec-20	08:00	20-Dec-20	18:00	Daily	For Carrying PID Work	-
94	569	MSETCL	220KV-BOISAR-NALASOPARA-1	12-Dec-20	09:00	12-Dec-20	17:00	Daily	Routine Maintenance work	Routine Maintenance work
95	575	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-1	12-Dec-20	9:00	12-Dec-20	18:00	D	For AMP Work	
96	581	MSETCL	400KV-SSP-DHULE-MS-2	12-Dec-20	08:00	12-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
97	590	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND FUTURE at KORADI-III - 400KV	12-Dec-20	09:00	12-Dec-20	19:00	Daily	Bay maintenance Activities	Tie Bay 402
98	592	MSETCL	220KV-TALEGAON-PUNE-PG-1	12-Dec-20	10:00	12-Dec-20	17:00	Daily	Half yearly maintenance , Diagonastic Testing	--
99	594	MSETCL	400KV-RGPPL-NEW KOYNA-1	12-Dec-20	09:00	13-Dec-20	18:00	Daily	Faulty string replacement Work & cold washing	Planned outage
100	600	MSETCL	220KV-BOISAR-BOISAR-M-2	13-Dec-20	09:00	13-Dec-20	17:00	Daily	POST MANSOON MAINTENANCE WORK	POST MANSOON MAINTENANCE WORK
101	603	MEGPTCL	AKOLA (2) - 765KV - BUS 1	13-Dec-20	09:00	13-Dec-20	19:00	Daily	Maintenance of Bus Related Equipments	765KV BUS - 1
102	607	MSETCL	400KV-SSP-DHULE-MS-2	13-Dec-20	08:00	14-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
103	608	MSETCL	400KV-KORADI-BHUSAWAL-1	13-Dec-20	09:00	26-Dec-20	18:00	Continuous	Proposal for shifting of 400kV Bhusawal on TBC for CB pole overhauling work and CB DCRM,CRM, timing	Outages will be availed subject to weather conditions.
104	616	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	14-Dec-20	7:00	14-Dec-20	18:00	D	For Replacement of Porcelain insulators at River crossing locations & 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AR to be kept in Non-auto mode for safety of precautions. Dia to be kept open .	
105	632	MSETCL	400KV-SSP-DHULE-MS-1	14-Dec-20	08:00	14-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
106	648	MSETCL	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2 at PARLI-M - 400KV	14-Dec-20	09:00	14-Dec-20	18:00	Daily	Replacement of old 400kV TELK make Circuit Breaker by New Siemens make CB as TELK CB is obsolete	400kV Main-I & II Buses will run seperately.
107	649	MEGPTCL	AKOLA (2) - 765KV - BUS 2	14-Dec-20	09:00	14-Dec-20	19:00	Daily	Maintenance of Bus Related Equipments	765KV BUS - 2
108	661	MSETCL	400KV-RGPPL-NAGOTHANE-1	14-Dec-20	09:00	16-Dec-20	18:00	Daily	Faulty string replacement Work & cold washing	Planned outage
109	663	MSETCL	400KV-KHARGHAR-PUNE-PG-1	14-Dec-20	09:00	19-Dec-20	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
110	664	MSETCL	400KV-KALWA-PUNE-PG-1	14-Dec-20	09:00	26-Dec-20	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
111	668	BDTCL	DHULE - 400KV - BUS 1	15-Dec-20	8:00	15-Dec-20	18:00	D	Sf6 gas analysis	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
112	669	MSETCL	AURANGABAD-M (WALUJ) - 400KV - BUS 1	15-Dec-20	09:00	15-Dec-20	17:00	Daily	Quarterly Maintenance	Quarterly Maintenance
113	677	MSETCL	400KV-CHANDRAPU-II-NANDED-2	15-Dec-20	08:00	15-Dec-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt-III. These lines are on DC tower so both lines require on same day A/R out.
114	699	POWERGRID_WR1	400kV-WARDHA-AKOLA-2	15-Dec-20	9:00	15-Dec-20	18:00	D	For AMP of Line Bay at Akola end & 400KV-Akola-Wardha-1 AR to be kept in Non-auto mode for safety of precautions.	
115	702	POWERGRID_WR1	400kV-WARDHA-AKOLA-2	15-Dec-20	9:00	15-Dec-20	18:00	D	For Insulator Replacement Works & 400KV-WARDHA-AKOLA-1 A/R to be kept in non auto mode for safety measures.	
116	723	MSETCL	400KV-BHUSAWAL-BABLESHWAR-1	15-Dec-20	09:00	19-Dec-20	17:00	Continuous	Samrudhhi Highway crossing 400kV Tower erection & dismantaling . Also CB Time,DCRM,CRM, CVT C & Tan D, M1&M2 relay Testing	400kV Ektuni cktI& II,400kV Aurangabad, 400kV Dhule I&II lines will be in in service
117	725	MSETCL	400KV-BHUSAWAL-BABLESHWAR-1	15-Dec-20	09:00	30-Dec-20	18:00	Continuous	400kV CGL make CB pole and mechanism overhauling work	Own CB will be taken on TBC
118	734	BDTCL	DHULE - 400KV - BUS 2	16-Dec-20	10:00	16-Dec-20	18:00	D	Sf6 gas analysis	
119	739	MSETCL	400KV-CHANDRAPUR-GCR-PARLI-M-3	16-Dec-20	10:00	16-Dec-20	18:00	Daily	line maintenance work	-
120	741	POWERGRID_WR1	400kV-WARDHA-AKOLA-1	16-Dec-20	7:00	16-Dec-20	18:00	D	For Insulator Replacement Works & 400KV-WARDHA-AKOLA-2 A/R to be kept in non auto mode for safety measures.	
121	747	MSETCL	132KV-MANSAR-MS-PENCH-1	16-Dec-20	08:00	16-Dec-20	18:00	Daily	Routine Maintenance work.	Outage proposed by LM Kanhan S/Dn
122	755	TATA	220KV-PARLI-OSMANABAD-M-1	16-Dec-20	09:00	16-Dec-20	17:00	Daily	Line maintenance	-
123	758	POWERGRID_WR1	400KV-KORADI-SATPURA	16-Dec-20	9:00	16-Dec-20	18:00	D	For AMP works & PLCC Work, Line work permit shall be provided	
124	765	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	16-Dec-20	09:00	16-Dec-20	18:00	Daily	Bay Maintenance Activities	Tie Bay 702
125	766	MSETCL	AKOLA - 400KV - BUS 1	16-Dec-20	09:00	16-Dec-20	18:00	Daily	Routine maintenance & testing work	Main Bus-2 will be in service
126	780	MSETCL	400KV/220KV SOLAPUR-M-ICT-2	16-Dec-20	10:00	18-Dec-20	18:00	Continuous	For Replacement of IV Bushing of B-Phase Unit.	Load will be Managed on ICT I & 220kV Grid.
127	781	MSETCL	400KV/220KV BHUSAWAL-ICT-3	16-Dec-20	08:00	19-Dec-20	17:00	Continuous	For the overhauling of own circuit breaker and Bus-1&2 P.G isolator	During the above period ICT-3 HV Side will be shifted on 400KV TBC
128	786	MSETCL	400KV-SSP-DHULE-MS-2	16-Dec-20	08:00	17-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
129	799	MSETCL	400KV-LONIKHAND-CHAKAN-1	17-Dec-20	09:00	17-Dec-20	18:00	Daily	Diagnostic testing and maintenance activities.	---
130	803	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-2	17-Dec-20	09:00	18-Dec-20	18:00	Daily	1)Measurement of Contact Resistance of CB. Routine maintenance work	Outage will be availed subjected to weather conditions.
131	805	MSETCL	765KV/400KV EKTUNI-ICT-1	17-Dec-20	10:00	17-Dec-20	18:00	Daily	"Diagnostic Testing & Routine Maintainece "	765kV, 1500MVA ICT-II Will be in service
132	808	POWERGRID_WR1	400KV-BHILAI-KORADI	17-Dec-20	7:00	17-Dec-20	18:00	D	For AMP works & PLCC Work, Line work permit shall be provided,	
133	809	POWERGRID_WR1	400kV-WARDHA-AKOLA-2	17-Dec-20	7:00	17-Dec-20	18:00	D	For Insulator Replacement Works & 400KV-WARDHA-AKOLA-1 A/R to be kept in non auto mode for safety measures.	
134	813	MSETCL	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	17-Dec-20	08:00	17-Dec-20	18:00	Daily	Routine Diagnostic testing and bay maintenance work.	---

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
135	824	APML	400KV/11.5KV TIRODA-ST-5	17-Dec-20	09:00	17-Dec-20	18:00	Daily	Transformer maintenance Activities	-
136	826	MSETCL	PARLI - LONIKAND 2 CKT 1	17-Dec-20	09:30	17-Dec-20	18:00	Daily	Hardware Tightening and Fitting Work.	-
137	827	MSETCL	EKTUNI - 765KV B/R 1	17-Dec-20	10:30	17-Dec-20	18:00	Daily	"Diagnostic Testing & Routine Maintainece "	765kV Bus Reactor will be out of service.
138	834	MSETCL	400KV-KALWA-PADGHE-2	17-Dec-20	09:00	19-Dec-20	17:30	Continuous	400kV Kalwa 2 on TBC for Bus isolator replacement work	M/s Bimco Hyderabad & S & S Hyderabad will be present for isolator replcement work .
139	836	MSETCL	400KV-RGPPL-NAGOTHANE-2	17-Dec-20	09:00	19-Dec-20	18:00	Daily	Faulty string replacement Work & cold washing	Planned outage
140	856	MSETCL	AKOLA - 400KV - BUS 2	18-Dec-20	09:00	18-Dec-20	18:00	Daily	Routine maintenance & testing work	Main Bus -01 will be in service
141	859	POWERGRID_WRI	400kV-WARDHA-AKOLA-1	18-Dec-20	7:00	18-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-2 A/R to be keep in non auto mode for safety measures.	
142	870	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	18-Dec-20	09:00	18-Dec-20	17:00	Daily	Post Monsoon Maintenance work	Post Monsoon Maintenance work
143	878	APML	400KV/11.5KV TIRODA-ST-5	18-Dec-20	09:00	18-Dec-20	18:00	Daily	Transformer maintenance Activities	-
144	890	MSETCL	BOISAR-M - 220KV - BUS 2	19-Dec-20	08:00	20-Dec-20	20:00	Continuous	Bus Isolator Maintenance, PT Diagnostic.	Bus Isolator Maintenance, PT Diagnostic.
145	899	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	19-Dec-20	09:00	19-Dec-20	18:00	Daily	Half yearly line maintenance and diagnostic testing work.	---
146	903	POWERGRID_WRI	400kV-WARDHA-AKOLA-2	19-Dec-20	7:00	19-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-1 A/R to be keep in non auto mode for safety measures.	
147	907	MSETCL	400KV-SSP-DHULE-MS-1	19-Dec-20	08:00	19-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
148	917	MSETCL	220KV-TALEGAON-PUNE-PG-2	19-Dec-20	10:00	19-Dec-20	17:00	Daily	Half yearly maintenance , Diagonastic Testing	--
149	922	MSETCL	400KV-SSP-DHULE-MS-2	19-Dec-20	08:00	31-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
150	927	MSETCL	765KV/400KV EKTUNI-ICT-2	20-Dec-20	10:00	20-Dec-20	18:00	Daily	"Diagnostic Testing & Routine Maintainece "	765kV, 1500MVA ICT-1 Will be in service
151	933	POWERGRID_WRI	400kV-WARDHA-AKOLA-1	20-Dec-20	7:00	20-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-2 A/R to be keep in non auto mode for safety measures.	
152	934	MSETCL	400KV-SSP-DHULE-MS-2	20-Dec-20	08:00	20-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
153	939	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	21-Dec-20	09:00	21-Dec-20	17:00	Daily	POST MANSOON MAINTENANCE WORK	POST MANSOON MAINTENANCE WORK
154	940	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	21-Dec-20	10:00	21-Dec-20	14:00	Daily	Line Equipment Maintenance Activities	-
155	941	POWERGRID_WRI	400kV-WARDHA-AKOLA-2	21-Dec-20	7:00	21-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-1 A/R to be keep in non auto mode for safety measures.	
156	945	MSETCL	NAGOTHANE - 400KV - BUS 1	21-Dec-20	08:00	21-Dec-20	17:00	Daily	Regular maintenance work	nil
157	951	MSETCL	400KV-SSP-DHULE-MS-2	21-Dec-20	08:00	21-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
158	958	POWERGRID_WRI	400KV-Wardha-WARORA-PG-1	21-Dec-20	9:00	21-Dec-20	18:00	D	Relay testing work at Warora end & for line AMP works 400KV-Wardha-WARORA-PG-2 A/R to be keep in non auto mode for safety measures.	
159	977	MSETCL	KOLHAPUR-MS - 400KV - BUS 1	21-Dec-20	09:00	27-Dec-20	18:00	Continuous	1. Replacements of faulty Bus Strings. 2. Replacement of Bus Hangers. 3. Annual Bus Maintenance work.	Load will be managed on 400kV Main Bus 2
160	981	MSETCL	400KV-KALWA-KHARGHAR-1	21-Dec-20	09:00	26-Dec-20	17:00	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
161	982	RGPPL	400KV-RGPPL-NEW KOYNA-1	21-Dec-20	9:00	26-Dec-20	18:00	Continuous	New Koyna Line-1 CVT replacement work.	
162	983	MSETCL	400KV-DHULE-MS-BABLESHWAR-2	21-Dec-20	08:00	31-Dec-20	18:00	Daily	For Carrying PID Work	-
163	984	MSETCL	400KV-DHULE-MS-BABLESHWAR-1	21-Dec-20	08:00	31-Dec-20	18:00	Daily	For Carrying PID Work	-
164	994	MSETCL	220KV-BOISAR-BOISAR-M-3	22-Dec-20	09:00	22-Dec-20	17:00	Daily	POST MANSOON MAINTENANCE WORK	POST MANSOON MAINTENANCE WORK
165	995	MSETCL	400KV-RGPPL-NEW KOYNA-2	22-Dec-20	09:00	31-Dec-20	18:00	Continuous	dismantling of existing tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor	Planned outage
166	997	POWERGRID_WRI	400KV-Wardha-WARORA-PG-2	22-Dec-20	9:00	22-Dec-20	18:00	D	Relay testing work at Warora end & for line AMP works 400KV-Wardha-WARORA-PG-1 A/R to be keep in non auto mode for safety measures.	
167	998	MSETCL	400KV-BABLESHWAR-Aurangabad-M (Waluj)-1	22-Dec-20	09:00	26-Dec-20	17:00	Continuous	Samrudhhi Highway crossing 400kV Tower erection & dismantaling . Also CB Time,DCRM, CRM Testing	400kV Ektuni ckt I&II,400kV Bhusawal and 400kV Dhule I&II lines will be in in service
168	999	POWERGRID_WRI	400KV-WARDHA-AKOLA-1	22-Dec-20	7:00	22-Dec-20	18:00	D	For Insulator Replacement Works & 400KV-WARDHA-AKOLA-2 A/R to be keep in non auto mode for safety measures.	
169	1000	POWERGRID_WRI	400KV-WARDHA-WARORA-PG-2	22-Dec-20	7:00	22-Dec-20	18:00	D	For Tie CB LBB circuit checking	
170	1003	MSETCL	NAGOTHANE - 400KV - BUS 2	22-Dec-20	08:00	22-Dec-20	17:00	Daily	Regular maintenance work	nil
171	1011	MSETCL	400KV-SSP-DHULE-MS-1	22-Dec-20	08:00	22-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
172	1019	POWERGRID_WRI	Tie Bay - 400KV-Wardha-WARORA-PG-2 AND WARORA-PG - 400KV - Bus 2 at Warora - 400KV	22-Dec-20	9:00	22-Dec-20	18:00	D	For AMP works.	
173	1034	MSETCL	400KV-BABLESHWAR-PADGHE-1	22-Dec-20	09:00	24-Dec-20	17:30	Continuous	400kV Bblr I on TBC for replacement of Bus isolator at padghe	M/s Bimco man power M/s S& S Hydrabad representative will be available for the work
174	1056	POWERGRID_WRI	400KV-WARDHA-AKOLA-2	23-Dec-20	7:00	23-Dec-20	18:00	D	For Insulator Replacement Works & 400KV-WARDHA-AKOLA-1 A/R to be keep in non auto mode for safety measures.	
175	1069	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	23-Dec-20	09:00	23-Dec-20	17:00	Daily	Routine Maintenance & Diagnostic testing work .	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
176	1070	MSETCL	220KV-PARLI-PARLI-M-2	23-Dec-20	09:00	23-Dec-20	17:00	Daily	Line maintenance	-
177	1078	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1	23-Dec-20	9:00	23-Dec-20	18:00	D	for CVT replcement work at waluj end & 400kV-PUNE-WALUJ-2 A/R to be keep in non auto mode for safety measures.	
178	1082	MSETCL	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	23-Dec-20	09:00	23-Dec-20	18:00	Daily	1)Measurement of Contact Resistance of CB. 2) Routine maintenance work	Outage will be availed subjected to weather conditions.
179	1086	MSETCL	400KV-SOLAPUR-M-Solapur-1	23-Dec-20	10:00	23-Dec-20	18:00	Daily	Line Signature Test and other activities.	Load will be managed on 400kV LBT-Parali Line & 220kV Grid.
180	1092	MSETCL	400KV-SSP-DHULE-MS-2	23-Dec-20	08:00	23-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
181	1095	MP_SLDC	220KV-Pandhurna-MP-Kamleshwar	23-Dec-20	9:00	23-Dec-20	17:00	D	For bay equipment maintenance and testing work	
182	1099	MSETCL	220KV-TALEGAON-PUNE-PG-1	24-Dec-20	10:00	24-Dec-20	17:00	Daily	Half yearly maintenance , Diagnostic Testing.	---
183	1101	POWERGRID_WRI	400kV-WARDHA-AKOLA-1	24-Dec-20	9:00	24-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-2 A/R to be kept in non auto mode for safety measures.	
184	1110	MEGPTCL	765KV-TIRODA-KORADI-III-2 L/R@ KORADI-III - 765KV	24-Dec-20	08:00	24-Dec-20	18:00	Daily	Reactor Maintenance Activities	-
185	1111	MSETCL	400KV-SSP-DHULE-MS-2	24-Dec-20	08:00	24-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
186	1117	MSETCL	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	24-Dec-20	09:00	24-Dec-20	17:00	Daily	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
187	1121	POWERGRID_WRI	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	24-Dec-20	9:00	24-Dec-20	18:00	D	for CVT replcement work at waluj end & 400kV-PUNE-WALUJ-2 A/R to be kept in non auto mode for safety measures.	
188	1126	MSETCL	400KV-PARLI-M-PARLI-2	24-Dec-20	09:00	24-Dec-20	18:00	Daily	1. C & Tan delta measurement of CVTs. 2.Bay maintenance work.	-
189	1134	POWERGRID_WRI	400KV-DHARIWAL-PARLI-2	24-Dec-20	8:00	27-Dec-20	18:00	Continuous	Transmission line Tower Shifting of at Parli end due to new railway route proposed by Central Railway-Pune from Beed-Parli.	
190	1144	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	25-Dec-20	09:30	25-Dec-20	18:00	Daily	Hardware Tightening and Fitting Work.	-
191	1145	POWERGRID_WRI	400KV-WARDHA-AKOLA-2	25-Dec-20	7:00	25-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-1 A/R to be kept in non auto mode for safety measures.	
192	1149	MSETCL	400KV-SSP-DHULE-MS-1	25-Dec-20	08:00	25-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
193	1156	POWERGRID_WRI	400KV-KHARGHAR-PUNE-PG-1	26-Dec-20	9:00	26-Dec-20	18:00	D	For AMP Work	
194	1161	MSETCL	KHARGHAR - TALEGAON (PG)	26-Dec-20	08:00	26-Dec-20	18:00	Daily	Routine Maintenance work	Routine Maintenance work
195	1165	MSETCL	400KV-SSP-DHULE-MS-2	26-Dec-20	08:00	26-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
196	1168	MSETCL	400KV-BABLESHWAR-PADGHE-2	26-Dec-20	09:00	26-Dec-20	17:00	Daily	CT & CVT C & tan D testing	-
197	1179	MSETCL	400KV-KALWA-PADGHE-2	27-Dec-20	08:00	27-Dec-20	18:00	Daily	Routine Maintenance work	Routine Maintenance work
198	1185	MSETCL	220KV-TALEGAON-PUNE-PG-2	27-Dec-20	10:00	27-Dec-20	17:00	Daily	Half yearly maintenance, Diagnostic Testing .	---
199	1189	MSETCL	400KV/220KV KORADI-ICT-1	27-Dec-20	09:00	9-Jan-21	18:00	Continuous	Proposal for shifting of 400kV ICT 1 on TBC for CB pole overhauling work and CB DCRM,CRM, timing.	Outages will be availed subject to weather conditions.
200	1191	MSETCL	400KV-SSP-DHULE-MS-2	27-Dec-20	08:00	27-Dec-20	18:00	Daily	Online PID Testing Work	400kV SSNNL Ckt-2 will be kept on Non Auto mode
201	1192	GETCO	400 kV-SSP-Dhule-MS-2	27-Dec-20	7:00	27-Dec-20	18:00	Daily	Maintenance work. Auto reclose of 400 kV SSP - Dhule line No. 1 will remain out.	
202	1194	POWERGRID_WRI	400kV-WARDHA-AKOLA-1	28-Dec-20	7:00	28-Dec-20	18:00	D	For Tie CB LBB circuit checking	
203	1195	POWERGRID_WRI	400kV-WARDHA-AKOLA-2	28-Dec-20	7:00	28-Dec-20	18:00	D	For Tie CB LBB circuit checking	

Sr.No.	OCCM Sr. No	Name of Requesting Agency	Line / Element	From	Time	To	Time	Daily / Continuous	reason	Remarks
204	1198	POWERGRID_WR1	400kV-WARDHA-AKOLA-2	28-Dec-20	7:00	28-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-1 A/R to be kept in non auto mode for safety measures.	
205	1203	MSETCL	400KV-SSP-DHULE-MS-1	28-Dec-20	08:00	28-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode
206	1207	MSETCL	AURANGABAD-M (WALUJ) - 400KV - BUS 1	28-Dec-20	09:00	28-Dec-20	17:00	Daily	Quarterly maintenance of 400kV Babhaleshwar Bay	Quarterly maintenance of 400kV Babhaleshwar Bay
207	1215	POWERGRID_WR1	DHULE-MS - 400KV B/R 1	28-Dec-20	9:00	28-Dec-20	18:00	D	for AMP works	
208	1232	POWERGRID_WR1	400kV-WARDHA-AKOLA-1	29-Dec-20	7:00	29-Dec-20	18:00	D	For Insulator Replacement Works & 400kV-WARDHA-AKOLA-2 A/R to be kept in non auto mode for safety measures.	
209	1239	MEGPTCL	765KV-TIRODA-KORADI-III-1 L/R@ KORADI-III - 765KV	29-Dec-20	08:00	29-Dec-20	18:00	Daily	Reactor Maintenance Activities	-
210	1240	MSETCL	400KV-SSP-DHULE-MS-2	29-Dec-20	08:00	29-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-1 A/R switch will be kept on non auto mode
211	1252	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	29-Dec-20	9:00	29-Dec-20	18:00	D	For AMP works	
212	1256	WTPL	400KV-ALKUD-SOLAPUR-1	29-Dec-20	10:00	29-Dec-20	18:00	Daily	Annual Line Maintenance	
213	1259	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	29-Dec-20	10:00	30-Dec-20	18:00	Daily	AR Mode to be kept in Disable mode	
214	1278	MSETCL	220KV-PARLI-OSMANABAD-M-1	30-Dec-20	09:00	30-Dec-20	17:00	Daily	Line maintenance	-
215	1286	MSETCL	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	30-Dec-20	10:00	30-Dec-20	15:00	Daily	DCRM of CB 408-Q52	Station Transformer -II will remain in service through Main bay 407
216	1287	MSETCL	MAIN BAY - 400KV-WARORA-CHANDRAPU-II-2 AND CHANDRAPU-II - 400KV - BUS 1 at CHANDRAPUR-II - 400KV	30-Dec-20	10:00	30-Dec-20	17:00	Daily	Diagnostic testing work on Line CT	400KV WArora ckt. I is in service.
217	1288	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	30-Dec-20	10:00	30-Dec-20	18:00	Daily	Annual Line Maintenance	
218	1289	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	30-Dec-20	10:00	30-Dec-20	18:00	Daily	AR Mode to be kept in Disable mode	
219	1295	POWERGRID_WR1	PUNE-PG - 220KV - BUS 1	31-Dec-20	9:00	31-Dec-20	18:00	D	For AMP Works.	
220	1296	MSETCL	BABLESHWAR - 400KV - BUS 1	31-Dec-20	08:00	31-Dec-20	18:00	Daily	Busbar Relay testing	400 KV RADSS Busbar bus outage not required
221	1302	MSETCL	400KV-SSP-DHULE-MS-1	31-Dec-20	08:00	31-Dec-20	18:00	Daily	Replacement of damaged earthwire, replacement PID suspicious disc insulator and other maintenance work	400kV SSNNL-2 A/R switch will be kept on non auto mode

Maharashtra State Load Despatch Centre												
State Element Outage list for the month of December 2020												
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	
1	400 KV	AKOLA - KHADKA (BHUSAWAL)	01-Dec-20	08:00	01-Dec-20	18:00	Daily	For Conversion of CT ratio from 1000 to 2000 Amp and routine bay maintenance work	MSETCL	MSETCL	work will be carried out by testing Unit Khadka as per instruction from SE TCC/Nashik	
2	400 KV	MIAN BAY-422 OF STATION TF - 1 @ KORADI -2	01-Dec-20	10:00	01-Dec-20	17:00	Daily	DCRM of CB 422-Q52	MSETCL	MSETCL	Station Transformer-1 will remain in service through Tie bay 423	
3	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	01-Dec-20	10:00	31-Dec-20	16:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Akola- Nandgaonpeth line shall be carried out by PID unit Akola.	MSETCL	MSETCL	PID is carried out by PID Unit Akola	
4	400 KV	KORADI-NANDGAONPETH (RPL)	01-Dec-20	08:00	15-Dec-20	18:00	Daily	PID Testing on insulator strings on various towers, with AR in non automode(off)	MSETCL	MSETCL	Online work proposed by LM Koradi	
5	400 KV	MAIN BAY (405) OF 500MVA ICT - 2 @ KHAPERKHEDA	02-Dec-20	10:00	02-Dec-20	17:00	Daily	DCRM of Main Breaker	MSETCL	MSETCL	ICT in service through 406 Tie bay	
6	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	02-Dec-20	09:00	02-Dec-20	18:00	Daily	1)For measurement of Bushing Tan delta 2)Measurement of Timing, Contact Resistance and DCRM of CB. 3) Numerical relay testing work	MSETCL	MSETCL	Outage will be availed subjected to weather conditions. Special Note:- 1) 315	
7	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	02-Dec-20	10:00	02-Dec-20	17:00	Daily	Diagnostic testing work of line CVT	MSETCL	MSETCL	400KV Chandrapur-3-Switching- CKT. 1 is in service.	
8	400 KV	THAPTI TANDA - WALUJ	02-Dec-20	10:00	02-Dec-20	17:00	Daily	Routine Maintenance of 400kV Waluj Thaptitanda Line under 400kV LMSD Waluj Jurisdiction	MSETCL	MSETCL	Routine Maintenance of 400kV Waluj Thaptitanda Line under 400kV LMSD Waluj Jurisdiction	
9	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	03-Dec-20	09:00	03-Dec-20	18:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---	
10	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	03-Dec-20	09:00	03-Dec-20	18:00	Daily	1)For measurement of Bushing Tan delta 2)Measurement of Timing, Contact Resistance and DCRM of CB. 3) Numerical relay testing work	MSETCL	MSETCL	Outage will be availed subjected to weather conditions. Special Note:- 1) 315	
11	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	03-Dec-20	09:00	03-Dec-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 2 will be in service for no supply interruption.	
12	400 KV	JEJURI- KOYNA STAGE-IV	03-Dec-20	08:00	03-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work . Annual maintenance work & testing work.	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work	
13	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	03-Dec-20	09:00	03-Dec-20	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.	
14	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	04-Dec-20	08:30	04-Dec-20	18:30	Daily	for quarterly bay maintenance work	MSETCL	MSETCL	quarterly maintenance is due	
15	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	04-Dec-20	09:00	04-Dec-20	17:00	Daily	ICT II Bay maintenance work- quarterly maintenance	MSETCL	MSETCL	ICT II Bay maintenance work- quarterly maintenance	
16	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	04-Dec-20	09:00	04-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work	
17	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	04-Dec-20	10:00	04-Dec-20	18:00	Daily	ICT-I unit diagnostic testing carried out	MSETCL	MSETCL	Nil	

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
18	400 KV	KARAD - TALANDGE CKT 2	04-Dec-20	08:00	04-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
19	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	04-Dec-20	08:00	04-Dec-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
20	400 KV	KARAD - TALANDGE CKT 1	05-Dec-20	08:00	05-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
21	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	05-Dec-20	08:00	05-Dec-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
22	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	07-Dec-20	09:00	07-Dec-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
23	400 KV	PADGHE - NAGOTHANE 1	07-Dec-20	08:00	07-Dec-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
24	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	08-Dec-20	09:00	08-Dec-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
25	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	08-Dec-20	10:00	08-Dec-20	18:00	Daily	line maintainance work	MSETCL	MSETCL	-
26	400 KV	NEW KOYNA -KARAD -CKT 2	08-Dec-20	08:00	09-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
27	400 KV	PADGHE - NAGOTHANE 2	08-Dec-20	08:00	08-Dec-20	17:00	Daily	Jumper tightening and cold wasing work	MSETCL	MSETCL	nil
28	400 KV	CHANDRAPUR - KHAPERKHEDA	08-Dec-20	08:00	08-Dec-20	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
29	400 KV	CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT - 2	08-Dec-20	08:00	08-Dec-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR-Parli Ckt-III. These lines are on DC tower so both lines require on same day A/R out.
30	400 KV	KORADI-KHAPERKHEDA II	09-Dec-20	10:00	09-Dec-20	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Line not in service
31	400 KV	105 MVA SPARE ICT @ AKOLA	09-Dec-20	10:00	09-Dec-20	17:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Spare ICT charged on No Load
32	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	09-Dec-20	09:00	09-Dec-20	17:00	Daily	Routine maintenance by 400 kV LMSD Waluj	MSETCL	MSETCL	Routine maintenance by 400 kV LMSD Waluj
33	400 KV	400/220/33KV SPARE ICT @ CHANDRAPUR	09-Dec-20	09:00	09-Dec-20	18:00	Daily	1)For measurement of Bushing Tan delta 2)For transformer aux. test trials 3) Numerical relay testing work	MSETCL	MSETCL	Outage will be availed subjected to weather conditions.
34	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	09-Dec-20	09:00	09-Dec-20	17:00	Daily	Diagnostic testing work on Main CB and allied maintenance work	MSETCL	MSETCL	Load is manage through 400KV Chandrapur2-Nanded Ckt.2
35	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	10-Dec-20	09:00	10-Dec-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
36	400 KV	MAIN BAY - 414 OF YELWAN CKT-1 @ AKOLA	10-Dec-20	10:00	10-Dec-20	16:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Yelwan ckt-01 will be in service through Tie bay 415
37	400 KV	400/11kV STN-4A @ DEEPNAGAR	10-Dec-20	08:30	10-Dec-20	16:30	Daily	For quarterly bay maintenance work & diagnostic testing work	MSETCL	MSETCL	as per bay maintenance plan work to be done
38	400 KV	NEW KOYNA - STAGE IV CKT 1	10-Dec-20	09:00	10-Dec-20	18:00	Daily	cold washing & Diagnostic testing & Relay testing	MSETCL	MSETCL	Planned outage
39	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	10-Dec-20	08:00	10-Dec-20	18:00	Daily	Routine Dignostic testing , Changing CT Ratio and bay maintenance work.	MSETCL	MSETCL	---
40	400 KV	WARORA - IEPL	10-Dec-20	09:00	10-Dec-20	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
41	400 KV	400/220/33KV SPARE ICT @ CHANDRAPUR	10-Dec-20	09:00	10-Dec-20	18:00	Daily	1)For measurement of Bushing Tan delta 2)For transformer aux. test trials 3) Numerical relay testing work	MSETCL	MSETCL	Outage will be availed subjected to weather conditions.
42	400 KV	LONIKAND 1 - KOYNA STAGE-IV	10-Dec-20	08:00	10-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work	MSETCL	MSETCL	PID Faulty disc insulator replacement work
43	400 KV	MAIN Bay - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	10-Dec-20	09:00	10-Dec-20	18:00	Daily	Half yearly maintenance and diagnostic testing..	MSETCL	MSETCL	ICT 1 will be in service for no supply interruption.
44	400 KV	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	11-Dec-20	09:00	11-Dec-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work	MSETCL	MSETCL	Only Main bay CB is in OFF condition
45	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	11-Dec-20	10:00	11-Dec-20	18:00	Daily	ICT-II UNIT diagnostic testing carried out	MSETCL	MSETCL	Nil
46	400 KV	NEW KOYNA - STAGE IV CKT 2	11-Dec-20	09:00	11-Dec-20	18:00	Daily	cold washing & Diagnostic testing & Relay testing	MSETCL	MSETCL	Planned outage
47	400 KV	KHADKA - BABLESHWAR	11-Dec-20	08:00	11-Dec-20	17:00	Daily	For the conversion of C.T ratio from 1000 to 2000 Amp and routine bay Maintenance work carry out	MSETCL	MSETCL	The above work will be carry out by testing unit ,as per instruction of SE TCC Nashik
48	400 KV	400/11kV STN-4B @ DEEPNAGAR	11-Dec-20	08:30	11-Dec-20	16:30	Daily	For quarterly bay maintenance work & diagnostic testing work	MSETCL	MSETCL	as per bay maintenance plan work to be done
49	400 KV	MAIN BAY (404) OF ICT -1 @ WARORA	12-Dec-20	09:00	12-Dec-20	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Only main Bay CB is in OFF condition not available.
50	400 KV	KHADKA - BABLESHWAR	12-Dec-20	08:00	15-Dec-20	17:00	Continuous	For the overhauling of own circuit breaker and Bus-1&2 P.G isolator	MSETCL	MSETCL	During the above period line will be shifted on 400KV TBC(A/R Out)
51	400 KV	TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	13-Dec-20	09:00	13-Dec-20	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	only Tie CB 403 is in OFF condition ,respective bay charged through its own main CB.
52	400 KV	400/220/20 KV 500MVA ICT - 1 @ KALWA	13-Dec-20	09:00	13-Dec-20	18:00	Daily	ICT & Bay Maint. And testing work	MSETCL	MSETCL	ICT & Bay Maint. And testing work
53	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	14-Dec-20	08:00	14-Dec-20	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
54	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	14-Dec-20	10:00	15-Dec-20	18:00	Continuous	Replacement of tertiary bushing.	MSETCL	MSETCL	Spare ICT is on No Load
55	400 KV	KARAD - TALANDGE CKT 1	14-Dec-20	09:00	14-Dec-20	18:00	Daily	1. QM Work 2. Chemical cleaning of CT & CB 3. Annual Relay & Diagnostic Testing	MSETCL	MSETCL	1. Load will be managed on Talandge- Karad Ckt 2 2. Monday is load staggering day in Kolhapur
56	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	15-Dec-20	09:00	15-Dec-20	18:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Load will be shifted on ICT-02
57	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	15-Dec-20	08:00	15-Dec-20	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
58	400 KV	220 KV DEEPNAGAR (400 KV) - KHADKA CKT	15-Dec-20	08:30	15-Dec-20	15:30	Daily	For quarterly bay maintenance work & diagnostic testing work	MSETCL	MSETCL	planned outage for bay maint
59	400 KV	400/11.5KV STATION TRANSFORMER - 2 @ TIRORA	15-Dec-20	09:00	15-Dec-20	18:00	Daily	Bay maintenance Activities	APML	APML	-
60	400 KV	MAIN BAY (402) OF 500MVA ICT - 1 @ KHAPERKHEDA	16-Dec-20	10:00	16-Dec-20	17:00	Daily	DCRM of Main Breaker	MSETCL	MSETCL	ICT in service through 403 Tie bay
61	400 KV	TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	16-Dec-20	09:00	16-Dec-20	17:00	Daily	Diagnostic testing work on 411 Tie CB and allied maintenance work	MSETCL	MSETCL	Both lines are service through main CB's
62	400 KV	125 MVAr BUS REACTOR @ TALANDGE	16-Dec-20	09:00	16-Dec-20	18:00	Daily	QM Work	MSETCL	MSETCL	Comparatively higher loading on Wednesday
63	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	16-Dec-20	08:00	16-Dec-20	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
64	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	16-Dec-20	08:00	22-Dec-20	18:00	Daily	PID Testing on insulator strings on various towers, with AR in non automode(off)	MSETCL	MSETCL	Online work proposed by LM Koradi
65	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	17-Dec-20	10:30	17-Dec-20	18:00	Daily	For Annual Tan-d of ICT Bushings, Winding & Relay testing work	MSETCL	MSETCL	-
66	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	17-Dec-20	09:00	17-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
67	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	17-Dec-20	09:00	17-Dec-20	17:00	Daily	Routine maintenance by 400 kV LMSD Waluj	MSETCL	MSETCL	Routine maintenance by 400 kV LMSD Waluj
68	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	17-Dec-20	09:30	17-Dec-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	400/220/33kV, 501 MVA ICT-I & II will be in service.
69	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	18-Dec-20	09:00	18-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
70	400 KV	KHADKA-AURANGABAD	21-Dec-20	08:00	21-Dec-20	18:00	Daily	For CT ratio changing from 1000 to 2000 Amp & routine bay maintenance work	MSETCL	MSETCL	work will be carried out by Testing Unit as per directives from SE/TCC/Nasik
71	400 KV	MAIN BAY (407) OF STATION TF - 2 @ KORADI - 2	21-Dec-20	10:00	21-Dec-20	15:00	Daily	DCRM of CB 407-Q52	MSETCL	MSETCL	Station Transformer -II will remain in service through Tie Bay 408

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
72	400 KV	JAIGAD-NEW KOYNA-I	21-Dec-20	09:00	21-Dec-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
73	400 KV	AKOLA - KHADKA (BHUSAWAL)	21-Dec-20	09:00	21-Dec-20	18:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Nandgaon Ckt will be in service
74	400 KV	CHANDRAPUR 2- KUMBHARGAON(NANDED) CKT - 2	21-Dec-20	08:00	21-Dec-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III These lines are on DC tower so both lines require on same day A/R out.
75	400 KV	JAIGAD-NEW KOYNA-II	22-Dec-20	09:00	22-Dec-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
76	400 KV	400/220 125MVAr BUS REACTOR @ LAMBOTI	22-Dec-20	10:00	22-Dec-20	18:00	Daily	Routine Maintenance. Diagnostic Testing Work.	MSETCL	MSETCL	Reactor will be in out of Service.
77	400 KV	TBC 1 @ CHANDRAPUR GCR	22-Dec-20	09:00	22-Dec-20	18:00	Daily	1)Measurement of CT Tan delta. 2) Relay testing work	MSETCL	MSETCL	Outage will be availed subjected to weather conditions.
78	400 KV	MAIN BAY (412) OF NANDED CKT-2 @ CHANDRAPUR - 2	23-Dec-20	09:00	23-Dec-20	17:00	Daily	Diagnostic testing work on 411 Tie CB, Line CT and allied maintenance work	MSETCL	MSETCL	400KV Chandrapur-2 nanded ckt. 1 is in service
79	400 KV	KHADKA-AURANGABAD	23-Dec-20	10:00	23-Dec-20	17:00	Daily	Routine maintenance by 400 kV LMSD Waluj	MSETCL	MSETCL	Routine maintenance by 400 kV LMSD Waluj
80	400 KV	MAIN BAY (430) OF ICT - 1 @ KORADI - 2	23-Dec-20	10:00	23-Dec-20	17:00	Daily	DCRM of CB 430-Q52 Tan delta measurement of Bus CT at Bay 430	MSETCL	MSETCL	ICT-1 will remain in service through its Tie bay 429
81	400 KV	CHANDRAPUR - KHAPERKHEDA	23-Dec-20	08:00	31-Dec-20	18:00	Daily	PID Testing on insulator strings on various towers, with AR in non automode(off)	MSETCL	MSETCL	Online work proposed by LM S/Dn Koradi.
82	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	24-Dec-20	10:30	24-Dec-20	18:00	Daily	For Annual Tan-d of ICT Bushings, Winding & Relay testing work	MSETCL	MSETCL	-
83	400 KV	LONIKAND 1 -JEJURI	24-Dec-20	09:30	24-Dec-20	17:30	Daily	Annual maintenance work & testing work.	MSETCL	MSETCL	400kV Jejuri-Koyna stage IV line will be in service.
84	400 KV	KARAD - LONIKAND 1	24-Dec-20	08:00	24-Dec-20	18:00	Daily	Routine Diagnostic testing and bay maintenance work & line maintenance work.	MSETCL	MSETCL	---
85	400 KV	JEJURI- KOYNA STAGE-IV	24-Dec-20	08:00	25-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
86	400 KV	STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	24-Dec-20	09:00	24-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
87	400 KV	GTR - 8 @ CHANDRAPUR SWITCHING SS	24-Dec-20	09:00	24-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
88	400 KV	GTR - 9 @ CHANDRAPUR SWITCHING SS	25-Dec-20	09:00	25-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
89	400 KV	NEW KOYNA-KARAD -CKT 1	26-Dec-20	08:00	26-Dec-20	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
90	400 KV	KARAD - TALANDGE CKT 2	28-Dec-20	09:00	28-Dec-20	18:00	Daily	1. QM Work 2. Chemical Cleaning of CT & CB 3. Annual Relay & Diagnostic Testing	MSETCL	MSETCL	1. Load will be managed on Talandge-Karad Ckt 1 2. Monday is Load Staggering day in Kolhapur
91	400 KV	TBC @ PARLI	28-Dec-20	09:00	28-Dec-20	18:00	Daily	1. Breaker testing work. 2.Bay maintenance work.	MSETCL	MSETCL	-
92	400 KV	TIE BAY (429) OF ICT - 1 @ KORADI - 2	28-Dec-20	10:00	28-Dec-20	15:00	Daily	DCRM of CB 429-Q52	MSETCL	MSETCL	ICT-1 will remain in service through its main Bay 430
93	400 KV	NEW KOYNA-KARAD -CKT 1	28-Dec-20	09:00	29-Dec-20	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	Planned outage
94	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	30-Dec-20	10:00	30-Dec-20	18:00	Daily	SFRA Testing.	MSETCL	MSETCL	Load will be Managed on ICT II & 220kV Grid
95	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	30-Dec-20	09:00	30-Dec-20	18:00	Daily	1. IV and HV breaker testing work. 2.Bay maintenance work.	MSETCL	MSETCL	-
96	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	31-Dec-20	10:30	31-Dec-20	18:00	Daily	For Annual Tan-d of ICT Bushings, Winding & Relay testing work	MSETCL	MSETCL	-
97	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	31-Dec-20	09:00	31-Dec-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work