

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of December 2023

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
1	1	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	For bunching arrangement of 400kv kalwa padgha Ckt 1 at loc.no. 3 on 400kv Padgha Kharghar line (Dead line) at loc.no. 132 using ERS for HTLS of 400KV Kalwa-Padgha I line.	13/11/2023	08:30	31/12/2023	18:30	Above arrangement will be kept for approximately 45 days where 400KV Padgha-Kharghar line will be formed & also Tapping Arrangement at Loc.No09 of temporarily formed 400KV Padgha-Kharghar line will be done with 400KV Kharghar-Talegaon line to form 400kv Padgha - Kharghar- Talegaon line.
2	2	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR-II-2	C	Scheme work of replacement of existing 0.5 ACSR conductor by HTLS conductor	19/11/2023	06:00	09/12/2023	17:00	for enhancing the capacity of this line.
3	3	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	C	1. CB pole overhauling work. 2.Diagnostic testing work of CT, CB. 3. Bay maintenance work.	28/11/2023	08:00	05/12/2023	18:00	400KV HVDC-1 will be in service. There will be power restriction of 750MW on HVDC Bipole during outage.
4	4	PLANNED	OCC_573	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	28/11/2023	08:00	07/12/2023	20:00	1.Pole-1 will be in service with 750 MW
5	5	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-2	C	1.Bay Maintenance Work. 2.Diagnostic Testing Work. 3.MTAMC work. 4.Replacement of old BHEL Make 7 Core CT with New 7 Core CT of CGL make. 5.Replacement of A Bus B Ph PG Isolator under LES Scheme.	28/11/2023	09:00	05/12/2023	18:00	Weather condition should be clear.
6	6	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work	28/11/2023	09:00	01/12/2023	18:00	400 KV Aurangabad will be in service through TBC
7	7	PLANNED	OCC_573	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1. replacement of hanger assembly of A Bus B Ph PG Isolator by hot line method of 400kv HVDC-2. 2.All feeders on A Bus will be in service.	30/11/2023	09:00	03/12/2023	18:30	1.Weather Condition should be clear. 2. Hot line team will be present in side.
8	56	PLANNED	OCC_573	MSLDC_OUTAGE	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV -	C	CB pole overhauling work	01/12/2023	09:00	04/12/2023	18:00	400kv Main Bus I and II will be separated
9	57	PLANNED	OCC_573	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	Over Head HTLS conductor stringing work of 400KV Chandrapur GCR- Chand2-ckt-2 & work is carried out above live bus. NOC required from GENCO	01/12/2023	06:00	05/12/2023	17:00	Replacement of existing 0.5 ACSR conductor to HTLS conductor on 400KV GCR chandrapur - Chand2- ckt-2 for enhancing the loading capacity. NOC required from GENCO
10	58	PLANNED	OCC_573	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	C	Over Head HTLS conductor stringing work of 400KV Chandrapur GCR- Chand-2- ckt-2 & work is carried out above live bus. NOC required from GENCO	01/12/2023	06:00	05/12/2023	17:00	work of replacement of existing 0.5 ACSR conductor to HTLS conductor on 400KV Chandrapur GCR- Chand-2 ckt-2 line NOC required from GENCO
11	59	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/12/2023	08:00	06/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode
12	62	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	A/R off for PID Testing work	01/12/2023	10:00	08/12/2023	18:00	A/R off for PID Testing work
13	64	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	PID work. Permission for Auto Reclose to be kept in Non auto mode	01/12/2023	08:00	15/12/2023	18:00	only A/R out of service during PID work.
14	65	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	PID testing work. Auto Reclose to be kept in Non auto mode	01/12/2023	09:00	15/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
15	66	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	For carry out PID. Permission for Auto Reclose to be kept in Non auto mode	01/12/2023	08:00	16/12/2023	18:00	For carry out PID.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
16	77	PLANNED	OCC_573	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01/12/2023	07:00	30/12/2023	18:00	
17	78	PLANNED	OCC_573	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01/12/2023	07:00	30/12/2023	18:00	
18	106	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	The OPGW (48F) installation work by replacing existing earthwire in live line condition on 400kV Babhaleshwar-Padghe Double Circuit Tower from Loc 1 to 59. Permission for Auto Reclose to be kept in Non auto mode	01/12/2023	08:00	31/12/2023	19:00	Being Double Circuit Tower, the AR-out of both circuits i.e. 400kV Babhaleshwar-Padghe Ckt-1 & Ckt 2 is requested by the MTCIL. Permission for Auto Reclose to be kept in Non auto mode
19	107	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	The OPGW (48F) installation work by replacing existing Earthwire in live line condition on 400kV Babhaleshwar- Padghe Ckt -2 Line (Single Circuit Line) from tower loc 855 to 998 and on 400kV Babhaleshwar-Padghe Double Circuit Line from Tower loc 1 - 59. Permission for Auto Reclose to be kept in Non auto mode	01/12/2023	08:00	31/12/2023	19:00	For 400kV Babhaleshwar-Padghe Double Circuit section i.e. from Loc 1 to 59 , AR out of both Circuits i.e. 400kV Babhaleshwar-Padghe Ckt -1 and Ckt -2 is requested by the MTCIL.
20	108	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-1	D	ON-LINE PID testing of 400 KV Dhule-BBLR CKT 1. During Outage A/R switch will be kept on Non-Auto mode.	01/12/2023	09:00	31/12/2023	16:00	During Outage A/R switch for 400 KV Dhule-BBLR CKT 1 will be kept on Non-Auto mode.
21	109	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-DHULE-MS-BABLESHWAR-2	D	ON-LINE PID testing of 400 KV Dhule-BBLR CKT 2. During Outage A/R switch will be kept on Non-Auto mode.	01/12/2023	09:00	31/12/2023	16:00	During Outage A/R switch of 400 KV Dhule-BBLR CKT 2 will be kept on Non-Auto mode.
22	110	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/12/2023	09:00	31/12/2023	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
23	111	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/12/2023	09:00	31/12/2023	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
24	112	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/12/2023	09:00	31/12/2023	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
25	113	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/12/2023	09:00	31/12/2023	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
26	114	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/12/2023	09:00	31/12/2023	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
27	115	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/12/2023	09:00	31/12/2023	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
28	116	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work. Auto Reclose to be kept in Non auto mode	01/12/2023	09:00	31/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
29	117	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work Permission for Auto Reclose to be kept in Non auto mode	01/12/2023	09:00	31/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode
30	118	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	D	FOR PID WORK Permission for Auto Reclose to be kept in Non auto mode	01/12/2023	09:00	31/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode
31	119	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-2	D	FOR PID WORK(JAIGAD-KARAD CKT 2 AR OUT)	01/12/2023	09:00	31/12/2023	18:00	FOR PID WORK(JAIGAD-KARAD CKT 2 AR OUT)
32	120	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID testing work. Auto Reclose to be kept in Non auto mode	01/12/2023	09:00	31/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode
33	121	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID testing work. Auto Reclose to be kept in Non auto mode	01/12/2023	09:00	31/12/2023	18:00	Permission for Auto Reclose to be kept in Non auto mode
34	122	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	01/12/2023	11:00	31/12/2023	15:00	Permission for Auto Reclose to be kept in Non auto mode
35	164	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-TARAPUR 1-2-BOISAR-M-1	D	Outage required on 220kV Tarapur-Boisar Line (For Safety Purpose) for replacement of damaged conductor of 220kV Boisar-PGCIL CKT III between loc no. 12-13.	02/12/2023	08:00	02/12/2023	18:00	Outage required on 220kV Tarapur-Boisar Line (For Safety Purpose) for replacement of damaged conductor of 220kV Boisar-PGCIL CKT III between loc no. 12-13.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
36	165	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	At Loc No.12-13 Conductor found damaged and same repaired with repair sleeve but need to be replace conductor by Mid Span Joint.	02/12/2023	08:00	02/12/2023	18:00	Simultaneously outage is required on 220kV Tarapur-Boisar Line For Safety Purpose.
37	166	PLANNED	OCC_573	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Connection of 501 MVA ICT V isolator jumps to Main Bus I by Hotline method	02/12/2023	09:00	02/12/2023	13:00	Work will be done online through Hotline method
38	168	PLANNED	OCC_573	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Connection of 501 MVA ICT V isolator jumps to Main Bus II by Hotline method	02/12/2023	13:00	02/12/2023	18:00	Work will be done online through Hotline method
39	173	PLANNED	OCC_573	POWERGRID_WR1	PUNE-PG - 400KV - BUS 1	D	For AMP Work	03/12/2023	09:00	03/12/2023	18:00	
40	176	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Bay maintenance & equipment testing.	03/12/2023	07:00	03/12/2023	19:00	Bay maintenance & equipment testing.
41	177	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	Cold line washing	03/12/2023	09:00	03/12/2023	18:00	Load managed on 400kV karjat-parli 2
42	178	PLANNED	OCC_573	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 1	D	for diagnostic testing work	03/12/2023	09:00	03/12/2023	18:00	-
43	184	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPU-II-1	C	for replacement of existing 0.5 ACSR conductor by HTLS conductor	04/12/2023	06:00	17/12/2023	17:00	for enhancing the current carrying capacity
44	189	PLANNED	OCC_573	POWERGRID_WR1	PARLI-M - 400KV - BUS 1	D	For erection of 89A isolator of 400KV New Parli-Parli-M-2 at msetcl girwali	04/12/2023	07:00	04/12/2023	18:00	For erection of 89A isolator of 400KV New Parli- Parli-M-2 at msetcl girwali
45	190	PLANNED	OCC_573	POWERGRID_WR1	220KV-SOLAPUR-KUMBARI-2	D	Line side equipments AMP at 765kV Solapur Substation	04/12/2023	07:00	04/12/2023	18:00	
46	191	PLANNED	OCC_573	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	04/12/2023	07:00	04/12/2023	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
47	192	PLANNED	OCC_573	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	04/12/2023	07:00	04/12/2023	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
48	234	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	For AMP Work	04/12/2023	09:00	04/12/2023	18:00	
49	253	PLANNED	OCC_573	MSLDC_OUTAGE	BHUSAWAL - 400KV - BUS 2	D	For replacement of B phase 400kV Bus - 2 CVT due to higher tan delta results.	04/12/2023	08:00	04/12/2023	15:00	urgent work.
50	256	PLANNED	OCC_573	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS	04/12/2023	09:00	04/12/2023	18:00	Bay outage
51	257	PLANNED	OCC_573	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	04/12/2023	09:00	04/12/2023	18:00	During 400KV Busbar Protection Relay testing works Outage, (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing
52	259	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	04/12/2023	10:00	04/12/2023	18:00	NA
53	273	PLANNED	OCC_573	APML	TIE BAY OF 765KV/21KV TIRODA-GT-5 AND 765KV-TIRODA-KORADI-III-1 @TIRODA - 765KV at TIRODA - 765KV	C	Annual testing and mechanism OH	04/12/2023	09:00	06/12/2023	18:00	GT-5 AND 765KV TIRODA-KORADI-III-1 WILL BE IN SERVICE ON MAIN BAY
54	285	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	04/12/2023	08:00	09/12/2023	18:00	---
55	286	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY (417) OF ICT-1 & FUTURE BAY @ TAPTITANDA (Element not found)	C	CB mechanism overhauling work by M/s CGL	04/12/2023	11:00	11/12/2023	18:00	C outage required for CB mechanism overhauling

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
56	290	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Online PID (Puncture insulation Detection)Work of 400 KV Dhule-SSNNL CKT 1. Auto Reclose switch will be kept on Non Auto mode during Outage period.	04/12/2023	09:00	30/12/2023	16:00	400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage period
57	291	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Online PID (Puncture insulation Detection)Work of 400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage period.	04/12/2023	09:00	30/12/2023	16:00	400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage period
58	330	PLANNED	OCC_573	POWERGRID_WR1	TIE BAY - 400KV-PARLI-M-PARLI-1 AND PARLI - 400KV B/R 1 at PARLI - 400KV	D	For AMP	05/12/2023	08:30	05/12/2023	18:00	AMP OF BAY
59	335	PLANNED	OCC_573	POWERGRID_WR2	220KV-BOISAR-PANCHALI-1	D	AMP	05/12/2023	09:00	05/12/2023	17:30	PG-WR2- BOISAR SS
60	363	PLANNED	OCC_573	POWERGRID_WR1	765KV-PUNE-GIS-SOLAPUR-1	D	For Spare Changeover. For taking Spare unit into service .	05/12/2023	10:00	05/12/2023	14:00	Last Spare Changeover was done on 12.05.2023
61	364	PLANNED	OCC_573	POWERGRID_WR1	765KV-PUNE-GIS-SOLAPUR-1 L/R@ PUNE-GIS - 765KV	D	For Spare Changeover. For taking Spare unit into service .	05/12/2023	10:00	05/12/2023	14:00	Last Spare Changeover was done on 12.05.2023
62	369	PLANNED	OCC_573	MSLDC_OUTAGE	BUS COUPLER BAY OF NEW KOYNA - 400KV - BUS 1 AND NEW KOYNA - 400KV - BUS 2 @NEW KOYNA - 400KV	D	Diagnostic testing & Relay testing work , Routine maint. Work	05/12/2023	08:00	05/12/2023	17:00	---
63	371	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	05/12/2023	10:00	05/12/2023	13:00	--
64	372	PLANNED	OCC_573	MSLDC_OUTAGE	ALKUD - 400KV - BUS 1	D	Diagnostic testing & Maintenance work	05/12/2023	10:00	05/12/2023	17:00	Load will be managed on 400KV Main Bus-2
65	373	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Diagnostic testing & Maintenance work	05/12/2023	10:00	05/12/2023	17:00	Load will be managed on 400KV Alkud Kolhapur line
66	374	PLANNED	OCC_573	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1 L/R@ AKOLA (2) - 765KV	D	Reactor changeover activity as per CEA guideline Spare reactor taken into service in place of Y- Ph Reactor at Akola SS.	05/12/2023	10:00	05/12/2023	18:00	Reactor outage
67	375	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY - 400KV-EKTUNI-BABLESHWAR-2 AND 765KV/400KV EKTUNI-ICT-1 at EKTUNI - 400KV	D	Diagnostic Testing and Routine Maintenance	05/12/2023	10:00	05/12/2023	18:00	400kV Bhabaleshwar Ckt-II will be in service though 408 (Main) Bay
68	376	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	05/12/2023	10:00	05/12/2023	18:00	NA
69	377	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-1	D	Routine Testing work, CT Tan-delta, CB CRM & amp; Timing testing work and Routine Maintenance work.	05/12/2023	10:00	05/12/2023	18:00	Outage proposed as per Diagnostics Testing Schedule.
70	379	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	05/12/2023	14:00	05/12/2023	17:00	--
71	380	PLANNED	OCC_573	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	05/12/2023	07:00	06/12/2023	18:00	Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
72	381	PLANNED	OCC_573	POWERGRID_WR1	400KV-WARORA (M)-WARORA-PG-2	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	05/12/2023	07:00	06/12/2023	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
73	394	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-2 @BABLESHWAR - 400KV at BABLESHWAR - 400KV(Element not found)	C	CB pole overhauling work	05/12/2023	09:00	08/12/2023	18:00	400/220 KV ICT II HV will be in service through TBC
74	408	PLANNED	OCC_573	POWERGRID_WRI	PARLI-M - 400KV - BUS 2	D	For erection of 89B isolator of 400KV New Parli-Parli-M-2 at msetcl girwali	06/12/2023	07:00	06/12/2023	18:00	For erection of 89B isolator of 400KV New Parli- Parli-M-2 at msetcl girwali
75	412	PLANNED	OCC_573	POWERGRID_WRI	WARDHA - 220KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element	06/12/2023	07:00	06/12/2023	20:00	Insulator replacement work is proposaed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line.
76	413	PLANNED	OCC_573	POWERGRID_WRI	220KV-WARDHA-PUSAD-1	D	For Replacement of Old BHEL Insulators on gantries of element	06/12/2023	07:00	06/12/2023	20:00	Insulator replacement work is proposaed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line.
77	414	PLANNED	OCC_573	POWERGRID_WRI	220KV-WARDHA-BHUGAON-1	D	For Replacement of Old BHEL Insulators on gantries of element	06/12/2023	07:00	06/12/2023	20:00	Insulator replacement work is proposaed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line.
78	474	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	06/12/2023	09:00	06/12/2023	17:00	only Tie CB 415 is in OFF condition , respective ckt charged through its own main CB.
79	475	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	06/12/2023	09:00	06/12/2023	17:30	-
80	476	PLANNED	OCC_573	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS	06/12/2023	09:00	06/12/2023	18:00	Bay outage
81	477	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Cold line washing	06/12/2023	09:00	06/12/2023	18:00	Load managed on 400kV Lamboti-PGCIL
82	478	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	06/12/2023	09:00	06/12/2023	18:00	The said work is very important
83	479	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Quarterly Maintenance	06/12/2023	10:00	06/12/2023	17:00	Quarterly Maintenance
84	495	PLANNED	OCC_573	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 1	C	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.	07/12/2023	20:00	10/12/2023	20:00	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.
85	496	PLANNED	OCC_573	MSLDC_OUTAGE	HVDC 500KV CHANDRAPUR HVDC POLE 2	C	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.	07/12/2023	20:00	10/12/2023	20:00	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.
86	548	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maint. Work	07/12/2023	06:00	07/12/2023	18:00	NA
87	549	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	DT Work & Bay Maintenance	07/12/2023	08:00	07/12/2023	18:00	-
88	550	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	Cold washing of Insulator Strings	07/12/2023	08:00	07/12/2023	18:00	-
89	551	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance wok	07/12/2023	08:00	07/12/2023	18:00	.
90	552	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	PID detected weak strings replacement.	07/12/2023	09:00	07/12/2023	18:00	-
91	553	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY - 400KV-EKTUNI-BABLESHWAR-1 AND EKTUNI - 400KV - BUS 1 at EKTUNI - 400KV	D	Diagnostic testing and routine maintenance	07/12/2023	10:00	07/12/2023	18:00	400kV Bhabaleshwar ckt-I will be in service through its 412 (TIE) bay
92	560	PLANNED	OCC_573	APML	MAIN BAY - TIRODA - 765KV - BUS 1 at TIRODA - 765KV	C	Annual testing and mechanism OH	07/12/2023	09:00	08/12/2023	18:00	B/R 1 WILL BE IN SERVICE ON TIE BAY

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
93	563	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3)String replacement work.	07/12/2023	09:00	08/12/2023	18:00	-
94	564	PLANNED	OCC_573	MEGPTCL	AKOLA (2) - 765KV - BUS 1	D	Annual maintenance of CVT and LED light installation	07/12/2023	10:00	08/12/2023	18:00	Bus- 1 outage
95	570	PLANNED	OCC_573	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	B Bus Conductor Replacement of Section -3 between 400kV HVDC II & Nagothane I 1) 400kV HVDC - 2 on TBC & 400kV Nagothane -1 H/T required fro 3 days . 2) 400kV HVDC -1 & Nagotane-2 H/t required for 3 hrs on day 1 & day 3 for jumper removing & fixing work by Hot line & Cold line method. Power restriction of 750MW for 3 hrs.	08/12/2023	05:00	10/12/2023	23:59	Weather Condition Should Be clear.
96	571	PLANNED	OCC_573	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 1	C	Replacement of deteriorated Bus conductor span	08/12/2023	07:00	10/12/2023	18:00	All 400kV Elements on A bus will be shifted via TBC on B bus and Bus coupler will be kept off
97	597	PLANNED	OCC_573	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-2	D	AMP of 418L at MSETCL Kudus substation	08/12/2023	08:00	08/12/2023	18:00	400kV Padghe Kudus circuit 2 will be out of service.
98	609	PLANNED	OCC_573	POWERGRID_WR2	BOISAR - 220KV - BUS 2	D	AMP	08/12/2023	09:00	08/12/2023	18:00	PG-WR2- BOISAR SS
99	616	PLANNED	OCC_573	MP_SLDC	220KV-PANDURNA-KALMESHVAR-1	D	FOR LINE MAINTENANCE WORK	08/12/2023	09:00	08/12/2023	18:00	
100	617	PLANNED	OCC_573	POWERGRID_WR1	PUNE-PG - 220KV - BUS 1	D	For AMP Work	08/12/2023	09:00	08/12/2023	18:00	Respective bay to be shifted to TBC(204) Bay while work on Respective bay.
101	631	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-5	D	1) Shifting from B bus to A bus for partial Bus outage	08/12/2023	05:00	08/12/2023	11:00	Weather condition should be clear.
102	632	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	D	1) Shifting from B bus to A bus for partial Bus outage	08/12/2023	05:00	08/12/2023	12:00	Weather condition should be clear.
103	633	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	1) shifting from B bus to A bus for partial Bus outage 2) H/T required for 2 to 3 hrs. for jumper removing work by cold line method between Nagothane 2&1 in afternoon hrs.	08/12/2023	05:00	08/12/2023	15:00	Weather Condition should be clear.
104	635	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-1	D	1.Shifting from B Bus to A Bus for load management during partial bus outage.	08/12/2023	09:00	08/12/2023	11:00	Weather condition should be clear
105	636	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	D	1) H/T required for safety proposed for removing jumper between HVDC 1&2 gantry by Hot line method. 2) power restriction of 750 MW for 3Hrs.	08/12/2023	10:00	08/12/2023	13:00	Weather condition should be clear.
106	637	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-SOLAPUR-NARANGWADI-2	D	Routine Testing work, CT Tan-delta, CB CRM & Timing testing work and Routine Maintenance work.	08/12/2023	10:00	08/12/2023	18:00	Outage proposed as per Diagnostics Testing Schedule. Max=68MW, Min=18MW YES, Load on 220 kV Narangwadi 2 Solapur PGCIL Ckt-1. Managed
107	645	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV-PADGHE HVDC-PADGHE-2 AND PADGHE HVDC - 400KV - BUS 1 @PADGHE HVDC - 400KV at PADGHE HVDC - 400KV	C	1) shifting on TBC for partial bus outage for Bus conductor replacement work 2) PG isolator alignment work	08/12/2023	09:00	10/12/2023	23:00	Weather condition should be clear.
108	646	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	C	1)H/T require for 3 days for Bus conductor replacement work of sec-3 between Nago-1 & HVDC-2 2) IPS tube removing work below B bus for Bus conductor replacement 3) PG isolator replacement & alignment work of B bus.	08/12/2023	11:00	10/12/2023	23:59	Weather condition should be clear.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
109	647	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	08/12/2023	08:00	13/12/2023	18:00	.
110	665	PLANNED	OCC_573	POWERGRID_WRI	TIE BAY OF 400KV-PADGHE-PG-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV	D	AMP of Tie bay (414 bay) at MSETCL Kudus Substation	09/12/2023	08:00	09/12/2023	18:00	Padghe-Kudus ckt#1 will be IN service through bay no. 415 at MSETCL Kudus Substation.
111	668	PLANNED	OCC_573	POWERGRID_WRI	TIE BAY - 400KV-PARLI-PUNE-PG-1 AND 400KV-WARORA-PG-PARLI-1 at PARLI - 400KV	D	CB SF6 LEAKAGE ARRESTING	09/12/2023	08:30	09/12/2023	18:00	CB SF6 LEAKAGE ARRESTING
112	683	PLANNED	OCC_573	POWERGRID_WRI	765KV-PUNE-GIS-SOLAPUR-1	D	For Spare Changeover. For taking Spare unit out of service .	09/12/2023	10:00	09/12/2023	14:00	
113	684	PLANNED	OCC_573	POWERGRID_WRI	765KV-PUNE-GIS-SOLAPUR-1 L/R@ PUNE-GIS - 765KV	D	For Spare Changeover. For taking Spare unit out of service .	09/12/2023	10:00	09/12/2023	14:00	
114	686	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Outage required for safety purpose during work of replacement of rusted nut bolts to avoid Hot Spot during peak load condition at loc no.DP Between Loc No.12-13 of 220kV PGCIL-Panchali Line.	09/12/2023	08:00	09/12/2023	18:00	Outage required for safety purpose during work of replacement of rusted nut bolts to avoid Hot Spot during peak load condition at loc no.DP Between Loc No.12-13 of 220kV PGCIL-Panchali Line.
115	689	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work CVT tan delta testing.	09/12/2023	08:00	10/12/2023	18:00	400kV Padghe I will be in service
116	690	PLANNED	OCC_573	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	C	Annual testing and mechanism OH	09/12/2023	09:00	10/12/2023	18:00	765KV Tiroda- Koradi-III-2 will be in service on Tie Bay
117	691	PLANNED	ERPC	POWERGRID	400KV-JHARSUGUDA-RAIGARH-2	D	Diversion/Modification of 400KV RKL-SNG-RGH line due to dedicated coal corridor road by R&B Division, Sundargarh	09/12/2023	07:00	09/12/2023	17:00	
118	693	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	for the work of for replacement of existing 0.5 ACSR conductor by HTLS conductor on 400KV Chandrapur GCR -Chandrapur ckt-1	10/12/2023	06:00	12/12/2023	18:00	This line is under crossing at Loc. No. LILO1 to LILO-2 of 400KV Chandrapur GCR- Chandrapur 2-ckt-1. Hence for safety point of view NON-Auto modes required.
119	694	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	for the work of for replacement of existing 0.5 ACSR conductor by HTLS conductor on 400KV Chandrapur GCR -Chandrapur ckt-1	10/12/2023	06:00	12/12/2023	18:00	This line is under crossing at Loc. No. LILO1 to LILO-2 of 400KV Chandrapur GCR- Chandrapur 2-ckt-1. Hence for safety point of view NON-Auto modes required.
120	695	PLANNED	OCC_573	POWERGRID_WRI	400KV-KALA-KUDUS-1	D	AMP of 401L at MSETCL Kudus Substation. Ckt-2 A/R off	10/12/2023	08:00	10/12/2023	18:00	400kV Kala Kudus Circuit-2 will be out of service.
121	700	PLANNED	OCC_573	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	D	220kV A-Bus for Isolator r/m works.	10/12/2023	07:00	10/12/2023	20:00	220kV A-Bus has following elements: 220kV Tarapur Line 220kV Borivali Line 220kV Viraj Line 220kV PGCIL Line 2 200MVA , 220/132kV ICT No.2 80MVA, 220/33-33kV PTR 150MVA , 220/132kV ICT No.2
122	701	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	Cold washing of Insulator Strings	10/12/2023	08:00	10/12/2023	18:00	-
123	702	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Removing of Bunching at Loc.No.03 for 400kv Kalwa padgha ckt 2 & 132 of 400KV padghe kharghar line & Tapping arrangement at Loc.No.09 (Kharghar Talegoan line)	10/12/2023	08:30	10/12/2023	15:00	Removing of Bunching at Loc.No.03 for 400kv Kalwa padgha ckt 2 & 132 of 400KV padghe kharghar line & Tapping arrangement at Loc.No.09 (Kharghar Talegoan line)
124	703	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	Cold line washing	10/12/2023	09:00	10/12/2023	18:00	Load managed on 400kV karjat-parli 1

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
125	704	PLANNED	OCC_573	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 2	D	for diagnostic testing work	10/12/2023	09:00	10/12/2023	18:00	-
126	705	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work. 4.Replacement of 29 C Bus PG Isolator under LES Scheme. 5.Replacement of all phase CT with new Ratio of 3000/1 A. 6.Distance Relay & Over Voltage Relay.	10/12/2023	09:00	10/12/2023	18:30	Weather condition should be clear.
127	706	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	1) H/t requires for safety purposed for re connection of jumper by cold line method between Nago I & II 2) shifting from A bus to B bus after Bus conductor replacement work.	10/12/2023	12:00	10/12/2023	22:00	Weather condition should be clear
128	707	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	D	1) H/T requires for safety purposed for re connection of jumper between HVDC 1 & II gantry of B bus by Hot line METHOD.	10/12/2023	14:00	10/12/2023	17:30	1) weather condition should be clear for Hot line method.
129	708	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	D	1) Shifting from A bus to B bus for partial Bus outage restoration.	10/12/2023	18:00	10/12/2023	23:30	Weather condition should be clear
130	709	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-5	D	1) Shifting from A bus to B bus for partial Bus outage	10/12/2023	18:00	10/12/2023	23:30	Weather condition should be clear
131	714	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Replacement of faulty insulator in live line method.	11/12/2023	08:00	20/12/2023	18:00	AR off
132	715	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Replacement of faulty insulator in live line method.	11/12/2023	08:00	20/12/2023	18:00	AR off
133	716	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	Replacement of existing conductor by HTLS conductor in Jambhul ROW area in dead portion of PADGHE - KALWA CKT - 2 by bunching the line on dead portion of 400KV Padgha-Khatghar line.	11/12/2023	08:30	18/12/2023	15:00	After above arrangement Tapping of 400KV Kharghar-Talegaon line line at loc no. 9 to form Temporary 400kv Padghe - kharghar- Talegoan line.
134	719	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Tapping Arrangement at Loc.No09 with 400KV Padgha-Kharghar line thereby formation of New 400kv Padghe - kharghar- Talegoan line after bunching of 400KV Kalwa-Padgha-II line with dead 400KV Padgha-Kharghar line for HTLS in dead portion of 400KV Kalwa-Padgha-II line.	11/12/2023	18:30	11/12/2023	22:00	This arrangement will be kept till 10.12.2023.
135	720	PLANNED	OCC_573	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	11/12/2023	07:00	11/12/2023	13:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
136	729	PLANNED	OCC_573	POWERGRID_WR1	AKOLA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	11/12/2023	07:00	11/12/2023	20:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
137	738	PLANNED	OCC_573	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line Bay AMP and relay testing	11/12/2023	08:00	11/12/2023	18:00	Outage required on line for Line bay equipment AMP works
138	763	PLANNED	OCC_573	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	11/12/2023	14:00	11/12/2023	20:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
139	764	PLANNED	OCC_573	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	11/12/2023	09:00	11/12/2023	17:00	.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
140	765	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Q/M work.	11/12/2023	09:00	11/12/2023	20:00	outage required
141	775	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	11/12/2023	08:00	12/12/2023	18:00	NA
142	776	PLANNED	OCC_573	MEGPTCL	AKOLA - 765KV - BUS 2	D	Annual maintenance of CVT and LED light installation	11/12/2023	10:00	12/12/2023	18:00	Bus- 2 outage
143	785	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV(Element not found)	C	CB pole overhauling work	11/12/2023	08:00	14/12/2023	18:00	400 KV Padghe I will be in service through TBC
144	786	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV TAPTHITHANDA-ICT-1 AND TAPTHITHANDA - 400KV - BUS 2 @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV (Element not found)	C	CB mechanism overhauling work carried out by M/s CGL	11/12/2023	11:00	14/12/2023	18:00	C outage required for CB mechanism overhauling work
145	791	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	11/12/2023	08:00	16/12/2023	18:00	---
146	800	PLANNED	OCC_573	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	12/12/2023	07:00	12/12/2023	13:00	Line Outages of both 400kV Akola-Wardha-1 and 2 are required one after another for replacement of insulators along with associated Busbar without which work cannot be completed.
147	808	PLANNED	OCC_573	POWERGRID_WR1	AKOLA - 400KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	12/12/2023	07:00	12/12/2023	20:00	Line Outages of both 400kV Akola-Wardha-1 and 2 are required one after another for replacement of insulators along with associated Busbar without which work cannot be completed.
148	819	PLANNED	OCC_573	POWERGRID_WR1	400KV-KALA-KUDUS-2	D	AMP of 404L at MSETCL Kudus Substation. ckt-1 A/r off	12/12/2023	08:00	12/12/2023	18:00	400kV Kala Kudus Circuit-1 will be out of service.
149	840	PLANNED	OCC_573	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-1	D	For AMP Work	12/12/2023	09:00	12/12/2023	18:00	Line Owned By MSETCL
150	850	PLANNED	OCC_573	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	12/12/2023	14:00	12/12/2023	20:00	Line Outages of both 400kV Akola-Wardha-1 and 2 are required one after another for replacement of insulators along with associated Busbar without which work cannot be completed.
151	853	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-II-1	D	Relay testing work & routine maintenance work.	12/12/2023	09:00	12/12/2023	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
152	861	PLANNED	OCC_573	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	C	OverHead HTLS conductor stringing work on 400KV Chandrapur GCR- Chandrapur 2-ckt-1 & Work is carried out above live Bus.	12/12/2023	06:00	17/12/2023	17:00	Permission to above live bus for replacement of existing 0.5 ACSR conductor by HTLS conductor.
153	862	PLANNED	OCC_573	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	OverHead HTLS conductor stringing work on 400KV Chandrapur GCR- Chandrapur 2-ckt-1 & Work is carried out above live Bus.	12/12/2023	06:00	17/12/2023	17:00	Permission to above live bus for replacement of existing 0.5 ACSR conductor by HTLS conductor.
154	863	PLANNED	OCC_573	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	1. For attending the high CRM problem of CB by executing the pole overhauling work. 2.Measurement of tandelta & capacitance of CT. 3. Bay routine maintenance work	12/12/2023	08:00	19/12/2023	18:00	1. During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV PARLI CKT-3, 400KV CHANDRAPUR-PGCIL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service. 2. Tie CB of AC Yard of HVDC Terminal Station Chandrapur will act as a Bus coupler.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
155	872	PLANNED	OCC_573	POWERGRID_WR1	SOLAPUR - 220KV - BUS 2	D	220KV Bus#2 AMP Works Note1 : Before shutdown , All the elements connected with 220kv Bus#2 shall be shifted to 220kv Bus#1 Note 2: Each element shall be shifted to TBC one by one for maintenance of Bus#2 Isolators.	13/12/2023	07:00	13/12/2023	18:00	
156	882	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY - 400KV-PARLI-M-PARLI-2 AND PARLI - 400KV - BUS 2 at PARLI - 400KV	D	For AMP	13/12/2023	08:30	13/12/2023	18:00	CT SEEPAGE ARRESTING
157	909	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location	13/12/2023	08:00	13/12/2023	16:00	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location
158	910	PLANNED	OCC_573	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT tan delta & maintenance work	13/12/2023	09:00	13/12/2023	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV, 125MVAR reactor kept off position during outage.
159	911	PLANNED	OCC_573	MSLDC_OUTAGE	EKTUNI - 765KV B/R 1	D	Diagnostic Testing and Routine Maintenance	13/12/2023	09:00	13/12/2023	18:00	Bus Reactor will be out of service
160	912	PLANNED	OCC_573	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS	13/12/2023	09:00	13/12/2023	18:00	Bay outage
161	913	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Cold line washin	13/12/2023	09:00	13/12/2023	18:00	Load managed on 400kv Lamboti-parli
162	914	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHVAR-1	D	Routine Maint. Work	13/12/2023	09:00	13/12/2023	18:00	NA
163	915	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-I	D	Maintenance work	13/12/2023	09:00	13/12/2023	18:00	The said work is very important
164	916	PLANNED	OCC_573	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	Routine Maint. Work	13/12/2023	09:00	13/12/2023	18:00	NA
165	917	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	13/12/2023	09:30	13/12/2023	17:30	-
166	923	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintainace work	13/12/2023	08:00	14/12/2023	18:00	NA
167	937	PLANNED	OCC_573	POWERGRID_WR1	220KV-PARLI-PARLI-M-2	D	For AMP	14/12/2023	07:30	14/12/2023	18:00	AMP OF LINE CIRCUIT
168	939	PLANNED	OCC_573	POWERGRID_WR1	220KV-AURANGABAD-SHENDRA-2	D	Line Bay AMP Work	14/12/2023	08:00	14/12/2023	17:00	209L
169	970	PLANNED	OCC_573	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	C	For attedning SF6 Leakage & AMP	14/12/2023	10:00	14/12/2023	22:00	
170	971	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARJAT-LONIKHAND-II-1 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Maintenance	14/12/2023	08:00	14/12/2023	18:00	-
171	972	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	14/12/2023	08:00	14/12/2023	18:00	.
172	973	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-1	D	Half yearly maintenance	14/12/2023	09:00	14/12/2023	17:00	-
173	974	PLANNED	OCC_573	MEGPTCL	AKOLA (2) - 765KV - BUS 1	D	Annual maintenance of CVT and LED light installation	14/12/2023	10:00	14/12/2023	18:00	Bus- 1 outage
174	976	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	PID detected weak strings replacement.	14/12/2023	11:00	14/12/2023	18:00	-

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
175	986	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-3	C	Rapid Restoration Scheme work;DFRA;Quarterly bay maintenance work	15/12/2023	09:00	17/12/2023	18:00	315 MVA ICT I and II and 501 MVA ICT IV will be in service
176	990	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-4	C	1) Replacement of B-PH Unit due to PD and Increasing key gases presence of theme fault. 2) Bay Maint work 3) MTAMC work 4) filtration of R ph & Y ph. unit 5) attending Oil leakage R & Yph. unit from various point. 6) Replacement of Differential Relay. 7) If outage not approved for replacement, TBC charging permission required for four days for CB mechanism overhauling work on HV side.	15/12/2023	07:00	26/12/2023	23:30	Weather Conditions should be clear.
177	992	PLANNED	OCC_573	POWERGRID_WRI	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	15/12/2023	07:00	15/12/2023	14:00	
178	994	PLANNED	OCC_573	POWERGRID_WRI	MAIN BAY - 220KV-AURANGABAD-CHITEGAON-1 AND AURANGABAD - 220KV - BUS 1 at AURANGABAD - 220KV	D	Bay AMP Work. Before outage of Bay Line will be shifted on TBC	15/12/2023	07:00	15/12/2023	18:00	207
179	996	PLANNED	OCC_573	POWERGRID_WRI	PARLI - 220KV - BUS 1	D	For Busbar Testing	15/12/2023	07:00	15/12/2023	18:00	For Busbar Testing
180	998	PLANNED	OCC_573	POWERGRID_WRI	KORADI - 400KV - BUS 1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	15/12/2023	07:00	15/12/2023	20:00	
181	999	PLANNED	OCC_573	POWERGRID_WRI	MAIN BAY - 220KV-WARDHA-PUSAD-1 AND WARDHA - 220KV - BUS 1 at Wardha - 220KV	D	For Amp of Bay	15/12/2023	07:00	15/12/2023	20:00	
182	1000	PLANNED	OCC_573	POWERGRID_WRI	220KV-WARDHA-PUSAD-1	D	For Line Bay Amp Works	15/12/2023	07:00	15/12/2023	20:00	
183	1026	PLANNED	OCC_573	POWERGRID_WRI	400KV-CHAKAN-PUNE-PG-1	D	For AMP Work	15/12/2023	09:00	15/12/2023	18:00	Line Owned By MSETCL
184	1040	PLANNED	OCC_573	POWERGRID_WRI	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	15/12/2023	14:00	15/12/2023	20:00	
185	1042	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-2	D	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location	15/12/2023	08:00	15/12/2023	16:00	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location
186	1043	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Badnera S/s	15/12/2023	09:00	15/12/2023	17:00	.
187	1045	PLANNED	OCC_573	MEGPTCL	AKOLA - 765KV - BUS 2	D	Annual maintenance of CVT and LED light installation	15/12/2023	10:00	15/12/2023	18:00	Bus- 2 outage
188	1061	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	15/12/2023	08:00	20/12/2023	18:00	.
189	1069	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual maintenance.	16/12/2023	22:00	17/12/2023	05:00	Outage

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
190	1070	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual maintenance.	16/12/2023	22:00	17/12/2023	05:00	Outage
191	1072	PLANNED	OCC_573	POWERGRID_WRI	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	16/12/2023	07:00	16/12/2023	14:00	
192	1079	PLANNED	OCC_573	POWERGRID_WRI	KORADI - 400KV - BUS 2	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	16/12/2023	07:00	16/12/2023	20:00	
193	1094	PLANNED	OCC_573	POWERGRID_WRI	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	For AMP Work	16/12/2023	09:00	16/12/2023	18:00	
194	1102	PLANNED	OCC_573	POWERGRID_WRI	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	16/12/2023	14:00	16/12/2023	20:00	
195	1103	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Outage is required on safety purpose for work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	16/12/2023	04:00	16/12/2023	09:00	Outage is required on safety purpose for work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
196	1104	PLANNED	OCC_573	MEGPTCL	KORADI-III - 765KV B/R 1	D	Six monthly changeover of B- Ph Reactor to be taken into service in place of Spare- Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 22.06.2023	16/12/2023	09:00	16/12/2023	14:00	Bus Reactor outage. Last changeover date 22.06.2023
197	1105	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Repairing and Overhauling of 89A PG isolators, Routine Maintenance and DT .	16/12/2023	10:00	16/12/2023	18:00	-
198	1107	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) CT testing. (2) Bay maintenance work. (3) String cold washing work	16/12/2023	09:00	17/12/2023	18:00	-
199	1108	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV WARORA-ICT-1	C	Removing cable from TB and Glands in Panel for taking continuity test and confirming other cables also i.e control room to ICT , Control room to panel.	16/12/2023	09:00	31/12/2023	18:00	Reactor (Bay no 402) is charged through Main Bay CB.
200	1117	PLANNED	OCC_573	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-4	D	For AMP Work	17/12/2023	09:00	17/12/2023	18:00	
201	1120	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Bay maintenance & equipment testing.	17/12/2023	07:00	17/12/2023	19:00	Bay maintenance & equipment testing.
202	1121	PLANNED	OCC_573	ATIL	400KV-TIRODA-WARORA-1	D	Annual maintenance of line	17/12/2023	08:00	17/12/2023	18:00	Line outage
203	1122	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work.	17/12/2023	09:00	17/12/2023	18:00	Weather condition should be clear.
204	1123	PLANNED	OCC_573	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 1	D	for diagnostic testing work	17/12/2023	09:00	17/12/2023	18:00	-
205	1124	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	SSN to DSN replacement of insulator string Project & FWC mid span joint	17/12/2023	09:00	17/12/2023	18:31	SSN to DSN replacement of insulator string Project & FWC mid span joint
206	1125	PLANNED	OCC_573	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	D	ICT changeover activity as per CEA guideline Spare ICT taken into service in place of Y- Ph ICT at Akola SS	17/12/2023	10:00	17/12/2023	18:00	ICT outage

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
207	1132	PLANNED	OCC_573	POWERGRID_WR1	TIE BAY - 400KV-WARDHA-AURANGABAD-1 AND 400KV-AKOLA-AURANGABAD-1 at AURANGABAD - 400KV	D	Bay AMP Work	18/12/2023	07:00	18/12/2023	18:00	414
208	1134	PLANNED	OCC_573	POWERGRID_WR1	PARLI - 220KV - BUS 2	D	For Busbar Testing	18/12/2023	07:00	18/12/2023	18:00	For Busbar Testing
209	1145	PLANNED	OCC_573	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1	D	Line Bay AMP and relay testing	18/12/2023	08:00	18/12/2023	18:00	Outage required on line for Line bay equipment AMP works
210	1178	PLANNED	OCC_573	ATIL	400KV-TIRODA-WARORA-2	D	Annual maintenance of line	18/12/2023	08:00	18/12/2023	18:00	Line outage
211	1179	PLANNED	OCC_573	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc. Routine Maintenance Work at 132kv Dharni SS.	18/12/2023	09:00	18/12/2023	17:00	outage
212	1180	PLANNED	OCC_573	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	18/12/2023	09:00	18/12/2023	18:00	The said work is very important
213	1181	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Q/m work.	18/12/2023	09:00	18/12/2023	20:00	outage required
214	1184	PLANNED	OCC_573	POWERGRID_WR1	400KV-BHILAI-KORADI-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Bhilai Line Out of Service.	18/12/2023	07:00	19/12/2023	20:00	
215	1191	PLANNED	OCC_573	APML	400KV/11.5KV TIRODA-ST-2	C	TRANSFORMER PAINTING WORK	18/12/2023	09:00	20/12/2023	18:00	400KV Line-2 will be in service on main bay
216	1195	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1	C	CB pole overhauling work	18/12/2023	09:00	21/12/2023	18:00	400 KV Padghe II will be in service through TBC
217	1198	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY - 400KV-BHILAI-KORADI-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of BHI CGL CB at Koradi SS, 400kv Koradi-Bhilai Line	18/12/2023	07:00	23/12/2023	20:00	
218	1200	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	18/12/2023	08:00	23/12/2023	18:00	---
219	1205	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	Bunching at Loc.No.03 & Loc.No132 of 400kv padghe kharghar line (Dead line) for HTLS in dead portion of PADGHE - KALWA CKT - 1	19/12/2023	22:00	02/02/2024	18:00	After above arrangement Tapping of 400KV Kharghar - Talegoan line at Loc no.9 will be done with 400KV Padghe-Kharghar line to form Temporary 400kv Padghe - kharghar- Talegoan line.
220	1207	PLANNED	OCC_573	POWERGRID_WR1	400KV-BHILAI-KORADI-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Bhilai line on TBC Bay.	19/12/2023	07:00	23/12/2023	20:00	
221	1209	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	Tapping Arrangement at Loc.No09 with 400KV Padghe-Kharghar line thereby formation of New 400kv Padghe - kharghar- Talegoan line after bunching of 400KV Kalwa-Padghe-I line with dead 400KV Padghe-Kharghar line for HTLS in dead portion of 400KV Kalwa-Padghe-I line.	19/12/2023	22:00	20/12/2023	05:00	This arrangement will be kept till 25.01.2024.
222	1228	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY OF 400KV-KUDUS-PADGHE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV	D	AMP of 415 bay at MSETCL Kudus	19/12/2023	08:00	19/12/2023	18:00	400KV-PADGHE-KUDUS-1 will be in Service through Tie Bay 414
223	1253	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1	D	CB Testing and Routine Maintenance	19/12/2023	09:00	19/12/2023	18:00	Bus Reactor will be in service through its 712 (TIE) Bay
224	1254	PLANNED	OCC_573	APTCL	400KV-AKOLA-AKOLA (2)-1	D	Routine maintenance & testing work	19/12/2023	09:00	19/12/2023	18:00	Yelwan Ckt-02 will be in service
225	1255	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Diagnostic testing & Maintenance work	19/12/2023	10:00	19/12/2023	13:00	--

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
226	1256	PLANNED	OCC_573	MSLDC_OUTAGE	ALKUD - 400KV - BUS 2	D	Diagnostic testing & Maintenance work	19/12/2023	10:00	19/12/2023	17:00	Load will be managed on 400KV Main Bus-2
227	1257	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Diagnostic testing & Maintenance work	19/12/2023	10:00	19/12/2023	17:00	Load will be managed on 400KV Alkud Solapur line
228	1259	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Diagnostic testing & Maintenance work	19/12/2023	14:00	19/12/2023	17:00	--
229	1261	PLANNED	OCC_573	POWERGRID_WRI	400KV-PARLI NEW-PARLI-M-2	C	For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS". AR to be kept in non Auto mode for 400KV-PARLI NEW-PARLI-M-1 for HTLS Reconductoring works.	20/12/2023	07:00	30/12/2023	18:00	for Re-conductoring work
230	1271	PLANNED	OCC_573	POWERGRID_WRI	220KV-AURANGABAD-CHITEGAON-2	D	Line Bay AMP Work	20/12/2023	08:00	20/12/2023	17:00	206L
231	1278	PLANNED	OCC_573	POWERGRID_WRI	MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	D	AMP of 404 bay at MSETCL Kudus	20/12/2023	08:00	20/12/2023	18:00	400KV-KALA-KUDUS-1 will be in Service through Tie Bay 405
232	1284	PLANNED	OCC_573	GETCO	220kV Navsari-Nashik line no.1	D	Routine bay maintenance & line maintenance	20/12/2023	09:00	20/12/2023	17:00	
233	1306	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	20/12/2023	09:00	20/12/2023	17:30	-
234	1307	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1	D	CB Diagnostic Testing and Routine Maintenance	20/12/2023	09:00	20/12/2023	18:00	Bus Reactor will be service through its Main (711) Bay
235	1308	PLANNED	OCC_573	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS	20/12/2023	09:00	20/12/2023	18:00	Bay outage
236	1309	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Cold line washin	20/12/2023	09:00	20/12/2023	18:00	Load managed on 220kV Jeur-Tembhurni
237	1310	PLANNED	OCC_573	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	Routine Maint. Work	20/12/2023	09:00	20/12/2023	18:00	NA
238	1311	PLANNED	OCC_573	MEGPTCL	AKOLA (2) - 765KV B/R 1	D	Bus Reactor changeover activity as per CEA guideline R- Ph reactor taken into service in place of B- Ph reactor at Akola SS	20/12/2023	10:00	20/12/2023	18:00	Bus Reactor Outage
239	1321	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Replacement of faulty insulator in live line method.	21/12/2023	08:00	31/12/2023	18:00	AR off
240	1322	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Replacement of faulty insulator in live line method.	21/12/2023	08:00	31/12/2023	18:00	AR off
241	1349	PLANNED	OCC_573	GETCO	220kV Navsari-Nashik line no.2	D	Routine bay maintenance & line maintenance	21/12/2023	09:00	21/12/2023	17:00	
242	1368	PLANNED	OCC_573	MSLDC_OUTAGE	LONIKHAND-II - 400KV - BUS 1	D	Diagnostic testing and Maintenance	21/12/2023	08:00	21/12/2023	18:00	-
243	1369	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	21/12/2023	08:00	21/12/2023	18:00	.
244	1370	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Diagnostic testing work .	21/12/2023	09:00	21/12/2023	17:00	400KV WARORA-IEPL Line is in ckt
245	1376	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Restranging of Earth wire between span 275 to 286	21/12/2023	08:00	22/12/2023	18:30	400kV Ektuni ckt I will be in service

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
246	1378	PLANNED	OCC_573	APML	400KV/11.5KV TIRODA-ST-3	C	TRANSFORMER PAINTING WORK	21/12/2023	09:00	23/12/2023	18:00	ST-5 will be in service with main bay
247	1379	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Earthwire Replacement Work	21/12/2023	08:00	23/12/2023	18:00	----
248	1383	PLANNED	OCC_573	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-4	C	Rapid Restoration Scheme work; LV LBB relay, LV CT tan D, Bushing tan D, DFRA; Quarterly bay maintenance work	22/12/2023	09:00	24/12/2023	18:00	315 MVA ICT I and II and 501 MVA ICT III will be in service
249	1384	PLANNED	OCC_573	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.	22/12/2023	09:00	28/12/2023	18:30	Weather condition should be clear for Hot Line Work. Hot Line Team will be present on site.
250	1385	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	1.Diagnostic Testing Work 2.Replacement of all phase LA. 3. Replacement of Distance & Over Voltage Relay. 4.CB Mechanism Pole Overhauling Work. 5. A & B Bus PG Isolator Maintenance Work. 6.B Bus PG Isolator Replacement work under LES Scheme. 7.Replacement of 29 D Isolator Under LES Scheme. After removing IPS Tube Between 29 C & 29 D Isolator BBLR-2 line will be taken on TBC. 8.After Completion of work BBLR-2 line will required hand trip for 3 Hrs for reconnection of IPS Tube between 29C & 29D Isolator.	22/12/2023	09:00	28/12/2023	23:00	Weather Condition should be clear.
251	1388	PLANNED	OCC_573	POWERGRID_WR1	SOLAPUR - 220KV - BUS 1	D	220KV Bus#1 AMP Works Note 1: Before shutdown , All the elements connected with 220kV Bus#1 shall be shifted to 220kV Bus#2 Note 2: Each element shall be shifted to TBC one by one for maintenance of Bus#1 Isolators.	22/12/2023	07:00	22/12/2023	18:00	
252	1395	PLANNED	OCC_573	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Annual maintenance.	22/12/2023	08:00	22/12/2023	18:00	Outage
253	1396	PLANNED	OCC_573	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for annual maintenance of 400KV Kolhapur-MS-Solapur-2 line.	22/12/2023	08:00	22/12/2023	18:00	AR off
254	1397	PLANNED	OCC_573	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for annual maintenance of 400KV Kolhapur-MS-Solapur-2 line.	22/12/2023	08:00	22/12/2023	18:00	AR off
255	1427	PLANNED	OCC_573	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS	22/12/2023	09:00	22/12/2023	18:00	Bay outage
256	1428	PLANNED	OCC_573	MSLDC_OUTAGE	AKOLA - 400KV - BUS 2	D	Routine and isolator maintenance & testing work	22/12/2023	09:00	22/12/2023	18:00	Bus-01 Will be in service
257	1437	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	22/12/2023	08:00	27/12/2023	18:00	.
258	1440	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual maintenance.	23/12/2023	22:00	24/12/2023	05:00	Outage
259	1441	PLANNED	OCC_573	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual maintenance.	23/12/2023	22:00	24/12/2023	05:00	Outage
260	1442	PLANNED	OCC_573	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	C	For attedning SF6 Leakage & AMP	23/12/2023	22:00	24/12/2023	05:00	

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
261	1443	PLANNED	OCC_573	MSLDC_OUTAGE	KHARGHAR - 400KV - BUS 2	C	Replacement of deteriorated Bus conductor span	23/12/2023	07:00	25/12/2023	18:00	All 400kV Elements of B Bus will be transferred on A bus via TBC and Bus coupler will be kept off
262	1448	PLANNED	OCC_573	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	Annual maintenance.	23/12/2023	08:00	23/12/2023	18:00	Outage
263	1449	PLANNED	OCC_573	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance of 400KV Kolhapur-MS-Alkud-1	23/12/2023	08:00	23/12/2023	18:00	AR off
264	1452	PLANNED	OCC_573	POWERGRID_WRI	MAIN BAY - PARLI - 400KV B/R 2 AND PARLI - 400KV - BUS 1 at PARLI - 400KV	D	For AMP	23/12/2023	08:30	23/12/2023	18:00	AMP OF BAY
265	1464	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Outage is required on safety purpose for work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	23/12/2023	04:00	23/12/2023	09:00	Outage is required on safety purpose for work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
266	1466	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Diagnostic testing work .	23/12/2023	09:00	23/12/2023	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
267	1467	PLANNED	OCC_573	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	For changeover of Y- Phase LR with R- Phase LR @ Ektuni SS for replacement of mechanical protection & bushing CT cable in Y- Phase LR	23/12/2023	10:00	23/12/2023	18:00	Line outage
268	1469	PLANNED	OCC_573	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	C	220kV B-Bus Isolator r/m works.	23/12/2023	07:00	24/12/2023	20:00	220KV B-Bus has following elements: 220kV Ghodbunder Line 220kV PGCIL Line 1 220kV Versova Line 200MVA , 220/132kV ICT No.1 100MVA, 220/33-33kV PTR 220kV PGCIL Line 3
269	1470	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) CT & CVT testing. (2) Bay maintenance work. (3) String cold washing work	23/12/2023	09:00	24/12/2023	18:00	-
270	1474	PLANNED	OCC_573	WTPL	400KV-ALKUD-SOLAPUR-1	D	Annual maintenance.	24/12/2023	08:00	24/12/2023	18:00	Outage
271	1475	PLANNED	OCC_573	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance of 400KV Alkud-MS-Solapur-1	24/12/2023	08:00	24/12/2023	18:00	AR off
272	1476	PLANNED	OCC_573	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	D	Annual maintenance of line	24/12/2023	08:00	24/12/2023	18:00	Line outage
273	1477	PLANNED	OCC_573	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 2	D	for diagnostic testing work	24/12/2023	09:00	24/12/2023	18:00	-
274	1478	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN replacement of insulator string Project & FWC mid span joint	24/12/2023	09:00	24/12/2023	18:30	SSN to DSN replacement of insulator string Project & FWC mid span joint
275	1479	PLANNED	OCC_573	NCA	400KV-SSP-DHULE-MS-2	C	Major Maintenance of GIS	25/12/2023	08:00	06/01/2024	18:00	
276	1484	PLANNED	OCC_573	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Annual maintenance of line	25/12/2023	08:00	25/12/2023	18:00	Line outage
277	1485	PLANNED	OCC_573	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Bus CVT tan D testing	25/12/2023	08:00	25/12/2023	18:00	All feeders and ICT on Main Bus II will be shifted on Main Bus I through TBC
278	1487	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold Washing Work	25/12/2023	08:00	26/12/2023	18:00	---

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
279	1516	PLANNED	OCC_573	POWERGRID_WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Sarni Line Out of Service.	26/12/2023	07:00	27/12/2023	20:00	
280	1520	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of SRN CGL CB at Koradi SS, 400kv Koradi-Sarni Line	26/12/2023	07:00	31/12/2023	20:00	
281	1531	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-1 AND KOLHAPUR-MS - 400KV - BUS 1 at KOLHAPUR-MS - 400KV	D	Bay AMP	27/12/2023	08:00	27/12/2023	18:00	Outage required on CB only. Line can be kept in service through TBC CB.
282	1548	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	27/12/2023	09:00	27/12/2023	17:00	.
283	1549	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	27/12/2023	09:00	27/12/2023	17:30	-
284	1550	PLANNED	OCC_573	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	27/12/2023	09:00	27/12/2023	18:00	The said work is very important
285	1551	PLANNED	OCC_573	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	BUS PT Capacitance and tan D testing	27/12/2023	09:00	27/12/2023	18:00	All feeders and ICTs on Main Bus II will be shifted on Main Bus I through TBC
286	1552	PLANNED	OCC_573	MSLDC_OUTAGE	AKOLA - 400KV - BUS 1	D	Routine maintenance and Isolator & testing Work	27/12/2023	09:00	27/12/2023	18:00	Bus -02 will be in service
287	1553	PLANNED	OCC_573	MSLDC_OUTAGE	BALE - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	27/12/2023	09:00	27/12/2023	18:00	Quarterly Maintenance
288	1554	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	27/12/2023	09:00	27/12/2023	18:00	The said work is very important
289	1555	PLANNED	OCC_573	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	27/12/2023	09:00	27/12/2023	18:00	NA
290	1563	PLANNED	OCC_573	POWERGRID_WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Sarni line on TBC Bay.	28/12/2023	07:00	31/12/2023	20:00	
291	1565	PLANNED	OCC_573	POWERGRID_WR1	MAIN BAY - DHULE-MS - 400KV B/R 1 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	D	Bay AMP Work	28/12/2023	07:00	28/12/2023	18:00	PGG
292	1575	PLANNED	OCC_573	POWERGRID_WR2	220KV-BOISAR-BORIVALI-1	D	AMP	28/12/2023	09:00	28/12/2023	17:30	PG-WR2- BOISAR SS
293	1587	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	28/12/2023	08:00	28/12/2023	18:00	.
294	1588	PLANNED	OCC_573	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400	D	Replacement of 89A PG isolator, Routine Maintenance and DT .	28/12/2023	09:00	28/12/2023	21:00	-
295	1600	PLANNED	OCC_573	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Line Bay AMP works & attedning Shutdown nature defects	29/12/2023	08:00	29/12/2023	18:00	400KV-KOLHAPUR MS-KOLHAPUR GIS-2 AR to be kept in Non-auto mode for safety in TLM works.
296	1615	PLANNED	OCC_573	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	29/12/2023	08:00	29/12/2023	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
297	1616	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	29/12/2023	08:00	29/12/2023	18:00	.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
298	1619	PLANNED	OCC_573	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	C	OPGW repairing work	29/12/2023	08:00	30/12/2023	18:00	AR in Non Auto
299	1620	PLANNED	OCC_573	NCA	400KV-SSP-DHULE-MS-1	C	Major Maintenance of GIS	30/12/2023	08:00	31/12/2023	18:00	
300	1636	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Outage is required on safety purpose for work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	30/12/2023	04:00	30/12/2023	09:00	Outage is required on safety purpose for work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
301	1637	PLANNED	OCC_573	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Diagnostic testing work .	30/12/2023	08:00	30/12/2023	17:00	Line will be charged through Main CB 429.
302	1638	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	30/12/2023	08:00	30/12/2023	18:00	.
303	1639	PLANNED	OCC_573	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Six monthly changeover of Spare- Ph to be taken into service in place of R- Ph ICT as per CEA regulation at Koradi- III SS. Last changeover date 03.07.2023	30/12/2023	09:00	30/12/2023	18:00	ICT outage. Last changeover date 03.07.2023
304	1640	PLANNED	OCC_573	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance and Insulator cleaning work	30/12/2023	08:00	31/12/2023	18:00	400kV Padghe I will be in service
305	1647	PLANNED	OCC_573	MSLDC_OUTAGE	KALWA - 400KV - BUS 1	D	400KV Padgha II stub bus erection work.	31/12/2023	08:00	31/12/2023	18:00	Partial outage will be taken on 400KV A-Bus
306	1648	PLANNED	OCC_573	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	31/12/2023	08:00	31/12/2023	18:00	.

Additional Monthly Outage list approved in WRLDC OCCM for the Month of December 2023

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time
1	36		OCC_573	POWERGRID_WRI	220KV-PARLI-OSMANABAD-M-1	C	For HTLS Reconductoring works of 400kV Parli-Parli(M) line-Ckt#2	15-Dec-23	6:00	18-Dec-23	18:00
2	37	ADDITIONAL	OCC_573	POWERGRID_WRI	220KV-GIRWALI-MURUD LINE	C	For HTLS Reconductoring works of 400kV Parli-Parli(M) line-Ckt#2	15-Dec-23	6:00	18-Dec-23	18:00
3	38	ADDITIONAL	OCC_573	POWERGRID_WRI	132KV-GIRWALI-YEDESHWARI LINE	D	For HTLS Reconductoring works of 400kV Parli-Parli(M) line-Ckt#2	20-Dec-23	7:00	20-Dec-23	19:00
4	39		OCC_573	POWERGRID_WRI	132KV-GIRWALI-YEDESHWARI LINE	D	For HTLS Reconductoring works of 400kV Parli-Parli(M) line-Ckt#2	22-Dec-23	7:00	22-Dec-23	19:00

State Element outage list for the month of December 2023

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	WARORA - IEPL	01-Dec-23	09:00	01-Dec-23	17:00	Daily	Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
2	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	01-Dec-23	09:00	31-Dec-23	18:00	Daily	PID testing work Permission for Auto Reclose to be kept in Non auto mode	MSETCL	MSETCL	Permission for Auto Reclose to be kept in Non auto mode
3	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	02-Dec-23	10:00	02-Dec-23	18:00	Daily	Routine maintenance and DT work	MSETCL	MSETCL	-
4	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	02-Dec-23	08:00	02-Dec-23	18:00	Daily	1. Maintenance of ICT 2. Measurement and alignment of Isolators 2. Bay routine maintenance work	MSETCL	MSETCL	1. During outage, 400KV ICT-1 & 220KV Chandrapur-2 will be in service.
5	400 KV	BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR	02-Dec-23	10:00	02-Dec-23	15:00	Daily	CB DCRM/Timing;Differential relay testing	MSETCL	MSETCL	Reactor is out of service during day hours
6	400 KV	CHANDRAPUR-PARLI CKT-3	04-Dec-23	09:00	04-Dec-23	18:00	Daily	Reactor Testing work, Bay maintenance work Nut bolt & hardware tightning work to be done	MSETCL	MSETCL	-
7	400 KV	KHADKA - BABLESHWAR	04-Dec-23	09:00	04-Dec-23	18:00	Daily	CVT tan D testing work and bay maintenance work	MSETCL	MSETCL	400kV Aurangabad,400kV Dhule ckt I&II, Ektuni I&II will be in service
8	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	05-Dec-23	09:00	05-Dec-23	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition ,respective ckt charged through its own main CB.
9	400 KV	CHANDRAPUR - KHAPERKHEDA	05-Dec-23	08:00	05-Dec-23	18:00	Daily	1. Measurement of tandelta & capacitance of Line CVT. 2. Relay Testing work. 2. Bay routine maintenance work	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV PARLI CKT-3, 400KV CHANDRAPUR-PGCII
10	400 KV	500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	06-Dec-23	09:00	07-Dec-23	17:00	Continuous	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
11	400 KV	NEW KOYNA-KARAD CKT - 1	06-Dec-23	08:00	06-Dec-23	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
12	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	06-Dec-23	09:00	06-Dec-23	17:00	Daily	Rapid Restoration Work of ICTs	MSETCL	MSETCL	NA
13	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	07-Dec-23	08:00	07-Dec-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
14	400 KV	NEW KOYNA - STAGE IV CKT - 1	07-Dec-23	08:00	07-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
15	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	07-Dec-23	10:00	08-Dec-23	21:00	Continuous	For Overhauling of SERGI NIFPS Fire system for ICT No.1, Repairing and Overhauling of 89A PG isolators, Routine Maintenance and DT.	MSETCL	MSETCL	-
16	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	07-Dec-23	10:30	07-Dec-23	18:00	Daily	Line CT Tan-d Test, Main CB DCRM test	MSETCL	MSETCL	Line CT Tan-d Test, Main CB DCRM test
17	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	07-Dec-23	08:00	07-Dec-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work CB DCRM timing tan delta quaterly bay maintenance work.	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I&II, Ektuni I&II will be in service
18	400 KV	KHADKA - BABLESHWAR	07-Dec-23	09:00	07-Dec-23	17:00	Daily	For bay maintenance works.	MSETCL	MSETCL	As per outage plan.
19	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	08-Dec-23	09:30	08-Dec-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-2 & ICT-3 will continue to remain in service
20	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	08-Dec-23	08:00	08-Dec-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I&II, Ektuni I&II will be in service
21	400 KV	FUTURE CKT - 1 @ WARORA	08-Dec-23	09:00	08-Dec-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
22	400 KV	KORADI II - IEPL	08-Dec-23	06:00	08-Dec-23	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	NA
23	400 KV	STATION TF - 1 @ KORADI -2	08-Dec-23	10:00	08-Dec-23	17:30	Daily	Diagnostic testing of Line current Transformer & Routine nut bolt tightening	MSETCL	MSETCL	Load will be shifted to Station Transformer -II
24	400 KV	NEW KOYNA-KARAD CKT - 2	08-Dec-23	08:00	08-Dec-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
25	400 KV	NEW KOYNA-KARAD CKT - 2	09-Dec-23	08:00	09-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
26	400 KV	NEW KOYNA-KARAD CKT - 1	09-Dec-23	08:00	09-Dec-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
27	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	09-Dec-23	09:00	09-Dec-23	18:00	Daily	Differential relay,LV CB DCRM/timing,DFRA,Excitation current;Quarterly bay maintenace work	MSETCL	MSETCL	315 MVA ICT II;501 MVA ICT III and IV will be in service
28	400 KV	STATION TF No 4 @ CHANDRAPUR GCR	09-Dec-23	08:00	09-Dec-23	18:00	Daily	1.Measurement of CB timing, CRM, DCRM. 2. STN-4 bay will be in service via TBC-2	MSETCL	MSETCL	STN-4 bay will be in service via TBC-2

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
29	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	10-Dec-23	09:00	10-Dec-23	18:00	Daily	Distance M1 & M2 Relay retrofitting work, Bay maintenance work, String replacement work at loc no. 843 and Nut bolt & Hardware tightning work to be done	MSETCL	MSETCL	-
30	400 KV	PADGHE - NAGOTHANE CKT - 2	10-Dec-23	12:00	10-Dec-23	22:00	Daily	1) H/t requires for safety purposed for re connection of jumper by cold line method between Nago I & II 2) shifting from A bus to B bus after Bus conductor replacement work.	MSETCL	MSETCL	Weather condition should be clear
31	400 KV	400/220 KV 500 MVA ICT - 5 @ PADGHE	10-Dec-23	18:00	10-Dec-23	23:30	Daily	1) Shifting from A bus to B bus for partial Bus outage	MSETCL	MSETCL	Weather condition should be clear
32	400 KV	400 KV FUTURE BAY II @ WARORA	11-Dec-23	09:00	11-Dec-23	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
33	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	11-Dec-23	09:00	12-Dec-23	18:00	Daily	Nut bolt hardware tightening work & Earth wire Stringing Work loc.no.497-500	MSETCL	MSETCL	-
34	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	11-Dec-23	09:00	11-Dec-23	23:59	Daily	1. C & tan delta testing of Bushings & Wdg. 2. QM of HV & IV Bays. 3. Supervisory protection Testing. 4. NIFPS Trials. 5. CB Testing	MSETCL	MSETCL	Monday is load staggering day for Kolhapur.
35	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	11-Dec-23	08:00	11-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
36	400 KV	CHANDRAPUR-PARLI CKT-3	12-Dec-23	08:00	12-Dec-23	16:00	Daily	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location	MSETCL	MSETCL	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location
37	400 KV	400/220 KV 500 MVA ICT @ ALKUD	12-Dec-23	10:00	12-Dec-23	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	Load will be managed on 400KV Karad & Talandge S/S
38	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	12-Dec-23	10:00	12-Dec-23	13:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
39	400 KV	AKOLA - KHADKA (BHUSAWAL)	12-Dec-23	09:00	12-Dec-23	18:00	Daily	Routine maintenance & testing Work	MSETCL	MSETCL	Nandgaon Ckt will be in service
40	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	12-Dec-23	14:00	12-Dec-23	17:00	Daily	Diagnostic testing & Maintenance work	MSETCL	MSETCL	--
41	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	13-Dec-23	10:00	13-Dec-23	17:00	Daily	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
42	400 KV	167 MVA SPARE ICT @ TALANDGE	13-Dec-23	09:00	13-Dec-23	18:00	Daily	Q/M work.	MSETCL	MSETCL	outage required

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
43	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	13-Dec-23	09:00	13-Dec-23	17:00	Daily	Rapid Restoration Work of ICTs	MSETCL	MSETCL	NA
44	400 KV	NEW KOYNA - STAGE IV CKT - 2	13-Dec-23	08:00	13-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
45	400 KV	PADGHE - NAGOTHANE CKT - 2	13-Dec-23	09:00	13-Dec-23	18:30	Daily	1.Replacement of Distance & Over Voltage Relay. 2.Bay Maintenance work. 3.Diagonostic Testing work. 4.MTAMC Work.	MSETCL	MSETCL	Weather Condition should be clear.
46	400 KV	LONIKAND - JEJURI CKT - 1	14-Dec-23	08:00	14-Dec-23	18:00	Daily	Cold washing of Insulator Strings	MSETCL	MSETCL	-
47	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	14-Dec-23	09:30	14-Dec-23	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-3 will continue to remain in service
48	400 KV	JEJURI - KARAD	14-Dec-23	08:00	14-Dec-23	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
49	400 KV	TIE BAY (412) OF KARJAT CKT - 1 @ LONIKAND 2	14-Dec-23	08:00	14-Dec-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
50	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	14-Dec-23	08:00	14-Dec-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
51	400 KV	WARORA - IEPL	14-Dec-23	09:00	14-Dec-23	17:00	Daily	Routine maintenance and diagnostic testing such as CVT/ CT tan delta, and, isolator maintenance work	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt .
52	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	14-Dec-23	10:00	14-Dec-23	17:00	Daily	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
53	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	14-Dec-23	10:30	14-Dec-23	18:00	Daily	408-LINE CT & Bus CT Tan-d, 409-TIE-3 CT Tan-d. TEST	MSETCL	MSETCL	408-LINE CT & Bus CT Tan-d, 409- TIE-3 CT Tan-d. TEST
54	400 KV	NEW KOYNA-KARAD CKT - 1	14-Dec-23	08:00	14-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
55	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	15-Dec-23	08:00	15-Dec-23	18:00	Daily	Diagnostic testing and R&M Work	MSETCL	MSETCL	ICT-2 & ICT-3 will remain in Service
56	400 KV	NEW KOYNA-KARAD CKT - 2	15-Dec-23	08:00	15-Dec-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
57	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	15-Dec-23	09:00	15-Dec-23	18:00	Daily	Routine maintenance & Testing work	MSETCL	MSETCL	ICT-01 & 03 Will be in service
58	400 KV	NEW KOYNA-KARAD CKT - 1	16-Dec-23	08:00	16-Dec-23	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
59	400 KV	JAIGAD - NEW KOYNA CKT - 1	16-Dec-23	08:00	16-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
60	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	18-Dec-23	08:00	18-Dec-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I&II, Ektuni I&II will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
61	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	18-Dec-23	08:00	18-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work & CTR Maintenance	MSETCL	MSETCL	---
62	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	18-Dec-23	09:00	18-Dec-23	18:00	Daily	Spacer replacement/Nut bolt Hardware tightening/ loc.no.497-500 Earth wire stringing work	MSETCL	MSETCL	-
63	400 KV	KARAD - TALANDGE CKT - 2	18-Dec-23	09:00	18-Dec-23	23:00	Daily	1. Relay Testing work 2. AR ckt Modification 3.C & tan delta testing of CT 4. QM of Bay	MSETCL	MSETCL	Monday is load staggering day for Kolhapur
64	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	19-Dec-23	08:00	19-Dec-23	18:00	Daily	Routine Line maintenance and Insulator cleaning work	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I&II, Ektuni I&II will be in service
65	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	19-Dec-23	08:00	19-Dec-23	16:00	Daily	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location	MSETCL	MSETCL	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location
66	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	19-Dec-23	09:00	19-Dec-23	18:00	Daily	(1) IV CT testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
67	400 KV	PADGHE - NAGOTHANE CKT - 1	20-Dec-23	09:30	20-Dec-23	19:00	Daily	1.Replacement of Distance & Over Voltage Relay. 2.Bay Maintenance work. 3.Diagnostic Testing work. 4.MTAMC Work.	MSETCL	MSETCL	Weather condition should be clear.
68	400 KV	JAIGAD - NEW KOYNA CKT - 2	20-Dec-23	08:00	20-Dec-23	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
69	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	20-Dec-23	08:00	20-Dec-23	15:00	Daily	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location	MSETCL	MSETCL	For conductor & earthwire hardware nut bolt tightening & fitting work at various tower location
70	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	20-Dec-23	10:00	20-Dec-23	17:00	Daily	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
71	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	21-Dec-23	10:00	22-Dec-23	21:00	Continuous	For Overhauling of SERGI NIFPS Fire system for ICT No.2, Repairing and Overhauling of 89B PG isolators, Routine Maintenance and DT.	MSETCL	MSETCL	-
72	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	21-Dec-23	09:30	21-Dec-23	18:00	Daily	For RRS Trial work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
73	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	21-Dec-23	08:00	21-Dec-23	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
74	400 KV	GTR - 7 @ CHANDRAPUR	21-Dec-23	08:00	21-Dec-23	18:00	Daily	1.Measurement of CB timing, CRM, DCRM. 2. GTR-7 will be in service via TBC-2	MSETCL	MSETCL	GTR-7 will be in service via TBC-2

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
75	400 KV	MAIN BAY (413) OF GT - 8 @ CHANDRAPUR SWITCHING SS	21-Dec-23	10:00	21-Dec-23	17:00	Daily	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
76	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	22-Dec-23	08:00	22-Dec-23	13:00	Daily	tightening of jumper nut bolt at Loc. no. LILO-1	MSETCL	MSETCL	tightening of jumper nut bolt at Loc. no. LILO-1
77	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	22-Dec-23	08:00	23-Dec-23	18:00	Continuous	1. Measurement of tandelta & capacitance of Line CVT. 2. Measurement of tandelta & C of CT. 2. Bay routine maintenance work	MSETCL	MSETCL	1. During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV PARLI CKT-3, 400KV CHANDRAPUR-PGCIL Bhadrawati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service. 2. Tie CB of AC Yard of HVDC Terminal Station Chandrapur be act as a Bus coupler.
78	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	22-Dec-23	08:00	22-Dec-23	18:00	Daily	Diagnostic testing and R&M Work	MSETCL	MSETCL	ICT-1& ICT-3 will remain in service
79	400 KV	TIE BAY (414) OF GT-8 @ CHANDRAPUR SWITCHING SS	22-Dec-23	10:00	22-Dec-23	17:00	Daily	Diagnostic testing and allied maintenance work	MSETCL	MSETCL	Diagnostic testing and allied maintenance work
80	400 KV	WARORA - IEPL	22-Dec-23	09:00	22-Dec-23	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
81	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	25-Dec-23	09:00	25-Dec-23	23:59	Daily	1. C & tan delta testing of Bushing & Wdg. 2. QM of HV & IV Bays 3. CB Testing work 4. NIFPS Trials 5. Supervisory protection trials	MSETCL	MSETCL	Monday is load staggering day for Kolhapur
82	400 KV	TBC @ BABHALESHWAR	26-Dec-23	09:00	26-Dec-23	16:00	Daily	CB DCRM/Timing	MSETCL	MSETCL	TBC will be free for avanning outage
83	400 KV	CHANDRAPUR - KHAPERKHEDA	27-Dec-23	09:00	27-Dec-23	17:00	Daily	High Level Jumper Tigtening & Isolator Maintenance Work	MSETCL	MSETCL	NA
84	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	27-Dec-23	08:00	27-Dec-23	17:00	Daily	Conductor & earthwire hardware tightening & fitting work	MSETCL	MSETCL	Conductor & earthwire hardware tightening & fitting work
85	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	28-Dec-23	08:00	28-Dec-23	16:00	Daily	Conductor & earthwire hardware tightening & fitting work	MSETCL	MSETCL	Conductor & earthwire hardware tightening & fitting work
86	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	28-Dec-23	09:00	28-Dec-23	18:00	Daily	Breaker testing work, Bay maintenance work and Nut bolt & hardware tightening works to be done	MSETCL	MSETCL	-
87	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	28-Dec-23	08:00	28-Dec-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
88	400 KV	MAIN BAY (419) OF 400/220/33kV 500MVA ICT-1 @ LONIKAND 2	28-Dec-23	08:00	28-Dec-23	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
89	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	28-Dec-23	08:00	28-Dec-23	18:00	Daily	1. Maintenance of ICT. 2. Measurement and alignment of Isolators. 2. Bay routine maintenance work.	MSETCL	MSETCL	1. During outage, 400KV ICT-1 & 220KV Chandrapur-2 will be in service.
90	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	29-Dec-23	08:00	29-Dec-23	18:00	Daily	1. Maintenance of ICT. 2. Measurement and alignment of Isolators. 2. Bay routine maintenance work.	MSETCL	MSETCL	1. During outage, 400KV ICT-1 & 220KV Chandrapur-2 will be in service.
91	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	29-Dec-23	08:00	29-Dec-23	18:00	Daily	Diagnostic testing and R&M Work	MSETCL	MSETCL	ICT-1 & ICT-2 will be in service
92	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	30-Dec-23	09:00	30-Dec-23	18:00	Daily	(1) Bushing & Winding Tan Delta testing work. (2) Bay maintenance work.	MSETCL	MSETCL	-
93	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	30-Dec-23	09:00	30-Dec-23	18:00	Daily	LV CB DCRM/timing and Quarterly bay maintenace work	MSETCL	MSETCL	315 MVA ICT I;501 MVA ICT III and IV will be in service